

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
4	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
5	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
6	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	402	
7	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	409	
8	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	428	
9	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	7	
13	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
14	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0	
15	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0	
16	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
17	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
18	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	General Comments		
19	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
20	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
21	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1208	
22	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1208	
23	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
24	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
25	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
26	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps B Phase V	0	
27	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps A Phase V	0	
28	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps C Ø	8	
29	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps B Ø	8	
30	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps A Ø	8	
31	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
32	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
33	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
34	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
35	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
36	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
37	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
38	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
39	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
40	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
41	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
42	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
43	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	529	
44	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	529	
45	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
46	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
47	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	General Comments		
48	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
49	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
50	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Unknown Operations	0	
51	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Switching Operations	0	
52	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations This Read Vac	2	
53	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AL	623	
54	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AF	623	
55	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Maintenance Operations	0	
56	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	General Comments		
57	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Follow-up Action Required?	n	
58	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations Ground	0	
59	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations C Ø	0	
60	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations B Ø	1	
61	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations A Ø	1	
62	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps C Phase V	0	
63	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps B Phase V	8	
64	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps A Phase V	8	
65	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps C Ø	328	
66	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps B Ø	388	
67	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps A Ø	363	
68	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
70	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations	28	
72	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	350	
73	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	400	
74	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	400	
75	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
78	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations	0	
79	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
80	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
81	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Follow-up Action Required?	n	
82	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	General Comments		
83	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Maintenance Operations	0	
84	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AF	67	
85	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AL	67	
86	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations This Read Vac	0	
87	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Switching Operations	0	
88	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Unknown Operations	0	
89	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
90	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1300	
91	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1300	
92	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
93	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
94	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	General Comments		
95	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
96	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
97	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0	
98	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0	
99	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0	
100	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	260	
101	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	260	
102	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	260	
103	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
104	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
105	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	General Comments		
106	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
107	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
108	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1217	
109	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1217	
110	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
111	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
112	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
113	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations Ground	0	
114	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations C Ø	0	
115	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
116	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	356	
117	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	356	
118	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
119	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
120	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
121	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
122	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
123	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
124	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
125	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
126	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
127	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
128	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	General Comments		
129	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	65	°C
130	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	60	°C
131	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	°C
132	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Present	60	°C
133	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
134	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
135	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
136	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	65	°C
137	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Max	65	°C
138	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Present	60	°C
139	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
140	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
141	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
142	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
143	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
144	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0	
145	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps C Phase V	0	
146	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations A Ø	0	
147	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations B Ø	0	
148	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	195	
149	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	195	
150	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
151	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
152	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
153	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
154	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	624.0	
155	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	620.0	
156	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	650.0	
157	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
158	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
159	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	1	
160	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
161	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
162	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	241	
163	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	241	
164	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
167	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
168	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
169	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
170	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
171	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
172	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
173	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	1	°C
174	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	°C
175	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	29	°C
176	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
177	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	0	°C
178	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	0	°C
179	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	29	°C
180	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Unknown Operations	0	
181	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Switching Operations	0	
182	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations This Read Vac	0	
183	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AL	30	
184	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AF	30	
185	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Maintenance Operations	0	
186	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	General Comments	na	
187	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Follow-up Action Required?	n	
188	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations Ground	0	
189	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations C Ø	0	
190	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations B Ø	0	
191	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations A Ø	0	
192	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps C Ø	147.0	
196	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps B Ø	131.0	
197	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps A Ø	135.0	
198	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	9 Month Operations	0	
202	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Unknown Operations	0	
203	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Switching Operations	0	
204	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations This Read Vac	0	
205	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AL	77	
206	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AF	77	
207	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Maintenance Operations	0	
208	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	General Comments	NA	
209	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Follow-up Action Required?	n	
210	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations Ground	0	
211	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations C Ø	0	
212	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations B Ø	0	
213	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations A Ø	0	
214	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps C Ø	70.0	
218	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps B Ø	82.0	
219	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps A Ø	81.0	
220	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
222	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
223	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	9 Month Operations	0	
224	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	80.0	
225	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	60.0	
226	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	60.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
227	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
228	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
229	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments	Actual counter	
230	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
231	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	6	
232	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	254	
233	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	254	
234	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
235	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
236	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
237	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
238	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	883	
239	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	883	
240	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	20	
241	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
242	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
243	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
244	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
245	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	160.0	
246	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	180.0	
247	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	180.0	
248	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	0	
249	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
250	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	580	
251	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
252	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
253	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
254	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
255	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
256	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	2	
257	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
258	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
259	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
260	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
261	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	400.0	
262	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	440.0	
263	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	480.0	
264	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
265	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
266	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
267	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	0	
268	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
269	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
270	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	23.92	%
271	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	27.1	%
272	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
273	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	220.0	
274	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	200.0	
275	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	180.0	
276	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	180.0	
277	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
278	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
279	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
280	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
281	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	1	
282	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	696	
283	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	696	
284	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
285	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
286	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	220.0	
287	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	210.0	
288	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
289	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
290	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
291	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
292	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
293	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
294	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	149	
295	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	149	
296	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
297	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
298	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
299	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
300	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
301	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
302	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
303	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
304	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
305	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
306	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	90.0	
307	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	90.0	
308	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	90.0	
309	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	22.32	%
310	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	30.29	%
311	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	29.5	%
312	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	17	
313	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
314	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	0	
315	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	154	
316	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	154	
317	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
318	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments		
319	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
320	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
321	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
322	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
323	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
324	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
325	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
326	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
327	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
328	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	75	
329	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	75	
330	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
331	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments	ok	
332	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
333	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	240.0	
334	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	240.0	
335	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
336	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	42.35	%
337	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	42.35	%
338	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	42.35	%
339	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
340	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
341	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
342	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
343	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
344	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
345	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
346	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
347	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
348	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
349	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
350	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments	Actual counter	
351	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
352	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	128	
353	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	128	
354	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
355	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
356	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	0	
357	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	26.31	%
358	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	23.92	%
359	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	23.92	%
360	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	120.0	
361	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	80.0	
362	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	50.0	
363	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
364	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
365	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
366	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
367	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
368	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
369	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
370	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
371	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments		
372	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
373	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	92	
374	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	92	
375	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	0	
376	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
377	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	260.0	
378	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
379	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
380	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
381	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	11.0	
382	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	0.0	
383	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	43.0	
384	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
385	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
386	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
387	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	3	
388	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
389	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
390	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
391	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	28	
392	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	580	
393	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Switching Operations	1	
394	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Unknown Operations	0	
395	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
396	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
397	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1317	
398	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1317	
399	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	3	
400	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
401	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments		
402	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
403	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
404	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	20.0	
405	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	40.0	
406	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	40.0	
407	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
408	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	4	
409	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	4	
410	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	173	
411	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
412	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
413	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
414	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
415	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments		
416	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
417	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
418	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	173	
419	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
420	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments	Actual counter	
421	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
422	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
423	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	160	°C
424	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
425	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	160	°C
426	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
427	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	100	°C
428	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
429	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
430	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
431	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	75	°C
432	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
433	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
434	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
435	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
436	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
437	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
438	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	75	°C
439	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
440	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
441	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
442	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
443	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
444	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
445	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
446	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
447	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
448	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
449	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
450	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
451	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
452	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
453	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
454	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
455	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	192.0	
456	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	179.0	
457	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations	1	
458	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
459	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
460	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
461	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps A Ø	0.0	
462	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps B Ø	0.0	
463	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps C Ø	0.0	
464	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
465	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
466	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
467	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations A Ø	0	
468	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations B Ø	0	
469	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations C Ø	0	
470	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations	4	
471	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
472	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
473	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
474	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps A Ø	282.0	
475	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps B Ø	297.0	
476	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps C Ø	288.0	
477	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations Ground	0	
478	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Follow-up Action Required?	n	
479	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	General Comments	NA	
480	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Maintenance Operations	0	
481	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AF	241	
482	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AL	241	
483	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations This Read Vac	1	
484	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Switching Operations	1	
485	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Unknown Operations	0	
486	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
487	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	3	
488	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	3	
489	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	189	
490	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	189	
491	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
492	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	General Comments	NA	
493	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
494	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
495	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
496	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
497	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
498	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
499	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
500	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
501	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
502	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
503	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
504	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
505	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
506	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
507	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
508	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
509	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
510	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
511	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
512	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
513	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
514	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
515	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
516	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	General Comments		
517	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Maintenance Operations	3	
518	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AF	203	
519	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AL	203	
520	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations This Read Vac	4	
521	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	47	°C
522	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	91	°C
523	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	47	°C
524	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	94	°C
525	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	47	°C
526	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	91	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
527	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
528	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
529	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	44	°C
530	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	75	°C
531	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
532	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
533	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
534	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	0	°C
535	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
536	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	6	
537	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
538	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments	Could not read all values, top oil max, H2 and X2 readings I could not get or reset counter. this was on Transformer Advantage 2	
539	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
540	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
541	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
542	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
543	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	195.0	
544	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	0	°C
545	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	0	°C
546	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	29	°C
547	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
548	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200	
549	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
550	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
551	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
552	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
553	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
554	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	
555	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
556	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
557	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
558	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
559	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
560	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	16	
561	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
562	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
563	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
564	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	124.0	
565	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	.1	
566	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.35	%
567	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	99.0	
568	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	120.0	
569	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	115.0	
570	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
571	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
572	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
573	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
574	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
575	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
576	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
577	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
578	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
579	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
580	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	134	
581	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	130.0	
582	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	50.96	%
583	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	63.1	%
584	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	33.97	%
585	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	42	
586	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
587	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
588	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	23	
589	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	957	
590	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	957	
591	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	24	
592	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
593	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
594	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
595	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
596	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
597	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
598	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
599	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	94.0	
600	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	7.2	%
601	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	11.64	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
677	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	79	
678	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1076	
679	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1076	
680	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
681	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
682	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
683	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	115.0	
684	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	112.0	
685	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	99.0	
686	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	18.2	%
687	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	43.68	%
688	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	40.04	%
689	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	48	
690	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	5	
691	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
692	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	520	
693	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	8L	
694	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	6R	
695	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	6L	
696	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	69573	
697	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	69573	
698	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		
699	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
700	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	906	
701	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	906	
702	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	6	
703	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
704	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
705	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	134	
706	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
707	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
708	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
709	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
710	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
711	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.56	%
712	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.92	%
713	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
714	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
715	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
716	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	15	
717	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	727	
718	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	727	
719	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	22	
720	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	General Comments		
721	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
722	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
723	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	53.0	
724	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	47.0	
725	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
726	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
727	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
728	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
729	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
730	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
731	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
732	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
733	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
734	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	23	
735	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
736	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
737	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
738	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	124	
739	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	124	
740	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
741	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
742	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
743	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
744	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
745	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
746	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
747	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
748	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
749	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
750	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
751	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.28	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
902	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
903	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	60	°C
904	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	80	°C
905	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	50	°C
906	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	80	°C
907	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
908	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	80	°C
909	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
910	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
911	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	12	
912	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	General Comments		
913	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
914	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
915	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
916	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
917	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
918	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	285	
919	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
920	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
921	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
922	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
923	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
924	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
925	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
926	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
927	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
928	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	333	
929	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	333	
930	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
931	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		
932	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
933	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
934	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
935	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
936	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	135.0	
937	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	105.0	
938	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	136.0	
939	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
940	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
941	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
942	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
943	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
944	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
945	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
946	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	n	
947	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments		
948	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
949	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	48	
950	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	48	
951	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
952	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
953	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
954	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	72	
955	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	0	
956	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
957	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
958	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
959	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
960	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
961	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1644	
962	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1644	
963	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	35	
964	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
965	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	General Comments		
966	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
967	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
968	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
969	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
970	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
971	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
972	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
973	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	19	
974	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1098	
975	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1098	
976	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	19	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
977	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
978	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
979	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
980	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	64	
981	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	64	
982	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
983	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
984	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
985	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
986	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	125.0	
987	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	136.0	
988	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	140.0	
989	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
990	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
991	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
992	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	1	
993	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	1	
994	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
995	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	
996	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	n	
997	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments		
998	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
999	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	71	
1000	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	71	
1001	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	2	
1002	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	0	
1003	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	0	
1004	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
1005	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1006	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	96.0	
1007	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	94.0	
1008	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1009	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1010	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1011	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
1012	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
1013	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
1014	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
1015	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
1016	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
1017	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
1018	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	72	
1019	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	18	
1020	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1021	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1022	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	49	
1023	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	67.06	%
1024	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	65.4	%
1025	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	62.63	%
1026	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	103.0	
1027	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	95.0	
1028	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	105.0	
1029	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1030	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1031	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1032	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
1033	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
1034	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
1035	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
1036	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
1037	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
1038	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
1039	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	165	
1040	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	165	
1041	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	4	
1042	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	4	
1043	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	
1044	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
1045	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
1046	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
1047	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	513	
1048	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	513	
1049	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1050	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1051	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	124.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1052	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	159.0	
1053	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	137.0	
1054	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	19.41	%
1055	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.41	%
1056	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.41	%
1057	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
1058	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1059	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1060	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1061	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	574	
1062	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	574	
1063	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
1064	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
1065	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
1066	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
1067	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
1068	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
1069	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
1070	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1071	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1072	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1073	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1074	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1075	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1076	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1077	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1192	
1078	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1192	
1079	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
1080	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
1081	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1082	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
1083	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
1084	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
1085	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
1086	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
1087	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	General Comments		
1088	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	18	
1089	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
1090	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
1091	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
1092	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
1093	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
1094	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1095	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1096	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1097	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	590.0	
1098	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	580.0	
1099	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	5	
1100	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
1101	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	1.03	%
1102	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1103	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	106.0	
1104	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	110.0	
1105	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	116.0	
1106	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1107	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1108	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1109	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
1110	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
1111	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
1112	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
1113	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
1114	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
1115	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
1116	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	274	
1117	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	274	
1118	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	1	
1119	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	1	
1120	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	1.15	%
1121	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	1.15	%
1122	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	580.0	
1123	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
1124	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	1	
1125	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
1126	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1127	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
1128	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	1	
1129	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	1	
1130	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	378	
1131	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	378	
1132	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
1133	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	14166.00	kw
1134	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	40	°C
1135	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	36	°C
1136	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1137	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.7870	
1138	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	7	
1139	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
1140	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
1141	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	45	°C
1142	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	40	°C
1143	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1144	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
1145	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
1146	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
1147	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1148	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	333.0	
1149	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	326.0	
1150	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	299.0	
1151	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1152	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1153	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1154	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
1155	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
1156	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
1157	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
1158	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
1159	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	1	
1160	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
1161	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
1162	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
1163	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
1164	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	205	
1165	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	205	
1166	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
1167	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
1168	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
1169	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	1	
1170	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	384	
1171	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	384	
1172	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
1173	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
1174	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
1175	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
1176	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
1177	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
1178	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
1179	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
1180	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1181	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1182	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1183	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	168.0	
1184	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	160.0	
1185	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	162.0	
1186	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
1187	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	5	
1188	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
1189	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
1190	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1191	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	773	
1192	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	2L	
1193	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	11L	
1194	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	7L	
1195	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	313258	
1196	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	313258	
1197	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments	corrected as left counter from 3132 to 313258	
1198	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	3.38	%
1199	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	3.38	%
1200	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	2	
1201	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AL	878	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1802	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps A Ø	123	
1803	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1804	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AF	174	
1805	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AL	174	
1806	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations This Read Vac	1	
1807	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1808	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1809	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations	41	
1810	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Unknown Operations	0	
1811	2/7/2019 11:07	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Switching Operations	1	
1812	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1813	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1814	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
1815	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
1816	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1657	
1817	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1657	
1818	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1819	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1820	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1821	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1822	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1823	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1824	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1825	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1826	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1038	
1827	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1038	
1828	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
1829	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
1830	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1831	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
1832	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.69	%
1833	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.46	%
1834	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.38	%
1835	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
1836	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
1837	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
1838	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1839	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1840	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1841	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1842	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
1843	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1844	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1845	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1846	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1847	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1848	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1849	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1850	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1851	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1852	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1853	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
1854	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
1855	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.84	%
1856	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.92	%
1857	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	4.84	%
1858	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
1859	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1860	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1861	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1862	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1863	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1864	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.6798	
1865	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1866	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	30	°C
1867	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	172	
1868	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	172	
1869	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1870	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1871	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1872	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	40	°C
1873	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	6526.08	kw
1874	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
1875	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
1876	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1877	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1878	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	17.26	
1879	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1880	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1881	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	4	
1882	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1883	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1884	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
1885	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
1886	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1887	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
1888	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments	changed 138102 to 238102: field verified	
1889	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	238099	
1890	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	238102	
1891	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	7L	
1892	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	16R	
1893	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	11L	
1894	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	609	
1895	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1896	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	27	
1897	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
1898	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
1899	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	2	
1900	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	199	
1901	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	199	
1902	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	1	
1903	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments	ok	
1904	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
1905	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
1906	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	1	
1907	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
1908	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
1909	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
1910	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1911	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1912	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	78.0	
1913	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	74.0	
1914	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	67.0	
1915	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	3.8	%
1916	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	3.8	%
1917	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	2.95	%
1918	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	3	
1919	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1920	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1921	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1922	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	10.0	
1923	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	10.0	
1924	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	10.0	
1925	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	.84	%
1926	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	.84	%
1927	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1928	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1929	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	.84	%
1930	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	3	
1931	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	10.0	
1932	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	10.0	
1933	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	0.0	
1934	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
1935	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	.84	%
1936	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	.84	%
1937	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	2	
1938	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1939	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	586	
1940	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	1L	
1941	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	3R	
1942	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
1943	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	1	
1944	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	149	
1945	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
1946	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
1947	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	
1948	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
1949	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	149	
1950	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
1951	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2252	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
2253	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	1	
2254	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2255	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2256	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	1	
2257	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	0	
2258	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	1	
2259	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
2260	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
2261	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
2262	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
2263	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	28.0	
2264	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	27.0	
2265	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	30.0	
2266	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2267	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	0	
2268	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2269	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
2270	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	1	
2271	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	0	
2272	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	1	
2273	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	93	
2274	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	93	
2275	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
2276	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments		
2277	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
2278	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
2279	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2280	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2281	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2282	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	0.0	
2283	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	0.0	
2284	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	0.0	
2285	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	14.70	
2286	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	14.70	
2287	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	14.70	
2288	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
2289	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
2290	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
2291	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
2292	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
2293	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
2294	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
2295	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
2296	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
2297	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
2298	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
2299	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
2300	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
2301	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
2302	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
2303	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
2304	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
2305	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
2306	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
2307	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
2308	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	600.0	
2309	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	600.0	
2310	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	550.0	
2311	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2312	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2313	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2314	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	2	
2315	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
2316	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
2317	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	0	
2318	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	314	
2319	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	314	
2320	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
2321	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments	Actual Counter	
2322	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
2323	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
2324	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments	ok	
2325	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
2326	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2327	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	62	
2328	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	62	
2329	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	0	
2330	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
2331	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
2332	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2333	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	1379	
2334	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	10L	
2335	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	2R	
2336	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	7L	
2337	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	27252	
2338	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	27252	
2339	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments	as left counter reading entered as 272252. should be 27252. Corrected 1/6/20	
2340	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	8	
2341	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	
2342	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
2343	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	9 Month Operations	11	
2344	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2345	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2346	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2347	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps A Ø	40.0	
2348	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps B Ø	50.0	
2349	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps C Ø	85.0	
2350	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps A Phase V	6.55	
2351	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2352	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2353	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations A Ø	1	
2354	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations B Ø	0	
2355	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations C Ø	0	
2356	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations Ground	0	
2357	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Follow-up Action Required?	n	
2358	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	General Comments		
2359	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Maintenance Operations	0	
2360	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AF	168	
2361	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AL	168	
2362	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations This Read Vac	1	
2363	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Switching Operations	0	
2364	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Unknown Operations	0	
2365	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2366	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
2367	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	60	°C
2368	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	70	°C
2369	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments	ok	
2370	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
2371	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2372	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2373	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	248	
2374	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	12L	
2375	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	2L	
2376	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	7L	
2377	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	35315	
2378	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	35305	
2379	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments	ok	
2380	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
2381	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2382	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
2383	7/25/2019 15:55	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
2384	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
2385	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
2386	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
2387	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Unknown Operations	0	
2388	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Switching Operations	0	
2389	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations This Read Vac	1	
2390	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AL	176	
2391	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AF	176	
2392	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
2393	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2394	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2395	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2396	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	115.0	
2397	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	110.0	
2398	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	105.0	
2399	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	2.44	%
2400	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
2401	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2402	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Maintenance Operations	0	
2403	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
2404	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
2405	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations Ground	0	
2406	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations C Ø	1	
2407	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
2408	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
2409	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
2410	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	184	
2411	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	184	
2412	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Operations This Read Vac	0	
2413	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Switching Operations	0	
2414	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
2415	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations B Ø	0	
2416	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations A Ø	0	
2417	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
2418	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2419	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2420	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps C Ø	40.0	
2421	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps B Ø	40.0	
2422	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps A Ø	45.0	
2423	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2424	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2425	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2426	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations	11	
2427	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
2428	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
2429	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
2430	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
2431	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
2432	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	511	
2433	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
2434	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2435	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
2436	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
2437	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2438	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
2439	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
2440	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
2441	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
2442	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.60	MegaWatts
2443	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.30	MegaVars
2444	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
2445	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	511	
2446	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
2447	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
2448	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
2449	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
2450	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
2451	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
2452	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2453	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2454	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2455	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	220.0	
2456	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	200.0	
2457	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	160.0	
2458	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
2459	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
2460	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2461	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
2462	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
2463	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
2464	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.10	MegaWatts
2465	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
2466	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
2467	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
2468	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	265	
2469	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2470	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
2471	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	0	
2472	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
2473	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
2474	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
2475	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
2476	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2477	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2478	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2479	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	200.0	
2480	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	230.0	
2481	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	230.0	
2482	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
2483	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
2484	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2485	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2486	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
2487	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
2488	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
2489	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
2490	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	360.0	
2491	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	220.0	
2492	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	190.0	
2493	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2494	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2495	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2496	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
2497	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
2498	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
2499	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
2500	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
2501	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
2502	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
2503	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	418	
2504	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	418	
2505	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
2506	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
2507	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
2508	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	0	
2509	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
2510	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
2511	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	2	
2512	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	2	
2513	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
2514	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
2515	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
2516	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
2517	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
2518	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	375	
2519	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	375	
2520	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
2521	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
2522	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
2523	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
2524	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
2525	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
2526	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
2527	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
2528	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
2529	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	240.0	
2530	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	290.0	
2531	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	310.0	
2532	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2533	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2534	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2535	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
2536	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
2537	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2538	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2539	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
2540	12/27/2019 14:00	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2541	12/27/2019 14:00	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
2542	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2543	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2544	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2545	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	9745	
2546	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	9745	
2547	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5R	
2548	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	14R	
2549	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2R	
2550	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
2551	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
2552	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	231	
2553	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2554	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2555	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
2556	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2557	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2558	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2559	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2560	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2561	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
2562	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2563	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
2564	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
2565	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	35	°C
2566	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	60	°C
2567	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
2568	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2569	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2570	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2571	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2572	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2573	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2574	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2575	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2576	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2577	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2578	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2579	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2580	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2581	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2582	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2583	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2584	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2585	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
2586	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2587	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2588	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2589	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
2590	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
2591	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2592	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2593	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2594	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2595	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2596	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2597	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2598	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2599	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2600	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2601	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2602	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2603	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2604	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2605	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2606	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2607	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2608	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2609	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2610	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2611	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2612	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2613	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	70.0	
2614	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	71.0	
2615	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2616	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2617	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
2618	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments		
2619	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
2620	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	128	
2621	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	128	
2622	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2623	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2624	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2625	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2626	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2627	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2628	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2629	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2630	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2631	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2632	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2633	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2634	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
2635	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2636	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2637	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
2638	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2639	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	80	°C
2640	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
2641	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
2642	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	45	°C
2643	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2644	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2645	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
2646	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
2647	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
2648	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2649	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2650	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2651	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2652	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2653	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2654	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2655	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2656	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2657	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
2658	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
2659	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
2660	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
2661	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
2662	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
2663	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2664	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2665	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	1	
2666	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2667	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2668	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2669	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
2670	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
2671	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
2672	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
2673	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
2674	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
2675	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
2676	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
2677	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
2678	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	182	
2679	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	182	
2680	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
2681	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2682	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2683	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2684	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2685	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
2686	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2687	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2688	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2689	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2690	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2691	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
2692	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2693	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
2694	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2695	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2696	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2697	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
2698	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
2699	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2700	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
2701	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2702	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2703	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2704	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
2705	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2706	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2707	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2708	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2709	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2710	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2711	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
2712	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
2713	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	0	
2714	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	149	
2715	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	149	
2716	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
2717	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
2718	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
2719	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	71.0	
2720	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2721	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2722	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2723	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2724	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
2725	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
2726	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
2727	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
2728	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
2729	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
2730	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2731	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2732	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
2733	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2734	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2735	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2736	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2737	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2738	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
2739	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2740	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2741	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2742	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
2743	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
2744	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
2745	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	187	
2746	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	187	
2747	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
2748	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
2749	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
2750	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
2751	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2752	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	102065	
2753	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	102065	
2754	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2755	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	1	
2756	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2757	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2758	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
2759	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2760	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2761	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2762	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	471.0	
2763	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	475.0	
2764	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	470.0	
2765	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2766	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2767	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2768	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2769	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2770	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments	Trip Hazard by TR 5 Pic sent to Stinson , Trench covers 4- 36X30.5 inch, and 2- 24X30 inch, the lights by Switchgear 5 and tr 5 don't wo	
2771	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
2772	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2773	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2774	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2775	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2776	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
2777	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2778	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
2779	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2780	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
2781	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2782	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2783	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2784	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2785	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2786	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
2787	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2788	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2789	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2790	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2791	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2792	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2793	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2794	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2795	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2796	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2797	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
2798	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2799	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2800	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2801	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2802	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2803	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2804	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2805	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2806	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2807	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2808	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	155	
2809	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
2810	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
2811	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
2812	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
2813	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
2814	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2815	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	0	
2816	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2817	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2818	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2819	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2820	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2821	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2822	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2823	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2824	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2825	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2826	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2827	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2828	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2829	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	693	
2830	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	*C
2831	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	52	*C
2832	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2833	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
2834	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2835	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
2836	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Broken	Need size info and qty
2837	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2838	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
2839	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
2840	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	13L	
2841	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	Neutral	
2842	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	11L	
2843	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2844	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	9111	
2845	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2846	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2847	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2848	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
2849	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2850	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
2851	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2852	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2853	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2854	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2855	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2856	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
2857	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	9111	
2858	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2859	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2860	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2861	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
2862	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2863	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2864	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2865	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	1	
2866	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	1	
2867	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2868	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2869	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2870	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
2871	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
2872	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
2873	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2874	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2875	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2876	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2877	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
2878	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	
2879	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
2880	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
2881	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
2882	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
2883	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
2884	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments		
2885	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
2886	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99968	
2887	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99968	
2888	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations This Read AM	0	
2889	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
2890	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
2891	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2892	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2893	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
2894	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2895	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2896	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2897	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
2898	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2899	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2900	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2901	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
2902	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2903	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2904	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2905	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2906	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2907	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2908	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2909	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2910	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2911	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
2912	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2913	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2914	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2915	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2916	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2917	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2918	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	35	°C
2919	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2920	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
2921	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2922	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
2923	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
2924	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
2925	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
2926	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2927	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
2928	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
2929	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
2930	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2931	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
2932	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
2933	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
2934	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
2935	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
2936	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
2937	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
2938	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
2939	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
2940	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2941	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2942	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
2943	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2944	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
2945	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
2946	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
2947	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
2948	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2949	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2950	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2951	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2952	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	631.0	
2953	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	623.0	
2954	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	645.0	
2955	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2956	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
2957	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
2958	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
2959	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	42	
2960	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	42	
2961	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
2962	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	0	
2963	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
2964	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
2965	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
2966	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
2967	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2968	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
2969	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
2970	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	166	
2971	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	166	
2972	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
2973	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
2974	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
2975	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
2976	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
2977	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
2978	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
2979	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
2980	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
2981	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2982	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2983	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2984	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2985	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	57.0	
2986	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	60.0	
2987	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	56.0	
2988	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2989	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2990	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
2991	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2992	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2993	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2994	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2995	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	88.0	
2996	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	87.0	
2997	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	85.0	
2998	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2999	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LTC0000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	OK	
3000	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3001	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3002	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3003	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
3004	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
3005	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3006	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
3007	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3008	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3009	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3010	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	0	
3011	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3012	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3013	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3014	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3015	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3016	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
3017	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
3018	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
3019	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3020	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
3021	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
3022	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
3023	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
3024	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
3025	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	173	
3026	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	173	
3027	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	0	
3028	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
3029	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3030	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
3031	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
3032	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
3033	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
3034	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
3035	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
3036	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
3037	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3038	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	0	
3039	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3040	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3041	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3042	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
3043	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
3044	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
3045	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3046	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3047	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3048	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3049	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
3050	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
3051	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
3052	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
3053	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
3054	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
3055	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
3056	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3057	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
3058	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
3059	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
3060	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3061	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3062	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3063	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3064	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3065	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3066	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3067	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3068	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3069	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
3070	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
3071	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	84	°C
3072	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	42	°C
3073	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	84	°C
3074	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	42	°C
3075	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	84	°C
3076	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	42	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3077	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
3078	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3079	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3080	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
3081	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3082	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3083	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3084	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	0	
3085	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3086	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3087	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
3088	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3089	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3090	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
3091	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
3092	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LTC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3093	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3094	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
3095	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3096	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3097	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3098	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3099	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3100	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3101	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3102	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3103	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments	HERE OR INFO CARDS ON CONRTROL HANDELS DO NOT CLOSE.	
3104	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3105	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3106	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
3107	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3108	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3109	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3110	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3111	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3112	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3113	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3114	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3115	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3116	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3117	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3118	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3119	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
3120	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3121	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3122	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3123	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
3124	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3125	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3126	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3127	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3128	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3129	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3130	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3131	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3132	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3133	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3134	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3135	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3136	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
3137	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3138	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3139	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3140	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
3141	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
3142	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
3143	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
3144	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3145	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
3146	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3147	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	38	°C
3148	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	75	°C
3149	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3150	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3151	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3152	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
3153	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
3154	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3155	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
3156	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
3157	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
3158	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3159	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3160	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3161	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3162	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3163	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3164	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3165	12/26/2019 11:10	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3166	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	0	*C
3167	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	Cant read oil temp guage	
3168	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	y	
3169	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3170	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	0	*C
3171	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
3172	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
3173	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	55	*C
3174	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	40	*C
3175	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC000597	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
3176	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC000597	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
3177	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LTC000597	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3178	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3179	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	293	
3180	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1L	
3181	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	10L	
3182	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
3183	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	37057	
3184	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	37057	
3185	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
3186	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
3187	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3188	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3189	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3190	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3191	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
3192	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3193	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3194	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3195	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
3196	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
3197	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3198	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3199	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3200	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3201	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3202	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3203	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
3204	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3205	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3206	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3207	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
3208	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3209	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3210	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3211	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3212	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
3213	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3214	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3215	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3216	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3217	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
3218	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3219	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3220	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3221	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3222	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3223	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
3224	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
3225	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
3226	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	64.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3227	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3228	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3229	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3230	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
3231	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
3232	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3233	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
3234	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3235	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
3236	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
3237	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments	Actual Counter	
3238	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
3239	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	424	
3240	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	424	
3241	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
3242	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
3243	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
3244	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3245	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3246	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
3247	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
3248	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3249	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3250	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3251	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
3252	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3253	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3254	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3255	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3256	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3257	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3258	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3259	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3260	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3261	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3262	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3263	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3264	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
3265	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
3266	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
3267	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
3268	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
3269	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
3270	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3271	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3272	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3273	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3274	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
3275	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3276	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3277	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
3278	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3279	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments		
3280	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3281	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3282	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3283	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3284	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3285	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3286	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3287	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3288	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3289	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3290	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3291	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
3292	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
3293	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
3294	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	242	
3295	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	242	
3296	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
3297	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
3298	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
3299	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3300	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3301	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3302	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3303	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3304	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
3305	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3306	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3307	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3308	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3309	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3310	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3311	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3312	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	221.0	
3313	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	215.0	
3314	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	231.0	
3315	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3316	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3317	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3318	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	3	
3319	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
3320	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
3321	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3322	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3323	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
3324	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
3325	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3326	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3327	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3328	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3329	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3330	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
3331	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3332	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3333	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
3334	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3335	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3336	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3337	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
3338	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3339	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3340	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3341	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
3342	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		If no, which cells in comments
3343	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3344	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
3345	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	
3346	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3347	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3348	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3349	12/23/2019 14:28	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3350	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	
3351	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3352	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	504	
3353	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	504	
3354	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3355	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3356	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3357	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3358	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3359	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	
3360	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	
3361	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	
3362	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3363	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3364	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3365	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3366	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3367	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3368	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3369	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3370	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3371	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3372	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3373	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3374	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	67.0	
3375	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	58.2	
3376	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
3377	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3378	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3379	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	6	
3380	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3381	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
3382	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	444	
3383	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	444	
3384	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
3385	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
3386	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
3387	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
3388	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
3389	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
3390	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3391	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3392	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3393	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3394	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
3395	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
3396	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
3397	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3398	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3399	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3400	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	32	
3401	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
3402	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
3403	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	0	
3404	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	727	
3405	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	727	
3406	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
3407	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
3408	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3409	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3410	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	149.0	
3411	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
3412	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3413	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3414	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3415	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3416	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
3417	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
3418	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
3419	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
3420	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
3421	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
3422	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
3423	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
3424	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3425	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3426	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3427	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3428	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments		
3429	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
3430	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3431	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3432	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3433	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3434	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
3435	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3436	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	
3437	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	0	
3438	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	0	
3439	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	0	
3440	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3441	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3442	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3443	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3444	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	90.0	
3445	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	80.0	
3446	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	90.0	
3447	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3448	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
3449	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	469	
3450	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	469	
3451	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3452	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	0	
3453	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
3454	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
3455	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	1	
3456	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3457	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3458	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3459	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
3460	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
3461	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
3462	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
3463	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
3464	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
3465	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3466	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3467	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
3468	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3469	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
3470	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	Not on site	
3471	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3472	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3473	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
3474	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
3475	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3476	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3477	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3478	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
3479	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
3480	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
3481	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3482	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3483	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3484	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3485	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3486	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3487	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3488	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3489	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3490	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3491	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
3492	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
3493	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
3494	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
3495	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
3496	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
3497	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3498	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3499	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3500	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3501	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
3502	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3503	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3504	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
3505	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
3506	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	97.0	
3507	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	146.0	
3508	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3509	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3510	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3511	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	11	
3512	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3513	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3514	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	2.10	MegaWatts
3515	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
3516	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	533	
3517	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	533	
3518	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
3519	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3520	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
3521	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
3522	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
3523	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3524	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
3525	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
3526	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3527	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
3528	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3529	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3530	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3531	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3532	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	280.0	
3533	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	250.0	
3534	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	380.0	
3535	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3536	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3537	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3538	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	
3539	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.40	MegaWatts
3540	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.30	MegaVars
3541	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.45	MegaVars
3542	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3543	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3544	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3545	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3546	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3547	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
3548	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
3549	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3550	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3551	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3552	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3553	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3554	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3555	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3556	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3557	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3558	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3559	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3560	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3561	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3562	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3563	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3564	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3565	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3566	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3567	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3568	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3569	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3570	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3571	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3572	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3573	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3574	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3575	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3576	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3577	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3578	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3579	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3580	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3581	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3582	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3583	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3584	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3585	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3586	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3587	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3588	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3589	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	104	
3590	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	104	
3591	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3592	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3593	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3594	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3595	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3596	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3597	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3598	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3599	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3600	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	350.0	
3601	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	350.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3602	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	350.0	
3603	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3604	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3605	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3606	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3607	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3608	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3609	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3610	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3611	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3612	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3613	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3614	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3615	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3616	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3617	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3618	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3619	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3620	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3621	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3622	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3623	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3624	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3625	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3626	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3627	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3628	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3629	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3630	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3631	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3632	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3633	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3634	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3635	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3636	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	118	
3637	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	118	
3638	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3639	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3640	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3641	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3642	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3643	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
3644	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3645	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3646	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3647	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3648	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3649	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3650	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3651	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3652	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3653	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3654	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3655	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3656	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3657	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3658	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3659	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3660	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3661	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3662	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3663	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3664	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3665	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3666	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3667	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3668	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3669	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3670	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3671	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3672	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3673	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3674	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3675	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3676	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3677	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3678	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3679	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3680	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3681	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3682	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3683	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3684	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3685	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3686	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3687	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	142	
3688	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	142	
3689	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3690	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3691	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3692	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3693	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3694	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3695	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3696	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	420.00	
3697	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	435.00	
3698	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3699	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3700	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
3701	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3702	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3703	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3704	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3705	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3706	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3707	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3708	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3709	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3710	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3711	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3712	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3713	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3714	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3715	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
3716	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
3717	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
3718	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	235.00	
3719	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3720	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3721	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	Not on site	
3722	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
3723	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3724	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
3725	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3726	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3727	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3728	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3729	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3730	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3731	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3732	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	6	
3733	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3734	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3735	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3736	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	11.0	
3737	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	11.0	
3738	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	11.0	
3739	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3740	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3741	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3742	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3743	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3744	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3745	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	113	
3746	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	113	
3747	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3748	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3749	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3750	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
3751	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3752	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3753	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3754	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3755	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3756	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3757	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
3758	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
3759	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
3760	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
3761	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3762	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
3763	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
3764	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
3765	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
3766	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
3767	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
3768	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
3769	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
3770	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
3771	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3772	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3773	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3774	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3775	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3776	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
3777	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
3778	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3779	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
3780	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
3781	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3782	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3783	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3784	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3785	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3786	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3787	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3788	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3789	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3790	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3791	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3792	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3793	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3794	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3795	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3796	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3797	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	115	
3798	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	115	
3799	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3800	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3801	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3802	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3803	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3804	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3805	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3806	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3807	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3808	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
3809	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	200.0	
3810	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
3811	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3812	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3813	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3814	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3815	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3816	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3817	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3818	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3819	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3820	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3821	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3822	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3823	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3824	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3825	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3826	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3827	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3828	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3829	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3830	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3831	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
3832	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3833	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3834	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
3835	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
3836	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3837	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
3838	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
3839	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
3840	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
3841	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
3842	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
3843	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3844	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
3845	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3846	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3847	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	234496	
3848	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3849	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3850	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
3851	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
3852	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3853	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
3854	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
3855	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3856	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3857	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3858	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3859	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3860	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3861	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3862	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3863	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3864	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3865	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3866	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3867	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3868	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3869	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3870	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3871	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3872	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3873	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3874	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3875	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	1	
3876	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3877	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3878	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3879	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
3880	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
3881	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
3882	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3883	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3884	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3885	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3886	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
3887	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
3888	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
3889	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
3890	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
3891	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
3892	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
3893	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
3894	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
3895	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
3896	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
3897	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
3898	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
3899	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
3900	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3901	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3902	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3903	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3904	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3905	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3906	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3907	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3908	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3909	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3910	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3911	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3912	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3913	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3914	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3915	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3916	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
3917	12/23/2019 14:28	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3918	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
3919	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3920	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3921	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3922	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3923	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3924	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3925	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3926	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3927	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3928	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3929	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3930	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
3931	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
3932	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
3933	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
3934	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
3935	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	General Comments		
3936	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
3937	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
3938	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
3939	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
3940	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99972	
3941	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99972	
3942	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
3943	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
3944	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
3945	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
3946	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
3947	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
3948	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
3949	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3950	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3951	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
3952	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3953	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3954	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3955	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	70.0	
3956	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
3957	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
3958	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3959	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3960	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3961	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3962	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3963	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3964	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3965	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3966	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3967	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3968	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3969	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3970	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
3971	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3972	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	15637	
3973	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	15637	
3974	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3975	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
3976	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3977	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3978	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3979	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	469	
3980	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	469	
3981	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3982	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3983	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3984	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
3985	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
3986	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3987	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1129	
3988	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3989	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3990	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3991	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3992	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3993	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3994	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
3995	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3996	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	234496	
3997	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	358	
3998	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	358	
3999	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
4000	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
4001	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
4002	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4003	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4004	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4005	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4006	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4007	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4008	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
4009	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
4010	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
4011	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
4012	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
4013	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
4014	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
4015	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
4016	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
4017	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
4018	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99978	
4019	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99978	
4020	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
4021	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
4022	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
4023	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
4024	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	General Comments		
4025	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
4026	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
4027	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
4028	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
4029	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
4030	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
4031	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
4032	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4033	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4034	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
4035	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
4036	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
4037	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
4038	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
4039	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
4040	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	215.00	
4041	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4042	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4043	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	Not on site	
4044	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
4045	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4046	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
4047	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4048	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4049	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4050	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4051	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4052	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4053	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4054	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4055	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4056	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4057	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
4058	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4059	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4060	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4061	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
4062	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
4063	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
4064	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
4065	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4066	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4067	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4068	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4069	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4070	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4071	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4072	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4073	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4074	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4075	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4076	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4077	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4078	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
4079	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4080	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4081	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4082	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4083	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4084	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4085	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
4086	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4087	12/23/2019 14:28	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4088	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
4089	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4090	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4091	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4092	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4093	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4094	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4095	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4096	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4097	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4098	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
4099	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4100	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4101	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4102	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4103	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4104	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4105	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
4106	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4107	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4108	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4109	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4110	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4111	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4112	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4113	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4114	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4115	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4116	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4117	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4118	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4119	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4120	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
4121	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4122	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4123	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1234	
4124	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4125	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4126	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4127	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4128	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	7	
4129	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4130	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4131	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4132	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	42.5	
4133	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	21.1	
4134	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	32.5	
4135	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4136	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4137	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4138	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4139	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
4140	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
4141	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
4142	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
4143	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
4144	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
4145	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
4146	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
4147	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
4148	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4149	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	7	
4150	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4151	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	75.0	
4152	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	75.0	
4153	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4154	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4155	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4156	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4157	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4158	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4159	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4160	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	103.0	
4161	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	138.0	
4162	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	105.0	
4163	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4164	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4165	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4166	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4167	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
4168	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
4169	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
4170	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
4171	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
4172	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
4173	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
4174	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
4175	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
4176	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	589	
4177	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	589	
4178	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	0	
4179	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
4180	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
4181	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4182	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
4183	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
4184	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
4185	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
4186	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
4187	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
4188	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4189	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
4190	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
4191	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
4192	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
4193	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
4194	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
4195	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
4196	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
4197	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
4198	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4199	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
4200	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
4201	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4202	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4203	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
4204	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4205	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4206	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4207	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	0	
4208	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	45.6	
4209	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4210	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4211	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4212	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4213	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
4214	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
4215	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
4216	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4217	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
4218	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
4219	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
4220	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4221	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
4222	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4223	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
4224	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
4225	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
4226	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4227	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
4228	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
4229	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
4230	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
4231	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4232	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4233	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4234	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4235	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
4236	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
4237	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
4238	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4239	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4240	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4241	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
4242	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4243	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4244	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4245	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4246	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4247	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4248	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
4249	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
4250	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
4251	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
4252	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
4253	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
4254	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	75.0	
4255	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4256	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
4257	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4258	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4259	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4260	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
4261	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
4262	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
4263	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4264	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4265	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4266	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4267	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4268	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
4269	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4270	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4271	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4272	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4273	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4274	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4275	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
4276	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4277	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
4278	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4279	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4280	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
4281	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
4282	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4283	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4284	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4285	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4286	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4287	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4288	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4289	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4290	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4291	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	370	
4292	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4293	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4294	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
4295	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
4296	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4297	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4298	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	50	°C
4299	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	25	°C
4300	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
4301	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
4302	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	25	°C
4303	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	50	°C
4304	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4305	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.100	millivolts
4306	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
4307	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC
4308	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.9	amps
4309	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4310	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4311	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
4312	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
4313	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4314	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4315	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4316	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4317	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4318	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
4319	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4320	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	425336	
4321	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	425336	
4322	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4323	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
4324	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
4325	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
4326	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4327	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	137	
4328	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4329	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4330	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4331	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4332	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
4333	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4334	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	141	
4335	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	141	
4336	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
4337	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4338	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
4339	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
4340	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
4341	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4342	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4343	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4344	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4345	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4346	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
4347	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
4348	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
4349	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
4350	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4351	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4352	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
4353	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
4354	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	430	
4355	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	430	
4356	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
4357	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
4358	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
4359	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Cabinet Door Seals OK?	y
4360	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Cabinet Internal Condition?	Clean
4361	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Equipment Properly Labeled?	y
4362	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Follow-up Action Required?	n
4363	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	General Comments	
4364	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Grounds in Place?	y
4365	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Heaters (All) Functioning?	y
4366	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Moisture and Leak Free?	y
4367	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Spring Compression Ind.	springcharged
4368	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Readings	9 Month Operations	2
4369	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Readings	Accumulated Fault Duty A Ph V	0.00 %
4370	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Readings	Accumulated Fault Duty B Ph V	0.00 %
4371	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Readings	Accumulated Fault Duty C Ph V	0.00 %
4372	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
4373	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
4374	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4375	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4376	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4377	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4378	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4379	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4380	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
4381	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4382	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4383	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4384	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Cabinet Door Seals OK?	y
4385	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Cabinet Internal Condition?	Clean
4386	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Equipment Properly Labeled?	y
4387	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Follow-up Action Required?	n
4388	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	General Comments	
4389	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Grounds in Place?	y
4390	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Heaters (All) Functioning?	y
4391	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Moisture and Leak Free?	y
4392	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	BreakerVacuum	VCB Patrol Inspection	Spring Compression Ind.	springcharged
4393	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
4394	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	90.0	
4395	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	100.0	
4396	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	90.0	
4397	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4398	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4399	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4400	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	11	
4401	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
4402	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	
4403	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	418	
4404	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4405	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4406	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4407	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
4408	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	418	
4409	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
4410	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4411	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
4412	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4413	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	26	
4414	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4415	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4416	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4417	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	140.0	
4418	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	90.0	
4419	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	90.0	
4420	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4421	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4422	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4423	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4424	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
4425	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
4426	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4427	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
4428	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
4429	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
4430	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
4431	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
4432	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
4433	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4434	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4435	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4436	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4437	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
4438	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4439	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
4440	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4441	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
4442	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4443	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4444	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4445	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4446	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4447	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4448	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4449	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4450	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4451	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4452	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4453	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4454	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4455	12/23/2019 14:28	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4456	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4457	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
4458	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
4459	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4460	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
4461	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4462	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4463	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
4464	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
4465	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
4466	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
4467	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4468	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
4469	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4470	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4471	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4472	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
4473	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
4474	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	467	
4475	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	467	
4476	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
4477	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4478	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
4479	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
4480	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
4481	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4482	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
4483	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
4484	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
4485	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
4486	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	1	
4487	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	488	
4488	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	488	
4489	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
4490	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4491	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments	B phase IOC	
4492	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
4493	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
4494	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4495	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
4496	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4497	12/23/2019 14:28	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
4498	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
4499	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
4500	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
4501	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	421	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
4502	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	421	
4503	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
4504	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4505	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
4506	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
4507	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
4508	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
4509	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
4510	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	1	
4511	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
4512	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4513	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
4514	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
4515	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
4516	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
4517	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
4518	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4519	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4520	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4521	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4522	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	50.0	
4523	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4524	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4525	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	260.0	
4526	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	250.0	
4527	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	200.0	
4528	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4529	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	10.67	%
4530	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
4531	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	10	
4532	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	8	
4533	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4534	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4535	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4536	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	57.9	
4537	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	28.5	
4538	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	50.0	
4539	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
4540	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4541	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
4542	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
4543	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		
4544	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4545	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
4546	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	412	
4547	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	412	
4548	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	0	
4549	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
4550	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
4551	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
4552	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
4553	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
4554	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
4555	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
4556	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
4557	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
4558	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
4559	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
4560	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
4561	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
4562	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4563	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
4564	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
4565	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
4566	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4567	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4568	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4569	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4570	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4571	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	50.0	
4572	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	50.0	
4573	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	50.0	
4574	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4575	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4576	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4577	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
4578	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
4579	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
4580	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
4581	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4582	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4583	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4584	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4585	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	50.0	
4586	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	130.0	
4587	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	100.0	
4588	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4589	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
4590	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
4591	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4592	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4593	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	0	
4594	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
4595	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4596	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4597	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	236	
4598	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	236	
4599	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4600	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
4601	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4602	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4603	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4604	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4605	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4606	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4607	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4608	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4609	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
4610	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4611	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
4612	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
4613	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
4614	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4615	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
4616	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4617	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
4618	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4619	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4620	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4621	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4622	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4623	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4624	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4625	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4626	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4627	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4628	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4629	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4630	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4631	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4632	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4633	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4634	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4635	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4636	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4637	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4638	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
4639	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4640	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
4641	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4642	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
4643	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4644	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4645	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4646	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4647	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	2.2	
4648	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	1.7	
4649	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	1.9	
4650	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4651	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
4652	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4653	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	13	
4654	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4655	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4656	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4657	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4658	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4659	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
4660	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
4661	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4662	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4663	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
4664	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.50	MegaWatts
4665	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.60	MegaVars
4666	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4667	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4668	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4669	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4670	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4671	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4672	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4673	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4674	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4675	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4676	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4677	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4678	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4679	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4680	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
4681	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4682	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4683	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
4684	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
4685	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
4686	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
4687	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
4688	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4689	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4690	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4691	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4692	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
4693	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
4694	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
4695	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4696	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
4697	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4698	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
4699	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
4700	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
4701	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
4702	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
4703	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
4704	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	435.00	
4705	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	420.00	
4706	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
4707	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
4708	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4709	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4710	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4711	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4712	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4713	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4714	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
4715	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4716	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
4717	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4718	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4719	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
4720	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
4721	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
4722	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
4723	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4724	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4725	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4726	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4727	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
4728	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
4729	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4730	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4731	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4732	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4733	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
4734	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
4735	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
4736	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
4737	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4738	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
4739	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
4740	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
4741	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
4742	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	692	
4743	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	692	
4744	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
4745	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4746	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4747	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
4748	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
4749	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
4750	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4751	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
4752	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
4753	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
4754	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
4755	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4756	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4757	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4758	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4759	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4760	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4761	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
4762	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
4763	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
4764	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4765	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4766	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4767	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
4768	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4769	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4770	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4771	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4772	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4773	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
4774	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4775	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
4776	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
4777	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4778	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4779	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	1	
4780	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4781	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
4782	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4783	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	100.0	
4784	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	190.0	
4785	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	150.0	
4786	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4787	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4788	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4789	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4790	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
4791	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
4792	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
4793	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
4794	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
4795	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
4796	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
4797	12/23/2019 14:28	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
4798	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
4799	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	145	
4800	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	145	
4801	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
4802	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4803	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4804	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4805	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4806	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4807	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4808	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4809	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4810	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4811	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4812	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4813	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4814	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4815	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4816	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4817	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4818	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4819	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4820	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4821	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
4822	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4823	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4824	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4825	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4826	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4827	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4828	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4829	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4830	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4831	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4832	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4833	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4834	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4835	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4836	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4837	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		
4838	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4839	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
4840	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
4841	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
4842	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
4843	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
4844	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
4845	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
4846	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
4847	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4848	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	370	
4849	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4850	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4851	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	.3	
4852	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	.4	
4853	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	.4	
4854	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4855	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4856	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4857	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4858	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
4859	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4860	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
4861	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
4862	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
4863	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
4864	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4865	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	5	
4866	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4867	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4868	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4869	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4870	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
4871	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4872	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4873	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4874	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
4875	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
4876	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4877	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
4878	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	348	
4879	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	348	
4880	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
4881	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
4882	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
4883	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4884	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4885	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
4886	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
4887	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
4888	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4889	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4890	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4891	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4892	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
4893	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4894	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4895	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4896	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
4897	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
4898	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4899	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4900	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4901	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4902	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4903	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4904	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
4905	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
4906	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
4907	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
4908	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4909	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
4910	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4911	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments		
4912	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4913	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4914	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4915	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4916	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4917	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4918	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4919	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4920	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4921	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4922	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4923	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4924	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4925	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4926	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4927	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4928	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4929	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
4930	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
4931	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
4932	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4933	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4934	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
4935	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
4936	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
4937	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
4938	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4939	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4940	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
4941	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
4942	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
4943	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4944	12/23/2019 10:08	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4945	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
4946	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4947	12/23/2019 14:28	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4948	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
4949	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4950	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4951	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4952	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4953	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4954	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
4955	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
4956	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4957	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4958	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4959	12/26/2019 12:41	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4960	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4961	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
4962	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
4963	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
4964	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	963	
4965	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
4966	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	check oil cup
4967	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	220.0	
4968	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	180.0	
4969	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	175.0	
4970	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4971	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4972	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4973	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4974	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
4975	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
4976	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4977	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4978	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4979	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4980	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
4981	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	
4982	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
4983	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
4984	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
4985	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
4986	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
4987	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	262	
4988	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	363	
4989	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
4990	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
4991	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
4992	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
4993	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
4994	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4995	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
4996	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	120	
4997	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	120	
4998	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations This Read Vac	0	
4999	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
5000	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
5001	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
5002	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
5003	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
5004	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
5005	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
5006	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
5007	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
5008	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
5009	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
5010	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
5011	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
5012	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
5013	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5014	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5015	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5016	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5017	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
5018	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
5019	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
5020	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
5021	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
5022	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
5023	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
5024	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments	open	
5025	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5026	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5027	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
5028	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
5029	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5030	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5031	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
5032	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
5033	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5034	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5035	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	250.0	
5036	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	260.0	
5037	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	270.0	
5038	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
5039	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
5040	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5041	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5042	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
5043	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
5044	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
5045	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
5046	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
5047	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
5048	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
5049	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
5050	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	88915	
5051	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	88915	
5052	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
5053	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
5054	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
5055	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
5056	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
5057	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
5058	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
5059	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
5060	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5061	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
5062	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	153	
5063	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	153	
5064	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
5065	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	961	
5066	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
5067	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
5068	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	6	
5069	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
5070	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
5071	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
5072	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	15.15	%
5073	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
5074	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	12.75	%
5075	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	170.0	
5076	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	100.0	
5077	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	150.0	
5078	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5079	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5080	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5081	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5082	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
5083	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
5084	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
5085	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
5086	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
5087	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
5088	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
5089	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
5090	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
5091	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	141	
5092	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	141	
5093	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
5094	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5095	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
5096	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
5097	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
5098	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
5099	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
5100	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
5101	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
5102	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
5103	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	0	
5104	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	399	
5105	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	399	
5106	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	32324	
5107	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	32324	
5108	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
5109	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
5110	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
5111	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
5112	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
5113	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	3	
5114	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	3	
5115	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	351	
5116	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	351	
5117	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
5118	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments	no targets	
5119	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
5120	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
5121	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
5122	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
5123	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
5124	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	0	
5125	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
5126	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
5127	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	0	
5128	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
5129	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
5130	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
5131	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	560.0	
5132	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	560.0	
5133	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	630.0	
5134	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
5135	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
5136	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
5137	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	13.48	%
5138	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	13.48	%
5139	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	13.48	%
5140	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
5141	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
5142	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
5143	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
5144	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
5145	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
5146	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
5147	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5148	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5149	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5150	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5151	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
5152	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
5153	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
5154	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
5155	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
5156	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5157	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5158	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5159	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5160	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	68.0	
5161	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	67.0	
5162	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	35.0	
5163	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	28.7	%
5164	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	30.29	%
5165	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	28.7	%
5166	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	16	
5167	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5168	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5169	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5170	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5171	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
5172	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	0	
5173	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	202	
5174	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	202	
5175	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
5176	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5177	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
5178	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
5179	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
5180	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
5181	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
5182	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
5183	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
5184	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
5185	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5186	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5187	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5188	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5189	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	45.0	
5190	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	40.0	
5191	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
5192	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
5193	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
5194	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
5195	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
5196	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
5197	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
5198	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
5199	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
5200	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
5201	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
5202	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
5203	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
5204	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
5205	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	60.0	
5206	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	34.35	%
5207	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	17.61	%
5208	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	13.11	%
5209	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	6	
5210	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
5211	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
5212	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
5213	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
5214	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
5215	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	14	
5216	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
5217	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
5218	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
5219	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	145	
5220	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	145	
5221	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
5222	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5223	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
5224	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
5225	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
5226	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
5227	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
5228	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
5229	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5230	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5231	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5232	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
5233	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
5234	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5235	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
5236	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
5237	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5238	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
5239	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5240	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
5241	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
5242	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5243	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5244	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
5245	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
5246	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
5247	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
5248	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5249	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5250	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5251	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5252	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	170.0	
5253	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	130.0	
5254	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	130.0	
5255	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	4.78	%
5256	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
5257	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
5258	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	2	
5259	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
5260	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
5261	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	566.0	
5262	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	560.0	
5263	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	565.0	
5264	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5265	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5266	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5267	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5268	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
5269	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
5270	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
5271	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
5272	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
5273	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
5274	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
5275	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
5276	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
5277	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
5278	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
5279	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
5280	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	223	
5281	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	223	
5282	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
5283	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
5284	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
5285	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
5286	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
5287	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
5288	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
5289	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
5290	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
5291	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
5292	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
5293	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
5294	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
5295	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
5296	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
5297	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
5298	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
5299	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
5300	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
5301	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
5302	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
5303	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
5304	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
5305	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
5306	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
5307	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
5308	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
5309	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5310	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5311	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5312	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5313	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5314	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
5315	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5316	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5317	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5318	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
5319	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
5320	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
5321	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5322	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
5323	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
5324	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
5325	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
5326	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5327	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
5328	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
5329	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
5330	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
5331	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
5332	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
5333	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
5334	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
5335	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
5336	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
5337	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
5338	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
5339	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments	open	
5340	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
5341	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	369	
5342	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	369	
5343	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
5344	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
5345	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
5346	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	0	
5347	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
5348	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
5349	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
5350	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
5351	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	0	
5352	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	343	
5353	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	343	
5354	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
5355	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
5356	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
5357	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
5358	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
5359	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
5360	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
5361	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
5362	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
5363	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5364	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5365	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5366	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5367	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	80.0	
5368	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	117.0	
5369	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	100.0	
5370	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
5371	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
5372	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
5373	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	1	
5374	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
5375	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5376	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
5377	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5378	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
5379	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	1	
5380	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
5381	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
5382	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5383	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5384	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
5385	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5386	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5387	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
5388	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
5389	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
5390	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
5391	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
5392	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
5393	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
5394	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
5395	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
5396	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
5397	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	14	°C
5398	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
5399	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5400	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
5401	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5402	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5403	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
5404	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
5405	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5406	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
5407	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5408	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	66	*C
5409	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	*C
5410	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5411	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	*C
5412	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	*C
5413	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
5414	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
5415	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5416	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	180.0	
5417	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	175.0	
5418	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	152	
5419	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	152	
5420	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	0	
5421	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
5422	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5423	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5424	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5425	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5426	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
5427	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
5428	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
5429	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
5430	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
5431	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
5432	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
5433	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	19.13	%
5434	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	*C
5435	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	220.0	
5436	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5437	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5438	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5439	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5440	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
5441	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	*C
5442	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
5443	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
5444	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
5445	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
5446	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
5447	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.2	VDC
5448	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.2	VDC
5449	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
5450	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
5451	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
5452	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
5453	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
5454	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
5455	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
5456	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
5457	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
5458	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
5459	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
5460	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
5461	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
5462	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
5463	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
5464	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
5465	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
5466	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
5467	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
5468	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
5469	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
5470	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
5471	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
5472	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
5473	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
5474	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
5475	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
5476	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5477	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
5478	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
5479	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
5480	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
5481	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5482	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
5483	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
5484	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5485	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
5486	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
5487	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5488	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
5489	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
5490	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
5491	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
5492	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
5493	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
5494	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
5495	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
5496	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
5497	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
5498	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
5499	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
5500	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5501	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5502	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5503	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
5504	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
5505	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
5506	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
5507	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5508	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
5509	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
5510	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
5511	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
5512	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
5513	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
5514	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
5515	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5516	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5517	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5518	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5519	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
5520	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
5521	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
5522	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
5523	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
5524	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
5525	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
5526	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
5527	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
5528	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
5529	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5530	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5531	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5532	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
5533	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5534	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps A Ø	0.0	
5535	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
5536	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
5537	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
5538	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
5539	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
5540	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps B Ø	0.0	
5541	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5542	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5543	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
5544	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
5545	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps C Ø	0.0	
5546	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5547	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5548	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5549	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5550	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5551	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5552	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
5553	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	10	°C
5554	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
5555	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
5556	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5557	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations A Ø	0	
5558	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations B Ø	0	
5559	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
5560	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
5561	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
5562	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
5563	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
5564	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
5565	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
5566	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
5567	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations C Ø	0	
5568	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations Ground	0	
5569	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
5570	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
5571	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
5572	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
5573	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
5574	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
5575	12/19/2019 12:13	Distribution	Muldrough Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5576	12/19/2019 12:13	Distribution	Muldrough Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5577	12/19/2019 12:13	Distribution	Muldrough Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
5578	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
5579	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5580	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	-.11	MegaVars
5581	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.63	MegaVars
5582	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	.79	MegaWatts
5583	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.02	MegaWatts
5584	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5585	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
5586	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
5587	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
5588	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5589	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	230.0	
5590	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	200.0	
5591	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	170.0	
5592	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
5593	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
5594	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
5595	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
5596	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
5597	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
5598	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
5599	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5600	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5601	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5602	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5603	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	1	
5604	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	140.0	
5605	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	150.0	
5606	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	180.0	
5607	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
5608	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
5609	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
5610	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
5611	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
5612	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
5613	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
5614	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
5615	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5616	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
5617	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
5618	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5619	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5620	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5621	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
5622	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
5623	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
5624	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
5625	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
5626	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5627	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
5628	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
5629	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
5630	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
5631	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
5632	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
5633	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
5634	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
5635	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
5636	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
5637	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
5638	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
5639	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
5640	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
5641	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
5642	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
5643	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
5644	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
5645	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
5646	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
5647	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5648	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
5649	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
5650	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5651	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5652	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5653	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
5654	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5655	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
5656	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
5657	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5658	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5659	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
5660	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
5661	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5662	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5663	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
5664	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
5665	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
5666	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
5667	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
5668	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
5669	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
5670	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
5671	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
5672	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
5673	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
5674	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
5675	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
5676	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
5677	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
5678	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
5679	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
5680	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
5681	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
5682	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	301	
5683	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	301	
5684	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
5685	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5686	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
5687	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
5688	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
5689	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	411	
5690	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	411	
5691	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
5692	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5693	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
5694	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
5695	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
5696	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
5697	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5698	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5699	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5700	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
5701	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5702	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
5703	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
5704	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5705	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
5706	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
5707	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
5708	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
5709	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
5710	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5711	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5712	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5713	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5714	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
5715	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
5716	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
5717	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
5718	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
5719	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
5720	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
5721	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
5722	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
5723	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
5724	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
5725	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
5726	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
5727	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
5728	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
5729	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
5730	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
5731	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5732	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
5733	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
5734	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
5735	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
5736	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
5737	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
5738	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
5739	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
5740	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5741	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5742	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5743	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5744	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	130.0	
5745	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	120.0	
5746	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	150.0	
5747	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
5748	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
5749	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
5750	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
5751	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
5752	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
5753	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
5754	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
5755	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
5756	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5757	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Maintenance Operations	0	
5758	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18463	
5759	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18463	
5760	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
5761	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Switching Operations	0	
5762	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Unknown Operations	0	
5763	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
5764	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
5765	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
5766	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
5767	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
5768	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
5769	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
5770	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
5771	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
5772	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
5773	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	26.03	%
5774	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	42.87	%
5775	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	35.22	%
5776	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	109.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
5777	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	153.0	
5778	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	122.0	
5779	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
5780	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
5781	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
5782	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
5783	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
5784	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
5785	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
5786	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
5787	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
5788	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
5789	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
5790	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
5791	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
5792	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
5793	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	312	
5794	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
5795	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
5796	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
5797	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
5798	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
5799	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
5800	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
5801	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	50.0	
5802	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	100.0	
5803	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	110.0	
5804	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5805	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5806	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5807	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5808	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
5809	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
5810	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
5811	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
5812	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
5813	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
5814	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
5815	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
5816	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5817	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
5818	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
5819	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
5820	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
5821	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
5822	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
5823	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
5824	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
5825	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
5826	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
5827	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
5828	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
5829	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
5830	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
5831	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
5832	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
5833	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
5834	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
5835	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
5836	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
5837	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
5838	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
5839	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
5840	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
5841	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
5842	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	247	
5843	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	247	
5844	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
5845	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
5846	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
5847	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
5848	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
5849	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
5850	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
5851	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
5852	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
5853	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
5854	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
5855	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
5856	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
5857	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
5858	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
5859	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
5860	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
5861	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
5862	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
5863	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
5864	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
5865	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
5866	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
5867	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
5868	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
5869	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
5870	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
5871	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
5872	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
5873	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
5874	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
5875	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	screw on desiccant filter	
5876	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	221066	
5877	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	221066	
5878	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
5879	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
5880	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	2	
5881	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
5882	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
5883	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
5884	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
5885	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
5886	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
5887	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
5888	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
5889	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
5890	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
5891	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
5892	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
5893	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
5894	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
5895	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
5896	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
5897	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
5898	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
5899	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
5900	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
5901	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
5902	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
5903	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
5904	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
5905	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
5906	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
5907	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
5908	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
5909	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
5910	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
5911	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
5912	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
5913	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
5914	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
5915	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
5916	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
5917	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
5918	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
5919	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
5920	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
5921	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
5922	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
5923	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
5924	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
5925	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
5926	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
5927	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
5928	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
5929	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
5930	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Switching Operations	0	
5931	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Unknown Operations	0	
5932	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5933	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
5934	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
5935	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
5936	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
5937	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
5938	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
5939	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
5940	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
5941	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
5942	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
5943	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
5944	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
5945	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
5946	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
5947	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
5948	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
5949	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
5950	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
5951	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
5952	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
5953	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
5954	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
5955	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
5956	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
5957	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
5958	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
5959	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
5960	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
5961	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
5962	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
5963	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
5964	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
5965	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
5966	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
5967	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps A Ø	0.0	
5968	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps B Ø	0.0	
5969	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps C Ø	0.0	
5970	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
5971	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
5972	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
5973	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
5974	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
5975	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
5976	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
5977	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations Ground	0	
5978	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
5979	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
5980	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
5981	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
5982	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
5983	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
5984	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
5985	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
5986	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
5987	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
5988	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
5989	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
5990	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
5991	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
5992	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
5993	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
5994	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
5995	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
5996	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
5997	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
5998	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
5999	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
6000	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
6001	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
6002	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
6003	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
6004	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
6005	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
6006	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
6007	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
6008	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
6009	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
6010	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
6011	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
6012	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
6013	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
6014	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
6015	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
6016	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
6017	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
6018	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
6019	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
6020	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
6021	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
6022	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
6023	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
6024	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
6025	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
6026	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
6027	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
6028	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
6029	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
6030	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
6031	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
6032	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
6033	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
6034	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
6035	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
6036	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
6037	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
6038	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
6039	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
6040	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
6041	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
6042	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
6043	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	4	
6044	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
6045	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
6046	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
6047	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Insp	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
6048	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
6049	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
6050	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
6051	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
6052	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	0	
6053	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
6054	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
6055	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
6056	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
6057	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
6058	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	167074	
6059	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	167074	
6060	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
6061	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
6062	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6063	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
6064	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
6065	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
6066	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	75.0	
6067	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
6068	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	280	
6069	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
6070	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
6071	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
6072	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
6073	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	25.0	
6074	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	50.0	
6075	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
6076	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
6077	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	317380	
6078	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	317380	
6079	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
6080	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
6081	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6082	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
6083	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
6084	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
6085	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
6086	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
6087	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
6088	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
6089	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
6090	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
6091	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
6092	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
6093	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
6094	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
6095	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
6096	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1065	
6097	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
6098	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
6099	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
6100	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
6101	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
6102	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
6103	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
6104	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
6105	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
6106	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
6107	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
6108	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
6109	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
6110	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
6111	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
6112	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
6113	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
6114	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6115	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
6116	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
6117	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
6118	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
6119	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
6120	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
6121	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	98260	
6122	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	98260	
6123	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
6124	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
6125	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
6126	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
6127	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
6128	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
6129	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
6130	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
6131	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
6132	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
6133	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	79	
6134	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
6135	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
6136	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
6137	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
6138	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
6139	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
6140	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
6141	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
6142	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
6143	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
6144	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
6145	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
6146	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
6147	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspec	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
6148	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	49.0	VDC
6149	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	49.0	VDC
6150	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
6151	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
6152	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
6153	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
6154	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
6155	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
6156	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
6157	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
6158	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
6159	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
6160	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	57	
6161	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
6162	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
6163	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
6164	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
6165	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
6166	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
6167	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6168	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
6169	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6170	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
6171	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
6172	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
6173	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
6174	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
6175	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
6176	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
6177	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
6178	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
6179	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
6180	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
6181	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
6182	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
6183	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
6184	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
6185	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
6186	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
6187	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	212908	
6188	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	212908	
6189	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
6190	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
6191	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6192	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
6193	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
6194	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
6195	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
6196	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	130.0	
6197	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	100.0	
6198	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	190.0	
6199	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
6200	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
6201	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
6202	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
6203	12/20/2019 13:10	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
6204	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
6205	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
6206	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
6207	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
6208	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
6209	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
6210	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
6211	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
6212	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
6213	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
6214	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
6215	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
6216	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
6217	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
6218	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
6219	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
6220	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
6221	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
6222	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
6223	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
6224	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
6225	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
6226	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	30	*F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6227	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
6228	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
6229	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
6230	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
6231	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
6232	12/19/2019 12:13	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
6233	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	3	
6234	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
6235	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
6236	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
6237	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
6238	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
6239	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
6240	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
6241	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
6242	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	if low,note cell #'s
6243	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
6244	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
6245	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	2.0	AMPS
6246	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6247	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
6248	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
6249	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
6250	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
6251	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
6252	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6253	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
6254	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6255	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
6256	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
6257	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
6258	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
6259	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
6260	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
6261	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
6262	12/20/2019 12:07	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
6263	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
6264	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
6265	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	
6266	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	311	
6267	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
6268	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
6269	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	311	
6270	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
6271	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
6272	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
6273	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
6274	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	430	
6275	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	430	
6276	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
6277	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
6278	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments	temp gauge will not reset	
6279	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
6280	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
6281	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
6282	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
6283	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
6284	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
6285	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
6286	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
6287	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
6288	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
6289	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
6290	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
6291	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
6292	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
6293	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
6294	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
6295	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
6296	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
6297	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
6298	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		
6299	12/19/2019 19:38	Distribution	Southern Baptist Seminary Quarterly Inspe	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
6300	12/19/2019 9:31	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
6301	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6302	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
6303	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6304	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	0	
6305	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
6306	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
6307	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
6308	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	0	
6309	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	164	
6310	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	164	
6311	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
6312	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
6313	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6314	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
6315	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
6316	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
6317	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
6318	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
6319	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
6320	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
6321	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	T/C oil level low.	
6322	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
6323	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6324	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
6325	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
6326	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
6327	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
6328	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
6329	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
6330	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
6331	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
6332	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
6333	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
6334	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	10	°C
6335	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
6336	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
6337	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
6338	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6339	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
6340	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6341	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
6342	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
6343	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6344	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
6345	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
6346	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
6347	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
6348	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
6349	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
6350	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
6351	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
6352	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
6353	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
6354	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6355	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6356	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7385	
6357	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
6358	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
6359	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
6360	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6361	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6362	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
6363	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
6364	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
6365	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments		
6366	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6367	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
6368	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
6369	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6370	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
6371	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6372	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6373	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6374	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6375	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
6376	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6377	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
6378	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6379	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6380	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7391	
6381	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
6382	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
6383	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
6384	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6385	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6386	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
6387	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
6388	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
6389	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments		
6390	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6391	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
6392	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
6393	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6394	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
6395	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6396	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
6397	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6398	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
6399	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
6400	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6401	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
6402	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
6403	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
6404	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
6405	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.7	VDC
6406	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
6407	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
6408	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
6409	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
6410	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
6411	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
6412	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
6413	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
6414	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
6415	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
6416	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	20.0	
6417	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	0.0	
6418	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	10.0	
6419	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6420	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
6421	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6422	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	10	
6423	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
6424	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
6425	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
6426	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
6427	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6428	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
6429	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
6430	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
6431	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
6432	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
6433	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
6434	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
6435	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
6436	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
6437	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
6438	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
6439	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
6440	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
6441	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
6442	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
6443	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
6444	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
6445	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6446	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
6447	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
6448	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
6449	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
6450	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
6451	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6452	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
6453	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments	oil temp gauge is not hooked up.	
6454	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
6455	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
6456	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	0	
6457	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
6458	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
6459	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
6460	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
6461	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
6462	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6463	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
6464	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6465	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
6466	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
6467	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
6468	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
6469	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
6470	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
6471	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
6472	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
6473	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
6474	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Heaters (All) Functioning?	y	
6475	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
6476	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
6477	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
6478	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
6479	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
6480	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
6481	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
6482	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
6483	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	1	
6484	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
6485	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6486	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
6487	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6488	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
6489	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
6490	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
6491	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
6492	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
6493	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
6494	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
6495	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	37.0	
6496	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	44.0	
6497	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6498	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
6499	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6500	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
6501	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
6502	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6503	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
6504	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
6505	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	49.0	
6506	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6507	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	2188.80	kw
6508	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
6509	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
6510	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	78	°C
6511	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	22	°C
6512	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6513	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
6514	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6515	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
6516	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
6517	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
6518	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6519	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
6520	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1560	
6521	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1560	
6522	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.4560	
6523	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
6524	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
6525	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	116.0	
6526	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	89.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6527	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	99.0	
6528	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6529	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
6530	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6531	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	2	
6532	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
6533	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
6534	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
6535	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
6536	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
6537	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
6538	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
6539	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
6540	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	General Comments		
6541	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
6542	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
6543	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1054	
6544	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
6545	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	16.19	
6546	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
6547	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6548	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	1	
6549	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	1	
6550	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
6551	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
6552	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
6553	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
6554	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
6555	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
6556	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
6557	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
6558	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Heaters (All) Functioning?	y	
6559	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	1	
6560	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
6561	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	202	
6562	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	202	
6563	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	3	
6564	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
6565	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
6566	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
6567	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
6568	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1054	
6569	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
6570	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
6571	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
6572	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
6573	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
6574	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
6575	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6576	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
6577	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
6578	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
6579	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
6580	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
6581	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
6582	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6583	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6584	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6585	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
6586	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	1	
6587	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	173	
6588	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	173	
6589	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
6590	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
6591	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6592	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
6593	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
6594	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6595	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
6596	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
6597	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
6598	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
6599	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6600	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6601	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
6602	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
6603	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
6604	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8360	
6605	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6606	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6607	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
6608	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
6609	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
6610	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6611	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6612	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6613	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6614	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
6615	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6616	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
6617	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
6618	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6619	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
6620	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
6621	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
6622	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
6623	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6624	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6625	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
6626	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
6627	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
6628	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7822	
6629	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6630	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6631	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
6632	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
6633	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6634	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
6635	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
6636	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
6637	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6638	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
6639	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5100	
6640	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
6641	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
6642	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
6643	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
6644	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
6645	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	-2	psi
6646	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
6647	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6648	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
6649	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6650	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
6651	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
6652	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
6653	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6654	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	2	
6655	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
6656	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
6657	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
6658	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
6659	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
6660	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
6661	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	General Comments	.	
6662	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
6663	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
6664	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
6665	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	70.0	
6666	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
6667	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6668	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
6669	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
6670	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
6671	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
6672	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
6673	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
6674	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
6675	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
6676	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6677	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
6678	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
6679	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
6680	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
6681	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
6682	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
6683	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
6684	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
6685	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
6686	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
6687	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
6688	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
6689	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
6690	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
6691	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
6692	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
6693	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
6694	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
6695	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
6696	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments		
6697	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments		
6698	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
6699	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
6700	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
6701	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1224.00	kw
6702	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
6703	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
6704	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
6705	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
6706	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6707	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
6708	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
6709	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
6710	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6711	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6712	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
6713	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
6714	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
6715	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8747	
6716	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6717	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6718	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
6719	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
6720	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
6721	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6722	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6723	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6724	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6725	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
6726	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	15R	
6727	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
6728	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6729	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6730	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
6731	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
6732	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
6733	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9369	
6734	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
6735	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6736	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
6737	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
6738	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
6739	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6740	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6741	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6742	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6743	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
6744	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6745	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
6746	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
6747	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6748	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
6749	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
6750	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
6751	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6752	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6753	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6754	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
6755	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
6756	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
6757	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9592	
6758	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
6759	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6760	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
6761	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
6762	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
6763	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
6764	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6765	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6766	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6767	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
6768	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6769	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
6770	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
6771	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6772	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
6773	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
6774	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
6775	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
6776	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
6777	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
6778	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
6779	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
6780	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1600	
6781	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
6782	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
6783	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
6784	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
6785	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
6786	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
6787	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
6788	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
6789	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	100.0	
6790	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	150.0	
6791	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
6792	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
6793	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
6794	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
6795	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
6796	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
6797	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
6798	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
6799	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
6800	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
6801	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
6802	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
6803	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
6804	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
6805	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
6806	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
6807	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	*F
6808	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
6809	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
6810	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
6811	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
6812	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
6813	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	223	
6814	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
6815	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
6816	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
6817	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
6818	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
6819	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	419339	
6820	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	419339	
6821	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
6822	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
6823	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6824	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
6825	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
6826	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6827	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
6828	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
6829	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
6830	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
6831	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
6832	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
6833	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
6834	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
6835	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
6836	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
6837	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
6838	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
6839	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
6840	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
6841	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
6842	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
6843	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
6844	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	240.0	
6845	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	180.0	
6846	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	150.0	
6847	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	7.47	%
6848	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
6849	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
6850	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	9	
6851	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
6852	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
6853	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	176	
6854	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	176	
6855	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
6856	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
6857	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
6858	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
6859	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
6860	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
6861	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
6862	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6863	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6864	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6865	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	171.0	
6866	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	172.0	
6867	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	168.0	
6868	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
6869	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
6870	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
6871	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	3	
6872	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
6873	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
6874	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
6875	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
6876	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
6877	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	General Comments		
6878	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
6879	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
6880	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1708	
6881	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1708	
6882	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
6883	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
6884	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6885	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
6886	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
6887	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
6888	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
6889	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
6890	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	General Comments		
6891	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC000819	LTCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
6892	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
6893	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10858	
6894	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
6895	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
6896	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
6897	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
6898	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	181.0	
6899	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	179.0	
6900	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	132.0	
6901	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6902	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
6903	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
6904	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
6905	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
6906	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
6907	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	2	
6908	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	0	
6909	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
6910	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6911	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6912	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
6913	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
6914	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
6915	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
6916	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments		
6917	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
6918	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
6919	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	201	
6920	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
6921	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
6922	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	6	
6923	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6924	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
6925	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6926	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	51.0	
6927	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	52.0	
6928	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	82.0	
6929	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
6930	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
6931	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
6932	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
6933	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
6934	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
6935	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
6936	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	LTC0000819	LTCControl	480-1	LTC Control Insp	All Connections OK?	y	
6937	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
6938	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
6939	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
6940	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	393	
6941	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	393	
6942	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
6943	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
6944	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
6945	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
6946	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
6947	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
6948	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
6949	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
6950	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
6951	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
6952	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
6953	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
6954	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
6955	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
6956	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
6957	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	Need size info and qty
6958	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
6959	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
6960	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
6961	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
6962	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
6963	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
6964	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
6965	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
6966	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps B Ø	500.0	
6967	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps C Ø	500.0	
6968	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6969	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6970	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6971	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
6972	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
6973	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
6974	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations Ground	0	
6975	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
6976	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
6977	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
6978	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
6979	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
6980	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	15	°C
6981	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
6982	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4662	
6983	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
6984	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
6985	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
6986	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
6987	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
6988	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
6989	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
6990	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
6991	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	13	°C
6992	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	13	°C
6993	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
6994	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
6995	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
6996	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
6997	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
6998	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
6999	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
7000	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
7001	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
7002	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
7003	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
7004	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
7005	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
7006	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
7007	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
7008	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
7009	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
7010	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
7011	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
7012	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
7013	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
7014	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6959	
7015	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
7016	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
7017	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations	20	
7018	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7019	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7020	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7021	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps A Ø	500.0	
7022	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
7023	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
7024	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
7025	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
7026	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
7027	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
7028	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
7029	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
7030	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments		
7031	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
7032	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
7033	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
7034	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
7035	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
7036	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
7037	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
7038	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
7039	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
7040	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
7041	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	1	
7042	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
7043	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
7044	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
7045	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	400.0	
7046	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	410.0	
7047	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	410.0	
7048	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7049	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7050	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7051	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7052	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
7053	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
7054	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
7055	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
7056	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
7057	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
7058	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	322	
7059	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	322	
7060	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
7061	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
7062	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	71	
7063	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7064	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7065	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7066	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	50.0	
7067	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	50.0	
7068	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	80.0	
7069	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7070	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7071	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7072	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
7073	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
7074	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.7	VDC
7075	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
7076	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
7077	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
7078	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments		
7079	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
7080	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
7081	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
7082	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
7083	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
7084	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
7085	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	412	
7086	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	412	
7087	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	6	
7088	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	6	
7089	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
7090	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
7091	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
7092	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
7093	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
7094	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
7095	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
7096	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
7097	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
7098	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
7099	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
7100	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
7101	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
7102	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
7103	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments	..	
7104	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
7105	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	343	
7106	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	343	
7107	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	13	
7108	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	13	
7109	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7110	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7111	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
7112	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	90.0	
7113	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
7114	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
7115	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1600	
7116	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
7117	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
7118	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
7119	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
7120	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
7121	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
7122	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
7123	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
7124	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
7125	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
7126	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7127	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
7128	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
7129	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
7130	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
7131	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
7132	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
7133	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
7134	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
7135	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
7136	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
7137	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
7138	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
7139	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
7140	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
7141	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
7142	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
7143	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
7144	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
7145	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
7146	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
7147	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
7148	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
7149	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4475.52	kw
7150	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
7151	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
7152	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
7153	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
7154	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
7155	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
7156	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
7157	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
7158	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
7159	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
7160	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
7161	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
7162	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
7163	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
7164	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
7165	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
7166	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
7167	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
7168	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
7169	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
7170	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
7171	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
7172	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
7173	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
7174	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
7175	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
7176	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
7177	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
7178	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
7179	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
7180	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
7181	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
7182	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
7183	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
7184	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
7185	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
7186	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	0	
7187	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	.21	%
7188	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
7189	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	.42	%
7190	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	132.0	
7191	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	128.0	
7192	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	138.0	
7193	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7194	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7195	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7196	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
7197	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
7198	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
7199	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
7200	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
7201	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7202	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
7203	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
7204	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
7205	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
7206	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	206	
7207	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	206	
7208	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
7209	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
7210	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
7211	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
7212	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
7213	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
7214	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
7215	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	20	°C
7216	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
7217	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
7218	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
7219	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
7220	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
7221	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
7222	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
7223	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
7224	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
7225	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
7226	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
7227	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
7228	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
7229	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7230	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7231	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7232	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	88.0	
7233	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	87.0	
7234	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	87.0	
7235	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	7.16	%
7236	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	8.94	%
7237	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	7.75	%
7238	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	10	
7239	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
7240	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	230.0	
7241	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7242	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7243	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7244	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
7245	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
7246	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
7247	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
7248	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
7249	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments	hold#3660	
7250	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
7251	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	200	
7252	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	200	
7253	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	2	
7254	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	2	
7255	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
7256	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
7257	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
7258	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
7259	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
7260	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409413	
7261	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409413	
7262	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
7263	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
7264	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
7265	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
7266	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
7267	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	12	
7268	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
7269	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
7270	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
7271	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
7272	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
7273	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
7274	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
7275	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
7276	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
7277	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
7278	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
7279	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
7280	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
7281	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
7282	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
7283	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
7284	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
7285	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
7286	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
7287	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
7288	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
7289	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
7290	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
7291	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
7292	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
7293	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
7294	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
7295	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
7296	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
7297	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
7298	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
7299	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
7300	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
7301	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
7302	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
7303	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
7304	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
7305	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
7306	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
7307	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
7308	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
7309	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
7310	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
7311	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	16	*C
7312	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	32	*C
7313	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	120.00	
7314	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	125.00	
7315	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
7316	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
7317	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
7318	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
7319	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	3	
7320	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
7321	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
7322	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	4	
7323	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	214	
7324	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	214	
7325	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
7326	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	0	
7327	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
7328	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
7329	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
7330	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
7331	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
7332	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
7333	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
7334	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	1	
7335	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
7336	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
7337	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
7338	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
7339	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
7340	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
7341	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
7342	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
7343	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
7344	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
7345	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
7346	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
7347	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
7348	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
7349	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
7350	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
7351	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
7352	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
7353	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
7354	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
7355	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments	..	
7356	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
7357	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
7358	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1866	
7359	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1866	
7360	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
7361	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
7362	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
7363	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
7364	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
7365	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
7366	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
7367	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
7368	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
7369	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
7370	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
7371	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
7372	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
7373	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
7374	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
7375	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
7376	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
7377	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
7378	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
7379	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
7380	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
7381	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
7382	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
7383	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
7384	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
7385	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
7386	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
7387	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
7388	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
7389	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
7390	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
7391	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
7392	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
7393	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
7394	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
7395	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
7396	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
7397	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
7398	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
7399	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
7400	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
7401	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
7402	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
7403	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
7404	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
7405	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments		
7406	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
7407	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
7408	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
7409	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
7410	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
7411	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
7412	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
7413	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments		
7414	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
7415	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
7416	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
7417	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
7418	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
7419	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments		
7420	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
7421	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
7422	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	6	
7423	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
7424	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
7425	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
7426	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7427	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7428	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7429	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7430	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
7431	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	32.38	
7432	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	32.38	
7433	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	32.38	
7434	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
7435	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
7436	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
7437	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	2	
7438	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
7439	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
7440	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
7441	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
7442	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
7443	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
7444	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
7445	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	0	
7446	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
7447	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	170	
7448	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	170	
7449	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	2	
7450	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
7451	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
7452	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
7453	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
7454	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
7455	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
7456	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
7457	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
7458	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
7459	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
7460	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
7461	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
7462	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
7463	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
7464	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
7465	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
7466	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
7467	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	906	
7468	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	906	
7469	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
7470	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
7471	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	General Comments		
7472	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
7473	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
7474	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	750.0	
7475	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	750.0	
7476	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	750.0	
7477	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
7478	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
7479	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
7480	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	204	
7481	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	204	
7482	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
7483	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments	Actual Counter, Current readout is acting up sent video to stinson	
7484	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
7485	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
7486	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
7487	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
7488	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	7	
7489	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7490	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7491	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7492	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	40.0	
7493	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	30.0	
7494	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	40.0	
7495	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
7496	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
7497	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
7498	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7499	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7500	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7501	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
7502	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
7503	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
7504	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7505	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7506	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7507	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	6	
7508	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
7509	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
7510	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
7511	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
7512	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
7513	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
7514	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
7515	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	515	
7516	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	515	
7517	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	1	
7518	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	1	
7519	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
7520	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
7521	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
7522	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
7523	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
7524	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
7525	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
7526	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
7527	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
7528	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
7529	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments		
7530	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
7531	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
7532	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
7533	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
7534	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
7535	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
7536	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	11	*C
7537	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	30	*C
7538	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
7539	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	221.67	
7540	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
7541	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
7542	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
7543	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
7544	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
7545	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
7546	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
7547	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
7548	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
7549	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
7550	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
7551	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
7552	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	1	
7553	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	1	
7554	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	215	
7555	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	215	
7556	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
7557	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments	..	
7558	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
7559	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
7560	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
7561	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	4	
7562	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
7563	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
7564	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	4.77	%
7565	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	220.0	
7566	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	220.0	
7567	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
7568	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
7569	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
7570	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
7571	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
7572	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
7573	12/18/2019 9:42	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
7574	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
7575	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
7576	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
7577	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
7578	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
7579	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
7580	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
7581	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
7582	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
7583	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
7584	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
7585	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
7586	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
7587	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
7588	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
7589	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
7590	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
7591	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
7592	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
7593	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
7594	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
7595	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
7596	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
7597	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
7598	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
7599	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
7600	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
7601	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
7602	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
7603	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
7604	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
7605	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
7606	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
7607	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	3.58	%
7608	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	3.58	%
7609	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	3.58	%
7610	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
7611	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
7612	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
7613	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
7614	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
7615	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
7616	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	315.0	
7617	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	315.0	
7618	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	290.0	
7619	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7620	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7621	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7622	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
7623	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
7624	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
7625	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
7626	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
7627	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	General Comments		
7628	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
7629	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	23	
7630	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2381	
7631	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2381	
7632	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
7633	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
7634	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
7635	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
7636	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
7637	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
7638	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
7639	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
7640	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	4	
7641	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.2	%
7642	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.2	%
7643	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.2	%
7644	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	150.0	
7645	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	180.0	
7646	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	240.0	
7647	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
7648	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7649	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7650	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
7651	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7652	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
7653	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
7654	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
7655	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
7656	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
7657	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
7658	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
7659	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
7660	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
7661	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	391	
7662	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	391	
7663	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
7664	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
7665	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
7666	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	159	
7667	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
7668	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
7669	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
7670	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments		
7671	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		
7672	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
7673	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
7674	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
7675	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
7676	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
7677	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
7678	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
7679	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
7680	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
7681	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
7682	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
7683	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	45.20	
7684	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	45.20	
7685	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	45.20	
7686	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
7687	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
7688	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
7689	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
7690	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
7691	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
7692	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
7693	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
7694	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
7695	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
7696	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
7697	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
7698	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
7699	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
7700	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
7701	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7702	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
7703	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
7704	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
7705	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	78.0	
7706	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	112.0	
7707	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	110.0	
7708	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7709	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
7710	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
7711	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
7712	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
7713	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7714	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7715	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	5	
7716	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
7717	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
7718	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
7719	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	0	
7720	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	171	
7721	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	171	
7722	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
7723	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
7724	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
7725	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
7726	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7727	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
7728	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
7729	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
7730	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
7731	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
7732	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
7733	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
7734	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7735	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7736	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7737	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
7738	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7739	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7740	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
7741	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
7742	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
7743	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
7744	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
7745	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
7746	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
7747	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	31	
7748	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	845	
7749	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	845	
7750	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
7751	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
7752	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
7753	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
7754	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	0	
7755	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
7756	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	255	
7757	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	255	
7758	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	2	
7759	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
7760	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
7761	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
7762	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
7763	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
7764	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7765	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7766	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
7767	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
7768	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
7769	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
7770	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
7771	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
7772	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
7773	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
7774	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
7775	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
7776	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
7777	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
7778	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
7779	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
7780	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
7781	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
7782	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
7783	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	2	
7784	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
7785	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
7786	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	21	
7787	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7788	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7789	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7790	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	120.0	
7791	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	60.0	
7792	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	120.0	
7793	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
7794	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
7795	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
7796	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7797	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7798	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7799	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
7800	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
7801	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7802	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
7803	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
7804	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
7805	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	27	*F
7806	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
7807	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
7808	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
7809	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
7810	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
7811	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
7812	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
7813	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7814	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7815	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7816	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
7817	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
7818	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
7819	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7820	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	89.0	
7821	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	127.0	
7822	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	83.0	
7823	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7824	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7825	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7826	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	5	
7827	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
7828	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	3	
7829	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7830	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7831	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7832	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	130.0	
7833	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	140.0	
7834	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	110.0	
7835	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
7836	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
7837	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
7838	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
7839	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7840	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7841	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
7842	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	32.38	
7843	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	32.38	
7844	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	32.38	
7845	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
7846	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
7847	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
7848	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
7849	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
7850	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
7851	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
7852	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
7853	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
7854	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
7855	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
7856	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
7857	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
7858	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
7859	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
7860	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
7861	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
7862	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
7863	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
7864	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
7865	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
7866	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
7867	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
7868	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7869	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
7870	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	
7871	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	
7872	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
7873	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	
7874	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments	..	
7875	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
7876	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	402	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7877	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	402	
7878	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	1	
7879	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	1	
7880	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
7881	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
7882	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
7883	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
7884	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	566	
7885	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	566	
7886	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
7887	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
7888	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
7889	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
7890	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
7891	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
7892	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
7893	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
7894	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
7895	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
7896	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
7897	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7898	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7899	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
7900	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	190.0	
7901	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	170.0	
7902	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	150.0	
7903	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	12.81	%
7904	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	11.74	%
7905	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
7906	12/18/2019 11:12	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	3	
7907	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
7908	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
7909	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
7910	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
7911	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
7912	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
7913	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
7914	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
7915	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
7916	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
7917	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
7918	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
7919	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
7920	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
7921	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
7922	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
7923	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
7924	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
7925	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
7926	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
7927	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
7928	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
7929	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
7930	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
7931	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
7932	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
7933	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
7934	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	20	°C
7935	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	37	°C
7936	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
7937	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
7938	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
7939	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
7940	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
7941	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
7942	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
7943	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
7944	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
7945	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
7946	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
7947	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
7948	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
7949	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
7950	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
7951	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7952	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
7953	12/18/2019 8:01	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
7954	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	12	
7955	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7956	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7957	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7958	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	140.0	
7959	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	120.0	
7960	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	140.0	
7961	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7962	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7963	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
7964	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
7965	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
7966	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
7967	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	689732	
7968	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	689738	
7969	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
7970	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	2R	
7971	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	1L	
7972	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	5L	
7973	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	717	
7974	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
7975	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	45.20	
7976	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	45.20	
7977	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
7978	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
7979	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
7980	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
7981	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
7982	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
7983	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
7984	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
7985	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
7986	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
7987	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
7988	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
7989	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
7990	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
7991	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
7992	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
7993	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
7994	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
7995	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
7996	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
7997	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
7998	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
7999	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8000	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
8001	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	3	
8002	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	159	
8003	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8004	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
8005	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8006	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8007	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8008	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8009	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8010	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8011	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8012	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8013	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8014	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8015	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8016	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8017	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8018	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8019	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
8020	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
8021	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8022	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
8023	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8024	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8025	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8026	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8027	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8028	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8029	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8030	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8031	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
8032	12/18/2019 10:28	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8033	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8034	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments		
8035	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8036	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
8037	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
8038	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8039	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8040	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8041	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
8042	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
8043	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
8044	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
8045	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
8046	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
8047	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
8048	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	213	
8049	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	213	
8050	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
8051	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
8052	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
8053	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
8054	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
8055	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
8056	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	1	
8057	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
8058	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	48.57	
8059	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	64.76	
8060	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	48.57	
8061	12/18/2019 10:54	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8062	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	3	
8063	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
8064	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
8065	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	3	
8066	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	187	
8067	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	187	
8068	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
8069	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
8070	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
8071	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
8072	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
8073	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
8074	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
8075	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
8076	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
8077	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
8078	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
8079	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
8080	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	3	
8081	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
8082	12/18/2019 11:58	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	45.20	
8083	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8084	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
8085	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8086	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8087	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8088	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8089	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8090	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8091	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
8092	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8093	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8094	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8095	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8096	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8097	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8098	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8099	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8100	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
8101	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8102	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
8103	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8104	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8105	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
8106	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8107	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
8108	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	97277	
8109	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8110	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments		
8111	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments	Not energized	
8112	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	161	
8113	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	161	
8114	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8115	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
8116	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8117	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8118	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8119	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8120	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8121	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
8122	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8123	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8124	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8125	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8126	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments		
8127	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8128	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
8129	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
8130	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	Neutral	
8131	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	Neutral	
8132	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	Neutral	
8133	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	0	
8134	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8135	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8136	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8137	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9990	
8138	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8139	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8140	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8141	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8142	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8143	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
8144	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31102	
8145	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8146	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8147	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8148	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8149	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8150	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8151	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8152	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8153	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8154	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8155	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments		
8156	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8157	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
8158	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8159	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9590.40	kw
8160	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
8161	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8162	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
8163	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	48	°C
8164	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8165	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8166	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8167	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8168	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8169	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8170	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
8171	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
8172	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8173	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8174	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
8175	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
8176	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8177	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8178	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8179	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8180	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8181	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8182	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8183	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8184	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8185	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8186	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8187	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8188	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8189	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8190	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
8191	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8192	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8193	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8194	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
8195	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8196	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8197	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
8198	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8199	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8200	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8201	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
8202	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	21	°C
8203	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
8204	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	21	°C
8205	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	51	°C
8206	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	21	°C
8207	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8208	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8209	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8210	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	32501	
8211	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
8212	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8213	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8214	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8215	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8216	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
8217	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
8218	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8219	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments		
8220	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8221	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8222	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8223	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8224	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
8225	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8226	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8227	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8228	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8229	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8230	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8231	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8232	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
8233	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8234	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8235	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8236	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8237	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8238	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8239	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8240	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8241	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8242	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
8243	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8244	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8245	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8246	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8247	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8248	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8249	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8250	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8251	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8252	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8253	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8254	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8255	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
8256	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8257	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8258	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
8259	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
8260	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8261	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8262	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8263	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
8264	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	51	°C
8265	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	21	°C
8266	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8267	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8268	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8269	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8270	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8271	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8272	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8273	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8274	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8275	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments		
8276	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8277	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
8278	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
8279	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8280	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8281	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8282	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
8283	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
8284	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30704	
8285	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8286	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8287	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	5264.64	kw
8288	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8289	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
8290	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments		
8291	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8292	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8293	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
8294	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8295	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8296	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8297	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8298	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8299	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8300	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8301	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8302	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8303	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8304	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8305	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8306	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
8307	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8308	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8309	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8310	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8311	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		
8312	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8313	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
8314	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
8315	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8316	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8317	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8318	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8319	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
8320	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	75657	
8321	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8322	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8323	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8324	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8325	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8326	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8327	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8328	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8329	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
8330	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8331	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8332	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8333	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
8334	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8335	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8336	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8337	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8338	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8339	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8340	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8341	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8342	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8343	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8344	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	590	
8345	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	4L	
8346	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	1R	
8347	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	2R	
8348	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8349	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	6963	
8350	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	6954	
8351	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
8352	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments		
8353	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8354	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
8355	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
8356	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8357	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.5484	
8358	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8359	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8360	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8361	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8362	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8363	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8364	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8365	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8366	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	30	°C
8367	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	55	°C
8368	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
8369	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8370	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8371	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8372	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8373	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8374	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8375	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8376	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
8377	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
8378	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8379	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8380	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8381	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8382	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8383	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8384	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8385	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments		
8386	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7542	
8387	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
8388	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8389	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8390	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8391	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8392	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8393	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8394	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8395	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
8396	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
8397	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8398	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
8399	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	905.04	
8400	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	kw
8401	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8402	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8403	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
8404	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
8405	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8406	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8407	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
8408	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8409	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8410	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8411	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8412	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8413	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8414	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8415	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
8416	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8417	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8418	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8419	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8420	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8421	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8422	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8423	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8424	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
8425	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8426	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
8427	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
8428	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8429	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8430	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8431	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8432	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
8433	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	174740	
8434	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8435	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8436	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8437	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	2	
8438	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8439	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8440	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8441	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	91.0	
8442	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	114.0	
8443	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	103.0	
8444	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8445	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8446	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8447	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8448	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
8449	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
8450	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
8451	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
8452	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8453	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8454	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
8455	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
8456	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
8457	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
8458	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8459	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8460	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8461	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8462	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
8463	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	343	
8464	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	343	
8465	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
8466	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
8467	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8468	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8469	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8470	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8471	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8472	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8473	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8474	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8475	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8476	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	35	*F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8477	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
8478	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
8479	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	0	
8480	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	1	
8481	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	180	
8482	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	180	
8483	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
8484	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	1	
8485	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8486	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
8487	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments		
8488	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
8489	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
8490	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
8491	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
8492	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
8493	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
8494	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
8495	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
8496	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8497	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8498	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8499	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8500	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8501	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8502	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8503	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8504	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8505	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
8506	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	19.0	
8507	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	15.0	
8508	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	15.0	
8509	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8510	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8511	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8512	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	3	
8513	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8514	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8515	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8516	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	241.0	
8517	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	309.0	
8518	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	321.0	
8519	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8520	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8521	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8522	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8523	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
8524	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
8525	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
8526	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
8527	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
8528	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
8529	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	1	
8530	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
8531	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
8532	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
8533	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	0	
8534	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	182	
8535	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	182	
8536	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
8537	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	0	
8538	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8539	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
8540	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments		
8541	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments		
8542	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8543	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8544	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8545	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8546	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8547	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
8548	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8549	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments		
8550	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8551	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8552	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8553	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8554	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8555	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8556	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8557	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8558	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8559	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8560	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8561	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8562	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8563	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8564	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8565	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8566	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8567	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8568	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8569	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8570	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8571	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8572	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8573	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8574	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8575	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
8576	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8577	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8578	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8579	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8580	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8581	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8582	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8583	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8584	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8585	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8586	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
8587	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
8588	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8589	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
8590	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	No SPR	
8591	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8592	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8593	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8594	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8595	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8596	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8597	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8598	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8599	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8600	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
8601	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8602	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
8603	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8604	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8605	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8606	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8607	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8608	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8609	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8610	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8611	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8612	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8613	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8614	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8615	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8616	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8617	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
8618	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8619	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8620	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8621	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8622	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8623	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8624	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8625	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8626	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8627	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments		
8628	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8629	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8630	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8631	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8632	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8633	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8634	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8635	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	2	
8636	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8637	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8638	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8639	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	179.0	
8640	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	183.0	
8641	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	226.0	
8642	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8643	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8644	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8645	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8646	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
8647	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
8648	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
8649	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
8650	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
8651	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
8652	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
8653	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments	Actual counter, IOC B and C Phase	
8654	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
8655	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	409	
8656	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	409	
8657	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
8658	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
8659	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
8660	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8661	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8662	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8663	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8664	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8665	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8666	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
8667	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8668	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8669	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
8670	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
8671	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	General Comments		
8672	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
8673	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	LTC0000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
8674	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8675	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
8676	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8677	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8678	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
8679	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
8680	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
8681	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8682	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
8683	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8684	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8685	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
8686	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
8687	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
8688	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8689	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8690	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
8691	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8692	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
8693	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
8694	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8695	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8696	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
8697	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
8698	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
8699	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
8700	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
8701	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8702	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
8703	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8704	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8705	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8706	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8707	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8708	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8709	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8710	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8711	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8712	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
8713	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
8714	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
8715	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
8716	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	139	
8717	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	139	
8718	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
8719	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
8720	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
8721	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8722	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8723	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8724	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	1	
8725	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	7	
8726	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8727	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8728	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8729	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	180.0	
8730	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	220.0	
8731	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	180.0	
8732	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
8733	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8734	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8735	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8736	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8737	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8738	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8739	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8740	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8741	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8742	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
8743	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
8744	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
8745	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
8746	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
8747	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
8748	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
8749	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments		
8750	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments		
8751	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
8752	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8753	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
8754	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
8755	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	95	
8756	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	0	
8757	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	0	
8758	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8759	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
8760	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
8761	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
8762	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
8763	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8764	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8765	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8766	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8767	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8768	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8769	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8770	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8771	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8772	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
8773	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8774	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
8775	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
8776	12/18/2019 9:54	Distribution	Jeffersonstown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
8777	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8778	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	3739	
8779	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	3739	
8780	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
8781	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
8782	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8783	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
8784	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
8785	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	61	°C
8786	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
8787	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	61	°C
8788	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
8789	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	61	°C
8790	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
8791	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8792	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8793	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8794	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8795	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8796	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8797	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8798	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8799	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8800	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8801	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
8802	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	58	°C
8803	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
8804	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8805	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8806	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8807	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
8808	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
8809	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8810	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8811	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
8812	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8813	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8814	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8815	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8816	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
8817	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8818	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8819	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8820	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8821	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8822	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8823	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8824	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8825	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8826	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8827	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	2	
8828	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8829	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8830	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8831	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8832	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8833	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8834	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8835	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
8836	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
8837	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
8838	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
8839	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8840	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
8841	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8842	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
8843	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
8844	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8845	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8846	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
8847	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8848	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8849	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8850	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8851	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8852	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8853	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
8854	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8855	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8856	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
8857	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8858	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
8859	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8860	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8861	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
8862	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
8863	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
8864	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8865	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
8866	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
8867	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8868	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8869	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
8870	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8871	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
8872	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
8873	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
8874	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8875	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8876	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
8877	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8878	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8879	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8880	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
8881	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8882	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8883	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8884	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8885	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
8886	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8887	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8888	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
8889	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
8890	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8891	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
8892	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
8893	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
8894	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	178	
8895	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	178	
8896	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
8897	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
8898	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
8899	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
8900	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
8901	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
8902	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
8903	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
8904	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
8905	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8906	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8907	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8908	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8909	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	123.0	
8910	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	83.0	
8911	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	48.0	
8912	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8913	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8914	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
8915	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	If no, which cells in comments
8916	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
8917	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	
8918	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	243	
8919	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	243	
8920	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8921	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8922	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8923	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8924	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	548	
8925	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	13	*C
8926	12/18/2019 9:54	Distribution	JeffersonTown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8927	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
8928	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
8929	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
8930	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
8931	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8932	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	0	
8933	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	181	
8934	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	181	
8935	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
8936	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
8937	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8938	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
8939	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments		
8940	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments		
8941	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
8942	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
8943	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
8944	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
8945	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
8946	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	0	
8947	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
8948	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8949	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8950	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8951	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8952	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8953	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8954	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8955	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8956	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8957	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
8958	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	120.0	
8959	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	140.0	
8960	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	180.0	
8961	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8962	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8963	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8964	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	2	
8965	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
8966	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
8967	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
8968	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8969	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
8970	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	n	
8971	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	General Comments	Not energized	
8972	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
8973	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
8974	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8975	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8976	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8977	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8978	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8979	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8980	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8981	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8982	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8983	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8984	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8985	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8986	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments		
8987	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8988	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8989	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8990	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8991	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8992	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8993	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8994	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8995	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8996	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8997	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
8998	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
8999	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9000	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments		
9001	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9002	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9003	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9004	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9005	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9006	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9007	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9008	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9009	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
9010	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
9011	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
9012	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9013	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9014	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9015	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9016	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9017	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9018	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9019	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9020	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9021	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9022	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	508.0	
9023	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	416.0	
9024	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	436.0	
9025	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9026	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9027	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9028	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	2	
9029	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
9030	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.3	VDC
9031	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9032	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9033	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9034	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9035	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9036	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9037	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9038	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9039	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
9040	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9041	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
9042	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9043	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9044	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.9	VDC
9045	12/17/2019 13:48	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.9	VDC
9046	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	2	
9047	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9048	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9049	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9050	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	226.0	
9051	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	178.0	
9052	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	196.0	
9053	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
9054	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9055	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9056	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9057	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9058	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9059	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9060	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9061	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9062	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9063	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
9064	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
9065	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
9066	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
9067	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
9068	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
9069	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
9070	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
9071	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments		
9072	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
9073	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9074	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	1	
9075	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
9076	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	173	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9077	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	173	
9078	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	1	
9079	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
9080	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
9081	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9082	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
9083	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
9084	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	General Comments		
9085	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
9086	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
9087	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	12	
9088	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9089	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9090	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9091	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	0.0	
9092	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	0.0	
9093	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	0.0	
9094	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9095	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9096	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9097	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9098	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
9099	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
9100	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
9101	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
9102	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
9103	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
9104	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		
9105	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments	Time Trip C phase	
9106	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
9107	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	373	
9108	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	373	
9109	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	1	
9110	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
9111	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	1	
9112	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	5207.04	kw
9113	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9114	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments		
9115	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments		
9116	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9117	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9118	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
9119	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9120	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9121	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9122	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9123	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9124	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9125	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9126	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9127	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9128	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9129	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9130	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9131	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9132	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	*F
9133	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9134	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9135	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9136	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9137	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9138	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9139	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9140	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.3	VDC
9141	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.2	VDC
9142	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9143	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9144	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9145	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9146	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
9147	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9148	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	4	
9149	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9150	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9151	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9152	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	169.0	
9153	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	134.0	
9154	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	177.0	
9155	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9156	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9157	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9158	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9159	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
9160	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
9161	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
9162	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
9163	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
9164	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
9165	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
9166	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
9167	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
9168	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	472	
9169	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	472	
9170	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
9171	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
9172	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
9173	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9174	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9175	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.5424	
9176	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9177	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9178	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9179	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9180	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9181	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9182	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9183	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9184	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	34	°C
9185	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	60	°C
9186	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
9187	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9188	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	4	
9189	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9190	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9191	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9192	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	59.0	
9193	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	62.0	
9194	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	12.0	
9195	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9196	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9197	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9198	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9199	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
9200	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
9201	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
9202	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
9203	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
9204	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
9205	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
9206	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
9207	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
9208	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	160	
9209	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	160	
9210	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
9211	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
9212	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
9213	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
9214	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9215	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9216	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
9217	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9218	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
9219	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
9220	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9221	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9222	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9223	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9224	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9225	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9226	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9227	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9228	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9229	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
9230	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
9231	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
9232	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	0	
9233	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	186	
9234	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	186	
9235	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
9236	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	0	
9237	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9238	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
9239	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments		
9240	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments		
9241	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
9242	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
9243	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
9244	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
9245	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9246	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9247	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
9248	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9249	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	19376	
9250	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	19376	
9251	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9252	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
9253	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9254	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
9255	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9256	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
9257	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	8	°C
9258	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	502	
9259	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9260	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9261	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9262	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9263	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
9264	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
9265	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
9266	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9267	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9268	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9269	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9270	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9271	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9272	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9273	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9274	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9275	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
9276	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	240.0	
9277	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	230.0	
9278	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	220.0	
9279	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9280	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9281	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9282	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	6	
9283	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9284	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9285	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9286	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
9287	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9288	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9289	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9290	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9291	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9292	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	160	
9293	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9294	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	3L	
9295	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	1L	
9296	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	1L	
9297	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9298	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	949	
9299	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	946	
9300	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments		
9301	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9302	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9303	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
9304	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
9305	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
9306	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	0	
9307	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	216	
9308	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	216	
9309	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
9310	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
9311	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
9312	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
9313	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
9314	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
9315	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
9316	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
9317	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
9318	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9319	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9320	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9321	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9322	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	62.0	
9323	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	29.0	
9324	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	41.0	
9325	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9326	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9327	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9328	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	5	
9329	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9330	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9331	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9332	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
9333	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9334	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9335	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9336	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9337	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9338	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	4	°C
9339	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	55	°C
9340	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9341	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9342	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9343	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
9344	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9345	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9346	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9347	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments		
9348	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments		
9349	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9350	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9351	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
9352	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
9353	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
9354	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
9355	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
9356	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9357	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9358	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9359	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9360	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
9361	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9362	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments		
9363	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9364	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9365	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
9366	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
9367	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
9368	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
9369	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
9370	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9371	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9372	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
9373	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9374	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9375	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9376	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9377	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9378	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9379	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9380	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9381	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9382	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
9383	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	60	°C
9384	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9385	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
9386	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9387	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9388	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9389	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
9390	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9391	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9392	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9393	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9394	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9395	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9396	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9397	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9398	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9399	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9400	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9401	12/17/2019 13:17	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9402	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
9403	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
9404	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9405	12/17/2019 10:09	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments		
9406	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	111.0	
9407	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	123.0	
9408	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	93.0	
9409	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9410	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	6	
9411	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9412	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9413	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9414	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
9415	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
9416	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
9417	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
9418	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
9419	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
9420	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
9421	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
9422	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
9423	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
9424	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
9425	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
9426	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
9427	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9428	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9429	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
9430	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
9431	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9432	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9433	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9434	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9435	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
9436	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
9437	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	0	
9438	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	207	
9439	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	207	
9440	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
9441	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.2	VDC
9442	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.4	VDC
9443	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9444	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9445	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9446	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9447	12/17/2019 12:50	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9448	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
9449	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
9450	12/18/2019 9:54	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
9451	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
9452	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9453	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9454	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9455	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9456	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	272404	
9457	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9458	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9459	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9460	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9461	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9462	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9463	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9464	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9465	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	272404	
9466	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9467	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9468	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9469	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	7	
9470	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9471	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9472	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9473	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	0.0	
9474	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	0.0	
9475	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
9476	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9477	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9478	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9479	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9480	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9481	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9482	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9483	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9484	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9485	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
9486	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
9487	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
9488	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9489	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9490	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9491	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9492	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9493	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9494	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
9495	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9496	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9497	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9498	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9499	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9500	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9501	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9502	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9503	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9504	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9505	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9506	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9507	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9508	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9509	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9510	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9511	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9512	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9513	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9514	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9515	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9516	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9517	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9518	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9519	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9520	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9521	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9522	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9523	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9524	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9525	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9526	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9527	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9528	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
9529	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9530	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9531	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9532	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9533	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9534	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9535	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	72	
9536	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9537	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9538	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
9539	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
9540	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	99986	
9541	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	99986	
9542	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	3L	
9543	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	6L	
9544	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9545	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	114896	
9546	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	114896	
9547	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
9548	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
9549	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9550	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
9551	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
9552	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
9553	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9554	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
9555	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
9556	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9557	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9558	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9559	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9560	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9561	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9562	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9563	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9564	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9565	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9566	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9567	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9568	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
9569	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9570	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9571	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
9572	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
9573	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9574	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	11728.80	kw
9575	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9576	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9577	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
9578	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
9579	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
9580	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
9581	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
9582	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
9583	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
9584	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
9585	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9586	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9587	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9588	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9589	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	22	°C
9590	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	18	°C
9591	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9592	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9593	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9594	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9595	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9596	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9597	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9598	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9599	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9600	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9601	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9602	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	189.0	
9603	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	174.0	
9604	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	132.0	
9605	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9606	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9607	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9608	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	5	
9609	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9610	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9611	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9612	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9613	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9614	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9615	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
9616	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9617	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9618	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
9619	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
9620	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9621	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9622	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9623	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9624	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	13230.00	kw
9625	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9626	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9627	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	25	°C
9628	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	22	°C
9629	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9630	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9631	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9632	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9633	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9634	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9635	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9636	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9637	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.7350	
9638	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	52	°C
9639	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	40	°C
9640	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9641	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9642	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9643	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9644	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9645	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9646	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9647	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9648	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	933	
9649	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9650	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
9651	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9652	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
9653	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
9654	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	615	
9655	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	12L	
9656	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9657	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	146767	
9658	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	146767	
9659	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9660	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
9661	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9662	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9663	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9664	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9665	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9666	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9667	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9668	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	38	*F
9669	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
9670	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
9671	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	1	
9672	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9673	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
9674	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
9675	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	1	
9676	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9677	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	1	
9678	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
9679	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
9680	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
9681	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
9682	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9683	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
9684	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9685	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
9686	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9687	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9688	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9689	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9690	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	20.0	
9691	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	198	
9692	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	1	
9693	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
9694	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	1	
9695	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	2	
9696	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9697	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9698	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9699	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	465.0	
9700	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	465.0	
9701	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	465.0	
9702	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
9703	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9704	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9705	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9706	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9707	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9708	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9709	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9710	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9711	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9712	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9713	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9714	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9715	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
9716	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
9717	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
9718	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
9719	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9720	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9721	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9722	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9723	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9724	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
9725	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
9726	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
9727	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
9728	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
9729	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9730	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
9731	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9732	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	63	
9733	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	63	
9734	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9735	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9736	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9737	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9738	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9739	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9740	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9741	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
9742	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9743	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
9744	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9745	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
9746	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	3	
9747	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9748	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9749	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9750	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	190.0	
9751	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	205.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9752	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	198	
9753	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
9754	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		
9755	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
9756	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
9757	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
9758	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
9759	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
9760	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9761	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9762	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9763	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
9764	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	19.0	
9765	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
9766	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9767	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
9768	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
9769	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	7	
9770	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
9771	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9772	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9773	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9774	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9775	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9776	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
9777	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
9778	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
9779	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
9780	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9781	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
9782	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
9783	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
9784	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9785	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
9786	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	315	
9787	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	314	
9788	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
9789	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
9790	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
9791	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	1	
9792	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9793	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9794	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9795	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	98.0	
9796	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	117.0	
9797	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	135.0	
9798	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9799	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9800	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9801	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9802	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9803	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9804	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9805	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9806	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
9807	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
9808	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
9809	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
9810	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9811	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
9812	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
9813	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
9814	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
9815	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
9816	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9817	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
9818	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9819	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99844	
9820	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99844	
9821	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
9822	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9823	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
9824	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
9825	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9826	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
9827	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9828	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9829	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
9830	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9831	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9832	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9833	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9834	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9835	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9836	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9837	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9838	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
9839	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
9840	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9841	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9842	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9843	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9844	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9845	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9846	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9847	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9848	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9849	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9850	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9851	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9852	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9853	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9854	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9855	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9856	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9857	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9858	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9859	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
9860	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
9861	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9862	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9863	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9864	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9865	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9866	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9867	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9868	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9869	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9870	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
9871	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
9872	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
9873	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9874	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9875	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
9876	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9877	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9878	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9879	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9880	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9881	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9882	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9883	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9884	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9885	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
9886	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	100.0	
9887	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	109.0	
9888	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	103.0	
9889	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9890	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9891	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9892	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	1	
9893	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9894	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9895	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9896	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9897	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9898	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9899	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9900	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	175.0	
9901	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9902	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9903	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9904	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9905	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9906	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9907	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9908	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9909	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9910	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9911	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9912	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9913	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9914	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9915	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9916	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9917	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9918	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9919	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
9920	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9921	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
9922	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9923	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9924	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9925	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
9926	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
9927	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	1	
9928	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	1	
9929	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	178	
9930	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	178	
9931	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
9932	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
9933	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
9934	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9935	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9936	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9937	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9938	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9939	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9940	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
9941	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
9942	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
9943	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
9944	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
9945	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
9946	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
9947	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
9948	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
9949	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
9950	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
9951	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
9952	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
9953	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
9954	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
9955	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
9956	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
9957	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9958	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
9959	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
9960	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	163	
9961	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	163	
9962	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	0	
9963	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9964	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9965	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9966	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9967	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9968	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9969	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9970	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9971	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9972	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
9973	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
9974	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
9975	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
9976	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9977	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	125.0	
9978	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	105.0	
9979	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9980	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9981	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9982	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	6	
9983	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
9984	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9985	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
9986	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9987	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
9988	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
9989	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
9990	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
9991	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9992	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9993	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9994	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9995	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9996	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9997	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
9998	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
9999	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10000	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
10001	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10002	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
10003	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
10004	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
10005	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
10006	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10007	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10008	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10009	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10010	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10011	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10012	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
10013	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
10014	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10015	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10016	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10017	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10018	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10019	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10020	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10021	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10022	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10023	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
10024	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10025	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10026	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10027	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10028	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10029	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10030	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10031	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
10032	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10033	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10034	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10035	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10036	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10037	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10038	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
10039	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
10040	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
10041	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
10042	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
10043	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10044	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	0	
10045	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	178	
10046	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	178	
10047	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
10048	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
10049	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10050	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
10051	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10052	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
10053	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
10054	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
10055	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
10056	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
10057	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
10058	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
10059	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
10060	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10061	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10062	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10063	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10064	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10065	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10066	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10067	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10068	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10069	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
10070	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	242.0	
10071	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	243.0	
10072	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	248.0	
10073	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10074	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10075	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10076	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	0	
10077	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
10078	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
10079	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	0	
10080	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	0	
10081	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	198	
10082	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	198	
10083	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
10084	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
10085	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
10086	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
10087	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
10088	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
10089	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
10090	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
10091	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
10092	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
10093	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
10094	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
10095	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10096	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10097	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10098	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10099	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10100	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10101	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10102	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10103	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10104	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
10105	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
10106	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10107	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10108	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10109	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10110	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10111	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10112	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10113	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10114	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10115	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10116	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10117	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10118	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10119	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
10120	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10121	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10122	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10123	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	20	°C
10124	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
10125	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10126	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10127	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10128	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10129	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10130	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10131	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10132	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10133	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
10134	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
10135	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
10136	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
10137	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	176	
10138	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	176	
10139	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	0	
10140	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
10141	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
10142	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
10143	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	2	
10144	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10145	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10146	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10147	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	88.0	
10148	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	99.0	
10149	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	75.0	
10150	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
10151	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10152	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10153	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10154	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10155	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10156	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10157	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10158	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10159	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10160	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
10161	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
10162	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
10163	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
10164	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
10165	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
10166	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
10167	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
10168	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
10169	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10170	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10171	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10172	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10173	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
10174	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10175	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10176	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10177	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10178	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10179	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10180	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10181	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10182	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10183	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10184	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10185	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10186	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	34	°C
10187	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	67	°C
10188	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10189	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10190	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10191	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	48	°C
10192	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	53	°C
10193	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10194	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitrogen bottle needs to be filled.	
10195	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
10196	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10197	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10198	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10199	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10200	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10201	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10202	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10203	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10204	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10205	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10206	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10207	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10208	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10209	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10210	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10211	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	2	
10212	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10213	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10214	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10215	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	158.0	
10216	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	161.0	
10217	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	162.0	
10218	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
10219	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10220	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10221	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10222	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10223	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10224	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10225	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10226	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10227	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10228	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
10229	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
10230	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
10231	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
10232	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
10233	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
10234	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10235	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
10236	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10237	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10238	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
10239	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10240	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10241	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10242	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10243	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10244	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10245	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
10246	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10247	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10248	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10249	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10250	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10251	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
10252	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10253	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10254	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10255	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10256	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10257	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10258	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
10259	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10260	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10261	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10262	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10263	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10264	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10265	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10266	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10267	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10268	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10269	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10270	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10271	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10272	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10273	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10274	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10275	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10276	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10277	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10278	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	35	°C
10279	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	35	°C
10280	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10281	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	130.00	
10282	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10283	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10284	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10285	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10286	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10287	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10288	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10289	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10290	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10291	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
10292	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	70	°C
10293	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10294	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10295	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10296	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
10297	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
10298	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10299	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	311	
10300	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10301	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10302	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10303	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10304	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	5R	
10305	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	11R	
10306	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	8R	
10307	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10308	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	79376	
10309	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	79376	
10310	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
10311	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
10312	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10313	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10314	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10315	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10316	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10317	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10318	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10319	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
10320	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10321	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	0	
10322	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	0	
10323	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	0	
10324	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	280	
10325	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	280	
10326	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
10327	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments		
10328	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
10329	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
10330	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C Ø	0	
10331	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B Ø	0	
10332	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A Ø	0	
10333	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10334	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10335	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10336	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	135.0	
10337	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	131.0	
10338	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	115.0	
10339	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
10340	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
10341	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
10342	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	8	
10343	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10344	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10345	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10346	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
10347	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10348	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
10349	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10350	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
10351	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10352	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10353	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10354	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10355	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10356	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10357	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10358	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10359	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10360	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10361	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10362	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10363	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10364	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments	Oil and winding temp gauges can't be reset, reset mechanisms have been painted.	
10365	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10366	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10367	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10368	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
10369	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10370	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10371	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10372	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10373	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10374	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10375	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10376	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10377	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10378	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10379	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10380	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10381	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10382	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10383	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10384	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10385	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	803	
10386	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10387	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
10388	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
10389	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10390	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	369931	
10391	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	369931	
10392	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10393	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
10394	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10395	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10396	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10397	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10398	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10399	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10400	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10401	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10402	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10403	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10404	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10405	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10406	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10407	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10408	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10409	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10410	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10411	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10412	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
10413	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
10414	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10415	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
10416	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10417	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10418	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10419	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
10420	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10421	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
10422	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
10423	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
10424	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10425	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10426	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10427	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10428	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10429	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10430	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10431	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10432	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10433	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
10434	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10435	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10436	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10437	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10438	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10439	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10440	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10441	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10442	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10443	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10444	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10445	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10446	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10447	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10448	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10449	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10450	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10451	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10452	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10453	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10454	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10455	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10456	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10457	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10458	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10459	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
10460	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10461	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10462	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10463	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10464	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10465	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10466	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10467	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10468	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10469	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10470	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10471	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10472	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10473	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10474	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10475	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10476	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10477	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10478	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10479	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10480	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10481	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10482	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
10483	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
10484	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
10485	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	*C
10486	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	*C
10487	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10488	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10489	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
10490	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.40	MegaWatts
10491	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
10492	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.30	MegaVars
10493	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10494	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10495	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10496	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10497	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10498	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10499	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10500	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10501	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
10502	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10503	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10504	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10505	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	457	
10506	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	12L	
10507	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
10508	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10509	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
10510	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
10511	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	7769	
10512	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	7769	
10513	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10514	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	6L	
10515	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	4L	
10516	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	11L	
10517	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10518	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	537	
10519	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10520	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10521	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10522	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	2L	
10523	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	5L	
10524	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10525	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	11725	
10526	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	11725	
10527	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
10528	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
10529	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10530	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
10531	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10532	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10533	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10534	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10535	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10536	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
10537	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10538	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10539	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10540	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
10541	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10542	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
10543	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	14L	
10544	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10545	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10546	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10547	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10548	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10549	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	10625	
10550	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10551	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10552	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10553	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10554	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10555	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10556	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10557	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10558	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
10559	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	893	
10560	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	893	
10561	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	1	
10562	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10563	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	1	
10564	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
10565	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
10566	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10567	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10568	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10569	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	37	*F
10570	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10571	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10572	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10573	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10574	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10575	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
10576	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
10577	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
10578	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
10579	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
10580	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
10581	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
10582	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
10583	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10584	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
10585	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
10586	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	1	
10587	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	47	
10588	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	87	
10589	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
10590	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10591	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	87	psi
10592	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10593	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
10594	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
10595	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10596	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10597	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10598	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10599	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10600	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10601	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10602	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10603	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10604	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10605	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10606	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10607	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10608	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
10609	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10610	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10611	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10612	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10613	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10614	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10615	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10616	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10617	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10618	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
10619	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10620	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10621	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10622	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
10623	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
10624	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
10625	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
10626	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
10627	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
10628	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
10629	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	187	
10630	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	187	
10631	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	0	
10632	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
10633	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
10634	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
10635	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
10636	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
10637	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	General Comments		
10638	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
10639	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
10640	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
10641	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10642	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10643	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
10644	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	1	
10645	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10646	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10647	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10648	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	352.0	
10649	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	358.0	
10650	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	360.0	
10651	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10652	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10653	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10654	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10655	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10656	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10657	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10658	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10659	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10660	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10661	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
10662	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
10663	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
10664	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
10665	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
10666	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
10667	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
10668	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
10669	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
10670	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
10671	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10672	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
10673	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
10674	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	277	
10675	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	277	
10676	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	1	
10677	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10678	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10679	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	31	°C
10680	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	72	°C
10681	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.6516	
10682	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10683	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10684	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10685	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10686	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10687	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10688	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10689	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
10690	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10691	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10692	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10693	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
10694	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10695	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
10696	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	12L	
10697	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10698	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10699	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10700	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10701	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10702	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	12051	
10703	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10704	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10705	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10706	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10707	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10708	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10709	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10710	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10711	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10712	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
10713	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10714	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10715	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10716	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
10717	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10718	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
10719	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	13L	
10720	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10721	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10722	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10723	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10724	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10725	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	10738	
10726	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
10727	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10728	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10729	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10730	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	4	
10731	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10732	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10733	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10734	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	120.0	
10735	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	80.0	
10736	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	90.0	
10737	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
10738	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10739	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10740	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10741	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10742	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10743	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10744	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10745	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10746	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10747	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
10748	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
10749	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
10750	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
10751	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
10752	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10753	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10754	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10755	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10756	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10757	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10758	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10759	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10760	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	55.0	
10761	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	53.0	
10762	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	57.0	
10763	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10764	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
10765	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
10766	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
10767	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10768	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10769	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10770	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10771	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10772	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10773	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10774	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10775	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	13	
10776	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	11.96	%
10777	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
10778	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	5.58	%
10779	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A Ø	95.0	
10780	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B Ø	118.0	
10781	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C Ø	124.0	
10782	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10783	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10784	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10785	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A Ø	0	
10786	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B Ø	0	
10787	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C Ø	0	
10788	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
10789	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
10790	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments	Actual Counter	
10791	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
10792	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	313	
10793	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	313	
10794	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	0	
10795	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
10796	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
10797	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10798	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10799	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTC0000201	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10800	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTC0000201	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10801	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTC0000201	LTCControl	Retired Distribution	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10802	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10803	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10804	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10805	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10806	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10807	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10808	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10809	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10810	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10811	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
10812	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10813	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10814	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
10815	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
10816	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
10817	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
10818	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
10819	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	251	
10820	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	251	
10821	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	0	
10822	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	0	
10823	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
10824	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
10825	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	1	
10826	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10827	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10828	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10829	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	472.0	
10830	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	477.0	
10831	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	460.0	
10832	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
10833	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10834	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10835	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10836	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10837	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10838	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10839	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10840	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10841	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10842	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
10843	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
10844	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
10845	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
10846	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10847	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
10848	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
10849	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
10850	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
10851	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
10852	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
10853	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10854	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	149	
10855	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	149	
10856	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
10857	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
10858	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10859	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
10860	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	All Connections OK?	y	
10861	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
10862	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	General Comments		
10863	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
10864	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10865	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10866	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10867	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
10868	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10869	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10870	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10871	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10872	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10873	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10874	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10875	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10876	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
10877	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1399	
10878	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1399	
10879	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10880	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10881	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10882	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10883	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10884	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10885	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10886	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	24	
10887	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10888	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10889	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10890	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	68.0	
10891	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	42.0	
10892	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	73.0	
10893	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
10894	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10895	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10896	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10897	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10898	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10899	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10900	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10901	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10902	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10903	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
10904	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
10905	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
10906	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
10907	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
10908	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
10909	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
10910	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
10911	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
10912	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
10913	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10914	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
10915	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10916	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10917	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10918	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10919	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
10920	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.3	VDC
10921	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.2	VDC
10922	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10923	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10924	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10925	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
10926	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
10927	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
10928	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10929	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10930	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
10931	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10932	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10933	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10934	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10935	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10936	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10937	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10938	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10939	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10940	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
10941	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10942	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10943	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
10944	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10945	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10946	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10947	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	13279.68	kw
10948	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10949	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10950	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
10951	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	56	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10952	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	25	°C
10953	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10954	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10955	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10956	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10957	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10958	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10959	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10960	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10961	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10962	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10963	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	.9222	
10964	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	56	°C
10965	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	25	°C
10966	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10967	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10968	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
10969	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10970	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
10971	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
10972	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	19201	
10973	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	19201	
10974	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10975	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	6L	
10976	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	4L	
10977	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	11L	
10978	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10979	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10980	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
10981	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
10982	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	773	
10983	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10984	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10985	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10986	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10987	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	All Connections OK?	y	
10988	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
10989	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	General Comments		
10990	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
10991	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10992	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
10993	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10994	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10995	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
10996	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10997	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10998	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10999	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11000	12/16/2019 12:14	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11001	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11002	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
11003	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11004	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11005	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11006	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11007	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11008	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11009	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11010	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11011	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
11012	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
11013	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
11014	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11015	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
11016	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11017	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11018	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11019	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11020	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11021	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11022	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11023	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11024	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11025	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11026	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11027	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11028	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11029	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11030	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
11031	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11032	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11033	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11034	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11035	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11036	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11037	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11038	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
11039	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
11040	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
11041	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11042	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11043	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11044	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11045	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11046	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11047	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
11048	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11049	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11050	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11051	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11052	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
11053	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11054	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11055	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
11056	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
11057	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11058	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11059	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11060	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11061	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11062	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11063	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11064	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
11065	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
11066	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
11067	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
11068	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11069	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
11070	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
11071	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
11072	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11073	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
11074	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	385	
11075	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	385	
11076	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
11077	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
11078	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
11079	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11080	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
11081	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11082	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
11083	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11084	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11085	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11086	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11087	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11088	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11089	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11090	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11091	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11092	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11093	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11094	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11095	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11096	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11097	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11098	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11099	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11100	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11101	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11102	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11103	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11104	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11105	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11106	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
11107	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11108	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11109	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11110	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11111	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11112	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11113	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
11114	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11115	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11116	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11117	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	134	
11118	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	134	
11119	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11120	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11121	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
11122	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11123	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
11124	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11125	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11126	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
11127	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11128	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
11129	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
11130	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
11131	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
11132	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	163.0	
11133	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	208.0	
11134	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	193.0	
11135	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11136	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
11137	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
11138	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11139	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11140	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11141	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11142	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11143	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11144	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11145	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	136	
11146	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	136	
11147	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11148	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11149	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
11150	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
11151	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	28.91	%
11152	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
11153	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	14.45	%
11154	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	237.0	
11155	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	231.0	
11156	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	168.0	
11157	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11158	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11159	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
11160	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11161	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11162	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11163	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11164	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11165	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11166	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11167	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11168	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
11169	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11170	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11171	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11172	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11173	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11174	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11175	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11176	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11177	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11178	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11179	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11180	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11181	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
11182	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11183	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11184	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11185	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11186	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11187	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
11188	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11189	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11190	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11191	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11192	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11193	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11194	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11195	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11196	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11197	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11198	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11199	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11200	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11201	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11202	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11203	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
11204	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
11205	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
11206	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
11207	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
11208	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	119.0	
11209	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	94.0	
11210	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11211	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
11212	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
11213	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11214	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11215	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11216	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11217	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
11218	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
11219	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
11220	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	n	
11221	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11222	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
11223	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11224	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
11225	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	0	
11226	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11227	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11228	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11229	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
11230	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
11231	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
11232	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushing Condition	Good	
11233	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11234	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11235	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11236	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11237	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11238	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11239	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11240	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11241	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11242	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
11243	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
11244	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
11245	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
11246	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Follow-up Action Required?	n	
11247	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
11248	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	0	
11249	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11250	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
11251	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11252	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
11253	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
11254	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
11255	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
11256	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
11257	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
11258	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
11259	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
11260	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11261	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11262	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11263	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11264	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11265	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11266	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11267	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11268	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Unknown Operations	0	
11269	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11270	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	1	
11271	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11272	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	1	
11273	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	339	
11274	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	339	
11275	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
11276	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11277	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11278	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
11279	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11280	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
11281	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments		
11282	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments		
11283	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
11284	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	n	
11285	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11286	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
11287	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
11288	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
11289	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	
11290	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11291	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11292	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11293	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11294	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11295	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11296	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11297	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11298	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11299	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
11300	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	0.0	
11301	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	0.0	
11302	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	0.0	
11303	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11304	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11305	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11306	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	1	
11307	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Unknown Operations	0	
11308	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
11309	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	0	
11310	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11311	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	0	
11312	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	350	
11313	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	350	
11314	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
11315	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11316	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11317	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11318	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11319	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11320	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
11321	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11322	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11323	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11324	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11325	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11326	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	37	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11327	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11328	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11329	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11330	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11331	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11332	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11333	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11334	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
11335	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
11336	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
11337	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
11338	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11339	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11340	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11341	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
11342	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11343	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11344	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	6	
11345	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11346	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11347	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11348	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	100.0	
11349	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	80.0	
11350	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	100.0	
11351	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11352	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11353	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11354	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11355	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11356	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11357	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
11358	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11359	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11360	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11361	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11362	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11363	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11364	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11365	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11366	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11367	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11368	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
11369	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11370	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11371	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11372	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11373	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
11374	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	0.0	
11375	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	0.0	
11376	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	0.0	
11377	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11378	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11379	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11380	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	0	
11381	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11382	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11383	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11384	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11385	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
11386	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	General Comments		
11387	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
11388	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11389	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11390	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11391	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11392	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11393	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11394	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11395	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
11396	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11397	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11398	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11399	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11400	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11401	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11402	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11403	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11404	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11405	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11406	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11407	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11408	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11409	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
11410	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11411	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Foundation Condition	Good	
11412	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	General Comments		
11413	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments		
11414	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Grounds in Place?	y	
11415	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11416	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
11417	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Moisture and Leak Free?	y	
11418	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	218	
11419	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	218	
11420	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	0	
11421	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11422	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	0	
11423	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Tank Paint Condition	Good	
11424	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11425	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2R	
11426	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
11427	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	2L	
11428	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.3	psi
11429	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	428	
11430	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11431	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11432	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11433	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
11434	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11435	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
11436	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11437	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
11438	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
11439	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
11440	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11441	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
11442	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11443	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
11444	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
11445	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
11446	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
11447	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
11448	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11449	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
11450	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
11451	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
11452	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
11453	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11454	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11455	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11456	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11457	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11458	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11459	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11460	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11461	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11462	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11463	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11464	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11465	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11466	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11467	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11468	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11469	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11470	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11471	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11472	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11473	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11474	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11475	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11476	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11477	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	35	°C
11478	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11479	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11480	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
11481	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
11482	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
11483	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
11484	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
11485	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
11486	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
11487	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
11488	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
11489	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
11490	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11491	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
11492	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
11493	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	988	
11494	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	988	
11495	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	1	
11496	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11497	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	1	
11498	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
11499	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
11500	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11501	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11502	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	5500.80	kw
11503	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11504	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
11505	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
11506	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11507	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11508	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
11509	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11510	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11511	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11512	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
11513	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11514	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59615	
11515	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59615	
11516	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11517	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
11518	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	29	
11519	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11520	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11521	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11522	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11523	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
11524	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11525	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	16770	
11526	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	16770	
11527	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11528	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11529	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
11530	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	460.0	
11531	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11532	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11533	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11534	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11535	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11536	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11537	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11538	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11539	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11540	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11541	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11542	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11543	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11544	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11545	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
11546	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11547	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11548	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11549	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11550	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11551	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
11552	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11553	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	460.0	
11554	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	460.0	
11555	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11556	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11557	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11558	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	0	
11559	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11560	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11561	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11562	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
11563	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
11564	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11565	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11566	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11567	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11568	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6892.80	kw
11569	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	108.33	
11570	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
11571	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
11572	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
11573	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11574	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11575	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11576	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11577	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7180	
11578	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11579	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11580	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11581	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11582	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11583	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11584	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11585	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11586	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
11587	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11588	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
11589	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11590	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
11591	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
11592	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
11593	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
11594	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11595	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11596	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11597	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11598	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11599	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11600	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
11601	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
11602	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11603	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11604	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11605	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11606	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
11607	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments	Needs spill kil	
11608	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11609	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11610	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11611	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11612	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11613	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
11614	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11615	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11616	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11617	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11618	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11619	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11620	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11621	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11622	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11623	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11624	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11625	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11626	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
11627	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11628	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11629	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11630	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11631	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
11632	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11633	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11634	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11635	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
11636	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11637	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11638	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11639	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
11640	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
11641	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11642	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
11643	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	478	
11644	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	478	
11645	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
11646	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
11647	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11648	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
11649	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
11650	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
11651	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
11652	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
11653	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
11654	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
11655	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
11656	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
11657	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
11658	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11659	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11660	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11661	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11662	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11663	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11664	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11665	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11666	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11667	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
11668	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	0.0	
11669	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11670	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11671	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11672	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11673	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	General Comments		
11674	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11675	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	0.0	
11676	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	0.0	
11677	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11678	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11679	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11680	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	140	
11681	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11682	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11683	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	85	
11684	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	85	
11685	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
11686	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11687	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11688	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11689	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11690	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11691	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
11692	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11693	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
11694	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11695	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
11696	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	216	
11697	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	216	
11698	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
11699	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11700	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11701	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11702	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11703	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11704	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11705	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11706	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11707	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11708	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11709	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11710	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11711	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11712	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11713	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11714	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11715	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11716	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11717	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
11718	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
11719	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	2	
11720	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
11721	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11722	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11723	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11724	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11725	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11726	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11727	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
11728	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11729	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11730	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
11731	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11732	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11733	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	168	
11734	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
11735	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
11736	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
11737	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
11738	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
11739	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
11740	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
11741	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11742	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11743	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11744	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	0.0	
11745	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
11746	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
11747	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11748	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11749	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11750	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	8	
11751	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11752	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11753	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11754	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11755	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11756	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11757	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11758	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11759	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
11760	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11761	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	1	
11762	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11763	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11764	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11765	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	7.0	
11766	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	2.0	
11767	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	3.0	
11768	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
11769	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11770	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11771	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11772	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11773	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11774	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11775	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11776	12/16/2019 12:34	Distribution	Paris 12KV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11777	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11778	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.5730	
11779	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11780	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11781	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11782	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11783	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11784	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11785	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
11786	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11787	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
11788	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11789	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
11790	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
11791	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
11792	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
11793	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11794	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11795	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11796	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11797	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11798	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11799	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
11800	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
11801	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11802	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11803	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11804	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
11805	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
11806	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
11807	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11808	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11809	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11810	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11811	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11812	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11813	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11814	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
11815	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11816	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11817	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11818	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Very Low	
11819	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Very Low	
11820	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Very Low	
11821	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11822	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11823	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11824	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11825	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	Oil level in all three tanks is below sight glass level.	
11826	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11827	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11828	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
11829	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11830	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11831	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11832	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11833	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	1	
11834	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
11835	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	1	
11836	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	168	
11837	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11838	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
11839	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
11840	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
11841	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
11842	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11843	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11844	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11845	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11846	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11847	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	26.6	AMPS
11848	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
11849	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11850	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11851	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11852	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11853	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11854	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11855	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2018-03-08 00:00:00.000000	
11856	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11857	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11858	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
11859	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11860	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11861	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11862	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11863	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11864	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
11865	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
11866	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
11867	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11868	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11869	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
11870	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11871	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11872	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	250.0	
11873	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	250.0	
11874	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	200.0	
11875	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11876	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11877	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11878	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	0	
11879	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11880	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11881	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11882	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11883	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11884	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11885	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11886	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11887	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11888	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11889	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11890	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11891	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11892	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11893	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11894	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11895	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11896	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11897	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11898	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11899	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11900	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11901	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11902	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11903	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11904	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11905	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11906	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
11907	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11908	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11909	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11910	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11911	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11912	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11913	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11914	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11915	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11916	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
11917	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
11918	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
11919	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	353	
11920	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	353	
11921	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
11922	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11923	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
11924	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
11925	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
11926	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11927	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11928	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Heater Condition	Good	
11929	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
11930	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
11931	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
11932	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11933	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11934	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11935	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11936	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11937	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11938	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11939	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11940	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11941	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11942	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11943	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11944	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11945	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11946	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11947	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11948	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11949	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11950	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
11951	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1186	
11952	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1186	
11953	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
11954	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11955	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
11956	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11957	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11958	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11959	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11960	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11961	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11962	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11963	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11964	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11965	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11966	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
11967	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11968	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
11969	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1587	
11970	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
11971	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
11972	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11973	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
11974	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
11975	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
11976	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11977	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11978	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
11979	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
11980	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11981	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
11982	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
11983	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
11984	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
11985	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
11986	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11987	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
11988	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11989	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11990	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
11991	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.23	%
11992	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
11993	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
11994	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	272.0	
11995	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	257.0	
11996	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	298.0	
11997	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11998	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11999	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12000	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12001	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12002	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12003	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12004	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12005	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12006	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12007	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	130	
12008	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	130	
12009	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12010	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12011	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12012	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12013	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12014	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12015	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12016	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
12017	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12018	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12019	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12020	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12021	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12022	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12023	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12024	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12025	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12026	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12027	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12028	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
12029	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12030	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12031	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12032	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12033	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12034	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12035	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12036	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12037	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12038	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12039	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12040	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12041	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
12042	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
12043	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	1	
12044	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12045	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	1	
12046	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	311	
12047	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	311	
12048	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
12049	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
12050	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12051	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
12052	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
12053	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
12054	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
12055	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
12056	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
12057	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
12058	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
12059	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
12060	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
12061	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12062	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
12063	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	40	
12064	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	40	
12065	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12066	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
12067	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12068	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
12069	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
12070	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
12071	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
12072	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
12073	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12074	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
12075	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
12076	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12077	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
12078	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12079	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12080	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12081	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12082	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12083	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12084	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12085	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12086	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	20.0	
12087	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	25.0	
12088	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	22.0	
12089	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12090	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12091	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12092	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
12093	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
12094	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12095	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12096	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12097	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12098	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12099	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12100	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12101	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12102	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
12103	12/16/2019 12:34	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12104	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	1	
12105	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12106	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12107	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12108	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12109	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12110	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12111	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12112	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12113	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12114	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12115	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12116	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12117	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12118	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12119	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12120	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12121	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12122	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12123	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12124	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12125	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12126	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12127	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12128	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12129	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12130	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12131	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12132	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12133	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12134	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12135	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12136	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12137	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12138	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12139	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12140	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12141	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12142	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12143	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12144	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12145	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12146	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
12147	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12148	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
12149	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
12150	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12151	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12152	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12153	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12154	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12155	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12156	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12157	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12158	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12159	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12160	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12161	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12162	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12163	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12164	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12165	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12166	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
12167	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12168	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12169	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12170	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12171	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12172	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12173	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12174	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12175	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12176	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12177	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12178	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12179	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12180	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12181	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12182	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12183	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12184	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12185	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12186	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
12187	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	100.0	
12188	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	101.0	
12189	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	115.0	
12190	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12191	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12192	12/16/2019 15:12	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12193	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
12194	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12195	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12196	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12197	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12198	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12199	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
12200	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12201	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12202	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12203	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12204	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12205	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12206	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12207	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12208	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
12209	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12210	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
12211	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
12212	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	1	
12213	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
12214	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
12215	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
12216	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12217	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
12218	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	461	
12219	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	461	
12220	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	0	
12221	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
12222	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	1	
12223	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	1	
12224	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
12225	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12226	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12227	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12228	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
12229	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12230	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12231	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12232	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12233	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12234	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12235	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12236	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12237	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12238	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12239	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12240	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
12241	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
12242	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
12243	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
12244	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	
12245	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
12246	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12247	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12248	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12249	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12250	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	130.0	
12251	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	110.0	
12252	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	130.0	
12253	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12254	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12255	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12256	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	7	
12257	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12258	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12259	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12260	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12261	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12262	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12263	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12264	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12265	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12266	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12267	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12268	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12269	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12270	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	12	
12271	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12272	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12273	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12274	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	50.0	
12275	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	210.0	
12276	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	230.0	
12277	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12278	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
12279	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12280	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12281	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12282	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
12283	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12284	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12285	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12286	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12287	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12288	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12289	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12290	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12291	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12292	12/16/2019 10:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12293	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12294	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12295	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12296	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12297	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12298	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12299	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12300	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12301	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12302	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12303	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12304	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12305	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12306	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12307	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12308	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12309	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12310	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12311	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12312	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12313	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12314	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12315	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
12316	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
12317	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
12318	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
12319	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
12320	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
12321	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12322	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
12323	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99962	
12324	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
12325	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12326	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments	A/B/C Phase IOC	
12327	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
12328	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
12329	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12330	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1587	
12331	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99962	
12332	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	3	
12333	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
12334	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12335	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12336	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12337	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
12338	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
12339	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12340	12/16/2019 8:16	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
12341	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12342	12/16/2019 15:21	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
12343	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12344	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12345	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
12346	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12347	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12348	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	811	
12349	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12350	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12351	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
12352	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12353	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12354	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12355	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12356	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12357	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12358	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12359	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12360	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12361	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	86.0	
12362	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	9.100	millivolts
12363	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.3	VDC
12364	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.3	VDC
12365	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
12366	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12367	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12368	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12369	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12370	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
12371	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
12372	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12373	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12374	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12375	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12376	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2797.92	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12377	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12378	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12379	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
12380	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	68.0	
12381	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12382	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	21	°C
12383	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	16	°C
12384	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12385	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12386	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12387	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12388	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12389	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12390	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12391	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12392	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1658	
12393	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	26	°C
12394	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12395	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12396	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12397	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12398	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12399	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
12400	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12401	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
12402	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
12403	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12404	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12405	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12406	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12407	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12408	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12409	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12410	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12411	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12412	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12413	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12414	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12415	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12416	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12417	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12418	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12419	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12420	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12421	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12422	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12423	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12424	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12425	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12426	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12427	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	542.0	
12428	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12429	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12430	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12431	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12432	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	566.0	
12433	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	568.0	
12434	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12435	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12436	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12437	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
12438	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12439	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12440	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
12441	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12442	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12443	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12444	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12445	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12446	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12447	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12448	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12449	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12450	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12451	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
12452	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
12453	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
12454	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
12455	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12456	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	115.0	
12457	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	134.0	
12458	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12459	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12460	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12461	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12462	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12463	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
12464	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12465	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12466	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12467	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	90.0	
12468	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
12469	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12470	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12471	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12472	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12473	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12474	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12475	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12476	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12477	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12478	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12479	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
12480	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
12481	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
12482	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
12483	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
12484	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
12485	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
12486	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
12487	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments		
12488	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
12489	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12490	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
12491	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
12492	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12493	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12494	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12495	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12496	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
12497	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
12498	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
12499	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12500	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
12501	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
12502	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
12503	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12504	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
12505	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	2	
12506	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	2	
12507	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
12508	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
12509	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
12510	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12511	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12512	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12513	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12514	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12515	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12516	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12517	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12518	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12519	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12520	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12521	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12522	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12523	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12524	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12525	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12526	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45313	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12527	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12528	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12529	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12530	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12531	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12532	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12533	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12534	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	2	
12535	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12536	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12537	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12538	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	124	
12539	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12540	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	176.0	
12541	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	163.0	
12542	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	236.0	
12543	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
12544	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12545	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12546	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12547	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12548	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12549	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12550	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12551	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12552	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12553	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
12554	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
12555	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
12556	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
12557	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
12558	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
12559	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
12560	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
12561	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments		
12562	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
12563	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12564	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
12565	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
12566	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	175	
12567	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	175	
12568	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	0	
12569	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
12570	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
12571	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
12572	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12573	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	258104	
12574	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	258104	
12575	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments	Fixed reset	
12576	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12577	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12578	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12579	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12580	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12581	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	106	
12582	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12583	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12584	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12585	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12586	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12587	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12588	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12589	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12590	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12591	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12592	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12593	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
12594	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12595	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12596	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12597	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12598	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
12599	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12600	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12601	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12602	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12603	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12604	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12605	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12606	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12607	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12608	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12609	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12610	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12611	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12612	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	43.000	millivolts
12613	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.8	VDC
12614	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	51.8	VDC
12615	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12616	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12617	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12618	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	189	
12619	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	189	
12620	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	0	
12621	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
12622	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
12623	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
12624	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	4	
12625	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12626	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12627	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12628	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	47.0	
12629	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
12630	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12631	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12632	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12633	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
12634	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
12635	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
12636	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12637	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12638	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12639	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	1	
12640	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12641	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12642	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12643	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	120.0	
12644	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	164.0	
12645	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	141.0	
12646	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
12647	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12648	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12649	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12650	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12651	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12652	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12653	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12654	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
12655	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
12656	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
12657	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
12658	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
12659	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
12660	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
12661	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
12662	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
12663	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
12664	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
12665	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
12666	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12667	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12668	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12669	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12670	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12671	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12672	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	154	
12673	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12674	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	60.0	
12675	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	62.0	
12676	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	67.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12677	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
12678	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12679	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12680	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12681	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12682	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12683	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12684	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12685	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12686	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12687	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
12688	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
12689	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
12690	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
12691	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Follow-up Action Required?	n	
12692	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
12693	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	
12694	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12695	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
12696	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
12697	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
12698	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
12699	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
12700	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
12701	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
12702	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
12703	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
12704	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
12705	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
12706	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
12707	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	153	
12708	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	0	
12709	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations This Read Vac	1	
12710	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	1	
12711	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
12712	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
12713	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	2	
12714	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12715	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12716	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12717	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	44.0	
12718	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	46.0	
12719	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
12720	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
12721	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
12722	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
12723	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
12724	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
12725	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
12726	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
12727	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments	removed large number of bugs. needs sprayed	
12728	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
12729	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
12730	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
12731	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	181	
12732	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	181	
12733	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
12734	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
12735	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
12736	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
12737	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12738	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12739	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12740	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12741	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12742	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12743	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12744	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12745	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12746	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
12747	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
12748	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
12749	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
12750	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
12751	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12752	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
12753	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12754	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12755	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12756	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12757	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
12758	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
12759	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
12760	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12761	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12762	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12763	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	16	
12764	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	154	
12765	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations This Read Vac	0	
12766	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	0	
12767	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
12768	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
12769	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12770	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	35.0	
12771	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
12772	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
12773	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12774	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12775	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
12776	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
12777	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
12778	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12779	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12780	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12781	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12782	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12783	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12784	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	249	
12785	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	249	
12786	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
12787	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
12788	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
12789	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
12790	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12791	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12792	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1768	
12793	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12794	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12795	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
12796	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12797	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12798	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
12799	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	140.0	
12800	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	165.0	
12801	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	100.0	
12802	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12803	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12804	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12805	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	1	
12806	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12807	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12808	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12809	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12810	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12811	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12812	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12813	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12814	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12815	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12816	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12817	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	1	
12818	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12819	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12820	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12821	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	91.0	
12822	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12823	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12824	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12825	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12826	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12827	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12828	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Ark sense, A phase trip	
12829	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12830	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	160	
12831	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	160	
12832	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12833	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12834	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12835	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12836	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12837	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.9940	
12838	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12839	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Present	37	°C
12840	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Max	69	°C
12841	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12842	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12843	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12844	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12845	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12846	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12847	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12848	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
12849	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12850	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	7156.80	kw
12851	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	87.0	
12852	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	88.0	
12853	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
12854	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12855	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	21	°C
12856	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12857	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12858	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12859	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12860	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12861	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12862	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12863	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12864	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12865	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12866	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12867	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12868	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12869	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12870	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12871	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12872	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
12873	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12874	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12875	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12876	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	110.0	
12877	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	185.0	
12878	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	175.0	
12879	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12880	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12881	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12882	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12883	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12884	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12885	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12886	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12887	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
12888	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12889	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12890	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12891	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
12892	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	General Comments		
12893	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
12894	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
12895	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12896	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12897	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
12898	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12899	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12900	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12901	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
12902	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12903	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	75	°C
12904	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12905	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12906	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10915.20	kw
12907	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12908	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12909	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12910	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments		
12911	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
12912	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12913	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12914	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12915	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12916	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12917	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12918	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12919	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12920	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12921	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12922	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12923	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
12924	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
12925	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
12926	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12927	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	0	
12928	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	312	
12929	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	312	
12930	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
12931	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	0	
12932	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
12933	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
12934	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
12935	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
12936	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
12937	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
12938	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	171	
12939	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	171	
12940	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
12941	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	
12942	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
12943	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
12944	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	5	
12945	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12946	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12947	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12948	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
12949	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
12950	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12951	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12952	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
12953	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12954	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12955	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12956	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12957	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12958	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12959	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12960	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12961	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12962	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12963	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12964	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12965	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12966	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12967	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12968	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12969	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12970	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12971	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
12972	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12973	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12974	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12975	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12976	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12977	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12978	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12979	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
12980	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
12981	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
12982	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
12983	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
12984	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
12985	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1370	
12986	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12987	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12988	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12989	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12990	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12991	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12992	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12993	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12994	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12995	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12996	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12997	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments	yard light near NA 6667 the right one of the pair is not working and the light in the parking lot is going on and off. Need small bucket t	
12998	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12999	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
13000	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
13001	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
13002	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13003	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
13004	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
13005	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
13006	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
13007	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13008	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13009	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13010	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13011	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13012	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
13013	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
13014	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
13015	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13016	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
13017	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13018	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13019	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13020	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13021	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13022	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
13023	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
13024	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
13025	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
13026	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
13027	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
13028	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
13029	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
13030	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
13031	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
13032	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
13033	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
13034	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
13035	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
13036	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
13037	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
13038	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
13039	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13040	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
13041	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
13042	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
13043	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
13044	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
13045	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
13046	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
13047	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
13048	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
13049	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
13050	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
13051	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
13052	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
13053	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
13054	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
13055	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
13056	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
13057	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13058	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13059	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13060	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13061	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13062	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13063	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13064	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13065	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13066	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13067	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
13068	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
13069	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
13070	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
13071	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
13072	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
13073	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
13074	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
13075	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13076	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13077	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13078	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13079	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13080	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13081	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13082	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13083	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
13084	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13085	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13086	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13087	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	335.0	
13088	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	150.0	
13089	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	100.0	
13090	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13091	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13092	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13093	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13094	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
13095	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
13096	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
13097	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
13098	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
13099	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
13100	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
13101	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
13102	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
13103	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
13104	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	419	
13105	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	419	
13106	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
13107	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
13108	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
13109	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13110	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13111	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13112	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13113	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13114	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
13115	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13116	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
13117	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13118	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13119	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
13120	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13121	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	0	
13122	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	0	
13123	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
13124	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
13125	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
13126	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13127	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13128	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13129	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13130	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13131	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13132	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13133	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13134	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments		
13135	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13136	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
13137	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13138	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
13139	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
13140	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
13141	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
13142	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
13143	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
13144	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
13145	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
13146	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
13147	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
13148	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
13149	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
13150	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
13151	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
13152	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?		
13153	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
13154	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
13155	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
13156	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	1439	
13157	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	6L	
13158	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
13159	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	3L	
13160	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
13161	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	32102	
13162	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	32100	
13163	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
13164	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
13165	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
13166	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
13167	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
13168	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
13169	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
13170	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
13171	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
13172	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
13173	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
13174	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
13175	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
13176	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
13177	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Middle fan of fan group 2 overheats and stops working	
13178	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
13179	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
13180	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
13181	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
13182	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
13183	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
13184	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
13185	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
13186	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
13187	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
13188	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
13189	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13190	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
13191	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
13192	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13193	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
13194	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
13195	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
13196	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
13197	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13198	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13199	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13200	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13201	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13202	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
13203	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13204	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
13205	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13206	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13207	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13208	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13209	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13210	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13211	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13212	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13213	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13214	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13215	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13216	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13217	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13218	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	3	
13219	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
13220	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
13221	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
13222	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	108.0	
13223	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	122.0	
13224	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	97.0	
13225	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
13226	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
13227	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
13228	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
13229	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
13230	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
13231	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13232	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
13233	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
13234	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
13235	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
13236	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
13237	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
13238	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
13239	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
13240	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
13241	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
13242	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
13243	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments	large number of bugs inside cabinet. removed as much as possible. will need sprayed	
13244	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
13245	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
13246	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
13247	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	165	
13248	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	165	
13249	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13250	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13251	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13252	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13253	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13254	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13255	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13256	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13257	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13258	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13259	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13260	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13261	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13262	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
13263	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13264	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
13265	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
13266	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
13267	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	120.3	VAC
13268	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
13269	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	General Comments		
13270	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
13271	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	LTC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
13272	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
13273	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
13274	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
13275	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
13276	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13277	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCCControl	636-1	LTC Control Insp	General Comments		
13278	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
13279	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCCControl	636-1	LTC Control Insp	All Connections OK?	y	
13280	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13281	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
13282	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13283	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
13284	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13285	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13286	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13287	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13288	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13289	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
13290	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13291	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13292	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
13293	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
13294	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13295	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
13296	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13297	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13298	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13299	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13300	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13301	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13302	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13303	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
13304	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
13305	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
13306	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13307	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	A couple of trees are starting to have some limbs to grow over the top of the fence line at the back of the station.	
13308	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13309	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
13310	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13311	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13312	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13313	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
13314	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
13315	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
13316	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
13317	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
13318	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
13319	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
13320	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
13321	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	n	
13322	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
13323	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
13324	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
13325	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
13326	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
13327	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
13328	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
13329	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
13330	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
13331	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
13332	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
13333	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	191	
13334	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	191	
13335	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
13336	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
13337	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
13338	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
13339	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
13340	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
13341	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
13342	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
13343	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
13344	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
13345	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
13346	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
13347	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13348	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	253.0	
13349	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	249.0	
13350	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	200.0	
13351	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13352	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
13353	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
13354	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
13355	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
13356	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	General Comments		
13357	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
13358	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
13359	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
13360	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
13361	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	LTC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
13362	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	3	
13363	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
13364	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
13365	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
13366	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
13367	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
13368	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
13369	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
13370	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
13371	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
13372	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
13373	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
13374	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
13375	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
13376	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
13377	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
13378	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
13379	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
13380	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
13381	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
13382	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
13383	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
13384	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
13385	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13386	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
13387	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
13388	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
13389	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
13390	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
13391	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
13392	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	500.0	
13393	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	500.0	
13394	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	500.0	
13395	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
13396	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
13397	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
13398	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	6	
13399	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
13400	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
13401	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
13402	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13403	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13404	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
13405	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
13406	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13407	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13408	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13409	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
13410	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13411	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
13412	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
13413	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
13414	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
13415	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13416	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
13417	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13418	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13419	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13420	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13421	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13422	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
13423	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13424	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13425	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13426	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13427	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13428	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13429	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13430	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13431	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13432	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13433	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13434	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13435	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13436	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13437	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
13438	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13439	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
13440	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13441	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13442	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13443	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13444	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13445	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
13446	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13447	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
13448	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13449	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13450	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13451	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13452	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13453	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
13454	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13455	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
13456	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
13457	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
13458	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase....one structure leg foundation is crumbling and another is starting to	
13459	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13460	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
13461	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13462	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13463	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13464	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
13465	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
13466	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13467	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13468	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
13469	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
13470	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
13471	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
13472	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
13473	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
13474	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
13475	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
13476	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
13477	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
13478	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
13479	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
13480	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
13481	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
13482	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
13483	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
13484	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
13485	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
13486	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
13487	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
13488	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
13489	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
13490	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
13491	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
13492	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
13493	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
13494	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	0	
13495	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	225	
13496	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	225	
13497	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
13498	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
13499	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
13500	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
13501	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
13502	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
13503	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
13504	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
13505	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13506	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13507	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13508	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13509	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
13510	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13511	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
13512	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
13513	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
13514	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13515	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
13516	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13517	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13518	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13519	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
13520	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
13521	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
13522	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13523	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13524	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
13525	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
13526	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
13527	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
13528	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
13529	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
13530	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	512	
13531	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	512	
13532	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
13533	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
13534	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
13535	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
13536	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
13537	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
13538	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
13539	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
13540	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
13541	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
13542	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13543	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13544	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13545	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13546	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	280.0	
13547	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	200.0	
13548	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	210.0	
13549	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13550	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13551	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13552	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
13553	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
13554	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
13555	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13556	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13557	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13558	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13559	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13560	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13561	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13562	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13563	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13564	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13565	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13566	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13567	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13568	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13569	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13570	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
13571	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13572	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13573	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13574	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13575	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13576	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13577	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13578	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
13579	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13580	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13581	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13582	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13583	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13584	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
13585	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13586	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
13587	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
13588	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
13589	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
13590	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13591	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
13592	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13593	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13594	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13595	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
13596	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
13597	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13598	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13599	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
13600	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
13601	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
13602	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
13603	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13604	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13605	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13606	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
13607	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
13608	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13609	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
13610	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
13611	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13612	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13613	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
13614	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13615	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
13616	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13617	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
13618	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
13619	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13620	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13621	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
13622	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13623	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13624	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13625	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13626	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13627	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
13628	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
13629	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13630	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
13631	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
13632	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
13633	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
13634	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
13635	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
13636	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
13637	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
13638	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
13639	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13640	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13641	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
13642	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
13643	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
13644	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
13645	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
13646	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
13647	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
13648	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
13649	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
13650	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
13651	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
13652	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
13653	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
13654	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
13655	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
13656	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
13657	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
13658	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
13659	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
13660	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
13661	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
13662	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
13663	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
13664	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
13665	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
13666	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
13667	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
13668	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
13669	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
13670	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
13671	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
13672	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
13673	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
13674	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
13675	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
13676	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
13677	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
13678	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
13679	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
13680	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
13681	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
13682	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
13683	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
13684	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
13685	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	0	
13686	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13687	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13688	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13689	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	230.0	
13690	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	240.0	
13691	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	200.0	
13692	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13693	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13694	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13695	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13696	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
13697	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
13698	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13699	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
13700	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
13701	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
13702	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
13703	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
13704	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
13705	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
13706	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
13707	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
13708	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
13709	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
13710	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
13711	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
13712	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
13713	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
13714	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
13715	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
13716	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13717	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
13718	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
13719	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
13720	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
13721	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
13722	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
13723	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
13724	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
13725	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
13726	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13727	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
13728	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
13729	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
13730	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
13731	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
13732	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
13733	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
13734	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
13735	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
13736	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
13737	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
13738	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
13739	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
13740	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
13741	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
13742	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
13743	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
13744	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
13745	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
13746	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
13747	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
13748	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	y	
13749	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
13750	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
13751	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
13752	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
13753	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
13754	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
13755	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
13756	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
13757	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
13758	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
13759	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
13760	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
13761	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
13762	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
13763	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
13764	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
13765	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
13766	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
13767	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
13768	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
13769	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
13770	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
13771	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
13772	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
13773	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
13774	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
13775	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	171	
13776	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	171	
13777	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
13778	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
13779	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
13780	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
13781	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
13782	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
13783	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
13784	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
13785	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
13786	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
13787	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
13788	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
13789	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
13790	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
13791	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
13792	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
13793	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
13794	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
13795	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
13796	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
13797	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
13798	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
13799	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
13800	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
13801	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
13802	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
13803	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
13804	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
13805	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Oil leak from radiator and pump on same side as temp gauges. Pic sent to Stinson	
13806	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
13807	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
13808	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
13809	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
13810	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
13811	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
13812	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
13813	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
13814	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
13815	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
13816	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13817	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13818	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13819	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
13820	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
13821	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
13822	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13823	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13824	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13825	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
13826	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
13827	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
13828	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
13829	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
13830	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
13831	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
13832	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
13833	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
13834	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
13835	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	375	
13836	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	375	
13837	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
13838	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
13839	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
13840	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
13841	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
13842	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
13843	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
13844	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
13845	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
13846	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
13847	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13848	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13849	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13850	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13851	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	230.0	
13852	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	210.0	
13853	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	180.0	
13854	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13855	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13856	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13857	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	0	
13858	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
13859	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
13860	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
13861	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
13862	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	822	
13863	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
13864	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
13865	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
13866	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
13867	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
13868	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	17134	
13869	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	17134	
13870	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
13871	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
13872	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
13873	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
13874	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
13875	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
13876	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13877	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
13878	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
13879	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
13880	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
13881	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
13882	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
13883	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
13884	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
13885	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
13886	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
13887	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
13888	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
13889	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
13890	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	40	
13891	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
13892	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
13893	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
13894	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
13895	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
13896	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	6527	
13897	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	6527	
13898	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
13899	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
13900	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
13901	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
13902	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
13903	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
13904	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13905	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13906	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
13907	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
13908	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13909	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13910	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
13911	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
13912	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
13913	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
13914	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
13915	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
13916	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
13917	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
13918	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
13919	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
13920	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
13921	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
13922	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
13923	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
13924	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
13925	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
13926	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
13927	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
13928	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
13929	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
13930	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
13931	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
13932	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
13933	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
13934	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
13935	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
13936	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
13937	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
13938	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
13939	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13940	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
13941	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
13942	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
13943	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
13944	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
13945	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
13946	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
13947	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
13948	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
13949	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
13950	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
13951	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
13952	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
13953	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
13954	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
13955	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
13956	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
13957	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
13958	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
13959	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
13960	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
13961	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
13962	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
13963	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	892	
13964	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	892	
13965	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
13966	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
13967	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
13968	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
13969	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
13970	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
13971	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
13972	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
13973	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
13974	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
13975	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
13976	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
13977	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
13978	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	20	°C
13979	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	26	°C
13980	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.7860	
13981	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
13982	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
13983	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
13984	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
13985	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
13986	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
13987	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
13988	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
13989	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	22	°C
13990	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	28	°C
13991	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
13992	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
13993	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	5659.20	kw
13994	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
13995	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
13996	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
13997	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
13998	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
13999	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
14000	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14001	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
14002	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
14003	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14004	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14005	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14006	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14007	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14008	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14009	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14010	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
14011	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
14012	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
14013	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
14014	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
14015	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14016	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14017	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14018	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14019	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
14020	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
14021	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
14022	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
14023	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
14024	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
14025	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
14026	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	3R	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
14027	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
14028	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
14029	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14030	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
14031	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
14032	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14033	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
14034	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14035	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
14036	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
14037	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
14038	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
14039	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
14040	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
14041	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
14042	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
14043	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
14044	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
14045	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
14046	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
14047	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14048	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
14049	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	1	
14050	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
14051	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
14052	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
14053	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	284.0	
14054	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	268.0	
14055	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	278.0	
14056	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
14057	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
14058	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
14059	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
14060	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
14061	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
14062	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
14063	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
14064	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
14065	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
14066	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
14067	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
14068	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1946	
14069	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
14070	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14071	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
14072	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
14073	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
14074	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
14075	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
14076	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
14077	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14078	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14079	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
14080	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
14081	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
14082	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
14083	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
14084	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
14085	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
14086	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
14087	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
14088	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
14089	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
14090	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
14091	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
14092	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
14093	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
14094	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
14095	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
14096	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
14097	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
14098	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
14099	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
14100	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
14101	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14102	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
14103	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
14104	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
14105	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14106	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
14107	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
14108	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
14109	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
14110	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
14111	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
14112	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
14113	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
14114	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14115	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14116	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14117	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
14118	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
14119	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
14120	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
14121	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14122	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
14123	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14124	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14125	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
14126	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.8070	
14127	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	72	°C
14128	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	72	°C
14129	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
14130	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14131	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
14132	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
14133	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
14134	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
14135	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
14136	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
14137	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
14138	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
14139	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
14140	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
14141	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
14142	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14143	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50770	
14144	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
14145	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
14146	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
14147	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14148	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14149	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14150	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14151	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
14152	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
14153	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
14154	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32254	
14155	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14156	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
14157	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14158	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
14159	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
14160	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
14161	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
14162	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	162	
14163	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	162	
14164	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
14165	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
14166	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
14167	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
14168	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14169	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14170	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14171	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14172	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
14173	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	19	°C
14174	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	63	°C
14175	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	19	°C
14176	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14177	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	19	°C
14178	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	64	°C
14179	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
14180	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
14181	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14182	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14183	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
14184	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14185	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14186	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
14187	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14188	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	19	°C
14189	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
14190	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
14191	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
14192	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
14193	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
14194	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14195	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
14196	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
14197	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14198	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
14199	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
14200	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
14201	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments	oil seeping from Radiator. Pic sent to stinson	
14202	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
14203	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
14204	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
14205	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
14206	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
14207	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
14208	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
14209	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
14210	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
14211	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
14212	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
14213	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
14214	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	324.0	
14215	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	463.0	
14216	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	421.0	
14217	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
14218	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
14219	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
14220	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
14221	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
14222	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
14223	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
14224	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
14225	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
14226	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
14227	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
14228	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
14229	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
14230	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14231	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14232	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14233	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
14234	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
14235	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
14236	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14237	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
14238	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
14239	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
14240	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
14241	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
14242	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
14243	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
14244	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
14245	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
14246	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
14247	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14248	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	43	°C
14249	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
14250	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43674	
14251	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14252	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
14253	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
14254	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14255	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14256	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
14257	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
14258	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
14259	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
14260	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14261	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
14262	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
14263	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14264	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
14265	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14266	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14267	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14268	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14269	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
14270	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
14271	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
14272	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14273	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14274	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29184	
14275	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
14276	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
14277	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
14278	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
14279	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
14280	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
14281	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
14282	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
14283	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
14284	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
14285	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
14286	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
14287	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
14288	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14289	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14290	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
14291	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
14292	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14293	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
14294	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
14295	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
14296	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
14297	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
14298	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	80.0	
14299	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	20.0	
14300	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
14301	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
14302	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
14303	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
14304	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
14305	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
14306	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
14307	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
14308	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
14309	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
14310	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
14311	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
14312	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14313	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
14314	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14315	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14316	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
14317	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
14318	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
14319	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
14320	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
14321	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
14322	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
14323	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
14324	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
14325	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
14326	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14327	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
14328	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
14329	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
14330	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
14331	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
14332	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
14333	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
14334	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
14335	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
14336	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
14337	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	295	
14338	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	295	
14339	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	198	
14340	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	198	
14341	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	0	
14342	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
14343	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	0	
14344	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
14345	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
14346	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
14347	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
14348	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
14349	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
14350	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
14351	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
14352	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
14353	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments	open	
14354	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
14355	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
14356	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	112	
14357	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
14358	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
14359	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
14360	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14361	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14362	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14363	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	11	
14364	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
14365	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14366	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
14367	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
14368	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14369	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
14370	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
14371	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	45090	
14372	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	45095	
14373	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14374	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	8L	
14375	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	3L	
14376	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
14377	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
14378	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
14379	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
14380	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
14381	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
14382	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
14383	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
14384	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	10L	
14385	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
14386	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	1990	
14387	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14388	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14389	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14390	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
14391	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
14392	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
14393	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
14394	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
14395	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
14396	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
14397	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14398	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14399	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14400	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
14401	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A5 Found Float Voltage	54.9	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
14402	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
14403	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
14404	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
14405	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14406	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14407	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14408	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14409	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
14410	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
14411	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14412	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
14413	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
14414	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
14415	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
14416	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
14417	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
14418	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
14419	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
14420	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
14421	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
14422	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
14423	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
14424	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
14425	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
14426	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	100.0	
14427	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1447	
14428	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
14429	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
14430	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
14431	12/13/2019 13:12	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
14432	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
14433	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	5592.96	kw
14434	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
14435	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14436	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14437	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14438	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14439	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14440	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
14441	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
14442	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14443	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
14444	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
14445	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
14446	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
14447	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
14448	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
14449	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
14450	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
14451	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14452	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14453	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14454	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14455	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14456	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14457	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14458	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
14459	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
14460	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14461	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
14462	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
14463	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14464	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
14465	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
14466	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
14467	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
14468	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
14469	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	14526.00	kw
14470	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
14471	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
14472	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	60	°C
14473	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	40	°C
14474	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14475	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
14476	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14477	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
14478	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
14479	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
14480	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
14481	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
14482	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
14483	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
14484	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
14485	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
14486	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
14487	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
14488	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
14489	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
14490	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
14491	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
14492	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.2	AMPS
14493	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
14494	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
14495	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
14496	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
14497	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
14498	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
14499	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
14500	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Eyewash Solution	Good	
14501	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
14502	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.10	MegaWatts
14503	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.60	MegaWatts
14504	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.50	MegaVars
14505	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
14506	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	0	
14507	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
14508	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
14509	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
14510	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
14511	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
14512	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
14513	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
14514	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
14515	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
14516	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14517	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
14518	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14519	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
14520	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
14521	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
14522	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
14523	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
14524	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
14525	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14526	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
14527	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
14528	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14529	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
14530	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
14531	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
14532	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
14533	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
14534	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
14535	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
14536	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
14537	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
14538	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
14539	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
14540	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
14541	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
14542	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
14543	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
14544	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	50.0	
14545	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
14546	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14547	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14548	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	30.0	
14549	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	50.0	
14550	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
14551	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14552	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
14553	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	1	
14554	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
14555	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
14556	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
14557	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
14558	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14559	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
14560	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
14561	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	39641	
14562	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14563	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14564	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
14565	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
14566	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
14567	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
14568	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14569	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
14570	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments		Guage hands will not reset
14571	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
14572	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Stround in Place?	y	
14573	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
14574	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14575	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14576	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14577	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14578	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
14579	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.5826	
14580	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
14581	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14582	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
14583	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
14584	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
14585	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
14586	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
14587	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	193960	
14588	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	193952	
14589	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
14590	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
14591	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14592	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
14593	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
14594	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
14595	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14596	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14597	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32292	
14598	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
14599	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
14600	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
14601	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14602	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14603	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
14604	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
14605	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
14606	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
14607	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14608	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
14609	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
14610	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14611	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
14612	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14613	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14614	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14615	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14616	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
14617	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
14618	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
14619	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
14620	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
14621	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
14622	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14623	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
14624	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	4L	
14625	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14626	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14627	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14628	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
14629	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
14630	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
14631	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
14632	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14633	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14634	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
14635	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
14636	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
14637	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
14638	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
14639	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
14640	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
14641	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
14642	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
14643	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
14644	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
14645	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
14646	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
14647	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
14648	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
14649	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
14650	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
14651	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	*C
14652	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	30	*C
14653	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14654	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
14655	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
14656	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
14657	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
14658	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
14659	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
14660	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14661	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14662	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	17484	
14663	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	17488	
14664	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14665	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	10L	
14666	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
14667	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
14668	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
14669	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
14670	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
14671	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
14672	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	General Comments		
14673	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
14674	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
14675	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
14676	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
14677	12/13/2019 9:14	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
14678	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
14679	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
14680	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
14681	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
14682	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
14683	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
14684	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
14685	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
14686	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
14687	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
14688	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
14689	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments	tower leg foundations crumbling, as well as transformer	
14690	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
14691	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
14692	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
14693	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
14694	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
14695	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
14696	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
14697	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14698	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	698	
14699	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
14700	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
14701	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
14702	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
14703	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
14704	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
14705	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
14706	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14707	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
14708	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
14709	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
14710	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
14711	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14712	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14713	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14714	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
14715	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
14716	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
14717	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14718	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14719	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28114	
14720	12/13/2019 12:33	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
14721	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14722	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
14723	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
14724	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
14725	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36131	
14726	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
14727	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
14728	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
14729	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
14730	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
14731	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
14732	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
14733	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
14734	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
14735	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
14736	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
14737	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
14738	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
14739	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
14740	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
14741	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
14742	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
14743	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
14744	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
14745	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
14746	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
14747	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
14748	12/13/2019 10:58	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
14749	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
14750	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14751	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
14752	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
14753	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
14754	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
14755	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
14756	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
14757	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14758	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14759	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
14760	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
14761	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
14762	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14763	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
14764	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
14765	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14766	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
14767	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
14768	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14769	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14770	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
14771	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
14772	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
14773	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14774	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
14775	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14776	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR00025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14777	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
14778	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14779	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
14780	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14781	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14782	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14783	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14784	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
14785	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
14786	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
14787	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
14788	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
14789	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
14790	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
14791	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
14792	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	870	
14793	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
14794	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	1R	
14795	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	2L	
14796	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14797	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
14798	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
14799	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
14800	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5734.08	kw
14801	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
14802	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
14803	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
14804	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14805	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
14806	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
14807	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14808	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
14809	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
14810	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
14811	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
14812	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.20	MegaWatts
14813	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	1.00	MegaWatts
14814	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
14815	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14816	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14817	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
14818	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
14819	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
14820	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
14821	12/13/2019 11:12	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14822	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
14823	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
14824	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	49	
14825	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	49	
14826	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
14827	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
14828	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
14829	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	74358	
14830	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	74358	
14831	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14832	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
14833	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
14834	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
14835	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
14836	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	5156	
14837	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
14838	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14839	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14840	12/13/2019 9:31	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
14841	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14842	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
14843	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14844	12/13/2019 12:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	5167	
14845	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	821	
14846	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
14847	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	9L	
14848	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14849	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	55717	
14850	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14851	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
14852	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
14853	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	55717	
14854	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14855	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
14856	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
14857	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14858	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14859	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14860	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14861	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
14862	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	741	
14863	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	53	*C
14864	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	1R	
14865	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	12L	
14866	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1432	
14867	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
14868	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
14869	12/16/2019 9:41	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
14870	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
14871	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
14872	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14873	12/13/2019 13:01	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
14874	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14875	12/13/2019 11:04	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14876	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
14877	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3774	
14878	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	370.0	
14879	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
14880	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
14881	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	35	*C
14882	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
14883	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
14884	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
14885	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	35	*C
14886	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
14887	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
14888	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1811.52	kw
14889	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
14890	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
14891	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
14892	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments		
14893	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments		
14894	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14895	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	405.0	
14896	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	395.0	
14897	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
14898	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
14899	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
14900	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
14901	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
14902	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14903	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
14904	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
14905	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
14906	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
14907	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
14908	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
14909	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14910	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14911	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
14912	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments		
14913	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
14914	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
14915	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
14916	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
14917	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
14918	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
14919	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
14920	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
14921	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
14922	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
14923	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
14924	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
14925	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
14926	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
14927	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	25873	
14928	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
14929	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
14930	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
14931	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
14932	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
14933	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
14934	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
14935	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
14936	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
14937	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
14938	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
14939	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
14940	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
14941	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
14942	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
14943	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
14944	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
14945	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
14946	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
14947	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
14948	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
14949	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
14950	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
14951	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
14952	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
14953	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
14954	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
14955	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
14956	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
14957	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.5646	
14958	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	35	*C
14959	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	25	*C
14960	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	310.00	
14961	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
14962	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
14963	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
14964	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
14965	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	864	
14966	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	12L	
14967	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	3L	
14968	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	6L	
14969	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
14970	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	24811	
14971	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	24811	
14972	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
14973	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
14974	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
14975	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
14976	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
14977	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
14978	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
14979	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
14980	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
14981	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
14982	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
14983	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
14984	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
14985	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
14986	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
14987	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
14988	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
14989	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
14990	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
14991	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
14992	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
14993	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
14994	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
14995	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
14996	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments		
14997	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
14998	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
14999	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
15000	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
15001	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
15002	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
15003	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
15004	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
15005	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
15006	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	2	
15007	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15008	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15009	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
15010	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	100.0	
15011	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	100.0	
15012	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
15013	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
15014	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
15015	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
15016	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
15017	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
15018	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
15019	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
15020	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
15021	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
15022	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments		
15023	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
15024	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
15025	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
15026	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
15027	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
15028	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
15029	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
15030	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
15031	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25760	
15032	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
15033	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
15034	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
15035	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
15036	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
15037	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
15038	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
15039	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
15040	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments		
15041	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
15042	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
15043	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
15044	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
15045	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
15046	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	80.0	
15047	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
15048	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15049	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15050	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15051	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15052	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15053	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15054	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	3.67	
15055	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	3.67	
15056	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
15057	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
15058	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
15059	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
15060	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
15061	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
15062	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
15063	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
15064	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	10162.80	kw
15065	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
15066	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
15067	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
15068	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
15069	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
15070	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
15071	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
15072	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
15073	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
15074	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
15075	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
15076	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15077	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments		
15078	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
15079	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
15080	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
15081	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
15082	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
15083	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
15084	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
15085	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
15086	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	25987	
15087	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
15088	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
15089	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	25	°C
15090	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
15091	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
15092	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
15093	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
15094	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
15095	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
15096	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
15097	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
15098	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
15099	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
15100	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
15101	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
15102	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
15103	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
15104	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
15105	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
15106	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
15107	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	25	°C
15108	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
15109	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
15110	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
15111	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
15112	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
15113	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
15114	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	164	
15115	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	164	
15116	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
15117	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
15118	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15119	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
15120	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
15121	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
15122	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
15123	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
15124	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
15125	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
15126	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
15127	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
15128	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
15129	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15130	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
15131	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
15132	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.0	VDC
15133	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.0	VDC
15134	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
15135	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
15136	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
15137	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
15138	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
15139	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
15140	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
15141	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
15142	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99952	
15143	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99952	
15144	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	2	
15145	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
15146	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
15147	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
15148	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	2	
15149	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15150	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15151	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15152	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15153	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15154	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15155	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15156	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	3.67	
15157	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
15158	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
15159	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
15160	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
15161	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
15162	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
15163	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
15164	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments		
15165	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments		
15166	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
15167	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15168	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
15169	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
15170	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
15171	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
15172	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
15173	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
15174	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
15175	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
15176	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
15177	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments		
15178	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
15179	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
15180	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
15181	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
15182	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
15183	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
15184	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
15185	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
15186	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
15187	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
15188	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
15189	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
15190	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
15191	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
15192	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
15193	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments		
15194	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
15195	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
15196	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
15197	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
15198	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
15199	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
15200	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
15201	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
15202	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
15203	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
15204	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
15205	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
15206	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
15207	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments		
15208	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments		
15209	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
15210	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
15211	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments		
15212	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments		
15213	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
15214	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
15215	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
15216	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	1	
15217	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
15218	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
15219	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
15220	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
15221	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
15222	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
15223	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15224	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15225	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15226	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15227	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15228	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15229	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
15230	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	50.0	
15231	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	20.0	
15232	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	20.0	
15233	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
15234	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15235	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15236	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	5	
15237	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
15238	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
15239	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2205.36	kw
15240	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
15241	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
15242	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
15243	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
15244	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
15245	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
15246	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
15247	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
15248	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
15249	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
15250	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
15251	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
15252	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6126	
15253	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
15254	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
15255	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
15256	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
15257	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
15258	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
15259	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
15260	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
15261	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
15262	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
15263	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
15264	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
15265	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
15266	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
15267	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
15268	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
15269	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
15270	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
15271	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
15272	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
15273	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
15274	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
15275	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
15276	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments		
15277	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments		
15278	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
15279	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15280	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	0	
15281	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
15282	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	155	
15283	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	155	
15284	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	0	
15285	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
15286	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
15287	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
15288	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
15289	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
15290	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
15291	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
15292	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	2	
15293	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	195	
15294	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	195	
15295	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
15296	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	1	
15297	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15298	12/12/2019 11:25	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
15299	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
15300	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
15301	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15302	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
15303	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
15304	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
15305	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	General Comments		
15306	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
15307	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
15308	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
15309	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
15310	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
15311	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
15312	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
15313	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
15314	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
15315	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
15316	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
15317	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
15318	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
15319	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
15320	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
15321	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
15322	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15323	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
15324	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	90.0	
15325	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	105.0	
15326	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	125.0	
15327	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
15328	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15329	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15330	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	4	
15331	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
15332	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
15333	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
15334	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
15335	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
15336	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
15337	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
15338	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
15339	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
15340	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
15341	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments		
15342	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
15343	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
15344	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
15345	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
15346	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
15347	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
15348	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
15349	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
15350	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	97093	
15351	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
15352	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
15353	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
15354	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
15355	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
15356	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
15357	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
15358	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
15359	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	96413	
15360	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
15361	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
15362	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
15363	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
15364	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
15365	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
15366	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
15367	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
15368	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments		
15369	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
15370	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
15371	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
15372	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
15373	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
15374	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
15375	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
15376	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15377	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
15378	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
15379	12/12/2019 11:25	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
15380	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
15381	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
15382	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
15383	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
15384	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
15385	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
15386	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
15387	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
15388	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
15389	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
15390	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
15391	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
15392	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
15393	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
15394	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
15395	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
15396	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
15397	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
15398	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
15399	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
15400	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
15401	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
15402	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
15403	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
15404	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
15405	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
15406	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
15407	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
15408	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
15409	12/12/2019 11:25	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
15410	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
15411	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
15412	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	0	
15413	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
15414	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	0	
15415	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1046	
15416	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1046	
15417	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
15418	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
15419	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15420	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
15421	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
15422	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
15423	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
15424	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
15425	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
15426	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
15427	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
15428	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
15429	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
15430	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15431	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15432	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15433	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15434	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15435	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15436	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15437	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15438	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
15439	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
15440	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
15441	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
15442	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
15443	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
15444	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
15445	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
15446	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments		
15447	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
15448	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
15449	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
15450	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
15451	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15452	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
15453	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
15454	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
15455	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments		
15456	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
15457	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
15458	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
15459	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
15460	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
15461	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
15462	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
15463	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
15464	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
15465	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
15466	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
15467	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
15468	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
15469	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
15470	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
15471	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
15472	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
15473	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
15474	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
15475	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
15476	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
15477	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
15478	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
15479	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
15480	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	211	
15481	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	211	
15482	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	0	
15483	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	0	
15484	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
15485	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
15486	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
15487	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
15488	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
15489	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
15490	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
15491	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
15492	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
15493	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
15494	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
15495	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
15496	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
15497	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
15498	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
15499	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments		
15500	12/12/2019 11:25	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
15501	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
15502	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Good Condition?	y	
15503	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
15504	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
15505	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
15506	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
15507	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
15508	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
15509	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
15510	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
15511	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
15512	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15513	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15514	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15515	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15516	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15517	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15518	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15519	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15520	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15521	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
15522	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
15523	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	10	
15524	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15525	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15526	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15527	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	265.0	
15528	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	305.0	
15529	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
15530	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
15531	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
15532	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
15533	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
15534	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	285.0	
15535	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
15536	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
15537	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
15538	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
15539	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	58852	
15540	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
15541	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
15542	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
15543	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15544	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15545	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15546	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15547	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
15548	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
15549	12/12/2019 11:25	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
15550	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
15551	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15552	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15553	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15554	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15555	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
15556	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
15557	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
15558	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
15559	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
15560	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
15561	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
15562	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
15563	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments		
15564	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
15565	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
15566	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
15567	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
15568	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	0	
15569	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
15570	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
15571	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
15572	12/12/2019 11:25	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
15573	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15574	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15575	12/12/2019 12:09	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
15576	12/12/2019 10:00	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
15577	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
15578	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
15579	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds In Place?	y	
15580	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
15581	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
15582	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
15583	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
15584	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	259	
15585	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
15586	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
15587	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	252	
15588	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.0	
15589	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.0	
15590	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.0	
15591	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	329	
15592	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B phase IOC	
15593	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
15594	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	78	
15595	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	78	
15596	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
15597	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
15598	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
15599	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
15600	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
15601	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
15752	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
15753	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
15754	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
15755	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
15756	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
15757	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15758	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	207	
15759	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	207	
15760	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
15761	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments		
15762	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments		
15763	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	618	
15764	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
15765	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
15766	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15767	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15768	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
15769	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
15770	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15771	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
15772	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
15773	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15774	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15775	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	
15776	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
15777	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
15778	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
15779	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
15780	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
15781	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	
15782	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
15783	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
15784	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
15785	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
15786	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	170	
15787	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	170	
15788	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
15789	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
15790	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	0	
15791	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
15792	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
15793	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
15794	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
15795	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
15796	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
15797	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15798	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15799	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15800	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
15801	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
15802	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
15803	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
15804	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
15805	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
15806	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
15807	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
15808	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
15809	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15810	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	0	
15811	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
15812	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
15813	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	50	°C
15814	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	50	°C
15815	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	1.0158	
15816	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
15817	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
15818	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
15819	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
15820	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
15821	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
15822	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
15823	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
15824	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
15825	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
15826	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15827	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
15828	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
15829	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
15830	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
15831	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
15832	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
15833	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
15834	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
15835	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
15836	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
15837	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
15838	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
15839	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
15840	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
15841	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
15842	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
15843	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
15844	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
15845	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
15846	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
15847	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
15848	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
15849	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
15850	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
15851	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
15852	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
15853	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
15854	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
15855	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
15856	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
15857	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
15858	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
15859	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
15860	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
15861	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
15862	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	14627.52	kw
15863	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
15864	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
15865	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7962	
15866	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
15867	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
15868	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	50	*C
15869	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	45	*C
15870	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
15871	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
15872	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
15873	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
15874	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
15875	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
15876	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
15877	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
15878	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
15879	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	5L	
15880	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
15881	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
15882	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
15883	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
15884	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
15885	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
15886	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
15887	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
15888	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
15889	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
15890	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
15891	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	180.0	
15892	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	220.0	
15893	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
15894	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	73765	
15895	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
15896	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
15897	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
15898	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
15899	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15900	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15901	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
15902	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15903	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15904	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15905	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15906	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
15907	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
15908	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
15909	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	73765	
15910	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
15911	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
15912	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
15913	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	8R	
15914	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	11L	
15915	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
15916	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	955.44	kw
15917	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
15918	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
15919	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments		
15920	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments		
15921	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
15922	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
15923	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
15924	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
15925	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	General Comments	BREAKER OPEN	
15926	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
15927	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
15928	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
15929	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
15930	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
15931	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
15932	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
15933	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
15934	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
15935	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
15936	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	2	
15937	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
15938	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
15939	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
15940	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
15941	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
15942	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
15943	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15944	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15945	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15946	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15947	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
15948	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
15949	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
15950	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
15951	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
15952	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
15953	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
15954	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
15955	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
15956	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
15957	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
15958	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99985	
15959	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99985	
15960	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
15961	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
15962	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
15963	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
15964	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
15965	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
15966	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
15967	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
15968	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
15969	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
15970	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
15971	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
15972	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
15973	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	0	
15974	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
15975	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
15976	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
15977	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
15978	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
15979	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
15980	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
15981	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	509.0	
15982	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	513.0	
15983	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
15984	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	0	
15985	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
15986	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
15987	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
15988	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
15989	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
15990	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
15991	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
15992	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
15993	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
15994	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
15995	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
15996	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
15997	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
15998	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	522.0	
15999	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16000	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16001	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16002	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	0	
16003	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16004	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16005	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16006	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
16007	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
16008	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
16009	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
16010	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
16011	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
16012	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
16013	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	975	
16014	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
16015	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
16016	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	2	
16017	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16018	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16019	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16020	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	136.0	
16021	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	152.0	
16022	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	166.0	
16023	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
16024	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	140	
16025	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	140	
16026	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	0	
16027	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
16028	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
16029	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
16030	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
16031	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16032	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16033	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16034	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16035	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16036	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
16037	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
16038	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
16039	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	179	
16040	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	179	
16041	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	0	
16042	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16043	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
16044	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
16045	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
16046	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	188	
16047	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
16048	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
16049	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments		
16050	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16051	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16052	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
16053	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
16054	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
16055	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
16056	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
16057	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
16058	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
16059	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
16060	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
16061	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
16062	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16063	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
16064	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
16065	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	214	
16066	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	214	
16067	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	1	
16068	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16069	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	1	
16070	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
16071	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
16072	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
16073	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
16074	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
16075	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
16076	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
16077	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
16078	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	20	°C
16079	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	20	°C
16080	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
16081	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
16082	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
16083	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
16084	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
16085	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
16086	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
16087	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
16088	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
16089	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	20	°C
16090	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	20	°C
16091	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
16092	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
16093	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
16094	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
16095	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	11952.00	kw
16096	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
16097	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
16098	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
16099	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
16100	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
16101	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
16102	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
16103	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
16104	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
16105	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
16106	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
16107	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
16108	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
16109	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
16110	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
16111	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
16112	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
16113	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
16114	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
16115	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
16116	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
16117	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
16118	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
16119	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
16120	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
16121	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
16122	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	2	
16123	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16124	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16125	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16126	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	118.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
16127	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	110.0	
16128	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	100.0	
16129	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
16130	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16131	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16132	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16133	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16134	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16135	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16136	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16137	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
16138	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
16139	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
16140	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
16141	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
16142	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
16143	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
16144	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
16145	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
16146	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
16147	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
16148	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
16149	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
16150	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
16151	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
16152	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
16153	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
16154	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
16155	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
16156	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
16157	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
16158	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	1	
16159	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16160	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16161	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16162	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	61.0	
16163	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	75.0	
16164	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	75.0	
16165	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
16166	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16167	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16168	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16169	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16170	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16171	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16172	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16173	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16174	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16175	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
16176	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
16177	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
16178	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
16179	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
16180	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
16181	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
16182	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
16183	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
16184	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
16185	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
16186	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
16187	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	LTCC000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
16188	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
16189	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16190	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16191	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16192	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	501.0	
16193	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	545.0	
16194	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	487.0	
16195	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
16196	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16197	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16198	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16199	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16200	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16201	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
16202	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16203	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16204	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16205	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
16206	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
16207	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
16208	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
16209	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
16210	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
16211	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
16212	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
16213	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
16214	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
16215	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16216	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
16217	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
16218	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
16219	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
16220	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
16221	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16222	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
16223	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
16224	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16225	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16226	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16227	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480.0	
16228	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480.0	
16229	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	480.0	
16230	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
16231	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16232	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16233	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16234	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16235	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16236	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16237	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16238	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16239	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	1	
16240	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16241	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16242	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16243	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	120.0	
16244	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	110.0	
16245	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	110.0	
16246	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
16247	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16248	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16249	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16250	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16251	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16252	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16253	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16254	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16255	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16256	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
16257	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
16258	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
16259	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
16260	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
16261	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
16262	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
16263	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16264	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
16265	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
16266	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
16267	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
16268	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
16269	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
16270	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	87	
16271	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	87	
16272	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
16273	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		
16274	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
16275	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
16276	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16277	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
16278	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
16279	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
16280	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
16281	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16282	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16283	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16284	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16285	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
16286	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
16287	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
16288	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16289	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16290	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16291	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	0	
16292	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
16293	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
16294	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
16295	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
16296	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
16297	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
16298	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
16299	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
16300	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
16301	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
16302	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
16303	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
16304	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
16305	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
16306	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
16307	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
16308	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
16309	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
16310	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B80419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
16311	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
16312	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
16313	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
16314	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
16315	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
16316	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
16317	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
16318	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
16319	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
16320	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
16321	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
16322	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
16323	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
16324	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
16325	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
16326	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
16327	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
16328	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
16329	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
16330	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
16331	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
16332	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
16333	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
16334	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
16335	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
16336	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
16337	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
16338	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
16339	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
16340	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	35	°C
16341	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	55	°C
16342	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.8300	
16343	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
16344	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
16345	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
16346	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
16347	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
16348	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
16349	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
16350	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
16351	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16352	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
16353	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
16354	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
16355	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
16356	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
16357	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
16358	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
16359	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16360	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
16361	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
16362	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	158	
16363	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	158	
16364	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
16365	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16366	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
16367	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
16368	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
16369	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
16370	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
16371	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
16372	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
16373	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
16374	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
16375	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
16376	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16377	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	1	
16378	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
16379	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	182	
16380	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	182	
16381	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	1	
16382	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
16383	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
16384	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	0	
16385	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
16386	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
16387	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
16388	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
16389	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
16390	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
16391	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
16392	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
16393	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
16394	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
16395	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
16396	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
16397	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
16398	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
16399	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
16400	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
16401	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	0	
16402	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16403	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	0	
16404	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
16405	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
16406	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
16407	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
16408	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
16409	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
16410	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
16411	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
16412	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
16413	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
16414	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
16415	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
16416	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
16417	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
16418	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
16419	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
16420	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
16421	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
16422	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
16423	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
16424	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
16425	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
16426	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16427	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	310190	
16428	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
16429	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
16430	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
16431	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
16432	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
16433	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
16434	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
16435	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
16436	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments		
16437	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
16438	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
16439	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
16440	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
16441	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
16442	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
16443	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
16444	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
16445	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
16446	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
16447	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
16448	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
16449	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	98	
16450	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	98	
16451	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
16452	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
16453	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
16454	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	0	
16455	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16456	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16457	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16458	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
16459	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
16460	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
16461	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16462	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16463	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16464	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16465	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
16466	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
16467	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
16468	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
16469	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
16470	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
16471	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
16472	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	8841	
16473	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
16474	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	5L	
16475	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	2L	
16476	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	11L	
16477	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
16478	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
16479	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	169	
16480	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	169	
16481	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
16482	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
16483	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
16484	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	709	
16485	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
16486	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16487	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16488	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	220.0	
16489	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16490	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16491	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16492	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16493	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16494	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16495	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16496	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
16497	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
16498	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
16499	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
16500	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
16501	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16502	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
16503	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
16504	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
16505	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
16506	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16507	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
16508	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
16509	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	274	
16510	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	274	
16511	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	0	
16512	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16513	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	0	
16514	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
16515	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
16516	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
16517	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
16518	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
16519	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	170	
16520	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	170	
16521	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
16522	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
16523	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
16524	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
16525	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
16526	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
16527	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
16528	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
16529	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
16530	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
16531	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
16532	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
16533	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
16534	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
16535	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
16536	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
16537	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
16538	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
16539	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
16540	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
16541	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
16542	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
16543	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	112779	
16544	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	112779	
16545	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
16546	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	2L	
16547	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
16548	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	8L	
16549	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
16550	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	678	
16551	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
16552	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
16553	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
16554	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
16555	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
16556	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
16557	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
16558	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	21550	
16559	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	21550	
16560	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
16561	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	11L	
16562	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	4	
16563	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16564	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16565	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16566	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	150.0	
16567	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	180.0	
16568	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	180.0	
16569	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
16570	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16571	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16572	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	5	
16573	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16574	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
16575	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
16576	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16577	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
16578	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
16579	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
16580	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
16581	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
16582	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
16583	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
16584	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
16585	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
16586	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
16587	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
16588	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
16589	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
16590	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
16591	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
16592	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
16593	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16594	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16595	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16596	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
16597	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
16598	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
16599	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
16600	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
16601	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
16602	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
16603	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
16604	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
16605	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	145	
16606	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	145	
16607	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
16608	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
16609	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
16610	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
16611	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
16612	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
16613	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
16614	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	370476	
16615	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
16616	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
16617	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
16618	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
16619	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
16620	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
16621	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
16622	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16623	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
16624	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
16625	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	210	
16626	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	210	
16627	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
16628	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
16629	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
16630	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
16631	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
16632	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
16633	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
16634	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
16635	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
16636	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
16637	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
16638	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
16639	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
16640	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
16641	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
16642	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
16643	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
16644	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
16645	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
16646	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
16647	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
16648	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
16649	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
16650	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	0	
16651	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
16652	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16653	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16654	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
16655	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
16656	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
16657	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16658	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
16659	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
16660	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
16661	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
16662	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Vent fan is not working	
16663	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
16664	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
16665	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
16666	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
16667	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
16668	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
16669	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
16670	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
16671	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
16672	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
16673	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
16674	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
16675	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
16676	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
16677	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
16678	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
16679	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
16680	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
16681	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16682	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16683	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16684	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16685	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	134.0	
16686	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	135.0	
16687	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	135.0	
16688	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16689	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16690	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16691	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	0	
16692	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	0	
16693	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16694	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16695	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16696	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	520.0	
16697	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	506.0	
16698	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	506.0	
16699	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16700	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16701	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16702	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16703	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
16704	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
16705	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
16706	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
16707	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
16708	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
16709	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
16710	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
16711	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments		
16712	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
16713	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
16714	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
16715	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
16716	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
16717	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
16718	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
16719	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
16720	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
16721	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
16722	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
16723	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
16724	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
16725	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
16726	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	8841	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16727	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
16728	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
16729	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
16730	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
16731	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
16732	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
16733	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
16734	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
16735	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
16736	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
16737	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
16738	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	0	
16739	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	146	
16740	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
16741	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
16742	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
16743	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
16744	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
16745	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
16746	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
16747	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
16748	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
16749	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	0	
16750	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
16751	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
16752	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
16753	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
16754	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
16755	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
16756	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
16757	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
16758	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
16759	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
16760	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
16761	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
16762	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
16763	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
16764	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
16765	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16766	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
16767	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
16768	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
16769	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
16770	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
16771	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16772	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
16773	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
16774	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
16775	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
16776	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
16777	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
16778	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16779	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16780	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16781	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
16782	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
16783	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
16784	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16785	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16786	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16787	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16788	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
16789	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
16790	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
16791	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
16792	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
16793	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	
16794	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments		
16795	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments		
16796	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
16797	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	158	
16798	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
16799	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
16800	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
16801	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16802	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
16803	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
16804	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
16805	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
16806	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
16807	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
16808	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
16809	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
16810	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
16811	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
16812	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
16813	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
16814	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
16815	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
16816	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
16817	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
16818	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
16819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	0	
16820	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
16821	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
16822	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
16823	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
16824	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
16825	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
16826	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	95	
16827	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	95	
16828	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
16829	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		
16830	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
16831	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
16832	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
16833	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
16834	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
16835	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
16836	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
16837	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16838	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16839	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16840	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16841	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	0.0	
16842	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
16843	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
16844	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
16845	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
16846	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
16847	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
16848	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
16849	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	238	
16850	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	238	
16851	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	1	
16852	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
16853	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	1	
16854	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
16855	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
16856	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
16857	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
16858	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
16859	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
16860	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
16861	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
16862	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	174	
16863	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	174	
16864	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
16865	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
16866	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
16867	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
16868	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
16869	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
16870	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
16871	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
16872	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
16873	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16874	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16875	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16876	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16877	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	149.0	
16878	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	148.0	
16879	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	148.0	
16880	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16881	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16882	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16883	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	0	
16884	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
16885	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
16886	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
16887	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
16888	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
16889	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
16890	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
16891	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
16892	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
16893	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments		
16894	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
16895	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
16896	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	158	
16897	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations This Read Vac	0	
16898	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
16899	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
16900	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
16901	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
16902	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
16903	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
16904	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16905	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16906	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16907	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16908	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16909	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16910	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16911	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16912	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16913	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	381.0	
16914	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	419.0	
16915	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	380.0	
16916	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
16917	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16918	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
16919	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
16920	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
16921	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
16922	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
16923	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
16924	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
16925	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
16926	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
16927	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
16928	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
16929	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
16930	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
16931	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
16932	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
16933	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
16934	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
16935	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
16936	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
16937	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
16938	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
16939	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
16940	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80277	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
16941	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
16942	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
16943	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
16944	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
16945	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
16946	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
16947	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
16948	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
16949	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	30	*C
16950	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	45	*C
16951	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.6040	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
16952	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
16953	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Present	27	°C
16954	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
16955	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
16956	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
16957	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
16958	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
16959	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
16960	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
16961	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
16962	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
16963	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
16964	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	10872.00	kw
16965	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
16966	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
16967	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
16968	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
16969	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
16970	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
16971	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
16972	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
16973	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
16974	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
16975	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
16976	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
16977	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
16978	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
16979	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
16980	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
16981	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
16982	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
16983	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
16984	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
16985	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
16986	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
16987	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
16988	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
16989	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
16990	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
16991	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
16992	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
16993	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
16994	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
16995	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
16996	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
16997	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
16998	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
16999	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
17000	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
17001	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	%
17002	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	%
17003	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	%
17004	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17005	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
17006	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
17007	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
17008	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
17009	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
17010	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
17011	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
17012	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
17013	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
17014	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17015	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17016	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17017	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	4	
17018	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
17019	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	6	
17020	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	27	°F
17021	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
17022	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
17023	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
17024	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
17025	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
17026	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
17027	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
17028	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
17029	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
17030	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
17031	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
17032	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
17033	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
17034	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
17035	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
17036	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
17037	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	0	
17038	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	50	
17039	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	50	
17040	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
17041	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
17042	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	80	psi
17043	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
17044	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
17045	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments	ok	
17046	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	1 Trip check, 2 Instantaneous A phase, 1 Instantaneous Neutral.	
17047	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
17048	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
17049	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
17050	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
17051	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	0	
17052	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
17053	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	2	
17054	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17055	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17056	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	8.38	
17057	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17058	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
17059	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
17060	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
17061	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
17062	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
17063	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
17064	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
17065	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
17066	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	General Comments		
17067	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
17068	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
17069	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
17070	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
17071	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
17072	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	213.0	
17073	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	198.0	
17074	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	222.0	
17075	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17076	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17077	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17078	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	7	
17079	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
17080	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
17081	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
17082	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
17083	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments		
17084	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments		
17085	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
17086	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	107	
17087	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	107	
17088	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations This Read Vac	0	
17089	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
17090	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
17091	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17092	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17093	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17094	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
17095	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
17096	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
17097	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
17098	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
17099	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
17100	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
17101	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
17102	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32318	
17103	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
17104	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	4	
17105	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17106	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17107	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17108	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17109	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17110	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17111	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17112	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17113	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17114	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17115	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17116	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17117	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17118	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17119	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
17120	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17121	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	0	
17122	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17123	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17124	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17125	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	127.0	
17126	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	116.0	
17127	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	129.0	
17128	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17129	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17130	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17131	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17132	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
17133	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
17134	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
17135	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
17136	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
17137	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	3	
17138	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	201	
17139	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	201	
17140	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
17141	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	1	
17142	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
17143	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
17144	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17145	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
17146	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
17147	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17148	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
17149	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
17150	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17151	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
17152	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
17153	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
17154	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
17155	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17156	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
17157	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
17158	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
17159	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17160	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
17161	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17162	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	1	
17163	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17164	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17165	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17166	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	38.0	
17167	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	67.0	
17168	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	58.0	
17169	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
17170	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
17171	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
17172	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
17173	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
17174	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
17175	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17176	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17177	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17178	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17179	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
17180	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
17181	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
17182	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
17183	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
17184	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
17185	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
17186	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
17187	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
17188	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
17189	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
17190	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
17191	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
17192	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	208	
17193	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
17194	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17195	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
17196	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
17197	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	35	°C
17198	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	50	°C
17199	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
17200	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
17201	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	7678.80	kw
17202	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
17203	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
17204	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
17205	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17206	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
17207	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
17208	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17209	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
17210	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
17211	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17212	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
17213	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
17214	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
17215	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
17216	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17217	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
17218	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
17219	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
17220	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
17221	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
17222	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	30	°C
17223	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	35	°C
17224	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.6462	
17225	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
17226	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17227	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
17228	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
17229	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17230	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17231	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
17232	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17233	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
17234	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
17235	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	25	°C
17236	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	35	°C
17237	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
17238	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
17239	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	9305.28	kw
17240	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
17241	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
17242	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
17243	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17244	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17245	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
17246	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
17247	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17248	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments		
17249	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	Leaking oil from top of transformer	
17250	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
17251	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17252	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
17253	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
17254	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	37	°C
17255	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	18	°C
17256	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17257	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
17258	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17259	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17260	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
17261	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
17262	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17263	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	30.0	
17264	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	60.0	
17265	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	30.0	
17266	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17267	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17268	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17269	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	6	
17270	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17271	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17272	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17273	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17274	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17275	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17276	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17277	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17278	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17279	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments	ok	
17280	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17281	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17282	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17283	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17284	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17285	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17286	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17287	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17288	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17289	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17290	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17291	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17292	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	208	
17293	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	0	
17294	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
17295	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	0	
17296	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
17297	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
17298	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
17299	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17300	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17301	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
17302	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
17303	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17304	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
17305	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
17306	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
17307	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
17308	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
17309	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
17310	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
17311	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
17312	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
17313	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
17314	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
17315	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
17316	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
17317	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
17318	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
17319	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	66.0	VDC
17320	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.0	VDC
17321	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
17322	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
17323	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
17324	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
17325	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
17326	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17327	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17328	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17329	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17330	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17331	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17332	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
17333	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
17334	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.0	VDC
17335	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.0	VDC
17336	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
17337	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
17338	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
17339	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments		
17340	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
17341	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17342	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
17343	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
17344	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
17345	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
17346	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
17347	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
17348	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	
17349	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
17350	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
17351	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
17352	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
17353	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
17354	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
17355	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
17356	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
17357	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	143	
17358	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	143	
17359	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
17360	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
17361	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
17362	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
17363	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
17364	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
17365	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
17366	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
17367	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
17368	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
17369	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
17370	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
17371	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
17372	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
17373	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
17374	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
17375	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17376	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17377	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17378	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17379	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
17380	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
17381	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
17382	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17383	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17384	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17385	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17386	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17387	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17388	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17389	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17390	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17391	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17392	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17393	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17394	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17395	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17396	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17397	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17398	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17399	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17400	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17401	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17402	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17403	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17404	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17405	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17406	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17407	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
17408	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
17409	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
17410	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
17411	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17412	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
17413	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17414	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17415	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17416	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17417	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17418	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17419	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17420	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
17421	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
17422	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	1	
17423	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
17424	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	1	
17425	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	315	
17426	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	315	
17427	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	0	
17428	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17429	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17430	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17431	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	127.0	
17432	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	125.0	
17433	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	125.0	
17434	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17435	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17436	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17437	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17438	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
17439	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
17440	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	General Comments		
17441	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17442	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17443	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17444	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17445	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
17446	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
17447	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.4500	
17448	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
17449	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17450	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
17451	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
17452	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17453	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17454	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
17455	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17456	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	25	°C
17457	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	30	°C
17458	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
17459	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
17460	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	2160.00	kw
17461	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
17462	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
17463	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
17464	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17465	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
17466	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
17467	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17468	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
17469	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
17470	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17471	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
17472	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
17473	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
17474	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
17475	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17476	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
17477	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
17478	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
17479	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
17480	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
17481	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	35	°C
17482	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	48	°C
17483	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.4266	
17484	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
17485	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17486	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
17487	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
17488	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17489	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17490	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17491	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17492	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
17493	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17494	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17495	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17496	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17497	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
17498	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
17499	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations This Read Vac	0	
17500	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	66	
17501	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	66	
17502	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
17503	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments		
17504	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments		
17505	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
17506	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
17507	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
17508	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
17509	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
17510	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
17511	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17512	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17513	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17514	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17515	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
17516	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
17517	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
17518	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17519	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17520	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17521	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	0	
17522	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
17523	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17524	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
17525	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17526	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
17527	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17528	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17529	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
17530	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
17531	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17532	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
17533	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
17534	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
17535	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
17536	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
17537	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
17538	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17539	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17540	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
17541	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17542	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17543	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17544	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17545	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17546	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17547	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17548	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17549	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17550	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments		
17551	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17552	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17553	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17554	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17555	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17556	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17557	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17558	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17559	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17560	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17561	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17562	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17563	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17564	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
17565	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17566	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17567	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
17568	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
17569	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
17570	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17571	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
17572	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17573	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17574	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
17575	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
17576	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17577	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
17578	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
17579	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
17580	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
17581	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
17582	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
17583	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
17584	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
17585	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
17586	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
17587	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17588	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	0	
17589	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
17590	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17591	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17592	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17593	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
17594	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
17595	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
17596	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17597	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17598	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17599	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	0	
17600	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	26	*F
17601	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17602	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17603	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17604	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17605	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17606	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17607	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17608	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17609	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17610	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
17611	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17612	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
17613	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
17614	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17615	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		
17616	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
17617	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
17618	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
17619	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
17620	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
17621	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
17622	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
17623	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
17624	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
17625	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
17626	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17627	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
17628	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
17629	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
17630	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
17631	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17632	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
17633	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
17634	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
17635	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
17636	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
17637	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
17638	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
17639	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments		
17640	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17641	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17642	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17643	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17644	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17645	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17646	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17647	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17648	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17649	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17650	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17651	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17652	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3231	
17653	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
17654	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17655	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
17656	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
17657	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17658	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17659	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
17660	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17661	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
17662	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
17663	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
17664	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
17665	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	258.48	kw
17666	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
17667	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
17668	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
17669	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments	ok	
17670	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments	ok	
17671	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17672	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
17673	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
17674	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17675	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17676	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17677	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
17678	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
17679	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
17680	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17681	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
17682	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
17683	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17684	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17685	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
17686	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17687	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
17688	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17689	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17690	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17691	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	0.0	
17692	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	0.0	
17693	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	0.0	
17694	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17695	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17696	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17697	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17698	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	
17699	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
17700	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
17701	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
17702	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
17703	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
17704	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
17705	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments		
17706	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
17707	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	175	
17708	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	175	
17709	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations This Read Vac	0	
17710	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
17711	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
17712	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
17713	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
17714	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
17715	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
17716	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
17717	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
17718	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17719	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
17720	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
17721	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
17722	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
17723	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
17724	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17725	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
17726	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17727	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments		
17728	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17729	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17730	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17731	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17732	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17733	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17734	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17735	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17736	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17737	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17738	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
17739	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17740	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17741	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17742	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17743	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17744	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17745	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17746	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17747	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
17748	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17749	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17750	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17751	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17752	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17753	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17754	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17755	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
17756	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
17757	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
17758	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
17759	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
17760	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
17761	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
17762	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
17763	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
17764	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
17765	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
17766	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
17767	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
17768	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
17769	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
17770	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
17771	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
17772	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
17773	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17774	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17775	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17776	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
17777	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17778	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
17779	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
17780	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
17781	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
17782	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17783	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
17784	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17785	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17786	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17787	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations This Read Vac	0	
17788	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
17789	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
17790	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17791	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
17792	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
17793	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
17794	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
17795	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17796	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
17797	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
17798	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
17799	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17800	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17801	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17802	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17803	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17804	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
17805	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
17806	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
17807	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
17808	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
17809	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
17810	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
17811	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments		
17812	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments		
17813	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
17814	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
17815	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
17816	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
17817	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	58	°C
17818	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	23	°C
17819	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
17820	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
17821	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
17822	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
17823	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
17824	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
17825	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
17826	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17827	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
17828	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17829	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
17830	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17831	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17832	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17833	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17834	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17835	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17836	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
17837	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
17838	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
17839	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
17840	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
17841	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
17842	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
17843	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
17844	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
17845	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.6	VDC
17846	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.4	VDC
17847	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
17848	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
17849	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	58.2	VDC
17850	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	58.2	VDC
17851	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17852	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
17853	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
17854	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
17855	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
17856	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
17857	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
17858	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
17859	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments		
17860	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
17861	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
17862	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	49	
17863	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	49	
17864	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
17865	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
17866	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
17867	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
17868	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
17869	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations This Read Vac	0	
17870	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	149	
17871	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	149	
17872	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
17873	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments		
17874	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments		
17875	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
17876	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
17877	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
17878	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
17879	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
17880	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
17881	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17882	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
17883	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
17884	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
17885	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
17886	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17887	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17888	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17889	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17890	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17891	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17892	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
17893	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17894	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
17895	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
17896	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17897	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
17898	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
17899	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
17900	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
17901	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
17902	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
17903	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
17904	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
17905	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
17906	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17907	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
17908	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
17909	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
17910	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17911	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
17912	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17913	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17914	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17915	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17916	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17917	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17918	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17919	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17920	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17921	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
17922	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	0	
17923	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
17924	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
17925	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
17926	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
17927	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
17928	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
17929	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
17930	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
17931	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
17932	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
17933	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
17934	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
17935	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
17936	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
17937	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
17938	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
17939	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
17940	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
17941	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
17942	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
17943	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
17944	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
17945	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
17946	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
17947	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
17948	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
17949	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
17950	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
17951	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
17952	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
17953	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
17954	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
17955	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
17956	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
17957	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
17958	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
17959	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
17960	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
17961	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
17962	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
17963	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
17964	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
17965	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
17966	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
17967	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
17968	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
17969	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
17970	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
17971	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
17972	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
17973	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
17974	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
17975	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
17976	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
17977	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
17978	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
17979	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
17980	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
17981	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
17982	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
17983	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
17984	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
17985	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
17986	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
17987	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
17988	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
17989	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
17990	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
17991	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
17992	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
17993	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
17994	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
17995	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
17996	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
17997	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
17998	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
17999	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18000	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18001	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18002	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
18003	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	217107	
18004	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18005	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
18006	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
18007	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
18008	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18009	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18010	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18011	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18012	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
18013	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18014	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
18015	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
18016	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18017	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
18018	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
18019	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
18020	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
18021	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18022	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18023	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
18024	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
18025	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
18026	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	23228	
18027	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18028	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18029	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
18030	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
18031	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
18032	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18033	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18034	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18035	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18036	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
18037	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
18038	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	0	
18039	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
18040	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	0	
18041	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	78	
18042	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	78	
18043	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
18044	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
18045	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
18046	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
18047	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
18048	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
18049	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
18050	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
18051	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
18052	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
18053	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
18054	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
18055	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
18056	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
18057	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
18058	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
18059	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
18060	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
18061	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18062	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18063	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18064	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18065	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	95.0	
18066	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	99.0	
18067	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	100.0	
18068	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
18069	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
18070	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
18071	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
18072	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	2	
18073	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
18074	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	2	
18075	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	447	
18076	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	447	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
18077	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
18078	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
18079	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
18080	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
18081	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
18082	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
18083	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
18084	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
18085	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
18086	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
18087	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
18088	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
18089	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
18090	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
18091	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
18092	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
18093	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
18094	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
18095	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
18096	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
18097	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
18098	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
18099	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
18100	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
18101	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
18102	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
18103	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
18104	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	70	
18105	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	70	
18106	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
18107	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments		
18108	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
18109	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
18110	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
18111	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
18112	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	
18113	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
18114	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
18115	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18116	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18117	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18118	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18119	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
18120	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	
18121	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
18122	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18123	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18124	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18125	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	0	
18126	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
18127	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
18128	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
18129	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
18130	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
18131	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
18132	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24633	
18133	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18134	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
18135	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
18136	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		
18137	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
18138	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
18139	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	56	
18140	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	56	
18141	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
18142	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
18143	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
18144	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
18145	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
18146	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
18147	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
18148	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
18149	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
18150	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
18151	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18152	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
18153	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
18154	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
18155	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
18156	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
18157	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
18158	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
18159	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
18160	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
18161	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
18162	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
18163	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
18164	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
18165	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
18166	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments		
18167	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
18168	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
18169	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
18170	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
18171	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
18172	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
18173	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
18174	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
18175	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
18176	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
18177	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
18178	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
18179	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
18180	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
18181	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
18182	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
18183	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	60	*C
18184	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
18185	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
18186	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
18187	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
18188	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
18189	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
18190	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments		
18191	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
18192	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
18193	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
18194	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
18195	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
18196	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
18197	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
18198	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
18199	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
18200	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
18201	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
18202	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
18203	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
18204	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
18205	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
18206	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
18207	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
18208	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
18209	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
18210	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
18211	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments		
18212	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
18213	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
18214	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
18215	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
18216	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
18217	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
18218	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	0	
18219	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
18220	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
18221	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
18222	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
18223	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
18224	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
18225	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18226	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18227	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18228	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18229	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
18230	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
18231	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
18232	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
18233	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
18234	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
18235	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
18236	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
18237	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
18238	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
18239	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
18240	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
18241	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
18242	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
18243	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
18244	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
18245	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
18246	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
18247	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
18248	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
18249	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
18250	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
18251	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
18252	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
18253	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
18254	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
18255	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments	ok	
18256	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
18257	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
18258	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
18259	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
18260	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
18261	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18262	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18263	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18264	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18265	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
18266	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18267	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
18268	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
18269	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18270	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
18271	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
18272	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
18273	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
18274	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18275	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18276	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
18277	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
18278	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	156038	
18279	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18280	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
18281	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
18282	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
18283	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
18284	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18285	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18286	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18287	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18288	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	0.0	
18289	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	0.0	
18290	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	0.0	
18291	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18292	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18293	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18294	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	0	
18295	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
18296	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
18297	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
18298	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
18299	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
18300	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
18301	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18302	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments		
18303	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
18304	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
18305	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
18306	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
18307	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
18308	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
18309	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
18310	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
18311	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
18312	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
18313	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
18314	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
18315	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
18316	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments		
18317	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
18318	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
18319	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
18320	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
18321	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
18322	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
18323	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
18324	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
18325	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
18326	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
18327	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
18328	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
18329	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
18330	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
18331	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
18332	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
18333	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
18334	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
18335	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
18336	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
18337	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
18338	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
18339	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	173	
18340	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	173	
18341	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	0	
18342	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
18343	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
18344	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
18345	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
18346	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
18347	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
18348	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	212	
18349	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
18350	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments	ok	
18351	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
18352	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
18353	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
18354	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
18355	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.7	
18356	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.8	
18357	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
18358	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	0	
18359	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18360	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18361	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18362	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
18363	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
18364	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
18365	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18366	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18367	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18368	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18369	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
18370	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
18371	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
18372	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
18373	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
18374	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
18375	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
18376	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18377	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	0	
18378	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18379	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18380	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18381	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	59.0	
18382	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	57.0	
18383	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	56.0	
18384	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18385	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18386	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
18387	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
18388	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	519	
18389	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
18390	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
18391	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
18392	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
18393	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
18394	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	114409	
18395	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	114409	
18396	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
18397	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
18398	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
18399	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
18400	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
18401	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
18402	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	742	
18403	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
18404	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
18405	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
18406	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
18407	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
18408	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
18409	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
18410	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
18411	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
18412	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
18413	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	1	
18414	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18415	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18416	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18417	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	63.0	
18418	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	54.0	
18419	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	57.0	
18420	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
18421	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
18422	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
18423	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
18424	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
18425	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
18426	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18427	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18428	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18429	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18430	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
18431	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
18432	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
18433	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
18434	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
18435	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
18436	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
18437	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
18438	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
18439	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
18440	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
18441	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
18442	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
18443	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
18444	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
18445	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
18446	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
18447	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
18448	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
18449	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
18450	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
18451	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	245	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18452	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	245	
18453	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
18454	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
18455	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
18456	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
18457	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
18458	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
18459	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
18460	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
18461	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
18462	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
18463	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
18464	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
18465	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
18466	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
18467	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	0	
18468	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
18469	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
18470	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments	trip counter reset by service man	
18471	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
18472	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
18473	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
18474	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
18475	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
18476	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
18477	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
18478	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
18479	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
18480	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
18481	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
18482	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	48.0	
18483	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
18484	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
18485	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
18486	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
18487	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
18488	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18489	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18490	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18491	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18492	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
18493	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
18494	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
18495	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
18496	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
18497	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
18498	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
18499	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
18500	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	150	
18501	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	150	
18502	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
18503	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
18504	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
18505	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
18506	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
18507	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	0	
18508	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
18509	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	0	
18510	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	380	
18511	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	380	
18512	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
18513	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
18514	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
18515	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
18516	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
18517	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
18518	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
18519	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
18520	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
18521	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
18522	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
18523	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	99	
18524	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	99	
18525	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
18526	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18527	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
18528	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
18529	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
18530	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
18531	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
18532	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
18533	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
18534	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
18535	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
18536	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
18537	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
18538	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
18539	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
18540	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
18541	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18542	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18543	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
18544	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18545	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
18546	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
18547	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
18548	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18549	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18550	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
18551	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
18552	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
18553	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
18554	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18555	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18556	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
18557	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
18558	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
18559	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	ok	
18560	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18561	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
18562	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
18563	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18564	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
18565	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18566	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18567	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18568	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18569	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
18570	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
18571	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
18572	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18573	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
18574	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
18575	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
18576	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	229	
18577	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	229	
18578	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
18579	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
18580	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
18581	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
18582	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
18583	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
18584	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
18585	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
18586	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
18587	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18588	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18589	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18590	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18591	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
18592	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18593	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18594	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
18595	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
18596	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
18597	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments	ok	
18598	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18599	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
18600	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
18601	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18602	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
18603	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18604	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18605	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18606	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
18607	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
18608	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
18609	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
18610	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
18611	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
18612	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
18613	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
18614	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
18615	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
18616	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
18617	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
18618	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
18619	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
18620	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
18621	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
18622	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
18623	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
18624	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
18625	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
18626	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
18627	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
18628	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
18629	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
18630	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	60	*F
18631	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
18632	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18633	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18634	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18635	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18636	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
18637	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18638	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
18639	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
18640	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18641	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
18642	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
18643	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
18644	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
18645	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
18646	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	22698	
18647	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18648	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18649	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
18650	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
18651	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
18652	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18653	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18654	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18655	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18656	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
18657	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	13	
18658	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
18659	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
18660	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
18661	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	83.0	
18662	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	83.0	
18663	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	80.0	
18664	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18665	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	102.07	
18666	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	102.07	
18667	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	102.07	
18668	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
18669	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
18670	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
18671	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
18672	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
18673	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
18674	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
18675	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
18676	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18677	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
18678	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
18679	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18680	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
18681	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
18682	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
18683	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
18684	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	88	
18685	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	88	
18686	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	3	
18687	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
18688	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	3	
18689	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
18690	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18691	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18692	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
18693	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
18694	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
18695	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	79617	
18696	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
18697	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
18698	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18699	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18700	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18701	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	0	
18702	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115770	
18703	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
18704	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
18705	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18706	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18707	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	1	
18708	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
18709	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations This Read Vac	1	
18710	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	189	
18711	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	189	
18712	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
18713	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments		
18714	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
18715	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
18716	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
18717	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
18718	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C Ø	0	
18719	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B Ø	0	
18720	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
18721	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
18722	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
18723	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
18724	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18725	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	54.0	
18726	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	49.0	
18727	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	53.0	
18728	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18729	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18730	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18731	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	1	
18732	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
18733	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
18734	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
18735	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
18736	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
18737	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
18738	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
18739	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18740	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
18741	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
18742	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18743	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
18744	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18745	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18746	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18747	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18748	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
18749	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18750	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
18751	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18752	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
18753	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
18754	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
18755	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
18756	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
18757	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
18758	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
18759	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18760	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18761	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18762	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
18763	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
18764	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
18765	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
18766	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
18767	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	127027	
18768	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	127027	
18769	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
18770	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	6L	
18771	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	3L	
18772	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	16L	
18773	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	1744	
18774	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
18775	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
18776	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
18777	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	2	
18778	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
18779	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18780	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18781	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
18782	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
18783	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
18784	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18785	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18786	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18787	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18788	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
18789	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
18790	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
18791	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations Ground	0	
18792	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Follow-up Action Required?	n	
18793	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
18794	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments		
18795	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments		
18796	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
18797	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	87	
18798	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	87	
18799	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations This Read Vac	0	
18800	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
18801	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
18802	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
18803	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	362	
18804	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
18805	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
18806	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
18807	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
18808	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	5	
18809	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18810	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
18811	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18812	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A Ø	92.0	
18813	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B Ø	90.0	
18814	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C Ø	90.0	
18815	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18816	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
18817	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
18818	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
18819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
18820	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
18821	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
18822	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
18823	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
18824	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
18825	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
18826	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18827	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
18828	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	94	
18829	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	94	
18830	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations This Read Vac	1	
18831	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
18832	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	1	
18833	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	23	°C
18834	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	67	°C
18835	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	23	°C
18836	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
18837	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
18838	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
18839	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	Spill kit missing	
18840	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
18841	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
18842	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
18843	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
18844	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
18845	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
18846	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
18847	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
18848	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
18849	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
18850	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18851	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18852	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18853	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
18854	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
18855	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
18856	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
18857	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
18858	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	330	
18859	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	330	
18860	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
18861	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
18862	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
18863	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
18864	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
18865	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
18866	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
18867	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
18868	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
18869	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
18870	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
18871	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
18872	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
18873	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18874	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18875	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18876	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18877	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
18878	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
18879	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
18880	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
18881	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
18882	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
18883	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
18884	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
18885	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	20.0	
18886	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18887	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18888	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18889	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	9	
18890	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
18891	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	22	°C
18892	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	65	°C
18893	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	22	°C
18894	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	65	°C
18895	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	22	°C
18896	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	65	°C
18897	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
18898	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
18899	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
18900	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
18901	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
18902	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
18903	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
18904	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
18905	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
18906	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
18907	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
18908	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
18909	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
18910	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
18911	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
18912	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
18913	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
18914	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
18915	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
18916	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	0	
18917	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
18918	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
18919	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
18920	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
18921	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
18922	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
18923	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
18924	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
18925	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
18926	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
18927	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
18928	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
18929	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
18930	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
18931	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
18932	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
18933	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
18934	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
18935	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
18936	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	49	
18937	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	49	
18938	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
18939	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
18940	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
18941	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
18942	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
18943	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
18944	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments		
18945	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
18946	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
18947	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
18948	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
18949	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
18950	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
18951	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
18952	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
18953	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	199919	
18954	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
18955	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
18956	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
18957	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
18958	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
18959	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
18960	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
18961	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
18962	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
18963	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
18964	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
18965	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	Need size info and qty
18966	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
18967	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
18968	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
18969	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
18970	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
18971	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
18972	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
18973	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
18974	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
18975	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
18976	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
18977	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
18978	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
18979	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
18980	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
18981	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
18982	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
18983	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
18984	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
18985	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
18986	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
18987	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
18988	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
18989	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
18990	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
18991	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
18992	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
18993	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
18994	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
18995	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
18996	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
18997	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
18998	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
18999	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
19000	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
19001	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
19002	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
19003	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
19004	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
19005	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
19006	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19007	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	122.0	
19008	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	118.0	
19009	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
19010	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
19011	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19012	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19013	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19014	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19015	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
19016	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
19017	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
19018	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
19019	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
19020	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
19021	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	320.0	
19022	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	320.0	
19023	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	300.0	
19024	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19025	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19026	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19027	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	4	
19028	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
19029	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
19030	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
19031	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
19032	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
19033	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
19034	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
19035	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
19036	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
19037	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
19038	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
19039	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
19040	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
19041	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
19042	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
19043	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
19044	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
19045	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
19046	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
19047	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
19048	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
19049	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	0	
19050	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19051	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19052	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
19053	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
19054	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
19055	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
19056	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
19057	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
19058	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
19059	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
19060	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
19061	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	68	*C
19062	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	*C
19063	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	*C
19064	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	*C
19065	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	64	*C
19066	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	22	*C
19067	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
19068	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
19069	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
19070	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
19071	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
19072	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
19073	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	0	
19074	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19075	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19076	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19077	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A Ø	0.0	
19078	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
19079	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
19080	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19081	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19082	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
19083	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
19084	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
19085	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	67	*C
19086	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	23	*C
19087	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	67	*C
19088	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19089	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19090	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
19091	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
19092	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
19093	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
19094	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
19095	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
19096	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
19097	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
19098	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
19099	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	80	
19100	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	80	
19101	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
19102	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
19103	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
19104	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
19105	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
19106	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
19107	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
19108	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	23206	
19109	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	23206	
19110	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
19111	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
19112	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
19113	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	120.0	
19114	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19115	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19116	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19117	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19118	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
19119	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
19120	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
19121	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
19122	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
19123	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
19124	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
19125	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
19126	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19127	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	106	
19128	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	106	
19129	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
19130	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
19131	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
19132	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
19133	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
19134	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
19135	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
19136	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
19137	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
19138	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
19139	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
19140	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
19141	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
19142	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
19143	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
19144	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
19145	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
19146	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
19147	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
19148	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	ok	
19149	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
19150	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
19151	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
19152	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
19153	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
19154	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
19155	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
19156	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
19157	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
19158	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
19159	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
19160	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
19161	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
19162	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
19163	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
19164	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	68	°C
19165	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
19166	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	recloser is bypassed.6 unknown operations.	
19167	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
19168	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
19169	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
19170	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
19171	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
19172	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
19173	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
19174	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
19175	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
19176	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
19177	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2019	
19178	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
19179	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
19180	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
19181	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
19182	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
19183	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
19184	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
19185	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
19186	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
19187	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19188	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19189	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19190	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19191	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
19192	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
19193	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
19194	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.5	VDC
19195	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19196	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19197	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
19198	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
19199	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
19200	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	88	
19201	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	88	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19202	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
19203	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
19204	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
19205	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
19206	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
19207	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
19208	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
19209	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
19210	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
19211	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19212	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19213	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19214	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19215	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
19216	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
19217	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
19218	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
19219	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
19220	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
19221	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
19222	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	120724	
19223	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
19224	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
19225	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
19226	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
19227	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
19228	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
19229	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
19230	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
19231	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
19232	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
19233	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
19234	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
19235	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
19236	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
19237	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
19238	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
19239	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	92.0	
19240	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	90.0	
19241	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	89.0	
19242	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19243	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19244	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19245	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19246	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
19247	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
19248	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
19249	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
19250	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
19251	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
19252	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
19253	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
19254	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
19255	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	279	
19256	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	279	
19257	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	0	
19258	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	0	
19259	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
19260	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
19261	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
19262	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
19263	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
19264	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
19265	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
19266	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
19267	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
19268	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	606	
19269	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
19270	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
19271	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
19272	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
19273	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
19274	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
19275	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
19276	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19277	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19278	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19279	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
19280	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19281	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
19282	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
19283	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
19284	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
19285	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
19286	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19287	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19288	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
19289	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
19290	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
19291	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	128	
19292	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	128	
19293	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
19294	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
19295	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
19296	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
19297	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
19298	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
19299	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
19300	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
19301	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
19302	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19303	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19304	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19305	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19306	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	92.0	
19307	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	93.0	
19308	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	94.0	
19309	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19310	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19311	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19312	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	0	
19313	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
19314	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
19315	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
19316	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
19317	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
19318	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
19319	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
19320	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
19321	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
19322	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
19323	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
19324	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
19325	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	0	
19326	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
19327	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
19328	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
19329	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
19330	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
19331	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
19332	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
19333	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
19334	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
19335	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
19336	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19337	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19338	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
19339	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
19340	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
19341	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
19342	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
19343	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
19344	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
19345	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
19346	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
19347	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
19348	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
19349	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19350	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19351	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19352	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
19353	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19354	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
19355	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
19356	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
19357	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
19358	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19359	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19360	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
19361	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
19362	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
19363	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
19364	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
19365	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
19366	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
19367	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
19368	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
19369	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
19370	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
19371	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19372	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19373	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19374	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19375	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19376	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19377	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19378	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19379	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
19380	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19381	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
19382	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19383	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19384	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19385	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19386	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
19387	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
19388	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
19389	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
19390	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
19391	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
19392	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
19393	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
19394	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
19395	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
19396	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19397	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
19398	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19399	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
19400	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19401	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
19402	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
19403	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
19404	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
19405	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
19406	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
19407	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
19408	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
19409	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCCControl	WS-TRANS 4	LTC Control Insp	General Comments		
19410	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
19411	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
19412	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19413	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19414	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
19415	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
19416	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
19417	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	323595	
19418	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
19419	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19420	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19421	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
19422	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
19423	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
19424	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
19425	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
19426	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19427	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19428	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19429	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19430	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19431	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19432	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19433	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19434	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19435	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19436	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19437	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19438	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19439	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19440	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19441	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19442	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19443	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19444	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19445	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19446	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19447	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19448	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19449	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19450	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
19451	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
19452	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
19453	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments		
19454	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
19455	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
19456	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
19457	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	117	
19458	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
19459	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
19460	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	166	
19461	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	37.5	
19462	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	49.5	
19463	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.2	
19464	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	154	
19465	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19466	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19467	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19468	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19469	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19470	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19471	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19472	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
19473	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19474	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19475	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
19476	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19477	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19478	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
19479	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
19480	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
19481	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19482	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19483	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
19484	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
19485	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	42	°C
19486	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	55	°C
19487	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.2770	
19488	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
19489	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
19490	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Max	155	°C
19491	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
19492	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
19493	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
19494	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
19495	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
19496	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
19497	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
19498	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
19499	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
19500	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	12259.20	kw
19501	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
19502	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
19503	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
19504	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
19505	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
19506	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
19507	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
19508	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
19509	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
19510	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
19511	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
19512	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
19513	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
19514	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
19515	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
19516	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
19517	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
19518	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
19519	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
19520	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4L	
19521	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	*C
19522	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	307	
19523	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
19524	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
19525	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
19526	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
19527	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	2	
19528	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
19529	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
19530	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19531	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19532	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
19533	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
19534	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments		
19535	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
19536	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
19537	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
19538	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
19539	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
19540	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
19541	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
19542	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
19543	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
19544	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
19545	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19546	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19547	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19548	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19549	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
19550	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
19551	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19552	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19553	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
19554	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
19555	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
19556	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
19557	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
19558	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	*C
19559	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	*C
19560	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
19561	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
19562	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	25493	
19563	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	25493	
19564	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
19565	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	1L	
19566	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	5R	
19567	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	30	Seconds
19568	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
19569	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
19570	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
19571	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
19572	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	y	
19573	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	General Comments		
19574	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
19575	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
19576	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19577	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
19578	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
19579	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
19580	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19581	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19582	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
19583	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19584	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
19585	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
19586	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
19587	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
19588	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
19589	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19590	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19591	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
19592	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
19593	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
19594	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
19595	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
19596	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	0	
19597	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
19598	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
19599	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
19600	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
19601	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
19602	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
19603	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19604	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19605	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19606	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19607	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
19608	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
19609	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
19610	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
19611	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
19612	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
19613	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
19614	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
19615	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
19616	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19617	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19618	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
19619	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
19620	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.5748	
19621	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
19622	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
19623	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
19624	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
19625	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
19626	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
19627	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
19628	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
19629	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	30	°C
19630	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	65	°C
19631	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
19632	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
19633	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	4138.56	kw
19634	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
19635	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
19636	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	75.0	
19637	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
19638	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
19639	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
19640	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19641	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19642	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19643	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
19644	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19645	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
19646	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
19647	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
19648	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
19649	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
19650	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19651	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19652	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
19653	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
19654	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
19655	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
19656	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
19657	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
19658	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
19659	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
19660	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	69.0	
19661	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	71.0	
19662	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19663	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19664	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19665	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19666	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
19667	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
19668	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
19669	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
19670	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
19671	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
19672	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
19673	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
19674	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
19675	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
19676	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
19677	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
19678	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
19679	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
19680	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
19681	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	"F
19682	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
19683	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19684	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19685	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19686	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
19687	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	267	
19688	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
19689	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
19690	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
19691	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
19692	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
19693	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
19694	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
19695	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
19696	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	94277	
19697	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
19698	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
19699	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
19700	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
19701	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
19702	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
19703	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
19704	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
19705	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments		
19706	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
19707	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
19708	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
19709	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
19710	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
19711	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
19712	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
19713	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
19714	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
19715	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
19716	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19717	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
19718	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
19719	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
19720	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
19721	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
19722	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
19723	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
19724	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
19725	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
19726	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19727	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
19728	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
19729	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
19730	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
19731	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
19732	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	
19733	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
19734	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
19735	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	999	
19736	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
19737	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
19738	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
19739	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments	ok	
19740	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments	ok	
19741	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
19742	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
19743	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
19744	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
19745	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
19746	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
19747	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
19748	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
19749	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
19750	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
19751	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
19752	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
19753	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
19754	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
19755	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
19756	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	49	
19757	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	49	
19758	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	0	
19759	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
19760	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
19761	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
19762	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19763	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19764	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19765	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
19766	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
19767	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
19768	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
19769	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
19770	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
19771	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
19772	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
19773	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
19774	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19775	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19776	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19777	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19778	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
19779	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
19780	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
19781	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
19782	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
19783	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
19784	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
19785	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
19786	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
19787	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
19788	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
19789	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
19790	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
19791	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	267	
19792	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19793	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
19794	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
19795	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
19796	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
19797	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
19798	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19799	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19800	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
19801	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19802	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
19803	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
19804	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
19805	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
19806	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	0	
19807	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	182	
19808	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	182	
19809	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
19810	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
19811	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
19812	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
19813	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
19814	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
19815	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
19816	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
19817	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
19818	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19820	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19821	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19822	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
19823	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
19824	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
19825	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19826	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19827	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19828	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	0	
19829	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
19830	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
19831	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
19832	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
19833	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
19834	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
19835	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
19836	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
19837	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
19838	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
19839	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
19840	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
19841	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
19842	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
19843	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
19844	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
19845	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
19846	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
19847	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
19848	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
19849	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
19850	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
19851	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
19852	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
19853	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19854	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19855	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
19856	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19857	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19858	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19859	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19860	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
19861	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
19862	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
19863	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
19864	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
19865	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
19866	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
19867	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
19868	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19869	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19870	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19871	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
19872	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
19873	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
19874	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
19875	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
19876	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	20.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19877	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	18.0	VDC
19878	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
19879	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
19880	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
19881	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
19882	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
19883	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
19884	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19885	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19886	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
19887	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
19888	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
19889	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
19890	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
19891	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
19892	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
19893	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
19894	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
19895	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
19896	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
19897	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
19898	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
19899	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
19900	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
19901	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
19902	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
19903	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
19904	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	702	
19905	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	702	
19906	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
19907	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
19908	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
19909	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
19910	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
19911	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
19912	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
19913	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
19914	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
19915	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
19916	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
19917	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
19918	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
19919	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
19920	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
19921	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
19922	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
19923	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
19924	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
19925	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
19926	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
19927	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
19928	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
19929	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	310.0	
19930	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	330.0	
19931	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	310.0	
19932	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
19933	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
19934	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
19935	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
19936	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
19937	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
19938	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
19939	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	General Comments		
19940	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
19941	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	LTC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
19942	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
19943	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
19944	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
19945	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	0	
19946	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	2.69	%
19947	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
19948	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
19949	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
19950	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
19951	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
19952	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
19953	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
19954	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
19955	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
19956	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	68	°C
19957	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
19958	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
19959	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
19960	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
19961	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
19962	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
19963	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
19964	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
19965	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
19966	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
19967	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
19968	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
19969	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
19970	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
19971	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
19972	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	174	
19973	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	174	
19974	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
19975	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
19976	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
19977	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
19978	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
19979	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
19980	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
19981	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
19982	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
19983	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
19984	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
19985	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	26	°C
19986	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	68	°C
19987	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	27	°C
19988	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	68	°C
19989	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	27	°C
19990	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
19991	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
19992	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments	ok	
19993	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments	ok	
19994	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	8251	
19995	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	8261	
19996	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
19997	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	7L	
19998	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	6L	
19999	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	11L	
20000	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	589	
20001	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	75.0	
20002	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
20003	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
20004	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
20005	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
20006	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
20007	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	1	
20008	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
20009	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
20010	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	2	
20011	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	143	
20012	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	143	
20013	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
20014	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	1	
20015	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
20016	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
20017	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
20018	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
20019	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
20020	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
20021	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
20022	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
20023	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
20024	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations E Ø	0	
20025	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
20026	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	4.19	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
20027	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
20028	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
20029	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20030	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
20031	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
20032	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
20033	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
20034	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
20035	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
20036	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
20037	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
20038	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
20039	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20040	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20041	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20042	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	5	
20043	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
20044	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20045	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	13.43	
20046	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
20047	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	13.43	
20048	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
20049	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
20050	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
20051	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
20052	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
20053	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	4R	
20054	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
20055	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20056	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	127046	
20057	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	127046	
20058	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
20059	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
20060	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20061	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20062	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20063	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	793	
20064	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
20065	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	8L	
20066	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	2R	
20067	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	4L	
20068	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20069	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	20542	
20070	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	20542	
20071	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
20072	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
20073	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20074	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
20075	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20076	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
20077	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
20078	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20079	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
20080	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
20081	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	49774	
20082	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	49774	
20083	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20084	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	9L	
20085	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	3L	
20086	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	10L	
20087	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
20088	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
20089	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	707	
20090	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
20091	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20092	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20093	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20094	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
20095	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20096	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
20097	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
20098	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	60853	
20099	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	21	
20100	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20101	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20102	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20103	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	0.0	
20104	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	75.0	
20105	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
20106	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
20107	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20108	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20109	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
20110	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	125.6	VAC
20111	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
20112	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	General Comments		
20113	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
20114	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	LTC0000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
20115	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
20116	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20117	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20118	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
20119	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
20120	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	General Comments	ok	
20121	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
20122	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	LTC0000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
20123	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	223	
20124	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	223	
20125	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	2	
20126	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
20127	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
20128	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
20129	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	1	
20130	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	60856	
20131	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20132	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
20133	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	5R	
20134	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	6L	
20135	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
20136	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
20137	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	55	°C
20138	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	899	
20139	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20140	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20141	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20142	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
20143	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
20144	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
20145	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
20146	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
20147	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
20148	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
20149	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
20150	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
20151	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
20152	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
20153	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
20154	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
20155	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
20156	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
20157	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
20158	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
20159	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments	1 trip check, 1 unknown operation	
20160	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments	ok	
20161	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
20162	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
20163	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20164	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20165	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20166	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
20167	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
20168	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
20169	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
20170	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
20171	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
20172	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
20173	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
20174	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
20175	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20176	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20177	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20178	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20179	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
20180	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
20181	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
20182	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
20183	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
20184	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
20185	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
20186	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
20187	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
20188	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
20189	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
20190	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
20191	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
20192	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	165	
20193	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
20194	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
20195	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
20196	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
20197	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
20198	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
20199	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
20200	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	1	
20201	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
20202	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
20203	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20204	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20205	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
20206	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
20207	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	General Comments		
20208	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
20209	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
20210	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
20211	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
20212	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
20213	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
20214	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
20215	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
20216	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
20217	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
20218	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	53	°C
20219	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	19	°C
20220	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	53	°C
20221	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	19	°C
20222	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	54	°C
20223	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	19	°C
20224	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
20225	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20226	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
20227	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
20228	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	9514	
20229	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	9514	
20230	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20231	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
20232	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
20233	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
20234	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	3	°C
20235	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	44	°C
20236	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	470	
20237	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
20238	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20239	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20240	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
20241	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
20242	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
20243	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
20244	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
20245	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
20246	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
20247	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
20248	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
20249	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
20250	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	0	
20251	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20252	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20253	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20254	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	699.0	
20255	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	687.0	
20256	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	685.0	
20257	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20258	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20259	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20260	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20261	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
20262	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
20263	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
20264	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	0	
20265	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20266	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20267	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20268	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
20269	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
20270	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
20271	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20272	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20273	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20274	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20275	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	
20276	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
20277	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
20278	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	
20279	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
20280	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
20281	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
20282	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments		
20283	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
20284	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	174	
20285	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	174	
20286	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations This Read Vac	0	
20287	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
20288	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
20289	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
20290	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
20291	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
20292	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
20293	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
20294	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
20295	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
20296	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
20297	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
20298	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
20299	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
20300	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
20301	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
20302	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
20303	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
20304	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
20305	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
20306	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
20307	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
20308	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
20309	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
20310	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
20311	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
20312	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	*C
20313	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	84143	
20314	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
20315	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	4L	
20316	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	2L	
20317	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	6L	
20318	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	261	
20319	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20320	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20321	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20322	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
20323	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
20324	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
20325	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments		
20326	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20327	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
20328	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
20329	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
20330	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
20331	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
20332	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
20333	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
20334	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
20335	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
20336	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
20337	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
20338	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
20339	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
20340	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
20341	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
20342	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
20343	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
20344	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
20345	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
20346	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
20347	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
20348	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
20349	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
20350	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
20351	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
20352	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20353	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20354	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
20355	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
20356	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
20357	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
20358	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
20359	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20360	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20361	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20362	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
20363	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	931	
20364	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	10L	
20365	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
20366	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
20367	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
20368	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
20369	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
20370	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
20371	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments		
20372	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments		
20373	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
20374	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	181	
20375	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	181	
20376	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
20377	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
20378	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
20379	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
20380	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
20381	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
20382	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
20383	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
20384	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
20385	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
20386	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
20387	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
20388	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
20389	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
20390	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
20391	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
20392	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
20393	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
20394	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
20395	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
20396	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
20397	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
20398	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
20399	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
20400	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
20401	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20402	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
20403	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
20404	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
20405	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
20406	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
20407	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
20408	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
20409	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
20410	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
20411	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
20412	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
20413	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
20414	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20415	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
20416	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
20417	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	84140	
20418	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
20419	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
20420	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
20421	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
20422	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
20423	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
20424	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
20425	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20426	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20427	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
20428	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
20429	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	General Comments		
20430	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
20431	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
20432	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
20433	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
20434	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
20435	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
20436	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	359	
20437	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
20438	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
20439	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
20440	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	Neutral	
20441	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	25648	
20442	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	25648	
20443	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
20444	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
20445	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20446	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
20447	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
20448	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
20449	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.2262	
20450	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
20451	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
20452	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
20453	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
20454	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
20455	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
20456	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
20457	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
20458	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
20459	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	48	°C
20460	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
20461	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
20462	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	1085.76	kw
20463	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
20464	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
20465	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
20466	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
20467	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
20468	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
20469	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
20470	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	90.0	
20471	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
20472	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
20473	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
20474	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
20475	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
20476	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20477	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
20478	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations This Read Vac	0	
20479	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	56	
20480	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	56	
20481	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
20482	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments		
20483	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments		
20484	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
20485	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
20486	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
20487	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	
20488	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
20489	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
20490	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20491	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20492	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20493	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20494	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
20495	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
20496	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
20497	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20498	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20499	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20500	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	0	
20501	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
20502	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20503	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20504	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20505	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20506	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
20507	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
20508	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
20509	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
20510	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
20511	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
20512	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
20513	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
20514	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
20515	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
20516	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
20517	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
20518	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
20519	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	31	
20520	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	31	
20521	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
20522	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
20523	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
20524	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments		
20525	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
20526	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
20527	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
20528	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
20529	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
20530	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
20531	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
20532	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
20533	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
20534	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
20535	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
20536	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
20537	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
20538	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
20539	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
20540	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
20541	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
20542	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
20543	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
20544	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
20545	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
20546	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
20547	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
20548	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
20549	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
20550	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
20551	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
20552	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
20553	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
20554	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
20555	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
20556	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
20557	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
20558	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
20559	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
20560	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
20561	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
20562	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
20563	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	35	°C
20564	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	35	°C
20565	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
20566	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
20567	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	5754.24	kw
20568	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
20569	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
20570	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
20571	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
20572	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
20573	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
20574	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
20575	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
20576	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
20577	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
20578	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
20579	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
20580	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
20581	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
20582	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
20583	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
20584	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
20585	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
20586	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
20587	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
20588	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
20589	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
20590	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
20591	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
20592	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
20593	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
20594	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
20595	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
20596	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
20597	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
20598	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
20599	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
20600	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
20601	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
20602	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
20603	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
20604	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
20605	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
20606	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
20607	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
20608	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
20609	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
20610	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
20611	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
20612	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
20613	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
20614	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
20615	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
20616	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
20617	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
20618	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
20619	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
20620	12/11/2019 11:30	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
20621	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	W/LTC Trn Dynamic Health	0.00	
20622	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
20623	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.5994	
20624	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
20625	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
20626	12/11/2019 14:33	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
20627	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
20628	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
20629	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
20630	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
20631	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
20632	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
20633	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
20634	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
20635	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1582.40	kw
20636	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
20637	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
20638	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
20639	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
20640	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments		
20641	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
20642	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
20643	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
20644	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
20645	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
20646	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
20647	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
20648	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
20649	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
20650	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
20651	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
20652	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
20653	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
20654	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
20655	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
20656	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
20657	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
20658	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
20659	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments		
20660	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments		
20661	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
20662	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
20663	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
20664	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1389.60	kw
20665	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
20666	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
20667	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
20668	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
20669	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
20670	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
20671	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
20672	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
20673	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
20674	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
20675	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
20676	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
20677	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
20678	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
20679	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
20680	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
20681	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
20682	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
20683	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
20684	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20685	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20686	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20687	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20688	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
20689	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
20690	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
20691	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
20692	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
20693	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
20694	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	213.0	
20695	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	189.0	
20696	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	181.0	
20697	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20698	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20699	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20700	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
20701	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20702	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
20703	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
20704	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	44	
20705	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	44	
20706	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
20707	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
20708	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
20709	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
20710	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
20711	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
20712	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
20713	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
20714	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
20715	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20716	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20717	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20718	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20719	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
20720	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
20721	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
20722	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20723	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20724	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20725	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	0	
20726	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9890	
20727	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
20728	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
20729	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
20730	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
20731	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
20732	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
20733	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
20734	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
20735	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
20736	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
20737	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
20738	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
20739	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
20740	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
20741	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
20742	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1580	
20743	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
20744	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
20745	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
20746	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
20747	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
20748	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
20749	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
20750	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
20751	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	LTC0000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
20752	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Unknown Operations	0	
20753	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Switching Operations	0	
20754	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations This Read Vac	0	
20755	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AL	191	
20756	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AF	191	
20757	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Maintenance Operations	0	
20758	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments		
20759	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments		
20760	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
20761	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
20762	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
20763	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
20764	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
20765	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
20766	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20767	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20768	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20769	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20770	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
20771	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
20772	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
20773	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
20774	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
20775	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
20776	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20777	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
20778	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20779	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20780	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20781	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	90.0	
20782	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	90.0	
20783	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
20784	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
20785	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
20786	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
20787	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
20788	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
20789	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
20790	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
20791	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
20792	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
20793	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
20794	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
20795	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	20959	
20796	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
20797	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
20798	12/11/2019 10:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
20799	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
20800	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
20801	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
20802	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	179	
20803	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	179	
20804	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
20805	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
20806	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
20807	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
20808	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
20809	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
20810	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
20811	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
20812	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	
20813	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20814	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20815	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20816	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20817	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
20818	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
20819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
20820	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20821	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20822	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20823	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	0	
20824	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
20825	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
20826	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
20827	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
20828	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
20829	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
20830	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
20831	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
20832	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
20833	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
20834	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
20835	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
20836	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		
20837	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
20838	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
20839	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
20840	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
20841	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
20842	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
20843	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20844	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20845	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20846	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20847	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
20848	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
20849	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
20850	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20851	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20852	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20853	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
20854	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
20855	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	0	
20856	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20857	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20858	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20859	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
20860	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
20861	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
20862	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20863	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20864	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20865	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20866	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
20867	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
20868	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
20869	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
20870	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
20871	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
20872	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
20873	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
20874	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
20875	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	52	
20876	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	52	
20877	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
20878	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
20879	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
20880	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	0	
20881	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20882	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20883	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20884	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
20885	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
20886	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
20887	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20888	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
20889	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
20890	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
20891	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
20892	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
20893	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
20894	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
20895	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
20896	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
20897	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
20898	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
20899	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
20900	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
20901	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
20902	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
20903	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
20904	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
20905	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
20906	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
20907	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
20908	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	3	
20909	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20910	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20911	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20912	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	82.0	
20913	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	81.0	
20914	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	81.0	
20915	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20916	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20917	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20918	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20919	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
20920	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
20921	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
20922	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	
20923	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
20924	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
20925	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments		
20926	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
20927	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
20928	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	111	
20929	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	111	
20930	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations This Read Vac	0	
20931	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
20932	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	0	
20933	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
20934	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
20935	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
20936	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	223	
20937	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	223	
20938	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
20939	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
20940	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
20941	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
20942	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
20943	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
20944	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
20945	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
20946	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
20947	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
20948	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
20949	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
20950	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
20951	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20952	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20953	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20954	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20955	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
20956	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
20957	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
20958	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
20959	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
20960	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
20961	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
20962	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
20963	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
20964	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
20965	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
20966	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
20967	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
20968	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
20969	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
20970	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
20971	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations This Read Vac	0	
20972	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	95	
20973	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	95	
20974	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
20975	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments		
20976	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
20977	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
20978	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
20979	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
20980	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
20981	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
20982	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
20983	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20984	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20985	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20986	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
20987	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	40	*F
20988	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
20989	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
20990	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
20991	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
20992	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
20993	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
20994	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
20995	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
20996	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
20997	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
20998	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
20999	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
21000	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
21001	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
21002	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments		
21003	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
21004	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	149	
21005	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	149	
21006	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	
21007	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
21008	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
21009	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Unknown Operations	3	
21010	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Switching Operations	0	
21011	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations This Read Vac	3	
21012	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AL	174	
21013	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AF	174	
21014	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Maintenance Operations	0	
21015	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	General Comments		
21016	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	General Comments		
21017	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Follow-up Action Required?	n	
21018	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Follow-up Action Required?	n	
21019	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations Ground	0	
21020	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations C Ø	0	
21021	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations B Ø	0	
21022	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations A Ø	0	
21023	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps C Phase V	102.07	
21024	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps B Phase V	102.07	
21025	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps A Phase V	102.07	
21026	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21027	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	81.0	
21028	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	84.0	
21029	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	85.0	
21030	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	.9 %	
21031	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	.9 %	
21032	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	.9 %	
21033	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	4	
21034	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
21035	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
21036	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
21037	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
21038	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	20R	
21039	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	2R	
21040	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	2R	
21041	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
21042	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4317	
21043	12/11/2019 9:59	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4317	
21044	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
21045	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
21046	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
21047	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
21048	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
21049	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
21050	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
21051	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00 %	
21052	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00 %	
21053	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00 %	
21054	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
21055	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
21056	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
21057	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
21058	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
21059	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
21060	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
21061	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
21062	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
21063	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
21064	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
21065	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
21066	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
21067	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
21068	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
21069	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
21070	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
21071	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
21072	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
21073	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
21074	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
21075	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
21076	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21077	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
21078	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
21079	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
21080	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
21081	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21082	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21083	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21084	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21085	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21086	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21087	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	5.46	
21088	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.46	
21089	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.46	
21090	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
21091	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
21092	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
21093	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
21094	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
21095	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
21096	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	89	
21097	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	89	
21098	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
21099	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
21100	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
21101	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
21102	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
21103	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
21104	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
21105	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
21106	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
21107	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21108	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21109	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21110	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21111	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
21112	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
21113	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
21114	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21115	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21116	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21117	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations	0	
21118	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
21119	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
21120	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
21121	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
21122	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	21	°C
21123	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	62	°C
21124	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
21125	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
21126	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
21127	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
21128	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
21129	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
21130	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
21131	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
21132	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
21133	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
21134	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
21135	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
21136	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
21137	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
21138	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
21139	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
21140	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
21141	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
21142	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
21143	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
21144	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
21145	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
21146	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
21147	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
21148	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
21149	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
21150	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
21151	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21152	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
21153	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
21154	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
21155	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
21156	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
21157	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
21158	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
21159	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
21160	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
21161	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
21162	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
21163	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
21164	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
21165	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
21166	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
21167	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
21168	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	25	°C
21169	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
21170	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
21171	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments		
21172	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
21173	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
21174	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
21175	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
21176	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
21177	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
21178	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
21179	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
21180	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
21181	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
21182	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	70	°C
21183	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
21184	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?		
21185	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	3214.08	kw
21186	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
21187	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
21188	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
21189	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
21190	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
21191	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
21192	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
21193	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
21194	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
21195	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
21196	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
21197	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
21198	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
21199	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
21200	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
21201	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
21202	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
21203	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
21204	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
21205	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
21206	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	0	
21207	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21208	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21209	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21210	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A ∅	0.0	
21211	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B ∅	0.0	
21212	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C ∅	0.0	
21213	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21214	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21215	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21216	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21217	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A ∅	0	
21218	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B ∅	0	
21219	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C ∅	0	
21220	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
21221	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
21222	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
21223	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
21224	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
21225	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
21226	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
21227	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
21228	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
21229	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
21230	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
21231	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
21232	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
21233	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
21234	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
21235	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
21236	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLT Bushing Dynamic Health	0.00	
21237	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
21238	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
21239	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.3348	
21240	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
21241	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
21242	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
21243	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	60	
21244	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	60	
21245	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	
21246	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	
21247	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
21248	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
21249	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	964	
21250	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	964	
21251	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
21252	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
21253	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
21254	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21255	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21256	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21257	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
21258	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
21259	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
21260	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
21261	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21262	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21263	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21264	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
21265	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
21266	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
21267	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21268	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21269	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21270	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21271	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
21272	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
21273	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
21274	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
21275	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
21276	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
21277	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
21278	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
21279	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
21280	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
21281	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
21282	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
21283	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
21284	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
21285	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
21286	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	569	
21287	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
21288	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
21289	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
21290	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
21291	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
21292	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
21293	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
21294	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
21295	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
21296	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
21297	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
21298	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	7.0	VDC
21299	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
21300	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
21301	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21302	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
21303	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
21304	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
21305	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
21306	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
21307	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
21308	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
21309	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
21310	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
21311	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
21312	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
21313	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
21314	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
21315	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
21316	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
21317	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
21318	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments		
21319	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
21320	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
21321	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
21322	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
21323	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
21324	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
21325	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
21326	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
21327	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
21328	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
21329	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
21330	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
21331	12/11/2019 13:57	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
21332	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	0	
21333	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21334	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21335	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21336	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
21337	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
21338	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
21339	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21340	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21341	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21342	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21343	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
21344	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
21345	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
21346	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
21347	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
21348	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
21349	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
21350	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
21351	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
21352	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	69	
21353	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	69	
21354	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
21355	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
21356	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
21357	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21358	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21359	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21360	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21361	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21362	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21363	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21364	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21365	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21366	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
21367	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	305.0	
21368	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	370.0	
21369	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	365.0	
21370	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21371	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21372	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21373	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	2	
21374	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
21375	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
21376	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21377	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
21378	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
21379	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
21380	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
21381	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
21382	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
21383	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
21384	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
21385	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
21386	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
21387	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
21388	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
21389	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
21390	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
21391	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
21392	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
21393	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
21394	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
21395	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
21396	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
21397	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
21398	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
21399	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
21400	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
21401	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
21402	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
21403	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
21404	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
21405	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
21406	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
21407	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
21408	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
21409	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	569	
21410	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
21411	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
21412	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
21413	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
21414	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
21415	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
21416	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
21417	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	0	
21418	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21419	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21420	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21421	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	100.0	
21422	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	97.0	
21423	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	95.0	
21424	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21425	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21426	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21427	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21428	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
21429	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
21430	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
21431	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
21432	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
21433	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
21434	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		
21435	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
21436	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
21437	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	78	
21438	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	78	
21439	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
21440	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
21441	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
21442	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
21443	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
21444	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
21445	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	1	
21446	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	1	
21447	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	227	
21448	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	227	
21449	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
21450	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
21451	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21452	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
21453	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
21454	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
21455	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
21456	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
21457	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
21458	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
21459	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
21460	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
21461	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
21462	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
21463	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	0	
21464	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations This Read Vac	0	
21465	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	185	
21466	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	185	
21467	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
21468	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
21469	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
21470	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
21471	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
21472	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
21473	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	
21474	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
21475	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
21476	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21477	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21478	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21479	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21480	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C Ø	103.0	
21481	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B Ø	101.0	
21482	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A Ø	103.0	
21483	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21484	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21485	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21486	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	0	
21487	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
21488	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
21489	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
21490	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
21491	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
21492	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
21493	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
21494	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
21495	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
21496	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
21497	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
21498	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
21499	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	27	°C
21500	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
21501	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	23	°C
21502	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
21503	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	27	°C
21504	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
21505	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
21506	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments	ok	
21507	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments	ok	
21508	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	40187	
21509	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	40204	
21510	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
21511	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	7L	
21512	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	4L	
21513	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	12L	
21514	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
21515	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
21516	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
21517	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
21518	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
21519	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
21520	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
21521	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	163.0	
21522	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	161.0	
21523	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	162.0	
21524	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21525	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21526	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21527	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	0	
21528	12/11/2019 9:56	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
21529	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
21530	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
21531	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
21532	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
21533	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
21534	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
21535	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
21536	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
21537	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
21538	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
21539	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
21540	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
21541	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
21542	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
21543	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
21544	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
21545	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
21546	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
21547	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
21548	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
21549	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
21550	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
21551	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
21552	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
21553	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
21554	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
21555	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
21556	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
21557	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
21558	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
21559	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
21560	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
21561	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
21562	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
21563	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
21564	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
21565	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
21566	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
21567	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
21568	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
21569	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
21570	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments	ok	
21571	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
21572	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
21573	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
21574	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
21575	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
21576	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
21577	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
21578	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
21579	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
21580	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
21581	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
21582	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
21583	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
21584	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
21585	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
21586	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
21587	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
21588	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
21589	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
21590	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
21591	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
21592	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
21593	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
21594	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
21595	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
21596	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
21597	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	226	
21598	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	226	
21599	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	0	
21600	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
21601	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
21602	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
21603	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
21604	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	ok	
21605	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
21606	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
21607	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
21608	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
21609	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
21610	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
21611	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
21612	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
21613	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
21614	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
21615	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
21616	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments	ok	
21617	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
21618	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	1467	
21619	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
21620	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
21621	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
21622	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
21623	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
21624	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
21625	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
21626	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
21627	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
21628	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
21629	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	36.0	
21630	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	32.0	
21631	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
21632	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
21633	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
21634	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
21635	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
21636	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
21637	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
21638	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
21639	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	249765	
21640	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	249770	
21641	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
21642	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	6L	
21643	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	5	
21644	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21645	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21646	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21647	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	40.0	
21648	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	50.0	
21649	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	60.0	
21650	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	3L	
21651	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	11L	
21652	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	931	
21653	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
21654	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
21655	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
21656	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
21657	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
21658	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
21659	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
21660	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21661	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21662	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21663	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21664	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21665	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21666	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21667	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21668	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21669	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
21670	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
21671	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21672	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21673	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
21674	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
21675	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
21676	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21677	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
21678	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
21679	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
21680	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
21681	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
21682	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
21683	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
21684	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
21685	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
21686	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
21687	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	0	
21688	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21689	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21690	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21691	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	158.0	
21692	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	152.0	
21693	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	156.0	
21694	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21695	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21696	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21697	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21698	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
21699	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
21700	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
21701	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
21702	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
21703	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
21704	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
21705	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
21706	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
21707	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	189	
21708	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	189	
21709	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	0	
21710	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
21711	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
21712	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
21713	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
21714	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
21715	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
21716	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
21717	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	97	
21718	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	97	
21719	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
21720	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
21721	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
21722	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
21723	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
21724	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
21725	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
21726	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
21727	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
21728	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
21729	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
21730	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
21731	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21732	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21733	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21734	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21735	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21736	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21737	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21738	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21739	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
21740	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21741	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21742	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21743	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
21744	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
21745	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
21746	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21747	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
21748	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
21749	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21750	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21751	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21752	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
21753	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
21754	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
21755	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
21756	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
21757	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
21758	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
21759	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
21760	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
21761	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
21762	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
21763	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
21764	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
21765	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
21766	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
21767	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
21768	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
21769	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	356	
21770	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	356	
21771	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	1	
21772	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	1	
21773	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
21774	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
21775	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
21776	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
21777	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
21778	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
21779	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
21780	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
21781	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21782	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
21783	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
21784	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	
21785	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
21786	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
21787	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Follow-up Action Required?	n	
21788	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	General Comments		
21789	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments		
21790	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
21791	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	101	
21792	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	101	
21793	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations This Read Vac	0	
21794	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
21795	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
21796	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
21797	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
21798	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
21799	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
21800	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
21801	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
21802	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
21803	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
21804	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21805	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21806	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21807	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations A Ø	0	
21808	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations B Ø	0	
21809	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
21810	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
21811	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
21812	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
21813	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments		
21814	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
21815	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21816	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21817	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21818	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
21819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
21820	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
21821	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21822	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21823	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
21824	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
21825	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21826	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21827	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21828	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21829	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21830	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
21831	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	120.0	
21832	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	110.0	
21833	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	100.0	
21834	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21835	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21836	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21837	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	5	
21838	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments		
21839	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
21840	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21841	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21842	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
21843	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
21844	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
21845	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
21846	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
21847	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	0	
21848	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	57	
21849	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	57	
21850	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
21851	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
21852	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Grounds in Place?	y	
21853	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
21854	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
21855	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
21856	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
21857	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
21858	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
21859	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
21860	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
21861	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
21862	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
21863	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
21864	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
21865	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
21866	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
21867	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
21868	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
21869	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
21870	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTLC Bushing Dynamic Health	0.00	
21871	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	140.00	
21872	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	40	°C
21873	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	55	°C
21874	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	1.3692	
21875	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
21876	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
21877	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
21878	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
21879	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
21880	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Foundation Condition	Good	
21881	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
21882	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
21883	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
21884	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
21885	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
21886	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
21887	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21888	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21889	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21890	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21891	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21892	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
21893	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
21894	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
21895	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
21896	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
21897	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
21898	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
21899	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21900	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21901	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
21902	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
21903	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
21904	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
21905	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
21906	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
21907	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
21908	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments		
21909	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments		
21910	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
21911	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	205	
21912	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	205	
21913	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	0	
21914	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
21915	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
21916	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
21917	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	151.0	
21918	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	149.0	
21919	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	148.0	
21920	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21921	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21922	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21923	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21924	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	
21925	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	
21926	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
21927	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
21928	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
21929	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
21930	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
21931	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
21932	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
21933	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	119	
21934	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	119	
21935	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
21936	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
21937	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
21938	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	
21939	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
21940	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
21941	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
21942	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
21943	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
21944	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	706	
21945	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	706	
21946	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
21947	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
21948	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
21949	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
21950	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
21951	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
21952	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
21953	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
21954	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
21955	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
21956	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
21957	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
21958	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
21959	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
21960	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
21961	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
21962	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
21963	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
21964	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21965	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21966	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21967	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21968	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21969	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
21970	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
21971	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
21972	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
21973	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21974	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21975	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
21976	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
21977	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
21978	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
21979	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
21980	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
21981	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
21982	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
21983	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
21984	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
21985	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
21986	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
21987	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
21988	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
21989	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
21990	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
21991	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
21992	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments		
21993	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments		
21994	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
21995	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
21996	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	212	
21997	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	212	
21998	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
21999	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
22000	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22001	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
22002	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
22003	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
22004	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
22005	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
22006	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
22007	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22008	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22009	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22010	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22011	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22012	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22013	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
22014	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22015	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22016	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22017	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22018	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
22019	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	150.0	
22020	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
22021	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	0	
22022	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22023	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22024	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22025	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps A Ø	54.0	
22026	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
22027	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
22028	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22029	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22030	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22031	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
22032	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
22033	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
22034	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
22035	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
22036	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
22037	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
22038	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
22039	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
22040	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
22041	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
22042	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
22043	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
22044	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22045	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	120.0	
22046	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	120.0	
22047	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22048	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22049	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
22050	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
22051	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22052	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22053	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22054	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22055	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22056	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22057	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22058	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22059	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
22060	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	0	
22061	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
22062	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	1	
22063	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
22064	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
22065	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
22066	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
22067	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments	1 Trip check, 1 Instantaneous C phase and Neutral	
22068	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments	ok	
22069	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
22070	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22071	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	1	
22072	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
22073	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	190	
22074	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	190	
22075	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22076	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	2	
22077	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
22078	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
22079	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22080	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22081	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22082	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22083	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22084	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
22085	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	140.0	
22086	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	130.0	
22087	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	130.0	
22088	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
22089	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
22090	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
22091	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22092	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
22093	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
22094	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
22095	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
22096	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
22097	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	0	
22098	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	137	
22099	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	137	
22100	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
22101	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	0	
22102	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22103	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
22104	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
22105	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
22106	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22107	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
22108	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	19	
22109	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	19	
22110	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22111	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
22112	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
22113	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	500	
22114	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	500	
22115	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
22116	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22117	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
22118	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
22119	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
22120	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
22121	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
22122	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22123	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
22124	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
22125	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
22126	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22127	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
22128	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
22129	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22130	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22131	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	4	
22132	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22133	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22134	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22135	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22136	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22137	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22138	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22139	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22140	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
22141	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22142	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22143	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22144	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
22145	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22146	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
22147	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
22148	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
22149	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.6	VDC
22150	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
22151	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
22152	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
22153	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
22154	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
22155	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
22156	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22157	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
22158	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	108.0	
22159	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	108.0	
22160	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	78.0	
22161	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	230.0	
22162	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	260.0	
22163	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	220.0	
22164	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
22165	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22166	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22167	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22168	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22169	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22170	12/11/2019 11:57	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22171	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22172	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
22173	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
22174	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
22175	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
22176	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22177	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22178	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	2	
22179	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	0	
22180	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22181	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22182	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22183	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	82.0	
22184	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	81.0	
22185	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	81.0	
22186	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22187	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22188	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22189	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22190	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22191	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	8	
22192	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
22193	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22194	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22195	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22196	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
22197	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
22198	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
22199	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22200	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22201	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22202	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22203	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
22204	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
22205	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	0	
22206	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	158	
22207	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	158	
22208	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
22209	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
22210	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
22211	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
22212	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
22213	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
22214	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
22215	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
22216	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
22217	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
22218	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
22219	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
22220	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22221	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22222	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22223	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22224	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22225	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22226	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22227	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22228	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22229	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
22230	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	12.0	
22231	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	43.0	
22232	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	33.0	
22233	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22234	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22235	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22236	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	3	
22237	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
22238	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
22239	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	0	
22240	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	0	
22241	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22242	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	2	
22243	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22244	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22245	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22246	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22247	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22248	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22249	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22250	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22251	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
22252	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
22253	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	B80278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
22254	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	63.0	
22255	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	63.0	
22256	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22257	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	163	
22258	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	163	
22259	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
22260	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
22261	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
22262	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
22263	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
22264	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
22265	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
22266	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
22267	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
22268	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
22269	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	0	
22270	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	144	
22271	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	144	
22272	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
22273	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	0	
22274	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22275	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
22276	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22277	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
22278	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
22279	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
22280	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
22281	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22282	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
22283	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
22284	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
22285	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
22286	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
22287	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
22288	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
22289	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
22290	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
22291	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
22292	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
22293	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22294	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22295	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22296	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22297	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22298	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22299	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22300	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22301	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22302	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
22303	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	640.0	
22304	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
22305	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22306	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	1	
22307	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	85	
22308	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	85	
22309	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
22310	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
22311	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
22312	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
22313	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
22314	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
22315	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
22316	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
22317	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
22318	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
22319	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
22320	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
22321	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
22322	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
22323	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
22324	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22325	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22326	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22327	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22328	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22329	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	46.0	
22330	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	10.0	
22331	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	61.0	
22332	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22333	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22334	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22335	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	4	
22336	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	640.0	
22337	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	640.0	
22338	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22339	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22340	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22341	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	1	
22342	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
22343	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
22344	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
22345	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
22346	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
22347	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	25	°C
22348	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	55	°C
22349	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
22350	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
22351	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	13144.32	kw

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22352	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
22353	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
22354	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
22355	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
22356	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
22357	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
22358	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	0	
22359	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	74	
22360	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	74	
22361	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
22362	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
22363	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Grounds in Place?	y	
22364	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
22365	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
22366	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Foundation Condition	Good	
22367	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
22368	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
22369	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
22370	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	0	
22371	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
22372	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
22373	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
22374	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	151.0	
22375	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	148.0	
22376	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	148.0	
22377	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22378	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22379	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22380	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22381	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
22382	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
22383	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
22384	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
22385	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
22386	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
22387	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
22388	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
22389	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
22390	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22391	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22392	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22393	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22394	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22395	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
22396	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
22397	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22398	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22399	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22400	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	118.0	
22401	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22402	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
22403	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
22404	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
22405	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
22406	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
22407	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
22408	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
22409	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
22410	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
22411	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
22412	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22413	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
22414	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
22415	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	27	
22416	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	27	
22417	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
22418	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22419	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
22420	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
22421	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
22422	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	157.0	
22423	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	106.0	
22424	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22425	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22426	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22427	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	0	
22428	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	1	
22429	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
22430	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
22431	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
22432	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	81	
22433	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	81	
22434	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22435	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
22436	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	96	
22437	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	96	
22438	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
22439	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments		
22440	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments		
22441	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
22442	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
22443	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
22444	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
22445	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
22446	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
22447	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
22448	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
22449	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	143	
22450	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	143	
22451	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
22452	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
22453	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
22454	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
22455	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
22456	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
22457	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
22458	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
22459	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
22460	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
22461	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
22462	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
22463	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
22464	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
22465	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
22466	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
22467	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
22468	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
22469	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
22470	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
22471	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
22472	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.6078	
22473	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
22474	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
22475	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
22476	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
22477	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
22478	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
22479	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
22480	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
22481	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	40	°C
22482	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	60	°C
22483	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
22484	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
22485	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
22486	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	5834.88	kw
22487	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
22488	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments	ok	
22489	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments	ok	
22490	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
22491	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
22492	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
22493	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
22494	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
22495	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
22496	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
22497	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
22498	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
22499	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22500	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22501	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22502	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22503	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	105.0	
22504	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	107.0	
22505	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	109.0	
22506	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22507	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22508	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22509	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	3	
22510	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
22511	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
22512	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
22513	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
22514	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
22515	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
22516	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
22517	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
22518	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
22519	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
22520	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9432	
22521	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
22522	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
22523	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
22524	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
22525	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
22526	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
22527	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
22528	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
22529	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
22530	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
22531	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
22532	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
22533	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
22534	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
22535	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
22536	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
22537	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1697.76	kw
22538	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
22539	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
22540	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
22541	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
22542	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
22543	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
22544	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
22545	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
22546	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
22547	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
22548	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
22549	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
22550	12/11/2019 7:00	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
22551	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
22552	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	3	
22553	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	3	
22554	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
22555	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
22556	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
22557	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
22558	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
22559	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
22560	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
22561	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
22562	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
22563	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22564	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22565	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22566	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22567	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	667.0	
22568	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	0	
22569	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	28.94	%
22570	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	680.0	
22571	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	682.0	
22572	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22573	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22574	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22575	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	0	
22576	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	28.94	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22577	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	28.94	%
22578	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
22579	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
22580	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	0	
22581	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations This Read Vac	0	
22582	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
22583	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
22584	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22585	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22586	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22587	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
22588	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
22589	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22590	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
22591	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22592	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22593	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22594	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22595	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22596	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
22597	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
22598	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22599	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22600	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
22601	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
22602	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	170.0	
22603	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
22604	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22605	12/11/2019 10:58	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22606	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	84	
22607	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	84	
22608	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
22609	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
22610	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
22611	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
22612	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
22613	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
22614	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
22615	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
22616	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
22617	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
22618	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
22619	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
22620	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22621	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22622	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22623	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22624	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22625	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22626	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22627	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22628	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	341.0	
22629	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	338.0	
22630	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	423.0	
22631	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22632	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22633	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22634	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	0	
22635	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
22636	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
22637	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
22638	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22639	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	0	
22640	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	81	
22641	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	81	
22642	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
22643	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
22644	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
22645	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
22646	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
22647	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
22648	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
22649	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
22650	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
22651	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22652	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
22653	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
22654	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
22655	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
22656	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
22657	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Grounds in Place?	y	
22658	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	
22659	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	0	
22660	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22661	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22662	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22663	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	960	
22664	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	960	
22665	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
22666	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
22667	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
22668	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22669	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22670	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22671	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	21.0	
22672	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	35.0	
22673	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
22674	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
22675	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	General Comments		
22676	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
22677	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
22678	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
22679	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
22680	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
22681	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
22682	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
22683	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
22684	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22685	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
22686	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22687	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22688	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22689	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	90.0	
22690	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	150.0	
22691	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	90.0	
22692	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
22693	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
22694	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22695	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22696	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22697	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22698	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
22699	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
22700	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
22701	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
22702	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160.0	
22703	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	90.0	
22704	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
22705	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22706	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22707	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22708	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22709	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	42.0	
22710	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	0	
22711	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
22712	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
22713	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
22714	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
22715	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
22716	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
22717	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22718	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22719	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22720	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22721	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
22722	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
22723	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
22724	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
22725	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
22726	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
22727	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
22728	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
22729	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
22730	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	60	
22731	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	60	
22732	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	0	
22733	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
22734	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
22735	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22736	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22737	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22738	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	0	
22739	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
22740	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	29.0	
22741	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22742	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22743	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22744	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	2	
22745	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
22746	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
22747	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
22748	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22749	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	0	
22750	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	69	
22751	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	69	
22752	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
22753	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
22754	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
22755	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
22756	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
22757	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
22758	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
22759	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
22760	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
22761	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
22762	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
22763	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
22764	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22765	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
22766	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
22767	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	161	
22768	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
22769	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
22770	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
22771	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22772	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22773	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22774	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
22775	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
22776	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
22777	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5247.36	kw
22778	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
22779	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
22780	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
22781	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
22782	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22783	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22784	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22785	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22786	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	161.0	
22787	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	147.0	
22788	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	172.0	
22789	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22790	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22791	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22792	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
22793	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
22794	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
22795	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
22796	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
22797	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22798	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
22799	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
22800	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
22801	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22802	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
22803	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5466	
22804	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations This Read Vac	0	
22805	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	201	
22806	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	201	
22807	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
22808	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
22809	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22810	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
22811	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	1	
22812	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
22813	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
22814	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
22815	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22816	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
22817	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
22818	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
22819	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22820	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22821	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22822	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
22823	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
22824	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
22825	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
22826	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
22827	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
22828	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
22829	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
22830	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
22831	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22832	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
22833	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
22834	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
22835	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
22836	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
22837	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
22838	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
22839	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
22840	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
22841	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
22842	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
22843	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
22844	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
22845	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
22846	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
22847	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
22848	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
22849	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
22850	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
22851	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
22852	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
22853	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
22854	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
22855	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
22856	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
22857	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
22858	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
22859	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
22860	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
22861	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
22862	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
22863	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
22864	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
22865	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
22866	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
22867	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
22868	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
22869	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
22870	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
22871	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
22872	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
22873	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
22874	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
22875	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	1255.0	volts
22876	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5915	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22877	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
22878	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
22879	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
22880	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
22881	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
22882	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
22883	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
22884	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
22885	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
22886	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
22887	12/11/2019 14:01	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
22888	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
22889	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
22890	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
22891	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	6.0	
22892	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
22893	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
22894	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
22895	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
22896	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
22897	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
22898	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22899	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	2	
22900	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	192	
22901	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
22902	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
22903	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
22904	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
22905	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
22906	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
22907	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
22908	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
22909	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
22910	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
22911	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
22912	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
22913	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
22914	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
22915	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
22916	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
22917	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	23	*F
22918	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
22919	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	192	
22920	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
22921	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
22922	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
22923	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
22924	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
22925	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
22926	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
22927	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	2	
22928	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
22929	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
22930	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	General Comments	ok	
22931	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
22932	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
22933	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
22934	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
22935	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
22936	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
22937	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
22938	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	229	
22939	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	229	
22940	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	2	
22941	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
22942	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	2	
22943	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
22944	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
22945	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
22946	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
22947	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
22948	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22949	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	0	
22950	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
22951	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
22952	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
22953	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
22954	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments	ok	
22955	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
22956	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
22957	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	General Comments		
22958	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
22959	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
22960	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
22961	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
22962	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
22963	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
22964	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
22965	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
22966	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
22967	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
22968	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
22969	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
22970	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
22971	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
22972	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
22973	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	0	
22974	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
22975	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	0	
22976	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	213	
22977	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	213	
22978	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
22979	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
22980	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
22981	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	58.0	
22982	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	49.0	
22983	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
22984	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
22985	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
22986	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	7	
22987	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
22988	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
22989	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
22990	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
22991	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
22992	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	General Comments		
22993	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
22994	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
22995	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	1L	
22996	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
22997	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	72	
22998	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	72	
22999	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
23000	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
23001	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
23002	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23003	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23004	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
23005	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
23006	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
23007	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
23008	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
23009	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
23010	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
23011	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
23012	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
23013	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
23014	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
23015	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
23016	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
23017	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
23018	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
23019	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
23020	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
23021	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	5356.80	kw
23022	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
23023	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
23024	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
23025	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23026	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
23027	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments	ok	
23028	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments	ok	
23029	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
23030	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
23031	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
23032	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
23033	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
23034	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
23035	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
23036	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23037	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23038	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23039	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps C Ø	0.0	
23040	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps B Ø	0.0	
23041	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps A Ø	0.0	
23042	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23043	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23044	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23045	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations	0	
23046	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
23047	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
23048	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	808	
23049	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	5L	
23050	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	3R	
23051	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	2R	
23052	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
23053	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	10698	
23054	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	10690	
23055	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
23056	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
23057	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
23058	12/11/2019 7:57	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
23059	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23060	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23061	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23062	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23063	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23064	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23065	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23066	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23067	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23068	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
23069	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	68.0	
23070	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23071	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
23072	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23073	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23074	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23075	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	2	
23076	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	112	
23077	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	0	
23078	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
23079	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
23080	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
23081	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
23082	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
23083	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
23084	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
23085	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
23086	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	1	
23087	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	184	
23088	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	184	
23089	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
23090	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	1	
23091	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23092	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	7	
23093	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	4.48	%
23094	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
23095	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
23096	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
23097	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	0	
23098	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	0	
23099	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23100	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	54.0	
23101	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	50.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23102	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	148	
23103	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	148	
23104	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
23105	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
23106	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	
23107	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
23108	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
23109	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
23110	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
23111	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	
23112	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
23113	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments	ok	
23114	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Unknown Operations	0	
23115	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Switching Operations	0	
23116	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations This Read Vac	0	
23117	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AL	65	
23118	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AF	65	
23119	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Maintenance Operations	0	
23120	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	General Comments		
23121	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	General Comments		
23122	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Follow-up Action Required?	n	
23123	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Follow-up Action Required?	n	
23124	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations Ground	0	
23125	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations C Ø	0	
23126	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations B Ø	0	
23127	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations A Ø	0	
23128	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23129	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
23130	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
23131	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	112	
23132	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
23133	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
23134	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23135	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
23136	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
23137	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
23138	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2069.28	kw
23139	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
23140	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
23141	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
23142	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
23143	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
23144	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
23145	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
23146	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
23147	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
23148	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
23149	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
23150	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
23151	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23152	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23153	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23154	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23155	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23156	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23157	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23158	12/11/2019 11:59	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23159	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23160	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23161	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23162	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
23163	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	81.0	
23164	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	68.0	
23165	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	61.0	
23166	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
23167	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
23168	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
23169	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	125	
23170	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	125	
23171	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
23172	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
23173	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
23174	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
23175	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
23176	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23177	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
23178	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
23179	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
23180	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23181	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23182	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23183	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23184	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
23185	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
23186	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
23187	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23188	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23189	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23190	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23191	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23192	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	4	
23193	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
23194	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
23195	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
23196	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
23197	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
23198	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
23199	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
23200	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
23201	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
23202	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
23203	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	52.0	
23204	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23205	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	68.05	
23206	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	68.05	
23207	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	68.05	
23208	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
23209	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
23210	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
23211	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
23212	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
23213	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
23214	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
23215	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
23216	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
23217	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
23218	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
23219	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
23220	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
23221	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
23222	12/11/2019 11:29	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8622	
23223	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
23224	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
23225	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
23226	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
23227	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments	1 trip check	
23228	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
23229	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
23230	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
23231	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
23232	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
23233	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
23234	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
23235	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
23236	12/11/2019 12:17	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
23237	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
23238	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
23239	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
23240	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	0	
23241	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
23242	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23243	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23244	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23245	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23246	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23247	12/11/2019 7:31	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23248	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
23249	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
23250	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23251	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
23252	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23253	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
23254	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
23255	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps C Ø	35.0	
23256	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
23257	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	0	
23258	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23259	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23260	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23261	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
23262	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23263	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23264	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	75.0	
23265	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	40.0	
23266	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
23267	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	10	°C
23268	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	15	°C
23269	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.5580	
23270	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
23271	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
23272	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23273	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23274	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
23275	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23276	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23277	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	0	
23278	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23279	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
23280	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
23281	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
23282	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23283	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23284	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23285	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23286	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
23287	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
23288	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
23289	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
23290	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	
23291	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
23292	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations Ground	0	
23293	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23294	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23295	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23296	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23297	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23298	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23299	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23300	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
23301	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23302	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	20	°C
23303	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	30	°C
23304	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
23305	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
23306	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	450.0	
23307	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	450.0	
23308	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	450.0	
23309	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
23310	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23311	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations C Ø	0	
23312	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations B Ø	0	
23313	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations A Ø	0	
23314	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23315	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23316	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23317	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23318	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23319	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23320	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23321	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23322	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
23323	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
23324	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23325	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23326	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
23327	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
23328	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
23329	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23330	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23331	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23332	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
23333	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
23334	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23335	12/11/2019 11:45	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushing Condition	Good	
23336	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
23337	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
23338	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
23339	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
23340	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
23341	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	158	
23342	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	158	
23343	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
23344	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
23345	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
23346	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
23347	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
23348	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
23349	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
23350	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
23351	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
23352	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
23353	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	General Comments		
23354	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
23355	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	21499	
23356	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	21499	
23357	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
23358	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
23359	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	5	
23360	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23361	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23362	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
23363	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
23364	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
23365	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
23366	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
23367	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
23368	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23369	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	25.0	
23370	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	73.0	
23371	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	44.0	
23372	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
23373	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
23374	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
23375	12/11/2019 9:40	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23376	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	319	
23377	12/11/2019 13:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
23378	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
23379	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
23380	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
23381	12/11/2019 12:38	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
23382	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23383	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
23384	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23385	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23386	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
23387	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
23388	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	
23389	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
23390	12/4/2019 12:00	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
23391	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
23392	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
23393	12/11/2019 13:38	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
23394	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
23395	12/11/2019 12:13	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
23396	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
23397	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
23398	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
23399	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
23400	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
23401	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23477	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
23478	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
23479	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
23480	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
23481	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
23482	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
23483	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
23484	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
23485	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	791	
23486	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	791	
23487	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
23488	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
23489	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
23490	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
23491	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
23492	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
23493	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
23494	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	492	
23495	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	492	
23496	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
23497	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	HSI B and C phase	
23498	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
23499	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
23500	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
23501	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
23502	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
23503	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
23504	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
23505	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
23506	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
23507	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	360.0	
23508	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	380.0	
23509	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
23510	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
23511	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
23512	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
23513	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
23514	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
23515	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
23516	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
23517	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
23518	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23519	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23520	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
23521	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
23522	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
23523	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	General Comments		
23524	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
23525	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
23526	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
23527	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23528	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
23529	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
23530	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
23531	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
23532	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1967	
23533	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
23534	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23535	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23536	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23537	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23538	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23539	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	13	
23540	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
23541	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23542	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23543	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
23544	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
23545	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
23546	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23547	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23548	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
23549	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	LTC0000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
23550	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
23551	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23552	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
23553	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
23554	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
23555	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
23556	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
23557	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
23558	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
23559	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
23560	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
23561	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
23562	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
23563	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
23564	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
23565	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
23566	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
23567	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23568	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
23569	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
23570	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	219	
23571	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	219	
23572	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
23573	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
23574	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
23575	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
23576	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
23577	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
23578	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
23579	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	100.0	
23580	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
23581	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
23582	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
23583	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
23584	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
23585	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
23586	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
23587	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
23588	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
23589	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
23590	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
23591	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
23592	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
23593	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
23594	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments		
23595	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
23596	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
23597	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
23598	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
23599	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
23600	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
23601	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
23602	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
23603	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
23604	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
23605	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
23606	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
23607	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
23608	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
23609	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	100.0	
23610	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	100.0	
23611	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
23612	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
23613	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23614	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23615	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23616	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23617	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23618	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23619	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23620	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
23621	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
23622	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
23623	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
23624	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
23625	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
23626	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23627	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
23628	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
23629	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
23630	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		
23631	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
23632	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
23633	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
23634	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
23635	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
23636	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
23637	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
23638	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
23639	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	152266	
23640	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
23641	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
23642	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
23643	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
23644	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
23645	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
23646	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
23647	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	219	
23648	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
23649	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
23650	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
23651	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	86301	
23652	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
23653	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
23654	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
23655	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
23656	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
23657	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
23658	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
23659	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
23660	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
23661	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
23662	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
23663	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
23664	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
23665	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
23666	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
23667	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
23668	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
23669	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
23670	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
23671	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
23672	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
23673	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
23674	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
23675	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
23676	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
23677	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
23678	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
23679	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
23680	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
23681	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	4L	
23682	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
23683	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
23684	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
23685	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
23686	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
23687	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
23688	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
23689	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
23690	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
23691	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
23692	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
23693	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
23694	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
23695	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
23696	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
23697	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
23698	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
23699	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
23700	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
23701	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23702	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
23703	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
23704	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
23705	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
23706	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
23707	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
23708	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
23709	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	116628	
23710	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
23711	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
23712	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
23713	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
23714	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
23715	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
23716	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
23717	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
23718	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
23719	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	20181	
23720	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
23721	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
23722	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	63.0	
23723	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	80.0	
23724	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	37.0	
23725	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23726	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23727	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23728	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	1	
23729	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
23730	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
23731	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
23732	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
23733	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
23734	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
23735	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
23736	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
23737	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
23738	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	10.0	
23739	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
23740	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23741	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
23742	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23743	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23744	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
23745	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23746	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23747	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23748	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23749	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
23750	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
23751	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
23752	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
23753	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
23754	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
23755	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
23756	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
23757	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments		
23758	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
23759	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23760	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	0	
23761	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
23762	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
23763	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
23764	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
23765	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
23766	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
23767	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
23768	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
23769	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
23770	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
23771	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
23772	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
23773	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
23774	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?		
23775	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
23776	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23777	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
23778	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
23779	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
23780	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
23781	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
23782	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
23783	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
23784	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
23785	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
23786	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
23787	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
23788	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
23789	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
23790	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
23791	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
23792	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
23793	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
23794	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
23795	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
23796	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
23797	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
23798	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
23799	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23800	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23801	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
23802	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
23803	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
23804	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
23805	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
23806	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
23807	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
23808	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
23809	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
23810	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
23811	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	52.0	
23812	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
23813	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
23814	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
23815	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
23816	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
23817	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
23818	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7686	
23819	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
23820	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
23821	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
23822	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
23823	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
23824	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
23825	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
23826	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
23827	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
23828	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
23829	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
23830	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2459.52	kw
23831	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
23832	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
23833	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
23834	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
23835	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
23836	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
23837	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
23838	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
23839	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
23840	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
23841	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
23842	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
23843	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
23844	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
23845	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
23846	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
23847	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
23848	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
23849	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.1	VDC
23850	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	7.5	VDC
23851	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Battery bank inside BK000721 Float voltage: 54.6V. Positive to ground: 7.9V Negative to ground: 8.2V.	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
23852	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
23853	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
23854	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
23855	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
23856	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
23857	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
23858	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
23859	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
23860	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
23861	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
23862	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
23863	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
23864	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
23865	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
23866	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
23867	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
23868	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	General Comments		
23869	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
23870	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
23871	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
23872	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
23873	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	532	
23874	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	532	
23875	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
23876	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
23877	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
23878	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
23879	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
23880	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
23881	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
23882	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
23883	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
23884	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
23885	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
23886	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
23887	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
23888	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
23889	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64354	
23890	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
23891	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
23892	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
23893	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
23894	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	340	
23895	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
23896	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
23897	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
23898	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	720	
23899	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
23900	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	8L	
23901	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
23902	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
23903	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
23904	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
23905	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
23906	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
23907	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
23908	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
23909	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
23910	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
23911	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
23912	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
23913	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
23914	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	188	
23915	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	188	
23916	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	0	
23917	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
23918	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
23919	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
23920	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
23921	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
23922	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
23923	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
23924	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
23925	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
23926	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
23927	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	167033	
23928	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	167030	
23929	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
23930	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
23931	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
23932	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
23933	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
23934	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
23935	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
23936	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	
23937	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	149.0	
23938	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	116.0	
23939	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	113.0	
23940	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
23941	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
23942	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
23943	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
23944	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
23945	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
23946	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
23947	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
23948	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
23949	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
23950	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
23951	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
23952	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
23953	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
23954	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
23955	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
23956	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
23957	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
23958	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
23959	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
23960	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
23961	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
23962	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
23963	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	190	
23964	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	190	
23965	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	0	
23966	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
23967	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
23968	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
23969	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
23970	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
23971	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
23972	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
23973	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
23974	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
23975	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
23976	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
23977	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
23978	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
23979	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
23980	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
23981	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
23982	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
23983	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
23984	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
23985	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
23986	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
23987	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	20.0	
23988	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	20.0	
23989	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	20.0	
23990	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
23991	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
23992	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
23993	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
23994	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
23995	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B Ø	0	
23996	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C Ø	0	
23997	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
23998	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
23999	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
24000	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
24001	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments	IOC A Phase	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24002	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
24003	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
24004	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	150.0	
24005	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	150.0	
24006	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	170.0	
24007	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
24008	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
24009	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
24010	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
24011	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
24012	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	2	
24013	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
24014	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
24015	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
24016	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	120.0	
24017	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	60.0	
24018	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	120.0	
24019	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
24020	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
24021	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
24022	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
24023	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
24024	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
24025	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
24026	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
24027	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
24028	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24029	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24030	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
24031	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
24032	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
24033	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
24034	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
24035	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	2349.60	kw
24036	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
24037	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2	psi
24038	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	30	°C
24039	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	55	°C
24040	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
24041	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
24042	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
24043	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
24044	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
24045	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
24046	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments	serviceman reset counters	
24047	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
24048	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
24049	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
24050	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
24051	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.9790	
24052	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
24053	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
24054	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
24055	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
24056	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
24057	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
24058	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
24059	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
24060	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
24061	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
24062	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
24063	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
24064	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
24065	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
24066	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
24067	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
24068	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
24069	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	66.0	
24070	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	139	
24071	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	139	
24072	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	0	
24073	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
24074	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
24075	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
24076	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24077	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
24078	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
24079	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
24080	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
24081	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
24082	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
24083	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
24084	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
24085	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
24086	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
24087	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
24088	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
24089	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
24090	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
24091	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
24092	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
24093	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
24094	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
24095	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
24096	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
24097	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
24098	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
24099	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
24100	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
24101	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
24102	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
24103	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
24104	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
24105	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
24106	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	0	
24107	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
24108	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
24109	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
24110	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
24111	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
24112	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
24113	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
24114	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
24115	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
24116	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
24117	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
24118	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
24119	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	40	°C
24120	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	60	°C
24121	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24122	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
24123	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
24124	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
24125	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
24126	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
24127	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	5379.84	kw
24128	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
24129	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
24130	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
24131	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	0	
24132	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
24133	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
24134	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments	serviceman reset counters	
24135	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
24136	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
24137	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
24138	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
24139	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
24140	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
24141	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
24142	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
24143	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
24144	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
24145	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	165.0	
24146	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	176.0	
24147	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	199.0	
24148	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
24149	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments	ok	
24150	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments	ok	
24151	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24152	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
24153	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
24154	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
24155	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
24156	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
24157	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
24158	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
24159	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
24160	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
24161	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
24162	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
24163	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
24164	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
24165	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
24166	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
24167	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
24168	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
24169	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
24170	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	3	
24171	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
24172	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24173	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
24174	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
24175	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
24176	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
24177	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24178	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24179	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
24180	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
24181	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	13361	
24182	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24183	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
24184	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
24185	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24186	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24187	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
24188	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
24189	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
24190	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	413	
24191	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	8	
24192	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
24193	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
24194	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
24195	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	1	
24196	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	175	
24197	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	174	
24198	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
24199	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	1	
24200	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
24201	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
24202	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments	ok	
24203	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments	ok	
24204	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
24205	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
24206	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
24207	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
24208	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
24209	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
24210	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
24211	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24212	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24213	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24214	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
24215	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
24216	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
24217	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
24218	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
24219	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
24220	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
24221	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
24222	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.5604	
24223	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
24224	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
24225	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
24226	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24227	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
24228	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
24229	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
24230	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
24231	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
24232	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
24233	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
24234	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
24235	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
24236	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
24237	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
24238	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
24239	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments		
24240	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
24241	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
24242	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
24243	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
24244	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
24245	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
24246	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
24247	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
24248	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
24249	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
24250	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
24251	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
24252	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
24253	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
24254	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
24255	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
24256	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
24257	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
24258	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
24259	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
24260	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
24261	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24262	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
24263	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
24264	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
24265	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
24266	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		
24267	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
24268	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
24269	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
24270	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
24271	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
24272	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
24273	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
24274	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
24275	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
24276	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
24277	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
24278	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
24279	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	1	
24280	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
24281	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
24282	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
24283	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000333	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
24284	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000333	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
24285	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000333	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
24286	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LTC000333	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
24287	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.1	VDC
24288	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
24289	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
24290	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
24291	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
24292	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24293	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	86755	
24294	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
24295	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
24296	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24297	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
24298	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
24299	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
24300	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
24301	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24302	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
24303	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
24304	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
24305	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
24306	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
24307	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
24308	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
24309	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
24310	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
24311	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
24312	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
24313	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
24314	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
24315	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
24316	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24317	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
24318	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
24319	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
24320	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
24321	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
24322	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
24323	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
24324	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
24325	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
24326	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
24327	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
24328	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
24329	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
24330	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
24331	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
24332	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
24333	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
24334	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
24335	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
24336	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
24337	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
24338	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
24339	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
24340	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
24341	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
24342	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
24343	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
24344	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
24345	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
24346	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	413	
24347	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
24348	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
24349	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
24350	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
24351	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
24352	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
24353	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
24354	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
24355	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24356	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
24357	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
24358	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24359	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
24360	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24361	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24362	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
24363	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
24364	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations This Read Vac	0	
24365	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	164	
24366	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	164	
24367	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
24368	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	General Comments		
24369	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
24370	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
24371	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Unknown Operations	0	
24372	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Switching Operations	0	
24373	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations This Read Vac	0	
24374	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AL	100	
24375	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AF	100	
24376	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24377	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24378	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	General Comments		
24379	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Follow-up Action Required?	n	
24380	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations Ground	0	
24381	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations C Ø	0	
24382	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations B Ø	0	
24383	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24384	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
24385	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations A Ø	0	
24386	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24387	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24388	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24389	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	83.0	
24390	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	51.0	
24391	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	70.0	
24392	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
24393	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
24394	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
24395	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	0	
24396	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	8	
24397	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
24398	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
24399	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
24400	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	40.0	
24401	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	20.0	
24402	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	10.0	
24403	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
24404	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
24405	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
24406	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
24407	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
24408	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
24409	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
24410	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24411	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24412	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24413	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
24414	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
24415	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
24416	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
24417	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
24418	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
24419	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
24420	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
24421	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
24422	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
24423	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
24424	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
24425	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
24426	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
24427	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
24428	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
24429	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24430	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	33802	
24431	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
24432	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
24433	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
24434	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24435	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24436	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #-'s
24437	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
24438	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
24439	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
24440	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
24441	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
24442	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
24443	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
24444	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
24445	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
24446	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	8	
24447	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
24448	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
24449	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
24450	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
24451	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24452	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
24453	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
24454	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24455	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24456	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
24457	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
24458	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
24459	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
24460	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24461	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
24462	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
24463	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24464	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
24465	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24466	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24467	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24468	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24469	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
24470	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
24471	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
24472	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24473	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47704	
24474	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
24475	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
24476	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
24477	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
24478	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
24479	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
24480	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
24481	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24482	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24483	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24484	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24485	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
24486	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24487	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
24488	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
24489	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	0	
24490	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations This Read Vac	0	
24491	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	131	
24492	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	131	
24493	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	0	
24494	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
24495	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
24496	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
24497	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	0	
24498	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	0	
24499	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	
24500	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24501	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24502	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24503	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	31.0	
24504	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	32.0	
24505	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	33.0	
24506	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	2.98	%
24507	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
24508	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
24509	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
24510	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
24511	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
24512	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
24513	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
24514	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
24515	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
24516	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
24517	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
24518	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
24519	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
24520	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
24521	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
24522	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
24523	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
24524	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
24525	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
24526	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24527	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
24528	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
24529	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	455	
24530	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	455	
24531	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
24532	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
24533	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
24534	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
24535	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
24536	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	38041	
24537	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
24538	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	0	
24539	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	0	
24540	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	0	
24541	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	135	
24542	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	135	
24543	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
24544	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
24545	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
24546	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
24547	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
24548	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
24549	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
24550	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24551	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24552	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24553	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	43.0	
24554	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	49.0	
24555	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	26.0	
24556	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
24557	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
24558	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
24559	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	2	
24560	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
24561	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
24562	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
24563	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
24564	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
24565	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
24566	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	83435	
24567	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
24568	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
24569	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24570	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24571	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
24572	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
24573	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
24574	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
24575	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
24576	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
24577	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	9	
24578	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
24579	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
24580	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
24581	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
24582	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
24583	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
24584	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
24585	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
24586	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
24587	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
24588	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
24589	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
24590	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
24591	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24592	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24593	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
24594	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
24595	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
24596	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
24597	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
24598	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
24599	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
24600	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
24601	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24602	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
24603	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
24604	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
24605	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
24606	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	0	
24607	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
24608	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
24609	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
24610	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
24611	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
24612	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24613	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
24614	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments	serviceman reset counters	
24615	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
24616	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
24617	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
24618	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
24619	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
24620	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
24621	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
24622	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
24623	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
24624	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
24625	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
24626	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
24627	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
24628	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
24629	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
24630	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
24631	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24632	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	75920	
24633	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
24634	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
24635	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
24636	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
24637	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
24638	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
24639	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
24640	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
24641	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments		
24642	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
24643	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
24644	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
24645	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
24646	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
24647	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24648	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24649	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	16L	
24650	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	161	
24651	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	161	
24652	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	0	
24653	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
24654	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
24655	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
24656	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
24657	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
24658	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24659	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
24660	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
24661	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24662	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
24663	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24664	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24665	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
24666	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
24667	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
24668	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
24669	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
24670	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
24671	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
24672	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24673	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
24674	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
24675	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
24676	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	2	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24677	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
24678	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24679	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
24680	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24681	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24682	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24683	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24684	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24685	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
24686	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
24687	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24688	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
24689	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24690	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
24691	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
24692	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24693	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	90011	
24694	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24695	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24696	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24697	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
24698	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
24699	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24700	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
24701	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
24702	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24703	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24704	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	8L	
24705	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
24706	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
24707	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
24708	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24709	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
24710	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
24711	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
24712	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
24713	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
24714	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
24715	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
24716	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
24717	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
24718	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps \emptyset	76.0	
24719	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B \emptyset	82.0	
24720	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A \emptyset	69.0	
24721	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
24722	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24723	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
24724	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24725	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
24726	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24727	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24728	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24729	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
24730	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24731	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24732	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24733	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24734	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
24735	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24736	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	94336	
24737	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
24738	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
24739	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
24740	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
24741	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24742	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24743	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	207129	
24744	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
24745	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
24746	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
24747	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
24748	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
24749	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
24750	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
24751	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24752	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24753	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
24754	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24755	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
24756	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
24757	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
24758	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
24759	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24760	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
24761	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
24762	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24763	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
24764	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24765	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24766	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24767	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24768	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
24769	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24770	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24771	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
24772	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
24773	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
24774	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
24775	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24776	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24777	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
24778	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
24779	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24780	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	155857	
24781	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
24782	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
24783	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
24784	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24785	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
24786	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
24787	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
24788	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
24789	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24790	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
24791	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
24792	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	460.0	
24793	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	515.0	
24794	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24795	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24796	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	0.0	
24797	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	0.0	
24798	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	0.0	
24799	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
24800	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
24801	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
24802	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	1	
24803	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Unknown Operations	0	
24804	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Switching Operations	0	
24805	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations This Read Vac	0	
24806	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AL	159	
24807	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AF	159	
24808	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Maintenance Operations	0	
24809	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	General Comments		
24810	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Follow-up Action Required?	n	
24811	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
24812	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
24813	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	0	
24814	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24815	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	0	
24816	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
24817	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
24818	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
24819	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
24820	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments		
24821	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
24822	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	0	
24823	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24824	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24825	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
24826	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24827	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24828	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24829	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24830	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	320.0	
24831	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	460.0	
24832	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24833	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
24834	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
24835	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
24836	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
24837	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
24838	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments	C phase lightning arrester blown on low side	
24839	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
24840	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
24841	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
24842	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
24843	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
24844	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
24845	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
24846	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
24847	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
24848	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
24849	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
24850	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	8.77	%
24851	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
24852	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
24853	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
24854	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
24855	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
24856	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
24857	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
24858	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
24859	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
24860	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
24861	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
24862	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
24863	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
24864	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
24865	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
24866	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
24867	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24868	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24869	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24870	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
24871	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24872	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	4	
24873	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
24874	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
24875	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
24876	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	10.0	
24877	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	20.0	
24878	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
24879	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
24880	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
24881	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
24882	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
24883	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
24884	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
24885	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
24886	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	LTCC000109	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
24887	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
24888	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
24889	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
24890	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
24891	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	485.0	
24892	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
24893	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
24894	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24895	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
24896	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
24897	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	8.0	
24898	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
24899	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
24900	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
24901	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
24902	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
24903	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
24904	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
24905	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
24906	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
24907	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
24908	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
24909	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
24910	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
24911	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
24912	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
24913	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
24914	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
24915	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
24916	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
24917	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
24918	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
24919	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
24920	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
24921	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
24922	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
24923	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
24924	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
24925	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
24926	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
24927	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
24928	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
24929	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
24930	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
24931	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
24932	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
24933	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
24934	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
24935	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
24936	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	207623	
24937	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
24938	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
24939	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
24940	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
24941	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
24942	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
24943	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
24944	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
24945	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
24946	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
24947	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
24948	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
24949	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
24950	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
24951	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
24952	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
24953	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
24954	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
24955	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
24956	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
24957	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
24958	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
24959	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
24960	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
24961	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments		
24962	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
24963	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
24964	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
24965	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
24966	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
24967	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
24968	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
24969	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
24970	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
24971	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	340.0	
24972	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
24973	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
24974	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
24975	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
24976	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
24977	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
24978	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
24979	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
24980	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
24981	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
24982	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
24983	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
24984	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
24985	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	0	
24986	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	186	
24987	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	186	
24988	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
24989	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
24990	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
24991	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
24992	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
24993	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
24994	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
24995	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
24996	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
24997	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
24998	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
24999	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25000	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25001	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
25002	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
25003	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
25004	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
25005	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
25006	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25007	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
25008	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
25009	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25010	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25011	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25012	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25013	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25014	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25015	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25016	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25017	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25018	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
25019	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments	1 Trip check	
25020	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
25021	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
25022	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
25023	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
25024	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
25025	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
25026	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
25027	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
25028	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
25029	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
25030	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25031	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25032	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
25033	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	31	*F
25034	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
25035	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
25036	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
25037	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
25038	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
25039	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
25040	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
25041	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
25042	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	128.0	
25043	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	85.0	
25044	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	80.0	
25045	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
25046	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
25047	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
25048	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	2	
25049	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
25050	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
25051	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25052	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	1	
25053	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	199	
25054	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	198	
25055	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
25056	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	1	
25057	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
25058	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.630	
25059	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
25060	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25061	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25062	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25063	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25064	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25065	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25066	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
25067	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
25068	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
25069	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
25070	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
25071	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
25072	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
25073	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
25074	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
25075	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25076	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25077	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
25078	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
25079	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
25080	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments	ok	
25081	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25082	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
25083	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
25084	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
25085	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
25086	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
25087	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
25088	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
25089	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25090	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25091	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
25092	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
25093	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
25094	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
25095	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25096	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
25097	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
25098	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
25099	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25100	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25101	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25102	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25103	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25104	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	7	
25105	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
25106	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
25107	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments		
25108	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
25109	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	469	
25110	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25111	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25112	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25113	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25114	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
25115	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
25116	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
25117	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
25118	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
25119	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
25120	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
25121	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
25122	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25123	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
25124	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
25125	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25126	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
25127	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
25128	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
25129	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
25130	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
25131	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
25132	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
25133	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
25134	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
25135	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
25136	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
25137	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
25138	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
25139	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	469	
25140	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
25141	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	10L	
25142	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	7L	
25143	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	15L	
25144	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	28	
25145	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
25146	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
25147	12/10/2019 14:36	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
25148	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
25149	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
25150	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
25151	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
25152	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
25153	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
25154	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
25155	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
25156	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
25157	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
25158	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
25159	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25160	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
25161	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25162	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments	ok	
25163	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
25164	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25165	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
25166	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
25167	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25168	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
25169	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
25170	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
25171	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
25172	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
25173	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
25174	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25175	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25176	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
25177	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
25178	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
25179	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
25180	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments	ok	
25181	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
25182	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
25183	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25184	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
25185	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
25186	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25187	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
25188	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
25189	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
25190	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
25191	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments		
25192	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
25193	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
25194	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
25195	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
25196	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
25197	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
25198	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25199	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25200	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
25201	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25202	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
25203	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
25204	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
25205	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25206	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
25207	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
25208	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
25209	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25210	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25211	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25212	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25213	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
25214	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
25215	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
25216	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
25217	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments	ok	
25218	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments	1 Trip check	
25219	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
25220	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
25221	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
25222	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
25223	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
25224	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
25225	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
25226	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
25227	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
25228	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
25229	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
25230	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
25231	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25232	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
25233	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
25234	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
25235	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
25236	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	0	
25237	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
25238	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
25239	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
25240	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
25241	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
25242	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
25243	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments	IOC A Phase	
25244	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25245	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25246	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25247	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25248	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25249	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25250	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25251	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments	ok	
25252	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
25253	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
25254	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
25255	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
25256	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
25257	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
25258	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
25259	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
25260	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
25261	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	397	
25262	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	397	
25263	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	0	
25264	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	0	
25265	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1447.20	kw
25266	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25267	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25268	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
25269	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
25270	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
25271	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25272	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
25273	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
25274	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25275	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
25276	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25277	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
25278	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
25279	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments	top flood light by SW 635 Bus not working. Replaced bulb and still didn't work	
25280	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
25281	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
25282	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25283	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
25284	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
25285	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
25286	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments	Actual Counter, IOC A, B, and C phase	
25287	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
25288	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	152	
25289	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	152	
25290	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	0	
25291	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
25292	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
25293	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
25294	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
25295	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
25296	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
25297	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8586	
25298	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
25299	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
25300	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
25301	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25302	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
25303	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
25304	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25305	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25306	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
25307	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25308	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25309	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25310	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25311	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25312	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25313	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25314	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
25315	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
25316	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
25317	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25318	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25319	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25320	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
25321	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
25322	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
25323	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
25324	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
25325	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
25326	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
25327	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
25328	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
25329	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
25330	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
25331	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
25332	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
25333	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
25334	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
25335	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
25336	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
25337	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
25338	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
25339	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
25340	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
25341	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
25342	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
25343	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
25344	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
25345	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTLC Bushing Dynamic Health	0.00	
25346	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
25347	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	.8720	
25348	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
25349	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25350	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
25351	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25352	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
25353	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
25354	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25355	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6181.92	kw
25356	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
25357	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
25358	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	65	*C
25359	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	40	*C
25360	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
25361	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
25362	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	62	*C
25363	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	27	*C
25364	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	74	*C
25365	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25366	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25367	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25368	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
25369	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
25370	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
25371	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
25372	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
25373	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25374	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25375	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25376	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25377	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
25378	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
25379	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
25380	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
25381	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
25382	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	27	*C
25383	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	*C
25384	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
25385	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
25386	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
25387	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
25388	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
25389	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	8	
25390	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
25391	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
25392	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
25393	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	50.0	
25394	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	50.0	
25395	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	82534	
25396	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
25397	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
25398	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
25399	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
25400	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
25401	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
25402	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
25403	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
25404	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
25405	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
25406	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
25407	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	50.0	
25408	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
25409	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
25410	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
25411	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
25412	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
25413	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
25414	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
25415	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
25416	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
25417	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25418	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
25419	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
25420	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
25421	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25422	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25423	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
25424	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
25425	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25426	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25427	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
25428	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
25429	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
25430	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25431	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25432	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25433	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25434	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
25435	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
25436	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
25437	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
25438	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
25439	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
25440	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25441	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25442	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
25443	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
25444	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
25445	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
25446	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
25447	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
25448	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
25449	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
25450	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
25451	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
25452	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
25453	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
25454	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
25455	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
25456	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
25457	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
25458	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
25459	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
25460	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
25461	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
25462	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
25463	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
25464	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	31	*F
25465	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	12	
25466	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
25467	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
25468	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
25469	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	50.0	
25470	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	50.0	
25471	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	50.0	
25472	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
25473	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
25474	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
25475	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	1	
25476	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	186	
25477	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	185	
25478	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
25479	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	1	
25480	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
25481	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
25482	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments	ok	
25483	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
25484	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
25485	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25486	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25487	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
25488	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25489	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	*C
25490	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	60	*C
25491	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
25492	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
25493	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	2092.80	kw
25494	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
25495	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
25496	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
25497	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25498	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25499	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
25500	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
25501	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
25502	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
25503	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
25504	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25505	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
25506	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
25507	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
25508	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
25509	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
25510	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Vent fan not working	
25511	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
25512	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
25513	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
25514	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25515	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	26	°C
25516	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
25517	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
25518	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
25519	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
25520	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
25521	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
25522	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
25523	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
25524	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
25525	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	62	°C
25526	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
25527	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
25528	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
25529	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
25530	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
25531	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25532	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25533	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
25534	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
25535	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25536	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
25537	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
25538	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25539	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
25540	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
25541	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
25542	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
25543	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25544	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
25545	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
25546	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
25547	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments	ok	
25548	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25549	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25550	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25551	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25552	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25553	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments	HSI A, B and C Phase	
25554	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
25555	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25556	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25557	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
25558	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	0	
25559	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
25560	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
25561	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
25562	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
25563	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
25564	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1617.12	kw
25565	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25566	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
25567	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
25568	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25569	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
25570	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
25571	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25572	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
25573	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
25574	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25575	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
25576	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
25577	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25578	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
25579	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
25580	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
25581	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
25582	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25583	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25584	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
25585	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
25586	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
25587	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
25588	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
25589	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
25590	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
25591	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
25592	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
25593	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
25594	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
25595	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
25596	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	320.0	
25597	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
25598	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
25599	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	185.0	
25600	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	240.0	
25601	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
25602	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
25603	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
25604	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
25605	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
25606	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
25607	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25608	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25609	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25610	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25611	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
25612	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
25613	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25614	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
25615	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
25616	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25617	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
25618	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
25619	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25620	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
25621	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
25622	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25623	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
25624	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25625	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2759.04	kw
25626	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
25627	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
25628	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
25629	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
25630	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
25631	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25632	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25633	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25634	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25635	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25636	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25637	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25638	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
25639	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1496	
25640	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
25641	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
25642	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
25643	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	0	
25644	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	235	
25645	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	235	
25646	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
25647	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
25648	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
25649	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
25650	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
25651	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25652	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
25653	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
25654	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
25655	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
25656	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
25657	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
25658	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
25659	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
25660	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
25661	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	280.0	
25662	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	180.0	
25663	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	150.0	
25664	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
25665	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
25666	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
25667	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	2	
25668	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
25669	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
25670	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
25671	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
25672	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
25673	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
25674	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
25675	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
25676	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	27	°C
25677	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	37	°C
25678	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6738	
25679	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
25680	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25681	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25682	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
25683	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
25684	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
25685	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
25686	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
25687	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
25688	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
25689	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7482	
25690	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
25691	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25692	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
25693	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
25694	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25695	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25696	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
25697	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25698	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
25699	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
25700	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
25701	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
25702	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	5387.04	kw
25703	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
25704	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
25705	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
25706	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
25707	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
25708	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
25709	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25710	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
25711	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
25712	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25713	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25714	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
25715	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
25716	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
25717	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25718	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
25719	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
25720	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
25721	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
25722	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25723	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25724	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25725	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25726	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25727	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25728	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25729	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25730	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	0	°C
25731	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
25732	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
25733	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25734	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25735	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	unable to read gauge	
25736	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
25737	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
25738	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
25739	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
25740	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25741	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
25742	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
25743	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25744	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
25745	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
25746	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
25747	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
25748	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25749	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25750	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	558.00	kw
25751	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
25752	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
25753	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	18	°C
25754	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25755	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25756	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25757	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25758	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25759	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25760	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
25761	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
25762	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4650	
25763	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
25764	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
25765	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
25766	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
25767	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
25768	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
25769	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
25770	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
25771	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
25772	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
25773	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
25774	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
25775	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
25776	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
25777	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
25778	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	29484	
25779	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
25780	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
25781	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
25782	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
25783	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
25784	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
25785	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
25786	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
25787	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	6L	
25788	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
25789	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
25790	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
25791	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
25792	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
25793	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
25794	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	6L	
25795	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
25796	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	320.0	
25797	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	380.0	
25798	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	240.0	
25799	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
25800	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
25801	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
25802	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	5	
25803	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
25804	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
25805	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
25806	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
25807	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
25808	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
25809	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
25810	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
25811	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
25812	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
25813	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
25814	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
25815	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	2R	
25816	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	8L	
25817	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	436	
25818	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
25819	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
25820	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
25821	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
25822	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
25823	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
25824	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
25825	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
25826	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25827	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
25828	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
25829	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25830	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
25831	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
25832	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
25833	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
25834	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
25835	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
25836	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
25837	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
25838	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25839	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25840	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25841	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25842	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25843	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25844	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25845	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25846	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25847	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
25848	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
25849	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
25850	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
25851	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
25852	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
25853	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
25854	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
25855	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
25856	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
25857	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
25858	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
25859	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
25860	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
25861	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
25862	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
25863	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
25864	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	34	
25865	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
25866	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
25867	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
25868	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
25869	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
25870	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
25871	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
25872	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
25873	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
25874	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
25875	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
25876	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25877	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
25878	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
25879	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
25880	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
25881	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
25882	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
25883	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
25884	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
25885	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
25886	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
25887	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
25888	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
25889	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
25890	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
25891	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
25892	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
25893	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
25894	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
25895	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
25896	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
25897	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
25898	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	*F
25899	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
25900	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
25901	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
25902	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
25903	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
25904	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
25905	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
25906	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	80.0	
25907	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	77.0	
25908	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	83.0	
25909	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
25910	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
25911	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
25912	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	2	
25913	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
25914	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
25915	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25916	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25917	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25918	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25919	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
25920	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
25921	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
25922	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
25923	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
25924	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
25925	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	1	
25926	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
25927	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
25928	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
25929	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
25930	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	82950	
25931	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
25932	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
25933	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
25934	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
25935	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
25936	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
25937	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
25938	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1316	
25939	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	9L	
25940	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
25941	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
25942	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
25943	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	82952	
25944	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
25945	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	4L	
25946	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
25947	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	*C
25948	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
25949	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
25950	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
25951	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
25952	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
25953	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
25954	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments		
25955	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
25956	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
25957	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
25958	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
25959	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	49	
25960	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	49	
25961	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
25962	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
25963	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	5L	
25964	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
25965	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
25966	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
25967	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	25174	
25968	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	121.4	volts
25969	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
25970	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
25971	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
25972	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	123078	
25973	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	123078	
25974	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
25975	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
25976	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
25977	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	0	
25978	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	216	
25979	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	216	
25980	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
25981	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
25982	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
25983	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
25984	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
25985	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
25986	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
25987	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
25988	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
25989	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
25990	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
25991	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
25992	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
25993	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
25994	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
25995	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
25996	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
25997	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
25998	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments		
25999	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
26000	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
26001	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
26002	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
26003	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
26004	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
26005	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
26006	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
26007	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
26008	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
26009	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
26010	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26011	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26012	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
26013	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
26014	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
26015	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
26016	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
26017	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1466	
26018	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
26019	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
26020	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
26021	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
26022	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
26023	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	75006	
26024	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	75006	
26025	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Pic of Guage sent to Stinson	
26026	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26027	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	257	
26028	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	256	
26029	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
26030	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	1	
26031	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
26032	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
26033	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments	ok	
26034	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments	ok	
26035	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
26036	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
26037	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
26038	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
26039	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
26040	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
26041	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	137282	
26042	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	137282	
26043	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
26044	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
26045	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26046	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
26047	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
26048	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
26049	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
26050	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
26051	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
26052	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
26053	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
26054	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
26055	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
26056	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
26057	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
26058	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	31	
26059	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
26060	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
26061	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
26062	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.0	
26063	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	25.0	
26064	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
26065	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
26066	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26067	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26068	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26069	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
26070	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26071	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26072	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26073	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
26074	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26075	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26076	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
26077	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	68	
26078	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
26079	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
26080	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	66	
26081	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
26082	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	1L	
26083	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	6L	
26084	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
26085	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	632	
26086	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
26087	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
26088	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
26089	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26090	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
26091	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26092	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26093	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
26094	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	KX0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
26095	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
26096	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	18.0	
26097	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
26098	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26099	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26100	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26101	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26102	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26103	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26104	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26105	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
26106	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26107	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26108	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26109	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26110	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26111	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
26112	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
26113	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
26114	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
26115	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
26116	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
26117	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
26118	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
26119	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
26120	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
26121	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
26122	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
26123	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
26124	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments	serviceman reset counters	
26125	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
26126	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
26127	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	0	
26128	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
26129	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
26130	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
26131	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
26132	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
26133	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26134	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26135	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
26136	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
26137	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
26138	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
26139	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
26140	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
26141	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
26142	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
26143	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	182	
26144	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	182	
26145	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
26146	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
26147	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
26148	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00		
26149	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
26150	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
26151	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26152	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
26153	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26154	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
26155	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
26156	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
26157	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26158	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26159	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26160	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26161	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26162	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
26163	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26164	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26165	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26166	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
26167	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26168	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26169	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
26170	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
26171	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
26172	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26173	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26174	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26175	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26176	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26177	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26178	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26179	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
26180	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
26181	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
26182	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26183	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
26184	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
26185	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
26186	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
26187	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26188	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26189	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
26190	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
26191	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	8	
26192	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
26193	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
26194	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
26195	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	200.0	
26196	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	200.0	
26197	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	290.0	
26198	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
26199	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
26200	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
26201	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
26202	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
26203	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
26204	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
26205	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
26206	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
26207	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26208	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26209	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26210	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26211	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26212	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26213	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
26214	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
26215	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
26216	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26217	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	5L	
26218	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26219	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26220	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26221	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26222	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
26223	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	789.12	kw
26224	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
26225	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
26226	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
26227	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26228	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26229	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26230	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26231	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26232	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26233	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26234	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
26235	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9864	
26236	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
26237	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26238	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
26239	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26240	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4590.72	kw
26241	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
26242	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
26243	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	91.0	
26244	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
26245	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
26246	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
26247	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
26248	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
26249	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
26250	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	90.0	
26251	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	92.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26252	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
26253	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
26254	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
26255	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
26256	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
26257	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
26258	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
26259	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
26260	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
26261	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
26262	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		
26263	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
26264	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
26265	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	196	
26266	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
26267	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	75	°C
26268	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
26269	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
26270	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
26271	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
26272	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
26273	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
26274	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26275	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26276	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26277	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
26278	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
26279	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
26280	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
26281	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
26282	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
26283	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
26284	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26285	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26286	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
26287	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
26288	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
26289	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44097	
26290	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26291	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
26292	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
26293	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26294	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26295	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
26296	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
26297	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26298	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
26299	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26300	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26301	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments		
26302	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
26303	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26304	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
26305	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26306	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
26307	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
26308	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
26309	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26310	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	115736	
26311	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
26312	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
26313	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
26314	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26315	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26316	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
26317	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
26318	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
26319	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
26320	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26321	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
26322	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
26323	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26324	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	8L	
26325	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26326	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26327	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26328	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26329	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
26330	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
26331	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
26332	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
26333	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26334	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	113427	
26335	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
26336	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
26337	12/10/2019 11:14	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
26338	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
26339	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26340	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26341	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
26342	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
26343	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
26344	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
26345	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26346	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
26347	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
26348	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26349	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	35	°C
26350	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	160	°C
26351	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	35	°C
26352	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	160	°C
26353	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	30	°C
26354	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26355	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26356	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26357	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26358	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
26359	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
26360	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
26361	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
26362	12/10/2019 9:12	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	43.0	
26363	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26364	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26365	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26366	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26367	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
26368	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26369	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26370	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26371	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
26372	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
26373	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
26374	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
26375	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	70	°C
26376	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26377	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26378	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26379	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26380	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26381	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26382	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26383	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
26384	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
26385	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
26386	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
26387	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
26388	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
26389	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
26390	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
26391	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
26392	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
26393	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
26394	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
26395	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
26396	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
26397	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
26398	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
26399	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
26400	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26401	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26402	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
26403	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26404	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
26405	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		
26406	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
26407	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
26408	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments		
26409	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
26410	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	530	
26411	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	530	
26412	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
26413	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
26414	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
26415	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
26416	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
26417	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
26418	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
26419	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
26420	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
26421	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
26422	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
26423	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
26424	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
26425	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
26426	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
26427	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
26428	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
26429	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
26430	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
26431	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
26432	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
26433	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
26434	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
26435	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
26436	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
26437	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
26438	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
26439	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
26440	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	589	
26441	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
26442	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
26443	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
26444	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
26445	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
26446	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
26447	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
26448	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	80.7	
26449	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	129.0	
26450	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
26451	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
26452	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
26453	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
26454	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
26455	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
26456	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26457	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
26458	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
26459	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
26460	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26461	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26462	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26463	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26464	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
26465	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	Charger will not go into EQ	
26466	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	y	
26467	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
26468	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
26469	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
26470	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
26471	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	23.800	millivolts
26472	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
26473	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26474	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
26475	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
26476	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
26477	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
26478	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
26479	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
26480	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26481	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
26482	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
26483	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
26484	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26485	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
26486	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	7078	
26487	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
26488	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
26489	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	
26490	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	
26491	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	
26492	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
26493	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26494	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26495	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26496	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26497	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	
26498	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
26499	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
26500	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.1	
26501	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.1	
26502	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
26503	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
26504	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
26505	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
26506	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
26507	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
26508	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
26509	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
26510	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
26511	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
26512	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
26513	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
26514	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
26515	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
26516	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
26517	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26518	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26519	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26520	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26521	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26522	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26523	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
26524	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments		
26525	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
26526	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	36	
26527	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
26528	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
26529	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
26530	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
26531	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
26532	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
26533	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
26534	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
26535	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
26536	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
26537	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
26538	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
26539	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
26540	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
26541	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26542	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26543	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26544	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26545	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
26546	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
26547	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26548	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26549	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26550	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
26551	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26552	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26553	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
26554	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26555	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
26556	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
26557	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26558	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26559	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26560	12/10/2019 11:56	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26561	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
26562	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
26563	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26564	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26565	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
26566	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26567	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26568	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26569	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
26570	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26571	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
26572	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
26573	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26574	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
26575	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26576	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
26577	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
26578	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
26579	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26580	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26581	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26582	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26583	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments	ok	
26584	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments	ok	
26585	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26586	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26587	12/10/2019 13:52	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26588	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	7064	
26589	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	75	°C
26590	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
26591	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
26592	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26593	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26594	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26595	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26596	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
26597	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
26598	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26599	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26600	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26601	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
26602	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
26603	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	63518	
26604	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26605	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
26606	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
26607	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
26608	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26609	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26610	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26611	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26612	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
26613	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
26614	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7410	
26615	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
26616	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26617	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26618	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26619	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26620	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26621	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26622	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
26623	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
26624	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
26625	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
26626	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26627	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCCControl	576-1	LTC Control Insp	General Comments	ok	
26628	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
26629	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCCControl	576-1	LTC Control Insp	All Connections OK?	y	
26630	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26631	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
26632	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
26633	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
26634	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
26635	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9128	
26636	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
26637	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
26638	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
26639	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26640	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46642	
26641	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
26642	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
26643	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
26644	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
26645	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
26646	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
26647	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
26648	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
26649	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
26650	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
26651	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
26652	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	110.0	
26653	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	170.0	
26654	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
26655	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26656	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
26657	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
26658	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	20.0	
26659	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	20.0	
26660	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	90.0	
26661	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
26662	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
26663	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26664	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
26665	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
26666	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
26667	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
26668	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
26669	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
26670	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
26671	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
26672	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
26673	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
26674	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26675	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46504	
26676	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
26677	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
26678	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
26679	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26680	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26681	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
26682	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
26683	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
26684	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
26685	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26686	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
26687	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
26688	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26689	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
26690	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26691	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26692	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26693	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26694	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
26695	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
26696	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
26697	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26698	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
26699	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
26700	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
26701	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments	ok	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26702	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
26703	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
26704	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
26705	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26706	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
26707	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
26708	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
26709	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
26710	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
26711	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
26712	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26713	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
26714	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
26715	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
26716	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
26717	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
26718	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
26719	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
26720	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
26721	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
26722	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
26723	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
26724	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
26725	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
26726	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
26727	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
26728	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
26729	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
26730	12/10/2019 12:55	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
26731	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26732	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26733	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26734	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26735	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
26736	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
26737	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
26738	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
26739	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
26740	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
26741	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
26742	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
26743	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
26744	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
26745	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
26746	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	159	
26747	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
26748	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
26749	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
26750	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
26751	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
26752	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
26753	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
26754	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
26755	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
26756	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
26757	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
26758	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
26759	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
26760	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	125.0	
26761	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	142.0	
26762	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	155.0	
26763	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
26764	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
26765	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
26766	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
26767	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
26768	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
26769	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
26770	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
26771	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
26772	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
26773	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
26774	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
26775	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
26776	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
26777	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
26778	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
26779	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
26780	12/10/2019 10:11	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
26781	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
26782	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
26783	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
26784	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
26785	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
26786	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
26787	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
26788	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
26789	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
26790	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
26791	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
26792	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
26793	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
26794	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
26795	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
26796	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
26797	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
26798	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
26799	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
26800	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	250	
26801	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
26802	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
26803	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
26804	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
26805	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
26806	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
26807	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
26808	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
26809	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
26810	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
26811	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
26812	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	287	
26813	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
26814	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
26815	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
26816	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
26817	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	210	
26818	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	210	
26819	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
26820	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
26821	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
26822	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26823	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
26824	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
26825	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
26826	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
26827	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
26828	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.7	VDC
26829	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
26830	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
26831	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
26832	12/10/2019 13:35	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
26833	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
26834	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
26835	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
26836	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
26837	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
26838	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
26839	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
26840	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
26841	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
26842	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
26843	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
26844	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.4	VDC
26845	12/10/2019 11:49	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26846	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
26847	12/13/2019 7:24	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	26	°C
26848	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.4	VDC
26849	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
26850	12/10/2019 9:40	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
26851	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.8	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
26852	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
26853	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
26854	12/10/2019 14:08	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
26855	12/10/2019 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
26856	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
26857	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
26858	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
26859	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
26860	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
26861	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
26862	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
26863	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
26864	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
26865	12/10/2019 10:47	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42302	
26866	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.00	psi
26867	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
26868	12/10/2019 9:12	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1185.60	kw
26869	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
26870	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
26871	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
26872	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
26873	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
26874	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
26875	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
26876	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
26877	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
26878	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
26879	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
26880	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
26881	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
26882	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
26883	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
26884	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
26885	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1493	
26886	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
26887	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
26888	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
26889	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.0	
26890	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
26891	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.0	
26892	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
26893	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
26894	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
26895	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
26896	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
26897	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
26898	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
26899	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
26900	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
26901	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
26902	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
26903	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	162	
26904	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
26905	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	60.0	
26906	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
26907	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	10.0	
26908	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
26909	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
26910	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
26911	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
26912	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
26913	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
26914	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
26915	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
26916	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
26917	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
26918	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26919	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
26920	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
26921	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
26922	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26923	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
26924	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
26925	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
26926	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
26927	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
26928	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
26929	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
26930	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
26931	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
26932	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
26933	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
26934	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
26935	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
26936	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
26937	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
26938	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
26939	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
26940	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
26941	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
26942	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	135.0	
26943	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	90.0	
26944	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	140.0	
26945	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
26946	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
26947	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
26948	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
26949	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
26950	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
26951	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
26952	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
26953	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	531	
26954	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	531	
26955	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
26956	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
26957	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
26958	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTC000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
26959	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
26960	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.83	%
26961	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.71	%
26962	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.77	%
26963	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	48.0	
26964	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
26965	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
26966	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
26967	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
26968	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
26969	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
26970	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
26971	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
26972	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
26973	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
26974	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
26975	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
26976	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
26977	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
26978	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
26979	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	60.0	
26980	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	60.0	
26981	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
26982	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
26983	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
26984	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
26985	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
26986	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	2	
26987	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	2	
26988	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	180	
26989	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	180	
26990	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
26991	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
26992	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
26993	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
26994	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
26995	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
26996	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
26997	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
26998	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
26999	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27000	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
27001	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
27002	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
27003	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
27004	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
27005	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27006	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations This Read Vac	4	
27007	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
27008	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AL	155	
27009	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations Ground	0	
27010	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Follow-up Action Required?	n	
27011	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Follow-up Action Required?	n	
27012	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AF	155	
27013	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Foundation Condition	Good	
27014	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	General Comments		
27015	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
27016	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27017	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27018	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27019	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27020	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
27021	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
27022	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
27023	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27024	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27025	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
27026	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
27027	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
27028	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
27029	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
27030	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
27031	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27032	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
27033	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
27034	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	General Comments		
27035	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Grounds in Place?	y	
27036	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27037	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Maintenance Operations	0	
27038	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Moisture and Leak Free?	y	
27039	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27040	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
27041	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
27042	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
27043	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
27044	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27045	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27046	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
27047	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
27048	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
27049	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
27050	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27051	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
27052	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27053	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27054	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27055	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27056	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27057	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
27058	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
27059	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000650	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
27060	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27061	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27062	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27063	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	38	
27064	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27065	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27066	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
27067	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	
27068	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations C Ø	0	
27069	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
27070	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
27071	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
27072	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
27073	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
27074	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	General Comments		
27075	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	General Comments		
27076	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27077	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations A Ø	0	
27078	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27079	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
27080	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
27081	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	4	
27082	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27083	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27084	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27085	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27086	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27087	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
27088	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
27089	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	60	
27090	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27091	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	60	
27092	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
27093	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
27094	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
27095	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27096	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
27097	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
27098	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	186	
27099	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	186	
27100	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	0	
27101	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27102	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27103	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	5	
27104	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
27105	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
27106	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
27107	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27108	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
27109	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
27110	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
27111	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
27112	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
27113	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
27114	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
27115	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
27116	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
27117	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
27118	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
27119	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
27120	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
27121	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
27122	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
27123	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
27124	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
27125	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
27126	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	5.0	
27127	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	15.0	
27128	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
27129	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
27130	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27131	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
27132	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
27133	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
27134	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	252	
27135	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	0	
27136	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27137	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	10.0	
27138	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27139	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27140	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27141	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	28	
27142	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
27143	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
27144	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	1	
27145	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	1	
27146	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	188	
27147	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	188	
27148	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
27149	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
27150	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
27151	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27152	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
27153	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
27154	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
27155	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	
27156	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
27157	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
27158	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
27159	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27160	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27161	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27162	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
27163	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
27164	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	284	
27165	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
27166	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
27167	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	ok	
27168	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27169	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27170	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27171	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27172	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
27173	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
27174	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
27175	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27176	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	0	
27177	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	284	
27178	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
27179	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
27180	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
27181	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
27182	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
27183	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
27184	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
27185	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
27186	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
27187	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	13780	
27188	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
27189	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
27190	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
27191	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
27192	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
27193	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
27194	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
27195	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
27196	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
27197	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
27198	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
27199	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
27200	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
27201	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
27202	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
27203	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
27204	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
27205	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
27206	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
27207	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
27208	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
27209	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
27210	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
27211	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
27212	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
27213	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
27214	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
27215	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
27216	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
27217	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
27218	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
27219	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
27220	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
27221	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
27222	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
27223	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
27224	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
27225	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
27226	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27227	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
27228	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
27229	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
27230	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
27231	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
27232	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
27233	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
27234	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
27235	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
27236	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
27237	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	15667	
27238	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
27239	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
27240	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27241	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
27242	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
27243	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
27244	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
27245	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
27246	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
27247	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
27248	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
27249	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	7	
27250	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	.59	%
27251	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	.29	%
27252	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27253	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	112.0	
27254	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	119.0	
27255	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
27256	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments	ok	
27257	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
27258	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
27259	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27260	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
27261	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments	lightening arrester has come loose at the chance clamp	
27262	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
27263	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
27264	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
27265	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
27266	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
27267	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
27268	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
27269	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
27270	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
27271	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
27272	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
27273	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
27274	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
27275	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
27276	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
27277	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27278	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27279	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27280	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27281	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27282	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27283	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27284	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
27285	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
27286	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
27287	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27288	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27289	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
27290	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	10.0	
27291	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	10.0	
27292	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
27293	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27294	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
27295	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
27296	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27297	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27298	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27299	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27300	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27301	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
27302	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
27303	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
27304	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27305	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
27306	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	219	
27307	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	219	
27308	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
27309	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27310	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
27311	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
27312	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
27313	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
27314	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
27315	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
27316	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27317	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	24.0	
27318	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	48.0	
27319	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
27320	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
27321	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
27322	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	3	
27323	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	2	
27324	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	5	
27325	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	164	
27326	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	164	
27327	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
27328	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
27329	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
27330	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
27331	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
27332	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
27333	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	0	
27334	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	11.86	
27335	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	11.86	
27336	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	11.86	
27337	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	108.0	
27338	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
27339	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
27340	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
27341	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27342	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27343	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
27344	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
27345	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
27346	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
27347	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
27348	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
27349	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
27350	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
27351	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
27352	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
27353	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	2	
27354	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27355	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27356	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27357	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	95.0	
27358	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	95.0	
27359	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	80.0	
27360	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
27361	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27362	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27363	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27364	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27365	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27366	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27367	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27368	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27369	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27370	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27371	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27372	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushing Condition	Good	
27373	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps C Ø	170.0	
27374	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps B Ø	180.0	
27375	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps A Ø	165.0	
27376	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27377	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
27378	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
27379	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
27380	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
27381	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
27382	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
27383	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
27384	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
27385	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
27386	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
27387	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
27388	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27389	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
27390	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
27391	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
27392	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
27393	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
27394	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
27395	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
27396	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
27397	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
27398	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
27399	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
27400	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
27401	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
27402	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
27403	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
27404	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
27405	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
27406	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
27407	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
27408	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	1	
27409	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
27410	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
27411	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
27412	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
27413	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	12478	
27414	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
27415	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
27416	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
27417	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
27418	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
27419	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	11L	
27420	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
27421	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27422	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
27423	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
27424	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
27425	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
27426	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
27427	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
27428	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
27429	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27430	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27431	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
27432	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27433	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
27434	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations	30	
27435	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	72.0	
27436	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
27437	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	72.0	
27438	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.77	%
27439	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	10.83	%
27440	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27441	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27442	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
27443	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27444	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
27445	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
27446	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
27447	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
27448	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
27449	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	252	
27450	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
27451	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
27452	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
27453	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
27454	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
27455	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
27456	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
27457	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
27458	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
27459	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
27460	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	194	
27461	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	194	
27462	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	0	
27463	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
27464	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	0	
27465	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
27466	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
27467	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
27468	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
27469	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
27470	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	1.5	AMPS
27471	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
27472	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
27473	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
27474	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
27475	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
27476	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
27477	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92313	
27478	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
27479	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
27480	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
27481	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
27482	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
27483	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
27484	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
27485	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
27486	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
27487	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
27488	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
27489	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
27490	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
27491	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
27492	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
27493	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
27494	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
27495	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
27496	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
27497	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
27498	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
27499	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
27500	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
27501	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
27502	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
27503	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
27504	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
27505	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27506	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27507	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27508	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
27509	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
27510	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
27511	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
27512	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
27513	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
27514	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
27515	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	3	
27516	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27517	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27518	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	11.86	
27519	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	20.0	
27520	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	20.0	
27521	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	20.0	
27522	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	1.9	%
27523	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	1.9	%
27524	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	1.9	%
27525	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	9	
27526	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27527	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
27528	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
27529	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
27530	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.9	VAC
27531	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
27532	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
27533	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
27534	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
27535	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
27536	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
27537	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
27538	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
27539	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
27540	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
27541	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
27542	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
27543	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
27544	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
27545	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
27546	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	104	
27547	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	0	
27548	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27549	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	
27550	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
27551	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
27552	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
27553	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
27554	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
27555	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	2	
27556	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	5	
27557	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
27558	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
27559	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
27560	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
27561	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
27562	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
27563	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	185	
27564	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	185	
27565	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
27566	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
27567	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
27568	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
27569	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
27570	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
27571	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
27572	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
27573	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
27574	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
27575	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
27576	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
27577	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
27578	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
27579	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
27580	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
27581	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
27582	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
27583	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
27584	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
27585	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27586	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
27587	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	341	
27588	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	341	
27589	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
27590	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
27591	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27592	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
27593	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
27594	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
27595	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
27596	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
27597	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
27598	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
27599	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
27600	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
27601	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27602	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27603	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27604	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27605	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27606	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27607	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27608	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27609	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27610	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27611	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
27612	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	230.0	
27613	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	240.0	
27614	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
27615	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
27616	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
27617	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
27618	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
27619	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
27620	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
27621	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
27622	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
27623	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27624	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27625	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27626	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27627	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27628	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27629	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27630	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27631	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27632	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
27633	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	280.0	
27634	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	160.0	
27635	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	310.0	
27636	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27637	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27638	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27639	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
27640	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
27641	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	1	
27642	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
27643	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
27644	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
27645	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
27646	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
27647	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
27648	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
27649	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
27650	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
27651	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
27652	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
27653	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
27654	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	475	
27655	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	13L	
27656	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	5L	
27657	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	9L	
27658	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
27659	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	56559	
27660	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	56559	
27661	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
27662	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
27663	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
27664	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
27665	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
27666	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
27667	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
27668	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
27669	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
27670	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
27671	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
27672	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
27673	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
27674	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
27675	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
27676	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27677	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
27678	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
27679	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
27680	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
27681	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
27682	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
27683	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
27684	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
27685	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
27686	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
27687	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
27688	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
27689	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
27690	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
27691	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
27692	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
27693	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
27694	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
27695	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	Blown lightning arrester 522	
27696	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
27697	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
27698	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
27699	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
27700	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
27701	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
27702	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
27703	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
27704	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
27705	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
27706	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
27707	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
27708	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
27709	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
27710	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
27711	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
27712	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
27713	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
27714	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
27715	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
27716	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
27717	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
27718	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
27719	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
27720	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
27721	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
27722	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
27723	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
27724	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
27725	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
27726	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	1	
27727	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27728	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	1	
27729	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
27730	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
27731	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
27732	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
27733	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
27734	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
27735	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
27736	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	65	
27737	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	65	
27738	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
27739	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
27740	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
27741	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
27742	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
27743	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
27744	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
27745	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
27746	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments	trees are getting large around station	
27747	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
27748	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27749	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
27750	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
27751	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27752	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
27753	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
27754	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
27755	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27756	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27757	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27758	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27759	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27760	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27761	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27762	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27763	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27764	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
27765	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
27766	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
27767	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
27768	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
27769	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
27770	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
27771	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
27772	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
27773	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
27774	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27775	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
27776	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	20	°C
27777	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	40	°C
27778	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
27779	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
27780	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
27781	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
27782	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
27783	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
27784	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
27785	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
27786	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
27787	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
27788	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
27789	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
27790	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	100	
27791	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	100	
27792	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
27793	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
27794	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1215	
27795	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1215	
27796	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
27797	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27798	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
27799	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
27800	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
27801	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27802	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
27803	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
27804	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
27805	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	414661	
27806	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
27807	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
27808	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
27809	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
27810	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	5	
27811	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27812	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27813	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27814	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	12.0	
27815	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	12.0	
27816	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	12.0	
27817	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
27818	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27819	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27820	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27821	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
27822	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
27823	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
27824	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
27825	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27826	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27827	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27828	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	100.0	
27829	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	120.0	
27830	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	120.0	
27831	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	5.7	%
27832	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	4.44	%
27833	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	3.8	%
27834	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	8	
27835	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27836	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
27837	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
27838	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
27839	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
27840	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
27841	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
27842	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
27843	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	484	
27844	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	484	
27845	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	197.0	
27846	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	206.0	
27847	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	202.0	
27848	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27849	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27850	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27851	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	7	
27852	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27853	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27854	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27855	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
27856	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	2	
27857	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	2	
27858	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
27859	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
27860	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
27861	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
27862	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27863	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27864	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27865	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27866	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27867	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
27868	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
27869	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
27870	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
27871	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
27872	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
27873	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
27874	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
27875	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
27876	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
27877	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
27878	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
27879	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
27880	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
27881	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
27882	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
27883	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
27884	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
27885	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
27886	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
27887	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
27888	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
27889	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
27890	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
27891	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
27892	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
27893	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
27894	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	123563	
27895	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	123563	
27896	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
27897	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
27898	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
27899	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
27900	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	977	
27901	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27902	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
27903	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
27904	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
27905	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
27906	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
27907	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
27908	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
27909	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
27910	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	20	°C
27911	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	60	°C
27912	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
27913	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
27914	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
27915	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
27916	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
27917	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
27918	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
27919	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments	ok	
27920	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments	ok	
27921	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
27922	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
27923	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	4	
27924	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
27925	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
27926	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
27927	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
27928	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
27929	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
27930	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
27931	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27932	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27933	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27934	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27935	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27936	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27937	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27938	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27939	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27940	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
27941	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
27942	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
27943	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
27944	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
27945	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
27946	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
27947	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
27948	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
27949	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
27950	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
27951	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
27952	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
27953	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	104	
27954	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
27955	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
27956	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
27957	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
27958	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
27959	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
27960	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
27961	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
27962	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
27963	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
27964	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
27965	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
27966	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
27967	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
27968	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
27969	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
27970	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
27971	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
27972	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
27973	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
27974	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
27975	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	335	
27976	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	335	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
27977	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	5	
27978	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
27979	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	5	
27980	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
27981	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
27982	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
27983	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
27984	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
27985	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
27986	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
27987	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
27988	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	General Comments		
27989	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
27990	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
27991	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
27992	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
27993	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
27994	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
27995	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
27996	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
27997	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
27998	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
27999	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
28000	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
28001	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
28002	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28003	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
28004	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28005	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Present	10	°C
28006	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Max	10	°C
28007	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
28008	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
28009	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
28010	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
28011	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
28012	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
28013	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	General Comments		
28014	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
28015	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28016	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
28017	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
28018	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28019	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28020	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28021	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28022	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28023	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28024	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28025	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	5	
28026	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28027	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28028	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28029	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28030	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28031	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28032	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
28033	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28034	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28035	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
28036	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
28037	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
28038	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28039	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28040	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
28041	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	
28042	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	0	
28043	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
28044	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
28045	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
28046	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
28047	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
28048	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
28049	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
28050	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	6	
28051	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28052	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
28053	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
28054	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
28055	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
28056	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
28057	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
28058	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
28059	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
28060	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
28061	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
28062	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
28063	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
28064	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28065	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	2	
28066	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
28067	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	194	
28068	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	194	
28069	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	7	
28070	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	1	
28071	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
28072	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
28073	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	22.0	
28074	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	22.0	
28075	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	25.0	
28076	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
28077	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
28078	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
28079	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
28080	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
28081	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	327	
28082	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	327	
28083	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
28084	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
28085	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
28086	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
28087	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
28088	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
28089	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
28090	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
28091	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
28092	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
28093	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
28094	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
28095	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
28096	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
28097	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
28098	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
28099	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
28100	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
28101	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
28102	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
28103	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
28104	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
28105	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
28106	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
28107	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
28108	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
28109	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
28110	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
28111	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
28112	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
28113	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
28114	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
28115	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
28116	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
28117	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
28118	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
28119	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
28120	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
28121	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	142	
28122	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	0	
28123	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	3	
28124	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
28125	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
28126	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28127	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
28128	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
28129	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	3	
28130	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
28131	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
28132	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	2L	
28133	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	8R	
28134	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	10L	
28135	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1323	
28136	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28137	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28138	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28139	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	9	
28140	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28141	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28142	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28143	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	85.0	
28144	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	100.0	
28145	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	90.0	
28146	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
28147	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28148	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
28149	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Trash?	y	
28150	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
28151	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
28152	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
28153	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
28154	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
28155	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
28156	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
28157	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
28158	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
28159	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
28160	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	319	
28161	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	319	
28162	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
28163	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
28164	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
28165	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
28166	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1131	
28167	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
28168	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
28169	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
28170	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
28171	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28172	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	165256	
28173	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	165256	
28174	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
28175	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
28176	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28177	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
28178	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	5	
28179	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
28180	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	5	
28181	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
28182	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
28183	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28184	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28185	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28186	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28187	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28188	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28189	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28190	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
28191	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28192	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28193	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28194	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28195	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
28196	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
28197	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28198	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28199	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	High Oil temp Alarm on the Annunicator in CCC	
28200	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28201	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28202	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28203	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
28204	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
28205	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28206	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
28207	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
28208	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28209	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28210	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28211	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28212	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28213	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28214	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
28215	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
28216	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	161348	
28217	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	161354	
28218	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28219	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	4L	
28220	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	2R	
28221	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	11L	
28222	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	2055	
28223	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28224	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28225	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28226	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.7332	
28227	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
28228	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28229	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28230	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
28231	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28232	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
28233	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
28234	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
28235	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
28236	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
28237	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
28238	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
28239	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
28240	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
28241	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
28242	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28243	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28244	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
28245	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
28246	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
28247	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
28248	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
28249	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
28250	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28251	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28252	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28253	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	28	*C
28254	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	52	*C
28255	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
28256	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28257	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
28258	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
28259	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
28260	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
28261	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
28262	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
28263	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
28264	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
28265	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	2346.24	kw
28266	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28267	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
28268	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments		
28269	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28270	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
28271	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
28272	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28273	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
28274	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
28275	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28276	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28277	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
28278	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
28279	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
28280	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
28281	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
28282	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
28283	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments	Blown lightning arrester	
28284	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
28285	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28286	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
28287	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
28288	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	
28289	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	0	
28290	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28291	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
28292	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments	BFTC	
28293	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
28294	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
28295	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	.7608	
28296	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	40	°C
28297	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
28298	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28299	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28300	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28301	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28302	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
28303	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
28304	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
28305	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
28306	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
28307	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
28308	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
28309	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
28310	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
28311	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
28312	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	38	
28313	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28314	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28315	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28316	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	5.0	
28317	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	5.0	
28318	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	8.0	
28319	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
28320	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28321	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28322	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	12.0	
28323	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28324	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28325	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28326	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28327	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28328	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28329	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28330	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28331	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28332	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
28333	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
28334	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
28335	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
28336	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
28337	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	
28338	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
28339	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
28340	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
28341	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
28342	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
28343	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
28344	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
28345	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
28346	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
28347	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments	Barb wire rusty	
28348	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
28349	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
28350	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
28351	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28352	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
28353	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
28354	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
28355	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
28356	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
28357	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
28358	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
28359	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
28360	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
28361	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments		
28362	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
28363	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28364	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
28365	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
28366	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28367	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
28368	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
28369	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28370	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
28371	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
28372	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
28373	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
28374	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	5	
28375	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
28376	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
28377	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	74538	
28378	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
28379	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	5	
28380	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28381	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	74550	
28382	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28383	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	10L	
28384	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	2L	
28385	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	13L	
28386	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	842	
28387	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28388	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28389	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28390	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
28391	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28392	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	7303.68	kw
28393	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28394	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
28395	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
28396	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
28397	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28398	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28399	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28400	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	210.0	
28401	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
28402	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
28403	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
28404	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28405	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	30	°C
28406	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	30	°C
28407	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28408	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28409	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28410	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28411	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
28412	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28413	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28414	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28415	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28416	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
28417	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
28418	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
28419	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	97984	
28420	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
28421	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
28422	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
28423	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
28424	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
28425	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
28426	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	4R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28427	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
28428	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
28429	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
28430	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
28431	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
28432	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
28433	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
28434	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28435	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28436	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28437	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28438	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28439	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28440	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28441	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28442	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28443	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
28444	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	300.0	
28445	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	340.0	
28446	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
28447	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
28448	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
28449	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
28450	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
28451	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
28452	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
28453	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
28454	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
28455	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
28456	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
28457	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
28458	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
28459	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
28460	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
28461	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
28462	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
28463	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	300.0	
28464	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28465	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28466	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28467	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28468	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28469	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28470	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
28471	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
28472	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
28473	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
28474	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
28475	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
28476	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	120.0	
28477	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	120.0	
28478	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	120.0	
28479	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
28480	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28481	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28482	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28483	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28484	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28485	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28486	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28487	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28488	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28489	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
28490	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
28491	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
28492	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
28493	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
28494	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
28495	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
28496	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
28497	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
28498	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
28499	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
28500	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	y	
28501	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28502	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
28503	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
28504	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
28505	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
28506	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28507	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
28508	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
28509	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	94644	
28510	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	94671	
28511	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28512	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	2R	
28513	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	16R	
28514	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	16L	
28515	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
28516	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	170	
28517	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
28518	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
28519	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	y	
28520	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	170	
28521	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	1	
28522	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	1	
28523	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
28524	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
28525	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	11	
28526	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28527	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28528	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28529	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
28530	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	850	
28531	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28532	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28533	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28534	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
28535	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28536	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
28537	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
28538	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	192293	
28539	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	192248	
28540	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
28541	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	12.0	
28542	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	12.0	
28543	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
28544	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28545	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28546	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28547	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
28548	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
28549	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	0	
28550	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
28551	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	0	
28552	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	360	
28553	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28554	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28555	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	360	
28556	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
28557	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28558	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
28559	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
28560	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
28561	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
28562	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
28563	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
28564	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
28565	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
28566	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28567	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
28568	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28569	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28570	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28571	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28572	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	25	°C
28573	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	45	°C
28574	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
28575	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28576	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1845.60	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28577	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28578	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
28579	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
28580	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28581	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
28582	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
28583	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28584	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
28585	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
28586	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28587	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
28588	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28589	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28590	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
28591	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28592	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28593	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28594	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	420.0	
28595	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	470.0	
28596	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	435.0	
28597	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
28598	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28599	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
28600	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28601	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28602	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
28603	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
28604	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
28605	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
28606	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28607	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28608	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28609	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28610	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28611	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
28612	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
28613	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
28614	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
28615	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28616	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
28617	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
28618	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
28619	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
28620	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
28621	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
28622	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
28623	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
28624	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
28625	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
28626	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
28627	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
28628	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	145	
28629	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	145	
28630	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
28631	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
28632	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
28633	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
28634	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28635	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28636	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28637	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28638	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28639	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
28640	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
28641	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
28642	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28643	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
28644	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
28645	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
28646	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
28647	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
28648	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
28649	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
28650	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
28651	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28652	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28653	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
28654	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28655	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
28656	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28657	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28658	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28659	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28660	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28661	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28662	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28663	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
28664	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
28665	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28666	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
28667	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
28668	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28669	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
28670	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
28671	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28672	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	4155.84	kw
28673	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28674	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
28675	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	47	°C
28676	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	25	°C
28677	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28678	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28679	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28680	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28681	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
28682	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28683	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28684	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
28685	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	.8658	
28686	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	45	°C
28687	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	27	°C
28688	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
28689	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
28690	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
28691	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	0	
28692	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	321	
28693	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	321	
28694	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
28695	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
28696	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
28697	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	2	
28698	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	4R	
28699	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	5R	
28700	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	4R	
28701	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28702	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121429	
28703	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121459	
28704	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
28705	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
28706	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28707	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
28708	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
28709	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
28710	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
28711	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
28712	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
28713	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.3076	
28714	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
28715	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28716	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
28717	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
28718	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
28719	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
28720	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
28721	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
28722	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
28723	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
28724	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28725	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	30	°C
28726	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	33	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28727	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
28728	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
28729	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
28730	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
28731	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
28732	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
28733	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
28734	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
28735	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
28736	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
28737	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
28738	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
28739	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	y	
28740	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
28741	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28742	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	5164.80	kw
28743	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	35	°C
28744	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
28745	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28746	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
28747	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
28748	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
28749	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28750	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
28751	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
28752	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28753	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
28754	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
28755	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28756	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28757	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
28758	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
28759	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
28760	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
28761	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	139980	
28762	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
28763	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
28764	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
28765	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
28766	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28767	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
28768	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
28769	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
28770	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
28771	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
28772	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28773	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28774	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
28775	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
28776	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	1	
28777	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28778	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28779	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
28780	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
28781	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	1	
28782	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	243	
28783	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	243	
28784	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
28785	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
28786	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
28787	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
28788	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
28789	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
28790	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
28791	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28792	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
28793	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
28794	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28795	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
28796	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
28797	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
28798	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28799	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
28800	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
28801	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3939.84	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28802	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
28803	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
28804	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
28805	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
28806	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
28807	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
28808	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
28809	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
28810	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
28811	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
28812	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
28813	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
28814	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
28815	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
28816	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
28817	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
28818	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
28819	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14L	
28820	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
28821	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
28822	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
28823	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
28824	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
28825	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
28826	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
28827	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Unknown Operations	0	
28828	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
28829	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Leaks	None	
28830	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
28831	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
28832	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
28833	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Switching Operations	0	
28834	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
28835	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations This Read Oil	0	
28836	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AL	1406	
28837	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AF	1406	
28838	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Number of Ops last 9 Months	0	
28839	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
28840	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Maintenance Operations	0	
28841	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
28842	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	General Comments	fixed small air leak	
28843	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	General Comments		
28844	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
28845	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
28846	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Follow-up Action Required?	n	
28847	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
28848	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Fault Operations	0	
28849	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
28850	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
28851	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
28852	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
28853	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
28854	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
28855	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
28856	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
28857	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps C Ø	0.0	
28858	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps B Ø	0.0	
28859	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps A Ø	0.0	
28860	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
28861	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
28862	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Leaks	None	
28863	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Compressor Oil Status	Replaced	
28864	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
28865	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
28866	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
28867	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
28868	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
28869	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
28870	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
28871	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
28872	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
28873	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
28874	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
28875	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
28876	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
28877	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
28878	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
28879	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28880	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
28881	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
28882	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
28883	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
28884	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
28885	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	60	°C
28886	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	65	°C
28887	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8856	
28888	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
28889	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
28890	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
28891	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
28892	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28893	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28894	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
28895	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28896	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
28897	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
28898	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
28899	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
28900	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8501.76	kw
28901	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
28902	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
28903	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
28904	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
28905	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
28906	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
28907	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
28908	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
28909	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
28910	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
28911	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
28912	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
28913	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
28914	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
28915	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
28916	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
28917	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
28918	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28919	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
28920	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
28921	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
28922	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
28923	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
28924	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
28925	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
28926	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
28927	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
28928	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
28929	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
28930	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
28931	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
28932	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
28933	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
28934	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
28935	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
28936	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
28937	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
28938	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
28939	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
28940	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
28941	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
28942	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
28943	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
28944	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
28945	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
28946	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
28947	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
28948	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
28949	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
28950	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
28951	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
28952	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
28953	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
28954	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
28955	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
28956	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
28957	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
28958	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
28959	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
28960	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
28961	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
28962	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
28963	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
28964	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
28965	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
28966	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
28967	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
28968	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
28969	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
28970	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
28971	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
28972	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	45	*C
28973	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
28974	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
28975	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
28976	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
28977	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
28978	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
28979	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
28980	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
28981	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
28982	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
28983	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
28984	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
28985	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28986	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
28987	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
28988	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
28989	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
28990	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
28991	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	50	*C
28992	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	40	*C
28993	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
28994	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
28995	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
28996	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
28997	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
28998	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
28999	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
29000	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
29001	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
29002	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29003	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
29004	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.5952	
29005	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
29006	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29007	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29008	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
29009	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.5380	
29010	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
29011	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29012	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29013	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
29014	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29015	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29016	12/9/2019 15:27	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
29017	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
29018	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
29019	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
29020	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
29021	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
29022	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
29023	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments	Some low spots in the station with standing water.	
29024	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
29025	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
29026	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29027	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
29028	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
29029	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
29030	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
29031	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
29032	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
29033	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
29034	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C Ø	0	
29035	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B Ø	0	
29036	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A Ø	0	
29037	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29038	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29039	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29040	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29041	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29042	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29043	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29044	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29045	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29046	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
29047	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
29048	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
29049	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
29050	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
29051	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	147.0	
29052	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	139.0	
29053	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	120.0	
29054	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29055	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29056	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29057	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	35	
29058	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
29059	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
29060	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
29061	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
29062	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
29063	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
29064	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
29065	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
29066	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
29067	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
29068	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
29069	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
29070	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
29071	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
29072	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
29073	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	13424.40	kw
29074	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
29075	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
29076	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	*C
29077	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
29078	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
29079	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29080	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29081	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29082	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29083	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
29084	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29085	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29086	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
29087	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7458	
29088	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Max	45	*C
29089	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
29090	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
29091	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
29092	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29093	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29094	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
29095	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
29096	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
29097	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
29098	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
29099	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
29100	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
29101	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	129275	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29102	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
29103	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
29104	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29105	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29106	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29107	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29108	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29109	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29110	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
29111	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
29112	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
29113	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
29114	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
29115	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
29116	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
29117	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
29118	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
29119	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
29120	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
29121	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
29122	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
29123	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	288	
29124	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	288	
29125	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
29126	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
29127	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
29128	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
29129	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
29130	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
29131	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
29132	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
29133	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	1086	
29134	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	13L	
29135	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	4L	
29136	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	7L	
29137	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
29138	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	298666	
29139	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	298660	
29140	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
29141	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
29142	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
29143	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
29144	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
29145	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
29146	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
29147	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
29148	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
29149	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
29150	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
29151	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
29152	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
29153	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
29154	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
29155	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
29156	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
29157	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
29158	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
29159	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
29160	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
29161	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
29162	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
29163	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	195	
29164	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	195	
29165	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
29166	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
29167	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
29168	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
29169	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
29170	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29171	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29172	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29173	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29174	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29175	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29176	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
29177	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
29178	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps C Ø	0.0	
29179	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps B Ø	0.0	
29180	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps A Ø	0.0	
29181	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29182	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29183	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29184	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations	1	
29185	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
29186	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
29187	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
29188	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
29189	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
29190	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
29191	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
29192	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
29193	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
29194	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
29195	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
29196	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
29197	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	16852	
29198	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	16856	
29199	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
29200	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	4L	
29201	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	9L	
29202	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	2R	
29203	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
29204	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29205	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
29206	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29207	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
29208	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29209	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
29210	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	1706	
29211	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
29212	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
29213	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
29214	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
29215	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
29216	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
29217	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
29218	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
29219	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
29220	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
29221	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
29222	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
29223	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29224	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29225	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29226	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29227	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
29228	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
29229	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
29230	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
29231	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
29232	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
29233	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
29234	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
29235	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
29236	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
29237	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
29238	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
29239	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
29240	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
29241	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
29242	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
29243	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
29244	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
29245	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
29246	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
29247	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
29248	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
29249	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
29250	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
29251	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
29252	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
29253	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
29254	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
29255	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
29256	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	35	°C
29257	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29258	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29259	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29260	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29261	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
29262	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29263	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29264	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
29265	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
29266	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
29267	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
29268	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
29269	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
29270	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
29271	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
29272	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
29273	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
29274	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29275	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
29276	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29277	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
29278	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29279	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
29280	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29281	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
29282	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29283	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
29284	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
29285	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
29286	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
29287	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	266	
29288	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Unknown Operations	0	
29289	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
29290	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Switching Operations	0	
29291	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
29292	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations This Read Vac	0	
29293	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AL	303	
29294	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AF	303	
29295	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
29296	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Maintenance Operations	0	
29297	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
29298	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
29299	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	General Comments	OPEN	
29300	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
29301	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
29302	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Follow-up Action Required?	n	
29303	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
29304	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations Ground	0	
29305	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations C Ø	0	
29306	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations B Ø	0	
29307	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations A Ø	0	
29308	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
29309	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
29310	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
29311	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29312	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29313	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	266	
29314	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	0	
29315	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
29316	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	0	
29317	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
29318	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
29319	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
29320	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
29321	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
29322	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
29323	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
29324	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
29325	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
29326	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29327	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
29328	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
29329	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
29330	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
29331	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
29332	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
29333	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
29334	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
29335	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
29336	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
29337	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
29338	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
29339	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
29340	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
29341	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
29342	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
29343	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
29344	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
29345	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
29346	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
29347	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
29348	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
29349	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Distribution OK?	y	
29350	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
29351	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
29352	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
29353	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC0000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
29354	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	5	
29355	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29356	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29357	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29358	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	220.0	
29359	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	218.0	
29360	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	180.0	
29361	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
29362	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29363	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC0000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
29364	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC0000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments	Not in service	
29365	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
29366	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
29367	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
29368	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
29369	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
29370	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
29371	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
29372	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
29373	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
29374	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
29375	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
29376	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
29377	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
29378	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
29379	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
29380	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
29381	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
29382	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
29383	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
29384	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
29385	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
29386	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
29387	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
29388	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
29389	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
29390	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
29391	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
29392	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
29393	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
29394	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
29395	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
29396	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
29397	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
29398	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
29399	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
29400	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
29401	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
29402	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
29403	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
29404	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
29405	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
29406	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
29407	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
29408	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
29409	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
29410	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
29411	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
29412	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
29413	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
29414	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
29415	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
29416	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
29417	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
29418	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
29419	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
29420	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
29421	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
29422	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
29423	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
29424	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
29425	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
29426	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
29427	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
29428	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
29429	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
29430	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
29431	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
29432	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
29433	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
29434	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
29435	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
29436	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
29437	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
29438	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
29439	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
29440	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
29441	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
29442	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
29443	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
29444	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
29445	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
29446	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
29447	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
29448	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
29449	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
29450	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
29451	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
29452	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
29453	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
29454	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
29455	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptable	y	
29456	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
29457	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
29458	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
29459	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
29460	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
29461	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
29462	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is old, looks rough ...couple of wash out spots on creek side of fence...corner fence post has been hit and bent in, making the	
29463	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
29464	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
29465	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
29466	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
29467	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
29468	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
29469	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
29470	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
29471	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
29472	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
29473	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	289	
29474	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	57391	
29475	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
29476	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	4L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29477	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	12L	
29478	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	1R	
29479	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	693	
29480	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
29481	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
29482	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
29483	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
29484	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
29485	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
29486	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
29487	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
29488	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
29489	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
29490	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
29491	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
29492	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
29493	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
29494	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
29495	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
29496	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
29497	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
29498	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
29499	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
29500	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
29501	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29502	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29503	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29504	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29505	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29506	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29507	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29508	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29509	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
29510	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	90.0	
29511	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	60.0	
29512	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	60.0	
29513	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
29514	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	
29515	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
29516	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29517	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29518	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29519	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	5	
29520	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
29521	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
29522	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
29523	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	General Comments		
29524	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
29525	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
29526	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
29527	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >S' Clearance To Trees?	y	
29528	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
29529	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
29530	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	289	
29531	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
29532	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
29533	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
29534	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
29535	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
29536	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
29537	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
29538	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
29539	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
29540	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
29541	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
29542	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
29543	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
29544	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
29545	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
29546	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
29547	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
29548	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
29549	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
29550	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
29551	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29552	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
29553	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
29554	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29555	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29556	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
29557	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
29558	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
29559	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
29560	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
29561	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
29562	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
29563	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
29564	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29565	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
29566	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.2312	
29567	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
29568	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
29569	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
29570	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
29571	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
29572	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
29573	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	1718	
29574	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	11L	
29575	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	11L	
29576	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	6L	
29577	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	256589	
29578	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	256589	
29579	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments	corrected counter readings. Field verified as 256589 by C Harris	
29580	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
29581	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
29582	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
29583	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	y	
29584	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
29585	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
29586	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
29587	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
29588	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
29589	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
29590	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	645	
29591	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	645	
29592	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
29593	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
29594	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments	ok	
29595	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
29596	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
29597	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
29598	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
29599	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
29600	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
29601	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
29602	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
29603	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
29604	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
29605	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
29606	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
29607	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
29608	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
29609	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	57388	
29610	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
29611	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
29612	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	n	
29613	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
29614	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
29615	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
29616	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
29617	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
29618	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
29619	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
29620	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
29621	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
29622	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
29623	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
29624	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
29625	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
29626	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29627	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	4	
29628	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
29629	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
29630	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
29631	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
29632	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
29633	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
29634	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
29635	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
29636	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	4	
29637	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29638	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29639	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29640	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	150.0	
29641	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	150.0	
29642	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	150.0	
29643	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
29644	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29645	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29646	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29647	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29648	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29649	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29650	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29651	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29652	12/9/2019 12:26	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29653	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
29654	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
29655	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
29656	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
29657	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
29658	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
29659	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
29660	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
29661	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
29662	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
29663	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
29664	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
29665	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
29666	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
29667	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
29668	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
29669	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	0 psi on Transformer and 0 psi on 6 pack; There is a Christmas Tree for fall protection on top of Transformer.	
29670	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
29671	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
29672	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
29673	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
29674	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
29675	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	30	°C
29676	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
29677	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
29678	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
29679	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29680	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29681	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29682	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29683	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
29684	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29685	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29686	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
29687	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29688	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
29689	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
29690	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
29691	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
29692	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
29693	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
29694	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
29695	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
29696	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
29697	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
29698	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
29699	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
29700	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
29701	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
29702	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29703	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
29704	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
29705	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
29706	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29707	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
29708	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
29709	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
29710	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
29711	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
29712	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
29713	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
29714	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
29715	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	
29716	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
29717	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29718	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29719	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29720	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29721	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29722	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29723	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29724	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29725	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
29726	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
29727	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
29728	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
29729	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
29730	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
29731	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
29732	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
29733	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
29734	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
29735	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
29736	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
29737	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
29738	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
29739	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
29740	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
29741	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
29742	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
29743	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
29744	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
29745	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
29746	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
29747	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
29748	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29749	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29750	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29751	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
29752	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	30.0	
29753	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	31.0	
29754	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	45.0	
29755	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29756	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29757	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29758	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
29759	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
29760	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
29761	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
29762	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
29763	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
29764	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
29765	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
29766	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
29767	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
29768	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
29769	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
29770	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
29771	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
29772	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
29773	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
29774	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	2998.08	kw
29775	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
29776	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29777	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
29778	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	32	°C
29779	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29780	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29781	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29782	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29783	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
29784	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29785	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29786	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
29787	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6246	
29788	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
29789	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29790	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
29791	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
29792	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	10080.00	kw
29793	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
29794	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
29795	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
29796	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1451	
29797	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
29798	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
29799	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
29800	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
29801	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
29802	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
29803	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
29804	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
29805	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
29806	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
29807	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
29808	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
29809	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
29810	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
29811	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
29812	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
29813	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
29814	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
29815	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
29816	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
29817	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
29818	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
29819	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments	Breaker #11 won't reset	
29820	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
29821	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
29822	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
29823	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
29824	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
29825	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
29826	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
29827	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
29828	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
29829	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
29830	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
29831	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29832	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29833	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
29834	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
29835	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
29836	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
29837	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
29838	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
29839	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
29840	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
29841	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
29842	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	4	
29843	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29844	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29845	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
29846	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29847	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29848	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
29849	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.5718	
29850	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
29851	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29852	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29853	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29854	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
29855	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
29856	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
29857	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
29858	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29859	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
29860	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
29861	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
29862	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
29863	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
29864	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments		
29865	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
29866	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LTC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
29867	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
29868	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
29869	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
29870	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
29871	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
29872	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
29873	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
29874	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
29875	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
29876	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
29877	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
29878	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
29879	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
29880	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
29881	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
29882	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
29883	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
29884	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
29885	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
29886	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
29887	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
29888	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
29889	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
29890	12/9/2019 11:54	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
29891	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
29892	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29893	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29894	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29895	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29896	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29897	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
29898	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
29899	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
29900	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
29901	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
29902	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
29903	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
29904	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
29905	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
29906	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
29907	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
29908	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
29909	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
29910	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
29911	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
29912	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
29913	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
29914	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
29915	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	256	
29916	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	256	
29917	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
29918	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
29919	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	1	
29920	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
29921	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
29922	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
29923	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
29924	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
29925	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
29926	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
29927	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
29928	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
29929	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
29930	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
29931	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
29932	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	0	
29933	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29934	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29935	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29936	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
29937	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
29938	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
29939	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
29940	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
29941	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
29942	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
29943	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
29944	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
29945	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
29946	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
29947	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
29948	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
29949	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
29950	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
29951	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
29952	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
29953	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
29954	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
29955	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
29956	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
29957	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
29958	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
29959	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	23	*C
29960	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	23	*C
29961	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
29962	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
29963	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
29964	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
29965	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
29966	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
29967	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	
29968	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
29969	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
29970	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
29971	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
29972	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
29973	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
29974	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
29975	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
29976	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	1.0500	
29977	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
29978	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
29979	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
29980	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	54.0	VDC
29981	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
29982	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	5	
29983	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
29984	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
29985	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
29986	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	370.0	
29987	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
29988	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
29989	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
29990	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	33.0	VDC
29991	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
29992	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
29993	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
29994	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
29995	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
29996	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
29997	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
29998	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
29999	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
30000	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
30001	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	390.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30002	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	400.0	
30003	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
30004	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
30005	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
30006	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
30007	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30008	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30009	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30010	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30011	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
30012	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
30013	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30014	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30015	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30016	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30017	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
30018	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
30019	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
30020	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
30021	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
30022	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30023	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30024	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
30025	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
30026	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
30027	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
30028	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
30029	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
30030	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
30031	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
30032	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
30033	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
30034	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >S' Clearance To Trees?	y	
30035	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
30036	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
30037	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
30038	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
30039	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
30040	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
30041	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
30042	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
30043	12/9/2019 12:45	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
30044	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
30045	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
30046	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
30047	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
30048	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
30049	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
30050	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
30051	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
30052	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	n	
30053	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
30054	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
30055	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
30056	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
30057	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
30058	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	0	
30059	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30060	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	0	
30061	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	341	
30062	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	341	
30063	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
30064	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
30065	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
30066	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
30067	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
30068	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
30069	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
30070	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
30071	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30072	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
30073	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
30074	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
30075	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
30076	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30077	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
30078	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
30079	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
30080	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
30081	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
30082	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
30083	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
30084	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30085	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
30086	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
30087	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
30088	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
30089	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
30090	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
30091	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
30092	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	153795	
30093	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
30094	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
30095	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
30096	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
30097	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	6	
30098	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
30099	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
30100	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
30101	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30102	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	0.0	
30103	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	0.0	
30104	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	0.0	
30105	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
30106	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30107	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	9	
30108	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30109	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments	Replaced yard light with new LED	
30110	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30111	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30112	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30113	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	40.0	
30114	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
30115	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
30116	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
30117	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
30118	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
30119	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	30.0	
30120	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	30.0	
30121	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
30122	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30123	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30124	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30125	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30126	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30127	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30128	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30129	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
30130	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
30131	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
30132	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
30133	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
30134	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
30135	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
30136	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	General Comments		
30137	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
30138	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
30139	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
30140	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
30141	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
30142	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	77	
30143	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	77	
30144	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	7	
30145	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
30146	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	7	
30147	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
30148	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
30149	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
30150	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
30151	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
30152	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
30153	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
30154	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
30155	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
30156	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
30157	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
30158	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
30159	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
30160	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
30161	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	1224.0	VAC
30162	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
30163	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
30164	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
30165	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30166	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30167	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
30168	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
30169	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
30170	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
30171	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
30172	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
30173	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
30174	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
30175	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
30176	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
30177	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
30178	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
30179	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments		
30180	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
30181	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
30182	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	5489.28	kw
30183	12/9/2019 11:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
30184	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
30185	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
30186	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
30187	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30188	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30189	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	64	*C
30190	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	23	*C
30191	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
30192	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	553	
30193	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
30194	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	8L	
30195	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
30196	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	4L	
30197	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
30198	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	222323	
30199	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	222323	
30200	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
30201	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
30202	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
30203	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
30204	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
30205	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
30206	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
30207	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
30208	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
30209	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
30210	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTCC000190	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
30211	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
30212	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
30213	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
30214	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
30215	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30216	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30217	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30218	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30219	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30220	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30221	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30222	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30223	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30224	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
30225	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	100.0	
30226	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	90.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30227	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
30228	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	100.0	
30229	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30230	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30231	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30232	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	9	
30233	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
30234	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
30235	12/9/2019 10:11	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
30236	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30237	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30238	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
30239	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
30240	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	260.0	
30241	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	260.0	
30242	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	260.0	
30243	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
30244	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
30245	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
30246	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
30247	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30248	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30249	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
30250	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
30251	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
30252	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
30253	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
30254	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30255	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30256	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30257	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30258	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30259	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30260	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
30261	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	204.0	
30262	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	209.0	
30263	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	206.0	
30264	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30265	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30266	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30267	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
30268	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
30269	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
30270	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
30271	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30272	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30273	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
30274	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
30275	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
30276	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
30277	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
30278	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
30279	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30280	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30281	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
30282	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
30283	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
30284	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
30285	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
30286	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
30287	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
30288	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
30289	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
30290	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
30291	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
30292	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
30293	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
30294	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
30295	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
30296	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
30297	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	8023.68	kw
30298	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
30299	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
30300	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	55	*C
30301	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	30	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30302	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
30303	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
30304	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
30305	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
30306	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
30307	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
30308	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
30309	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
30310	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.8358	
30311	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
30312	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
30313	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
30314	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
30315	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
30316	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
30317	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
30318	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
30319	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
30320	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
30321	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
30322	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
30323	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
30324	12/9/2019 12:54	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
30325	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
30326	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
30327	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
30328	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
30329	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
30330	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
30331	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
30332	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
30333	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
30334	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
30335	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
30336	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
30337	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
30338	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	186	
30339	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	186	
30340	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
30341	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30342	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
30343	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
30344	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
30345	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
30346	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
30347	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
30348	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
30349	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
30350	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
30351	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
30352	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
30353	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
30354	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
30355	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
30356	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
30357	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
30358	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
30359	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
30360	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
30361	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
30362	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
30363	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
30364	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
30365	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
30366	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
30367	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
30368	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
30369	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30370	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30371	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30372	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
30373	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
30374	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
30375	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	89805	
30376	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	89816	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30377	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
30378	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	3L	
30379	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
30380	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
30381	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
30382	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
30383	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
30384	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
30385	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
30386	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
30387	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
30388	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
30389	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
30390	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
30391	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
30392	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
30393	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	1R	
30394	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	9L	
30395	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	965	
30396	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
30397	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
30398	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
30399	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
30400	12/9/2019 14:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
30401	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
30402	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
30403	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
30404	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
30405	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
30406	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
30407	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
30408	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
30409	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
30410	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
30411	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
30412	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
30413	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
30414	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
30415	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
30416	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
30417	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
30418	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
30419	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
30420	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
30421	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
30422	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
30423	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments	lightening arrestor has come loose at the chance clamp. 4618 circuit	
30424	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
30425	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
30426	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
30427	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
30428	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
30429	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
30430	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
30431	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
30432	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
30433	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
30434	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	1904.64	kw
30435	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
30436	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
30437	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
30438	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
30439	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30440	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
30441	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	132	
30442	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	132	
30443	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
30444	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
30445	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
30446	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
30447	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
30448	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
30449	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30450	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	0	
30451	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
30452	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	254	
30453	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	254	
30454	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
30455	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
30456	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
30457	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
30458	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
30459	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
30460	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
30461	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
30462	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
30463	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
30464	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
30465	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
30466	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
30467	12/9/2019 12:23	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
30468	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
30469	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
30470	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
30471	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
30472	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
30473	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
30474	12/9/2019 14:02	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
30475	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
30476	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
30477	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
30478	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
30479	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
30480	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	724	
30481	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
30482	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
30483	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
30484	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
30485	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
30486	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	6902	
30487	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	6902	
30488	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
30489	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
30490	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
30491	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
30492	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
30493	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
30494	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
30495	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Ground in Place?	y	
30496	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
30497	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	4	
30498	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
30499	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
30500	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
30501	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30502	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
30503	12/9/2019 13:23	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30504	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
30505	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
30506	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
30507	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
30508	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
30509	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
30510	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
30511	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	General Comments		
30512	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
30513	12/9/2019 9:22	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
30514	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
30515	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
30516	12/9/2019 15:15	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
30517	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
30518	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
30519	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30520	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	207	
30521	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
30522	12/11/2019 10:21	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
30523	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
30524	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	207	
30525	12/9/2019 12:28	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
30526	12/9/2019 13:12	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30677	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
30678	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
30679	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
30680	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
30681	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
30682	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
30683	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
30684	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
30685	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen to 1psi	
30686	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
30687	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	2736.00	kw
30688	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
30689	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
30690	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	58	°C
30691	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	35	°C
30692	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
30693	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
30694	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
30695	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
30696	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
30697	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
30698	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
30699	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
30700	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.9048	
30701	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	70	°C
30702	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
30703	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
30704	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
30705	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
30706	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
30707	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
30708	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
30709	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30710	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30711	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30712	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30713	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	50	°C
30714	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
30715	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
30716	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
30717	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
30718	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
30719	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
30720	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
30721	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
30722	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
30723	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
30724	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
30725	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
30726	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
30727	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
30728	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
30729	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
30730	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
30731	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
30732	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
30733	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
30734	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
30735	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30736	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30737	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30738	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
30739	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
30740	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
30741	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
30742	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
30743	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
30744	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30745	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	0	
30746	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	0	
30747	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
30748	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
30749	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
30750	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
30751	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30752	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30753	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
30754	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
30755	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
30756	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	167	
30757	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	167	
30758	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
30759	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
30760	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
30761	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
30762	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
30763	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
30764	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	571	
30765	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	571	
30766	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
30767	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
30768	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30769	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30770	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	10	
30771	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30772	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30773	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
30774	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	41.0	
30775	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	35.0	
30776	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	33.0	
30777	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
30778	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
30779	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30780	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30781	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
30782	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
30783	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
30784	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
30785	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
30786	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
30787	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
30788	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
30789	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	5700	
30790	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
30791	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
30792	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
30793	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
30794	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
30795	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
30796	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
30797	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
30798	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
30799	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
30800	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	15	
30801	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
30802	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
30803	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
30804	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
30805	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
30806	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
30807	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
30808	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
30809	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
30810	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
30811	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
30812	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
30813	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
30814	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	0	
30815	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
30816	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
30817	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Present	0	*C
30818	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Max	0	*C
30819	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.4890	
30820	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
30821	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Present	35	*C
30822	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
30823	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
30824	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
30825	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
30826	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Max	60	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30827	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
30828	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
30829	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	23.0	
30830	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
30831	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
30832	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
30833	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
30834	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
30835	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
30836	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
30837	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
30838	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
30839	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
30840	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	2139	
30841	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	8L	
30842	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	3R	
30843	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	3L	
30844	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
30845	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
30846	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
30847	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
30848	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
30849	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
30850	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
30851	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
30852	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
30853	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
30854	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
30855	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
30856	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
30857	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
30858	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
30859	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	200.0	
30860	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	210.0	
30861	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30862	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30863	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30864	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	180.0	
30865	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
30866	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
30867	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30868	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30869	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30870	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30871	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30872	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30873	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30874	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
30875	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
30876	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
30877	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
30878	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
30879	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
30880	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	22311	
30881	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	22303	
30882	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
30883	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
30884	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
30885	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
30886	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
30887	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
30888	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
30889	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
30890	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
30891	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	not on site	
30892	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	not on site	
30893	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
30894	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
30895	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
30896	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
30897	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
30898	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
30899	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
30900	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
30901	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30902	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
30903	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
30904	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
30905	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
30906	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
30907	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
30908	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
30909	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
30910	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
30911	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
30912	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
30913	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
30914	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
30915	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
30916	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
30917	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
30918	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
30919	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
30920	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
30921	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
30922	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
30923	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	2	
30924	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
30925	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
30926	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
30927	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
30928	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
30929	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
30930	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
30931	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
30932	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
30933	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
30934	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
30935	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
30936	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
30937	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
30938	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
30939	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
30940	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
30941	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
30942	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
30943	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
30944	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
30945	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
30946	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
30947	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
30948	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
30949	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
30950	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
30951	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
30952	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
30953	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
30954	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
30955	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
30956	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
30957	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
30958	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
30959	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	717	
30960	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
30961	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
30962	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
30963	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	717	
30964	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
30965	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
30966	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
30967	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
30968	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
30969	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
30970	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
30971	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
30972	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
30973	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
30974	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
30975	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
30976	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
30977	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
30978	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	0	
30979	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
30980	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
30981	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
30982	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
30983	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
30984	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
30985	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
30986	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
30987	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
30988	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
30989	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
30990	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
30991	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
30992	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
30993	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
30994	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
30995	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
30996	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	451	
30997	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
30998	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
30999	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
31000	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
31001	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	21704	
31002	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	21704	
31003	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
31004	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
31005	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
31006	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
31007	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
31008	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
31009	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
31010	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
31011	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
31012	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
31013	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
31014	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
31015	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
31016	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
31017	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
31018	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
31019	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
31020	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
31021	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
31022	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
31023	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
31024	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
31025	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
31026	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
31027	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
31028	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
31029	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
31030	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
31031	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
31032	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
31033	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	*F
31034	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
31035	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
31036	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
31037	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
31038	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
31039	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
31040	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
31041	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
31042	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
31043	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
31044	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
31045	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31046	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
31047	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
31048	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	35	*C
31049	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
31050	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
31051	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31052	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31053	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31054	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Insects	
31055	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	1	
31056	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	1	
31057	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	201	
31058	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	201	
31059	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
31060	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
31061	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
31062	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
31063	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
31064	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
31065	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
31066	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
31067	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
31068	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31069	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31070	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31071	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31072	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	99.0	
31073	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	50	°C
31074	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	50	°C
31075	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
31076	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
31077	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	16286.40	kw
31078	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
31079	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
31080	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
31081	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
31082	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
31083	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
31084	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
31085	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	102.0	
31086	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	97.0	
31087	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
31088	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
31089	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
31090	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
31091	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
31092	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
31093	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
31094	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31095	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31096	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31097	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	14	
31098	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	280.0	
31099	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	3	
31100	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31101	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31102	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
31103	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
31104	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
31105	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
31106	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
31107	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
31108	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
31109	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
31110	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
31111	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
31112	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
31113	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
31114	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
31115	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
31116	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
31117	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31118	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
31119	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	3	
31120	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31121	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31122	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31123	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31124	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31125	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
31126	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
31127	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
31128	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
31129	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31130	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31131	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31132	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31133	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
31134	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
31135	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
31136	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
31137	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
31138	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
31139	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	28	
31140	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
31141	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31142	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31143	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31144	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
31145	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
31146	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
31147	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
31148	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
31149	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
31150	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
31151	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
31152	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	314	
31153	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	314	
31154	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
31155	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
31156	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
31157	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
31158	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
31159	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
31160	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
31161	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
31162	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
31163	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.38	
31164	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
31165	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
31166	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
31167	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
31168	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
31169	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
31170	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
31171	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31172	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31173	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31174	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31175	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31176	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31177	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
31178	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
31179	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
31180	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
31181	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
31182	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
31183	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
31184	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
31185	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
31186	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
31187	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	58132	
31188	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
31189	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
31190	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
31191	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
31192	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
31193	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	265	
31194	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	1	
31195	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	1	
31196	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	265	
31197	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	15	°C
31198	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
31199	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
31200	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
31201	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31202	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
31203	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
31204	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
31205	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
31206	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
31207	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
31208	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
31209	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
31210	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
31211	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
31212	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
31213	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
31214	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
31215	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
31216	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
31217	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
31218	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
31219	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
31220	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
31221	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
31222	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
31223	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1677	
31224	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1677	
31225	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
31226	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
31227	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
31228	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
31229	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
31230	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
31231	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
31232	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
31233	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
31234	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
31235	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
31236	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	2	
31237	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31238	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.38	
31239	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
31240	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
31241	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
31242	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
31243	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
31244	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
31245	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
31246	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
31247	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
31248	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
31249	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
31250	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
31251	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
31252	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
31253	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
31254	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
31255	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
31256	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	135.0	
31257	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	139.0	
31258	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	158.0	
31259	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31260	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31261	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31262	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	75	
31263	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
31264	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	
31265	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62896	volts
31266	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
31267	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
31268	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
31269	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
31270	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
31271	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
31272	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
31273	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3	
31274	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	20.0	
31275	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	20.0	
31276	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	20.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
31277	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
31278	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31279	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31280	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31281	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31282	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31283	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31284	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31285	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31286	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31287	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
31288	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
31289	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
31290	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
31291	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
31292	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
31293	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
31294	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
31295	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
31296	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
31297	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	148	
31298	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	248	
31299	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	0	
31300	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	0	
31301	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
31302	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
31303	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
31304	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
31305	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
31306	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
31307	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
31308	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
31309	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
31310	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
31311	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
31312	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
31313	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	top rail rusty .bottom of alot of the fence has a large gap	
31314	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
31315	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
31316	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
31317	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
31318	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
31319	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
31320	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
31321	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
31322	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
31323	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
31324	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
31325	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
31326	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
31327	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
31328	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
31329	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
31330	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
31331	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3	
31332	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
31333	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
31334	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments		
31335	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
31336	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
31337	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	0	
31338	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2466	
31339	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
31340	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
31341	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
31342	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
31343	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
31344	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
31345	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	278.0	
31346	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	292.0	
31347	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	285.0	
31348	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
31349	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31350	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31351	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31352	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31353	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31354	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31355	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	3	
31356	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	3	
31357	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	184	
31358	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	44	
31359	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
31360	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
31361	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
31362	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	8	
31363	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	390.0	
31364	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	184	
31365	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
31366	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
31367	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31368	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31369	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
31370	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
31371	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31372	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31373	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31374	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31375	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
31376	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
31377	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
31378	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
31379	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
31380	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
31381	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
31382	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
31383	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
31384	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
31385	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
31386	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31387	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
31388	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
31389	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
31390	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
31391	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	
31392	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
31393	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
31394	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
31395	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
31396	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31397	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31398	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31399	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
31400	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
31401	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
31402	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
31403	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
31404	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
31405	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
31406	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
31407	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
31408	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	y	
31409	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
31410	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
31411	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments	counter was entered wrong on last check for final counter	
31412	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
31413	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
31414	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	6	
31415	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31416	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31417	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31418	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
31419	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	0	
31420	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	0	
31421	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31422	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31423	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31424	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31425	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	320.0	
31426	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	300.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
31427	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
31428	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
31429	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
31430	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
31431	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
31432	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
31433	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
31434	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
31435	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
31436	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
31437	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
31438	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments		
31439	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
31440	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
31441	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
31442	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
31443	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
31444	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
31445	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
31446	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	42	°C
31447	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	79	°C
31448	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
31449	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	72	°C
31450	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
31451	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
31452	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
31453	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
31454	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
31455	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
31456	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
31457	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
31458	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
31459	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	37	°C
31460	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
31461	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
31462	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
31463	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
31464	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
31465	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
31466	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
31467	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
31468	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
31469	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
31470	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
31471	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	
31472	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
31473	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
31474	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31475	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31476	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31477	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31478	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31479	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Insects	
31480	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31481	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31482	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31483	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31484	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31485	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
31486	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	142.0	
31487	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	156.0	
31488	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	147.0	
31489	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
31490	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
31491	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
31492	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
31493	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		two lights on wall between tr1 and tr2 are going on and off. Top light by tr2 69kv mod box is not working, replaced bulb and still not v
31494	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
31495	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
31496	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
31497	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
31498	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
31499	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
31500	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
31501	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31502	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
31503	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
31504	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
31505	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
31506	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31507	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
31508	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
31509	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
31510	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
31511	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
31512	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
31513	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
31514	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
31515	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
31516	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
31517	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
31518	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
31519	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
31520	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
31521	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
31522	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
31523	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
31524	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
31525	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31526	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31527	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31528	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31529	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	67.0	
31530	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	85.0	
31531	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	79.0	
31532	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
31533	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
31534	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
31535	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
31536	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
31537	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
31538	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58989	
31539	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
31540	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
31541	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
31542	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	5	
31543	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	5	
31544	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	205	
31545	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	205	
31546	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
31547	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
31548	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
31549	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
31550	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
31551	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
31552	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
31553	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
31554	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
31555	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
31556	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
31557	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
31558	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31559	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2466	
31560	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
31561	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments		
31562	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
31563	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
31564	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
31565	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
31566	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
31567	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
31568	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
31569	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
31570	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
31571	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
31572	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
31573	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
31574	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	
31575	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
31576	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31577	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31578	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31579	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31580	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	95.0	
31581	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	106.0	
31582	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	119.0	
31583	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
31584	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
31585	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
31586	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	15	
31587	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
31588	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	1	
31589	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	483	
31590	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	483	
31591	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
31592	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
31593	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
31594	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments		
31595	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
31596	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
31597	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
31598	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
31599	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
31600	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	
31601	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
31602	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
31603	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31604	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31605	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31606	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31607	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31608	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31609	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
31610	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
31611	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
31612	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
31613	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
31614	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
31615	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
31616	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
31617	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
31618	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
31619	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	24271	
31620	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	24271	
31621	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
31622	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	4L	
31623	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	2R	
31624	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	9L	
31625	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
31626	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
31627	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	65	°C
31628	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
31629	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	1070	
31630	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
31631	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
31632	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
31633	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
31634	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
31635	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
31636	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
31637	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
31638	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
31639	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
31640	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
31641	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
31642	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
31643	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
31644	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
31645	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
31646	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
31647	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
31648	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
31649	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
31650	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
31651	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31652	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
31653	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
31654	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	1	
31655	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31656	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31657	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
31658	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	4	
31659	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	4	
31660	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1281	
31661	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1281	
31662	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
31663	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
31664	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
31665	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
31666	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
31667	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
31668	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
31669	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	0	
31670	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
31671	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
31672	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
31673	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
31674	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
31675	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
31676	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
31677	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
31678	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
31679	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
31680	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
31681	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
31682	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
31683	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
31684	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
31685	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
31686	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
31687	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
31688	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
31689	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
31690	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
31691	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
31692	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
31693	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
31694	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
31695	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
31696	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
31697	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
31698	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
31699	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
31700	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
31701	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
31702	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
31703	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
31704	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
31705	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
31706	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
31707	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
31708	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
31709	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
31710	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	on site	
31711	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	not on site	
31712	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
31713	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31714	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31715	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31716	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
31717	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
31718	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
31719	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	145	
31720	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	145	
31721	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
31722	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
31723	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
31724	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
31725	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
31726	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31727	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
31728	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
31729	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
31730	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31731	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31732	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31733	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31734	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	350.0	
31735	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	425.0	
31736	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31737	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
31738	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
31739	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	250.0	
31740	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
31741	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
31742	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31743	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31744	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31745	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
31746	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
31747	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
31748	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	1	
31749	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
31750	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
31751	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
31752	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
31753	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
31754	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
31755	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
31756	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
31757	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
31758	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
31759	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
31760	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
31761	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
31762	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
31763	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
31764	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
31765	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
31766	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
31767	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
31768	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
31769	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
31770	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
31771	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
31772	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
31773	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
31774	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
31775	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
31776	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
31777	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
31778	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
31779	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
31780	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
31781	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
31782	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
31783	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
31784	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
31785	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
31786	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
31787	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
31788	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
31789	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
31790	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
31791	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
31792	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
31793	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
31794	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
31795	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
31796	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
31797	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
31798	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
31799	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
31800	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
31801	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31802	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
31803	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
31804	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31805	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
31806	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
31807	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
31808	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
31809	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
31810	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
31811	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
31812	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
31813	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
31814	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
31815	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
31816	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	106707	
31817	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	106707	
31818	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
31819	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
31820	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
31821	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
31822	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC0000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
31823	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC0000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
31824	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC0000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
31825	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	209	
31826	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	1	
31827	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	1	
31828	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
31829	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
31830	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
31831	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
31832	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	809	
31833	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	809	
31834	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
31835	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	
31836	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	58	°C
31837	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
31838	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9204	
31839	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
31840	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
31841	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
31842	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
31843	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
31844	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
31845	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
31846	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
31847	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8835.84	kw
31848	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
31849	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
31850	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
31851	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
31852	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
31853	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
31854	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
31855	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Poor	
31856	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
31857	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	n	If no, which cells in comments
31858	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
31859	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
31860	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	n	If no, which cells in comments
31861	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
31862	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	4 out of the 6 batteries need to be replaced.	
31863	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
31864	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
31865	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
31866	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
31867	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
31868	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
31869	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
31870	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
31871	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
31872	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
31873	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
31874	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
31875	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	68.0	
31876	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	95.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31877	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
31878	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
31879	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
31880	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
31881	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
31882	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
31883	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
31884	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
31885	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
31886	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
31887	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
31888	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
31889	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
31890	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
31891	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
31892	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
31893	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
31894	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
31895	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
31896	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
31897	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
31898	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
31899	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
31900	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
31901	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
31902	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
31903	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
31904	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
31905	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
31906	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
31907	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
31908	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
31909	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
31910	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
31911	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
31912	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
31913	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
31914	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
31915	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
31916	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
31917	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	29	
31918	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
31919	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
31920	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
31921	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
31922	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
31923	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
31924	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
31925	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
31926	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
31927	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
31928	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
31929	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		
31930	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
31931	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
31932	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
31933	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
31934	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
31935	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
31936	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
31937	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
31938	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
31939	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
31940	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
31941	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
31942	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
31943	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
31944	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
31945	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
31946	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
31947	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
31948	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
31949	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
31950	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
31951	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
31952	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
31953	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
31954	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
31955	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
31956	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
31957	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
31958	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
31959	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
31960	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
31961	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
31962	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
31963	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
31964	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
31965	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
31966	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
31967	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
31968	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
31969	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
31970	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
31971	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
31972	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
31973	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
31974	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
31975	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
31976	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
31977	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
31978	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
31979	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
31980	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
31981	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
31982	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
31983	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	y	
31984	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
31985	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
31986	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
31987	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
31988	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
31989	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
31990	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	y	
31991	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
31992	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
31993	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
31994	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
31995	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
31996	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
31997	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
31998	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
31999	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32000	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32001	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32002	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32003	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32004	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32005	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32006	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32007	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32008	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
32009	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
32010	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
32011	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
32012	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
32013	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
32014	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
32015	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
32016	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
32017	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
32018	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
32019	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
32020	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
32021	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
32022	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
32023	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
32024	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
32025	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
32026	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32027	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
32028	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32029	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32030	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32031	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	9	
32032	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
32033	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
32034	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
32035	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
32036	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
32037	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
32038	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
32039	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
32040	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
32041	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
32042	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
32043	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
32044	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
32045	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
32046	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
32047	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	5	
32048	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
32049	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
32050	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32051	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
32052	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32053	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	892	
32054	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
32055	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
32056	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
32057	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	
32058	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	0	
32059	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	0	
32060	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	102	
32061	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	102	
32062	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
32063	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
32064	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
32065	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
32066	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32067	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	243314	
32068	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	243306	
32069	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	theres an order to replace the drag hand cable	
32070	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
32071	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32072	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
32073	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
32074	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
32075	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
32076	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
32077	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
32078	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
32079	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
32080	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
32081	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
32082	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	40.0	
32083	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	70.0	
32084	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	50.0	
32085	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32086	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32087	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32088	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	3	
32089	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
32090	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
32091	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
32092	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
32093	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
32094	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
32095	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
32096	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
32097	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
32098	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
32099	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
32100	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
32101	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32102	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
32103	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
32104	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
32105	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32106	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments	many places along the fence have gaps greater than 4" at the bottom	
32107	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32108	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
32109	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
32110	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
32111	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
32112	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32113	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32114	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
32115	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
32116	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
32117	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
32118	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
32119	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
32120	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
32121	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
32122	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
32123	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32124	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32125	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32126	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32127	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
32128	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32129	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
32130	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32131	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32132	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32133	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32134	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32135	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32136	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
32137	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
32138	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
32139	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
32140	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
32141	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
32142	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
32143	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
32144	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
32145	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
32146	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
32147	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32148	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
32149	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
32150	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
32151	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32152	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32153	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32154	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
32155	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32156	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32157	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32158	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32159	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32160	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
32161	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32162	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
32163	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	109.44	kw
32164	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
32165	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
32166	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	40	*C
32167	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	35	*C
32168	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
32169	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
32170	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
32171	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
32172	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
32173	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32174	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	5L	
32175	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
32176	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	11L	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32177	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	28	
32178	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32179	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32180	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32181	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
32182	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
32183	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0342	
32184	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
32185	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
32186	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
32187	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
32188	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
32189	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
32190	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
32191	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
32192	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
32193	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
32194	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
32195	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
32196	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
32197	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
32198	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
32199	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
32200	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
32201	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
32202	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
32203	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
32204	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
32205	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
32206	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
32207	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
32208	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
32209	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32210	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
32211	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
32212	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
32213	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
32214	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
32215	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
32216	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
32217	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
32218	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
32219	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
32220	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
32221	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
32222	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
32223	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
32224	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
32225	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
32226	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
32227	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32228	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	A few limbs are starting to grow over the fence. Fence top and mid rails getting rusty.	
32229	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32230	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
32231	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
32232	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
32233	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
32234	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
32235	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
32236	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
32237	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
32238	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
32239	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32240	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32241	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
32242	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32243	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant on tr 1 LTC needs changed	
32244	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
32245	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32246	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32247	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32248	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
32249	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	227	
32250	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
32251	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	13L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
32252	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	4L	
32253	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	9L	
32254	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32255	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	339724	
32256	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	338715	
32257	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
32258	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
32259	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32260	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
32261	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
32262	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
32263	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
32264	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
32265	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
32266	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
32267	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	4	
32268	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32269	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
32270	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	289	
32271	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	285	
32272	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
32273	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
32274	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
32275	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments	out of service.	
32276	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
32277	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
32278	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
32279	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
32280	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
32281	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	5	
32282	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32283	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32284	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32285	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
32286	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
32287	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
32288	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
32289	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32290	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32291	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32292	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32293	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32294	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32295	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32296	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32297	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32298	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
32299	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
32300	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
32301	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
32302	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
32303	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
32304	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
32305	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
32306	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
32307	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
32308	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
32309	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
32310	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	60	
32311	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	60	
32312	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	5	
32313	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32314	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	5	
32315	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
32316	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
32317	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LTC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	ok	
32318	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LTC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
32319	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
32320	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
32321	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
32322	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
32323	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
32324	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
32325	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
32326	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32327	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	19.0	
32328	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	400.0	
32329	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	450.0	
32330	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	250.0	
32331	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32332	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32333	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32334	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	0	
32335	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	13.0	
32336	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	11.0	
32337	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
32338	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32339	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32340	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
32341	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
32342	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
32343	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
32344	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
32345	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
32346	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
32347	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
32348	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
32349	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32350	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	?	
32351	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32352	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	?	
32353	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
32354	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
32355	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
32356	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
32357	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2109.60	kw
32358	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32359	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
32360	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32361	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
32362	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32363	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
32364	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
32365	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
32366	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	41	°C
32367	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	18	°C
32368	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
32369	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
32370	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
32371	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
32372	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
32373	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
32374	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32375	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32376	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32377	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32378	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
32379	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32380	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32381	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
32382	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32383	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
32384	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
32385	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	0	
32386	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	418	
32387	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	418	
32388	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
32389	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments	A, B,C phase IOC	
32390	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
32391	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
32392	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
32393	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
32394	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
32395	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
32396	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
32397	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
32398	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
32399	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
32400	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
32401	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
32402	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
32403	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
32404	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
32405	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
32406	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
32407	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
32408	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32409	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32410	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32411	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	2	
32412	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32413	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32414	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
32415	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32416	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32417	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
32418	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32419	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32420	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32421	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32422	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
32423	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
32424	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
32425	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
32426	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
32427	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
32428	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
32429	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
32430	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
32431	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
32432	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
32433	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
32434	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
32435	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
32436	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
32437	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
32438	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
32439	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
32440	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
32441	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
32442	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
32443	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
32444	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
32445	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
32446	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
32447	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
32448	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	General Comments		
32449	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
32450	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
32451	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
32452	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
32453	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
32454	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
32455	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
32456	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
32457	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
32458	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
32459	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
32460	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
32461	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
32462	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments	construction going on,yard is a muddy mess. 1 400w mercury vapor light out. this is the large plexiglass old style box. Recommend a 4	
32463	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
32464	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
32465	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
32466	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
32467	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
32468	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
32469	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.1172	
32470	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	31	°C
32471	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	15	°C
32472	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
32473	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32474	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
32475	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32476	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
32477	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
32478	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
32479	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Present	0	°C
32480	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Max	0	°C
32481	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.6012	
32482	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
32483	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Present	40	°C
32484	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Max	65	°C
32485	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
32486	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
32487	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32488	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
32489	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
32490	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
32491	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
32492	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
32493	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
32494	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
32495	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
32496	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	5771.52	kw
32497	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32498	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
32499	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
32500	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
32501	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
32502	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
32503	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
32504	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
32505	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
32506	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
32507	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
32508	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
32509	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	125	
32510	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	125	
32511	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
32512	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
32513	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
32514	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
32515	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
32516	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
32517	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
32518	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32519	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
32520	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
32521	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
32522	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
32523	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32524	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	ap under fence in back right corner. Barb wire and some of the posts and rails have some rust.	
32525	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32526	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
32527	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
32528	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
32529	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
32530	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32531	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32532	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32533	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32534	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32535	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32536	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
32537	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32538	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
32539	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
32540	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
32541	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
32542	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
32543	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
32544	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
32545	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
32546	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
32547	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
32548	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
32549	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
32550	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		If no, which cells in comments
32551	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32552	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
32553	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
32554	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
32555	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
32556	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
32557	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
32558	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
32559	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
32560	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
32561	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
32562	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
32563	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
32564	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
32565	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	5	
32566	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32567	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32568	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32569	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
32570	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
32571	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
32572	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
32573	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
32574	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
32575	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
32576	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
32577	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
32578	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
32579	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
32580	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
32581	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
32582	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
32583	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	4694.40	kw
32584	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
32585	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	120.0	
32586	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	10.0	
32587	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	50.0	
32588	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
32589	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32590	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32591	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32592	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32593	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32594	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32595	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32596	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32597	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32598	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
32599	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
32600	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
32601	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
32602	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
32603	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
32604	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
32605	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
32606	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
32607	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
32608	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
32609	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
32610	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	740	
32611	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	740	
32612	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
32613	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
32614	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
32615	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
32616	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
32617	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
32618	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
32619	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	523	
32620	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	523	
32621	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
32622	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
32623	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
32624	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32625	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments		cubicle heater is bad
32626	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32627	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
32628	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32629	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
32630	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32631	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
32632	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32633	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
32634	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
32635	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
32636	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
32637	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32638	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
32639	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments		
32640	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	45718	
32641	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	45718	
32642	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32643	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
32644	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	8R	
32645	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	10L	
32646	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
32647	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
32648	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
32649	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1313	
32650	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
32651	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32652	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32653	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32654	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
32655	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
32656	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
32657	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32658	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32659	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
32660	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
32661	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
32662	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
32663	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
32664	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
32665	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
32666	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
32667	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
32668	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
32669	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
32670	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
32671	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
32672	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
32673	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
32674	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
32675	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.6	VDC
32676	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.7	VDC
32677	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
32678	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
32679	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
32680	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
32681	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
32682	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Heaters not woking and tagged out of service, no name or date on tag. One 8' single pin light not working. No broom in contro	
32683	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
32684	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
32685	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
32686	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
32687	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
32688	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
32689	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
32690	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
32691	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
32692	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
32693	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
32694	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	1	
32695	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32696	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32697	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32698	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	97.0	
32699	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	102.0	
32700	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	99.0	
32701	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32702	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
32703	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
32704	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
32705	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
32706	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
32707	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
32708	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
32709	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
32710	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	
32711	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
32712	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
32713	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
32714	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	657	
32715	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32716	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32717	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32718	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
32719	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
32720	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
32721	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
32722	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
32723	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
32724	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
32725	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
32726	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	176	
32727	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	176	
32728	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	0	
32729	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
32730	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	1	
32731	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32732	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32733	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32734	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	10.0	
32735	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	10.0	
32736	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	100.0	
32737	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
32738	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32739	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32740	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32741	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32742	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32743	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32744	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32745	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32746	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32747	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
32748	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
32749	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
32750	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
32751	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
32752	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
32753	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
32754	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
32755	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32756	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32757	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32758	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32759	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32760	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32761	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32762	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32763	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32764	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
32765	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	190.0	
32766	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	200.0	
32767	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	170.0	
32768	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32769	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32770	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32771	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	9	
32772	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
32773	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
32774	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
32775	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32776	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32777	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
32778	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	223884	
32779	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	223884	
32780	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32781	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
32782	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
32783	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
32784	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	0	
32785	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32786	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32787	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32788	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	20.0	
32789	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	20.0	
32790	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	20.0	
32791	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
32792	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
32793	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
32794	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
32795	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
32796	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
32797	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
32798	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
32799	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
32800	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
32801	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
32802	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32803	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32804	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
32805	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
32806	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
32807	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
32808	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
32809	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
32810	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
32811	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
32812	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
32813	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
32814	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
32815	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
32816	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
32817	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	119.0	
32818	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	106.0	
32819	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	95.0	
32820	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
32821	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
32822	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	209	
32823	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
32824	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32825	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
32826	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
32827	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	15034	
32828	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	15034	
32829	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32830	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
32831	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
32832	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
32833	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
32834	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	610	
32835	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32836	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32837	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32838	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32839	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32840	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32841	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
32842	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	3472	
32843	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	42	°C
32844	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	70	°C
32845	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
32846	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	10L	
32847	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	16R	
32848	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	8R	
32849	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
32850	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments	B phase IOC	
32851	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
32852	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
32853	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
32854	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
32855	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	707	
32856	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	707	
32857	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	0	
32858	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32859	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	0	
32860	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
32861	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
32862	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
32863	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
32864	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
32865	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
32866	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
32867	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
32868	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
32869	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
32870	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
32871	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
32872	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
32873	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
32874	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
32875	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
32876	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	0	
32877	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
32878	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
32879	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
32880	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
32881	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
32882	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	1	
32883	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
32884	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
32885	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
32886	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
32887	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	782.0	
32888	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	790.0	
32889	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	760.0	
32890	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
32891	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
32892	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
32893	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32894	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32895	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32896	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32897	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
32898	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
32899	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
32900	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
32901	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
32902	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
32903	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
32904	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
32905	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
32906	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
32907	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
32908	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
32909	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32910	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
32911	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32912	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
32913	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
32914	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32915	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32916	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
32917	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
32918	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	0	
32919	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
32920	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	0	
32921	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	196	
32922	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	196	
32923	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
32924	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
32925	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
32926	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
32927	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
32928	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
32929	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
32930	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
32931	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
32932	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments	this is the correct counter	
32933	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220366	
32934	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220366	
32935	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
32936	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
32937	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
32938	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
32939	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	-169	
32940	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
32941	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
32942	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
32943	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
32944	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	n	
32945	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32946	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32947	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
32948	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
32949	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
32950	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
32951	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
32952	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
32953	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
32954	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
32955	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
32956	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
32957	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
32958	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
32959	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
32960	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
32961	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
32962	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
32963	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
32964	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	130.0	
32965	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
32966	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
32967	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
32968	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
32969	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
32970	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
32971	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
32972	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
32973	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
32974	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
32975	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
32976	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
32977	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
32978	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
32979	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
32980	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
32981	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
32982	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
32983	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
32984	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
32985	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
32986	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
32987	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
32988	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
32989	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
32990	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
32991	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
32992	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
32993	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
32994	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
32995	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
32996	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
32997	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
32998	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
32999	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33000	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
33001	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
33002	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
33003	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
33004	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
33005	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
33006	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
33007	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
33008	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
33009	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33010	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
33011	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
33012	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
33013	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
33014	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
33015	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33016	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33017	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33018	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33019	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33020	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33021	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
33022	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
33023	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
33024	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
33025	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
33026	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
33027	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
33028	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	175	
33029	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	175	
33030	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	0	
33031	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33032	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	0	
33033	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
33034	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
33035	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
33036	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
33037	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
33038	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
33039	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
33040	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
33041	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
33042	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
33043	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
33044	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
33045	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
33046	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
33047	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
33048	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
33049	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
33050	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	*F
33051	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
33052	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
33053	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
33054	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
33055	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	85275	
33056	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	85275	
33057	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
33058	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
33059	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
33060	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
33061	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
33062	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	762	
33063	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
33064	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
33065	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
33066	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
33067	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	9	
33068	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
33069	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
33070	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
33071	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	360.0	
33072	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	370.0	
33073	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	360.0	
33074	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
33075	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33076	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33077	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33078	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33079	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33080	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33081	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33082	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33083	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33084	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
33085	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
33086	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
33087	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33088	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33089	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33090	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33091	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33092	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33093	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33094	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
33095	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33096	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
33097	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
33098	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33099	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
33100	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33101	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33102	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
33103	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
33104	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33105	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	13370.40	kw
33106	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33107	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
33108	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	35	°C
33109	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	35	°C
33110	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33111	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33112	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33113	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33114	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
33115	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33116	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33117	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
33118	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.7428	
33119	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	35	°C
33120	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	25	°C
33121	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
33122	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
33123	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
33124	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33125	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33126	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33127	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33128	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33129	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33130	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33131	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33132	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
33133	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
33134	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33135	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
33136	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33137	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33138	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
33139	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
33140	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
33141	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	500.0	
33142	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	490.0	
33143	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
33144	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
33145	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
33146	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	C80263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
33147	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
33148	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
33149	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
33150	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
33151	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33152	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
33153	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
33154	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
33155	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
33156	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
33157	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99996	
33158	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99996	
33159	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
33160	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
33161	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33162	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
33163	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33164	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
33165	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
33166	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
33167	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
33168	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
33169	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
33170	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	14057	
33171	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	14059	
33172	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
33173	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	4L	
33174	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	7R	
33175	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	11L	
33176	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	574	
33177	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Not Good Replaced	check oil cup
33178	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
33179	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
33180	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
33181	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
33182	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
33183	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
33184	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
33185	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
33186	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33187	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
33188	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
33189	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
33190	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
33191	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
33192	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
33193	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
33194	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
33195	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
33196	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33197	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33198	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
33199	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	There is an old oil leak on the top of a few radiators. Oil is barely seeping.	
33200	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33201	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33202	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
33203	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
33204	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
33205	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33206	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33207	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33208	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33209	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
33210	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33211	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33212	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
33213	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
33214	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
33215	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
33216	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
33217	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
33218	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
33219	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
33220	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
33221	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
33222	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
33223	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	511	
33224	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	511	
33225	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
33226	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
33227	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33228	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
33229	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33230	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
33231	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
33232	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
33233	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
33234	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
33235	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
33236	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
33237	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33238	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
33239	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	370.0	
33240	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	380.0	
33241	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
33242	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
33243	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
33244	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
33245	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
33246	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
33247	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
33248	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
33249	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
33250	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
33251	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
33252	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
33253	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
33254	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33255	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
33256	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
33257	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
33258	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
33259	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
33260	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
33261	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
33262	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33263	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
33264	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	not on site	
33265	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	not on site	
33266	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
33267	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
33268	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
33269	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
33270	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
33271	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
33272	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
33273	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33274	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	2454.00	kw
33275	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33276	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
33277	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	55	°C
33278	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	40	°C
33279	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33280	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33281	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33282	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33283	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
33284	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33285	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
33286	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33287	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33288	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33289	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33290	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33291	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33292	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33293	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
33294	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33295	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33296	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
33297	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.4090	
33298	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
33299	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
33300	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
33301	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
33302	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33303	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	38	
33304	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	38	
33305	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
33306	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
33307	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
33308	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
33309	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
33310	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
33311	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
33312	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
33313	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
33314	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33315	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33316	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33317	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33318	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33319	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33320	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
33321	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
33322	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
33323	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
33324	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	264	
33325	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	0	
33326	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	0	
33327	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
33328	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
33329	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
33330	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
33331	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
33332	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
33333	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
33334	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33335	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
33336	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
33337	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
33338	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
33339	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
33340	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
33341	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
33342	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33343	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
33344	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
33345	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
33346	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
33347	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
33348	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	General Comments		
33349	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
33350	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
33351	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
33352	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
33353	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
33354	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
33355	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
33356	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	General Comments		
33357	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33358	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33359	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33360	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33361	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33362	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33363	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
33364	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
33365	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
33366	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
33367	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
33368	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
33369	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
33370	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
33371	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
33372	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
33373	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
33374	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
33375	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
33376	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33377	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
33378	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
33379	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
33380	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
33381	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
33382	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
33383	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
33384	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
33385	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
33386	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
33387	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
33388	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
33389	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
33390	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
33391	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
33392	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
33393	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
33394	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
33395	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	3.7	VDC
33396	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	3.5	VDC
33397	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
33398	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33399	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
33400	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
33401	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
33402	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
33403	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
33404	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
33405	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
33406	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
33407	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
33408	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
33409	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
33410	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
33411	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
33412	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
33413	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
33414	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
33415	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
33416	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
33417	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
33418	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
33419	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
33420	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
33421	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
33422	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
33423	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
33424	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
33425	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99946	
33426	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99946	
33427	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
33428	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
33429	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
33430	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
33431	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
33432	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
33433	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
33434	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
33435	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
33436	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
33437	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
33438	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
33439	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
33440	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33441	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
33442	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
33443	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
33444	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
33445	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
33446	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
33447	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
33448	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
33449	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
33450	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
33451	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33452	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
33453	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
33454	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
33455	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33456	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33457	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33458	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33459	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33460	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33461	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33462	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33463	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
33464	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	510.0	
33465	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
33466	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	LTC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
33467	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
33468	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
33469	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
33470	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
33471	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
33472	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	General Comments		
33473	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
33474	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
33475	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
33476	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33477	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
33478	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
33479	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	576	
33480	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	576	
33481	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
33482	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
33483	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
33484	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33485	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33486	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33487	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
33488	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
33489	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
33490	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33491	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
33492	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33493	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33494	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33495	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
33496	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
33497	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
33498	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
33499	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
33500	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
33501	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
33502	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
33503	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
33504	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
33505	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
33506	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
33507	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
33508	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
33509	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
33510	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
33511	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
33512	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
33513	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
33514	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
33515	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
33516	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
33517	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
33518	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
33519	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33520	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33521	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33522	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
33523	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
33524	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33525	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
33526	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33527	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
33528	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
33529	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
33530	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
33531	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
33532	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
33533	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	15	°C
33534	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33535	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
33536	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33537	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33538	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
33539	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
33540	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
33541	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
33542	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
33543	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
33544	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
33545	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33546	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33547	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33548	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33549	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
33550	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
33551	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
33552	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
33553	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
33554	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33555	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33556	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
33557	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33558	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
33559	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
33560	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
33561	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
33562	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
33563	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33564	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33565	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33566	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
33567	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
33568	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
33569	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33570	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
33571	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33572	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33573	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
33574	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
33575	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
33576	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
33577	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
33578	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
33579	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
33580	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
33581	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
33582	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
33583	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
33584	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
33585	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
33586	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
33587	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
33588	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
33589	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
33590	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
33591	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33592	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33593	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33594	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33595	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
33596	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
33597	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33598	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
33599	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
33600	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
33601	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33602	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
33603	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	296.16	kw
33604	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
33605	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33606	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
33607	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
33608	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33609	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
33610	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33611	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33612	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33613	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
33614	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	41	°C
33615	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
33616	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33617	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
33618	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33619	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33620	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
33621	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
33622	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33623	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
33624	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3702	
33625	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
33626	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33627	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
33628	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
33629	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
33630	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
33631	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
33632	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
33633	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
33634	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33635	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33636	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33637	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
33638	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
33639	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
33640	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	272	
33641	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	272	
33642	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
33643	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33644	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33645	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
33646	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
33647	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33648	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
33649	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
33650	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
33651	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
33652	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
33653	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
33654	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
33655	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
33656	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
33657	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
33658	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
33659	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
33660	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
33661	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
33662	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
33663	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
33664	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
33665	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments	Voltmeter reading is 55.8 with temp compensator	
33666	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
33667	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
33668	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
33669	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
33670	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
33671	12/6/2019 11:10	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
33672	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
33673	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
33674	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
33675	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
33676	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33677	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
33678	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
33679	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
33680	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
33681	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33682	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33683	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
33684	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
33685	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
33686	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33687	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33688	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
33689	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
33690	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
33691	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
33692	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
33693	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
33694	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33695	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33696	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33697	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33698	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33699	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
33700	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33701	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33702	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33703	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33704	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
33705	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
33706	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33707	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33708	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
33709	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33710	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
33711	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
33712	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33713	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
33714	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33715	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33716	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33717	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
33718	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33719	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
33720	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
33721	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
33722	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
33723	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
33724	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
33725	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
33726	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
33727	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
33728	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33729	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
33730	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33731	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33732	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
33733	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
33734	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
33735	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
33736	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
33737	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
33738	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
33739	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
33740	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
33741	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
33742	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
33743	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
33744	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
33745	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
33746	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
33747	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
33748	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33749	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
33750	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	158	
33751	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	158	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33752	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
33753	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
33754	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
33755	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
33756	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
33757	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
33758	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
33759	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
33760	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
33761	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
33762	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
33763	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
33764	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33765	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33766	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33767	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33768	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33769	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
33770	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33771	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33772	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
33773	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
33774	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
33775	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33776	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
33777	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
33778	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
33779	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
33780	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
33781	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
33782	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
33783	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
33784	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
33785	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
33786	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
33787	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
33788	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
33789	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
33790	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
33791	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
33792	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
33793	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
33794	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
33795	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
33796	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
33797	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
33798	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
33799	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
33800	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
33801	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
33802	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33803	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
33804	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
33805	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
33806	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
33807	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
33808	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
33809	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
33810	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
33811	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
33812	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
33813	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
33814	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
33815	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
33816	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
33817	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
33818	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
33819	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
33820	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
33821	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
33822	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
33823	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
33824	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
33825	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
33826	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33827	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
33828	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
33829	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
33830	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
33831	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
33832	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
33833	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
33834	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
33835	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
33836	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
33837	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	General Comments		
33838	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
33839	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
33840	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
33841	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
33842	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
33843	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33844	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	43	*C
33845	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	60	*C
33846	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
33847	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33848	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	8269.92	kw
33849	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33850	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
33851	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
33852	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33853	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33854	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
33855	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
33856	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
33857	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
33858	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
33859	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
33860	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
33861	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
33862	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
33863	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
33864	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
33865	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
33866	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
33867	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
33868	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	*C
33869	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	*C
33870	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
33871	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
33872	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33873	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33874	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
33875	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33876	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33877	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33878	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
33879	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	*C
33880	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	*C
33881	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
33882	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
33883	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
33884	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
33885	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
33886	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
33887	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
33888	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
33889	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
33890	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
33891	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
33892	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
33893	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
33894	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
33895	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
33896	12/6/2019 11:50	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
33897	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
33898	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
33899	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
33900	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
33901	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
33902	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
33903	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
33904	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33905	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33906	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33907	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
33908	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
33909	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
33910	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
33911	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
33912	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
33913	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
33914	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
33915	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
33916	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
33917	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
33918	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
33919	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
33920	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	148	
33921	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	148	
33922	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
33923	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
33924	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
33925	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
33926	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
33927	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
33928	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
33929	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
33930	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
33931	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
33932	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
33933	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	LTC000502	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
33934	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
33935	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
33936	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	LTC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
33937	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
33938	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33939	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33940	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33941	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
33942	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
33943	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	11486	
33944	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
33945	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
33946	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
33947	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
33948	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
33949	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
33950	12/6/2019 15:01	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
33951	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
33952	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	125105	
33953	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	125105	
33954	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
33955	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
33956	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
33957	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
33958	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	264	
33959	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
33960	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
33961	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
33962	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
33963	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
33964	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
33965	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
33966	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
33967	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
33968	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
33969	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
33970	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
33971	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
33972	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
33973	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
33974	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	166	
33975	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	166	
33976	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
33977	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
33978	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
33979	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
33980	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
33981	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
33982	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
33983	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
33984	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
33985	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
33986	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
33987	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
33988	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
33989	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
33990	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
33991	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
33992	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
33993	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
33994	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	General Comments		
33995	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
33996	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	LTC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
33997	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
33998	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	438.0	
33999	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	436.0	
34000	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	536.0	
34001	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
34002	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
34003	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
34004	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
34005	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
34006	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
34007	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
34008	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
34009	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
34010	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
34011	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
34012	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
34013	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
34014	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
34015	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
34016	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34017	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
34018	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
34019	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
34020	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.2	amps
34021	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
34022	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
34023	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
34024	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34025	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34026	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34027	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34028	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34029	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
34030	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
34031	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
34032	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
34033	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
34034	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
34035	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
34036	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
34037	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
34038	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
34039	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
34040	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
34041	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
34042	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
34043	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	1440	
34044	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	*C
34045	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	*C
34046	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
34047	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
34048	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	11L	
34049	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
34050	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	6L	
34051	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34052	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
34053	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
34054	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
34055	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
34056	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
34057	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
34058	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
34059	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
34060	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
34061	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
34062	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
34063	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
34064	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
34065	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
34066	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
34067	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
34068	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
34069	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
34070	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
34071	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
34072	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
34073	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
34074	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
34075	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
34076	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
34077	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
34078	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
34079	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
34080	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
34081	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
34082	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
34083	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
34084	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
34085	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
34086	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
34087	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
34088	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
34089	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
34090	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
34091	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	General Comments		
34092	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
34093	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000714	LTCCControl	611-2	LTC Control Insp	All Connections OK?	y	
34094	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
34095	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
34096	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
34097	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	LTC Output Voltage Level	1236.0	VAC
34098	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
34099	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	General Comments		
34100	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTC0000713	LTCCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
34101	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34102	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34103	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34104	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	1	
34105	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
34106	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
34107	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
34108	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
34109	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
34110	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
34111	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTC0000114	LTCCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
34112	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	LTC0000114	LTCCControl	PL-TRANS 1	LTC Control Insp	General Comments	?	
34113	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
34114	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
34115	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
34116	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
34117	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
34118	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
34119	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34120	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34121	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34122	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34123	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34124	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34125	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34126	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34127	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34128	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
34129	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	478.0	
34130	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	490.0	
34131	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	480.0	
34132	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34133	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34134	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34135	12/6/2019 11:55	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	2	
34136	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
34137	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
34138	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
34139	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
34140	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
34141	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
34142	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
34143	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
34144	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
34145	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
34146	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
34147	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
34148	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
34149	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
34150	12/6/2019 15:15	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
34151	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
34152	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
34153	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
34154	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
34155	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
34156	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
34157	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
34158	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
34159	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
34160	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
34161	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
34162	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
34163	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
34164	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
34165	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
34166	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
34167	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
34168	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
34169	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
34170	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
34171	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
34172	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
34173	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
34174	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
34175	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
34176	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
34177	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
34178	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
34179	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
34180	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
34181	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34182	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34183	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
34184	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
34185	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	64	°C
34186	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	28	°C
34187	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
34188	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
34189	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
34190	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
34191	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
34192	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
34193	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
34194	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
34195	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
34196	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
34197	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
34198	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
34199	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
34200	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
34201	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
34202	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
34203	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34204	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34205	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
34206	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitro cyl at 100 psi needs to be filled.	
34207	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34208	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34209	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
34210	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
34211	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	64	*C
34212	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	*C
34213	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
34214	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
34215	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
34216	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
34217	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
34218	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
34219	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
34220	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
34221	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
34222	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
34223	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
34224	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
34225	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
34226	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
34227	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
34228	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
34229	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
34230	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
34231	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
34232	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
34233	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
34234	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
34235	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
34236	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
34237	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34238	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34239	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34240	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
34241	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
34242	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
34243	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
34244	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
34245	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
34246	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
34247	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
34248	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
34249	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
34250	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
34251	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
34252	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
34253	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
34254	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
34255	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
34256	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	234	
34257	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	234	
34258	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
34259	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
34260	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
34261	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
34262	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
34263	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
34264	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
34265	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
34266	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
34267	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
34268	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	n	
34269	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
34270	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
34271	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
34272	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
34273	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
34274	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
34275	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
34276	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	no door alarms	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34277	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
34278	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
34279	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
34280	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
34281	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
34282	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
34283	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
34284	12/6/2019 11:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
34285	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
34286	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
34287	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
34288	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
34289	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
34290	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
34291	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
34292	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
34293	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
34294	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
34295	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
34296	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
34297	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
34298	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
34299	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
34300	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
34301	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
34302	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
34303	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
34304	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
34305	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
34306	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
34307	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
34308	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
34309	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
34310	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
34311	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
34312	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
34313	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
34314	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
34315	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
34316	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
34317	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
34318	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
34319	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
34320	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
34321	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
34322	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
34323	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
34324	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
34325	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
34326	12/6/2019 10:43	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
34327	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
34328	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34329	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34330	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34331	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	29.0	
34332	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	28.0	
34333	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	29.0	
34334	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
34335	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34336	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34337	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34338	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34339	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34340	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34341	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34342	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34343	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34344	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
34345	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
34346	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
34347	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
34348	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
34349	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
34350	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
34351	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
34352	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
34353	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
34354	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	64	°C
34355	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	35	°C
34356	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34357	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34358	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34359	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
34360	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
34361	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34362	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34363	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
34364	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	1.1976	
34365	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
34366	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
34367	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
34368	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
34369	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34370	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34371	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
34372	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34373	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
34374	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
34375	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34376	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34377	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34378	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34379	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34380	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
34381	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
34382	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
34383	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
34384	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34385	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34386	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34387	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34388	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34389	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34390	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34391	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
34392	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34393	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34394	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
34395	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
34396	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
34397	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34398	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
34399	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
34400	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34401	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34402	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	29.0	
34403	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	28.0	
34404	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	29.0	
34405	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
34406	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
34407	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
34408	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
34409	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
34410	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
34411	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
34412	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
34413	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
34414	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
34415	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	167	
34416	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34417	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	7044.48	kw
34418	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34419	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
34420	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
34421	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34422	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	167	
34423	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
34424	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
34425	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
34426	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	34	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34427	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	34	°C
34428	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34429	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34430	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34431	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
34432	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34433	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34434	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
34435	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.7338	
34436	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34437	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
34438	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34439	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34440	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34441	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34442	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34443	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
34444	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
34445	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34446	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
34447	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34448	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
34449	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
34450	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34451	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
34452	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
34453	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34454	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	8622.72	kw
34455	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34456	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
34457	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
34458	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
34459	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
34460	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
34461	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
34462	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
34463	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
34464	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
34465	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
34466	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
34467	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
34468	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
34469	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
34470	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34471	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
34472	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
34473	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
34474	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
34475	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
34476	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
34477	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
34478	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
34479	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
34480	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
34481	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34482	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	2	
34483	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
34484	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34485	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
34486	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
34487	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34488	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	102.0	
34489	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	101.0	
34490	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	97.0	
34491	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
34492	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
34493	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments	Breaker 234,235 the foundation is crumbling.	
34494	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
34495	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
34496	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
34497	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	0	
34498	12/6/2019 11:04	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
34499	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
34500	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
34501	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34502	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
34503	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
34504	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
34505	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
34506	12/6/2019 12:44	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
34507	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
34508	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
34509	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
34510	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
34511	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
34512	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
34513	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34514	12/6/2019 15:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34515	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34516	12/9/2019 10:48	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34517	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
34518	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
34519	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
34520	12/6/2019 13:00	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
34521	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
34522	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
34523	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
34524	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
34525	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
34526	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
34527	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
34528	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34529	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34530	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34531	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
34532	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
34533	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	65.0	
34534	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34535	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34536	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34537	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
34538	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
34539	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
34540	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
34541	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
34542	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
34543	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
34544	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
34545	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	218	
34546	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	218	
34547	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
34548	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
34549	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
34550	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34551	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34552	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34553	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34554	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34555	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34556	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
34557	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
34558	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
34559	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
34560	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
34561	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
34562	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
34563	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
34564	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
34565	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
34566	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34567	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34568	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
34569	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
34570	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34571	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34572	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34573	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34574	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
34575	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
34576	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34577	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6800	
34578	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
34579	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34580	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34581	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
34582	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
34583	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
34584	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34585	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34586	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
34587	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
34588	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34589	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34590	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
34591	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34592	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34593	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
34594	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
34595	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
34596	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
34597	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6528.00	kw
34598	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
34599	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34600	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34601	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
34602	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34603	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
34604	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
34605	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
34606	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
34607	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
34608	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
34609	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
34610	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
34611	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
34612	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34613	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34614	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34615	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
34616	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
34617	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	0	
34618	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	0	
34619	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	249	
34620	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34621	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
34622	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
34623	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
34624	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
34625	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	249	
34626	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
34627	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
34628	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
34629	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
34630	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Heaters (All) Functioning?	y	
34631	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
34632	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
34633	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
34634	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
34635	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
34636	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
34637	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
34638	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
34639	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
34640	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
34641	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
34642	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
34643	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
34644	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
34645	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
34646	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
34647	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
34648	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
34649	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
34650	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34651	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34652	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34653	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34654	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34655	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34656	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34657	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
34658	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
34659	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
34660	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34661	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
34662	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
34663	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
34664	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
34665	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34666	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
34667	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
34668	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34669	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
34670	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
34671	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
34672	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
34673	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
34674	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
34675	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
34676	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
34677	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34678	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34679	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
34680	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
34681	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
34682	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
34683	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
34684	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
34685	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
34686	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
34687	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
34688	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
34689	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
34690	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
34691	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
34692	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
34693	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
34694	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34695	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34696	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34697	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
34698	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
34699	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
34700	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
34701	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
34702	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
34703	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34704	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34705	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
34706	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34707	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34708	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34709	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34710	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
34711	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
34712	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
34713	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
34714	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
34715	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
34716	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
34717	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
34718	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
34719	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
34720	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
34721	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
34722	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
34723	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
34724	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	64035	
34725	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
34726	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34727	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
34728	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
34729	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	83559	
34730	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	83562	
34731	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
34732	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	7L	
34733	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	2L	
34734	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	10L	
34735	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	650	
34736	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
34737	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
34738	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
34739	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	243	
34740	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	243	
34741	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
34742	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
34743	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
34744	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
34745	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
34746	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
34747	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
34748	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
34749	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
34750	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34751	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
34752	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
34753	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
34754	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
34755	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
34756	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
34757	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
34758	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
34759	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
34760	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
34761	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
34762	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
34763	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
34764	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
34765	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
34766	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
34767	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
34768	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
34769	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
34770	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
34771	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	6	
34772	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34773	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
34774	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	25	°C
34775	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
34776	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
34777	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
34778	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
34779	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34780	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34781	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34782	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
34783	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
34784	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
34785	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
34786	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
34787	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
34788	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
34789	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
34790	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
34791	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
34792	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
34793	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
34794	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
34795	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	179	
34796	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	179	
34797	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
34798	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
34799	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
34800	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34801	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34802	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
34803	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34804	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34805	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34806	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
34807	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
34808	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
34809	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
34810	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
34811	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	302	
34812	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	302	
34813	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
34814	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
34815	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
34816	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
34817	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B80265	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
34818	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
34819	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
34820	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
34821	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
34822	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
34823	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
34824	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
34825	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
34826	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
34827	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
34828	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34829	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34830	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34831	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34832	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34833	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34834	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34835	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
34836	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34837	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
34838	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
34839	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
34840	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
34841	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
34842	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
34843	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
34844	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
34845	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
34846	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
34847	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
34848	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
34849	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	General Comments		
34850	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
34851	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
34852	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
34853	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	48	*F
34854	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
34855	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
34856	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34857	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34858	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
34859	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34860	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34861	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34862	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
34863	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
34864	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	265317	
34865	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	265317	
34866	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
34867	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9R	
34868	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15R	
34869	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6R	
34870	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
34871	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	136	
34872	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
34873	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
34874	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
34875	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
34876	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34877	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
34878	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
34879	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
34880	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
34881	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34882	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34883	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
34884	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	46222	
34885	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	46222	
34886	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
34887	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
34888	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
34889	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	16L	
34890	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
34891	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	461	
34892	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
34893	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
34894	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
34895	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
34896	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
34897	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
34898	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
34899	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
34900	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	5	
34901	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
34902	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
34903	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
34904	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	30	°C
34905	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	60	°C
34906	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	30	°C
34907	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	60	°C
34908	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	30	°C
34909	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	60	°C
34910	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
34911	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
34912	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
34913	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	50	°C
34914	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
34915	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
34916	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
34917	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
34918	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
34919	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
34920	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
34921	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
34922	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
34923	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	20	°C
34924	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
34925	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
34926	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
34927	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
34928	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments		
34929	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments		
34930	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
34931	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
34932	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	n	
34933	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
34934	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
34935	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
34936	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
34937	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
34938	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
34939	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
34940	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
34941	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
34942	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
34943	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
34944	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
34945	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
34946	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
34947	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
34948	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
34949	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
34950	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
34951	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
34952	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
34953	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
34954	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
34955	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
34956	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
34957	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
34958	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
34959	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
34960	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
34961	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
34962	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	0	
34963	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
34964	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
34965	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
34966	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
34967	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
34968	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
34969	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
34970	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
34971	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
34972	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
34973	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	0	
34974	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	251	
34975	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	251	
34976	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
34977	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
34978	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
34979	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
34980	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
34981	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
34982	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
34983	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
34984	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
34985	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
34986	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37433	
34987	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
34988	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
34989	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
34990	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
34991	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
34992	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
34993	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
34994	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
34995	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
34996	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
34997	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
34998	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
34999	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
35000	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
35001	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
35002	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
35003	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
35004	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
35005	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
35006	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35007	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35008	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	60.0	
35009	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	60.0	
35010	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	30.0	
35011	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
35012	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35013	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35014	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35015	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35016	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35017	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35018	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35019	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35020	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35021	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
35022	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
35023	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
35024	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
35025	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
35026	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35027	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
35028	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
35029	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
35030	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
35031	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
35032	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
35033	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
35034	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	7332.48	kw
35035	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
35036	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
35037	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
35038	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	207	
35039	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	207	
35040	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
35041	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
35042	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	36	°C
35043	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	33	°C
35044	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
35045	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
35046	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
35047	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
35048	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
35049	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
35050	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35051	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
35052	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.7638	
35053	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
35054	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
35055	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
35056	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
35057	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
35058	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
35059	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
35060	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
35061	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments	Replaced SPR bulb.	
35062	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
35063	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
35064	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
35065	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
35066	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
35067	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
35068	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
35069	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
35070	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
35071	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
35072	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
35073	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
35074	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
35075	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35076	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
35077	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0806	
35078	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
35079	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
35080	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
35081	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
35082	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
35083	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
35084	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
35085	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
35086	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
35087	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
35088	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
35089	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
35090	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
35091	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
35092	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
35093	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
35094	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1047.60	kw
35095	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
35096	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
35097	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	31	°C
35098	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
35099	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
35100	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
35101	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35102	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
35103	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
35104	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
35105	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
35106	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
35107	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
35108	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
35109	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
35110	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
35111	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		
35112	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
35113	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
35114	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
35115	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
35116	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
35117	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
35118	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
35119	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
35120	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
35121	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
35122	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
35123	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	185003	
35124	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
35125	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
35126	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
35127	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
35128	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
35129	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
35130	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
35131	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
35132	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	185003	
35133	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
35134	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
35135	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	1R	
35136	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
35137	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	638	
35138	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
35139	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
35140	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
35141	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
35142	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
35143	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35144	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
35145	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
35146	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
35147	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
35148	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
35149	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
35150	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
35151	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
35152	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
35153	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
35154	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
35155	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
35156	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
35157	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
35158	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
35159	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1728.96	kw
35160	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
35161	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
35162	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35163	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
35164	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
35165	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
35166	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
35167	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
35168	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
35169	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
35170	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
35171	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
35172	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
35173	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
35174	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
35175	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
35176	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35177	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
35178	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
35179	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
35180	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
35181	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
35182	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
35183	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
35184	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
35185	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
35186	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
35187	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
35188	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35189	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35190	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
35191	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
35192	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
35193	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
35194	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
35195	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
35196	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
35197	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
35198	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
35199	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
35200	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
35201	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	102	
35202	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
35203	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
35204	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	
35205	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
35206	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
35207	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
35208	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
35209	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
35210	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35211	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
35212	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8730	
35213	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
35214	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
35215	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
35216	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
35217	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
35218	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
35219	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
35220	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
35221	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
35222	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
35223	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
35224	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
35225	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
35226	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35227	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35228	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35229	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
35230	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
35231	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	OO173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
35232	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	445.0	
35233	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	465.0	
35234	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	490.0	
35235	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
35236	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35237	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35238	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35239	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
35240	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	82.0	
35241	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35242	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35243	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35244	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66348	
35245	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
35246	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
35247	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
35248	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
35249	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
35250	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
35251	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
35252	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35253	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35254	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35255	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
35256	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
35257	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	51.0	
35258	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	52.0	
35259	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35260	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35261	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35262	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	4	
35263	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
35264	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
35265	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
35266	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
35267	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
35268	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35269	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
35270	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
35271	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	cube heater bad.	
35272	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35273	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
35274	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
35275	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
35276	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
35277	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
35278	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
35279	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
35280	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
35281	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
35282	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
35283	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
35284	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
35285	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
35286	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
35287	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
35288	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
35289	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35290	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
35291	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35292	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
35293	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	4	
35294	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35295	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35296	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35297	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	183.0	
35298	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	186.0	
35299	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	142.0	
35300	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
35301	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35302	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35303	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35304	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35305	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35306	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35307	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35308	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35309	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35310	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
35311	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
35312	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	0	
35313	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
35314	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
35315	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
35316	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
35317	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
35318	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
35319	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
35320	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35321	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
35322	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
35323	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	177	
35324	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	177	
35325	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	0	
35326	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35327	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
35328	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
35329	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	10	
35330	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
35331	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
35332	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
35333	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35334	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
35335	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
35336	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	375	
35337	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	375	
35338	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	0	
35339	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
35340	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	0	
35341	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
35342	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
35343	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
35344	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
35345	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
35346	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
35347	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
35348	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
35349	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
35350	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
35351	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35352	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
35353	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
35354	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
35355	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
35356	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
35357	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
35358	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
35359	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
35360	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
35361	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
35362	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
35363	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
35364	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
35365	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
35366	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
35367	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
35368	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
35369	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
35370	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
35371	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
35372	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
35373	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
35374	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
35375	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
35376	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
35377	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
35378	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
35379	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
35380	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
35381	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
35382	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
35383	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
35384	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
35385	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
35386	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
35387	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
35388	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
35389	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
35390	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
35391	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
35392	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
35393	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
35394	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
35395	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
35396	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitro 6 pack at 0	
35397	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
35398	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	60	°C
35399	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
35400	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
35401	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35402	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
35403	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
35404	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
35405	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
35406	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
35407	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
35408	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
35409	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
35410	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35411	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
35412	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
35413	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35414	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
35415	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35416	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
35417	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
35418	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
35419	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
35420	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
35421	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
35422	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
35423	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
35424	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
35425	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
35426	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
35427	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35428	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
35429	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
35430	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	188	
35431	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	188	
35432	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	1	
35433	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	0	
35434	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
35435	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
35436	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	3	
35437	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35438	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35439	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35440	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	154.0	
35441	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	134.0	
35442	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	136.0	
35443	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
35444	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35445	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35446	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35447	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35448	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35449	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35450	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35451	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35452	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35453	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
35454	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
35455	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
35456	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
35457	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
35458	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
35459	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
35460	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
35461	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
35462	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
35463	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35464	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
35465	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
35466	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	165	
35467	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	165	
35468	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	0	
35469	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	0	
35470	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
35471	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
35472	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
35473	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
35474	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
35475	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
35476	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35477	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
35478	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
35479	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
35480	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
35481	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
35482	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
35483	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
35484	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
35485	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments	Vegetation needs to be cut back away from the fence.	
35486	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
35487	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
35488	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
35489	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
35490	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
35491	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
35492	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
35493	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000550	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
35494	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35495	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35496	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35497	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	128.0	
35498	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	127.0	
35499	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	91.0	
35500	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
35501	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35502	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35503	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35504	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35505	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35506	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35507	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
35508	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
35509	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
35510	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
35511	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
35512	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
35513	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
35514	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	72715	
35515	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35516	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
35517	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
35518	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
35519	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
35520	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35521	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35522	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35523	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35524	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	72715	
35525	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35526	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35527	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushing Condition	Good	
35528	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Tank Paint Condition	Good	
35529	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
35530	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	3L	
35531	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	2L	
35532	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	8L	
35533	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
35534	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Moisture and Leak Free?	y	
35535	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	713	
35536	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
35537	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
35538	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35539	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Grounds in Place?	y	
35540	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	General Comments		
35541	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Foundation Condition	Good	
35542	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Follow-up Action Required?	n	
35543	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35544	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35545	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35546	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35547	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35548	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35549	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushing Condition	Good	
35550	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
35551	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35552	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
35553	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35554	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	
35555	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
35556	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
35557	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
35558	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35559	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35560	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35561	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35562	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35563	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35564	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
35565	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35566	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
35567	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35568	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
35569	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	1	
35570	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35571	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35572	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
35573	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	175.0	
35574	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	175.0	
35575	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	175.0	
35576	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35577	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35578	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35579	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
35580	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
35581	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
35582	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
35583	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
35584	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
35585	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
35586	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
35587	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
35588	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
35589	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
35590	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
35591	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
35592	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
35593	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
35594	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
35595	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
35596	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
35597	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
35598	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
35599	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
35600	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
35601	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
35602	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
35603	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
35604	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
35605	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
35606	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
35607	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35608	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
35609	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
35610	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
35611	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
35612	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
35613	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
35614	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
35615	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
35616	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
35617	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
35618	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
35619	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
35620	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
35621	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
35622	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
35623	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
35624	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
35625	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
35626	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35627	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35628	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
35629	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
35630	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
35631	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
35632	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
35633	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
35634	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
35635	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
35636	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
35637	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
35638	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
35639	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
35640	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
35641	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
35642	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
35643	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
35644	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
35645	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
35646	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
35647	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
35648	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
35649	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
35650	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
35651	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
35652	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
35653	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
35654	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
35655	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
35656	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
35657	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
35658	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
35659	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
35660	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
35661	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
35662	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
35663	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
35664	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	618	
35665	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	618	
35666	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
35667	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
35668	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35669	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
35670	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
35671	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	B80269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
35672	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
35673	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
35674	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
35675	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
35676	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
35677	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
35678	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
35679	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
35680	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
35681	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
35682	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
35683	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
35684	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
35685	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
35686	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
35687	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
35688	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
35689	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
35690	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
35691	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	7979.04	kw
35692	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
35693	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
35694	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	35	*C
35695	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	35	*C
35696	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
35697	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
35698	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
35699	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
35700	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
35701	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35702	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35703	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
35704	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.1082	
35705	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
35706	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
35707	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
35708	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
35709	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
35710	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
35711	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
35712	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
35713	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
35714	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35715	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35716	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35717	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35718	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35719	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35720	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35721	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
35722	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
35723	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
35724	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
35725	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
35726	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
35727	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
35728	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
35729	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
35730	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
35731	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
35732	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
35733	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
35734	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
35735	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
35736	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
35737	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
35738	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
35739	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
35740	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
35741	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
35742	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
35743	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
35744	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8888	
35745	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
35746	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
35747	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
35748	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
35749	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
35750	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
35751	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
35752	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
35753	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
35754	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
35755	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
35756	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
35757	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
35758	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
35759	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
35760	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
35761	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
35762	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
35763	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
35764	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
35765	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
35766	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
35767	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
35768	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	3	
35769	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35770	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35771	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35772	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
35773	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
35774	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
35775	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
35776	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35777	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35778	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2021	
35779	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
35780	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35781	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35782	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35783	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35784	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35785	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35786	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
35787	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
35788	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
35789	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
35790	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
35791	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
35792	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
35793	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
35794	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
35795	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
35796	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
35797	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
35798	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
35799	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
35800	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
35801	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
35802	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	168	
35803	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	168	
35804	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
35805	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
35806	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35807	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
35808	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
35809	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
35810	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
35811	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
35812	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
35813	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
35814	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
35815	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
35816	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
35817	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35818	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35819	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35820	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35821	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35822	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35823	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35824	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35825	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35826	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
35827	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	315.0	
35828	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	300.0	
35829	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	300.0	
35830	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35831	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35832	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35833	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
35834	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
35835	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35836	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35837	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
35838	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
35839	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
35840	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
35841	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
35842	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
35843	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
35844	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
35845	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
35846	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
35847	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
35848	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
35849	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
35850	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
35851	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
35852	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
35853	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
35854	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
35855	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
35856	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
35857	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
35858	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
35859	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
35860	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
35861	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
35862	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
35863	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
35864	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
35865	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
35866	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
35867	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
35868	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
35869	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
35870	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
35871	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	LTC0000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
35872	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
35873	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
35874	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
35875	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
35876	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
35877	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
35878	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
35879	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
35880	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
35881	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
35882	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
35883	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
35884	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
35885	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
35886	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
35887	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
35888	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
35889	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
35890	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
35891	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
35892	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	34	°C
35893	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	80	°C
35894	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
35895	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	80	°C
35896	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	5	
35897	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35898	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35899	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35900	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	240.0	
35901	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	240.0	
35902	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	240.0	
35903	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
35904	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35905	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
35906	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35907	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35908	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35909	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35910	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35911	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35912	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35913	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35914	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
35915	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
35916	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
35917	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
35918	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
35919	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
35920	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
35921	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
35922	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
35923	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
35924	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35925	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
35926	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
35927	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	198	
35928	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	198	
35929	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	0	
35930	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
35931	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	0	
35932	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
35933	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
35934	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	2	
35935	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35936	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35937	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35938	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	20.0	
35939	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	20.0	
35940	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	25.0	
35941	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	5	
35942	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35943	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35944	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35945	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	30.0	
35946	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	30.0	
35947	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	0	
35948	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	284	
35949	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	284	
35950	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
35951	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
35952	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
35953	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
35954	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
35955	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
35956	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
35957	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
35958	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
35959	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
35960	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
35961	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
35962	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
35963	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
35964	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
35965	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
35966	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
35967	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
35968	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
35969	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
35970	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
35971	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
35972	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
35973	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	390.0	
35974	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	375.0	
35975	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	345.0	
35976	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
35977	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
35978	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
35979	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	4	
35980	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
35981	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
35982	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
35983	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
35984	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
35985	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
35986	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
35987	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
35988	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
35989	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
35990	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
35991	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
35992	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
35993	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
35994	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
35995	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
35996	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
35997	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
35998	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
35999	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
36000	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	42.0	
36001	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36002	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	40.0	
36003	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
36004	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
36005	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
36006	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	793	
36007	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
36008	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
36009	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
36010	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
36011	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
36012	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
36013	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
36014	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
36015	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
36016	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
36017	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
36018	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
36019	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
36020	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
36021	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
36022	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
36023	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
36024	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
36025	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
36026	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
36027	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
36028	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
36029	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
36030	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
36031	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
36032	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
36033	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
36034	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
36035	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
36036	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
36037	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
36038	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
36039	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36040	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36041	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
36042	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
36043	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
36044	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
36045	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
36046	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
36047	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
36048	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
36049	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
36050	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
36051	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
36052	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
36053	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
36054	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
36055	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
36056	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
36057	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	255	
36058	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	255	
36059	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	0	
36060	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36061	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
36062	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
36063	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
36064	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
36065	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
36066	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	*C
36067	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36068	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	0	
36069	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
36070	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
36071	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
36072	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
36073	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
36074	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
36075	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
36076	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	8L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36077	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
36078	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
36079	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
36080	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
36081	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
36082	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
36083	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
36084	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
36085	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
36086	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
36087	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
36088	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
36089	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
36090	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64705	
36091	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
36092	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
36093	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
36094	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
36095	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
36096	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
36097	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
36098	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	60.0	
36099	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
36100	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36101	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36102	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36103	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36104	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36105	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36106	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36107	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36108	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36109	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
36110	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
36111	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
36112	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
36113	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
36114	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
36115	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
36116	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
36117	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
36118	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
36119	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
36120	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
36121	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
36122	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	282	
36123	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	292	
36124	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	0	
36125	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36126	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	0	
36127	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
36128	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
36129	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
36130	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36131	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36132	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36133	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36134	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
36135	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
36136	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.8292	
36137	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
36138	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
36139	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
36140	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
36141	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
36142	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
36143	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
36144	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36145	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	35	°C
36146	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	40	°C
36147	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
36148	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
36149	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	7960.32	
36150	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
36151	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
36152	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
36153	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
36154	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
36155	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
36156	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
36157	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
36158	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
36159	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36160	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
36161	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
36162	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
36163	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
36164	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36165	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
36166	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
36167	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
36168	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36169	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36170	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36171	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36172	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36173	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
36174	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
36175	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
36176	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
36177	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	General Comments		
36178	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
36179	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
36180	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
36181	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	179	
36182	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	179	
36183	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	5	
36184	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	5	
36185	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
36186	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
36187	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
36188	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
36189	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
36190	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
36191	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
36192	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
36193	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
36194	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
36195	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
36196	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
36197	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
36198	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
36199	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
36200	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
36201	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
36202	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
36203	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
36204	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
36205	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
36206	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
36207	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
36208	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
36209	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	30	*C
36210	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	35	*C
36211	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
36212	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
36213	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
36214	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
36215	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
36216	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
36217	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
36218	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
36219	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments	Cubicle heaters in bus pot/ station service fuses are bad in both Sec 3 & 4. The wiring is bad. Pictures have been sent to Kevin S. and D	
36220	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
36221	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	y	
36222	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
36223	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
36224	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
36225	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
36226	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36227	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
36228	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
36229	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
36230	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.6060	
36231	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
36232	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
36233	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
36234	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
36235	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
36236	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
36237	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
36238	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36239	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	30	°C
36240	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	40	°C
36241	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
36242	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
36243	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
36244	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	10908.00	kw
36245	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
36246	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
36247	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
36248	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
36249	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC000550	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
36250	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC000550	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
36251	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
36252	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
36253	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
36254	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
36255	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	1637	
36256	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	16L	
36257	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	4L	
36258	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	7L	
36259	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
36260	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	57533	
36261	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	57533	
36262	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
36263	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
36264	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
36265	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
36266	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
36267	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
36268	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
36269	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
36270	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
36271	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
36272	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	General Comments		
36273	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
36274	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
36275	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
36276	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
36277	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
36278	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	62	
36279	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.9	
36280	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.0	
36281	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.6	
36282	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	6	
36283	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
36284	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
36285	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	69	
36286	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
36287	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
36288	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
36289	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
36290	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
36291	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
36292	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
36293	12/5/2019 14:49	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
36294	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
36295	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence >'5' Clearance To Trees?	y	
36296	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
36297	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
36298	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
36299	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
36300	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
36301	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36302	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
36303	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
36304	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
36305	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
36306	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
36307	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
36308	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
36309	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	25	
36310	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36311	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36312	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36313	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
36314	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
36315	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
36316	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36317	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36318	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36319	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36320	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
36321	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
36322	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
36323	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
36324	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
36325	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
36326	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
36327	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
36328	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
36329	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
36330	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
36331	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
36332	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
36333	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
36334	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36335	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
36336	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
36337	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
36338	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
36339	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
36340	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
36341	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
36342	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
36343	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
36344	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
36345	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
36346	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
36347	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
36348	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
36349	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
36350	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
36351	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
36352	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
36353	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
36354	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
36355	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
36356	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
36357	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
36358	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
36359	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
36360	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
36361	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
36362	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
36363	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
36364	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
36365	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
36366	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
36367	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
36368	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
36369	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
36370	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
36371	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
36372	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
36373	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
36374	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
36375	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	50360	
36376	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	50360	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36377	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
36378	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
36379	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
36380	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
36381	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
36382	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
36383	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
36384	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
36385	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
36386	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
36387	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
36388	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
36389	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
36390	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
36391	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
36392	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
36393	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
36394	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
36395	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
36396	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
36397	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
36398	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
36399	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	0	
36400	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
36401	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
36402	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
36403	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
36404	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
36405	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36406	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
36407	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
36408	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
36409	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
36410	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
36411	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36412	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
36413	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
36414	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
36415	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
36416	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
36417	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
36418	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
36419	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
36420	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
36421	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
36422	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
36423	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
36424	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36425	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36426	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
36427	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
36428	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
36429	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
36430	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
36431	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
36432	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
36433	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
36434	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
36435	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
36436	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
36437	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
36438	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
36439	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
36440	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
36441	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
36442	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36443	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
36444	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
36445	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
36446	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
36447	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
36448	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36449	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
36450	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
36451	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36452	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
36453	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
36454	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
36455	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
36456	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
36457	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
36458	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
36459	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
36460	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
36461	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
36462	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
36463	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
36464	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
36465	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
36466	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
36467	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
36468	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
36469	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
36470	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
36471	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
36472	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
36473	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	nitro cylinder at 0	
36474	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
36475	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
36476	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36477	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36478	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36479	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36480	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36481	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36482	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
36483	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	133.0	
36484	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	75.0	
36485	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	100.0	
36486	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36487	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36488	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36489	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	8	
36490	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36491	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36492	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36493	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
36494	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36495	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
36496	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
36497	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36498	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36499	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
36500	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
36501	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
36502	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
36503	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
36504	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	190792	
36505	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	190792	
36506	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
36507	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	4L	
36508	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	2L	
36509	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	16L	
36510	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
36511	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
36512	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
36513	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
36514	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	930	
36515	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
36516	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
36517	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
36518	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
36519	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
36520	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36521	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36522	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	655	
36523	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	655	
36524	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	22	
36525	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
36526	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
36527	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
36528	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
36529	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
36530	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
36531	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
36532	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
36533	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
36534	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
36535	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
36536	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
36537	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
36538	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	90.0	
36539	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
36540	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
36541	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
36542	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
36543	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36544	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36545	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
36546	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
36547	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
36548	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
36549	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
36550	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
36551	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
36552	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
36553	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
36554	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
36555	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
36556	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36557	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
36558	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
36559	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
36560	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
36561	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
36562	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
36563	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36564	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
36565	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
36566	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	4	
36567	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36568	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	4	
36569	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	255	
36570	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36571	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
36572	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
36573	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
36574	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
36575	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
36576	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
36577	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
36578	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
36579	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36580	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36581	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
36582	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
36583	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
36584	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
36585	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36586	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	0	
36587	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36588	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36589	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36590	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36591	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36592	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36593	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	14	
36594	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
36595	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
36596	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36597	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36598	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36599	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
36600	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
36601	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36602	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
36603	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
36604	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
36605	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
36606	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
36607	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
36608	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
36609	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
36610	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
36611	12/5/2019 14:50	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	255	
36612	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	142	
36613	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
36614	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
36615	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
36616	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
36617	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
36618	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
36619	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
36620	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
36621	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments	Breaker open	
36622	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
36623	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
36624	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
36625	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
36626	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	332	
36627	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
36628	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
36629	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	7L	
36630	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	5L	
36631	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	5L	
36632	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
36633	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	37715	
36634	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	37715	
36635	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
36636	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
36637	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
36638	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
36639	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	27648	
36640	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
36641	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36642	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36643	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
36644	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
36645	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
36646	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
36647	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
36648	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
36649	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
36650	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
36651	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
36652	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	8780.40	kw
36653	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
36654	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
36655	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
36656	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
36657	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
36658	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
36659	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	30	°C
36660	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	30	°C
36661	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
36662	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
36663	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
36664	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
36665	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
36666	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
36667	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
36668	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
36669	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
36670	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
36671	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
36672	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.6942	
36673	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	240	
36674	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
36675	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
36676	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36677	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	240	
36678	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
36679	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36680	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
36681	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
36682	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36683	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	130.0	
36684	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	35	*C
36685	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	130.0	
36686	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	130.0	
36687	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36688	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
36689	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
36690	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
36691	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	35	*C
36692	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.4878	
36693	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
36694	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
36695	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
36696	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
36697	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
36698	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
36699	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
36700	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
36701	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
36702	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	142	
36703	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
36704	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
36705	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
36706	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
36707	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
36708	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
36709	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
36710	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
36711	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
36712	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
36713	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
36714	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36715	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
36716	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
36717	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
36718	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
36719	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
36720	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
36721	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
36722	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
36723	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
36724	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
36725	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
36726	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
36727	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
36728	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
36729	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
36730	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
36731	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
36732	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	General Comments		
36733	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
36734	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
36735	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
36736	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
36737	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
36738	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
36739	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
36740	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
36741	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
36742	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
36743	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
36744	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
36745	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
36746	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
36747	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
36748	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
36749	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
36750	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
36751	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36752	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
36753	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
36754	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
36755	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
36756	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36757	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36758	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
36759	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
36760	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	27648	
36761	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
36762	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	12L	
36763	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	7L	
36764	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
36765	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
36766	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
36767	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	647	
36768	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
36769	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
36770	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36771	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
36772	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
36773	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
36774	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
36775	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
36776	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36777	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36778	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
36779	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
36780	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36781	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36782	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
36783	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
36784	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
36785	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36786	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
36787	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	0	
36788	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
36789	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	75.0	
36790	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	75.0	
36791	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
36792	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
36793	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
36794	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	0	
36795	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
36796	12/4/2019 7:43	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
36797	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	75.0	
36798	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36799	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
36800	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
36801	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
36802	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	0.0	
36803	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
36804	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
36805	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
36806	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
36807	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
36808	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
36809	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36810	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
36811	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
36812	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
36813	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
36814	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
36815	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
36816	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
36817	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
36818	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
36819	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
36820	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
36821	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36822	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
36823	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
36824	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	6664.32	kw
36825	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
36826	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36827	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
36828	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
36829	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
36830	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
36831	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
36832	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
36833	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
36834	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	0	
36835	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36836	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	0	
36837	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	169	
36838	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	169	
36839	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
36840	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
36841	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
36842	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
36843	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
36844	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
36845	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
36846	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
36847	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
36848	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36849	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36850	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36851	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
36852	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
36853	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
36854	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
36855	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36856	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36857	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
36858	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
36859	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
36860	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
36861	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
36862	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
36863	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
36864	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
36865	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
36866	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36867	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36868	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36869	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
36870	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
36871	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
36872	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
36873	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
36874	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
36875	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
36876	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
36877	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
36878	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	481	
36879	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	481	
36880	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
36881	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
36882	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
36883	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	0	
36884	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
36885	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	0	
36886	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
36887	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
36888	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
36889	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
36890	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
36891	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
36892	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
36893	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
36894	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
36895	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
36896	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
36897	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36898	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
36899	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
36900	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
36901	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36902	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
36903	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
36904	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36905	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	3	
36906	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
36907	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
36908	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
36909	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
36910	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
36911	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
36912	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
36913	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
36914	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
36915	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
36916	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	295	
36917	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	295	
36918	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	0	
36919	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
36920	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
36921	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
36922	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
36923	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
36924	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
36925	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
36926	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
36927	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
36928	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40040	
36929	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
36930	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
36931	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	4	
36932	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36933	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
36934	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
36935	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	596	
36936	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	596	
36937	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
36938	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
36939	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
36940	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
36941	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
36942	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
36943	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
36944	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
36945	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
36946	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
36947	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
36948	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
36949	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
36950	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
36951	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
36952	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36953	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
36954	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	140.0	
36955	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	180.0	
36956	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
36957	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	120.0	
36958	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36959	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36960	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
36961	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
36962	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
36963	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
36964	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
36965	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
36966	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
36967	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
36968	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
36969	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
36970	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
36971	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
36972	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
36973	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
36974	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
36975	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
36976	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
36977	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	19.0	
36978	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
36979	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
36980	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
36981	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
36982	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
36983	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
36984	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
36985	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
36986	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
36987	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	2	
36988	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
36989	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
36990	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
36991	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
36992	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
36993	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
36994	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
36995	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
36996	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
36997	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
36998	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
36999	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
37000	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
37001	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37002	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
37003	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
37004	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
37005	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37006	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37007	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37008	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37009	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
37010	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
37011	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
37012	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
37013	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
37014	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
37015	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
37016	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
37017	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	LTC0000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
37018	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC0000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
37019	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC0000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
37020	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LTC0000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
37021	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
37022	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
37023	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	30	*C
37024	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
37025	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
37026	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
37027	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	35151	
37028	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
37029	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
37030	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
37031	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
37032	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
37033	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
37034	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
37035	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	0	
37036	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37037	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37038	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
37039	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
37040	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
37041	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
37042	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
37043	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
37044	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
37045	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
37046	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
37047	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37048	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
37049	12/5/2019 14:50	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37050	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37051	12/5/2019 10:59	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37052	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
37053	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37054	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37055	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37056	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37057	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
37058	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
37059	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
37060	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
37061	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
37062	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
37063	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
37064	12/5/2019 13:56	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
37065	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
37066	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
37067	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
37068	12/6/2019 8:34	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
37069	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
37070	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
37071	12/5/2019 8:09	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37072	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37073	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37074	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130.0	
37075	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
37076	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
37077	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
37078	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	567	
37079	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	567	
37080	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
37081	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
37082	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	145.0	
37083	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37084	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37085	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37086	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
37087	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
37088	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
37089	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
37090	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
37091	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	23	
37092	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37093	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
37094	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37095	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37096	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37097	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37098	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37099	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37100	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
37101	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
37102	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37103	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
37104	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
37105	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
37106	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
37107	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
37108	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
37109	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
37110	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37111	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
37112	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
37113	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
37114	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37115	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37116	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
37117	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	55.0	
37118	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	85.0	
37119	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
37120	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
37121	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
37122	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37123	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37124	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37125	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	27	
37126	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37127	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
37128	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	362	
37129	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	362	
37130	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
37131	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
37132	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37133	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
37134	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
37135	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
37136	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37137	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37138	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37139	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
37140	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37141	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37142	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37143	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
37144	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
37145	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
37146	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
37147	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	90120	
37148	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	90120	
37149	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	11L	
37150	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	6L	
37151	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	15L	
37152	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	662	
37153	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
37154	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
37155	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
37156	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
37157	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
37158	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
37159	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
37160	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	1.0410	
37161	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
37162	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	35	°C
37163	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	35	°C
37164	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	9993.60	kw
37165	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
37166	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
37167	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
37168	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
37169	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
37170	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
37171	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
37172	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
37173	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
37174	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
37175	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
37176	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
37177	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
37178	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
37179	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
37180	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
37181	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
37182	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
37183	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
37184	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
37185	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
37186	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
37187	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
37188	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
37189	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
37190	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
37191	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
37192	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
37193	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
37194	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
37195	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
37196	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
37197	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
37198	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
37199	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
37200	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
37201	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37202	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
37203	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
37204	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
37205	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
37206	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
37207	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
37208	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
37209	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
37210	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
37211	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
37212	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	663	
37213	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	663	
37214	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	3	
37215	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
37216	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
37217	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
37218	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
37219	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
37220	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	19.9	
37221	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	18.6	
37222	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	21.6	
37223	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	608	
37224	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	608	
37225	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	1	
37226	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	1	
37227	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
37228	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
37229	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	19.0	
37230	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
37231	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
37232	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
37233	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
37234	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	19.0	
37235	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	21.0	
37236	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
37237	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
37238	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
37239	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	421	
37240	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	421	
37241	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	0	
37242	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
37243	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
37244	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
37245	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
37246	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	0.0	
37247	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	0.0	
37248	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	0.0	
37249	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
37250	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
37251	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
37252	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
37253	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
37254	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
37255	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
37256	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37257	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
37258	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
37259	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
37260	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
37261	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
37262	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
37263	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
37264	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
37265	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
37266	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
37267	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37268	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
37269	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
37270	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
37271	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
37272	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
37273	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
37274	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
37275	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
37276	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37277	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
37278	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
37279	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37280	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
37281	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
37282	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
37283	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
37284	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
37285	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
37286	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
37287	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
37288	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
37289	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
37290	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
37291	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37292	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
37293	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
37294	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37295	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37296	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
37297	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
37298	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
37299	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
37300	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
37301	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
37302	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	490.0	
37303	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
37304	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
37305	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
37306	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
37307	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37308	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37309	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37310	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37311	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37312	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
37313	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
37314	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
37315	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
37316	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
37317	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
37318	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
37319	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
37320	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
37321	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
37322	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'-s
37323	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37324	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37325	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37326	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37327	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	115.0	
37328	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	96.0	
37329	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	161.0	
37330	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37331	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37332	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37333	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
37334	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
37335	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
37336	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
37337	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
37338	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
37339	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
37340	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
37341	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37342	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37343	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37344	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
37345	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
37346	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	30	
37347	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
37348	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
37349	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
37350	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
37351	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37352	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
37353	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
37354	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37355	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
37356	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
37357	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	122473	
37358	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	122481	
37359	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
37360	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	49	
37361	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	49	
37362	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
37363	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
37364	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
37365	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	0	
37366	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
37367	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
37368	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
37369	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
37370	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
37371	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37372	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37373	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37374	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37375	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37376	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37377	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37378	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37379	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37380	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC0000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
37381	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC0000280	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
37382	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC0000280	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
37383	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC0000280	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
37384	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
37385	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
37386	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
37387	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
37388	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
37389	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
37390	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	212	
37391	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	212	
37392	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	0	
37393	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	0	
37394	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
37395	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
37396	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37397	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37398	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
37399	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
37400	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
37401	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
37402	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
37403	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37404	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37405	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37406	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
37407	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
37408	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
37409	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37410	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	
37411	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
37412	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
37413	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
37414	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
37415	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
37416	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
37417	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
37418	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
37419	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
37420	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
37421	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
37422	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
37423	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
37424	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
37425	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
37426	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37427	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
37428	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
37429	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
37430	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
37431	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
37432	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	0	
37433	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations	-1	
37434	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
37435	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
37436	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
37437	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37438	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
37439	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	36	*F
37440	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
37441	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
37442	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37443	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
37444	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37445	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
37446	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37447	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
37448	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
37449	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
37450	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
37451	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
37452	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	204	
37453	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
37454	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
37455	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
37456	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
37457	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
37458	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
37459	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
37460	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	48	*C
37461	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	*C
37462	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
37463	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
37464	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
37465	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
37466	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
37467	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37468	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37469	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37470	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37471	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37472	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
37473	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
37474	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
37475	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
37476	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
37477	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
37478	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
37479	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
37480	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
37481	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
37482	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	204	
37483	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
37484	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
37485	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
37486	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
37487	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
37488	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
37489	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	67	psi
37490	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
37491	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
37492	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	42	
37493	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	42	
37494	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
37495	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
37496	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
37497	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
37498	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
37499	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
37500	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37501	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37502	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
37503	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
37504	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
37505	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
37506	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
37507	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
37508	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
37509	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
37510	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
37511	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
37512	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
37513	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37514	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
37515	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
37516	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	39	°C
37517	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	44	°C
37518	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
37519	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
37520	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	10963.20	kw
37521	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37522	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
37523	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
37524	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
37525	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
37526	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
37527	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
37528	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
37529	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
37530	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
37531	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
37532	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
37533	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
37534	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	25	°C
37535	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	67	°C
37536	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37537	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37538	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	304	
37539	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37540	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37541	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37542	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	510.0	
37543	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
37544	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
37545	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
37546	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
37547	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	56.0	
37548	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
37549	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
37550	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
37551	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
37552	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
37553	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
37554	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
37555	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
37556	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
37557	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	524.0	
37558	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	490.0	
37559	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	420.0	
37560	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	22	
37561	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	304	
37562	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	459.0	
37563	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
37564	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37565	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37566	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37567	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	74.0	
37568	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37569	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37570	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37571	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37572	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	1	
37573	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37574	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	1	
37575	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
37576	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37577	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
37578	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
37579	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37580	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37581	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37582	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
37583	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
37584	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
37585	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
37586	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37587	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37588	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
37589	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
37590	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
37591	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
37592	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37593	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
37594	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
37595	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	0	
37596	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
37597	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
37598	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
37599	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1777	
37600	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1777	
37601	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
37602	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
37603	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
37604	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
37605	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
37606	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
37607	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	0	
37608	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
37609	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
37610	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
37611	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
37612	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
37613	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
37614	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	54	
37615	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37616	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37617	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37618	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	45.0	
37619	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	35.0	
37620	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	60.0	
37621	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
37622	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
37623	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
37624	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
37625	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
37626	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
37627	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
37628	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
37629	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
37630	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
37631	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
37632	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
37633	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
37634	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
37635	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
37636	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
37637	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
37638	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
37639	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37640	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
37641	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
37642	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
37643	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37644	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
37645	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
37646	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
37647	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
37648	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
37649	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
37650	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37651	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37652	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37653	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37654	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
37655	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	212	
37656	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	212	
37657	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
37658	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
37659	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
37660	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
37661	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
37662	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
37663	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
37664	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
37665	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	
37666	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
37667	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
37668	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
37669	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37670	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37671	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37672	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37673	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37674	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
37675	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	78.0	
37676	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	75.0	
37677	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
37678	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
37679	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
37680	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
37681	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
37682	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
37683	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
37684	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
37685	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
37686	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
37687	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
37688	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	0	
37689	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	140	
37690	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
37691	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
37692	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
37693	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
37694	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37695	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37696	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37697	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37698	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37699	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37700	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
37701	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
37702	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	260.0	
37703	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	260.0	
37704	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
37705	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
37706	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
37707	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
37708	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
37709	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	240.0	
37710	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
37711	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
37712	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
37713	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
37714	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
37715	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
37716	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
37717	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
37718	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
37719	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
37720	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
37721	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
37722	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
37723	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
37724	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
37725	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	14	
37726	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37727	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	14	
37728	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	229	
37729	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37730	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37731	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	229	
37732	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37733	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	12	
37734	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	67.0	
37735	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
37736	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
37737	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
37738	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
37739	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
37740	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
37741	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
37742	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
37743	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
37744	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments		
37745	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
37746	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	22	
37747	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37748	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC0000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
37749	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC0000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
37750	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37751	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
37752	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
37753	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
37754	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
37755	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
37756	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments		
37757	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
37758	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
37759	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments		
37760	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
37761	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
37762	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
37763	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
37764	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	67	
37765	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	67	
37766	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
37767	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
37768	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37769	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37770	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
37771	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
37772	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
37773	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	26	
37774	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
37775	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
37776	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
37777	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37778	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9516	
37779	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
37780	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
37781	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37782	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37783	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37784	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37785	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
37786	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
37787	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
37788	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
37789	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	258.0	
37790	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	258.0	
37791	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	273.0	
37792	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37793	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37794	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37795	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37796	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
37797	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
37798	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
37799	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
37800	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	140	
37801	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37802	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
37803	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
37804	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
37805	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
37806	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37807	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37808	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37809	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37810	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
37811	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
37812	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
37813	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
37814	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
37815	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	231	
37816	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	231	
37817	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
37818	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments	Actual counter	
37819	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
37820	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
37821	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
37822	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
37823	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
37824	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
37825	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
37826	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
37827	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
37828	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
37829	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
37830	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
37831	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
37832	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
37833	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
37834	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
37835	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37836	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37837	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37838	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37839	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
37840	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
37841	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
37842	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37843	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37844	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37845	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
37846	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37847	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
37848	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	4L	
37849	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	7L	
37850	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
37851	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
37852	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
37853	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
37854	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
37855	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1141.92	kw
37856	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
37857	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
37858	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	0	
37859	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	0	
37860	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	295355	
37861	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	295344	
37862	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments	Work order made to add oil	
37863	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
37864	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
37865	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
37866	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
37867	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
37868	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
37869	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	17	
37870	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
37871	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
37872	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
37873	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
37874	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
37875	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
37876	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Max	0	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37877	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Present	0	°C
37878	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
37879	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
37880	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
37881	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
37882	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	3	
37883	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37884	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37885	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37886	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	97.0	
37887	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	96.0	
37888	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	93.0	
37889	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
37890	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
37891	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37892	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	17	
37893	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99978	
37894	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99978	
37895	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
37896	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
37897	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
37898	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments	open	
37899	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
37900	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
37901	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
37902	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
37903	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	3R	
37904	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
37905	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
37906	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
37907	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
37908	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
37909	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
37910	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
37911	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
37912	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
37913	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
37914	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
37915	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	6L	
37916	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	1204	
37917	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
37918	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
37919	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
37920	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
37921	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
37922	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
37923	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
37924	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
37925	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
37926	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	324	
37927	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
37928	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
37929	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
37930	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
37931	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	324	
37932	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
37933	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
37934	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
37935	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
37936	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
37937	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37938	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	1	
37939	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
37940	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37941	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
37942	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
37943	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
37944	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
37945	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
37946	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
37947	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
37948	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
37949	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
37950	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	1247	
37951	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	12L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
37952	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
37953	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
37954	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
37955	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
37956	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
37957	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B \emptyset	0	
37958	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A \emptyset	0	
37959	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37960	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37961	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
37962	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
37963	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
37964	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
37965	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
37966	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
37967	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
37968	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A \emptyset	0	
37969	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37970	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37971	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B \emptyset	0.0	
37972	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C \emptyset	0.0	
37973	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37974	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37975	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	4	
37976	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
37977	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
37978	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
37979	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A \emptyset	147.0	
37980	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B \emptyset	146.0	
37981	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C \emptyset	139.0	
37982	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
37983	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37984	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
37985	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
37986	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
37987	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
37988	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A \emptyset	0	
37989	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B \emptyset	0	
37990	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
37991	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
37992	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
37993	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		
37994	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C \emptyset	0	
37995	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
37996	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
37997	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
37998	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
37999	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
38000	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
38001	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	182	
38002	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	182	
38003	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	0	
38004	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
38005	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
38006	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
38007	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
38008	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	3	
38009	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38010	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38011	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38012	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
38013	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-5TA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38014	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-5TA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
38015	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38016	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38017	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A \emptyset	0.0	
38018	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
38019	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38020	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A \emptyset	240.0	
38021	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B \emptyset	260.0	
38022	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38023	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C \emptyset	280.0	
38024	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
38025	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	2	
38026	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38027	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38028	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38029	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	53.0	
38030	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	62.0	
38031	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
38032	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
38033	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	2	
38034	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
38035	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38036	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	2	
38037	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	399	
38038	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
38039	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38040	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
38041	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
38042	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
38043	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	399	
38044	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
38045	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
38046	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
38047	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
38048	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
38049	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
38050	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
38051	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
38052	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
38053	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
38054	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
38055	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
38056	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
38057	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
38058	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
38059	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38060	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38061	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
38062	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	34	°C
38063	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38064	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38065	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38066	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38067	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
38068	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38069	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
38070	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38071	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
38072	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	67	°C
38073	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	37	°C
38074	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	67	°C
38075	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	37	°C
38076	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	67	°C
38077	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	37	°C
38078	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	200.0	
38079	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
38080	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38081	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	250.0	
38082	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	200.0	
38083	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38084	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38085	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38086	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	3	
38087	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	?	
38088	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38089	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38090	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38091	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	0	
38092	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
38093	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
38094	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
38095	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
38096	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
38097	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
38098	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
38099	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
38100	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
38101	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38102	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
38103	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
38104	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
38105	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
38106	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
38107	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
38108	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38109	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	872	
38110	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
38111	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
38112	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
38113	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	112153	
38114	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	112153	
38115	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
38116	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
38117	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
38118	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
38119	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
38120	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
38121	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
38122	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38123	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38124	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38125	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
38126	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	160.0	
38127	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	200.0	
38128	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	180.0	
38129	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
38130	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38131	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
38132	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
38133	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
38134	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
38135	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38136	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
38137	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
38138	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
38139	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38140	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38141	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38142	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
38143	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
38144	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
38145	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
38146	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
38147	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38148	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
38149	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
38150	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38151	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38152	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
38153	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
38154	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
38155	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
38156	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
38157	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38158	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
38159	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
38160	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
38161	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
38162	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
38163	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
38164	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
38165	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
38166	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
38167	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	
38168	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
38169	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
38170	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38171	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
38172	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38173	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38174	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38175	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38176	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38177	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38178	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
38179	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
38180	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38181	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
38182	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
38183	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
38184	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
38185	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
38186	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
38187	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
38188	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38189	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
38190	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments	Actual counter	
38191	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
38192	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	593	
38193	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	593	
38194	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	0	
38195	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
38196	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	69	
38197	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38198	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38199	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
38200	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38201	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
38202	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
38203	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
38204	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
38205	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
38206	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
38207	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38208	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38209	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38210	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38211	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
38212	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38213	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38214	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38215	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
38216	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
38217	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
38218	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	-1	
38219	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38220	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38221	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	192	
38222	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	192	
38223	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
38224	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
38225	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
38226	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38227	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
38228	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
38229	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
38230	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
38231	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
38232	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
38233	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
38234	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
38235	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
38236	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
38237	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
38238	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
38239	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
38240	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
38241	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
38242	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
38243	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38244	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38245	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38246	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38247	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	131.0	
38248	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
38249	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
38250	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
38251	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38252	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
38253	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	130.0	
38254	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	131.0	
38255	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	131.0	
38256	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
38257	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	-1	
38258	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
38259	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	404	
38260	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	24	
38261	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38262	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	?	
38263	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	9L	
38264	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	5L	
38265	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	3R	
38266	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	866	
38267	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
38268	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38269	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
38270	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38271	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38272	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	3	
38273	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38274	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38275	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38276	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	47.0	
38277	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	49.0	
38278	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	44.0	
38279	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
38280	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38281	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38282	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
38283	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
38284	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
38285	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
38286	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
38287	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
38288	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
38289	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
38290	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
38291	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
38292	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
38293	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
38294	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
38295	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
38296	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
38297	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
38298	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38299	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38300	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC needs oil	
38301	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	52849	
38302	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	52849	
38303	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
38304	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
38305	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
38306	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
38307	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
38308	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
38309	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	5	
38310	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38311	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38312	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38313	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	234.0	
38314	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	209.0	
38315	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	218.0	
38316	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38317	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38318	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38319	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
38320	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
38321	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
38322	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
38323	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
38324	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
38325	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
38326	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38327	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
38328	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
38329	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
38330	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
38331	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
38332	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
38333	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
38334	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
38335	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	0	
38336	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
38337	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
38338	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
38339	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
38340	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	397	
38341	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	397	
38342	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
38343	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
38344	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
38345	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
38346	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	209	
38347	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
38348	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
38349	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
38350	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
38351	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
38352	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
38353	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	209	
38354	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
38355	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
38356	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
38357	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
38358	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	0	
38359	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	0	
38360	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
38361	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
38362	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
38363	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
38364	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
38365	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
38366	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
38367	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
38368	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
38369	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
38370	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	23	*C
38371	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	63	*C
38372	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	23.0	VDC
38373	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
38374	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
38375	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
38376	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	158	
38377	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	158	
38378	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
38379	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	*C
38380	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	53	*C
38381	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	15	*C
38382	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	*C
38383	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
38384	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38385	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
38386	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38387	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
38388	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
38389	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
38390	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
38391	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
38392	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
38393	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
38394	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
38395	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
38396	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
38397	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
38398	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
38399	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
38400	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	6.0	
38401	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	7.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
38402	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	7.0	
38403	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
38404	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
38405	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
38406	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
38407	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
38408	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
38409	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
38410	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
38411	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
38412	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
38413	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
38414	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
38415	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
38416	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
38417	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
38418	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
38419	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
38420	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
38421	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
38422	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
38423	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
38424	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
38425	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
38426	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
38427	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
38428	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
38429	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
38430	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
38431	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
38432	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
38433	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
38434	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
38435	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
38436	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
38437	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
38438	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
38439	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
38440	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
38441	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
38442	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
38443	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
38444	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
38445	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
38446	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
38447	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
38448	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
38449	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
38450	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
38451	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
38452	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
38453	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
38454	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
38455	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
38456	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
38457	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38458	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38459	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	260.0	
38460	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	264.0	
38461	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	0	
38462	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
38463	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	0	
38464	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	334	
38465	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	334	
38466	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
38467	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
38468	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
38469	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
38470	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
38471	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
38472	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	220.0	
38473	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38474	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38475	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38476	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38477	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38478	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38479	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38480	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38481	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	23	°C
38482	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	59	°C
38483	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
38484	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	0.0	
38485	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1481	
38486	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1481	
38487	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	0.0	
38488	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
38489	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
38490	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
38491	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
38492	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
38493	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38494	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38495	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Ltc relief device alarm is still isolated	
38496	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
38497	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
38498	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
38499	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	4	
38500	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	°C
38501	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
38502	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
38503	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
38504	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
38505	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
38506	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38507	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38508	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	0.0	
38509	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
38510	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
38511	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38512	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38513	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
38514	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
38515	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
38516	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
38517	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
38518	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
38519	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38520	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38521	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38522	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
38523	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38524	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
38525	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
38526	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
38527	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
38528	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
38529	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
38530	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
38531	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
38532	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
38533	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
38534	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
38535	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
38536	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
38537	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
38538	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
38539	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
38540	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments		
38541	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
38542	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
38543	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
38544	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
38545	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
38546	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
38547	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
38548	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
38549	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
38550	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
38551	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38552	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
38553	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
38554	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
38555	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
38556	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
38557	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
38558	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
38559	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38560	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	404	
38561	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
38562	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
38563	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
38564	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
38565	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
38566	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
38567	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
38568	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38569	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
38570	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
38571	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
38572	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
38573	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
38574	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
38575	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
38576	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
38577	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
38578	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
38579	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	
38580	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
38581	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
38582	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	58682	
38583	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	58689	
38584	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
38585	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
38586	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
38587	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
38588	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
38589	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38590	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38591	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
38592	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
38593	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
38594	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
38595	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
38596	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38597	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
38598	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
38599	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
38600	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
38601	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
38602	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38603	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
38604	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	1L	
38605	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	5L	
38606	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
38607	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	3440	
38608	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	3440	
38609	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
38610	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
38611	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
38612	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
38613	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	5960	
38614	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
38615	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
38616	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
38617	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	26894	
38618	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	26894	
38619	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
38620	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
38621	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
38622	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
38623	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
38624	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
38625	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38626	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38627	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
38628	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
38629	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
38630	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
38631	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38632	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
38633	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
38634	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
38635	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
38636	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
38637	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
38638	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
38639	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2R	
38640	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	273	
38641	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
38642	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38643	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
38644	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	531	
38645	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	531	
38646	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
38647	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
38648	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
38649	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
38650	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
38651	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
38652	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
38653	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
38654	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
38655	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
38656	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
38657	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
38658	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38659	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38660	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
38661	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
38662	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
38663	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38664	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	1	
38665	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	182	
38666	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	182	
38667	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
38668	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
38669	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
38670	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
38671	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
38672	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
38673	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
38674	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38675	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38676	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
38677	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
38678	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	726	
38679	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
38680	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	12L	
38681	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
38682	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
38683	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
38684	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
38685	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
38686	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
38687	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38688	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38689	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38690	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	818	
38691	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
38692	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
38693	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38694	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38695	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
38696	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	463	
38697	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
38698	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	14L	
38699	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38700	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38701	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38702	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
38703	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
38704	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38705	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	35	°C
38706	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	?	
38707	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38708	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	?	
38709	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38710	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38711	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
38712	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	4L	
38713	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
38714	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
38715	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	9L	
38716	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
38717	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	5960	
38718	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38719	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38720	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	35	°C
38721	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38722	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
38723	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
38724	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
38725	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
38726	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
38727	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
38728	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
38729	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38730	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
38731	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
38732	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
38733	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
38734	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38735	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
38736	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
38737	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
38738	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
38739	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
38740	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
38741	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
38742	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments	heater is 12" long. 125/250v 350W. Approximately 1.5" wide.	
38743	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38744	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38745	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
38746	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
38747	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
38748	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
38749	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38750	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38751	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38752	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38753	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38754	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments		
38755	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
38756	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
38757	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
38758	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
38759	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
38760	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
38761	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38762	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
38763	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38764	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
38765	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
38766	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
38767	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
38768	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
38769	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38770	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments		
38771	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
38772	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
38773	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	
38774	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
38775	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
38776	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	bad vent fan motor. A.O. Smith model JA2R182N+ 115V 1550RPM 1/15th HP	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38777	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
38778	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
38779	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
38780	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
38781	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
38782	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	
38783	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	25	
38784	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	25	
38785	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	0	
38786	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
38787	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	0	
38788	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38789	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
38790	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38791	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	VCB Patrol Inspection	Tank Paint Condition	Good	
38792	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
38793	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
38794	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
38795	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
38796	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	83.0	
38797	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	72.0	
38798	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	54.0	
38799	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
38800	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
38801	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
38802	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
38803	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
38804	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
38805	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
38806	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
38807	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
38808	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
38809	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
38810	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
38811	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38812	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
38813	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
38814	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38815	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	0	
38816	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
38817	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38818	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
38819	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38820	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	0	
38821	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	0	
38822	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
38823	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	1	
38824	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38825	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38826	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
38827	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
38828	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
38829	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
38830	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
38831	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38832	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38833	12/4/2019 15:13	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38834	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
38835	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
38836	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
38837	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
38838	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
38839	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	need nitrogen added	
38840	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38841	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38842	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
38843	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	59	°C
38844	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	21	°C
38845	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38846	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38847	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38848	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38849	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
38850	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38851	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38852	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
38853	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
38854	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	57	°C
38855	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
38856	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	58	°C
38857	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
38858	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	59	°C
38859	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
38860	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
38861	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
38862	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
38863	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
38864	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
38865	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Oil level shows level low.	
38866	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
38867	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
38868	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38869	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
38870	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
38871	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
38872	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
38873	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
38874	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
38875	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
38876	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
38877	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
38878	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38879	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38880	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
38881	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
38882	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
38883	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
38884	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
38885	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
38886	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38887	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38888	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38889	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
38890	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
38891	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
38892	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
38893	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
38894	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
38895	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
38896	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
38897	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	
38898	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	44	
38899	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	44	
38900	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	0	
38901	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
38902	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
38903	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	4	
38904	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38905	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
38906	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
38907	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
38908	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
38909	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
38910	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
38911	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
38912	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
38913	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
38914	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTCC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
38915	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
38916	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
38917	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
38918	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
38919	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
38920	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
38921	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
38922	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
38923	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
38924	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
38925	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
38926	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
38927	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
38928	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
38929	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	2	
38930	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	160.0	
38931	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	100.0	
38932	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
38933	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
38934	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
38935	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
38936	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
38937	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
38938	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
38939	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
38940	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
38941	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
38942	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
38943	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
38944	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.5076	
38945	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
38946	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
38947	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
38948	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
38949	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
38950	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
38951	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
38952	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
38953	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	40	°C
38954	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
38955	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
38956	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
38957	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	4872.96	kw
38958	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
38959	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
38960	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
38961	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
38962	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
38963	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
38964	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
38965	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
38966	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
38967	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
38968	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
38969	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
38970	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
38971	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
38972	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
38973	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
38974	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
38975	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
38976	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
38977	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1002	
38978	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
38979	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
38980	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
38981	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
38982	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
38983	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
38984	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	1	
38985	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
38986	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	1	
38987	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	316	
38988	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	316	
38989	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
38990	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
38991	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments		
38992	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
38993	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
38994	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
38995	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
38996	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
38997	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	205	
38998	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	205	
38999	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	5	
39000	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
39001	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39002	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
39003	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39004	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
39005	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
39006	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
39007	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
39008	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
39009	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
39010	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
39011	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
39012	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
39013	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
39014	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
39015	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
39016	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
39017	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
39018	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
39019	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	1	
39020	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
39021	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
39022	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
39023	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
39024	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
39025	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
39026	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	35690	
39027	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	35690	
39028	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
39029	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
39030	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
39031	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
39032	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	52	°C
39033	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
39034	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
39035	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1251	
39036	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
39037	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
39038	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
39039	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
39040	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
39041	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
39042	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
39043	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
39044	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
39045	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
39046	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
39047	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
39048	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
39049	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
39050	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
39051	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1251	
39052	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39053	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39054	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	120.0	
39055	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	180.0	
39056	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	120.0	
39057	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
39058	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39059	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39060	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39061	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39062	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
39063	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39064	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39065	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39066	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	27	
39067	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
39068	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
39069	12/4/2019 15:19	Distribution	London Quarterly Inspection	LTC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
39070	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39071	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	195.0	
39072	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	180.0	
39073	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	190.0	
39074	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
39075	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
39076	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39077	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
39078	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
39079	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
39080	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
39081	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
39082	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
39083	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39084	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39085	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
39086	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
39087	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
39088	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	116.0	
39089	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
39090	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39091	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39092	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39093	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39094	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39095	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39096	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39097	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
39098	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
39099	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39100	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39101	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39102	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39103	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
39104	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
39105	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
39106	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
39107	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39108	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39109	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39110	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	114.0	
39111	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
39112	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
39113	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
39114	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
39115	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
39116	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
39117	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
39118	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
39119	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
39120	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39121	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39122	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39123	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
39124	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	24	
39125	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
39126	12/4/2019 15:19	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
39127	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
39128	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
39129	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
39130	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
39131	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
39132	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
39133	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
39134	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
39135	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
39136	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
39137	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
39138	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
39139	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
39140	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
39141	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
39142	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
39143	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
39144	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99955	
39145	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99955	
39146	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
39147	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
39148	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
39149	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
39150	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
39151	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39152	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
39153	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
39154	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
39155	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
39156	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
39157	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
39158	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
39159	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
39160	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
39161	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
39162	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
39163	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
39164	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
39165	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
39166	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
39167	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
39168	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
39169	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
39170	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
39171	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
39172	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
39173	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
39174	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
39175	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
39176	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	111746	
39177	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
39178	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
39179	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
39180	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
39181	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
39182	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
39183	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
39184	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
39185	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
39186	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
39187	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
39188	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	194821	
39189	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	194821	
39190	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
39191	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
39192	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
39193	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
39194	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
39195	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
39196	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
39197	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
39198	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
39199	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
39200	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
39201	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
39202	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
39203	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
39204	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
39205	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
39206	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
39207	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
39208	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
39209	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
39210	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32	
39211	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
39212	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
39213	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
39214	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
39215	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
39216	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
39217	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
39218	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
39219	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
39220	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
39221	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
39222	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
39223	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
39224	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
39225	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
39226	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	248.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39227	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	255.0	
39228	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
39229	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
39230	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
39231	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
39232	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
39233	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
39234	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
39235	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
39236	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
39237	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
39238	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
39239	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	776	
39240	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	776	
39241	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	0	
39242	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
39243	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
39244	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
39245	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
39246	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
39247	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
39248	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
39249	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	42.0	
39250	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	45.0	
39251	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	40.0	
39252	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	296361	
39253	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
39254	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
39255	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
39256	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
39257	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
39258	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
39259	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
39260	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
39261	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
39262	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
39263	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
39264	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
39265	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
39266	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
39267	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
39268	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
39269	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
39270	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
39271	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
39272	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1493	
39273	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1493	
39274	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
39275	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
39276	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
39277	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
39278	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
39279	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	General Comments		
39280	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1619	
39281	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1619	
39282	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
39283	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
39284	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
39285	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
39286	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
39287	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
39288	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
39289	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
39290	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
39291	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
39292	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
39293	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
39294	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
39295	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
39296	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	205416	
39297	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
39298	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
39299	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
39300	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
39301	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
39302	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
39303	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
39304	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
39305	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
39306	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
39307	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
39308	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
39309	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
39310	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
39311	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
39312	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
39313	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
39314	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments		
39315	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
39316	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
39317	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
39318	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
39319	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
39320	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
39321	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
39322	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
39323	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
39324	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
39325	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
39326	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
39327	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
39328	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
39329	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
39330	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
39331	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
39332	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
39333	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
39334	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
39335	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
39336	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
39337	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
39338	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
39339	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
39340	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
39341	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
39342	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
39343	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	20	°C
39344	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
39345	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
39346	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
39347	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
39348	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
39349	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
39350	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
39351	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
39352	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
39353	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
39354	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
39355	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
39356	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
39357	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
39358	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
39359	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
39360	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
39361	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
39362	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
39363	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
39364	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
39365	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
39366	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
39367	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
39368	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
39369	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
39370	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
39371	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
39372	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
39373	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
39374	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
39375	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
39376	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39377	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
39378	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
39379	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
39380	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
39381	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	30	°C
39382	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6660	
39383	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
39384	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
39385	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
39386	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
39387	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
39388	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
39389	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
39390	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
39391	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
39392	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15R	
39393	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
39394	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	744	
39395	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
39396	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
39397	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
39398	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
39399	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	827	
39400	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	15L	
39401	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	3R	
39402	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	16L	
39403	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
39404	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	205416	
39405	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
39406	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
39407	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39408	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39409	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39410	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39411	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
39412	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
39413	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
39414	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39415	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39416	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39417	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	0	
39418	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
39419	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
39420	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
39421	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39422	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39423	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39424	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39425	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39426	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39427	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
39428	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
39429	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
39430	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
39431	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
39432	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39433	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39434	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39435	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
39436	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	575.0	
39437	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
39438	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
39439	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
39440	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
39441	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
39442	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
39443	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	1.2948	
39444	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
39445	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
39446	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49247	
39447	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
39448	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
39449	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
39450	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
39451	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39452	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
39453	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
39454	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
39455	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	575.0	
39456	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	400.0	
39457	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39458	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39459	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39460	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	1	
39461	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
39462	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
39463	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
39464	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
39465	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.400	millivolts
39466	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
39467	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
39468	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.7	amps
39469	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
39470	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
39471	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
39472	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
39473	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
39474	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC0000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
39475	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC0000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
39476	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC0000067	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
39477	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC0000067	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
39478	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC0000067	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
39479	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
39480	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
39481	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
39482	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
39483	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
39484	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
39485	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	743	
39486	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
39487	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
39488	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
39489	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	General Comments		
39490	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
39491	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
39492	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39493	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39494	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39495	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39496	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39497	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39498	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39499	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
39500	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
39501	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39502	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
39503	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
39504	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
39505	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
39506	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
39507	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	14R	
39508	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
39509	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
39510	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
39511	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
39512	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	576	
39513	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
39514	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
39515	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
39516	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
39517	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
39518	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
39519	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
39520	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
39521	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
39522	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
39523	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
39524	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
39525	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
39526	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39527	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
39528	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
39529	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
39530	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
39531	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
39532	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
39533	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
39534	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
39535	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	151	
39536	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	151	
39537	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
39538	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
39539	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
39540	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
39541	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
39542	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
39543	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
39544	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
39545	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
39546	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
39547	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
39548	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
39549	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
39550	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
39551	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
39552	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
39553	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
39554	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	156	
39555	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
39556	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
39557	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
39558	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
39559	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
39560	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
39561	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
39562	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
39563	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
39564	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
39565	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
39566	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
39567	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
39568	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
39569	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
39570	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
39571	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
39572	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
39573	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
39574	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
39575	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
39576	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	156	
39577	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
39578	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
39579	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
39580	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
39581	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
39582	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
39583	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
39584	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
39585	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
39586	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
39587	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
39588	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
39589	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
39590	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
39591	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
39592	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
39593	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
39594	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39595	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
39596	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
39597	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
39598	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
39599	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
39600	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
39601	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	35	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
39602	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
39603	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs Nitro. Transformer has a 6 pack	
39604	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
39605	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
39606	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
39607	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
39608	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
39609	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
39610	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
39611	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
39612	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
39613	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
39614	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
39615	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	.8710	
39616	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
39617	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
39618	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
39619	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
39620	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
39621	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
39622	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
39623	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39624	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	40	°C
39625	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	40	°C
39626	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
39627	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
39628	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments		
39629	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
39630	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
39631	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	8361.60	kw
39632	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
39633	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
39634	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
39635	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
39636	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
39637	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
39638	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
39639	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	324	
39640	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
39641	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
39642	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
39643	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
39644	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
39645	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
39646	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
39647	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Need 2 screw on desiccant filters	
39648	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	1584	
39649	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	1584	
39650	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
39651	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10R	
39652	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	
39653	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7R	
39654	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	177	
39655	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
39656	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
39657	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
39658	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
39659	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
39660	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
39661	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
39662	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
39663	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
39664	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
39665	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
39666	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
39667	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
39668	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
39669	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
39670	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
39671	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
39672	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
39673	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
39674	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
39675	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
39676	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39677	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
39678	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
39679	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
39680	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
39681	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
39682	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
39683	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
39684	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
39685	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
39686	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
39687	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
39688	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
39689	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
39690	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39691	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
39692	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
39693	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39694	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
39695	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
39696	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
39697	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
39698	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
39699	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
39700	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
39701	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
39702	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
39703	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
39704	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	5865.60	kw
39705	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
39706	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
39707	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
39708	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
39709	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
39710	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
39711	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
39712	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	y	
39713	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
39714	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
39715	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
39716	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
39717	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
39718	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
39719	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
39720	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
39721	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
39722	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	1	
39723	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	0	
39724	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	1	
39725	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	213	
39726	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	213	
39727	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
39728	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments	IOC A and B Phase	
39729	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
39730	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
39731	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
39732	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
39733	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
39734	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
39735	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
39736	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
39737	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
39738	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
39739	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
39740	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
39741	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
39742	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
39743	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
39744	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
39745	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
39746	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
39747	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
39748	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
39749	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	0	
39750	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
39751	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39752	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
39753	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39754	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39755	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39756	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39757	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
39758	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	57.0	
39759	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	44.0	
39760	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	40.0	
39761	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39762	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39763	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
39764	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39765	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
39766	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
39767	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
39768	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
39769	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
39770	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
39771	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
39772	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39773	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
39774	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
39775	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
39776	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
39777	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
39778	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
39779	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
39780	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
39781	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	3	
39782	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
39783	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
39784	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	0	
39785	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	0	
39786	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	180	
39787	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	180	
39788	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
39789	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
39790	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
39791	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
39792	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
39793	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
39794	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
39795	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
39796	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
39797	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
39798	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
39799	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
39800	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
39801	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
39802	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
39803	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
39804	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39805	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	25	°C
39806	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	25	°C
39807	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	6	
39808	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39809	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39810	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39811	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	155.0	
39812	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	170.0	
39813	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	140.0	
39814	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
39815	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39816	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39817	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39818	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
39819	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
39820	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
39821	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
39822	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
39823	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
39824	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	2	
39825	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
39826	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39827	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
39828	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.87	
39829	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.87	
39830	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.87	
39831	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
39832	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
39833	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130.0	
39834	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	9.96	%
39835	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.54	%
39836	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.96	%
39837	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
39838	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
39839	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
39840	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
39841	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
39842	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
39843	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
39844	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
39845	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
39846	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
39847	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
39848	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
39849	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
39850	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
39851	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
39852	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
39853	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
39854	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
39855	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
39856	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
39857	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
39858	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
39859	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
39860	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39861	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39862	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39863	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
39864	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	34	
39865	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39866	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39867	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
39868	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	80.0	
39869	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
39870	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
39871	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
39872	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
39873	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
39874	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39875	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
39876	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
39877	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
39878	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
39879	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3196.80	kw
39880	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
39881	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
39882	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
39883	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
39884	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
39885	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0200	
39886	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
39887	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	72.0	
39888	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39889	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	82.0	
39890	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	76.0	
39891	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
39892	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
39893	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
39894	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
39895	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
39896	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	60.0	
39897	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
39898	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		
39899	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
39900	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	64.0	
39901	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	98.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
39902	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
39903	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
39904	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
39905	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	3	
39906	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
39907	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
39908	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
39909	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
39910	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
39911	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
39912	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
39913	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
39914	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
39915	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
39916	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
39917	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
39918	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
39919	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
39920	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
39921	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
39922	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
39923	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	0	
39924	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	
39925	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	181	
39926	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	181	
39927	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	0	
39928	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	0	
39929	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
39930	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
39931	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
39932	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
39933	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
39934	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
39935	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
39936	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
39937	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
39938	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments	Bathroom is out of service	
39939	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
39940	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
39941	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
39942	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
39943	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
39944	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
39945	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
39946	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	169	
39947	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	169	
39948	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	4	
39949	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	4	
39950	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
39951	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
39952	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
39953	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
39954	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
39955	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
39956	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
39957	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
39958	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
39959	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
39960	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB00056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	32	
39961	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB00056	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
39962	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB00056	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
39963	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
39964	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
39965	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	1	
39966	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	1	
39967	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	161	
39968	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	161	
39969	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
39970	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
39971	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
39972	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
39973	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
39974	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
39975	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
39976	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
39977	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
39978	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
39979	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
39980	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
39981	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
39982	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
39983	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
39984	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
39985	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
39986	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
39987	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
39988	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
39989	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
39990	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
39991	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
39992	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
39993	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
39994	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
39995	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
39996	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
39997	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
39998	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
39999	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	45	°F
40000	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
40001	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
40002	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
40003	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40004	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
40005	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40006	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
40007	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
40008	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
40009	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40010	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
40011	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
40012	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	4	
40013	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40014	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
40015	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40016	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	120.0	
40017	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	110.0	
40018	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	100.0	
40019	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
40020	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
40021	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40022	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40023	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40024	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40025	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40026	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40027	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40028	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40029	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
40030	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
40031	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
40032	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40033	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40034	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
40035	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
40036	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40037	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
40038	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40039	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
40040	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
40041	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40042	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40043	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40044	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40045	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
40046	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
40047	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40048	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
40049	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
40050	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
40051	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40052	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
40053	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
40054	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
40055	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
40056	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
40057	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
40058	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
40059	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
40060	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
40061	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
40062	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
40063	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
40064	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
40065	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
40066	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.6110	
40067	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
40068	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
40069	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
40070	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
40071	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
40072	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
40073	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
40074	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
40075	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
40076	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
40077	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
40078	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
40079	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
40080	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
40081	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
40082	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
40083	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
40084	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
40085	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
40086	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
40087	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
40088	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
40089	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
40090	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
40091	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40092	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40093	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40094	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40095	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
40096	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
40097	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
40098	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
40099	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
40100	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40101	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40102	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
40103	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
40104	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
40105	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	52	°C
40106	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
40107	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	52	°C
40108	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
40109	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	318	
40110	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	318	
40111	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
40112	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
40113	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	2	
40114	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40115	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
40116	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40117	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
40118	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
40119	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40120	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40121	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40122	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	20.0	
40123	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	30.0	
40124	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	31.0	
40125	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
40126	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40127	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40128	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40129	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40130	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40131	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40132	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
40133	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40134	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
40135	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
40136	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
40137	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
40138	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
40139	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
40140	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
40141	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
40142	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	118	
40143	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
40144	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
40145	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
40146	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
40147	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
40148	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
40149	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
40150	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	43.4	
40151	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.0	
40152	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.7	
40153	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
40154	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
40155	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
40156	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
40157	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
40158	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	408.00	kw
40159	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
40160	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
40161	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
40162	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	53	°C
40163	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
40164	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
40165	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
40166	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
40167	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
40168	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
40169	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40170	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40171	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40172	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
40173	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
40174	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
40175	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
40176	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
40177	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
40178	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
40179	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
40180	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
40181	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
40182	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	192	
40183	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	192	
40184	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	0	
40185	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
40186	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	0	
40187	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
40188	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
40189	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
40190	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
40191	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
40192	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
40193	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
40194	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	19	
40195	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
40196	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
40197	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
40198	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
40199	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
40200	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
40201	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40202	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
40203	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
40204	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
40205	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
40206	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
40207	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
40208	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
40209	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
40210	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
40211	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	1	
40212	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
40213	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	3	
40214	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	80	
40215	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	80	
40216	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	7	
40217	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
40218	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
40219	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
40220	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
40221	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
40222	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	2	
40223	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
40224	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	73.0	
40225	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	70.0	
40226	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
40227	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	70.0	
40228	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	0	
40229	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
40230	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
40231	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
40232	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
40233	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
40234	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
40235	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40236	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
40237	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
40238	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments	Racked Out	
40239	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
40240	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
40241	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
40242	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
40243	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
40244	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		
40245	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
40246	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
40247	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	0	
40248	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	392	
40249	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	392	
40250	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
40251	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
40252	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
40253	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
40254	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
40255	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
40256	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
40257	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
40258	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40259	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
40260	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
40261	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
40262	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
40263	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40264	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40265	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
40266	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
40267	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
40268	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
40269	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
40270	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
40271	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
40272	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
40273	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
40274	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
40275	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
40276	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40277	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
40278	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
40279	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
40280	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
40281	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
40282	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
40283	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
40284	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
40285	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40286	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40287	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
40288	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
40289	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
40290	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
40291	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
40292	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments		
40293	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
40294	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
40295	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
40296	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
40297	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
40298	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
40299	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
40300	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
40301	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
40302	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
40303	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
40304	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
40305	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
40306	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	n	
40307	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
40308	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments	Plastic safety barrier is deteriorating.	
40309	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
40310	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
40311	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40312	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
40313	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
40314	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
40315	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
40316	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
40317	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
40318	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
40319	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
40320	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
40321	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	29	
40322	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	29	
40323	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
40324	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
40325	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
40326	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
40327	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
40328	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	169927	
40329	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
40330	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
40331	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
40332	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
40333	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
40334	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
40335	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
40336	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
40337	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
40338	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32	
40339	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	32	
40340	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
40341	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
40342	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
40343	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
40344	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
40345	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
40346	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	9.0	
40347	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40348	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
40349	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
40350	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
40351	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40352	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
40353	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
40354	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
40355	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
40356	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
40357	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
40358	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
40359	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
40360	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	114	
40361	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	114	
40362	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
40363	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
40364	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
40365	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
40366	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
40367	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
40368	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
40369	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
40370	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
40371	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
40372	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
40373	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
40374	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
40375	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
40376	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakersSF6	SH-1285	GCB Readings	Amps A Ø	80.0	
40377	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakersSF6	SH-1285	GCB Readings	Amps B Ø	82.0	
40378	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakersSF6	SH-1285	GCB Readings	Amps C Ø	81.0	
40379	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakersSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
40380	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0856	BreakersSF6	SH-1285	GCB Readings	Fault Operations	0	
40381	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
40382	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	198570	
40383	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	198567	
40384	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
40385	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
40386	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
40387	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
40388	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
40389	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
40390	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
40391	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
40392	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	General Comments		
40393	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
40394	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
40395	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
40396	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
40397	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
40398	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40399	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	570.0	
40400	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	622.0	
40401	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	598.0	
40402	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
40403	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
40404	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40405	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40406	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
40407	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
40408	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Amps A Ø	92.0	
40409	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Amps B Ø	93.0	
40410	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Amps C Ø	100.0	
40411	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
40412	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
40413	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
40414	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
40415	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40416	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
40417	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
40418	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
40419	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
40420	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
40421	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40422	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
40423	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
40424	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
40425	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	6474.24	kw
40426	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40427	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
40428	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
40429	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
40430	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
40431	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
40432	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
40433	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
40434	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
40435	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Max	30	°C
40436	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
40437	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
40438	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
40439	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments		
40440	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
40441	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	
40442	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	5	
40443	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	683	
40444	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	683	
40445	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	1	
40446	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	1	
40447	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
40448	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Present	26	°C
40449	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
40450	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.6744	
40451	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
40452	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
40453	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
40454	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
40455	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
40456	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
40457	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
40458	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
40459	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
40460	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
40461	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
40462	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
40463	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
40464	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
40465	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
40466	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
40467	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
40468	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
40469	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
40470	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
40471	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
40472	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	622	
40473	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	3L	
40474	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	10L	
40475	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
40476	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
40477	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
40478	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
40479	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
40480	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
40481	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
40482	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil Level	Good	
40483	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
40484	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
40485	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
40486	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
40487	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40488	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40489	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40490	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40491	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40492	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40493	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40494	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
40495	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
40496	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
40497	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
40498	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
40499	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
40500	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40501	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue		AssetInspectionQuestionUnit
40502	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40503	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
40504	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
40505	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
40506	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
40507	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	317	
40508	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	317	
40509	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
40510	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
40511	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments		
40512	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
40513	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
40514	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
40515	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
40516	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
40517	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
40518	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
40519	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
40520	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	8L	
40521	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
40522	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
40523	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
40524	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1416	
40525	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1416	
40526	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
40527	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
40528	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
40529	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
40530	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
40531	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
40532	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
40533	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
40534	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
40535	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
40536	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
40537	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
40538	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
40539	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40540	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40541	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
40542	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
40543	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
40544	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
40545	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
40546	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
40547	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
40548	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
40549	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
40550	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
40551	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
40552	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
40553	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
40554	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
40555	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
40556	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
40557	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
40558	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
40559	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
40560	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
40561	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
40562	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
40563	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
40564	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
40565	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
40566	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
40567	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
40568	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
40569	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
40570	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	0	
40571	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
40572	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
40573	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40574	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40575	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40576	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40577	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40578	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
40579	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	2	
40580	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40581	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
40582	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40583	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	270.0	
40584	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	270.0	
40585	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	230.0	
40586	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40587	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40588	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
40589	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
40590	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
40591	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
40592	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
40593	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.1420	
40594	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	67	°C
40595	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	25	°C
40596	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	67	°C
40597	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	25	°C
40598	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	71	°C
40599	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	56	°C
40600	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
40601	12/4/2019 15:19	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
40602	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
40603	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
40604	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
40605	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
40606	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
40607	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
40608	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
40609	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
40610	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
40611	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
40612	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
40613	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
40614	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
40615	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
40616	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
40617	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
40618	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
40619	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
40620	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
40621	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
40622	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
40623	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
40624	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
40625	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
40626	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
40627	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
40628	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
40629	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	57.0	
40630	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	48.0	
40631	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
40632	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
40633	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40634	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
40635	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
40636	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
40637	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
40638	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
40639	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
40640	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
40641	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40642	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40643	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40644	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
40645	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
40646	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
40647	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
40648	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
40649	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
40650	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
40651	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40652	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
40653	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	LTC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
40654	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
40655	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LTC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
40656	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LTC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
40657	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
40658	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
40659	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
40660	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	439.0	
40661	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	372.0	
40662	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	402.0	
40663	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40664	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
40665	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40666	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	1	
40667	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
40668	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
40669	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
40670	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
40671	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	Cl-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
40672	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	Cl-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
40673	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	80	°C
40674	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	30	°C
40675	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
40676	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40677	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40678	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40679	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
40680	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
40681	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	72.0	
40682	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	126.0	
40683	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	146.0	
40684	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
40685	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
40686	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
40687	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
40688	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
40689	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
40690	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
40691	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
40692	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
40693	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
40694	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
40695	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
40696	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments		
40697	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
40698	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
40699	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
40700	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	3	
40701	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
40702	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
40703	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
40704	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
40705	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
40706	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
40707	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79891	
40708	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
40709	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
40710	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
40711	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
40712	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
40713	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
40714	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
40715	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
40716	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
40717	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
40718	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
40719	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
40720	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
40721	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
40722	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
40723	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
40724	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
40725	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
40726	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40727	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
40728	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
40729	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40730	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	1	
40731	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	1	
40732	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	143	
40733	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	143	
40734	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
40735	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
40736	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
40737	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
40738	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
40739	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
40740	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40741	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
40742	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40743	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40744	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
40745	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
40746	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
40747	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
40748	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
40749	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
40750	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
40751	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40752	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
40753	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
40754	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
40755	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
40756	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
40757	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
40758	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
40759	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
40760	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
40761	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	3	
40762	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	3	
40763	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	169	
40764	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40765	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
40766	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
40767	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
40768	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
40769	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
40770	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40771	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments		
40772	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
40773	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
40774	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	10013.76	kw
40775	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
40776	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
40777	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
40778	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
40779	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
40780	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
40781	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
40782	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
40783	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
40784	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
40785	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
40786	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
40787	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
40788	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
40789	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
40790	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	169	
40791	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
40792	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
40793	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
40794	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
40795	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
40796	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
40797	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
40798	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
40799	12/4/2019 15:19	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
40800	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
40801	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40802	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
40803	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
40804	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
40805	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Ph AM	0.00	
40806	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
40807	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40808	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
40809	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
40810	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
40811	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
40812	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
40813	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
40814	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
40815	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
40816	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
40817	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
40818	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
40819	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
40820	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40821	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
40822	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
40823	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
40824	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
40825	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
40826	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40827	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
40828	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
40829	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
40830	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
40831	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
40832	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
40833	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
40834	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
40835	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
40836	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
40837	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
40838	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	62152	
40839	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
40840	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
40841	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
40842	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
40843	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
40844	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	6215.04	kw
40845	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
40846	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
40847	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	60	°C
40848	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	40	°C
40849	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
40850	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
40851	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
40852	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
40853	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
40854	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
40855	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40856	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
40857	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
40858	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
40859	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
40860	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
40861	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	472	
40862	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	472	
40863	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
40864	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
40865	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
40866	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
40867	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
40868	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
40869	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
40870	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	743	
40871	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
40872	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
40873	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
40874	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
40875	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
40876	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40877	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
40878	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
40879	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
40880	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
40881	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	28054	
40882	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	28054	
40883	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
40884	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
40885	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
40886	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
40887	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	18.0	
40888	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
40889	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	13.0	
40890	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40891	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
40892	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
40893	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
40894	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
40895	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
40896	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
40897	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
40898	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
40899	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
40900	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
40901	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
40902	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
40903	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
40904	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
40905	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
40906	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
40907	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
40908	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
40909	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
40910	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
40911	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
40912	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
40913	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
40914	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
40915	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
40916	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
40917	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
40918	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	1	
40919	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
40920	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	1	
40921	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	242	
40922	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	242	
40923	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
40924	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
40925	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
40926	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
40927	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
40928	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
40929	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
40930	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
40931	12/4/2019 15:19	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
40932	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
40933	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
40934	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
40935	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
40936	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
40937	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
40938	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
40939	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
40940	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
40941	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
40942	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
40943	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
40944	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
40945	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
40946	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
40947	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
40948	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
40949	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
40950	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
40951	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
40952	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
40953	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
40954	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
40955	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
40956	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
40957	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	47	°C
40958	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
40959	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
40960	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
40961	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
40962	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
40963	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
40964	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
40965	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
40966	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
40967	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
40968	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
40969	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
40970	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
40971	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
40972	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	60906	
40973	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
40974	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
40975	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
40976	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
40977	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
40978	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
40979	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
40980	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
40981	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
40982	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
40983	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
40984	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
40985	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
40986	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
40987	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
40988	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
40989	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
40990	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
40991	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
40992	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
40993	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
40994	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
40995	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	68	°C
40996	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	48	°C
40997	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
40998	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
40999	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
41000	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
41001	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
41002	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
41003	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
41004	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
41005	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
41006	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
41007	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
41008	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
41009	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
41010	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
41011	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
41012	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
41013	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
41014	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
41015	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
41016	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
41017	12/4/2019 11:00	Distribution	Elizabethtown 5 Quarterly Inspection	LTC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
41018	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
41019	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
41020	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
41021	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
41022	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
41023	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
41024	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
41025	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
41026	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41027	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
41028	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
41029	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
41030	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
41031	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
41032	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
41033	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
41034	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
41035	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
41036	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
41037	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41038	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
41039	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41040	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41041	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
41042	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
41043	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
41044	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	90.0	
41045	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
41046	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	55.0	
41047	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
41048	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
41049	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
41050	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	34	
41051	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
41052	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
41053	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
41054	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
41055	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
41056	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
41057	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
41058	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
41059	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
41060	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
41061	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
41062	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3R	
41063	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
41064	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
41065	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
41066	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
41067	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
41068	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
41069	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
41070	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
41071	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
41072	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
41073	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
41074	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
41075	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
41076	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
41077	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
41078	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
41079	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
41080	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
41081	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
41082	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
41083	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	4414	
41084	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	4414	
41085	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
41086	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	12L	
41087	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	6L	
41088	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	16L	
41089	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
41090	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	724	
41091	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
41092	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
41093	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
41094	12/4/2019 14:15	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
41095	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
41096	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
41097	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	0	
41098	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	0	
41099	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	238	
41100	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	238	
41101	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41102	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
41103	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
41104	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
41105	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	2	
41106	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
41107	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
41108	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
41109	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
41110	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
41111	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
41112	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
41113	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
41114	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
41115	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
41116	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
41117	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
41118	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41119	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
41120	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41121	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41122	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
41123	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
41124	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
41125	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	100.0	
41126	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	110.0	
41127	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	85.0	
41128	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
41129	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
41130	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
41131	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
41132	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
41133	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
41134	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
41135	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
41136	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
41137	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
41138	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
41139	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
41140	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	2R	
41141	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
41142	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
41143	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41144	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41145	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
41146	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.6954	
41147	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	43	°C
41148	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	20	°C
41149	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
41150	12/4/2019 15:19	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
41151	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
41152	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
41153	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
41154	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
41155	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
41156	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	loose desiccant	
41157	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	84363	
41158	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
41159	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
41160	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
41161	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
41162	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
41163	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
41164	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
41165	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
41166	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	84363	
41167	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
41168	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
41169	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
41170	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
41171	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	109	
41172	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
41173	12/4/2019 15:27	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
41174	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41175	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41176	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	29	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41177	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
41178	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	65703	
41179	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
41180	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
41181	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
41182	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
41183	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
41184	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
41185	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
41186	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
41187	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
41188	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
41189	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
41190	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
41191	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
41192	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
41193	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
41194	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
41195	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
41196	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
41197	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
41198	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
41199	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
41200	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
41201	12/9/2019 7:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
41202	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
41203	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
41204	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
41205	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
41206	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
41207	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
41208	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
41209	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
41210	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
41211	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
41212	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
41213	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	131	
41214	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	131	
41215	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
41216	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
41217	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
41218	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
41219	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
41220	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
41221	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
41222	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
41223	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
41224	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
41225	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
41226	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
41227	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41228	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
41229	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
41230	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
41231	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
41232	12/4/2019 13:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
41233	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
41234	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
41235	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
41236	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
41237	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
41238	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
41239	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
41240	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
41241	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
41242	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
41243	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
41244	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
41245	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
41246	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
41247	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
41248	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
41249	12/4/2019 14:24	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
41250	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
41251	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41252	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3	
41253	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
41254	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
41255	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
41256	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
41257	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments	Front posts near gate not aligned.	
41258	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
41259	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
41260	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
41261	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
41262	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
41263	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
41264	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	553	
41265	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
41266	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
41267	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
41268	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
41269	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
41270	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	100.0	
41271	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	95.0	
41272	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	11	
41273	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	0	
41274	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments		
41275	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	General Comments		
41276	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Follow-up Action Required?	n	
41277	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
41278	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	100.0	
41279	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
41280	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
41281	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.8	
41282	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.0	
41283	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.3	
41284	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
41285	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
41286	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
41287	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
41288	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
41289	12/4/2019 15:14	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
41290	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
41291	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Fault Operations	0	
41292	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
41293	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
41294	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
41295	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
41296	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
41297	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
41298	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
41299	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
41300	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
41301	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
41302	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
41303	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
41304	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
41305	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
41306	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
41307	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
41308	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
41309	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
41310	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
41311	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
41312	12/4/2019 11:51	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
41313	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
41314	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	0	
41315	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	0	
41316	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	662	
41317	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
41318	12/4/2019 12:16	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
41319	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
41320	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
41321	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
41322	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
41323	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
41324	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
41325	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
41326	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41327	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
41328	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
41329	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
41330	12/4/2019 11:36	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	89469	
41331	12/4/2019 11:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	662	
41332	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
41333	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
41334	12/4/2019 15:14	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
41335	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
41336	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
41337	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	926	
41338	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	926	
41339	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
41340	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
41341	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
41342	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
41343	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	2	
41344	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
41345	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
41346	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
41347	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
41348	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
41349	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	225.0	
41350	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	230.0	
41351	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	210.0	
41352	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41353	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41354	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41355	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	29	
41356	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
41357	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
41358	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41359	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
41360	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41361	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41362	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41363	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	225.0	
41364	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
41365	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	275.0	
41366	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
41367	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
41368	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
41369	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
41370	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
41371	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
41372	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
41373	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	726	
41374	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	726	
41375	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
41376	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
41377	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
41378	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
41379	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
41380	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41381	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
41382	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
41383	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
41384	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
41385	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	647	
41386	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	647	
41387	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
41388	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
41389	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
41390	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
41391	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41392	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41393	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
41394	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
41395	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
41396	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
41397	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
41398	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
41399	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
41400	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41401	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	125.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
41402	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	125.0	
41403	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	130.0	
41404	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
41405	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
41406	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0064	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41407	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Follow-up Action Required?	n	
41408	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations Ground	0	
41409	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps B Ø	75.0	
41410	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps C Ø	100.0	
41411	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
41412	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
41413	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
41414	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	General Comments		
41415	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Maintenance Operations	0	
41416	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AF	643	
41417	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AL	643	
41418	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations This Read AM	2	
41419	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Switching Operations	0	
41420	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations A Ø	1	
41421	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps A Ø	100.0	
41422	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41423	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations C Ø	0	
41424	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations B Ø	1	
41425	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41426	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41427	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	9 Months Operations	3	
41428	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41429	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Follow-up Action Required?	n	
41430	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	General Comments		
41431	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
41432	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations This Read AM	0	
41433	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	403	
41434	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	403	
41435	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
41436	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
41437	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
41438	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
41439	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
41440	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
41441	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
41442	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
41443	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
41444	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
41445	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	693.0	
41446	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	648.0	
41447	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	627.0	
41448	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41449	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41450	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41451	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	0	
41452	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
41453	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
41454	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41455	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
41456	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
41457	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
41458	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	62	°C
41459	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	38	°C
41460	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
41461	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
41462	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	72	°C
41463	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	43	°C
41464	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	74	°C
41465	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	44	°C
41466	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	76	°C
41467	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	44	°C
41468	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
41469	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
41470	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
41471	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
41472	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
41473	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
41474	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
41475	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
41476	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41477	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
41478	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
41479	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
41480	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
41481	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
41482	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
41483	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
41484	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
41485	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
41486	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
41487	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
41488	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
41489	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
41490	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
41491	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
41492	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
41493	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
41494	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
41495	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41496	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41497	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
41498	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
41499	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
41500	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
41501	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
41502	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
41503	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
41504	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
41505	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
41506	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
41507	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
41508	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
41509	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	85.0	
41510	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	89.0	
41511	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
41512	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
41513	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
41514	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
41515	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
41516	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	347	
41517	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
41518	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
41519	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41520	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41521	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
41522	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
41523	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
41524	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
41525	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
41526	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	45	°C
41527	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	60	°C
41528	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
41529	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
41530	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	15076.80	kw
41531	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
41532	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
41533	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
41534	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
41535	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
41536	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
41537	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
41538	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
41539	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
41540	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
41541	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
41542	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
41543	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
41544	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
41545	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
41546	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
41547	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
41548	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
41549	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
41550	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
41551	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
41552	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
41553	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41554	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
41555	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41556	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41557	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	55	°C
41558	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	42	°C
41559	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
41560	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
41561	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
41562	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
41563	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
41564	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	200.0	
41565	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
41566	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
41567	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
41568	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	1189	
41569	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
41570	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	1	
41571	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
41572	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
41573	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
41574	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
41575	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
41576	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
41577	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.8376	
41578	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
41579	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41580	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41581	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
41582	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
41583	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
41584	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
41585	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
41586	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
41587	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	403	
41588	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	403	
41589	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	1	
41590	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
41591	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	0	
41592	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
41593	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
41594	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
41595	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	Follow-up Action Required?	n	
41596	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	General Comments		
41597	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
41598	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
41599	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
41600	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
41601	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
41602	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
41603	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
41604	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
41605	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
41606	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
41607	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
41608	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
41609	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
41610	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
41611	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
41612	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
41613	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	641	
41614	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
41615	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
41616	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	11L	
41617	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	5L	
41618	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	8L	
41619	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.9822	
41620	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
41621	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	50	°C
41622	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	85	°C
41623	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	17679.60	kw
41624	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
41625	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
41626	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41627	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
41628	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
41629	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
41630	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
41631	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	.8112	
41632	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	71842	
41633	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	71842	
41634	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
41635	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
41636	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
41637	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
41638	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
41639	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
41640	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
41641	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	off
41642	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
41643	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
41644	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41645	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41646	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
41647	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
41648	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
41649	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
41650	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
41651	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	50	°C
41652	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
41653	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
41654	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
41655	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
41656	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
41657	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
41658	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
41659	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
41660	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
41661	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
41662	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
41663	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
41664	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
41665	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
41666	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	60	°C
41667	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	95	°C
41668	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
41669	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
41670	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
41671	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
41672	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
41673	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
41674	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
41675	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
41676	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
41677	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
41678	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
41679	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
41680	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
41681	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
41682	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
41683	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
41684	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
41685	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
41686	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
41687	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallel	IPAR
41688	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
41689	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
41690	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
41691	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
41692	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
41693	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
41694	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
41695	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
41696	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
41697	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
41698	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
41699	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
41700	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
41701	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41702	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
41703	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
41704	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
41705	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
41706	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
41707	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
41708	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
41709	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
41710	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
41711	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
41712	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
41713	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
41714	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
41715	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
41716	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
41717	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41718	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
41719	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41720	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41721	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
41722	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
41723	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
41724	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
41725	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
41726	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
41727	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
41728	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
41729	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
41730	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	5	
41731	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	19	
41732	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
41733	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	8	
41734	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
41735	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
41736	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	General Comments		
41737	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
41738	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
41739	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
41740	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
41741	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
41742	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
41743	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
41744	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
41745	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	0	
41746	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
41747	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	0	
41748	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	261	
41749	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	261	
41750	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
41751	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
41752	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
41753	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
41754	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
41755	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
41756	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
41757	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
41758	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
41759	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
41760	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
41761	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
41762	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
41763	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
41764	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
41765	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
41766	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
41767	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
41768	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
41769	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
41770	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	11R	
41771	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	29	
41772	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	1	
41773	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	1	
41774	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
41775	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
41776	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
41777	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
41778	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
41779	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
41780	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
41781	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
41782	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	194742	
41783	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
41784	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
41785	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
41786	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
41787	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
41788	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
41789	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
41790	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
41791	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
41792	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
41793	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
41794	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
41795	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	0	
41796	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
41797	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
41798	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
41799	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
41800	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
41801	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
41802	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
41803	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
41804	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
41805	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
41806	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
41807	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
41808	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
41809	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
41810	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
41811	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
41812	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
41813	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
41814	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
41815	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	8	
41816	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	34	
41817	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	34	
41818	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
41819	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
41820	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	0	
41821	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
41822	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	0	
41823	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	615	
41824	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	615	
41825	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
41826	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
41827	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
41828	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
41829	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
41830	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
41831	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
41832	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
41833	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
41834	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
41835	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
41836	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20	
41837	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20	
41838	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20	
41839	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
41840	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
41841	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
41842	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
41843	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
41844	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
41845	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
41846	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
41847	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
41848	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
41849	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
41850	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
41851	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41852	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	14R	
41853	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	7R	
41854	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
41855	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
41856	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
41857	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
41858	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
41859	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	118455	
41860	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
41861	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
41862	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
41863	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
41864	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
41865	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
41866	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
41867	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
41868	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
41869	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
41870	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
41871	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
41872	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
41873	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
41874	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
41875	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
41876	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
41877	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
41878	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
41879	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
41880	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
41881	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
41882	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
41883	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
41884	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
41885	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
41886	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
41887	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
41888	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
41889	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
41890	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	9	
41891	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
41892	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
41893	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
41894	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	200.0	
41895	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	180.0	
41896	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	194749	
41897	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
41898	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	3L	
41899	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	2L	
41900	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	13L	
41901	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
41902	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
41903	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
41904	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
41905	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
41906	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0	
41907	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0	
41908	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0	
41909	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
41910	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
41911	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41912	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41913	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
41914	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
41915	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
41916	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	120	
41917	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	130	
41918	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	180	
41919	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0	%
41920	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	2.13	%
41921	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	2.85	%
41922	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	26	
41923	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
41924	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
41925	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
41926	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
41927	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
41928	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
41929	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
41930	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
41931	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
41932	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
41933	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
41934	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
41935	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
41936	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
41937	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
41938	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
41939	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
41940	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
41941	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
41942	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
41943	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
41944	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
41945	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
41946	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
41947	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
41948	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
41949	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
41950	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
41951	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
41952	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
41953	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
41954	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
41955	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
41956	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
41957	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
41958	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
41959	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
41960	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
41961	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
41962	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
41963	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
41964	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
41965	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
41966	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
41967	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
41968	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
41969	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
41970	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.4572	
41971	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
41972	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
41973	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
41974	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
41975	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
41976	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
41977	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
41978	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	293	
41979	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
41980	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
41981	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
41982	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
41983	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
41984	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
41985	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
41986	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
41987	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
41988	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
41989	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
41990	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
41991	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
41992	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
41993	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
41994	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
41995	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
41996	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
41997	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
41998	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
41999	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
42000	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B80242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
42001	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
42002	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
42003	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42004	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	555	
42005	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	555	
42006	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	3291.84	kw
42007	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
42008	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
42009	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
42010	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42011	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
42012	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
42013	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42014	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42015	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
42016	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
42017	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42018	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42019	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
42020	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
42021	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
42022	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	1	
42023	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
42024	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	1	
42025	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	166	
42026	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	166	
42027	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
42028	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
42029	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
42030	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
42031	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60	
42032	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60	
42033	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
42034	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
42035	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
42036	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
42037	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
42038	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
42039	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42040	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180	
42041	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
42042	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
42043	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
42044	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5179.68	kw
42045	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
42046	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
42047	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42048	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
42049	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
42050	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
42051	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
42052	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
42053	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
42054	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	184	
42055	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	184	
42056	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
42057	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
42058	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
42059	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
42060	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
42061	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
42062	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
42063	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
42064	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
42065	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42066	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
42067	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
42068	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
42069	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	83.0	
42070	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
42071	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
42072	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
42073	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
42074	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
42075	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
42076	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42077	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
42078	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
42079	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
42080	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	5	
42081	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42082	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42083	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42084	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42085	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42086	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42087	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42088	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
42089	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
42090	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3012.48	kw
42091	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.5	
42092	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
42093	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
42094	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
42095	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42096	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
42097	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42098	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42099	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
42100	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
42101	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
42102	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42103	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42104	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
42105	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
42106	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
42107	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
42108	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
42109	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
42110	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
42111	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
42112	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
42113	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	190.0	
42114	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
42115	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
42116	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	50.0	
42117	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	50.0	
42118	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
42119	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
42120	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
42121	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
42122	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
42123	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
42124	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	50.0	
42125	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
42126	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
42127	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
42128	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
42129	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
42130	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
42131	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42132	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
42133	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9414	
42134	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
42135	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
42136	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
42137	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
42138	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
42139	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
42140	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
42141	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
42142	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
42143	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
42144	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
42145	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
42146	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
42147	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42148	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
42149	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
42150	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42151	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42152	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42153	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42154	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42155	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42156	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42157	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
42158	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
42159	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
42160	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	480.0	
42161	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42162	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
42163	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
42164	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
42165	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
42166	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
42167	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
42168	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
42169	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	323	
42170	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	323	
42171	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
42172	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
42173	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
42174	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
42175	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
42176	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
42177	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
42178	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
42179	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
42180	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
42181	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
42182	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
42183	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
42184	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42185	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42186	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42187	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	480.0	
42188	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	480.0	
42189	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
42190	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
42191	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42192	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
42193	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42194	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
42195	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42196	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42197	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
42198	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
42199	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
42200	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
42201	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
42202	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
42203	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
42204	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42205	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42206	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42207	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
42208	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
42209	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42210	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
42211	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
42212	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42213	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
42214	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
42215	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
42216	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
42217	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
42218	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2540	kw
42219	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
42220	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
42221	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
42222	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
42223	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
42224	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
42225	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
42226	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42227	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
42228	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
42229	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
42230	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
42231	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
42232	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
42233	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
42234	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
42235	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
42236	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
42237	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
42238	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
42239	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
42240	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
42241	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
42242	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
42243	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
42244	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
42245	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
42246	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42247	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	5840.64	kw
42248	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
42249	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
42250	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
42251	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
42252	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
42253	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
42254	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42255	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42256	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42257	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42258	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	O0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42259	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
42260	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42261	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
42262	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
42263	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
42264	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCCControl	683-1	LTC Control Insp	General Comments		
42265	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
42266	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCCControl	683-1	LTC Control Insp	All Connections OK?	y	
42267	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
42268	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
42269	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42270	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
42271	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
42272	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42273	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42274	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42275	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42276	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42277	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42278	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42279	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
42280	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
42281	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
42282	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
42283	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42284	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
42285	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
42286	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	220	
42287	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	220	
42288	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
42289	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
42290	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42291	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42292	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42293	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42294	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42295	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42296	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
42297	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
42298	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
42299	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
42300	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42301	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs paint	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42302	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
42303	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
42304	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
42305	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42306	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42307	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42308	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
42309	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42310	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42311	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
42312	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
42313	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
42314	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
42315	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
42316	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
42317	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42318	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1000	
42319	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.54	
42320	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
42321	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
42322	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42323	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42324	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
42325	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
42326	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42327	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42328	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42329	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
42330	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
42331	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
42332	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
42333	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
42334	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
42335	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42336	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42337	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
42338	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
42339	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
42340	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
42341	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42342	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
42343	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
42344	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
42345	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
42346	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
42347	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
42348	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
42349	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	General Comments		
42350	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
42351	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
42352	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
42353	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
42354	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
42355	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
42356	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
42357	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
42358	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
42359	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7194	
42360	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
42361	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
42362	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42363	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
42364	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
42365	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
42366	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
42367	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
42368	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
42369	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
42370	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
42371	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
42372	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
42373	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
42374	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	500	
42375	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
42376	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	15151	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
42377	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
42378	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
42379	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
42380	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
42381	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
42382	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
42383	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
42384	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
42385	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
42386	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
42387	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
42388	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
42389	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
42390	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
42391	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
42392	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
42393	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	496	
42394	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
42395	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
42396	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
42397	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
42398	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
42399	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
42400	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
42401	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
42402	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
42403	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
42404	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
42405	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
42406	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
42407	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
42408	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42409	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42410	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
42411	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
42412	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
42413	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
42414	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
42415	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
42416	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
42417	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
42418	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
42419	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
42420	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
42421	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
42422	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
42423	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
42424	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
42425	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
42426	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
42427	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
42428	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	88	
42429	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	88	
42430	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
42431	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
42432	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
42433	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
42434	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
42435	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
42436	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	243	
42437	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	243	
42438	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
42439	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
42440	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
42441	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
42442	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
42443	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
42444	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
42445	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42446	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
42447	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
42448	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
42449	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
42450	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42451	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
42452	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
42453	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
42454	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
42455	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.71	%
42456	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
42457	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
42458	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
42459	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
42460	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
42461	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
42462	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
42463	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
42464	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
42465	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
42466	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
42467	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
42468	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
42469	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
42470	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
42471	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
42472	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
42473	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
42474	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
42475	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
42476	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
42477	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
42478	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	74492	
42479	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
42480	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
42481	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
42482	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
42483	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
42484	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
42485	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42486	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42487	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42488	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
42489	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
42490	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
42491	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
42492	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42493	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42494	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42495	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
42496	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
42497	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
42498	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
42499	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
42500	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.63	%
42501	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.55	%
42502	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
42503	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
42504	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
42505	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
42506	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
42507	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
42508	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
42509	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
42510	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
42511	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
42512	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
42513	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
42514	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
42515	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42516	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42517	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42518	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
42519	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
42520	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	225.0	
42521	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	184.0	
42522	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	200.0	
42523	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	6.46	%
42524	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	3.06	%
42525	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	10.54	%
42526	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	5	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42527	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
42528	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
42529	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
42530	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
42531	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
42532	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
42533	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
42534	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
42535	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42536	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
42537	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
42538	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
42539	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
42540	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
42541	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
42542	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42543	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42544	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
42545	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
42546	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
42547	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
42548	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.7308	
42549	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTC000248	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
42550	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTC000248	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
42551	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
42552	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42553	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
42554	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
42555	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42556	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42557	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
42558	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
42559	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
42560	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
42561	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
42562	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
42563	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
42564	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	2R	
42565	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	6R	
42566	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
42567	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		
42568	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
42569	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
42570	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
42571	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
42572	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	4R	
42573	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
42574	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
42575	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
42576	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
42577	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
42578	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
42579	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
42580	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
42581	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Leaks	None	
42582	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
42583	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
42584	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42585	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	25	°C
42586	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	33	°C
42587	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
42588	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42589	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	7015.68	kw
42590	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
42591	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25771	
42592	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
42593	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
42594	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
42595	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
42596	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
42597	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
42598	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
42599	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
42600	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
42601	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42602	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
42603	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
42604	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	29	°C
42605	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	35	°C
42606	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.8082	
42607	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
42608	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Present	71	°C
42609	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Max	75	°C
42610	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
42611	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
42612	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
42613	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
42614	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
42615	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
42616	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
42617	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
42618	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
42619	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
42620	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
42621	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.2	VDC
42622	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
42623	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
42624	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
42625	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
42626	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
42627	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
42628	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
42629	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42630	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
42631	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
42632	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42633	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42634	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
42635	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42636	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
42637	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42638	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	11638.08	kw
42639	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
42640	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
42641	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
42642	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42643	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
42644	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
42645	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42646	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
42647	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
42648	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
42649	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
42650	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
42651	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42652	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42653	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42654	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42655	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
42656	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
42657	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
42658	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
42659	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
42660	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
42661	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
42662	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
42663	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
42664	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
42665	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
42666	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
42667	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
42668	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
42669	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
42670	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
42671	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
42672	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
42673	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
42674	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
42675	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
42676	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42677	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
42678	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
42679	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
42680	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
42681	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
42682	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
42683	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
42684	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
42685	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42686	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42687	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
42688	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
42689	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
42690	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
42691	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
42692	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
42693	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
42694	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
42695	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
42696	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
42697	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	0	
42698	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
42699	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
42700	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
42701	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.5	
42702	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	45.6	
42703	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
42704	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
42705	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
42706	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
42707	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
42708	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
42709	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
42710	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
42711	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	298	
42712	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
42713	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
42714	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	0	
42715	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
42716	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
42717	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
42718	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
42719	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
42720	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
42721	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments	drive needs repair	
42722	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
42723	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
42724	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
42725	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
42726	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
42727	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
42728	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
42729	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
42730	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
42731	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
42732	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
42733	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
42734	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
42735	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
42736	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
42737	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
42738	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
42739	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
42740	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
42741	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
42742	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
42743	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
42744	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
42745	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
42746	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
42747	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
42748	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
42749	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
42750	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
42751	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
42752	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
42753	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
42754	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
42755	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
42756	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
42757	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
42758	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
42759	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
42760	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
42761	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
42762	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
42763	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
42764	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
42765	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
42766	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
42767	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	0	
42768	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
42769	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	0	
42770	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	447	
42771	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	447	
42772	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
42773	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
42774	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
42775	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
42776	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
42777	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
42778	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	17760	
42779	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	17760	
42780	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
42781	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	6L	
42782	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	5L	
42783	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
42784	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
42785	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
42786	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
42787	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
42788	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
42789	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
42790	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
42791	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
42792	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
42793	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
42794	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
42795	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
42796	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
42797	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
42798	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
42799	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
42800	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
42801	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
42802	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	11L	
42803	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	525	
42804	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
42805	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
42806	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
42807	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
42808	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
42809	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
42810	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
42811	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
42812	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
42813	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
42814	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
42815	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
42816	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
42817	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
42818	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
42819	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
42820	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	298	
42821	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
42822	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
42823	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
42824	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
42825	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	298	
42826	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42827	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
42828	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
42829	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	General Comments		
42830	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
42831	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
42832	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
42833	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
42834	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
42835	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	239	
42836	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	239	
42837	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
42838	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
42839	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	60.0	
42840	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	110.0	
42841	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	60.0	
42842	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
42843	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
42844	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
42845	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
42846	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
42847	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
42848	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
42849	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
42850	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
42851	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
42852	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
42853	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
42854	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	5	
42855	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
42856	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
42857	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
42858	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
42859	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
42860	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
42861	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
42862	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
42863	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
42864	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
42865	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
42866	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
42867	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
42868	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
42869	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
42870	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
42871	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
42872	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
42873	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
42874	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
42875	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
42876	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
42877	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
42878	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	6782.40	kw
42879	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
42880	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
42881	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	43	°C
42882	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	35	°C
42883	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
42884	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
42885	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42886	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42887	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
42888	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
42889	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42890	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
42891	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.9420	
42892	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
42893	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
42894	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
42895	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
42896	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
42897	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
42898	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	2L	
42899	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	6L	
42900	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	2R	
42901	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42902	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	479	
42903	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
42904	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
42905	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
42906	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
42907	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	1	
42908	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
42909	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
42910	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
42911	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
42912	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
42913	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
42914	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
42915	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
42916	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
42917	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
42918	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
42919	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
42920	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
42921	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
42922	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
42923	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
42924	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
42925	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
42926	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
42927	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
42928	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
42929	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
42930	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
42931	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
42932	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
42933	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
42934	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
42935	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
42936	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
42937	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
42938	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
42939	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
42940	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
42941	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
42942	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
42943	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
42944	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
42945	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	100.00	
42946	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
42947	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.6438	
42948	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
42949	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
42950	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
42951	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
42952	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
42953	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
42954	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
42955	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
42956	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
42957	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
42958	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
42959	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
42960	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
42961	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
42962	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
42963	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
42964	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
42965	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
42966	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
42967	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
42968	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
42969	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
42970	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	67856	
42971	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	67860	
42972	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
42973	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
42974	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
42975	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
42976	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
42977	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	7L	
42978	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	2L	
42979	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	11L	
42980	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	439	
42981	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
42982	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
42983	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
42984	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
42985	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
42986	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
42987	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
42988	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	229430	
42989	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	229433	
42990	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
42991	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
42992	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
42993	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
42994	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
42995	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
42996	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
42997	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
42998	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
42999	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
43000	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments	There are a few washouts underneath the substation fence	
43001	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
43002	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
43003	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	0	
43004	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43005	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	1	
43006	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	450	
43007	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	450	
43008	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
43009	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
43010	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43011	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
43012	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
43013	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
43014	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
43015	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	4635.36	kw
43016	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
43017	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
43018	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
43019	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43020	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
43021	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
43022	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
43023	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
43024	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43025	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43026	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43027	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43028	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
43029	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
43030	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
43031	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	90	
43032	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
43033	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
43034	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
43035	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
43036	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
43037	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
43038	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
43039	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
43040	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
43041	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
43042	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
43043	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
43044	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
43045	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	54.0	
43046	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
43047	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	48.0	
43048	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43049	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43050	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
43051	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43052	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
43053	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43054	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
43055	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
43056	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
43057	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
43058	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
43059	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
43060	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
43061	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	0	
43062	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	0	
43063	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	324	
43064	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	324	
43065	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
43066	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
43067	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
43068	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
43069	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
43070	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
43071	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
43072	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
43073	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
43074	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	29	
43075	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
43076	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	45	°C
43077	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	°C
43078	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
43079	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
43080	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
43081	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
43082	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
43083	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
43084	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
43085	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
43086	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
43087	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
43088	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
43089	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0	
43090	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	1.48	
43091	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0	
43092	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43093	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43094	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43095	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43096	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43097	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43098	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
43099	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	140	
43100	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	120	
43101	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	120	
43102	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
43103	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
43104	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
43105	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	8	
43106	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
43107	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
43108	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
43109	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
43110	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	94867	
43111	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
43112	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
43113	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
43114	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
43115	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
43116	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
43117	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
43118	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
43119	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments	STILL BROKE	
43120	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
43121	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
43122	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
43123	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
43124	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
43125	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
43126	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43127	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
43128	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
43129	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
43130	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
43131	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43132	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
43133	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
43134	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
43135	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
43136	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
43137	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
43138	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
43139	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
43140	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
43141	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
43142	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
43143	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
43144	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
43145	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	1015	
43146	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
43147	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
43148	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
43149	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
43150	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
43151	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
43152	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
43153	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
43154	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
43155	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
43156	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	118455	
43157	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	118450	
43158	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
43159	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
43160	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
43161	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
43162	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
43163	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	7R	
43164	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
43165	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
43166	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
43167	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
43168	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
43169	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
43170	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
43171	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	21.94	%
43172	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
43173	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
43174	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
43175	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
43176	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
43177	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	69757	
43178	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	14R	
43179	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
43180	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
43181	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
43182	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
43183	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
43184	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
43185	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
43186	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
43187	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
43188	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
43189	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
43190	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	11R	
43191	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
43192	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
43193	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
43194	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
43195	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
43196	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
43197	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
43198	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
43199	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
43200	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
43201	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43202	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
43203	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
43204	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
43205	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
43206	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
43207	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
43208	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
43209	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
43210	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
43211	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
43212	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
43213	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
43214	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
43215	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
43216	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
43217	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
43218	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	General Comments		
43219	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
43220	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
43221	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
43222	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
43223	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
43224	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
43225	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	326	
43226	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
43227	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
43228	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
43229	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
43230	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
43231	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
43232	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
43233	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
43234	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
43235	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
43236	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
43237	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
43238	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
43239	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	74.3	
43240	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	57.5	
43241	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
43242	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
43243	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	70.0	
43244	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
43245	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
43246	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
43247	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
43248	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
43249	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
43250	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
43251	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
43252	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
43253	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
43254	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	LTCC000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124	VAC
43255	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
43256	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
43257	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
43258	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
43259	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
43260	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
43261	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
43262	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
43263	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
43264	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
43265	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
43266	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
43267	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
43268	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
43269	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
43270	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43271	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43272	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
43273	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43274	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
43275	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
43276	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	179671	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
43277	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	179671	
43278	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
43279	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
43280	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
43281	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
43282	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	412	
43283	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
43284	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43285	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43286	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
43287	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
43288	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
43289	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
43290	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
43291	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
43292	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
43293	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
43294	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
43295	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
43296	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
43297	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
43298	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
43299	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
43300	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
43301	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
43302	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
43303	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
43304	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
43305	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
43306	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
43307	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
43308	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	General Comments		
43309	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
43310	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43311	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
43312	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
43313	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
43314	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
43315	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
43316	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
43317	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
43318	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
43319	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
43320	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
43321	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
43322	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
43323	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
43324	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
43325	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
43326	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43327	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
43328	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
43329	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	227313	
43330	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	227313	
43331	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
43332	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
43333	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
43334	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
43335	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
43336	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
43337	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	*C
43338	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	*C
43339	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1087	
43340	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
43341	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
43342	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
43343	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
43344	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
43345	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
43346	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	64423	
43347	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
43348	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
43349	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
43350	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
43351	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43352	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
43353	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
43354	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
43355	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments	this is C phase reg	
43356	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
43357	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
43358	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
43359	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
43360	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
43361	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
43362	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
43363	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
43364	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
43365	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
43366	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
43367	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
43368	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
43369	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
43370	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
43371	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	y	
43372	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
43373	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BC000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
43374	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BC000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
43375	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43376	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43377	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43378	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
43379	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
43380	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
43381	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
43382	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
43383	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
43384	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
43385	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
43386	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
43387	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
43388	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
43389	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
43390	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
43391	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
43392	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
43393	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	6	
43394	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43395	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43396	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43397	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	89.0	
43398	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	80.0	
43399	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	71.0	
43400	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
43401	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43402	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43403	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43404	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43405	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43406	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43407	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43408	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43409	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43410	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
43411	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
43412	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
43413	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
43414	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
43415	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
43416	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
43417	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
43418	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
43419	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
43420	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43421	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
43422	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
43423	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	178	
43424	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	178	
43425	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	0	
43426	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43427	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
43428	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
43429	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
43430	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
43431	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
43432	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
43433	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
43434	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
43435	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
43436	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
43437	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43438	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
43439	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43440	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
43441	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
43442	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
43443	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
43444	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43445	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43446	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43447	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43448	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43449	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43450	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
43451	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
43452	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
43453	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
43454	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
43455	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
43456	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
43457	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
43458	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
43459	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
43460	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	228	
43461	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	0	
43462	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	0	
43463	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
43464	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
43465	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	23	
43466	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43467	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43468	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43469	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	200.0	
43470	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	206.0	
43471	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	183.0	
43472	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
43473	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43474	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43475	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43476	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43477	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43478	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43479	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43480	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43481	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43482	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	
43483	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	0	
43484	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
43485	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
43486	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
43487	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
43488	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
43489	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
43490	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
43491	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
43492	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
43493	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	1.1	%
43494	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	1.1	%
43495	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	1.1	%
43496	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	480.0	
43497	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	495.0	
43498	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	480.0	
43499	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
43500	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
43501	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43502	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
43503	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
43504	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
43505	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
43506	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
43507	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
43508	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
43509	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
43510	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	*F
43511	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
43512	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	4279.68	kw
43513	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
43514	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
43515	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	55	*C
43516	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	40	*C
43517	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
43518	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
43519	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
43520	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	0	
43521	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43522	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	10	
43523	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	247	
43524	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	247	
43525	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
43526	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	10	
43527	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43528	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
43529	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
43530	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
43531	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
43532	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
43533	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
43534	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
43535	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
43536	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
43537	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
43538	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0	
43539	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0	
43540	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0	
43541	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43542	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43543	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43544	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43545	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43546	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43547	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
43548	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	150	
43549	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	130	
43550	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	130	
43551	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
43552	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	.65	%
43553	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
43554	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	20	
43555	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
43556	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
43557	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
43558	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
43559	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
43560	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
43561	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
43562	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
43563	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
43564	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
43565	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
43566	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
43567	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
43568	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
43569	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
43570	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
43571	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
43572	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
43573	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
43574	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
43575	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
43576	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43577	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43578	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
43579	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
43580	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	4185	
43581	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	4185	
43582	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
43583	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	5L	
43584	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	3L	
43585	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	8L	
43586	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	302	
43587	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
43588	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43589	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43590	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
43591	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
43592	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
43593	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
43594	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
43595	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
43596	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
43597	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43598	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
43599	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	285	
43600	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	285	
43601	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
43602	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
43603	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
43604	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
43605	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
43606	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
43607	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
43608	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
43609	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
43610	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
43611	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
43612	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
43613	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
43614	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
43615	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
43616	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
43617	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
43618	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
43619	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
43620	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
43621	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
43622	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
43623	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
43624	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
43625	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
43626	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
43627	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	211	
43628	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	211	
43629	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	0	
43630	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	0	
43631	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
43632	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
43633	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	22	
43634	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43635	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43636	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43637	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	40.0	
43638	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	40.0	
43639	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	35.0	
43640	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
43641	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43642	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43643	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43644	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43645	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43646	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43647	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43648	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43649	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43650	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A Ø	0	
43651	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43652	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C Ø	0	
43653	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
43654	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
43655	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
43656	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
43657	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
43658	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
43659	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
43660	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	18	
43661	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
43662	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	171	
43663	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	171	
43664	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	20	
43665	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	2	
43666	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
43667	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
43668	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
43669	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
43670	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
43671	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
43672	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	4	
43673	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43674	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43675	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43676	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	27.0	
43677	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	36.0	
43678	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	24.0	
43679	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
43680	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43681	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43682	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43683	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43684	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43685	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	179	
43686	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	179	
43687	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	1	
43688	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	1	
43689	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
43690	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
43691	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
43692	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
43693	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
43694	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
43695	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
43696	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
43697	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
43698	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
43699	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
43700	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
43701	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
43702	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
43703	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
43704	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21973	
43705	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
43706	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
43707	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Leaks	None	
43708	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
43709	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
43710	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
43711	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
43712	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
43713	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
43714	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43715	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
43716	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
43717	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	400546	
43718	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	400554	
43719	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
43720	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	4R	
43721	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	6R	
43722	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	4L	
43723	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1134	
43724	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
43725	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43726	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43727	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
43728	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
43729	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
43730	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
43731	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
43732	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
43733	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
43734	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
43735	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
43736	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
43737	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
43738	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
43739	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
43740	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
43741	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
43742	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
43743	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
43744	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
43745	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
43746	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
43747	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
43748	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
43749	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
43750	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	182	
43751	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	182	
43752	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	1	
43753	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	1	
43754	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
43755	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
43756	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
43757	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43758	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
43759	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43760	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43761	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
43762	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	11	
43763	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
43764	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
43765	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
43766	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
43767	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	8L	
43768	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
43769	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	5L	
43770	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
43771	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	231089	
43772	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	231089	
43773	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
43774	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
43775	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
43776	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
43777	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
43778	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
43779	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
43780	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
43781	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
43782	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
43783	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
43784	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
43785	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
43786	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
43787	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
43788	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
43789	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
43790	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
43791	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
43792	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
43793	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
43794	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
43795	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
43796	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
43797	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
43798	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
43799	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
43800	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
43801	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
43802	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
43803	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
43804	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
43805	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
43806	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
43807	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
43808	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
43809	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43810	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43811	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43812	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43813	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
43814	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
43815	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
43816	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
43817	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
43818	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
43819	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
43820	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
43821	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
43822	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
43823	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
43824	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
43825	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	171	
43826	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	171	
43827	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	0	
43828	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
43829	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
43830	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
43831	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	4	
43832	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43833	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43834	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43835	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	133.0	
43836	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	158.0	
43837	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	184.0	
43838	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
43839	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43840	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43841	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43842	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43843	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43844	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43845	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43846	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
43847	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
43848	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
43849	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
43850	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
43851	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
43852	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
43853	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
43854	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
43855	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
43856	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
43857	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
43858	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
43859	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
43860	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	20626	
43861	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	20626	
43862	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
43863	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
43864	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
43865	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
43866	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
43867	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
43868	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
43869	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
43870	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
43871	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
43872	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
43873	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
43874	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
43875	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
43876	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Present	12	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43877	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
43878	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3186	
43879	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
43880	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
43881	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
43882	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
43883	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
43884	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
43885	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
43886	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
43887	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
43888	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
43889	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
43890	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
43891	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
43892	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
43893	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
43894	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
43895	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
43896	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
43897	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
43898	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
43899	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
43900	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
43901	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
43902	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
43903	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
43904	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
43905	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
43906	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
43907	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
43908	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
43909	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
43910	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
43911	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
43912	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
43913	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
43914	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
43915	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
43916	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
43917	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
43918	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
43919	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
43920	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
43921	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
43922	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
43923	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
43924	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
43925	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	724	
43926	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
43927	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	12L	
43928	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	5L	
43929	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	5L	
43930	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
43931	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	2497	
43932	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	2497	
43933	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B80252	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	25.0	
43934	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B80252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
43935	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B80252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
43936	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B80252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
43937	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B80252	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
43938	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
43939	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
43940	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
43941	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
43942	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	50	*C
43943	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
43944	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
43945	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
43946	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
43947	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
43948	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
43949	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
43950	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
43951	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
43952	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
43953	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
43954	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
43955	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
43956	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
43957	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
43958	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
43959	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
43960	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
43961	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
43962	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	.7356	
43963	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
43964	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	80317	WithLTC	836-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
43965	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
43966	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
43967	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
43968	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
43969	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
43970	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
43971	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
43972	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
43973	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
43974	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
43975	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
43976	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
43977	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments		
43978	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
43979	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
43980	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
43981	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
43982	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	509.76	kw
43983	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
43984	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
43985	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
43986	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
43987	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
43988	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
43989	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
43990	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
43991	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
43992	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
43993	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Max	20	°C
43994	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
43995	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
43996	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
43997	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
43998	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
43999	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
44000	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
44001	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	General Comments		
44002	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
44003	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
44004	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
44005	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
44006	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
44007	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44008	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
44009	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
44010	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	463	
44011	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	463	
44012	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	0	
44013	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
44014	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	0	
44015	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
44016	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
44017	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
44018	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
44019	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
44020	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
44021	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
44022	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
44023	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
44024	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
44025	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
44026	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44027	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
44028	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
44029	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
44030	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
44031	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44032	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
44033	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44034	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
44035	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
44036	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
44037	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
44038	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
44039	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
44040	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
44041	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
44042	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
44043	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	248	
44044	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	248	
44045	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
44046	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
44047	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
44048	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
44049	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
44050	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
44051	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
44052	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
44053	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
44054	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
44055	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
44056	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
44057	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
44058	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
44059	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
44060	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
44061	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
44062	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
44063	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
44064	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
44065	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
44066	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
44067	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
44068	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
44069	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
44070	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
44071	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
44072	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
44073	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
44074	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
44075	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
44076	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
44077	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
44078	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTC0000325	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
44079	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTC0000325	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
44080	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTC0000325	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
44081	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
44082	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
44083	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
44084	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
44085	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
44086	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
44087	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
44088	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	4	
44089	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0	%
44090	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0	%
44091	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0	%
44092	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0	
44093	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0	
44094	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0	
44095	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
44096	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44097	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44098	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44099	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44100	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44101	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	178	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44102	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	178	
44103	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
44104	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
44105	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
44106	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
44107	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
44108	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
44109	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44110	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0	
44111	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0	
44112	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0	
44113	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
44114	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
44115	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
44116	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
44117	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
44118	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
44119	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
44120	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
44121	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
44122	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44123	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44124	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
44125	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
44126	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
44127	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
44128	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
44129	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
44130	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
44131	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	6R	
44132	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	All Connections OK?	y	
44133	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
44134	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	General Comments		
44135	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
44136	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
44137	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
44138	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	2R	
44139	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
44140	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
44141	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
44142	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
44143	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
44144	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
44145	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
44146	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
44147	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
44148	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
44149	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
44150	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
44151	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
44152	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
44153	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
44154	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
44155	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44156	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
44157	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
44158	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
44159	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
44160	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44161	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44162	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
44163	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
44164	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
44165	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	201277	
44166	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44167	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44168	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
44169	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
44170	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
44171	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments		
44172	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
44173	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	2	
44174	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
44175	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	173	
44176	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	173	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44177	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	2	
44178	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	0	
44179	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
44180	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
44181	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
44182	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
44183	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
44184	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
44185	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
44186	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
44187	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44188	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44189	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
44190	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
44191	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	General Comments		
44192	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
44193	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
44194	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
44195	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
44196	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	LTC0000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
44197	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
44198	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	4R	
44199	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
44200	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
44201	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	1.1	%
44202	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44203	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44204	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44205	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44206	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
44207	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150	
44208	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
44209	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130	
44210	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.77	%
44211	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
44212	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	1.1	%
44213	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
44214	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
44215	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
44216	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
44217	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
44218	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	1.1	%
44219	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	480.0	
44220	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	480.0	
44221	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	480.0	
44222	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44223	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44224	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44225	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
44226	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
44227	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
44228	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44229	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
44230	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.38	%
44231	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
44232	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
44233	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
44234	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
44235	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
44236	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
44237	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
44238	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.4458	
44239	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
44240	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0	
44241	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44242	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	204992	
44243	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTC0000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
44244	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	LTC0000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
44245	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
44246	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
44247	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
44248	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
44249	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
44250	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
44251	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	428	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44252	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	428	
44253	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
44254	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
44255	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44256	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
44257	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
44258	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
44259	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
44260	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
44261	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
44262	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
44263	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
44264	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
44265	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
44266	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
44267	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
44268	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
44269	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
44270	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	6620	
44271	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	6620	
44272	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
44273	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	6L	
44274	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	3L	
44275	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	8L	
44276	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	601	
44277	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
44278	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44279	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
44280	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44281	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44282	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	28	
44283	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44284	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44285	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
44286	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
44287	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
44288	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
44289	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
44290	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
44291	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
44292	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
44293	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44294	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
44295	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44296	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44297	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44298	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44299	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44300	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44301	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44302	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
44303	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
44304	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
44305	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
44306	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
44307	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
44308	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
44309	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
44310	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
44311	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
44312	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
44313	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
44314	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
44315	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
44316	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
44317	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
44318	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	4	
44319	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
44320	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	4	
44321	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	231	
44322	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	227	
44323	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
44324	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
44325	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44326	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44327	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
44328	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
44329	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
44330	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
44331	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
44332	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
44333	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
44334	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
44335	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
44336	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44337	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44338	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44339	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44340	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44341	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44342	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44343	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44344	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44345	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
44346	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	101.0	
44347	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	75.0	
44348	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	108.0	
44349	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44350	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44351	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44352	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	4	
44353	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
44354	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
44355	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
44356	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
44357	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
44358	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
44359	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
44360	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	4413.60	kw
44361	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
44362	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
44363	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
44364	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
44365	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
44366	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
44367	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
44368	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
44369	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
44370	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	172	
44371	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	172	
44372	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	0	
44373	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	0	
44374	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
44375	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
44376	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44377	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	2225	
44378	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	8L	
44379	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	6R	
44380	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	3L	
44381	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	117786	
44382	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	117786	
44383	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
44384	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
44385	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
44386	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
44387	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
44388	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
44389	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
44390	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44391	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
44392	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
44393	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
44394	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
44395	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44396	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44397	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
44398	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
44399	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
44400	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
44401	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44402	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
44403	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
44404	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
44405	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	2	
44406	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44407	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44408	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44409	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	166.0	
44410	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	176.0	
44411	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44412	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44413	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44414	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
44415	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
44416	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
44417	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
44418	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
44419	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
44420	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
44421	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
44422	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
44423	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
44424	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12213	
44425	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44426	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44427	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
44428	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
44429	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
44430	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
44431	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
44432	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
44433	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
44434	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	51.0	
44435	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	64.0	
44436	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
44437	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
44438	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AL	25771	
44439	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AF	25763	
44440	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
44441	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
44442	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
44443	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
44444	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
44445	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Min Tap Position	14L	
44446	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Max Tap Position	6L	
44447	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	General Comments		
44448	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
44449	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Current Tap Position	7L	
44450	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	All Connections OK?	y	
44451	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
44452	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments		
44453	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
44454	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
44455	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
44456	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
44457	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
44458	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
44459	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
44460	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
44461	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
44462	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
44463	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
44464	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
44465	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
44466	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
44467	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
44468	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
44469	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
44470	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
44471	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
44472	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
44473	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44474	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
44475	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
44476	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	146	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44477	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	146	
44478	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
44479	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44480	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44481	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44482	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	
44483	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	500.0	
44484	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	500.0	
44485	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
44486	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44487	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44488	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44489	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44490	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44491	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44492	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
44493	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
44494	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
44495	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
44496	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
44497	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
44498	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
44499	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
44500	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
44501	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
44502	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
44503	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
44504	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
44505	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
44506	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
44507	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
44508	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
44509	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
44510	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
44511	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	8184.96	kw
44512	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
44513	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
44514	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	60	°C
44515	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
44516	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
44517	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
44518	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
44519	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
44520	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
44521	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
44522	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
44523	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
44524	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
44525	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
44526	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
44527	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
44528	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
44529	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
44530	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
44531	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
44532	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
44533	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
44534	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
44535	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
44536	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
44537	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
44538	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
44539	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
44540	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
44541	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
44542	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
44543	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
44544	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
44545	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
44546	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
44547	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
44548	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44549	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
44550	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44551	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44552	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
44553	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
44554	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
44555	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
44556	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
44557	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
44558	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
44559	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
44560	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
44561	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
44562	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44563	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
44564	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
44565	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
44566	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44567	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
44568	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
44569	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	122	
44570	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	122	
44571	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
44572	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
44573	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
44574	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
44575	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
44576	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	174.0	
44577	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
44578	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44579	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44580	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44581	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44582	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44583	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44584	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
44585	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
44586	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44587	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44588	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44589	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
44590	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
44591	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	
44592	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9328	volts
44593	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44594	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44595	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
44596	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
44597	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
44598	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
44599	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
44600	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
44601	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
44602	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
44603	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
44604	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
44605	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44606	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44607	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
44608	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
44609	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
44610	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
44611	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
44612	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
44613	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
44614	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
44615	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
44616	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
44617	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
44618	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44619	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
44620	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44621	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
44622	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
44623	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
44624	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
44625	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
44626	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44627	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
44628	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
44629	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
44630	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
44631	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
44632	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
44633	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
44634	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
44635	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
44636	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
44637	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
44638	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
44639	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
44640	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
44641	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
44642	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
44643	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
44644	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
44645	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
44646	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
44647	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
44648	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
44649	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
44650	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
44651	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
44652	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
44653	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
44654	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	3	
44655	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	3	
44656	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	99963	
44657	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	99963	
44658	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
44659	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments		
44660	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
44661	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
44662	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
44663	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
44664	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
44665	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
44666	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
44667	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
44668	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
44669	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
44670	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
44671	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	50.0	
44672	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	75.0	
44673	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	100.0	
44674	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
44675	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
44676	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
44677	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	8	
44678	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
44679	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
44680	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
44681	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
44682	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
44683	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	59514	
44684	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	59514	
44685	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
44686	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	3L	
44687	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	2L	
44688	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	8L	
44689	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
44690	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	n	
44691	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
44692	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
44693	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
44694	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
44695	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
44696	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44697	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44698	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44699	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44700	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44701	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
44702	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	364	
44703	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
44704	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44705	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
44706	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
44707	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
44708	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
44709	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
44710	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	15559	
44711	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	15562	
44712	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
44713	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	7L	
44714	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	5L	
44715	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	11L	
44716	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	620	
44717	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
44718	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
44719	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44720	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
44721	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	506	
44722	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44723	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
44724	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
44725	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
44726	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
44727	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
44728	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
44729	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
44730	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
44731	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
44732	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
44733	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
44734	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
44735	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
44736	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
44737	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
44738	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
44739	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
44740	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
44741	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
44742	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
44743	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
44744	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
44745	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	10L	
44746	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
44747	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	1L	
44748	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	118292	
44749	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	118292	
44750	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
44751	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
44752	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
44753	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
44754	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	2	
44755	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44756	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44757	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44758	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	107.0	
44759	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	102.0	
44760	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	104.0	
44761	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
44762	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44763	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44764	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AL	21973	
44765	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AF	21969	
44766	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
44767	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
44768	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
44769	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
44770	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
44771	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Min Tap Position	14L	
44772	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Max Tap Position	7L	
44773	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	General Comments		
44774	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Follow-up Action Required?	n	
44775	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44776	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44777	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Current Tap Position	7L	
44778	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	All Connections OK?	y	
44779	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
44780	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44781	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44782	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44783	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44784	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44785	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
44786	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
44787	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
44788	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
44789	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
44790	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
44791	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
44792	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	58	
44793	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
44794	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
44795	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
44796	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
44797	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
44798	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
44799	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
44800	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
44801	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
44802	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	40	
44803	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44804	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44805	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44806	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	152.0	
44807	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	189.0	
44808	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	186.0	
44809	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
44810	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44811	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44812	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44813	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44814	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44815	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44816	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44817	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44818	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44819	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
44820	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
44821	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
44822	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
44823	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
44824	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
44825	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
44826	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
44827	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
44828	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
44829	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
44830	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
44831	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	185	
44832	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	185	
44833	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	0	
44834	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	0	
44835	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
44836	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
44837	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
44838	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
44839	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
44840	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	255	
44841	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	12L	
44842	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	7L	
44843	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	9L	
44844	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
44845	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	36	
44846	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44847	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44848	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44849	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A Ø	186.0	
44850	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B Ø	115.0	
44851	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C Ø	160.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44852	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
44853	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44854	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
44855	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44856	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
44857	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
44858	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
44859	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
44860	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
44861	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
44862	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A Ø	0	
44863	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B Ø	0	
44864	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C Ø	0	
44865	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
44866	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
44867	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
44868	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
44869	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
44870	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
44871	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
44872	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
44873	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
44874	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
44875	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44876	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
44877	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44878	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
44879	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44880	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	30	Seconds
44881	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
44882	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
44883	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
44884	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
44885	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
44886	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
44887	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
44888	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
44889	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
44890	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
44891	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
44892	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
44893	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
44894	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
44895	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
44896	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
44897	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
44898	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
44899	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
44900	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
44901	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
44902	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
44903	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
44904	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	32	
44905	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44906	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44907	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	26	
44908	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
44909	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
44910	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
44911	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	55.0	
44912	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	110.0	
44913	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	70.0	
44914	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
44915	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
44916	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
44917	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
44918	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
44919	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44920	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
44921	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
44922	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
44923	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments	fence is rusty, large gap beneath fenced, but has barb wire spanning it. One fence post washed out and is loose	
44924	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44925	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
44926	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
44927	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
44928	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
44929	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
44930	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
44931	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
44932	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
44933	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
44934	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
44935	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
44936	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
44937	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
44938	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
44939	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
44940	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
44941	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
44942	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
44943	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
44944	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
44945	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
44946	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	General Comments		
44947	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
44948	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
44949	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
44950	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	LTC0000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
44951	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44952	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44953	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	91837	
44954	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
44955	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
44956	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
44957	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
44958	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
44959	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44960	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44961	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
44962	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
44963	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
44964	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
44965	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
44966	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
44967	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
44968	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
44969	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
44970	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
44971	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
44972	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
44973	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
44974	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
44975	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
44976	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
44977	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
44978	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
44979	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	117612	
44980	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
44981	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
44982	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
44983	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
44984	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
44985	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
44986	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
44987	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
44988	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
44989	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
44990	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
44991	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
44992	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
44993	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
44994	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	622	
44995	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	622	
44996	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	1	
44997	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
44998	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
44999	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
45000	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
45001	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
45002	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
45003	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
45004	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
45005	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
45006	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
45007	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
45008	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
45009	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
45010	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
45011	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
45012	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
45013	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
45014	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
45015	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
45016	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
45017	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
45018	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
45019	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
45020	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
45021	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
45022	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
45023	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
45024	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
45025	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
45026	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
45027	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
45028	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
45029	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments		
45030	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	
45031	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
45032	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
45033	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	228	
45034	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	4	
45035	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	2.72	%
45036	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
45037	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
45038	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	84.0	
45039	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	93.0	
45040	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	100.0	
45041	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
45042	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
45043	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
45044	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
45045	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
45046	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
45047	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
45048	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
45049	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
45050	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
45051	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
45052	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
45053	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
45054	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
45055	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
45056	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
45057	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
45058	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	71.0	
45059	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
45060	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
45061	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
45062	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
45063	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
45064	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
45065	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
45066	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
45067	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
45068	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
45069	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
45070	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	
45071	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
45072	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
45073	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
45074	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
45075	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	General Comments		
45076	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45077	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
45078	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
45079	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	155	
45080	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	155	
45081	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	0	
45082	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	0	
45083	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
45084	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
45085	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	0	
45086	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
45087	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
45088	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
45089	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	30.0	
45090	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	50.0	
45091	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	25.0	
45092	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
45093	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
45094	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
45095	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	76.0	
45096	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	67.0	
45097	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
45098	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	3	
45099	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
45100	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
45101	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
45102	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	50.0	
45103	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	50.0	
45104	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	50.0	
45105	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
45106	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
45107	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
45108	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
45109	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	1	
45110	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
45111	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
45112	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
45113	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
45114	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
45115	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
45116	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
45117	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
45118	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
45119	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
45120	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	4R	
45121	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	6R	
45122	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
45123	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
45124	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
45125	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
45126	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	
45127	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	29891	volts
45128	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
45129	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45130	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45131	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45132	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
45133	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45134	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45135	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45136	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
45137	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45138	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45139	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
45140	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45141	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
45142	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45143	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
45144	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45145	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45146	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
45147	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45148	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45149	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45150	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
45151	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45152	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments	Road coming up to the substation has multiple wash outs	
45153	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
45154	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	General Comments	asks for counter and drag hands on reg and reg control sheets for all 3 regs	
45155	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
45156	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
45157	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Follow-up Action Required?	y	
45158	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
45159	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
45160	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
45161	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
45162	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Heaters Functioning?	y	
45163	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
45164	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
45165	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
45166	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
45167	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
45168	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
45169	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
45170	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
45171	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
45172	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
45173	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
45174	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	40	°C
45175	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
45176	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
45177	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
45178	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
45179	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
45180	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
45181	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
45182	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
45183	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
45184	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
45185	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
45186	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
45187	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
45188	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
45189	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
45190	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
45191	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
45192	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
45193	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
45194	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
45195	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
45196	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	10	
45197	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
45198	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
45199	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
45200	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	50.0	
45201	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	50.0	
45202	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	50.0	
45203	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
45204	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
45205	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
45206	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
45207	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	1	
45208	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	1	
45209	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
45210	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
45211	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
45212	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
45213	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
45214	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
45215	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
45216	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	938	
45217	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	938	
45218	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	2	
45219	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
45220	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
45221	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Leaks	None	
45222	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
45223	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
45224	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Regulator As Left Counter	26312	
45225	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
45226	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
45227	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
45228	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
45229	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
45230	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
45231	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
45232	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
45233	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
45234	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
45235	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
45236	12/3/2019 10:47	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	6R	
45237	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
45238	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
45239	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
45240	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
45241	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
45242	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
45243	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
45244	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
45245	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
45246	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
45247	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
45248	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
45249	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	General Comments		
45250	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
45251	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
45252	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
45253	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
45254	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
45255	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
45256	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
45257	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
45258	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
45259	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
45260	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
45261	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
45262	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45263	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45264	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45265	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
45266	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45267	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45268	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
45269	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
45270	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
45271	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
45272	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
45273	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
45274	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
45275	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
45276	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
45277	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
45278	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
45279	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
45280	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45281	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45282	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
45283	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45284	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
45285	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45286	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
45287	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs paint	
45288	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45289	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
45290	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
45291	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
45292	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
45293	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45294	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45295	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45296	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45297	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45298	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45299	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45300	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45301	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
45302	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45303	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
45304	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45305	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45306	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
45307	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
45308	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
45309	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
45310	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	179	
45311	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	179	
45312	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	0	
45313	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
45314	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
45315	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
45316	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
45317	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
45318	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
45319	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
45320	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
45321	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45322	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45323	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45324	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
45325	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45326	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45327	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45328	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
45329	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45330	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45331	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
45332	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45333	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		
45334	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45335	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
45336	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
45337	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45338	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45339	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45340	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45341	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45342	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
45343	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
45344	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
45345	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
45346	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
45347	12/16/2019 14:38	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
45348	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
45349	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
45350	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
45351	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
45352	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.8526	
45353	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
45354	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
45355	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
45356	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
45357	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
45358	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
45359	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
45360	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
45361	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
45362	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
45363	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45364	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45365	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45366	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
45367	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
45368	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	0	
45369	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	2	
45370	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	226	
45371	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	226	
45372	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
45373	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
45374	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
45375	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
45376	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45377	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
45378	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
45379	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45380	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45381	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45382	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
45383	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45384	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45385	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45386	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
45387	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45388	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45389	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
45390	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45391	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
45392	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45393	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
45394	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
45395	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
45396	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
45397	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
45398	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45399	12/3/2019 10:47	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
45400	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
45401	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45402	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45403	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
45404	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45405	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45406	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45407	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
45408	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
45409	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
45410	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
45411	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
45412	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
45413	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
45414	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
45415	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
45416	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
45417	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
45418	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
45419	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	All Connections OK?	y	
45420	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	1	
45421	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	1	
45422	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
45423	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	2.94	
45424	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	2.94	
45425	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
45426	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
45427	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
45428	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
45429	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
45430	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
45431	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
45432	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
45433	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
45434	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	125.0	
45435	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	100.0	
45436	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	95.0	
45437	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
45438	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
45439	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45440	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
45441	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45442	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45443	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125	VAC
45444	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125	VAC
45445	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	125	VAC
45446	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
45447	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	General Comments		
45448	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
45449	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC0000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
45450	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
45451	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	124	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45452	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
45453	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
45454	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
45455	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	General Comments		
45456	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
45457	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45458	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
45459	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45460	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45461	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
45462	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45463	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
45464	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
45465	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
45466	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
45467	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
45468	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
45469	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
45470	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45471	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45472	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45473	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45474	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45475	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
45476	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45477	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
45478	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15810	
45479	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
45480	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
45481	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
45482	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
45483	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
45484	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
45485	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
45486	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
45487	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45488	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45489	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45490	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45491	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
45492	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
45493	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
45494	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
45495	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	All Connections OK?	y	
45496	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
45497	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45498	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
45499	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
45500	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
45501	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
45502	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
45503	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45504	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
45505	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
45506	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
45507	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
45508	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
45509	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
45510	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
45511	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
45512	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45513	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45514	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45515	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
45516	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
45517	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45518	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	9L	
45519	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45520	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45521	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
45522	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
45523	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45524	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45525	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
45526	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45527	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
45528	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
45529	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
45530	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
45531	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	1L	
45532	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	2L	
45533	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
45534	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
45535	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
45536	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
45537	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
45538	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
45539	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
45540	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	21942	
45541	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	21942	
45542	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
45543	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
45544	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
45545	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45546	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
45547	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
45548	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45549	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
45550	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45551	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45552	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
45553	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
45554	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
45555	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
45556	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45557	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45558	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45559	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
45560	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45561	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
45562	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
45563	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
45564	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	General Comments		
45565	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Max Tap Position	4L	
45566	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Min Tap Position	12L	
45567	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
45568	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
45569	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
45570	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
45571	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
45572	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AF	26309	
45573	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AL	26312	
45574	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
45575	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
45576	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
45577	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	74236	
45578	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
45579	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
45580	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
45581	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45582	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45583	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45584	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
45585	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
45586	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
45587	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
45588	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
45589	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
45590	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
45591	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
45592	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
45593	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
45594	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Current Tap Position	4L	
45595	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
45596	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
45597	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
45598	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
45599	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
45600	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
45601	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
45602	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
45603	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
45604	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
45605	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
45606	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
45607	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
45608	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
45609	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
45610	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
45611	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
45612	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
45613	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
45614	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
45615	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
45616	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
45617	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
45618	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45619	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45620	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
45621	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
45622	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
45623	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45624	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45625	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45626	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
45627	12/3/2019 13:18	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	4	
45628	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
45629	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
45630	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
45631	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
45632	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
45633	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
45634	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
45635	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
45636	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45637	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
45638	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
45639	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
45640	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
45641	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45642	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
45643	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
45644	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2199.96	kw
45645	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
45646	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
45647	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	50	*C
45648	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45649	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45650	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45651	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45652	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45653	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
45654	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
45655	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
45656	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
45657	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45658	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.6630	
45659	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
45660	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45661	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45662	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
45663	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45664	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
45665	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45666	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45667	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
45668	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
45669	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
45670	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	560	
45671	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45672	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
45673	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
45674	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
45675	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
45676	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45677	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
45678	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
45679	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
45680	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
45681	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
45682	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
45683	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
45684	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
45685	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	General Comments		
45686	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
45687	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	16L	
45688	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	553	
45689	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
45690	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
45691	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
45692	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
45693	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	8998.56	kw
45694	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45695	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
45696	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	62	°C
45697	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
45698	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
45699	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
45700	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
45701	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	461	
45702	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	35	°C
45703	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
45704	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
45705	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
45706	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
45707	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
45708	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
45709	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
45710	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45711	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45712	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45713	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	461	
45714	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
45715	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
45716	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
45717	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45718	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45719	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
45720	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.6480	
45721	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
45722	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
45723	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
45724	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
45725	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
45726	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
45727	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45728	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45729	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45730	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45731	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
45732	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45733	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45734	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
45735	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	1.2498	
45736	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
45737	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
45738	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
45739	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
45740	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
45741	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
45742	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
45743	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	n	
45744	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
45745	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45746	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
45747	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
45748	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
45749	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
45750	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
45751	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45752	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
45753	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
45754	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
45755	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
45756	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
45757	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
45758	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
45759	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
45760	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
45761	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
45762	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
45763	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
45764	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
45765	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45766	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45767	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
45768	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45769	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
45770	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45771	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
45772	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
45773	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
45774	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs paint	
45775	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45776	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
45777	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
45778	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
45779	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
45780	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
45781	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	72033	
45782	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	72036	
45783	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
45784	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	3L	
45785	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	16R	
45786	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
45787	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
45788	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	90	
45789	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120	
45790	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110	
45791	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
45792	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
45793	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
45794	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
45795	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
45796	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
45797	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	704	
45798	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	7L	
45799	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
45800	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	2L	
45801	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
45802	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	12595	
45803	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	12590	
45804	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
45805	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
45806	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
45807	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
45808	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
45809	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
45810	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
45811	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45812	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45813	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45814	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45815	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45816	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45817	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45818	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
45819	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
45820	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
45821	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
45822	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
45823	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45824	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
45825	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
45826	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45827	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
45828	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
45829	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
45830	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
45831	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
45832	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
45833	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45834	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
45835	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
45836	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.3768	
45837	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
45838	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45839	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45840	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
45841	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45842	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
45843	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45844	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45845	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45846	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	40	°C
45847	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	55	°C
45848	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
45849	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
45850	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
45851	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45852	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30125	Seconds
45853	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
45854	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
45855	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
45856	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
45857	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
45858	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
45859	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
45860	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
45861	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
45862	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
45863	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
45864	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
45865	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
45866	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
45867	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
45868	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
45869	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	General Comments		
45870	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
45871	12/3/2019 12:27	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
45872	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	2712.96	kw
45873	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
45874	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
45875	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
45876	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
45877	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
45878	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
45879	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
45880	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45881	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
45882	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45883	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
45884	12/3/2019 13:49	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
45885	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
45886	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
45887	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
45888	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45889	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
45890	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
45891	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
45892	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
45893	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
45894	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45895	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
45896	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
45897	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
45898	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
45899	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
45900	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
45901	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45902	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
45903	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
45904	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
45905	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
45906	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
45907	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45908	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45909	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45910	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
45911	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	40	°C
45912	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
45913	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
45914	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
45915	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
45916	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
45917	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
45918	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45919	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45920	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45921	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
45922	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45923	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	6220.80	kw
45924	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
45925	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
45926	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
45927	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
45928	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
45929	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
45930	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
45931	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
45932	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45933	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
45934	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
45935	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
45936	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	6114.24	kw
45937	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
45938	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
45939	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
45940	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
45941	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
45942	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
45943	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
45944	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
45945	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
45946	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
45947	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
45948	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
45949	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
45950	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
45951	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
45952	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
45953	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
45954	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
45955	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
45956	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
45957	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
45958	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
45959	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
45960	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
45961	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
45962	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
45963	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
45964	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
45965	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
45966	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
45967	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
45968	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
45969	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
45970	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
45971	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
45972	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
45973	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
45974	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
45975	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Max	57	°C
45976	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
45977	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
45978	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	1.2738	
45979	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
45980	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
45981	12/3/2019 13:03	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
45982	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
45983	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
45984	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
45985	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
45986	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
45987	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
45988	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
45989	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
45990	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
45991	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	General Comments		
45992	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
45993	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
45994	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
45995	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
45996	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
45997	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
45998	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
45999	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
46000	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
46001	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
46002	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
46003	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
46004	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
46005	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46006	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46007	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
46008	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46009	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
46010	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
46011	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
46012	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
46013	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
46014	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
46015	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46016	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46017	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
46018	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
46019	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
46020	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17699	
46021	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
46022	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
46023	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
46024	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
46025	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
46026	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
46027	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
46028	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
46029	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
46030	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
46031	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
46032	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
46033	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	LTC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
46034	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
46035	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
46036	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
46037	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
46038	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
46039	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
46040	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
46041	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
46042	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
46043	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
46044	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
46045	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.08	%
46046	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
46047	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
46048	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20	
46049	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	0	
46050	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20	
46051	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
46052	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
46053	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	5	
46054	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0	%
46055	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0	%
46056	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0	%
46057	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46058	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46059	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46060	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
46061	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
46062	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
46063	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
46064	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.5	VDC
46065	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.5	VDC
46066	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.5	amps
46067	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
46068	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
46069	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
46070	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
46071	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
46072	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46073	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46074	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
46075	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
46076	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
46077	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
46078	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
46079	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments	this is A phase reg	
46080	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
46081	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
46082	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	y	
46083	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46084	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
46085	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
46086	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
46087	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
46088	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
46089	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
46090	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
46091	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46092	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46093	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46094	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46095	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
46096	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46097	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
46098	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.2222	
46099	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
46100	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
46101	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
46102	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
46103	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
46104	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
46105	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
46106	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
46107	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
46108	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
46109	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
46110	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
46111	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
46112	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
46113	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
46114	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
46115	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
46116	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
46117	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
46118	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
46119	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
46120	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
46121	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
46122	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
46123	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
46124	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
46125	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
46126	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46127	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
46128	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
46129	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
46130	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
46131	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
46132	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
46133	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
46134	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
46135	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
46136	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
46137	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46138	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46139	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
46140	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	34.0	
46141	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	20.0	
46142	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
46143	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
46144	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
46145	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46146	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
46147	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.7302	
46148	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
46149	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0	
46150	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
46151	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
46152	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46153	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46154	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46155	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46156	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
46157	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46158	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
46159	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
46160	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	46.0	
46161	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
46162	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
46163	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
46164	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
46165	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
46166	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
46167	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
46168	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
46169	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
46170	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
46171	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
46172	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
46173	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
46174	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
46175	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
46176	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
46177	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
46178	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
46179	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
46180	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
46181	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	320	
46182	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	320	
46183	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	320	
46184	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
46185	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
46186	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
46187	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46188	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46189	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
46190	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
46191	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
46192	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
46193	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	B80220	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
46194	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
46195	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
46196	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
46197	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
46198	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
46199	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
46200	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
46201	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46202	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
46203	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
46204	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
46205	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240	
46206	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140	
46207	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	160	
46208	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
46209	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
46210	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
46211	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
46212	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46213	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46214	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
46215	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
46216	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	20	
46217	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	20	
46218	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46219	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46220	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46221	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
46222	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
46223	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
46224	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	60	°C
46225	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	30	°C
46226	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46227	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
46228	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
46229	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
46230	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
46231	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
46232	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	20	
46233	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
46234	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
46235	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46236	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46237	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46238	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46239	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46240	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46241	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0	
46242	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0	
46243	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0	
46244	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
46245	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
46246	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
46247	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
46248	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
46249	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
46250	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
46251	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
46252	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
46253	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
46254	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
46255	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
46256	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
46257	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
46258	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
46259	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
46260	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
46261	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
46262	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	220	
46263	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	220	
46264	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	0	
46265	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
46266	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	0	
46267	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
46268	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
46269	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
46270	12/3/2019 11:34	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
46271	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
46272	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
46273	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
46274	12/3/2019 15:05	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
46275	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
46276	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46277	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
46278	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
46279	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	0	
46280	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
46281	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
46282	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
46283	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
46284	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	LTC Readings	Fault Adjusted Amps B Phase V	0.00	
46285	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
46286	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
46287	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46288	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
46289	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46290	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46291	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46292	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46293	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46294	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
46295	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
46296	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
46297	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
46298	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
46299	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
46300	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	
46301	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	0	
46302	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	0	
46303	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	208	
46304	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	208	
46305	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
46306	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
46307	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
46308	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments		
46309	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
46310	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
46311	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
46312	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
46313	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
46314	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
46315	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
46316	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
46317	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
46318	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
46319	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
46320	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
46321	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
46322	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
46323	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
46324	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
46325	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
46326	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
46327	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
46328	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
46329	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
46330	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
46331	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
46332	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
46333	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
46334	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
46335	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
46336	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
46337	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	161	
46338	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	161	
46339	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
46340	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
46341	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
46342	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
46343	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	*C
46344	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
46345	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	*C
46346	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	*C
46347	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46348	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
46349	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46350	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
46351	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
46352	12/3/2019 15:48	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
46353	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
46354	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
46355	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46356	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46357	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46358	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46359	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46360	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46361	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
46362	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
46363	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
46364	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
46365	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
46366	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
46367	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
46368	12/4/2019 6:23	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
46369	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
46370	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46371	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3504.96	kw
46372	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46373	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
46374	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46375	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
46376	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitro bottle empty	
46377	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46378	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46379	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
46380	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
46381	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
46382	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
46383	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
46384	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
46385	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
46386	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-07 00:00:00.000000000	
46387	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
46388	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	351	
46389	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	351	
46390	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
46391	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
46392	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
46393	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46394	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
46395	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46396	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
46397	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
46398	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
46399	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46400	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	0	
46401	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
46402	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
46403	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
46404	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
46405	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
46406	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
46407	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
46408	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
46409	12/3/2019 13:38	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
46410	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	480.0	
46411	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	465.0	
46412	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	465.0	
46413	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
46414	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46415	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46416	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46417	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46418	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46419	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46420	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	1	
46421	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
46422	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
46423	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
46424	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
46425	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46426	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46427	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
46428	12/3/2019 11:13	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
46429	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
46430	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	33	*F
46431	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
46432	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
46433	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
46434	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
46435	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
46436	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
46437	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
46438	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
46439	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
46440	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
46441	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
46442	12/3/2019 15:15	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
46443	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	40	*C
46444	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	50	*C
46445	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
46446	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46447	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	3978.00	kw
46448	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46449	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46450	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
46451	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
46452	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46453	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46454	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
46455	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
46456	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
46457	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
46458	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46459	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
46460	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
46461	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
46462	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
46463	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
46464	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
46465	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
46466	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
46467	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
46468	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
46469	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
46470	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
46471	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
46472	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
46473	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
46474	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
46475	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
46476	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
46477	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
46478	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
46479	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
46480	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
46481	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
46482	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
46483	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
46484	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
46485	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
46486	12/3/2019 13:13	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
46487	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46488	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
46489	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
46490	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
46491	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
46492	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
46493	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
46494	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
46495	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
46496	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
46497	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
46498	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
46499	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
46500	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
46501	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46502	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
46503	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
46504	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
46505	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
46506	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
46507	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
46508	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
46509	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46510	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
46511	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
46512	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
46513	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
46514	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
46515	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
46516	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
46517	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
46518	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
46519	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
46520	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
46521	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
46522	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
46523	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46524	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
46525	12/3/2019 14:58	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
46526	12/3/2019 13:31	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
46527	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
46528	12/3/2019 13:21	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
46529	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
46530	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
46531	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
46532	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
46533	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46534	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18925	
46535	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
46536	12/3/2019 14:50	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
46537	12/3/2019 14:42	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
46538	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
46539	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
46540	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	30	
46541	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	27	
46542	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	37	
46543	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
46544	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	477	
46545	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
46546	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
46547	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
46548	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
46549	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
46550	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
46551	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
46552	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
46553	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
46554	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
46555	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
46556	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
46557	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
46558	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
46559	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
46560	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	53	
46561	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46562	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
46563	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
46564	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46565	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
46566	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
46567	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
46568	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
46569	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
46570	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
46571	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
46572	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
46573	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
46574	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
46575	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
46576	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
46577	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48759	
46578	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
46579	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
46580	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
46581	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
46582	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
46583	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
46584	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
46585	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
46586	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46587	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	553	
46588	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	39	°C
46589	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46590	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	1.1238	
46591	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
46592	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
46593	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46594	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	VRR Time Delay	30	Seconds
46595	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
46596	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	10788.48	kw
46597	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
46598	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	12	°C
46599	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
46600	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
46601	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	575	
46602	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
46603	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
46604	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
46605	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	10L	
46606	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
46607	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46608	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46609	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
46610	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
46611	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
46612	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
46613	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
46614	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
46615	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	6L	
46616	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	4L	
46617	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	10L	
46618	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
46619	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
46620	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
46621	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
46622	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	All Connections OK?	y	
46623	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
46624	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	General Comments	transformer not online	
46625	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	LTC Operation Checked?	n	
46626	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
46627	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
46628	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46629	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
46630	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
46631	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
46632	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
46633	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
46634	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
46635	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
46636	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
46637	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
46638	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	0	
46639	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	0	
46640	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	195	
46641	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	195	
46642	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
46643	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
46644	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
46645	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
46646	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
46647	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46648	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46649	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46650	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
46651	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46652	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
46653	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
46654	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46655	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
46656	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	39	°C
46657	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46658	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
46659	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
46660	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
46661	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
46662	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
46663	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
46664	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
46665	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
46666	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
46667	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
46668	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
46669	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
46670	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
46671	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
46672	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
46673	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
46674	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46675	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
46676	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
46677	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
46678	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
46679	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
46680	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46681	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
46682	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
46683	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
46684	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
46685	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
46686	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46687	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
46688	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
46689	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46690	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46691	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
46692	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.951	
46693	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
46694	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
46695	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
46696	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	4	
46697	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
46698	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
46699	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
46700	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments		
46701	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46702	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46703	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46704	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
46705	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
46706	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2048.64	kw
46707	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
46708	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
46709	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments		
46710	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
46711	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
46712	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
46713	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC0000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
46714	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC0000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
46715	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC0000261	LTCControl	793-1	LTC Control Insp	General Comments		
46716	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
46717	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
46718	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
46719	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63815	
46720	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
46721	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
46722	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
46723	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46724	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46725	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
46726	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	2R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46727	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
46728	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
46729	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
46730	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	8	
46731	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
46732	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
46733	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments		
46734	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
46735	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
46736	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
46737	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
46738	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	53.0	
46739	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
46740	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	72.0	
46741	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
46742	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46743	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
46744	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
46745	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
46746	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
46747	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
46748	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
46749	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
46750	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	3L	
46751	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
46752	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
46753	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	4667	
46754	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	4667	
46755	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
46756	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
46757	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	1124.0	VAC
46758	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	1124.0	VAC
46759	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	2R	
46760	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
46761	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
46762	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
46763	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46764	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
46765	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
46766	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
46767	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
46768	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
46769	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
46770	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
46771	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
46772	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
46773	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46774	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
46775	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
46776	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
46777	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
46778	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
46779	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
46780	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
46781	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
46782	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
46783	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	32	
46784	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
46785	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
46786	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
46787	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
46788	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	96303	
46789	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	96303	
46790	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
46791	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
46792	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
46793	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
46794	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
46795	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
46796	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
46797	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
46798	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1422	
46799	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
46800	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
46801	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
46802	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
46803	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
46804	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
46805	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
46806	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
46807	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
46808	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
46809	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
46810	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
46811	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
46812	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
46813	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
46814	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
46815	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
46816	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
46817	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
46818	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
46819	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46820	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46821	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46822	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46823	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
46824	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
46825	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
46826	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
46827	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0	
46828	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
46829	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
46830	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
46831	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
46832	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
46833	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
46834	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
46835	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	60.0	
46836	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
46837	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
46838	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
46839	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	5	
46840	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	0	
46841	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	5	
46842	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	197	
46843	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	197	
46844	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
46845	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
46846	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
46847	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	349006	
46848	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
46849	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
46850	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
46851	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
46852	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46853	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
46854	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
46855	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
46856	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46857	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46858	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
46859	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
46860	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
46861	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
46862	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
46863	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
46864	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
46865	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46866	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
46867	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46868	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46869	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46870	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46871	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
46872	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
46873	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	5	
46874	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
46875	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
46876	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46877	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
46878	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
46879	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
46880	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
46881	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
46882	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
46883	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
46884	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0	
46885	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0	
46886	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0	
46887	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	14	
46888	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0	
46889	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
46890	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
46891	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
46892	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
46893	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
46894	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
46895	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
46896	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46897	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46898	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
46899	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
46900	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
46901	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46902	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
46903	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46904	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
46905	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46906	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	2801.28	kw
46907	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46908	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27583	
46909	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
46910	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
46911	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
46912	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
46913	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	100	
46914	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0	%
46915	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0	%
46916	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0	%
46917	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	7	
46918	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
46919	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
46920	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
46921	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
46922	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
46923	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
46924	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
46925	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
46926	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	3926.40	kw
46927	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
46928	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
46929	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
46930	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
46931	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
46932	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
46933	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
46934	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
46935	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	5	
46936	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
46937	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
46938	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.4908	
46939	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
46940	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
46941	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
46942	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
46943	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	0	
46944	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	65	
46945	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	65	
46946	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
46947	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
46948	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure	67	psi
46949	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
46950	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
46951	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
46952	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
46953	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
46954	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
46955	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	95	
46956	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	102	
46957	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
46958	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46959	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
46960	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
46961	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
46962	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
46963	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
46964	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
46965	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
46966	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
46967	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
46968	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
46969	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
46970	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
46971	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
46972	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
46973	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
46974	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
46975	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
46976	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26224	
46977	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
46978	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
46979	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
46980	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
46981	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
46982	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
46983	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
46984	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
46985	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
46986	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
46987	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
46988	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
46989	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
46990	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
46991	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
46992	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	30	°C
46993	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Max	32	°C
46994	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	.8754	
46995	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
46996	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
46997	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
46998	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
46999	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47000	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47001	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47002	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
47003	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
47004	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47005	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
47006	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
47007	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47008	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47009	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
47010	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
47011	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47012	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
47013	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
47014	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47015	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47016	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47017	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
47018	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
47019	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
47020	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
47021	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
47022	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
47023	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
47024	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
47025	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
47026	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47027	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
47028	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47029	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
47030	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
47031	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
47032	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
47033	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
47034	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
47035	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
47036	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
47037	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
47038	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
47039	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
47040	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
47041	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
47042	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
47043	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47044	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
47045	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
47046	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
47047	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
47048	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
47049	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
47050	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47051	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
47052	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
47053	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47054	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47055	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
47056	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
47057	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	0	
47058	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
47059	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	0	
47060	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	913	
47061	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	913	
47062	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
47063	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
47064	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47065	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
47066	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
47067	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
47068	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
47069	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47070	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47071	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
47072	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
47073	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47074	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47075	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47076	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
47077	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
47078	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
47079	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
47080	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
47081	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
47082	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
47083	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	n	
47084	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
47085	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47086	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
47087	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
47088	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
47089	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
47090	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
47091	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
47092	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
47093	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
47094	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
47095	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
47096	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47097	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	58501	
47098	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
47099	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
47100	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
47101	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47102	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47103	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
47104	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
47105	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
47106	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments		
47107	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47108	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
47109	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
47110	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47111	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
47112	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47113	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47114	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47115	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47116	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
47117	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	85	
47118	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0	%
47119	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0	%
47120	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0	%
47121	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	5	
47122	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
47123	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
47124	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
47125	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
47126	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
47127	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
47128	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
47129	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
47130	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
47131	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
47132	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
47133	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47134	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	24	*C
47135	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	32	*C
47136	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
47137	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
47138	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4073.76	kw
47139	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
47140	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
47141	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
47142	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
47143	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
47144	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
47145	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
47146	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
47147	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
47148	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
47149	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
47150	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
47151	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
47152	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47153	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
47154	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
47155	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47156	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
47157	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
47158	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47159	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47160	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47161	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
47162	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
47163	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47164	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
47165	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	385.0	
47166	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	280.0	
47167	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	290.0	
47168	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47169	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47170	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
47171	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	7	
47172	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
47173	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
47174	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
47175	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
47176	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47177	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
47178	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
47179	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
47180	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
47181	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
47182	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
47183	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
47184	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
47185	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
47186	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
47187	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
47188	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
47189	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
47190	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
47191	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
47192	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
47193	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
47194	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47096	
47195	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47196	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
47197	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
47198	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
47199	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
47200	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
47201	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
47202	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
47203	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
47204	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
47205	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
47206	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
47207	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
47208	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
47209	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
47210	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47211	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
47212	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
47213	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47214	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47215	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47216	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
47217	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
47218	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47219	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
47220	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
47221	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47222	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
47223	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47224	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47225	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
47226	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
47227	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
47228	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
47229	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
47230	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47231	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
47232	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
47233	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
47234	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47235	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47236	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
47237	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47238	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47239	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47240	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
47241	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	20.0	
47242	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	30.0	
47243	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	27	°C
47244	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	31	°C
47245	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6974	
47246	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
47247	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47248	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
47249	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
47250	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47251	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47252	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
47253	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47254	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47255	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47256	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	20	°C
47257	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	50	°C
47258	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
47259	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
47260	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	9158.40	kw
47261	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
47262	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
47263	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
47264	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47265	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
47266	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47267	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47268	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
47269	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47270	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
47271	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
47272	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
47273	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
47274	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
47275	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47276	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
47277	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
47278	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47279	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
47280	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
47281	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
47282	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
47283	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
47284	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
47285	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
47286	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
47287	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
47288	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
47289	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
47290	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47291	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
47292	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47293	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
47294	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
47295	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
47296	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	9129.6	kw
47297	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
47298	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	37	°F
47299	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
47300	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
47301	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
47302	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
47303	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
47304	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
47305	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
47306	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
47307	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	LTC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
47308	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47309	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
47310	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47311	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
47312	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
47313	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
47314	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47315	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
47316	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
47317	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
47318	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	100	°C
47319	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	44	°C
47320	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47321	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
47322	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
47323	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47324	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
47325	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
47326	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47327	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
47328	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.3080	
47329	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
47330	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
47331	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
47332	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
47333	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	80595	
47334	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47335	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
47336	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
47337	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
47338	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
47339	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47340	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47341	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
47342	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
47343	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47344	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
47345	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
47346	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
47347	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
47348	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
47349	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
47350	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
47351	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	General Comments		
47352	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
47353	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
47354	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
47355	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
47356	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
47357	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47358	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42792	
47359	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
47360	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
47361	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
47362	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47363	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47364	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
47365	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	1	
47366	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
47367	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
47368	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
47369	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
47370	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47371	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
47372	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
47373	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
47374	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47375	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
47376	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	1	
47377	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
47378	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
47379	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
47380	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47381	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
47382	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
47383	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
47384	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
47385	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
47386	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
47387	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
47388	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
47389	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
47390	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47391	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47392	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
47393	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
47394	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
47395	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
47396	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
47397	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
47398	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
47399	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
47400	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
47401	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
47402	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
47403	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
47404	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
47405	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
47406	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
47407	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
47408	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
47409	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
47410	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
47411	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
47412	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
47413	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47414	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47415	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
47416	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
47417	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
47418	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47419	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47420	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
47421	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
47422	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47423	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
47424	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	9415	
47425	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	9415	
47426	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
47427	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	5L	
47428	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	2L	
47429	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	8L	
47430	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
47431	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	623	
47432	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
47433	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
47434	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
47435	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	45	
47436	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0	%
47437	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0	%
47438	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0	%
47439	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A Ø	61	
47440	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B Ø	42	
47441	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C Ø	74	
47442	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
47443	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47444	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
47445	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
47446	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	0	
47447	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	0	
47448	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	185	
47449	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	185	
47450	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
47451	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
47452	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
47453	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments		
47454	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
47455	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
47456	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
47457	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47458	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
47459	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
47460	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
47461	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
47462	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
47463	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
47464	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
47465	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47466	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
47467	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
47468	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47469	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47470	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47471	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47472	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47473	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47474	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
47475	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	0.0	
47476	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47477	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	0.0	
47478	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
47479	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
47480	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47481	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47482	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
47483	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	4	
47484	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
47485	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
47486	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	0	
47487	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	0	
47488	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
47489	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	50	°C
47490	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	40	°C
47491	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	200	
47492	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	200	
47493	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
47494	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
47495	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
47496	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
47497	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
47498	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
47499	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator chipped.	
47500	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
47501	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
47502	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
47503	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
47504	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47505	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
47506	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
47507	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
47508	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.5088	
47509	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
47510	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47511	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
47512	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
47513	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47514	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47515	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
47516	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
47517	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
47518	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47519	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47520	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47521	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47522	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
47523	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47524	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
47525	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
47526	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47527	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
47528	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
47529	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
47530	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
47531	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47532	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47533	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
47534	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
47535	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
47536	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	48293	
47537	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47538	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
47539	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
47540	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
47541	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
47542	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47543	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47544	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47545	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47546	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
47547	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47548	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
47549	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
47550	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47551	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
47552	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
47553	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
47554	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
47555	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47556	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47557	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
47558	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
47559	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
47560	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	15	
47561	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
47562	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
47563	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
47564	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
47565	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
47566	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49801	
47567	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47568	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
47569	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
47570	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
47571	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments		
47572	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
47573	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
47574	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	63.0	
47575	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
47576	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
47577	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
47578	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
47579	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
47580	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
47581	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
47582	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
47583	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
47584	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
47585	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
47586	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
47587	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
47588	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
47589	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
47590	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
47591	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
47592	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
47593	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
47594	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
47595	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
47596	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
47597	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
47598	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	0	
47599	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	447	
47600	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
47601	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
47602	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
47603	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
47604	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47605	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47606	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47607	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
47608	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
47609	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47610	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99991	
47611	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
47612	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
47613	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
47614	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
47615	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
47616	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
47617	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
47618	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	630	
47619	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	14L	
47620	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	6L	
47621	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	8L	
47622	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
47623	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	277683	
47624	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	277679	
47625	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
47626	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47627	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
47628	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
47629	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
47630	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
47631	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
47632	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
47633	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
47634	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	22	*C
47635	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	60	*C
47636	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47637	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
47638	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	450.0	
47639	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	420.0	
47640	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	414.0	
47641	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47642	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47643	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
47644	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
47645	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
47646	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
47647	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47648	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47649	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
47650	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		
47651	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
47652	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
47653	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	49	
47654	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
47655	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
47656	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
47657	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
47658	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
47659	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
47660	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
47661	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
47662	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
47663	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
47664	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
47665	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
47666	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
47667	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
47668	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
47669	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
47670	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
47671	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
47672	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47673	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47674	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
47675	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
47676	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47677	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
47678	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
47679	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47680	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
47681	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
47682	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
47683	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	9417.60	kw
47684	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
47685	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47686	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47687	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47688	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47689	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
47690	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47691	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
47692	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
47693	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47694	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments		
47695	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
47696	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
47697	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
47698	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47699	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47700	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
47701	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
47702	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
47703	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
47704	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
47705	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
47706	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
47707	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
47708	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
47709	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
47710	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47711	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
47712	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
47713	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
47714	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
47715	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
47716	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
47717	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
47718	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
47719	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
47720	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
47721	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
47722	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
47723	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
47724	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
47725	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
47726	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
47727	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments		
47728	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
47729	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
47730	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
47731	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
47732	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47733	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
47734	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
47735	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47736	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments		
47737	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
47738	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
47739	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
47740	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47741	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47742	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
47743	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
47744	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
47745	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
47746	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	39.0	
47747	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
47748	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
47749	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	76825	
47750	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47751	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
47752	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
47753	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
47754	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
47755	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
47756	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
47757	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
47758	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
47759	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
47760	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
47761	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
47762	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47763	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47764	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47765	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47766	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47767	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47768	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
47769	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
47770	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
47771	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.7188	
47772	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
47773	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47774	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
47775	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
47776	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
47777	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47778	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
47779	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
47780	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
47781	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
47782	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
47783	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
47784	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
47785	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
47786	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
47787	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
47788	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
47789	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
47790	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
47791	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47792	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
47793	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
47794	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47795	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
47796	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
47797	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
47798	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
47799	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47800	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
47801	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47802	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47803	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47804	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47805	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
47806	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
47807	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
47808	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
47809	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	35	°C
47810	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	38	°C
47811	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
47812	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
47813	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5175.36	kw
47814	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
47815	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
47816	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
47817	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
47818	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
47819	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
47820	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
47821	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
47822	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
47823	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
47824	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
47825	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
47826	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
47827	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
47828	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47829	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47830	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47831	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47832	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47833	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47834	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47835	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
47836	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	300.0	
47837	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	260.0	
47838	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	240.0	
47839	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47840	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47841	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
47842	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
47843	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	0.0	
47844	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	0.0	
47845	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
47846	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
47847	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
47848	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
47849	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
47850	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
47851	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47852	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
47853	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
47854	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
47855	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
47856	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
47857	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
47858	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
47859	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
47860	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
47861	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
47862	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
47863	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
47864	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47865	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47866	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47867	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	0.0	
47868	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
47869	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47870	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
47871	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
47872	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	4	
47873	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
47874	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
47875	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	55256	
47876	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
47877	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
47878	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
47879	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
47880	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
47881	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
47882	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
47883	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
47884	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47885	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
47886	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	120.0	
47887	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	140.0	
47888	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	100.0	
47889	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
47890	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47891	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47892	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
47893	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
47894	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	36	*F
47895	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
47896	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
47897	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
47898	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
47899	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
47900	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
47901	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
47902	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47903	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47904	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47905	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47906	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
47907	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47908	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
47909	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	336	
47910	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	425	
47911	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	410	
47912	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
47913	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
47914	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
47915	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	2	
47916	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
47917	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	0	
47918	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
47919	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0	
47920	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0	
47921	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0	
47922	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
47923	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
47924	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
47925	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
47926	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
47927	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
47928	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
47929	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
47930	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
47931	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
47932	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
47933	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
47934	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	261	
47935	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	261	
47936	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
47937	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	65	
47938	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	78	
47939	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
47940	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
47941	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
47942	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
47943	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
47944	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
47945	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
47946	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
47947	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
47948	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
47949	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
47950	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
47951	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
47952	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	157405	
47953	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	157405	
47954	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
47955	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	1R	
47956	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
47957	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
47958	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
47959	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
47960	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
47961	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
47962	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
47963	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
47964	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
47965	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
47966	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
47967	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
47968	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
47969	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
47970	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
47971	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
47972	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
47973	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments		
47974	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
47975	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
47976	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
47977	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
47978	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
47979	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6402	
47980	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
47981	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
47982	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	235	
47983	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	235	
47984	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	0	
47985	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
47986	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	0	
47987	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
47988	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
47989	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	2	
47990	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	179	
47991	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	179	
47992	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
47993	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
47994	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
47995	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
47996	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
47997	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
47998	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
47999	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
48000	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
48001	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48002	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
48003	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48004	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48005	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48006	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
48007	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48008	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48009	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
48010	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
48011	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48012	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48013	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48014	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48015	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
48016	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
48017	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
48018	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
48019	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
48020	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48021	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48022	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0	
48023	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0	
48024	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0	
48025	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A Ø	0	
48026	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B Ø	0	
48027	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C Ø	0	
48028	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	2L	
48029	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	12L	
48030	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	951	
48031	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48032	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48033	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
48034	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
48035	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48036	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
48037	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
48038	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
48039	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48040	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
48041	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
48042	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
48043	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
48044	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
48045	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
48046	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
48047	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
48048	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
48049	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48050	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	45	
48051	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
48052	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	220	
48053	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	220	
48054	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	45	
48055	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	General Comments		
48056	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
48057	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48058	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48059	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
48060	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48061	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48062	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
48063	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48064	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48065	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
48066	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
48067	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
48068	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48069	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	0	
48070	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
48071	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
48072	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
48073	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
48074	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
48075	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
48076	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48077	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
48078	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
48079	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
48080	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
48081	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
48082	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
48083	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
48084	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48085	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	2	
48086	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48087	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	2	
48088	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	226	
48089	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	226	
48090	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
48091	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48092	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
48093	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
48094	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
48095	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
48096	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	y	
48097	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
48098	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
48099	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		
48100	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	GREEN GOOD	
48101	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
48102	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
48103	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
48104	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C Ø	0	
48105	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B Ø	0	
48106	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
48107	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
48108	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
48109	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
48110	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
48111	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
48112	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
48113	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28614	
48114	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
48115	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
48116	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
48117	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
48118	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
48119	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48120	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48121	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48122	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
48123	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	242	
48124	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
48125	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48126	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	242	
48127	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
48128	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
48129	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48130	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
48131	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
48132	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
48133	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
48134	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
48135	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
48136	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48137	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
48138	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
48139	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
48140	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
48141	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	11119	
48142	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	11119	
48143	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
48144	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	4L	
48145	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48146	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48147	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48148	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
48149	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
48150	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	232369	
48151	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	232365	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48152	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
48153	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
48154	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
48155	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
48156	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
48157	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
48158	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
48159	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48160	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48161	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48162	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48163	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48164	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48165	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
48166	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48167	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48168	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48169	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
48170	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48171	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48172	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48173	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48174	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48175	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
48176	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
48177	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48178	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
48179	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
48180	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
48181	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
48182	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45995	
48183	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
48184	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
48185	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
48186	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
48187	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
48188	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
48189	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
48190	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
48191	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	37.0	
48192	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
48193	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
48194	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
48195	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
48196	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
48197	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
48198	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
48199	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
48200	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
48201	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
48202	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
48203	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
48204	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	94	
48205	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
48206	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
48207	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
48208	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48209	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48210	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48211	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48212	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil Level	Good	
48213	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
48214	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
48215	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
48216	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
48217	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-26 00:00:00.000000	
48218	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
48219	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
48220	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
48221	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
48222	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
48223	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
48224	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
48225	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1294	
48226	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
48227	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	13L	
48228	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	4R	
48229	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	9L	
48230	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
48231	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	37246	
48232	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	37238	
48233	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
48234	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
48235	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
48236	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
48237	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
48238	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
48239	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
48240	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
48241	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
48242	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
48243	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
48244	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
48245	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	344	
48246	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
48247	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
48248	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
48249	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
48250	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
48251	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
48252	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	2	
48253	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
48254	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
48255	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
48256	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48257	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48258	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
48259	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
48260	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	2R	
48261	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	2L	
48262	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	1R	
48263	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
48264	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
48265	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
48266	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
48267	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
48268	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
48269	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
48270	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
48271	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
48272	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
48273	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
48274	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
48275	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
48276	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
48277	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
48278	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
48279	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
48280	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
48281	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48282	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48283	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48284	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48285	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48286	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
48287	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
48288	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
48289	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48290	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48291	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
48292	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
48293	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
48294	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
48295	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
48296	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48297	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48298	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48299	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48300	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48301	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48302	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48303	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48304	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48305	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48306	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
48307	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
48308	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48309	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
48310	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
48311	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
48312	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	n	
48313	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
48314	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.5380	
48315	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
48316	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
48317	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
48318	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
48319	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
48320	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
48321	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
48322	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
48323	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	20	*C
48324	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	30	*C
48325	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
48326	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
48327	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	5164.80	kw
48328	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
48329	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
48330	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
48331	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
48332	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
48333	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
48334	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48335	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48336	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
48337	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
48338	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
48339	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
48340	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
48341	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48342	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48343	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48344	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48345	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48346	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
48347	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
48348	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
48349	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48350	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48351	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
48352	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
48353	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
48354	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
48355	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
48356	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
48357	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
48358	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
48359	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
48360	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
48361	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
48362	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
48363	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48364	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48365	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
48366	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48367	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48368	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
48369	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
48370	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
48371	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
48372	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48373	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48374	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
48375	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
48376	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48377	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48378	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48379	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
48380	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
48381	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
48382	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
48383	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
48384	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
48385	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
48386	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48387	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48388	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48389	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48390	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48391	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
48392	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
48393	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
48394	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
48395	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
48396	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48397	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48398	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
48399	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
48400	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
48401	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
48402	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48403	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48404	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
48405	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
48406	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
48407	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
48408	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48409	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48410	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48411	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48412	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
48413	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
48414	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48415	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
48416	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48417	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48418	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48419	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
48420	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48421	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48422	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48423	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48424	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48425	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48426	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
48427	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48428	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48429	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48430	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
48431	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48432	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48433	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48434	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48435	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48436	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48437	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	0	
48438	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
48439	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
48440	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
48441	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
48442	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	0	
48443	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48444	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	0	
48445	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	154	
48446	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	154	
48447	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
48448	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
48449	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48450	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
48451	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48452	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
48453	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
48454	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
48455	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
48456	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
48457	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
48458	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
48459	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
48460	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
48461	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
48462	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48463	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48464	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
48465	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	n	
48466	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
48467	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
48468	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
48469	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
48470	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
48471	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
48472	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	y	
48473	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
48474	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
48475	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
48476	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
48477	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
48478	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
48479	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
48480	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48481	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48482	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48483	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48484	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48485	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
48486	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	120.0	
48487	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	120.0	
48488	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	120.0	
48489	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
48490	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
48491	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
48492	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	5	
48493	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
48494	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
48495	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
48496	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48497	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48498	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48499	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48500	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48501	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
48502	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
48503	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
48504	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
48505	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
48506	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48507	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48508	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
48509	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
48510	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48511	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48512	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48513	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
48514	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
48515	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
48516	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
48517	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48518	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48519	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48520	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48521	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48522	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
48523	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
48524	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
48525	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48526	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48527	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
48528	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	3	
48529	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
48530	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
48531	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
48532	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
48533	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
48534	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
48535	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
48536	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
48537	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
48538	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
48539	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
48540	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
48541	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
48542	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
48543	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	4	
48544	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
48545	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
48546	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
48547	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120.0	
48548	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	120.0	
48549	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	120.0	
48550	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
48551	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48552	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48553	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
48554	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
48555	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
48556	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
48557	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48558	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	0	
48559	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	102	
48560	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	102	
48561	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
48562	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
48563	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48564	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
48565	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
48566	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
48567	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
48568	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
48569	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
48570	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
48571	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
48572	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
48573	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
48574	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
48575	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
48576	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48577	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48578	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48579	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48580	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	VRR Time Delay	30	Seconds
48581	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
48582	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
48583	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
48584	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	LTC Operation Checked?	y	
48585	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	General Comments		
48586	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	Follow-up Action Required?	n	
48587	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	LTC000047	LTCControl	427-1 C	LTC Control Insp	All Connections OK?	y	
48588	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48589	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
48590	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
48591	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
48592	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
48593	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48594	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48595	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48596	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48597	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48598	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
48599	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
48600	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
48601	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
48602	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
48603	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
48604	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	252300	
48605	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	252305	
48606	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
48607	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	3L	
48608	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	7L	
48609	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48610	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48611	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48612	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48613	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48614	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
48615	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	1L	
48616	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	625	
48617	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48618	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
48619	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
48620	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
48621	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
48622	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
48623	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48624	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48625	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48626	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
48627	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
48628	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
48629	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
48630	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48631	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48632	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48633	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
48634	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48635	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48636	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
48637	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48638	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
48639	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
48640	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
48641	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
48642	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
48643	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
48644	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	All Connections OK?	y	
48645	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
48646	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	General Comments		
48647	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48648	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
48649	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
48650	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
48651	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
48652	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
48653	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	All Connections OK?	y	
48654	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
48655	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	General Comments		
48656	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
48657	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
48658	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
48659	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
48660	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
48661	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	All Connections OK?	y	
48662	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
48663	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	General Comments		
48664	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
48665	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
48666	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
48667	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
48668	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
48669	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	All Connections OK?	y	
48670	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
48671	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	General Comments		
48672	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
48673	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
48674	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
48675	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
48676	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48677	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
48678	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
48679	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
48680	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
48681	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	305	
48682	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	305	
48683	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	1	
48684	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48685	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	1	
48686	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
48687	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
48688	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
48689	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
48690	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48691	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48692	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
48693	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48694	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48695	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
48696	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48697	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48698	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
48699	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
48700	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48701	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48702	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48703	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
48704	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
48705	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
48706	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
48707	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
48708	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
48709	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
48710	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
48711	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
48712	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
48713	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48714	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48715	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
48716	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48717	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48718	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
48719	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
48720	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
48721	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
48722	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
48723	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
48724	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
48725	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
48726	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
48727	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
48728	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
48729	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
48730	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
48731	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
48732	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
48733	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
48734	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
48735	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	337	
48736	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	8L	
48737	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	6L	
48738	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	8L	
48739	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
48740	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	83255	
48741	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	83255	
48742	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
48743	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
48744	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
48745	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
48746	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
48747	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
48748	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
48749	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
48750	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
48751	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48752	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
48753	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
48754	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
48755	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
48756	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48757	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48758	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
48759	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
48760	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	50.0	
48761	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	50.0	
48762	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	50.0	
48763	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
48764	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
48765	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
48766	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	4	
48767	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
48768	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48769	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
48770	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48771	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
48772	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
48773	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
48774	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
48775	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48776	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48777	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48778	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48779	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48780	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48781	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48782	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
48783	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48784	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
48785	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
48786	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
48787	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.047	millivolts
48788	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48789	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48790	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
48791	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
48792	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments		
48793	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
48794	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48795	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
48796	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48797	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48798	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
48799	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
48800	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
48801	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
48802	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments		
48803	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48804	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
48805	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
48806	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
48807	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
48808	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
48809	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48810	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48811	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48812	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48813	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
48814	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48815	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48816	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
48817	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
48818	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
48819	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
48820	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
48821	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
48822	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
48823	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
48824	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
48825	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
48826	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48827	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
48828	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
48829	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
48830	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
48831	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
48832	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
48833	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
48834	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
48835	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
48836	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48837	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48838	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
48839	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
48840	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	0	
48841	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48842	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	0	
48843	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	272	
48844	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	272	
48845	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
48846	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
48847	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48848	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
48849	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	General Comments		
48850	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
48851	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
48852	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
48853	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
48854	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
48855	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
48856	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
48857	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
48858	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
48859	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
48860	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
48861	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
48862	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
48863	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
48864	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
48865	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
48866	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
48867	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
48868	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
48869	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
48870	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48871	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48872	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	4	
48873	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
48874	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
48875	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
48876	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	100.0	
48877	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	100.0	
48878	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	100.0	
48879	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48880	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48881	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
48882	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
48883	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
48884	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
48885	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
48886	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
48887	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48888	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48889	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	C80286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48890	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
48891	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
48892	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	0	
48893	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
48894	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	0	
48895	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	19	
48896	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	19	
48897	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
48898	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
48899	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
48900	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
48901	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B80206	BreakerVacuum	697-0903	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
48902	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
48903	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
48904	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
48905	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
48906	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
48907	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
48908	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
48909	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
48910	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
48911	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
48912	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
48913	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48914	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48915	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48916	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48917	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48918	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48919	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
48920	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0	
48921	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
48922	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
48923	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
48924	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
48925	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
48926	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
48927	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
48928	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
48929	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
48930	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
48931	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
48932	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
48933	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
48934	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
48935	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
48936	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
48937	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
48938	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
48939	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
48940	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
48941	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
48942	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
48943	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
48944	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
48945	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0	
48946	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0	
48947	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
48948	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
48949	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
48950	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
48951	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
48952	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
48953	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
48954	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
48955	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
48956	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
48957	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
48958	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
48959	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
48960	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
48961	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
48962	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
48963	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
48964	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
48965	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
48966	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
48967	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
48968	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
48969	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
48970	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
48971	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
48972	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
48973	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
48974	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
48975	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
48976	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
48977	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
48978	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
48979	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
48980	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
48981	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
48982	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
48983	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
48984	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
48985	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
48986	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
48987	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
48988	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
48989	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
48990	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
48991	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
48992	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
48993	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
48994	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
48995	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
48996	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
48997	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
48998	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
48999	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49000	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
49001	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
49002	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
49003	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
49004	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49005	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49006	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
49007	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49008	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49009	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49010	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
49011	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49012	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
49013	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49014	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49015	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49016	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49017	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49018	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49019	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
49020	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49021	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
49022	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49023	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49024	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49025	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49026	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49027	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49028	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49029	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49030	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49031	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49032	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
49033	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49034	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
49035	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
49036	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	159	
49037	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	159	
49038	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	0	
49039	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	0	
49040	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49041	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49042	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49043	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49044	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49045	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49046	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
49047	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	193	
49048	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	277	
49049	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	244	
49050	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
49051	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	.76	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49052	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	1.51	%
49053	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	5	
49054	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
49055	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49056	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
49057	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
49058	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
49059	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
49060	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49061	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49062	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49063	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49064	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49065	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49066	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49067	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
49068	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49069	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
49070	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49071	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
49072	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
49073	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
49074	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49075	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
49076	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
49077	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49078	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
49079	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
49080	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
49081	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49082	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49083	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
49084	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
49085	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
49086	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49087	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49088	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	10.0	VDC
49089	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
49090	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
49091	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
49092	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
49093	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
49094	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
49095	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
49096	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49097	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49098	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
49099	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
49100	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
49101	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49102	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49103	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
49104	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
49105	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
49106	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
49107	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
49108	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
49109	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
49110	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
49111	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49112	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49113	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
49114	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49115	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49116	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49117	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
49118	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
49119	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
49120	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
49121	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	294	
49122	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	294	
49123	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	0	
49124	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
49125	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	0	
49126	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49127	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
49128	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49129	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
49130	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49131	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
49132	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49133	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49134	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49135	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49136	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49137	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49138	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49139	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
49140	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
49141	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49142	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49143	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49144	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
49145	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
49146	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
49147	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
49148	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49149	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49150	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49151	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49152	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49153	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
49154	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49155	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49156	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
49157	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
49158	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49159	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49160	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
49161	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49162	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
49163	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
49164	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49165	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
49166	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49167	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49168	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
49169	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
49170	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
49171	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
49172	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
49173	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
49174	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
49175	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
49176	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	213	
49177	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	213	
49178	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	2	
49179	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	2	
49180	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
49181	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
49182	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49183	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
49184	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
49185	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
49186	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
49187	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
49188	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
49189	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49190	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49191	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
49192	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
49193	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
49194	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
49195	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
49196	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
49197	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
49198	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49199	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49200	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	4	
49201	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
49202	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
49203	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
49204	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
49205	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
49206	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
49207	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
49208	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
49209	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49210	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49211	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49212	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49213	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49214	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
49215	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49216	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49217	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
49218	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
49219	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
49220	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
49221	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
49222	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
49223	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
49224	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
49225	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
49226	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49227	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49228	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49229	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49230	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49231	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49232	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49233	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49234	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49235	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
49236	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	40.0	
49237	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	60.0	
49238	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	90.0	
49239	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49240	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49241	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49242	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
49243	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49244	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments		
49245	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49246	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
49247	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
49248	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49249	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
49250	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49251	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49252	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
49253	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
49254	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49255	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
49256	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49257	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49258	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49259	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49260	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
49261	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49262	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49263	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49264	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49265	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49266	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49267	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49268	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
49269	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49270	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
49271	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49272	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49273	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
49274	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
49275	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
49276	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49277	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	581	
49278	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
49279	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	3R	
49280	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	6R	
49281	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	3R	
49282	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49283	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
49284	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
49285	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
49286	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
49287	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49288	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49289	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49290	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49291	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49292	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49293	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49294	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49295	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
49296	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
49297	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
49298	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
49299	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
49300	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
49301	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
49302	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
49303	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	°C
49304	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
49305	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
49306	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	26	°C
49307	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
49308	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
49309	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
49310	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49311	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49312	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49313	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49314	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49315	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49316	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
49317	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
49318	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
49319	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
49320	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
49321	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
49322	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
49323	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
49324	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
49325	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
49326	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
49327	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
49328	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
49329	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49330	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49331	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49332	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49333	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49334	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49335	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49336	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
49337	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
49338	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
49339	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
49340	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49341	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49342	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49343	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49344	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49345	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49346	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49347	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49348	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49349	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
49350	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49351	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49352	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49353	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49354	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49355	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49356	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49357	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49358	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49359	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49360	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49361	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49362	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
49363	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49364	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49365	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
49366	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49367	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49368	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49369	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49370	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49371	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
49372	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
49373	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
49374	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49375	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49376	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49377	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49378	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49379	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49380	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49381	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49382	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49383	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49384	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
49385	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49386	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
49387	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49388	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49389	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49390	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49391	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49392	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49393	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49394	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49395	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49396	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
49397	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	180.0	
49398	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	130.0	
49399	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	155.0	
49400	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49401	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
49402	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49403	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49404	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
49405	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
49406	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49407	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49408	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49409	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49410	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49411	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49412	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49413	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
49414	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
49415	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
49416	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-26 00:00:00.00000000	
49417	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
49418	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
49419	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
49420	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
49421	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
49422	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
49423	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49424	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49425	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49426	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49427	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49428	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49429	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49430	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49431	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49432	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49433	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
49434	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49435	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
49436	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49437	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49438	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49439	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
49440	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
49441	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49442	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49443	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49444	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49445	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
49446	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49447	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49448	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
49449	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	36759	
49450	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	36759	
49451	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
49452	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments		
49453	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
49454	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
49455	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
49456	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
49457	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
49458	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
49459	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
49460	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
49461	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
49462	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
49463	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
49464	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
49465	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
49466	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
49467	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
49468	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
49469	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
49470	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
49471	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
49472	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
49473	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
49474	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
49475	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
49476	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
49477	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
49478	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
49479	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
49480	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
49481	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49482	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
49483	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
49484	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
49485	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
49486	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49487	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
49488	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49489	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
49490	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
49491	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49492	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49493	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
49494	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
49495	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
49496	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49497	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49498	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49499	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49500	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49501	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49502	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49503	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
49504	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49505	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
49506	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49507	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
49508	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
49509	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49510	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
49511	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49512	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
49513	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
49514	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
49515	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
49516	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
49517	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49518	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49519	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
49520	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
49521	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
49522	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
49523	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49524	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
49525	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49526	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
49527	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
49528	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49529	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49530	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
49531	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49532	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
49533	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
49534	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49535	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49536	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49537	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49538	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49539	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49540	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49541	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49542	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49543	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49544	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
49545	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	45.0	
49546	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	60.0	
49547	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	80.0	
49548	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49549	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49550	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49551	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	2	
49552	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
49553	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
49554	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	0	
49555	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	0	
49556	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	159	
49557	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	159	
49558	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
49559	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
49560	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
49561	12/2/2019 11:38	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	Fabric and top rails rusty.	
49562	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
49563	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
49564	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
49565	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
49566	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
49567	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
49568	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
49569	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
49570	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
49571	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	
49572	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
49573	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
49574	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
49575	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
49576	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49577	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	161	
49578	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	161	
49579	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	4	
49580	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	4	
49581	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
49582	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
49583	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	0	
49584	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49585	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49586	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49587	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	161.0	
49588	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	175.0	
49589	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	167.0	
49590	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49591	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
49592	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49593	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
49594	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
49595	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49596	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
49597	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
49598	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
49599	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
49600	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
49601	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
49602	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49603	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
49604	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
49605	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
49606	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
49607	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
49608	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
49609	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
49610	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
49611	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49612	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49613	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49614	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49615	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49616	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49617	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49618	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49619	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49620	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	3	
49621	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49622	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49623	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49624	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	150.0	
49625	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	100.0	
49626	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	140.0	
49627	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
49628	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49629	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49630	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49631	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49632	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49633	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49634	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49635	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49636	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49637	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
49638	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
49639	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
49640	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
49641	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
49642	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
49643	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
49644	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	364	
49645	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	0	
49646	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
49647	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	0	
49648	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
49649	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
49650	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49651	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49652	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49653	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
49654	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B Ø	0	
49655	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C Ø	0	
49656	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
49657	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
49658	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
49659	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	4	
49660	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49661	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49662	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49663	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	160.0	
49664	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	180.0	
49665	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	160.0	
49666	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
49667	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49668	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49669	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49670	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49671	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49672	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49673	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49674	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49675	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49676	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
49677	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
49678	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
49679	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
49680	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
49681	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
49682	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
49683	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
49684	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
49685	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
49686	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
49687	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
49688	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
49689	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
49690	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
49691	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	0	
49692	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
49693	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
49694	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	8017.92	kw
49695	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
49696	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
49697	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
49698	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	25	°C
49699	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	20	°C
49700	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
49701	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
49702	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
49703	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	0	
49704	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2025	
49705	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2025	
49706	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
49707	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
49708	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
49709	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
49710	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
49711	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
49712	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
49713	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
49714	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
49715	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
49716	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
49717	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
49718	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.5568	
49719	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	30	°C
49720	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	20	°C
49721	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
49722	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
49723	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
49724	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
49725	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
49726	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49727	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
49728	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
49729	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49730	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49731	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
49732	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
49733	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
49734	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49735	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
49736	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
49737	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
49738	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
49739	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
49740	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
49741	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
49742	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
49743	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
49744	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
49745	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
49746	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
49747	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
49748	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
49749	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
49750	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
49751	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
49752	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
49753	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
49754	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
49755	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
49756	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
49757	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
49758	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
49759	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
49760	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	206	
49761	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	206	
49762	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
49763	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
49764	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
49765	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
49766	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
49767	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
49768	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
49769	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
49770	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
49771	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
49772	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
49773	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
49774	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
49775	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49776	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49777	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49778	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49779	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49780	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49781	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
49782	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	294.0	
49783	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	317.0	
49784	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	293.0	
49785	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49786	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49787	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49788	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	1	
49789	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	5	
49790	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
49791	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
49792	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
49793	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	50.0	
49794	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	50.0	
49795	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	30.0	
49796	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
49797	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49798	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49799	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49800	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49801	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
49802	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49803	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
49804	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
49805	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments		
49806	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments		
49807	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
49808	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
49809	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	0	
49810	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
49811	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	139	
49812	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	139	
49813	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	0	
49814	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
49815	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
49816	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
49817	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
49818	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
49819	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
49820	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
49821	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
49822	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
49823	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
49824	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
49825	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
49826	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
49827	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
49828	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
49829	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	209	
49830	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	209	
49831	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
49832	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
49833	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
49834	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
49835	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
49836	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
49837	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
49838	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
49839	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
49840	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
49841	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
49842	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
49843	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
49844	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.4600	
49845	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
49846	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
49847	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
49848	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
49849	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	if no, which cells in comments
49850	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
49851	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
49852	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
49853	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
49854	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
49855	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
49856	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
49857	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
49858	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
49859	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
49860	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
49861	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
49862	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
49863	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
49864	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
49865	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
49866	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
49867	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
49868	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
49869	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
49870	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
49871	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
49872	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
49873	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2760.00	kw
49874	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
49875	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
49876	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	55	*C

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49877	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	°C
49878	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
49879	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
49880	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
49881	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
49882	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
49883	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
49884	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
49885	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
49886	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
49887	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
49888	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTC000030	LTCControl	593-2	LTC Control Insp	General Comments		
49889	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
49890	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
49891	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
49892	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
49893	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
49894	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
49895	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
49896	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
49897	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
49898	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
49899	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
49900	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
49901	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
49902	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	1	
49903	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	1	
49904	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	221	
49905	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	221	
49906	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
49907	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
49908	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
49909	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
49910	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
49911	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
49912	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
49913	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
49914	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
49915	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
49916	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
49917	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
49918	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
49919	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0	
49920	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0	
49921	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0	
49922	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
49923	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
49924	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
49925	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
49926	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
49927	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
49928	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
49929	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	72	
49930	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	69	
49931	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	77	
49932	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0	%
49933	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
49934	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0	%
49935	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	3	
49936	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
49937	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
49938	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
49939	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
49940	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
49941	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
49942	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
49943	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
49944	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
49945	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
49946	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
49947	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
49948	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
49949	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
49950	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
49951	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
49952	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
49953	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
49954	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
49955	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
49956	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
49957	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
49958	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
49959	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top rail is getting rusty	
49960	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
49961	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
49962	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
49963	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
49964	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
49965	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
49966	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
49967	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
49968	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
49969	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
49970	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
49971	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
49972	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
49973	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
49974	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
49975	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
49976	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
49977	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
49978	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
49979	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
49980	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
49981	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
49982	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
49983	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
49984	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
49985	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
49986	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
49987	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
49988	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
49989	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
49990	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
49991	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
49992	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
49993	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
49994	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
49995	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
49996	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
49997	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
49998	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
49999	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
50000	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
50001	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
50002	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
50003	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
50004	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
50005	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
50006	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
50007	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
50008	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
50009	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
50010	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
50011	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
50012	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
50013	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
50014	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
50015	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
50016	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
50017	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
50018	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
50019	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
50020	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
50021	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
50022	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
50023	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
50024	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
50025	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
50026	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50027	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
50028	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50029	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
50030	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
50031	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
50032	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
50033	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50034	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50035	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
50036	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
50037	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
50038	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
50039	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
50040	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
50041	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
50042	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
50043	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
50044	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
50045	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
50046	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
50047	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50048	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50049	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50050	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50051	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50052	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50053	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50054	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50055	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
50056	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
50057	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
50058	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
50059	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
50060	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
50061	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
50062	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
50063	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
50064	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
50065	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50066	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
50067	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
50068	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	168	
50069	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	168	
50070	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	1	
50071	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50072	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	1	
50073	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
50074	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
50075	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	5	
50076	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	1.25	%
50077	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
50078	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
50079	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	60	
50080	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	60	
50081	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
50082	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
50083	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
50084	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
50085	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
50086	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	100	
50087	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
50088	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50089	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50090	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50091	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50092	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50093	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50094	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0	
50095	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0	
50096	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0	
50097	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
50098	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
50099	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
50100	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
50101	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50102	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
50103	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
50104	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
50105	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
50106	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
50107	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	General Comments		
50108	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
50109	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
50110	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50111	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50112	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
50113	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50114	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	330	
50115	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	12L	
50116	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	4L	
50117	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	7L	
50118	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50119	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	16432	
50120	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	16432	
50121	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
50122	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
50123	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50124	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
50125	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
50126	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	364	
50127	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
50128	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
50129	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
50130	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
50131	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
50132	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
50133	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
50134	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.5	
50135	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
50136	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
50137	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50138	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
50139	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50140	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50141	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
50142	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
50143	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
50144	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
50145	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50146	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
50147	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
50148	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50149	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
50150	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
50151	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
50152	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
50153	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
50154	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
50155	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	3628.80	kw
50156	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
50157	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
50158	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	85	°C
50159	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
50160	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstruction?	y	
50161	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
50162	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50163	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
50164	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
50165	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
50166	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
50167	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50168	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
50169	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	384.0	
50170	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	480.0	
50171	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	448.0	
50172	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50173	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50174	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50175	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	2	
50176	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50177	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50178	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50179	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50180	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50181	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50182	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
50183	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	75.0	
50184	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	90.0	
50185	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	102.0	
50186	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50187	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50188	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50189	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	4	
50190	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50191	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50192	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50193	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	289	
50194	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	7L	
50195	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	2L	
50196	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	4L	
50197	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50198	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	177463	
50199	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	177463	
50200	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
50201	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
50202	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
50203	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
50204	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
50205	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
50206	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7560	
50207	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
50208	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
50209	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
50210	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
50211	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
50212	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
50213	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
50214	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
50215	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
50216	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
50217	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
50218	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
50219	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
50220	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
50221	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
50222	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
50223	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
50224	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
50225	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
50226	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
50227	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
50228	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
50229	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
50230	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
50231	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
50232	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
50233	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
50234	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
50235	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
50236	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
50237	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
50238	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
50239	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
50240	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
50241	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
50242	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
50243	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
50244	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	n	
50245	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
50246	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
50247	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments		
50248	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
50249	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	n	
50250	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
50251	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50252	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
50253	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
50254	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50255	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50256	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
50257	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
50258	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
50259	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
50260	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50261	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
50262	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
50263	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50264	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
50265	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
50266	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
50267	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
50268	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
50269	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
50270	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	4668.48	kw
50271	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
50272	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
50273	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
50274	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	30	°C
50275	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	20	°C
50276	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
50277	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
50278	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50279	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
50280	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
50281	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
50282	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
50283	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
50284	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	.9726	
50285	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	30	°C
50286	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	15	°C
50287	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
50288	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140	
50289	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	160	
50290	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	160	
50291	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50292	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
50293	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	100	
50294	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	90	
50295	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	100	
50296	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0	%
50297	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0	%
50298	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0	%
50299	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	4	
50300	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
50301	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50302	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50303	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50304	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50305	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50306	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50307	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
50308	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
50309	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
50310	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
50311	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
50312	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
50313	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
50314	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
50315	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
50316	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
50317	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
50318	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
50319	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
50320	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
50321	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
50322	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
50323	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
50324	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
50325	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
50326	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50327	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
50328	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
50329	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
50330	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
50331	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
50332	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
50333	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
50334	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
50335	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	5	
50336	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50337	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
50338	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
50339	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
50340	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
50341	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
50342	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	General Comments		
50343	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
50344	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	All Connections OK?	y	
50345	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50346	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50347	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	141.0	
50348	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	135.0	
50349	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	134.0	
50350	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
50351	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50352	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50353	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50354	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50355	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50356	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50357	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50358	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50359	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50360	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
50361	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
50362	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
50363	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
50364	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
50365	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
50366	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
50367	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
50368	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
50369	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50370	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50371	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50372	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50373	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50374	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50375	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50376	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50377	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
50378	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
50379	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
50380	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
50381	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
50382	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
50383	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
50384	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
50385	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
50386	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
50387	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50388	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
50389	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
50390	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	104	
50391	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	104	
50392	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	0	
50393	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50394	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	0	
50395	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
50396	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
50397	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	5	
50398	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50399	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50400	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50401	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	20.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50402	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	20.0	
50403	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	20.0	
50404	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
50405	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50406	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50407	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50408	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50409	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50410	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50411	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50412	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50413	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50414	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
50415	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
50416	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
50417	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50418	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50419	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50420	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50421	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
50422	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
50423	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
50424	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
50425	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
50426	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
50427	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
50428	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
50429	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
50430	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
50431	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
50432	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
50433	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
50434	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
50435	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	41.18	kw
50436	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
50437	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
50438	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	26	°C
50439	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
50440	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
50441	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
50442	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50443	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
50444	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
50445	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
50446	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	240	
50447	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1716	
50448	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
50449	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
50450	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
50451	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
50452	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
50453	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
50454	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	10905	
50455	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	10905	
50456	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50457	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	5L	
50458	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	3L	
50459	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	8L	
50460	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
50461	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
50462	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	443	
50463	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50464	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
50465	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50466	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50467	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
50468	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
50469	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
50470	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
50471	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
50472	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
50473	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
50474	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
50475	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
50476	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
50477	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
50478	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
50479	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
50480	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
50481	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
50482	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
50483	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
50484	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
50485	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
50486	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
50487	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
50488	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
50489	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50490	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
50491	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	100.0	
50492	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	100.0	
50493	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	150.0	
50494	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50495	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50496	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50497	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	4	
50498	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
50499	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
50500	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
50501	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
50502	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	63135	
50503	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	63135	
50504	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50505	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	2L	
50506	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
50507	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	12L	
50508	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	*C
50509	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	*C
50510	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	830	
50511	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
50512	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50513	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50514	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50515	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
50516	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
50517	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
50518	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
50519	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
50520	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	LTC000648	LTCControl	824-1	LTC Control Insp	General Comments		
50521	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
50522	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
50523	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
50524	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
50525	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
50526	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
50527	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
50528	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
50529	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
50530	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
50531	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	34	
50532	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	34	
50533	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	0	
50534	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50535	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	0	
50536	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
50537	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
50538	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
50539	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
50540	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
50541	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50542	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	0	
50543	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	146	
50544	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	146	
50545	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
50546	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
50547	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50548	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
50549	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
50550	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
50551	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50552	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
50553	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
50554	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
50555	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
50556	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
50557	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
50558	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
50559	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50560	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50561	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
50562	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
50563	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
50564	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
50565	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50566	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
50567	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
50568	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50569	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
50570	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
50571	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
50572	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50573	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50574	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50575	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50576	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50577	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50578	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50579	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50580	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50581	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
50582	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	112.0	
50583	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	75.0	
50584	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	100.0	
50585	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50586	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
50587	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
50588	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
50589	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
50590	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
50591	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
50592	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
50593	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
50594	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
50595	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
50596	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
50597	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
50598	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
50599	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
50600	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
50601	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
50602	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
50603	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
50604	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
50605	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
50606	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
50607	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
50608	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
50609	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
50610	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50611	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
50612	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
50613	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
50614	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
50615	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
50616	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
50617	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
50618	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
50619	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
50620	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	n	
50621	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
50622	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
50623	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
50624	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
50625	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
50626	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50627	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
50628	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
50629	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
50630	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	0	
50631	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50632	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	0	
50633	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	408	
50634	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	408	
50635	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
50636	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
50637	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50638	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
50639	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
50640	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
50641	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
50642	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
50643	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
50644	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
50645	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
50646	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
50647	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
50648	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50649	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50650	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
50651	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
50652	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
50653	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
50654	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
50655	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	5770	
50656	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	5778	
50657	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50658	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	2R	
50659	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	7R	
50660	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	7L	
50661	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	1043	
50662	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50663	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50664	12/2/2019 12:51	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50665	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50666	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
50667	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
50668	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
50669	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
50670	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
50671	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
50672	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
50673	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
50674	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
50675	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
50676	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	5	
50677	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50678	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50679	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50680	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	100.0	
50681	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	100.0	
50682	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	120.0	
50683	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
50684	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50685	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50686	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50687	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50688	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50689	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50690	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50691	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
50692	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
50693	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
50694	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
50695	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
50696	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
50697	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
50698	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
50699	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
50700	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
50701	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50702	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	237	
50703	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	237	
50704	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
50705	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
50706	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50707	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
50708	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
50709	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
50710	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
50711	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
50712	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
50713	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
50714	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
50715	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
50716	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
50717	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0	
50718	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0	
50719	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0	
50720	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50721	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
50722	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
50723	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
50724	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
50725	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
50726	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
50727	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
50728	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
50729	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
50730	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
50731	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
50732	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
50733	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
50734	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
50735	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
50736	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
50737	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
50738	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50739	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50740	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50741	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50742	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
50743	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
50744	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
50745	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
50746	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
50747	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
50748	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
50749	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	72	
50750	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	72	
50751	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
50752	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
50753	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
50754	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
50755	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
50756	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
50757	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
50758	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
50759	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
50760	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
50761	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
50762	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
50763	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
50764	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
50765	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50766	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50767	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
50768	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
50769	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
50770	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
50771	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments	SPR Lights not lit, showing a target on the relay. Bulb was blown, replaced and the normal light is on. Also reset target.	
50772	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
50773	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
50774	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
50775	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
50776	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50777	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
50778	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
50779	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
50780	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
50781	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
50782	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
50783	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
50784	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
50785	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
50786	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
50787	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
50788	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
50789	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
50790	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
50791	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
50792	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
50793	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
50794	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
50795	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
50796	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
50797	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
50798	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
50799	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
50800	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
50801	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
50802	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
50803	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
50804	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
50805	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
50806	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
50807	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
50808	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
50809	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
50810	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
50811	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
50812	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
50813	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
50814	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	0	
50815	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
50816	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
50817	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
50818	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
50819	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	207	
50820	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	207	
50821	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
50822	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
50823	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
50824	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
50825	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
50826	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
50827	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.3348	
50828	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
50829	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Present	43	*C
50830	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Max	50	*C
50831	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
50832	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
50833	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
50834	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
50835	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50836	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
50837	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
50838	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
50839	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
50840	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	3214.08	kw
50841	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
50842	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
50843	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
50844	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
50845	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	2	
50846	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50847	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50848	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
50849	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
50850	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
50851	12/2/2019 11:54	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50852	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
50853	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
50854	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
50855	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
50856	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	out of service	
50857	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
50858	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
50859	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
50860	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
50861	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
50862	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments	LTC has breather installed	
50863	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	2189	
50864	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	2197	
50865	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
50866	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
50867	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	7R	
50868	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	9L	
50869	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
50870	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	897	
50871	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
50872	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
50873	12/2/2019 13:30	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
50874	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
50875	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
50876	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
50877	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
50878	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
50879	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
50880	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
50881	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
50882	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
50883	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
50884	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
50885	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
50886	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50887	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50888	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50889	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50890	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50891	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50892	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50893	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50894	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
50895	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
50896	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
50897	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
50898	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
50899	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
50900	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
50901	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
50902	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50903	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
50904	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
50905	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50906	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50907	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50908	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
50909	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
50910	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
50911	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
50912	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
50913	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
50914	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
50915	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
50916	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
50917	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
50918	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
50919	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	6663.60	kw
50920	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
50921	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
50922	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	30	°C
50923	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
50924	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
50925	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
50926	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
50927	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	20	°C
50928	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
50929	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
50930	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
50931	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
50932	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
50933	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
50934	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
50935	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
50936	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
50937	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
50938	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
50939	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
50940	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
50941	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
50942	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
50943	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
50944	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
50945	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
50946	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
50947	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
50948	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
50949	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
50950	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	76.0	
50951	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	119.0	
50952	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
50953	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
50954	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
50955	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
50956	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
50957	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
50958	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
50959	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
50960	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
50961	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
50962	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
50963	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
50964	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	80	
50965	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
50966	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
50967	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
50968	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
50969	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
50970	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
50971	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	236	
50972	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	236	
50973	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	0	
50974	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
50975	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
50976	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
50977	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps A Ø	0.0	
50978	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps B Ø	0.0	
50979	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps C Ø	0.0	
50980	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushing Condition	Good	
50981	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushings Connection/Risers	Good	
50982	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
50983	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
50984	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
50985	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Paint Condition	Good	
50986	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
50987	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
50988	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
50989	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
50990	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
50991	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
50992	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
50993	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
50994	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
50995	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
50996	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
50997	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
50998	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
50999	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
51000	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
51001	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1487	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
51002	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
51003	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
51004	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
51005	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51006	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51007	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51008	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51009	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51010	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51011	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51012	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations A Ø	0	
51013	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations B Ø	0	
51014	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations C Ø	0	
51015	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations Ground	0	
51016	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Follow-up Action Required?	n	
51017	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Follow-up Action Required?	n	
51018	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Foundation Condition	Good	
51019	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	General Comments		
51020	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	General Comments		BREAKER NOT IN SERVICE
51021	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Grounds in Place?	y	
51022	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51023	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Maintenance Operations	0	
51024	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Moisture and Leak Free?	y	
51025	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AF	205	
51026	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	100.0	
51027	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
51028	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51029	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51030	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51031	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51032	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51033	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
51034	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.3702	
51035	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	35	°C
51036	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	25	°C
51037	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
51038	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
51039	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments		
51040	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
51041	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51042	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
51043	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
51044	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
51045	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
51046	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
51047	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
51048	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	0	
51049	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
51050	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	110	
51051	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	110	
51052	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	0	
51053	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
51054	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
51055	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
51056	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51057	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
51058	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100	
51059	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6520.32	kw
51060	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
51061	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
51062	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
51063	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
51064	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51065	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
51066	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
51067	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51068	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
51069	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
51070	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51071	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
51072	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6792	
51073	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
51074	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
51075	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
51076	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51077	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
51078	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
51079	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
51080	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
51081	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
51082	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
51083	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
51084	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
51085	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
51086	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
51087	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
51088	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	18	
51089	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
51090	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
51091	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
51092	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	40.0	
51093	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	40.0	
51094	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51095	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
51096	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
51097	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51098	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51099	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51100	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
51101	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51102	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0	
51103	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	0	
51104	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0	
51105	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51106	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
51107	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
51108	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
51109	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
51110	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
51111	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments		
51112	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
51113	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
51114	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51115	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51116	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51117	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51118	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51119	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51120	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51121	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51122	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
51123	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51124	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
51125	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
51126	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
51127	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
51128	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
51129	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
51130	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
51131	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
51132	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
51133	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	5192.64	kw
51134	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51135	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51136	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
51137	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	50	°C
51138	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51139	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51140	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51141	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
51142	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	12	
51143	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	27	
51144	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	20	
51145	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	5.29	%
51146	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	8.31	%
51147	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	6.8	%
51148	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
51149	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	6	
51150	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
51151	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51152	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
51153	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
51154	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
51155	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
51156	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51157	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
51158	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
51159	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
51160	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
51161	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
51162	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
51163	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
51164	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
51165	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	0	
51166	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
51167	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
51168	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
51169	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
51170	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
51171	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
51172	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
51173	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
51174	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
51175	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
51176	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
51177	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
51178	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
51179	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
51180	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
51181	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
51182	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51183	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51184	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51185	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51186	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51187	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51188	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51189	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51190	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51191	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51192	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51193	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51194	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
51195	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51196	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
51197	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51198	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51199	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51200	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51201	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51202	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51203	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51204	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51205	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51206	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
51207	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51208	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51209	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51210	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51211	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51212	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51213	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
51214	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
51215	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
51216	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
51217	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
51218	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
51219	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
51220	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
51221	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51222	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
51223	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
51224	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
51225	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
51226	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
51227	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	1.0818	
51228	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
51229	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
51230	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
51231	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
51232	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51233	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51234	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51235	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51236	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
51237	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
51238	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
51239	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
51240	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
51241	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
51242	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51243	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
51244	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51245	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
51246	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
51247	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
51248	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
51249	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51250	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51251	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51252	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51253	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51254	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51255	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
51256	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
51257	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	876	
51258	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
51259	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
51260	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
51261	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51262	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51263	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51264	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51265	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51266	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51267	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51268	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51269	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51270	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51271	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
51272	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51273	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
51274	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
51275	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
51276	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
51277	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
51278	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
51279	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
51280	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
51281	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.7854	
51282	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
51283	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51284	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
51285	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
51286	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51287	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
51288	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
51289	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51290	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	20	*C
51291	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	50	*C
51292	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
51293	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51294	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	3769.92	kw
51295	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
51296	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
51297	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
51298	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
51299	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
51300	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
51301	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51302	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
51303	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
51304	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51305	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51306	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51307	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51308	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51309	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51310	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51311	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
51312	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
51313	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
51314	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
51315	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
51316	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
51317	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
51318	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
51319	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
51320	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
51321	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
51322	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
51323	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
51324	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
51325	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
51326	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
51327	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
51328	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51329	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51330	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
51331	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51332	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
51333	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
51334	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51335	12/2/2019 13:35	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51336	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
51337	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51338	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51339	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51340	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51341	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51342	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51343	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
51344	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
51345	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
51346	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
51347	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
51348	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
51349	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
51350	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
51351	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
51352	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
51353	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
51354	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
51355	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
51356	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
51357	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
51358	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
51359	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
51360	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51361	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51362	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51363	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51364	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51365	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
51366	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51367	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
51368	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.6672	
51369	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
51370	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51371	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
51372	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
51373	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
51374	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
51375	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
51376	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51377	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
51378	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health?	100.00	
51379	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
51380	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
51381	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
51382	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
51383	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
51384	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
51385	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
51386	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
51387	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
51388	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
51389	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
51390	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
51391	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
51392	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
51393	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
51394	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
51395	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
51396	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
51397	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
51398	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
51399	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
51400	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
51401	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
51402	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
51403	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
51404	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51405	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
51406	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
51407	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51408	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51409	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51410	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51411	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51412	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51413	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
51414	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	20.0	
51415	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	20.0	
51416	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	20.0	
51417	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
51418	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
51419	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
51420	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	5	
51421	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
51422	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
51423	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
51424	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
51425	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
51426	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
51427	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
51428	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
51429	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
51430	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-11 00:00:00.000000	
51431	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
51432	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	419	
51433	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	419	
51434	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
51435	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
51436	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
51437	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
51438	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
51439	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
51440	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
51441	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
51442	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
51443	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
51444	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
51445	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
51446	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
51447	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
51448	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51449	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51450	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
51451	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51452	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
51453	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
51454	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
51455	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
51456	12/2/2019 13:44	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
51457	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
51458	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C Ø	0	
51459	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B Ø	0	
51460	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A Ø	0	
51461	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51462	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
51463	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
51464	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51465	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51466	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51467	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	n	
51468	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51469	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51470	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	
51471	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C Ø	0.0	
51472	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps B Ø	0.0	
51473	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps A Ø	0.0	
51474	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
51475	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
51476	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
51477	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51478	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51479	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51480	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
51481	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51482	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments	POST CAPS HOLDING BARB WIRE ARE COMING OFF THE POSTS. POSTS APPEAR TO BE SINKING	
51483	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51484	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51485	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51486	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51487	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51488	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51489	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51490	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51491	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51492	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51493	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51494	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51495	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
51496	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	1	
51497	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
51498	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
51499	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51500	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	2	
51501	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	388	
51502	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	388	
51503	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
51504	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
51505	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51506	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
51507	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
51508	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
51509	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
51510	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
51511	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations	0	
51512	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Unknown Operations	0	
51513	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Tank Paint Condition	Good	
51514	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Switching Operations	0	
51515	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51516	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations This Read Vac	0	
51517	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
51518	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
51519	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
51520	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
51521	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
51522	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
51523	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
51524	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
51525	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
51526	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51527	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
51528	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
51529	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
51530	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
51531	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
51532	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
51533	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
51534	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
51535	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
51536	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
51537	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
51538	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
51539	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
51540	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
51541	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
51542	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
51543	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
51544	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
51545	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
51546	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
51547	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
51548	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
51549	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
51550	12/2/2019 13:04	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
51551	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51552	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		POST CAPS HOLDING BARB WIRE ARE COMING OFF THE POSTS. POSTS APPEAR TO BE SINKING
51553	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51554	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51555	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51556	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51557	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
51558	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51559	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51560	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51561	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51562	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	0	
51563	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
51564	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	0	
51565	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51566	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	0	
51567	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	174	
51568	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	174	
51569	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
51570	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
51571	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	n	
51572	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	n	
51573	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		not in service yet
51574	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
51575	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
51576	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
51577	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
51578	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
51579	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
51580	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
51581	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
51582	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51583	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51584	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51585	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51586	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51587	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
51588	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
51589	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
51590	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
51591	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
51592	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
51593	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51594	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51595	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51596	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
51597	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
51598	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
51599	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
51600	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
51601	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51602	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51603	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51604	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51605	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51606	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51607	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51608	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51609	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51610	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51611	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51612	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51613	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51614	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51615	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51616	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51617	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51618	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51619	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments		
51620	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51621	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51622	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51623	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51624	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51625	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51626	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51627	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
51628	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
51629	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
51630	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
51631	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
51632	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	200.0	
51633	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	180.0	
51634	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	240.0	
51635	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
51636	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
51637	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
51638	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51639	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51640	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51641	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51642	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
51643	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
51644	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
51645	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
51646	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
51647	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
51648	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
51649	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51650	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51651	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51652	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
51653	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
51654	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
51655	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
51656	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
51657	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
51658	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
51659	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
51660	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
51661	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	37	°C
51662	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
51663	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1420	
51664	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
51665	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51666	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
51667	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
51668	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51669	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
51670	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
51671	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51672	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
51673	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
51674	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
51675	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
51676	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2740.80	kw

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51677	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
51678	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
51679	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51680	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
51681	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
51682	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
51683	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
51684	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	0	
51685	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51686	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	0	
51687	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	224	
51688	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	224	
51689	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
51690	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
51691	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51692	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
51693	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
51694	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
51695	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
51696	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
51697	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
51698	12/2/2019 12:39	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
51699	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51700	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
51701	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
51702	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51703	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
51704	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
51705	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
51706	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	General Comments		
51707	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
51708	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
51709	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
51710	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
51711	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
51712	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
51713	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
51714	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	0	
51715	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51716	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	0	
51717	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	544	
51718	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	544	
51719	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
51720	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	2	
51721	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
51722	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
51723	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
51724	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	75.0	
51725	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	155.0	
51726	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	110.0	
51727	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
51728	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
51729	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
51730	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
51731	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
51732	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
51733	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
51734	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
51735	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
51736	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
51737	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
51738	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
51739	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
51740	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
51741	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
51742	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
51743	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
51744	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
51745	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
51746	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
51747	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
51748	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
51749	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	112	
51750	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	112	
51751	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51752	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	0	
51753	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
51754	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
51755	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
51756	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51757	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
51758	12/2/2019 13:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
51759	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	7	
51760	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
51761	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
51762	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
51763	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
51764	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
51765	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
51766	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
51767	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
51768	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
51769	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
51770	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
51771	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
51772	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
51773	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
51774	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
51775	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
51776	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
51777	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
51778	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	1	
51779	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
51780	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
51781	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
51782	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
51783	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
51784	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
51785	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
51786	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
51787	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
51788	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
51789	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
51790	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
51791	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
51792	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
51793	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
51794	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
51795	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
51796	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
51797	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AL	205	
51798	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
51799	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51800	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51801	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51802	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51803	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51804	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51805	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51806	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
51807	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
51808	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
51809	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
51810	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
51811	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
51812	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
51813	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
51814	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
51815	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	6405.12	kw
51816	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51817	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
51818	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	60	*C
51819	12/2/2019 12:34	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	30	*C
51820	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51821	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51822	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51823	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
51824	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
51825	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
51826	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51827	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
51828	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
51829	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51830	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51831	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
51832	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
51833	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
51834	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
51835	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
51836	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
51837	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
51838	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
51839	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
51840	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
51841	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	49	
51842	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	67	
51843	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	61	
51844	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
51845	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
51846	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	*C
51847	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	50	*C
51848	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
51849	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
51850	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3432.00	kw
51851	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
51852	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
51853	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
51854	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
51855	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
51856	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
51857	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
51858	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
51859	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
51860	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
51861	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
51862	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
51863	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
51864	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
51865	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
51866	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
51867	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
51868	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
51869	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
51870	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
51871	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
51872	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	0	
51873	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
51874	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	0	
51875	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51876	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51877	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
51878	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
51879	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
51880	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
51881	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
51882	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
51883	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments	lot base is not sufficient for travel. even small trucks are leaving ruts when it is dry in the new sub.	
51884	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
51885	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
51886	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
51887	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
51888	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
51889	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
51890	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
51891	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
51892	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
51893	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
51894	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
51895	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
51896	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
51897	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
51898	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
51899	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
51900	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	149	
51901	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	149	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51902	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
51903	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
51904	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
51905	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
51906	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
51907	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
51908	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
51909	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
51910	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
51911	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
51912	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.4290	
51913	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
51914	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
51915	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
51916	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
51917	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
51918	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
51919	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
51920	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
51921	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
51922	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51923	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
51924	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
51925	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
51926	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
51927	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
51928	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
51929	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
51930	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
51931	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
51932	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
51933	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
51934	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
51935	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
51936	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
51937	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
51938	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
51939	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	91	
51940	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
51941	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
51942	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
51943	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
51944	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
51945	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
51946	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
51947	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
51948	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
51949	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
51950	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
51951	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
51952	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
51953	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
51954	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
51955	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
51956	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
51957	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments	out of service	
51958	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
51959	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
51960	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
51961	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
51962	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
51963	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
51964	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
51965	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
51966	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
51967	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
51968	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
51969	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
51970	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
51971	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
51972	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
51973	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	957	
51974	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
51975	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
51976	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
51977	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
51978	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
51979	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
51980	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
51981	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
51982	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
51983	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
51984	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
51985	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
51986	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
51987	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
51988	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
51989	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
51990	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
51991	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
51992	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
51993	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
51994	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
51995	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
51996	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
51997	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
51998	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
51999	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	15	°C
52000	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
52001	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5334	
52002	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
52003	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
52004	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
52005	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
52006	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
52007	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
52008	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
52009	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
52010	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
52011	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
52012	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
52013	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
52014	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
52015	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
52016	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
52017	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
52018	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
52019	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
52020	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
52021	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
52022	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
52023	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
52024	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
52025	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52026	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52027	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52028	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
52029	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
52030	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
52031	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
52032	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
52033	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
52034	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
52035	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
52036	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
52037	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
52038	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
52039	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52040	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52041	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52042	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
52043	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
52044	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
52045	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
52046	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
52047	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
52048	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	181	
52049	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	181	
52050	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52051	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
52052	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52053	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52054	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
52055	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
52056	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
52057	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
52058	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
52059	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
52060	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
52061	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
52062	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
52063	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
52064	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
52065	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
52066	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
52067	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52068	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
52069	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52070	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
52071	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
52072	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52073	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
52074	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
52075	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
52076	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
52077	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
52078	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	170	
52079	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	170	
52080	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	0	
52081	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	0	
52082	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
52083	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
52084	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	1	
52085	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52086	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52087	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52088	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	58.0	
52089	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	52.0	
52090	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
52091	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
52092	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	52.0	
52093	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
52094	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52095	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52096	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52097	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52098	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
52099	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52100	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52101	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52102	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52103	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52104	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52105	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52106	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52107	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52108	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52109	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52110	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52111	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52112	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52113	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52114	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
52115	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52116	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
52117	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
52118	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52119	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52120	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52121	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52122	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
52123	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	61.0	
52124	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	50.0	
52125	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
52126	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52127	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
52128	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	216	
52129	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	12L	
52130	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	8L	
52131	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	9L	
52132	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
52133	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
52134	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
52135	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
52136	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
52137	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
52138	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
52139	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
52140	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
52141	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
52142	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
52143	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	179	
52144	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	179	
52145	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	0	
52146	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	0	
52147	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52148	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
52149	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	81178	
52150	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	81178	
52151	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	50.0	
52152	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52153	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52154	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52155	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
52156	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
52157	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
52158	12/2/2019 13:17	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
52159	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	1	
52160	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
52161	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
52162	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
52163	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
52164	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	850	
52165	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
52166	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
52167	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
52168	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
52169	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
52170	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
52171	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
52172	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
52173	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
52174	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	21	°C
52175	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	12	°C
52176	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
52177	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
52178	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
52179	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
52180	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
52181	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
52182	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
52183	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
52184	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
52185	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
52186	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
52187	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
52188	12/16/2019 14:35	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
52189	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
52190	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
52191	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	0	
52192	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	0	
52193	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
52194	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
52195	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	1	
52196	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52197	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52198	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52199	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	37.0	
52200	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	37.0	
52201	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	33.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
52202	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
52203	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52204	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
52205	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
52206	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
52207	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
52208	12/2/2019 15:41	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
52209	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52210	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52211	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52212	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52213	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
52214	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52215	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52216	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52217	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	4	
52218	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
52219	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
52220	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
52221	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	2 large gaps under fence on side closest to the scrap yard ...top rail getting rusty ...1 bayonet is broken.	
52222	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52223	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
52224	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
52225	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52226	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52227	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52228	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52229	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52230	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52231	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52232	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
52233	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52234	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52235	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
52236	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52237	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52238	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52239	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
52240	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
52241	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
52242	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
52243	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
52244	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
52245	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
52246	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
52247	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
52248	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
52249	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52250	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52251	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52252	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52253	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
52254	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
52255	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52256	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52257	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52258	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52259	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52260	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52261	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
52262	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
52263	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
52264	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
52265	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
52266	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
52267	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
52268	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
52269	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
52270	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
52271	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
52272	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
52273	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
52274	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
52275	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
52276	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
52277	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
52278	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
52279	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
52280	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
52281	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
52282	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
52283	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
52284	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
52285	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
52286	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
52287	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
52288	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
52289	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
52290	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
52291	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
52292	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
52293	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments		
52294	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
52295	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
52296	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
52297	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
52298	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
52299	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
52300	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
52301	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
52302	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
52303	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
52304	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
52305	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
52306	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
52307	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	60.0	
52308	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	120.0	
52309	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	60.0	
52310	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52311	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52312	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52313	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52314	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52315	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52316	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52317	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52318	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52319	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
52320	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52321	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52322	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52323	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
52324	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52325	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52326	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52327	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52328	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52329	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52330	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52331	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52332	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52333	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52334	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
52335	12/2/2019 14:09	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52336	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52337	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52338	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
52339	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52340	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52341	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52342	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52343	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52344	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52345	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52346	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52347	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52348	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52349	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
52350	12/2/2019 14:22	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52351	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	140.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
52352	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	125.0	
52353	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	160.0	
52354	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
52355	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
52356	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	2	
52357	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	2	
52358	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	267	
52359	12/2/2019 15:23	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	267	
52360	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
52361	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
52362	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
52363	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
52364	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
52365	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
52366	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
52367	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
52368	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
52369	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
52370	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	395	
52371	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	395	
52372	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
52373	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
52374	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
52375	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
52376	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
52377	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
52378	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
52379	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
52380	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
52381	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
52382	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	3	
52383	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
52384	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
52385	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
52386	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52387	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
52388	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
52389	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
52390	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
52391	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
52392	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
52393	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
52394	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
52395	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
52396	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
52397	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
52398	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
52399	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
52400	12/2/2019 12:37	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
52401	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52402	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52403	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
52404	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
52405	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
52406	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
52407	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
52408	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
52409	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
52410	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
52411	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
52412	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
52413	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
52414	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
52415	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
52416	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
52417	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
52418	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
52419	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
52420	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
52421	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
52422	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
52423	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
52424	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
52425	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
52426	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52427	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
52428	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52429	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52430	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52431	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
52432	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
52433	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
52434	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
52435	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
52436	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
52437	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
52438	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.5868	
52439	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	40	°C
52440	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	30	°C
52441	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
52442	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52443	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52444	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
52445	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
52446	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
52447	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
52448	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
52449	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
52450	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
52451	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
52452	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
52453	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
52454	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
52455	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
52456	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
52457	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
52458	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
52459	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
52460	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
52461	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
52462	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52463	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52464	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52465	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52466	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
52467	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52468	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
52469	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
52470	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
52471	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
52472	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
52473	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	10562.40	kw
52474	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
52475	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
52476	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	45	°C
52477	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	35	°C
52478	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
52479	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
52480	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
52481	12/2/2019 11:17	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
52482	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
52483	12/3/2019 7:38	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
52484	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
52485	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
52486	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
52487	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
52488	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
52489	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
52490	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	810	
52491	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
52492	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
52493	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
52494	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
52495	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
52496	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
52497	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
52498	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
52499	12/2/2019 12:14	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52500	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
52501	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52502	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
52503	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
52504	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
52505	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
52506	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
52507	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
52508	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2560.32	kw
52509	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
52510	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
52511	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
52512	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
52513	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
52514	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
52515	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
52516	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
52517	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
52518	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
52519	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
52520	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
52521	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	General Comments		
52522	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
52523	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
52524	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
52525	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
52526	12/2/2019 15:41	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
52527	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
52528	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
52529	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
52530	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
52531	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
52532	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
52533	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
52534	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
52535	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
52536	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
52537	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
52538	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
52539	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
52540	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
52541	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
52542	12/2/2019 14:43	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
52543	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
52544	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
52545	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
52546	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
52547	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
52548	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
52549	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
52550	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
52551	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
52552	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
52553	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
52554	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
52555	12/2/2019 13:33	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
52556	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
52557	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
52558	12/2/2019 15:05	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
52559	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
52560	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
52561	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
52562	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
52563	12/2/2019 11:06	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
52564	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
52565	12/2/2019 14:55	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
52566	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
52567	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
52568	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
52569	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
52570	12/2/2019 10:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
52571	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
52572	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
52573	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
52574	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
52575	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
52576	12/2/2019 13:01	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52577	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
52578	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
52579	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
52580	12/2/2019 11:37	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
52581	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	80.0	
52582	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	7	
52583	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	693	
52584	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	246	
52585	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	693	
52586	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
52587	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	80.0	
52588	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
52589	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
52590	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
52591	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Unknown Operations	0	
52592	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	246	
52593	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	19	
52594	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
52595	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
52596	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
52597	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
52598	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
52599	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	General Comments		
52600	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
52601	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
52602	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
52603	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	815	
52604	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	815	
52605	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
52606	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
52607	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
52608	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
52609	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
52610	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
52611	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Adequate	
52612	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
52613	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
52614	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
52615	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
52616	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
52617	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
52618	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	42.35	%
52619	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3973	
52620	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3973	
52621	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	10	
52622	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	10	
52623	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
52624	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
52625	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	280.0	
52626	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	280.0	
52627	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	280.0	
52628	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
52629	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
52630	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	General Comments		
52631	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
52632	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
52633	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
52634	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
52635	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
52636	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
52637	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Unknown Operations	0	
52638	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
52639	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
52640	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
52641	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
52642	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
52643	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
52644	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
52645	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
52646	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
52647	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
52648	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments	Tap Changer Guage leaking, tried to tighten, would not get any tighter, still leaking	WO # 2019-395332
52649	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
52650	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
52651	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52652	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
52653	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
52654	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
52655	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
52656	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
52657	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
52658	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
52659	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	80.0	
52660	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	24	
52661	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
52662	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	General Comments		
52663	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
52664	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	16	
52665	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
52666	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	26.31	%
52667	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
52668	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	400.0	
52669	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	400.0	
52670	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	420.0	
52671	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52672	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52673	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52674	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
52675	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
52676	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
52677	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
52678	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
52679	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments		
52680	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
52681	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	152	
52682	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	152	
52683	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	0	
52684	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
52685	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Unknown Operations	0	
52686	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
52687	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
52688	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	9	
52689	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	24.71	%
52690	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	25.51	%
52691	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
52692	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	350.0	
52693	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	320.0	
52694	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	320.0	
52695	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52696	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52697	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52698	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
52699	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	
52700	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
52701	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
52702	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52703	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52704	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52705	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	916.0	
52706	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	813.0	
52707	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	840.0	
52708	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
52709	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	92	
52710	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	92	
52711	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	9	
52712	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
52713	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Unknown Operations	9	
52714	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Unknown Operations	0	
52715	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	1	
52716	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	1	
52717	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
52718	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
52719	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	566	
52720	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	566	
52721	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	18	
52722	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
52723	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
52724	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
52725	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
52726	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	280.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52727	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
52728	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	4	
52729	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
52730	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations A Ø	0	
52731	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52732	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52733	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Unknown Operations	0	
52734	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	280.0	
52735	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	280.0	
52736	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52737	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
52738	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
52739	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
52740	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3442	
52741	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3442	
52742	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52743	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52744	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
52745	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
52746	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations	5	
52747	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty A Ph V	5	%
52748	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps A Ø	116.0	
52749	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty C Ph V	5	%
52750	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty B Ph V	6.67	%
52751	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty A Ph V	5	%
52752	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations	13	
52753	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Unknown Operations	0	
52754	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
52755	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
52756	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty B Ph V	5	%
52757	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty C Ph V	3.33	%
52758	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps A Ø	86.0	
52759	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps B Ø	85.0	
52760	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps C Ø	88.0	
52761	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52762	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52763	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52764	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations A Ø	0	
52765	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations B Ø	0	
52766	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	75	
52767	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	75	
52768	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
52769	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
52770	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
52771	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations C Ø	0	
52772	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations Ground	0	
52773	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Follow-up Action Required?	n	
52774	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	General Comments		
52775	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Maintenance Operations	0	
52776	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AF	168	
52777	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AL	168	
52778	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations This Read Vac	2	
52779	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Switching Operations	2	
52780	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Unknown Operations	0	
52781	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
52782	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
52783	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
52784	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
52785	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
52786	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
52787	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
52788	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
52789	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
52790	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
52791	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
52792	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
52793	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
52794	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
52795	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
52796	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
52797	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	140	
52798	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	140	
52799	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
52800	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
52801	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
52802	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
52803	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
52804	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
52805	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1446	
52806	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1446	
52807	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
52808	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
52809	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
52810	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
52811	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
52812	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
52813	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
52814	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
52815	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	3	
52816	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
52817	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
52818	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps C Ø	126.0	
52819	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps B Ø	107.0	
52820	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
52821	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	650.0	
52822	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	620.0	
52823	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	570.0	
52824	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52825	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	126	
52826	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
52827	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
52828	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AL	162	
52829	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
52830	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
52831	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
52832	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
52833	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1314	
52834	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
52835	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1314	
52836	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	4	
52837	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
52838	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments		
52839	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
52840	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
52841	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	20.0	
52842	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	20.0	
52843	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	20.0	
52844	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
52845	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
52846	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
52847	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Unknown Operations	0	
52848	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
52849	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
52850	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	861	
52851	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	861	
52852	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	13	
52853	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
52854	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
52855	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
52856	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations B Ø	0	
52857	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations C Ø	0	
52858	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations Ground	0	
52859	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Follow-up Action Required?	n	
52860	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
52861	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
52862	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
52863	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	General Comments		
52864	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
52865	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	28	°C
52866	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
52867	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
52868	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
52869	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
52870	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Unknown Operations	0	
52871	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
52872	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	645	
52873	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Maintenance Operations	0	
52874	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AF	162	
52875	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	645	
52876	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52877	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
52878	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
52879	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
52880	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
52881	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Unknown Operations	0	
52882	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Switching Operations	4	
52883	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations This Read Vac	4	
52884	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	200.0	
52885	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	220.0	
52886	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	200.0	
52887	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
52888	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments		
52889	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
52890	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
52891	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
52892	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
52893	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
52894	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	100.62	
52895	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
52896	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	100.62	
52897	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	100.62	
52898	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	400.0	
52899	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	400.0	
52900	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	420.0	
52901	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	16.74	%
52902	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	16.74	%
52903	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	42.35	%
52904	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	42.35	%
52905	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
52906	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
52907	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
52908	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
52909	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
52910	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
52911	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	241	
52912	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	241	
52913	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
52914	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
52915	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Unknown Operations	0	
52916	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
52917	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	19.13	%
52918	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	18	
52919	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	1.0	
52920	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	1.0	
52921	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	1.0	
52922	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	4	
52923	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
52924	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	General Comments	remove from inspection	
52925	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
52926	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	1	
52927	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	126	
52928	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
52929	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
52930	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
52931	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
52932	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
52933	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1	
52934	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1	
52935	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	7	
52936	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
52937	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
52938	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
52939	3/5/2019 11:35	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
52940	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
52941	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
52942	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
52943	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	.35	%
52944	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
52945	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Unknown Operations	0	
52946	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
52947	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
52948	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
52949	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
52950	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Switching Operations	0	
52951	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
52952	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	4	
52953	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
52954	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
52955	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	610	
52956	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
52957	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
52958	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
52959	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
52960	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	VRR Time Delay	30	Seconds
52961	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
52962	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
52963	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
52964	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	LTC Operation Checked?	y	
52965	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	General Comments		
52966	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	Follow-up Action Required?	n	
52967	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	LTCC000075	LTCCControl	108-5	LTC Control Insp	All Connections OK?	y	
52968	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
52969	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
52970	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
52971	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
52972	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
52973	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
52974	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
52975	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
52976	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
52977	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
52978	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
52979	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Regulator As Left Counter	28051	
52980	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
52981	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
52982	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Leaks	None	
52983	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
52984	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
52985	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
52986	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
52987	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	General Comments		
52988	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
52989	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
52990	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
52991	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
52992	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
52993	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
52994	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
52995	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
52996	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Current Tap Position	4L	
52997	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
52998	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
52999	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	822	
53000	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	431	
53001	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
53002	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
53003	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
53004	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
53005	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4896	
53006	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
53007	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
53008	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
53009	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
53010	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
53011	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
53012	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
53013	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
53014	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
53015	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
53016	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
53017	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
53018	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
53019	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
53020	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
53021	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
53022	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53023	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	330	
53024	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	5	
53025	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	5	
53026	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53027	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Follow-up Action Required?	n	
53028	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
53029	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations Ground	0	
53030	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
53031	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
53032	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
53033	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
53034	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
53035	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
53036	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
53037	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
53038	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
53039	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
53040	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
53041	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
53042	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
53043	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
53044	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
53045	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations C Ø	0	
53046	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations B Ø	0	
53047	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations A Ø	0	
53048	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53049	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53050	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53051	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53052	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53053	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53054	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
53055	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
53056	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
53057	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
53058	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53059	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
53060	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	General Comments		
53061	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
53062	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53063	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53064	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
53065	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps C Ø	0.0	
53066	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps B Ø	0.0	
53067	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps A Ø	0.0	
53068	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53069	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53070	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53071	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53072	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53073	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53074	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53075	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushing Condition	Good	
53076	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	275.0	
53077	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	279.0	
53078	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	265.0	
53079	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53080	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53081	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53082	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AL	288	
53083	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AF	288	
53084	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
53085	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Maintenance Operations	0	
53086	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53087	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
53088	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	General Comments	open	
53089	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	General Comments		
53090	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
53091	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	10	
53092	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	2.1	%
53093	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	2	
53094	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
53095	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	2.1	%
53096	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
53097	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	0.0	
53098	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	0.0	
53099	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	0.0	
53100	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53101	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53102	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53103	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
53104	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	0	
53105	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	0	
53106	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
53107	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
53108	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments	substation is out	
53109	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
53110	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	330	
53111	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
53112	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
53113	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
53114	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4405	
53115	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
53116	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
53117	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
53118	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
53119	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
53120	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
53121	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53122	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53123	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53124	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53125	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53126	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53127	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushing Condition	Good	
53128	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps C Ø	407.0	
53129	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps B Ø	400.0	
53130	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps A Ø	385.0	
53131	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53132	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53133	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53134	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations	0	
53135	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
53136	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
53137	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
53138	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
53139	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
53140	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	1	
53141	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	1	
53142	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	269	
53143	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	269	
53144	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
53145	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments	substation is out	
53146	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
53147	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
53148	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
53149	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	All Connections OK?	y	
53150	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	Follow-up Action Required?	n	
53151	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	General Comments		
53152	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	LTC Operation Checked?	y	
53153	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
53154	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
53155	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
53156	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCCControl	723-2	LTC Control Insp	VRR Time Delay	30	Seconds
53157	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
53158	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
53159	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53160	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53161	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53162	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	0.0	
53163	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	0.0	
53164	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	0.0	
53165	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	.35	%
53166	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53167	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations	0	
53168	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Unknown Operations	0	
53169	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Tank Paint Condition	Good	
53170	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53171	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53172	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53173	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A Ø	0	
53174	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B Ø	0	
53175	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C Ø	0	
53176	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53177	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Follow-up Action Required?	n	
53178	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Follow-up Action Required?	n	
53179	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Foundation Condition	Good	
53180	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	General Comments		
53181	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	General Comments		
53182	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Grounds in Place?	y	
53183	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53184	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Maintenance Operations	0	
53185	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Moisture and Leak Free?	y	
53186	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AF	309	
53187	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AL	309	
53188	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations This Read Vac	0	
53189	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Switching Operations	0	
53190	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations This Read Vac	0	
53191	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AL	241	
53192	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AF	241	
53193	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
53194	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Maintenance Operations	0	
53195	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Switching Operations	0	
53196	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Tank Paint Condition	Good	
53197	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Unknown Operations	0	
53198	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53199	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Grounds in Place?	y	
53200	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	General Comments		
53201	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	General Comments		
53202	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Foundation Condition	Good	
53203	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
53204	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
53205	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Follow-up Action Required?	n	
53206	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Follow-up Action Required?	n	
53207	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations Ground	0	
53208	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations C Ø	0	
53209	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations B Ø	0	
53210	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations A Ø	0	
53211	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53212	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53213	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53214	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53215	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53216	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53217	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53218	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53219	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53220	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Unknown Operations	0	
53221	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Tank Paint Condition	Good	
53222	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Switching Operations	0	
53223	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations This Read Vac	0	
53224	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AL	247	
53225	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AF	247	
53226	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
53227	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Maintenance Operations	0	
53228	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53229	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Grounds in Place?	y	
53230	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	General Comments		
53231	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	General Comments		
53232	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Foundation Condition	Good	
53233	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Follow-up Action Required?	n	
53234	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Follow-up Action Required?	n	
53235	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations Ground	0	
53236	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations C Ø	0	
53237	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations B Ø	0	
53238	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations A Ø	0	
53239	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53240	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53241	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53242	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53243	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53244	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53245	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53246	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53247	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53248	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushing Condition	Good	
53249	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps C Ø	540.0	
53250	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps B Ø	540.0	
53251	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps A Ø	534.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53252	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53253	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53254	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53255	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations	0	
53256	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53257	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations A Ø	0	
53258	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations B Ø	0	
53259	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations C Ø	0	
53260	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations Ground	0	
53261	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Follow-up Action Required?	n	
53262	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Follow-up Action Required?	n	
53263	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Foundation Condition	Good	
53264	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	General Comments		
53265	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	General Comments		
53266	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Grounds in Place?	y	
53267	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53268	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Maintenance Operations	0	
53269	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Moisture and Leak Free?	y	
53270	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AF	528	
53271	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AL	530	
53272	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations This Read Vac	2	
53273	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53274	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Switching Operations	2	
53275	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Tank Paint Condition	Good	
53276	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Unknown Operations	0	
53277	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
53278	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
53279	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR00089	Regulator	666-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
53280	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR00089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Leaks	None	
53281	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR00089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
53282	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
53283	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Tank Paint Condition	Good	
53284	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	0	
53285	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations This Read Vac	0	
53286	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	301	
53287	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	301	
53288	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Moisture and Leak Free?	y	
53289	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
53290	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53291	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Grounds in Place?	y	
53292	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
53293	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	General Comments		
53294	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Foundation Condition	Good	
53295	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
53296	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Follow-up Action Required?	n	
53297	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
53298	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
53299	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
53300	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
53301	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
53302	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
53303	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
53304	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
53305	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53306	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53307	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53308	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53309	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53310	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53311	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53312	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53313	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53314	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushing Condition	Good	
53315	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
53316	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
53317	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
53318	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
53319	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
53320	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	General Comments	low battery water	
53321	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
53322	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
53323	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
53324	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
53325	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	230.0	
53326	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	222.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53327	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	210.0	
53328	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53329	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53330	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53331	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	6	
53332	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations	9	
53333	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53334	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53335	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53336	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps A Ø	33.0	
53337	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps B Ø	34.0	
53338	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps C Ø	36.0	
53339	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushing Condition	Good	
53340	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53341	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53342	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53343	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53344	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
53345	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
53346	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
53347	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
53348	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
53349	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
53350	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
53351	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
53352	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
53353	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
53354	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
53355	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
53356	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
53357	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	45	*F
53358	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
53359	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
53360	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
53361	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
53362	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
53363	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
53364	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	General Comments		
53365	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
53366	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
53367	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
53368	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53369	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53370	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53371	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53372	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53373	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
53374	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53375	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
53376	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
53377	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53378	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
53379	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
53380	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53381	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	General Comments		
53382	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	General Comments		
53383	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
53384	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	HV Winding Temp Max	45	*C
53385	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	HV Winding Temp Present	20	*C
53386	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53387	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Unknown Operations	0	
53388	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Tank Paint Condition	Good	
53389	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Switching Operations	0	
53390	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53391	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations This Read Vac	0	
53392	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AL	269	
53393	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
53394	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
53395	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
53396	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	69258.00	kw
53397	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
53398	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
53399	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Max	40	*C
53400	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Present	20	*C
53401	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53402	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
53403	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53404	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53405	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
53406	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
53407	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Reading	1.6488	
53408	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
53409	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53410	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
53411	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
53412	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53413	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53414	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
53415	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53416	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Present	35	°C
53417	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Max	35	°C
53418	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
53419	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53420	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	LTC Totalizer Reading	11871.36	kw
53421	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
53422	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	General Comments		
53423	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	General Comments		
53424	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53425	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations	0	
53426	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53427	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53428	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53429	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps A Ø	231.0	
53430	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps B Ø	248.0	
53431	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps C Ø	262.0	
53432	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushing Condition	Good	
53433	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53434	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53435	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53436	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53437	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53438	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53439	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53440	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53441	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53442	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations A Ø	0	
53443	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations B Ø	0	
53444	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations C Ø	0	
53445	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations Ground	0	
53446	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Follow-up Action Required?	n	
53447	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Follow-up Action Required?	n	
53448	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Foundation Condition	Good	
53449	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	General Comments		
53450	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	General Comments		
53451	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Grounds in Place?	y	
53452	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53453	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Maintenance Operations	0	
53454	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
53455	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AF	232	
53456	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AL	232	
53457	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations This Read Vac	0	
53458	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Switching Operations	0	
53459	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Tank Paint Condition	Good	
53460	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Unknown Operations	0	
53461	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
53462	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Follow-up Action Required?	n	
53463	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53464	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
53465	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
53466	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53467	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
53468	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53469	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53470	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53471	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Trash?	y	
53472	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
53473	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
53474	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
53475	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
53476	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	4	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53477	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53478	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53479	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53480	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	120.0	
53481	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
53482	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
53483	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
53484	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
53485	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Operations Since Last Insp	1122	
53486	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Min Tap Position	9L	
53487	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
53488	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Current Tap Position	4L	
53489	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
53490	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53491	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53492	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53493	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53494	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53495	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
53496	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53497	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
53498	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
53499	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53500	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
53501	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
53502	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
53503	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
53504	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
53505	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
53506	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
53507	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
53508	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
53509	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
53510	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
53511	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
53512	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
53513	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
53514	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
53515	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	120.0	
53516	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	120.0	
53517	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushing Condition	Good	
53518	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53519	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53520	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
53521	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BAT000495	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
53522	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53523	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53524	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53525	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53526	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53527	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53528	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53529	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
53530	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
53531	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
53532	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
53533	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Follow-up Action Required?	n	
53534	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
53535	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations	4	
53536	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53537	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53538	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53539	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps A Ø	191.0	
53540	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps B Ø	150.0	
53541	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps C Ø	147.0	
53542	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
53543	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
53544	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
53545	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
53546	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
53547	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
53548	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
53549	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
53550	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
53551	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
53552	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	General Comments		
53553	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
53554	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
53555	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
53556	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
53557	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
53558	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
53559	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
53560	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
53561	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4069	
53562	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
53563	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
53564	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Leaks	None	
53565	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
53566	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushing Condition	Good	
53567	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53568	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53569	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53570	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53571	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53572	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53573	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53574	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53575	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53576	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations A Ø	0	
53577	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations B Ø	0	
53578	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations C Ø	0	
53579	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations Ground	0	
53580	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Follow-up Action Required?	n	
53581	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Follow-up Action Required?	n	
53582	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Foundation Condition	Good	
53583	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	General Comments		
53584	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	General Comments		
53585	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Grounds in Place?	y	
53586	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53587	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
53588	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Vegetation	None	
53589	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
53590	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
53591	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
53592	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	General Comments		
53593	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
53594	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
53595	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
53596	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
53597	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
53598	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
53599	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	0	
53600	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53601	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	0	
53602	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Tank Paint Condition	Good	
53603	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
53604	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
53605	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
53606	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
53607	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
53608	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
53609	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
53610	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
53611	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
53612	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
53613	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
53614	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	General Comments		
53615	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
53616	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
53617	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
53618	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
53619	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
53620	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
53621	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Maintenance Operations	0	
53622	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Moisture and Leak Free?	y	
53623	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AF	290	
53624	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AL	290	
53625	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations This Read Vac	0	
53626	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53627	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
53628	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
53629	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
53630	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
53631	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
53632	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
53633	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
53634	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
53635	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
53636	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
53637	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
53638	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
53639	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
53640	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	General Comments		
53641	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
53642	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
53643	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Foundation Condition	Good	
53644	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
53645	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
53646	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
53647	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
53648	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
53649	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
53650	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Switching Operations	0	
53651	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Tank Paint Condition	Good	
53652	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Unknown Operations	0	
53653	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
53654	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
53655	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
53656	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
53657	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
53658	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BCH000531	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
53659	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
53660	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
53661	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Regulator As Left Counter	30955	
53662	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
53663	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Foundation Condition	Good	
53664	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	General Comments		
53665	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
53666	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Grounds in Place?	y	
53667	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53668	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Left Counter	48329	
53669	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Found Counter	48322	
53670	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	General Comments	needs guardian desiccant installed. 1" pipe out of LTC	
53671	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	General Comments		
53672	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
53673	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
53674	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Moisture and Leak Free?	y	
53675	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	341	
53676	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Follow-up Action Required?	n	
53677	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
53678	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53679	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	General Comments		
53680	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	General Comments		
53681	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
53682	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53683	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
53684	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
53685	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7516.80	kw
53686	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
53687	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
53688	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
53689	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
53690	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53691	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
53692	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53693	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53694	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
53695	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
53696	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53697	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Top Oil Temperature Max	25	°C
53698	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
53699	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
53700	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7830	
53701	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Max	30	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
53702	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
53703	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
53704	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
53705	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
53706	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
53707	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
53708	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
53709	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
53710	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
53711	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
53712	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
53713	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	General Comments		
53714	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
53715	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
53716	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
53717	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
53718	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
53719	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
53720	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
53721	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
53722	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Regulator As Left Counter	30305	
53723	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
53724	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
53725	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Leaks	None	
53726	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
53727	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	341	
53728	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53729	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53730	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps A Ø	290.0	
53731	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps B Ø	350.0	
53732	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps C Ø	270.0	
53733	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushing Condition	Good	
53734	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53735	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53736	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53737	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53738	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53739	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53740	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53741	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps B Phase V	5.99	
53742	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53743	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
53744	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
53745	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53746	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
53747	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
53748	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53749	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	General Comments		
53750	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
53751	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
53752	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	19497.60	kw
53753	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53754	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
53755	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
53756	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53757	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
53758	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53759	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53760	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
53761	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
53762	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53763	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Max	70	°C
53764	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
53765	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
53766	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
53767	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations A Ø	0	
53768	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations B Ø	1	
53769	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations C Ø	0	
53770	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	1.3540	
53771	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	75	°C
53772	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	40	°C
53773	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
53774	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
53775	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations Ground	0	
53776	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53777	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Follow-up Action Required?	n	
53778	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Foundation Condition	Good	
53779	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	General Comments		
53780	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	General Comments		
53781	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Grounds in Place?	y	
53782	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53783	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Maintenance Operations	0	
53784	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Moisture and Leak Free?	y	
53785	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AF	434	
53786	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AL	435	
53787	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5964	
53788	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
53789	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53790	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
53791	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
53792	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Follow-up Action Required?	n	
53793	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Foundation Condition	Good	
53794	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	General Comments		
53795	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	General Comments		
53796	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Grounds in Place?	y	
53797	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53798	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Maintenance Operations	0	
53799	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Moisture and Leak Free?	y	
53800	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AF	31	
53801	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AL	31	
53802	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations This Read Vac	0	
53803	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53804	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Switching Operations	0	
53805	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Tank Paint Condition	Good	
53806	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Unknown Operations	0	
53807	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
53808	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
53809	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53810	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53811	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53812	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53813	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53814	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
53815	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53816	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
53817	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
53818	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53819	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Follow-up Action Required?	n	
53820	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
53821	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53822	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	General Comments		
53823	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	General Comments		
53824	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
53825	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	LTC Totalizer Reading	17628.48	kw
53826	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53827	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
53828	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
53829	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53830	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
53831	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53832	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53833	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
53834	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
53835	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53836	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Top Oil Temperature Max	70	°C
53837	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Top Oil Temperature Present	30	°C
53838	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
53839	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Reading	1.2242	
53840	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Max	70	°C
53841	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Present	30	°C
53842	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
53843	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
53844	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
53845	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
53846	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53847	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53848	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53849	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53850	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53851	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
53852	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
53853	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53854	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations	5	
53855	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53856	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
53857	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
53858	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
53859	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
53860	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
53861	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
53862	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
53863	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushing Condition	Good	
53864	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	120.0	
53865	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	100.0	
53866	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	100.0	
53867	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
53868	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
53869	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
53870	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	3	
53871	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
53872	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
53873	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Present	30	°C
53874	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Max	30	°C
53875	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Reading	.9430	
53876	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
53877	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
53878	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
53879	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
53880	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
53881	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53882	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
53883	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53884	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Present	25	°C
53885	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Max	25	°C
53886	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
53887	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
53888	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
53889	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	LTC Totalizer Reading	16974.00	kw
53890	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
53891	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	General Comments		
53892	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	General Comments		
53893	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53894	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
53895	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Follow-up Action Required?	n	
53896	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53897	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
53898	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
53899	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53900	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
53901	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
53902	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
53903	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
53904	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53905	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53906	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
53907	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	VRR Time Delay	30	Seconds
53908	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
53909	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
53910	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
53911	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	LTC Operation Checked?	y	
53912	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	General Comments		
53913	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	Follow-up Action Required?	n	
53914	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCCControl	723-1	LTC Control Insp	All Connections OK?	y	
53915	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
53916	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
53917	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
53918	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	General Comments		
53919	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
53920	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
53921	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
53922	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
53923	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
53924	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
53925	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
53926	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
53927	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	715.68	kw
53928	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
53929	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
53930	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
53931	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
53932	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
53933	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
53934	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
53935	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
53936	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
53937	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
53938	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
53939	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
53940	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
53941	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
53942	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations This Read Vac	1	
53943	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53944	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Switching Operations	0	
53945	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Tank Paint Condition	Good	
53946	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Unknown Operations	0	
53947	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
53948	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
53949	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
53950	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
53951	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Operations Since Last Insp	18666	
53952	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
53953	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Min Tap Position	5R	
53954	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Max Tap Position	16L	
53955	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Current Tap Position	13L	
53956	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
53957	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Left Counter	679716	
53958	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Found Counter	679711	
53959	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	General Comments	no oil cup, has guardian	
53960	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	General Comments		
53961	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
53962	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Follow-up Action Required?	n	
53963	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Unknown Operations	0	
53964	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Tank Paint Condition	Good	
53965	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Switching Operations	0	
53966	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
53967	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations This Read Vac	0	
53968	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AL	295	
53969	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AF	295	
53970	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Moisture and Leak Free?	y	
53971	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
53972	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
53973	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Grounds in Place?	y	
53974	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
53975	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	General Comments		
53976	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Foundation Condition	Good	
53977	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
53978	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Follow-up Action Required?	n	
53979	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
53980	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
53981	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
53982	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
53983	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
53984	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
53985	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
53986	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
53987	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
53988	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
53989	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
53990	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
53991	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
53992	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
53993	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
53994	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	General Comments		
53995	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
53996	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
53997	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
53998	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
53999	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
54000	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
54001	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
54002	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
54003	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Follow-up Action Required?	n	
54004	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
54005	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	General Comments		
54006	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	General Comments	no oil cup, has guardian	
54007	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Found Counter	57960	
54008	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
54009	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
54010	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Left Counter	57966	
54011	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
54012	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Current Tap Position	1L	
54013	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Max Tap Position	8R	
54014	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Min Tap Position	13L	
54015	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
54016	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Operations Since Last Insp	1684	
54017	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
54018	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
54019	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
54020	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
54021	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Follow-up Action Required?	n	
54022	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
54023	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
54024	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
54025	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
54026	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations	5	
54027	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54028	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54029	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54030	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps A Ø	221.0	
54031	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps B Ø	235.0	
54032	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps C Ø	201.0	
54033	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushing Condition	Good	
54034	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54035	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54036	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54037	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54038	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54039	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54040	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
54041	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
54042	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
54043	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations A Ø	0	
54044	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations B Ø	0	
54045	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations C Ø	0	
54046	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
54047	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	General Comments		
54048	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	General Comments		
54049	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
54050	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
54051	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	42000	
54052	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AF	269	
54053	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Moisture and Leak Free?	y	
54054	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Maintenance Operations	0	
54055	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54056	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Grounds in Place?	y	
54057	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	General Comments		
54058	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	General Comments		
54059	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Foundation Condition	Good	
54060	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Follow-up Action Required?	n	
54061	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Follow-up Action Required?	n	
54062	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations Ground	0	
54063	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations C Ø	0	
54064	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations B Ø	0	
54065	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations A Ø	0	
54066	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54067	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54068	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54069	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54070	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54071	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54072	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54073	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54074	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54075	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushing Condition	Good	
54076	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps C Ø	145.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54077	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps B Ø	108.0	
54078	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps A Ø	116.0	
54079	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54080	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54081	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54082	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations	2	
54083	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6490	
54084	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
54085	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
54086	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
54087	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
54088	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
54089	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
54090	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
54091	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
54092	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
54093	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
54094	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
54095	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
54096	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
54097	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	General Comments		
54098	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
54099	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
54100	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
54101	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
54102	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
54103	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
54104	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
54105	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Foundation Condition	Good	
54106	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
54107	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
54108	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	General Comments		
54109	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
54110	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
54111	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
54112	11/25/2019 11:56	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
54113	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC0000574	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
54114	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC0000574	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
54115	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC0000574	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
54116	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC0000574	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
54117	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC0000574	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
54118	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Unknown Operations	0	
54119	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Tank Paint Condition	Good	
54120	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Switching Operations	4	
54121	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations This Read Vac	5	
54122	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AL	268	
54123	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AF	263	
54124	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Moisture and Leak Free?	y	
54125	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Maintenance Operations	0	
54126	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54127	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
54128	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Grounds in Place?	y	
54129	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	General Comments		
54130	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	General Comments		
54131	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Foundation Condition	Good	
54132	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Follow-up Action Required?	n	
54133	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Follow-up Action Required?	n	
54134	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations Ground	0	
54135	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations C Ø	0	
54136	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations B Ø	0	
54137	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations A Ø	1	
54138	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54139	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54140	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
54141	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54142	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54143	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54144	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54145	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54146	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54147	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushing Condition	Good	
54148	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps C Ø	120.0	
54149	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps B Ø	136.0	
54150	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps A Ø	132.0	
54151	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54152	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54153	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54154	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations	7	
54155	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations	4	
54156	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54157	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54158	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54159	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps A Ø	99.0	
54160	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps B Ø	86.0	
54161	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps C Ø	92.0	
54162	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushing Condition	Good	
54163	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54164	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54165	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54166	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54167	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54168	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54169	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54170	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54171	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54172	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations A Ø	0	
54173	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations B Ø	0	
54174	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations C Ø	0	
54175	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations Ground	0	
54176	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Follow-up Action Required?	n	
54177	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Found Counter	24610	
54178	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations Ground	0	
54179	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Follow-up Action Required?	n	
54180	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Follow-up Action Required?	n	
54181	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Foundation Condition	Good	
54182	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Left Counter	24619	
54183	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
54184	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	General Comments		
54185	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	General Comments		
54186	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Grounds in Place?	y	
54187	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54188	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Maintenance Operations	0	
54189	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Moisture and Leak Free?	y	
54190	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AF	230	
54191	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AL	231	
54192	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations This Read Vac	1	
54193	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54194	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Switching Operations	0	
54195	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Current Tap Position	2L	
54196	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Max Tap Position	2R	
54197	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Min Tap Position	10L	
54198	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
54199	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Operations Since Last Insp	1138	
54200	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
54201	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
54202	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
54203	11/25/2019 13:57	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
54204	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Tank Paint Condition	Good	
54205	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Unknown Operations	1	
54206	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
54207	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
54208	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
54209	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
54210	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
54211	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
54212	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
54213	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
54214	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
54215	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
54216	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
54217	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments		
54218	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
54219	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
54220	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
54221	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
54222	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
54223	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
54224	11/25/2019 15:51	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
54225	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
54226	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Vegetation	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54227	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
54228	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
54229	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	General Comments	major pot hole in drive outside of gate	
54230	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
54231	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
54232	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
54233	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
54234	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
54235	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
54236	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Trash?	y	
54237	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
54238	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
54239	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
54240	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
54241	11/25/2019 10:37	Distribution	Oxford Quarterly Inspection	LTC000574	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
54242	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
54243	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
54244	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
54245	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
54246	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
54247	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	82.50	
54248	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
54249	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	General Comments		
54250	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
54251	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
54252	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54253	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
54254	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
54255	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
54256	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
54257	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
54258	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
54259	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
54260	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
54261	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
54262	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54263	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
54264	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54265	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	General Comments		
54266	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
54267	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
54268	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
54269	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
54270	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
54271	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
54272	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
54273	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
54274	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Regulator As Left Counter	293946	
54275	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
54276	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
54277	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Leaks	None	
54278	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
54279	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	General Comments		
54280	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Follow-up Action Required?	n	
54281	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
54282	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
54283	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
54284	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
54285	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
54286	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
54287	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
54288	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
54289	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
54290	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
54291	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
54292	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
54293	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
54294	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
54295	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
54296	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
54297	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	General Comments		
54298	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
54299	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
54300	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
54301	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54302	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Unknown Operations	0	
54303	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Switching Operations	0	
54304	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations This Read AM	0	
54305	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AL	491	
54306	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AF	491	
54307	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Maintenance Operations	0	
54308	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	General Comments		
54309	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	General Comments		
54310	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Follow-up Action Required?	n	
54311	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
54312	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations Ground	0	
54313	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations C Ø	0	
54314	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations B Ø	0	
54315	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations A Ø	0	
54316	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
54317	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
54318	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
54319	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
54320	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps C Ø	0.0	
54321	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps B Ø	0.0	
54322	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps A Ø	0.0	
54323	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
54324	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
54325	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
54326	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Months Operations	0	
54327	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
54328	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
54329	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
54330	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
54331	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	General Comments		
54332	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
54333	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
54334	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
54335	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
54336	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
54337	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
54338	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
54339	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AF	351	
54340	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Num Operations Last 9 Months	3	
54341	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Maintenance Operations	0	
54342	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	General Comments	ok	
54343	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
54344	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
54345	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
54346	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
54347	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
54348	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
54349	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
54350	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
54351	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
54352	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
54353	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps B Ø	68.0	
54354	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps A Ø	68.0	
54355	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54356	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54357	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54358	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations	13	
54359	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations This Read Vac	14	
54360	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AL	349	
54361	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AF	349	
54362	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Moisture and Leak Free?	y	
54363	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Maintenance Operations	14	
54364	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54365	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Grounds in Place?	y	
54366	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	General Comments		
54367	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	General Comments		
54368	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Foundation Condition	Good	
54369	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Follow-up Action Required?	n	
54370	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Follow-up Action Required?	n	
54371	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations Ground	0	
54372	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
54373	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
54374	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations C Ø	0	
54375	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations B Ø	0	
54376	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54377	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54378	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54379	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC0000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
54380	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
54381	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
54382	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
54383	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
54384	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
54385	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
54386	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
54387	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
54388	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
54389	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
54390	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC0000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
54391	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC0000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
54392	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54393	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
54394	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54395	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
54396	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
54397	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
54398	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
54399	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
54400	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
54401	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
54402	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
54403	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
54404	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
54405	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
54406	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
54407	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	General Comments		
54408	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
54409	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
54410	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
54411	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
54412	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
54413	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
54414	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
54415	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
54416	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		
54417	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
54418	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
54419	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
54420	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
54421	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	45	°C
54422	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	75	°C
54423	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
54424	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
54425	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
54426	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
54427	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
54428	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
54429	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
54430	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
54431	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	8277	
54432	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	8277	
54433	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
54434	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
54435	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Unknown Operations	0	
54436	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Switching Operations	0	
54437	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations This Read Vac	0	
54438	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AL	101	
54439	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AF	101	
54440	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Maintenance Operations	0	
54441	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	General Comments		
54442	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	General Comments		
54443	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Follow-up Action Required?	n	
54444	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
54445	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations Ground	0	
54446	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations C Ø	0	
54447	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations B Ø	0	
54448	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations A Ø	0	
54449	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54450	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54451	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
54452	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54453	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps C Ø	68.0	
54454	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Left Counter	18238	
54455	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Found Counter	18238	
54456	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
54457	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
54458	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
54459	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	General Comments		
54460	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
54461	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
54462	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
54463	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
54464	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
54465	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
54466	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
54467	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
54468	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
54469	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
54470	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
54471	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
54472	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
54473	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54474	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54475	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
54476	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
54477	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
54478	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
54479	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
54480	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	1	
54481	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
54482	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	1	
54483	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1042	
54484	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1042	
54485	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
54486	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
54487	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
54488	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
54489	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
54490	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
54491	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
54492	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
54493	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
54494	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
54495	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
54496	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
54497	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
54498	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	140.0	
54499	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
54500	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	188.0	
54501	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
54502	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	177.0	
54503	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
54504	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54505	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
54506	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
54507	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
54508	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54509	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
54510	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Months Operations	0	
54511	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
54512	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
54513	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
54514	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps A Ø	100.0	
54515	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps B Ø	95.0	
54516	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps C Ø	100.0	
54517	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
54518	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
54519	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
54520	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
54521	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations A Ø	0	
54522	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations B Ø	0	
54523	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations C Ø	0	
54524	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations Ground	0	
54525	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Follow-up Action Required?	n	
54526	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54527	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	General Comments		
54528	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	General Comments		
54529	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Maintenance Operations	0	
54530	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AF	930	
54531	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AL	930	
54532	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations This Read AM	0	
54533	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Switching Operations	0	
54534	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Unknown Operations	0	
54535	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
54536	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
54537	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
54538	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
54539	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
54540	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
54541	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
54542	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
54543	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
54544	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
54545	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
54546	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
54547	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	559	
54548	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
54549	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
54550	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
54551	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
54552	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
54553	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
54554	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54555	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54556	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54557	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54558	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54559	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54560	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54561	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54562	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations A Ø	0	
54563	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations B Ø	0	
54564	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
54565	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
54566	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
54567	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
54568	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
54569	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		
54570	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
54571	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
54572	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54573	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
54574	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
54575	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99895	
54576	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99895	
54577	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations This Read Vac	0	
54578	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54579	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	0	
54580	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
54581	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
54582	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Unknown Operations	0	
54583	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Tank Paint Condition	Good	
54584	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC0000023	LTCControl	MD-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
54585	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC0000023	LTCControl	MD-TRANS 1	LTC Control Insp	General Comments		
54586	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC0000023	LTCControl	MD-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
54587	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Switching Operations	0	
54588	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54589	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
54590	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
54591	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
54592	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	603	
54593	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
54594	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
54595	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
54596	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
54597	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
54598	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Vegetation	None	
54599	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
54600	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Unknown Operations	0	Need size info and qty
54601	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
54602	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations This Read SF6	0	
54603	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AL	351	
54604	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
54605	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	1	
54606	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54607	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54608	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54609	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps A Ø	430.0	
54610	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps B Ø	430.0	
54611	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps C Ø	430.0	
54612	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushing Condition	Good	
54613	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54614	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54615	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54616	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54617	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54618	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54619	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54620	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54621	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54622	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations A Ø	0	
54623	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations B Ø	0	
54624	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations C Ø	0	
54625	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations Ground	0	
54626	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Follow-up Action Required?	n	
54627	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Follow-up Action Required?	n	
54628	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
54629	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
54630	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
54631	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
54632	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54633	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
54634	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
54635	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	268	
54636	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	268	
54637	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations This Read Vac	0	
54638	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54639	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	0	
54640	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	
54641	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
54642	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
54643	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
54644	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	12	
54645	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations	2	
54646	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54647	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54648	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54649	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps A Ø	430.0	
54650	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps B Ø	430.0	
54651	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps C Ø	480.0	
54652	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushing Condition	Good	
54653	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54654	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
54655	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AL	325	
54656	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AF	325	
54657	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Moisture and Leak Free?	y	
54658	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Maintenance Operations	16	
54659	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54660	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Grounds in Place?	y	
54661	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	General Comments		
54662	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	General Comments		
54663	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Foundation Condition	Good	
54664	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Follow-up Action Required?	n	
54665	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Follow-up Action Required?	n	
54666	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations Ground	0	
54667	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations C Ø	0	
54668	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations B Ø	0	
54669	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations A Ø	0	
54670	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54671	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54672	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54673	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54674	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54675	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54676	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54677	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
54678	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
54679	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
54680	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
54681	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
54682	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
54683	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
54684	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
54685	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
54686	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
54687	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
54688	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
54689	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	General Comments	Blown lightning arrester on circuit #302	
54690	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
54691	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
54692	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Foundation Condition	Good	
54693	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
54694	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54695	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54696	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushing Condition	Good	
54697	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps C Ø	0.0	
54698	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps B Ø	0.0	
54699	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps A Ø	0.0	
54700	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54701	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54702	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54703	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	9 Month Operations	23	
54704	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
54705	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
54706	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
54707	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
54708	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
54709	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Reading	.8468	
54710	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
54711	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
54712	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
54713	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
54714	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
54715	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
54716	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
54717	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
54718	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
54719	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
54720	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Present	35	°C
54721	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Max	65	°C
54722	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
54723	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
54724	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	LTC Totalizer Reading	12905.23	kw
54725	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
54726	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	General Comments		
54727	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	General Comments		
54728	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
54729	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
54730	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Follow-up Action Required?	n	
54731	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
54732	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
54733	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
54734	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
54735	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
54736	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
54737	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54738	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Moisture and Leak Free?	y	
54739	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AF	181	
54740	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AL	181	
54741	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations This Read Vac	5	
54742	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Switching Operations	1	
54743	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Tank Paint Condition	Good	
54744	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Unknown Operations	0	
54745	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Unknown Operations	0	
54746	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Tank Paint Condition	Good	
54747	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Switching Operations	0	
54748	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54749	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations This Read Vac	16	
54750	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
54751	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
54752	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
54753	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54754	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
54755	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
54756	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
54757	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
54758	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
54759	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
54760	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
54761	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Missing Winter blanks	
54762	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
54763	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
54764	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
54765	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
54766	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
54767	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
54768	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
54769	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
54770	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
54771	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
54772	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54773	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
54774	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54775	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
54776	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54777	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
54778	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54779	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Unknown Operations	0	
54780	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Tank Paint Condition	Good	
54781	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Switching Operations	0	
54782	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
54783	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations This Read Vac	15	
54784	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AL	325	
54785	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AF	325	
54786	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Moisture and Leak Free?	y	
54787	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Maintenance Operations	15	
54788	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Heaters (All) Functioning?	y	
54789	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	?	
54790	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54791	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
54792	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54793	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
54794	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54795	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	General Comments	OK	
54796	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps A Ø	500.0	
54797	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps B Ø	500.0	
54798	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps C Ø	500.0	
54799	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
54800	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Fault Operations	0	
54801	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54802	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Follow-up Action Required?	n	
54803	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
54804	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
54805	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54806	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
54807	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
54808	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
54809	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
54810	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
54811	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
54812	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
54813	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
54814	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
54815	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
54816	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
54817	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
54818	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
54819	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
54820	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
54821	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
54822	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
54823	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Vegetation	None	
54824	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
54825	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	General Comments		
54826	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54827	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
54828	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
54829	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
54830	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
54831	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Trash?	y	
54832	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
54833	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
54834	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
54835	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	General Comments		
54836	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
54837	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
54838	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
54839	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
54840	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
54841	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
54842	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
54843	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
54844	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
54845	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
54846	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
54847	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
54848	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
54849	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
54850	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
54851	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
54852	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
54853	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
54854	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
54855	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	0	
54856	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
54857	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	General Comments		
54858	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
54859	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
54860	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
54861	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
54862	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Unknown Operations	0	
54863	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Switching Operations	1	
54864	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations This Read AM	1	
54865	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AL	626	
54866	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AF	626	
54867	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Maintenance Operations	0	
54868	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	General Comments		
54869	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	General Comments		
54870	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
54871	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
54872	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
54873	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
54874	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
54875	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
54876	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
54877	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
54878	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
54879	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
54880	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
54881	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
54882	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
54883	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
54884	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps C Ø	50.0	
54885	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps B Ø	50.0	
54886	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps A Ø	50.0	
54887	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
54888	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
54889	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
54890	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
54891	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
54892	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Months Operations	2	
54893	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
54894	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
54895	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
54896	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
54897	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
54898	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
54899	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Follow-up Action Required?	n	
54900	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Fault Operations	0	
54901	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
54902	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps C Ø	185.0	
54903	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps B Ø	185.0	
54904	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54905	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54906	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54907	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54908	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54909	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54910	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54911	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushing Condition	Good	
54912	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps C Ø	0.0	
54913	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps B Ø	0.0	
54914	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps A Ø	0.0	
54915	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
54916	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
54917	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
54918	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	9 Month Operations	26	
54919	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
54920	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
54921	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
54922	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
54923	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
54924	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
54925	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
54926	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
54927	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
54928	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
54929	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
54930	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
54931	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
54932	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	794	
54933	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
54934	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
54935	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
54936	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
54937	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
54938	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
54939	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
54940	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
54941	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
54942	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
54943	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
54944	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
54945	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
54946	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
54947	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
54948	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
54949	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
54950	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
54951	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
54952	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
54953	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
54954	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
54955	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
54956	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54957	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54958	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
54959	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
54960	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
54961	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
54962	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
54963	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
54964	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
54965	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
54966	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
54967	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations A Ø	0	
54968	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations B Ø	0	
54969	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations C Ø	0	
54970	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations Ground	0	
54971	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Follow-up Action Required?	n	
54972	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Follow-up Action Required?	n	
54973	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Foundation Condition	Good	
54974	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	General Comments		
54975	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	General Comments		
54976	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
54977	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Maintenance Operations	4	
54978	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
54979	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
54980	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
54981	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
54982	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	All Connections OK?	y	
54983	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
54984	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	General Comments		
54985	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
54986	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
54987	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
54988	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
54989	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
54990	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCCControl	220-2	LTC Control Insp	VRR Time Delay	45	Seconds
54991	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	All Connections OK?	y	
54992	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
54993	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	General Comments		
54994	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
54995	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
54996	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
54997	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
54998	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
54999	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCCControl	220-1	LTC Control Insp	VRR Time Delay	45	Seconds
55000	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
55001	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
55002	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55003	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55004	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps A Ø	185.0	
55005	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	4	
55006	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
55007	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	4	
55008	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11586	
55009	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11586	
55010	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
55011	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
55012	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
55013	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
55014	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
55015	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
55016	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
55017	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
55018	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
55019	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	38.18	
55020	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	38.18	
55021	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	38.18	
55022	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55023	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	187.0	
55024	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	59.0	
55025	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	199.0	
55026	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	62.0	
55027	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	187.0	
55028	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
55029	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
55030	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55031	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
55032	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments	need nitrogen	
55033	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55034	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55035	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
55036	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	53.0	
55037	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55038	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55039	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55040	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	4	
55041	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
55042	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
55043	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
55044	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
55045	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
55046	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
55047	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations	15	
55048	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55049	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55050	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55051	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps A Ø	51.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
55052	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps B Ø	55.0	
55053	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps C Ø	75.0	
55054	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushing Condition	Good	
55055	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
55056	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
55057	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
55058	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
55059	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
55060	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
55061	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Follow-up Action Required?	n	
55062	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
55063	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
55064	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
55065	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
55066	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
55067	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
55068	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
55069	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations Ground	0	
55070	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
55071	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
55072	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
55073	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
55074	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
55075	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
55076	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
55077	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
55078	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
55079	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
55080	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
55081	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
55082	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
55083	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments	barbed wire is rusty and fence post	
55084	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
55085	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
55086	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
55087	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
55088	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	
55089	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
55090	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
55091	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
55092	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	n	
55093	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
55094	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
55095	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
55096	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	n	
55097	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
55098	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
55099	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	remove from inspection	
55100	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	n	
55101	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	n	
55102	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
55103	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
55104	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
55105	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Foundation Condition	Good	
55106	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
55107	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
55108	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	General Comments		
55109	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
55110	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
55111	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
55112	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
55113	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
55114	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
55115	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
55116	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
55117	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
55118	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
55119	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
55120	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
55121	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
55122	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
55123	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
55124	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
55125	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
55126	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55127	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
55128	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
55129	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Missing winter blanks, (7)19wx26h needs to be cut for sec 2	
55130	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
55131	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
55132	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
55133	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
55134	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
55135	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
55136	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
55137	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
55138	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
55139	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
55140	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
55141	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
55142	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
55143	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Unknown Operations	0	
55144	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Switching Operations	0	
55145	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations This Read AM	0	
55146	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AL	644	
55147	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AF	644	
55148	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Maintenance Operations	0	
55149	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	General Comments		
55150	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	General Comments		
55151	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
55152	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
55153	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
55154	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
55155	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Maintenance Operations	0	
55156	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AF	164	
55157	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AL	164	
55158	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations This Read Vac	0	
55159	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Switching Operations	0	
55160	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Unknown Operations	0	
55161	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
55162	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
55163	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
55164	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
55165	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
55166	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
55167	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	General Comments		
55168	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
55169	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
55170	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Swept?	y	
55171	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
55172	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
55173	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
55174	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
55175	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
55176	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
55177	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
55178	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Broom on Site?	y	
55179	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
55180	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
55181	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
55182	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
55183	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
55184	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
55185	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
55186	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
55187	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
55188	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
55189	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
55190	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
55191	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
55192	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
55193	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
55194	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
55195	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
55196	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
55197	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
55198	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
55199	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
55200	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations C Ø	0	
55201	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55202	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations A Ø	0	
55203	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
55204	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
55205	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
55206	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
55207	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
55208	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
55209	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
55210	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
55211	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
55212	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
55213	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
55214	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	9 Month Operations	1	
55215	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55216	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55217	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
55218	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
55219	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
55220	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	1103	
55221	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
55222	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	13L	
55223	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	2L	
55224	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	7L	
55225	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
55226	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	943958	
55227	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	943958	
55228	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
55229	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
55230	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
55231	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
55232	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55233	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps A Ø	490.0	
55234	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps B Ø	459.0	
55235	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps C Ø	423.0	
55236	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55237	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55238	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
55239	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
55240	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
55241	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
55242	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
55243	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
55244	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
55245	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
55246	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
55247	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
55248	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
55249	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
55250	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations Ground	0	
55251	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
55252	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
55253	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	General Comments		
55254	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	General Comments		
55255	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
55256	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
55257	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
55258	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
55259	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
55260	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
55261	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
55262	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
55263	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	10	°C
55264	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
55265	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55266	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	8616.70	kw
55267	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55268	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
55269	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
55270	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
55271	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55272	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55273	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
55274	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
55275	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
55276	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55277	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
55278	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Top Oil Temperature Max	40	°C
55279	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
55280	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
55281	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	.5654	
55282	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	70	°C
55283	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	30	°C
55284	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
55285	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
55286	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
55287	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
55288	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
55289	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	7	
55290	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1	
55291	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1	
55292	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
55293	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	94370	
55294	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	94370	
55295	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
55296	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	5L	
55297	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
55298	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	12L	
55299	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
55300	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	1027	
55301	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
55302	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
55303	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
55304	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	n	
55305	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55306	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	75	°C
55307	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
55308	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55309	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
55310	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
55311	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
55312	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
55313	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	130498	
55314	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	130498	
55315	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
55316	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	6L	
55317	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
55318	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
55319	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
55320	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	859	
55321	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
55322	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
55323	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
55324	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
55325	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55326	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55327	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
55328	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
55329	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
55330	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
55331	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
55332	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
55333	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
55334	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
55335	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
55336	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
55337	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
55338	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
55339	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
55340	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
55341	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
55342	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
55343	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
55344	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
55345	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
55346	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55347	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
55348	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
55349	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
55350	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
55351	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55352	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
55353	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
55354	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
55355	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55356	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
55357	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55358	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
55359	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55360	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
55361	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
55362	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	Control Valve	
55363	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Bad	
55364	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	60	°C
55365	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.8292	
55366	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
55367	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
55368	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
55369	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
55370	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
55371	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
55372	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55373	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55374	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
55375	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
55376	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	30	°C
55377	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	50	°C
55378	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
55379	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55380	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	12637.01	kw
55381	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55382	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
55383	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		
55384	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55385	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
55386	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
55387	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
55388	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
55389	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
55390	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
55391	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
55392	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
55393	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
55394	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
55395	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
55396	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
55397	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
55398	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
55399	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
55400	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
55401	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
55402	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
55403	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
55404	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
55405	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	1	
55406	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	n	
55407	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	General Comments	remove from inspection	
55408	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
55409	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
55410	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
55411	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
55412	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
55413	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
55414	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
55415	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
55416	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
55417	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	40	°C
55418	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
55419	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
55420	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
55421	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	General Comments		
55422	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
55423	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
55424	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
55425	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
55426	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55427	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
55428	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
55429	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
55430	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Regulator As Left Counter	181996	
55431	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
55432	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Leaks	None	
55433	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
55434	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	remove from inspection	
55435	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
55436	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
55437	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
55438	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
55439	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	4	
55440	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	n	
55441	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
55442	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
55443	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
55444	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	n	
55445	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
55446	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
55447	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	1.0	
55448	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	1.0	
55449	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	1.0	
55450	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
55451	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	n	
55452	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
55453	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
55454	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
55455	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
55456	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptable?	n	
55457	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
55458	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
55459	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
55460	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55461	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55462	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55463	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
55464	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	290.0	
55465	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	285.0	
55466	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55467	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
55468	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
55469	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
55470	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
55471	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
55472	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
55473	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
55474	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
55475	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
55476	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
55477	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
55478	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
55479	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
55480	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
55481	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
55482	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
55483	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
55484	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
55485	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
55486	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
55487	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
55488	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
55489	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
55490	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
55491	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55492	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55493	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
55494	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
55495	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
55496	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
55497	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
55498	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
55499	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
55500	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
55501	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A & B phase High set Inst.	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55502	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
55503	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	649	
55504	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	649	
55505	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
55506	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	1	
55507	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	912	
55508	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	912	
55509	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
55510	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
55511	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
55512	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
55513	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
55514	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
55515	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
55516	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
55517	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
55518	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
55519	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
55520	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
55521	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55522	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	105.0	
55523	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	105.0	
55524	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	110.0	
55525	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	110.0	
55526	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	100.0	
55527	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	100.0	
55528	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55529	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55530	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55531	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	2	
55532	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC0000434	LTCControl	FA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
55533	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC0000435	LTCControl	FA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
55534	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC0000435	LTCControl	FA-TRANS 2	LTC Control Insp	General Comments		
55535	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC0000435	LTCControl	FA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
55536	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
55537	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
55538	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	n	
55539	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
55540	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
55541	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	n	
55542	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
55543	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
55544	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments	basement is a hazard all together. 2 4' 2 pin light fixtures out(4 bulbs total).	
55545	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
55546	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	y	
55547	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	n	
55548	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
55549	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
55550	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
55551	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
55552	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
55553	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
55554	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	n	
55555	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
55556	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Unknown Operations	0	
55557	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
55558	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
55559	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
55560	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
55561	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
55562	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
55563	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
55564	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
55565	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
55566	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
55567	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
55568	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
55569	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
55570	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55571	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	General Comments		
55572	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	General Comments		
55573	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
55574	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
55575	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	925.92	kw
55576	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55577	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
55578	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
55579	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
55580	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55581	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
55582	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
55583	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
55584	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
55585	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
55586	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
55587	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.7716	
55588	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Present	29	°C
55589	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Max	40	°C
55590	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
55591	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
55592	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55593	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55594	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	General Comments		
55595	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
55596	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55597	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
55598	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
55599	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
55600	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
55601	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
55602	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
55603	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
55604	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
55605	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
55606	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
55607	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
55608	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Unknown Operations	0	
55609	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Switching Operations	0	
55610	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations This Read Vac	2	
55611	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AL	158	
55612	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AF	158	
55613	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Maintenance Operations	0	
55614	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	General Comments	B & C phase I.O.C	
55615	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	General Comments		
55616	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Follow-up Action Required?	n	
55617	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
55618	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations Ground	0	
55619	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations C Ø	1	
55620	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations B Ø	1	
55621	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations A Ø	0	
55622	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
55623	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
55624	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55625	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55626	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps C Ø	7.0	
55627	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps B Ø	76.0	
55628	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps A Ø	76.0	
55629	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55630	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55631	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55632	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations	23	
55633	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Months Operations	2	
55634	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55635	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55636	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55637	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps A Ø	0.0	
55638	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps B Ø	0.0	
55639	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps C Ø	0.0	
55640	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55641	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
55642	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
55643	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
55644	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations A Ø	0	
55645	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations B Ø	0	
55646	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations C Ø	0	
55647	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations Ground	0	
55648	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
55649	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Follow-up Action Required?	n	
55650	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	General Comments		
55651	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55652	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Maintenance Operations	0	
55653	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AF	504	
55654	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AL	504	
55655	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations This Read AM	0	
55656	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Switching Operations	0	
55657	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
55658	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
55659	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
55660	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
55661	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4986	
55662	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	All Connections OK?	y	
55663	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	Follow-up Action Required?	n	
55664	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	General Comments		
55665	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	LTC Operation Checked?	y	
55666	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
55667	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
55668	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
55669	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
55670	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCCControl	221-2	LTC Control Insp	VRR Time Delay	30	Seconds
55671	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	All Connections OK?	y	
55672	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	Follow-up Action Required?	n	
55673	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	General Comments		
55674	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	LTC Operation Checked?	y	
55675	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
55676	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
55677	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
55678	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
55679	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCCControl	221-3	LTC Control Insp	VRR Time Delay	30	Seconds
55680	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
55681	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
55682	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
55683	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
55684	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C Ø	0	
55685	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B Ø	0	
55686	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A Ø	0	
55687	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
55688	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
55689	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55690	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55691	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
55692	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
55693	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
55694	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
55695	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
55696	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
55697	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	200.0	
55698	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	200.0	
55699	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	200.0	
55700	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55701	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55702	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55703	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	2	
55704	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4986	
55705	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	2	
55706	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
55707	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
55708	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55709	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps C Ø	0.0	
55710	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps B Ø	0.0	
55711	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps A Ø	0.0	
55712	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55713	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
55714	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
55715	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	0	
55716	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
55717	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations This Read Vac	0	
55718	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	53	
55719	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	53	
55720	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
55721	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
55722	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
55723	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
55724	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
55725	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
55726	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCCControl	221-1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55727	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Follow-up Action Required?	n	
55728	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	General Comments		
55729	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Operation Checked?	y	
55730	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
55731	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
55732	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
55733	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
55734	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Time Delay	30	Seconds
55735	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55736	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55737	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Months Operations	1	
55738	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	4	
55739	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55740	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55741	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55742	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	106.0	
55743	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	133.0	
55744	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	118.0	
55745	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	294.0	
55746	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	50.0	
55747	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	351.0	
55748	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55749	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
55750	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	19.09	
55751	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	19.09	
55752	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
55753	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
55754	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
55755	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
55756	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
55757	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
55758	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LTC000434	LTCControl	FA-TRANS 1	LTC Control Insp	General Comments		
55759	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
55760	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	10	
55761	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	10	
55762	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
55763	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
55764	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps B Ø	200.0	
55765	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps A Ø	200.0	
55766	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55767	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55768	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55769	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations	1	
55770	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Unknown Operations	0	
55771	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Switching Operations	0	
55772	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations This Read Vac	0	
55773	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AL	167	
55774	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AF	167	
55775	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Maintenance Operations	0	
55776	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	General Comments		
55777	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	General Comments		
55778	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Follow-up Action Required?	n	
55779	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Follow-up Action Required?	n	
55780	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations Ground	0	
55781	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations C Ø	0	
55782	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations B Ø	0	
55783	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations A Ø	0	
55784	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
55785	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
55786	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55787	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55788	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps C Ø	0.0	
55789	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps B Ø	0.0	
55790	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps A Ø	0.0	
55791	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55792	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55793	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55794	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations	0	
55795	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	33	°C
55796	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	44	°C
55797	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	39	°C
55798	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	44	°C
55799	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	39	°C
55800	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	46	°C
55801	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55802	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
55803	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
55804	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
55805	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	1	
55806	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
55807	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	2	
55808	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Unknown Operations	0	
55809	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Tank Paint Condition	Good	
55810	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Switching Operations	0	
55811	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
55812	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations This Read Vac	0	
55813	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AL	99918	
55814	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AF	99918	
55815	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
55816	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Maintenance Operations	0	
55817	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
55818	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	
55819	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
55820	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
55821	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
55822	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Follow-up Action Required?	n	
55823	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Follow-up Action Required?	n	
55824	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations Ground	0	
55825	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations C Ø	0	
55826	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations B Ø	0	
55827	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations A Ø	0	
55828	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
55829	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
55830	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55831	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55832	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
55833	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
55834	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
55835	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
55836	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
55837	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushing Condition	Good	
55838	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps C Ø	200.0	
55839	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
55840	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
55841	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
55842	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	15.66	%
55843	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	26.0	
55844	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
55845	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	23.0	
55846	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55847	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
55848	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
55849	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
55850	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
55851	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
55852	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
55853	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
55854	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
55855	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
55856	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
55857	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
55858	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
55859	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
55860	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
55861	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
55862	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
55863	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
55864	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
55865	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
55866	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	5	°C
55867	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	30	°C
55868	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
55869	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
55870	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
55871	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
55872	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
55873	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
55874	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
55875	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
55876	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55877	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
55878	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
55879	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55880	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55881	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
55882	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
55883	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
55884	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
55885	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
55886	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	*C
55887	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations	3	
55888	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
55889	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
55890	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
55891	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps A Ø	248.0	
55892	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps B Ø	246.0	
55893	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps C Ø	244.0	
55894	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
55895	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
55896	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	*C
55897	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
55898	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55899	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55900	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
55901	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
55902	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
55903	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
55904	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
55905	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
55906	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
55907	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55908	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55909	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55910	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	29.0	
55911	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	141.0	
55912	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	26.0	
55913	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	158.0	
55914	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	32.0	
55915	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	129.0	
55916	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55917	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	38.18	
55918	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	38.18	
55919	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	38.18	
55920	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
55921	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
55922	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
55923	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
55924	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	*C
55925	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	*C
55926	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
55927	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
55928	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	
55929	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
55930	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
55931	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
55932	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
55933	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
55934	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
55935	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	269	
55936	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	269	
55937	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	4	
55938	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
55939	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	4	
55940	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
55941	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
55942	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
55943	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
55944	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1100.0	psi
55945	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
55946	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
55947	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	General Comments		
55948	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
55949	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
55950	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
55951	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
55952	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
55953	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
55954	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
55955	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
55956	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
55957	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Unknown Operations	0	
55958	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	8	
55959	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55960	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55961	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55962	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
55963	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
55964	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
55965	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
55966	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
55967	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
55968	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
55969	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	47.73	
55970	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
55971	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
55972	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
55973	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
55974	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
55975	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
55976	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	47.73	
55977	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	47.73	
55978	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
55979	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
55980	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
55981	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
55982	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
55983	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
55984	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
55985	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
55986	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
55987	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	921	
55988	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	921	
55989	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	5	
55990	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
55991	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	5	
55992	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	3	
55993	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
55994	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
55995	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
55996	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	92.0	
55997	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	316.0	
55998	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	74.0	
55999	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	235.0	
56000	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	102.0	
56001	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	323.0	
56002	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56003	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	28.64	
56004	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	28.64	
56005	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	28.64	
56006	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
56007	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
56008	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
56009	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
56010	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
56011	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
56012	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
56013	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
56014	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
56015	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
56016	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
56017	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments		
56018	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
56019	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
56020	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
56021	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
56022	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
56023	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
56024	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
56025	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	General Comments	X3 winding temp gauge, may need to be calibrated	
56026	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nirogen @ -5	Desiccant filter about 50%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56027	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56028	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56029	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
56030	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
56031	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
56032	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
56033	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
56034	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
56035	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
56036	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
56037	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
56038	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
56039	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56040	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56041	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56042	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
56043	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
56044	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations A Ø	0	
56045	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations B Ø	0	
56046	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations C Ø	0	
56047	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations Ground	0	
56048	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Follow-up Action Required?	n	
56049	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Follow-up Action Required?	n	
56050	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	General Comments		
56051	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	General Comments		
56052	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Maintenance Operations	0	
56053	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AF	114	
56054	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AL	114	
56055	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations This Read Vac	0	
56056	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Switching Operations	0	
56057	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
56058	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
56059	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
56060	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
56061	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
56062	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
56063	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
56064	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
56065	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
56066	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
56067	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
56068	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
56069	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
56070	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
56071	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
56072	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
56073	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
56074	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
56075	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
56076	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
56077	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
56078	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
56079	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
56080	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	127780	
56081	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
56082	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
56083	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
56084	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
56085	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
56086	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Vegetation	None	
56087	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
56088	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
56089	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
56090	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
56091	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	General Comments		
56092	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
56093	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
56094	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
56095	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
56096	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
56097	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
56098	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
56099	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
56100	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
56101	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
56102	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56103	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56104	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
56105	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
56106	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	General Comments		
56107	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
56108	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
56109	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
56110	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
56111	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
56112	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	45	Seconds
56113	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
56114	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
56115	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
56116	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
56117	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
56118	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
56119	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
56120	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
56121	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
56122	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
56123	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
56124	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
56125	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
56126	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
56127	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
56128	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
56129	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
56130	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
56131	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
56132	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
56133	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
56134	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
56135	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
56136	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
56137	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
56138	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
56139	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
56140	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
56141	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56142	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
56143	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
56144	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC000532	LTCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
56145	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC000532	LTCControl	C-TRANS 4	LTC Control Insp	General Comments		
56146	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LTC000532	LTCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
56147	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
56148	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
56149	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
56150	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
56151	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
56152	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
56153	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
56154	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
56155	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	120636	
56156	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
56157	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
56158	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
56159	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
56160	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
56161	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
56162	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
56163	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
56164	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
56165	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
56166	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
56167	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
56168	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
56169	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
56170	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
56171	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
56172	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
56173	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
56174	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
56175	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
56176	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
56177	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56178	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
56179	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	oil guage still shows low	
56180	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
56181	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
56182	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56183	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56184	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
56185	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
56186	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
56187	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
56188	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
56189	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
56190	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
56191	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
56192	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
56193	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
56194	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
56195	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56196	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
56197	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56198	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56199	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
56200	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
56201	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
56202	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
56203	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
56204	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56205	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	7	
56206	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56207	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
56208	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
56209	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56210	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
56211	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
56212	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
56213	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
56214	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
56215	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5.04	kw
56216	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
56217	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
56218	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	44	*C
56219	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	22	*C
56220	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56221	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
56222	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56223	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56224	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
56225	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
56226	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56227	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
56228	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0042	
56229	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
56230	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
56231	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
56232	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
56233	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
56234	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
56235	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
56236	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
56237	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
56238	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
56239	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
56240	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
56241	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	General Comments		
56242	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
56243	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
56244	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
56245	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
56246	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
56247	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
56248	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
56249	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
56250	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
56251	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56252	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
56253	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
56254	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
56255	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
56256	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56257	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56258	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56259	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
56260	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56261	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
56262	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
56263	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56264	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
56265	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56266	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56267	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
56268	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	General Comments		
56269	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56270	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	41	°C
56271	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	39	°C
56272	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56273	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
56274	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Max	31	°C
56275	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
56276	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
56277	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
56278	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56279	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56280	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56281	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56282	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
56283	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56284	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Unknown Operations	0	
56285	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Switching Operations	0	
56286	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations This Read AM	0	
56287	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AL	564	
56288	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AF	564	
56289	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Maintenance Operations	0	
56290	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	General Comments		
56291	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	General Comments		
56292	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Follow-up Action Required?	n	
56293	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
56294	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations Ground	0	
56295	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations C Ø	0	
56296	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations B Ø	0	
56297	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations A Ø	0	
56298	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
56299	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56300	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
56301	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
56302	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
56303	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56304	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps C Ø	0.0	
56305	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	840	
56306	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	6	
56307	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	1	
56308	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	5	
56309	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56310	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56311	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56312	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56313	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56314	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56315	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56316	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56317	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56318	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
56319	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
56320	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56321	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
56322	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56323	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56324	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
56325	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	General Comments		
56326	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
56327	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
56328	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	46	°C
56329	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56330	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
56331	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Max	44	°C
56332	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
56333	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
56334	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
56335	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56336	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56337	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56338	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56339	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
56340	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56341	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56342	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
56343	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
56344	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
56345	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
56346	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
56347	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
56348	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
56349	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
56350	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56351	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56352	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56353	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56354	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56355	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
56356	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
56357	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
56358	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
56359	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
56360	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
56361	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
56362	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
56363	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
56364	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
56365	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
56366	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
56367	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
56368	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
56369	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
56370	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
56371	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
56372	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
56373	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
56374	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
56375	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
56376	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
56377	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
56378	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
56379	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
56380	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC0000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
56381	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC0000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
56382	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC0000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
56383	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Unknown Operations	0	
56384	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Switching Operations	0	
56385	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations This Read SF6	0	
56386	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AL	628	
56387	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AF	628	
56388	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Num Operations Last 9 Months	3	
56389	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Maintenance Operations	0	
56390	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	General Comments	ok	
56391	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	General Comments		
56392	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Follow-up Action Required?	n	
56393	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Follow-up Action Required?	n	
56394	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Fault Operations	0	
56395	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Equipment Properly Labeled?	y	
56396	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps C Ø	100.0	
56397	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps B Ø	50.0	
56398	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps A Ø	100.0	
56399	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	853	
56400	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Current Tap Position	4R	
56401	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Left Counter	75500	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56402	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
56403	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	General Comments		
56404	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Found Counter	75500	
56405	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps B Ø	0.0	
56406	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps A Ø	0.0	
56407	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56408	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56409	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56410	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Months Operations	1	
56411	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
56412	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
56413	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
56414	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	30	°C
56415	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	40	°C
56416	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	5477	
56417	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
56418	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Top Oil Temperature Present	25	°C
56419	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Top Oil Temperature Max	45	°C
56420	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56421	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56422	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
56423	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56424	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56425	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56426	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56427	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
56428	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
56429	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
56430	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56431	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	8346.95	kw
56432	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56433	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
56434	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
56435	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56436	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56437	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
56438	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56439	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
56440	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
56441	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56442	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56443	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56444	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56445	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56446	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56447	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56448	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56449	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56450	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
56451	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
56452	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
56453	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
56454	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
56455	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations This Read SF6	1	
56456	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Switching Operations	0	
56457	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations	0	
56458	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Unknown Operations	1	
56459	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56460	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56461	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56462	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56463	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56464	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56465	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56466	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56467	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
56468	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Leaks	None	
56469	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
56470	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Regulator As Left Counter	170187	
56471	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
56472	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
56473	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
56474	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
56475	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
56476	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Min Tap Position	10L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56477	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
56478	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
56479	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	General Comments		
56480	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
56481	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
56482	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
56483	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
56484	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
56485	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
56486	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
56487	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
56488	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
56489	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
56490	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56491	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
56492	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	n	
56493	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
56494	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
56495	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56496	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56497	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
56498	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments	need nitrogen, many fans unplugged	
56499	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56500	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56501	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
56502	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
56503	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
56504	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
56505	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
56506	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
56507	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
56508	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
56509	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
56510	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
56511	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
56512	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	390	
56513	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	390	
56514	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	3	
56515	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
56516	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	3	
56517	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps A Ø	90.0	
56518	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps B Ø	90.0	
56519	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps C Ø	90.0	
56520	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Equipment Properly Labeled?	y	
56521	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Fault Operations	0	
56522	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Follow-up Action Required?	n	
56523	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Follow-up Action Required?	n	
56524	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	General Comments		
56525	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	General Comments	ok	
56526	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Unknown Operations	0	
56527	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Switching Operations	0	
56528	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations This Read Vac	0	
56529	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AL	217	
56530	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AF	217	
56531	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Maintenance Operations	0	
56532	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	General Comments		
56533	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	General Comments		
56534	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Follow-up Action Required?	n	
56535	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
56536	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations Ground	0	
56537	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations C Ø	0	
56538	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations B Ø	0	
56539	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations A Ø	0	
56540	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
56541	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
56542	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
56543	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
56544	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps C Ø	68.0	
56545	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps B Ø	62.0	
56546	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps A Ø	69.0	
56547	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
56548	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
56549	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
56550	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Maintenance Operations	0	
56551	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Num Operations Last 9 Months	9	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56552	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AF	707	
56553	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AL	707	
56554	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
56555	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56556	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	162.0	
56557	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps Ø	105.0	
56558	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	244.0	
56559	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	111.0	
56560	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	269.0	
56561	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	66.0	
56562	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56563	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56564	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56565	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	2	
56566	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	8	
56567	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56568	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56569	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56570	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	50.0	
56571	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	50.0	
56572	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	25.0	
56573	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	25.0	
56574	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	50.0	
56575	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	50.0	
56576	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56577	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	47.73	
56578	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	47.73	
56579	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	47.73	
56580	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
56581	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
56582	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
56583	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
56584	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
56585	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
56586	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
56587	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56588	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
56589	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
56590	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
56591	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
56592	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
56593	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56594	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56595	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
56596	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
56597	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
56598	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
56599	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
56600	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
56601	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
56602	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
56603	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	840	
56604	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
56605	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56606	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56607	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56608	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56609	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
56610	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56611	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56612	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
56613	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
56614	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
56615	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
56616	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Operations Counter	461	
56617	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
56618	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	General Comments		
56619	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
56620	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
56621	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
56622	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
56623	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
56624	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps C Ø	43.0	
56625	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.0	
56626	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps A Ø	41.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56627	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56628	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56629	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56630	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56631	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56632	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
56633	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56634	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
56635	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56636	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
56637	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56638	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	2	
56639	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
56640	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	2	
56641	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4497	
56642	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4497	
56643	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
56644	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
56645	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
56646	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
56647	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
56648	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
56649	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
56650	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
56651	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
56652	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	19.09	
56653	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	19.09	
56654	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56655	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56656	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56657	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
56658	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
56659	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
56660	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
56661	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
56662	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
56663	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56664	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
56665	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
56666	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
56667	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
56668	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
56669	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
56670	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
56671	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
56672	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
56673	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
56674	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
56675	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
56676	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	743	
56677	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	743	
56678	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations This Read AM	2	
56679	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	2	
56680	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
56681	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56682	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
56683	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
56684	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
56685	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
56686	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
56687	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
56688	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56689	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
56690	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
56691	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
56692	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
56693	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
56694	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
56695	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
56696	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56697	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Follow-up Action Required?	n	
56698	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56699	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56700	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	General Comments		
56701	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56702	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56703	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
56704	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
56705	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
56706	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
56707	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
56708	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
56709	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations A Ø	0	
56710	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
56711	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
56712	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
56713	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
56714	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
56715	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
56716	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
56717	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
56718	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
56719	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushing Condition	Good	
56720	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps C Ø	61.0	
56721	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps B Ø	48.0	
56722	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps A Ø	54.0	
56723	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
56724	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
56725	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CA0000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
56726	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56727	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56728	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56729	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56730	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56731	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56732	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56733	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56734	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56735	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CA0000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
56736	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CA0000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
56737	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
56738	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
56739	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
56740	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
56741	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	302646	
56742	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	302646	
56743	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
56744	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	7L	
56745	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
56746	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	14L	
56747	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
56748	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	1127	
56749	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	2	
56750	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56751	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56752	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	7	
56753	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
56754	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
56755	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
56756	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
56757	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
56758	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
56759	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
56760	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
56761	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
56762	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
56763	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
56764	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
56765	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
56766	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
56767	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
56768	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	General Comments		
56769	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
56770	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
56771	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
56772	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
56773	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
56774	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99871	
56775	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99871	
56776	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56777	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
56778	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	0	
56779	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
56780	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
56781	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
56782	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
56783	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Follow-up Action Required?	n	
56784	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
56785	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
56786	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
56787	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
56788	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	790	
56789	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	790	
56790	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations This Read AM	0	
56791	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	0	
56792	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
56793	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
56794	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
56795	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
56796	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
56797	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
56798	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
56799	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
56800	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
56801	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
56802	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
56803	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	LTC Totalizer Reading	4475.52	kw
56804	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56805	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
56806	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Max	24	°C
56807	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Present	15	°C
56808	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56809	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56810	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56811	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56812	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
56813	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56814	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56815	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
56816	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Reading	.4662	
56817	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
56818	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
56819	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Months Operations	1	
56820	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
56821	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56822	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56823	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps A Ø	0.0	
56824	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps B Ø	0.0	
56825	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps C Ø	0.0	
56826	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56827	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
56828	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
56829	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
56830	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations A Ø	0	
56831	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations B Ø	0	
56832	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations C Ø	0	
56833	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations Ground	0	
56834	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
56835	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Follow-up Action Required?	n	
56836	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	General Comments		
56837	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	General Comments		
56838	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Maintenance Operations	0	
56839	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AF	599	
56840	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AL	599	
56841	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations This Read AM	0	
56842	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Switching Operations	0	
56843	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Unknown Operations	0	
56844	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	2	
56845	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
56846	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
56847	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
56848	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0.0	
56849	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0.0	
56850	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0.0	
56851	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
56852	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
56853	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
56854	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
56855	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
56856	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
56857	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
56858	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
56859	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
56860	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
56861	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
56862	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	10	°C
56863	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
56864	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
56865	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56866	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
56867	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56868	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		
56869	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
56870	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56871	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56872	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
56873	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
56874	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56875	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56876	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56877	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56878	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56879	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56880	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56881	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
56882	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
56883	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Follow-up Action Required?	n	
56884	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations Ground	0	
56885	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
56886	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
56887	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
56888	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
56889	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
56890	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	n	
56891	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
56892	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
56893	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
56894	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
56895	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
56896	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments	many fans unplugged. needs nitrogen	
56897	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
56898	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
56899	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
56900	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
56901	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	676	°C
56902	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	General Comments		
56903	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	General Comments		
56904	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Found Counter	136000	
56905	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Left Counter	136000	
56906	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
56907	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	4L	
56908	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
56909	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	13L	
56910	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
56911	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	617	
56912	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
56913	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
56914	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
56915	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	General Comments	OK	
56916	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56917	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
56918	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56919	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
56920	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56921	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
56922	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56923	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
56924	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56925	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Grounds in Place?	y	
56926	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
56927	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	General Comments		
56928	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Foundation Condition	Good	
56929	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
56930	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
56931	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
56932	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
56933	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
56934	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
56935	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Follow-up Action Required?	n	
56936	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
56937	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Follow-up Action Required?	n	
56938	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
56939	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	General Comments		
56940	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	General Comments	ok	
56941	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Maintenance Operations	0	
56942	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Num Operations Last 9 Months	0	
56943	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AF	314	
56944	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AL	314	
56945	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations This Read SF6	0	
56946	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Switching Operations	0	
56947	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Unknown Operations	0	
56948	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
56949	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
56950	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	10	°C
56951	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	30	°C
56952	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
56953	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
56954	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
56955	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
56956	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	1	
56957	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
56958	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	1	
56959	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2557	
56960	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2557	
56961	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
56962	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
56963	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
56964	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
56965	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
56966	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Unknown Operations	0	
56967	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Tank Paint Condition	Good	
56968	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Switching Operations	1	
56969	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations This Read Vac	6	
56970	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AL	199	
56971	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AF	199	
56972	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Moisture and Leak Free?	y	
56973	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Maintenance Operations	5	
56974	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Grounds in Place?	y	
56975	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	General Comments		
56976	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	General Comments		
56977	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Foundation Condition	Good	
56978	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Follow-up Action Required?	n	
56979	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Follow-up Action Required?	n	
56980	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations Ground	0	
56981	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations C Ø	0	
56982	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations B Ø	0	
56983	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
56984	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
56985	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
56986	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
56987	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
56988	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
56989	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
56990	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
56991	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
56992	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
56993	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	3.7	
56994	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
56995	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
56996	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
56997	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
56998	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
56999	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57000	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	1	
57001	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57002	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
57003	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57004	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
57005	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
57006	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
57007	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57008	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
57009	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
57010	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
57011	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	9 Month Operations	0	
57012	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57013	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57014	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57015	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps A Ø	0.0	
57016	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps B Ø	0.0	
57017	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps C Ø	0.0	
57018	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57019	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57020	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57021	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57022	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations A Ø	0	
57023	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations B Ø	0	
57024	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations C Ø	0	
57025	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations Ground	0	
57026	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
57027	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Follow-up Action Required?	n	
57028	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	General Comments		
57029	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	General Comments		
57030	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Maintenance Operations	0	
57031	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AF	160	
57032	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AL	160	
57033	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations This Read Vac	0	
57034	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Switching Operations	0	
57035	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Unknown Operations	0	
57036	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations C Ø	0	
57037	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations B Ø	0	
57038	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations A Ø	0	
57039	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57040	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
57041	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
57042	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
57043	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
57044	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
57045	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
57046	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
57047	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
57048	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
57049	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
57050	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
57051	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
57052	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
57053	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations This Read Vac	0	
57054	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AL	331	
57055	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AF	331	
57056	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Moisture and Leak Free?	y	
57057	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
57058	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57059	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
57060	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57061	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Maintenance Operations	0	
57062	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
57063	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Grounds in Place?	y	
57064	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	General Comments		
57065	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Unknown Operations	0	
57066	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Tank Paint Condition	Good	
57067	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Switching Operations	0	
57068	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
57069	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations This Read Vac	0	
57070	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AL	170	
57071	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AF	170	
57072	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
57073	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Maintenance Operations	0	
57074	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
57075	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Grounds in Place?	y	
57076	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57077	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	General Comments		
57078	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Foundation Condition	Good	
57079	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
57080	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
57081	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations Ground	0	
57082	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
57083	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
57084	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
57085	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57086	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57087	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57088	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57089	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57090	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57091	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57092	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57093	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57094	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushing Condition	Good	
57095	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps C Ø	0.0	
57096	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps B Ø	0.0	
57097	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps A Ø	0.0	
57098	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57099	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57100	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57101	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57102	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
57103	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57104	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	?	
57105	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57106	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	?	
57107	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57108	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	?	
57109	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57110	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Unknown Operations	0	
57111	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57112	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
57113	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57114	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
57115	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57116	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
57117	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57118	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57119	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	9 Month Operations	42	
57120	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
57121	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
57122	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
57123	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Operations Since Last Insp	1117	
57124	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Min Tap Position	12L	
57125	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Max Tap Position	4R	
57126	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Current Tap Position	5L	
57127	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
57128	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Left Counter	232556	
57129	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Found Counter	232546	
57130	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	General Comments		
57131	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	General Comments		
57132	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
57133	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Follow-up Action Required?	n	
57134	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
57135	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57136	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
57137	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
57138	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
57139	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57140	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
57141	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
57142	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57143	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
57144	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
57145	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
57146	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	125	°C
57147	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
57148	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Unknown Operations	0	
57149	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Tank Paint Condition	Good	
57150	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Switching Operations	0	
57151	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
57152	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
57153	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
57154	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
57155	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
57156	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
57157	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	General Comments		
57158	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
57159	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
57160	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
57161	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
57162	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
57163	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
57164	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
57165	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
57166	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
57167	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57168	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57169	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57170	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57171	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57172	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57173	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57174	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57175	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushing Condition	Good	
57176	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps C Ø	0.0	
57177	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps B Ø	0.0	
57178	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps A Ø	0.0	
57179	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57180	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57181	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57182	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	9 Month Operations	20	
57183	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
57184	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
57185	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
57186	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
57187	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
57188	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
57189	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A&B I.O.C	A -phase wont rest
57190	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
57191	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	910	
57192	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	910	
57193	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
57194	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
57195	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
57196	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
57197	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
57198	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
57199	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
57200	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	LTC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
57201	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations	0	
57202	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	General Comments		
57203	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Foundation Condition	Good	
57204	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Follow-up Action Required?	n	
57205	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Follow-up Action Required?	n	
57206	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations Ground	0	
57207	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations C Ø	0	
57208	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations B Ø	0	
57209	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations A Ø	0	
57210	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57211	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
57212	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
57213	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
57214	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	85	
57215	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	85	
57216	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
57217	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B&C phase I.O.C	
57218	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
57219	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
57220	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
57221	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
57222	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
57223	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
57224	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
57225	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57226	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57227	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57228	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57229	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
57230	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
57231	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
57232	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57233	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57234	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57235	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
57236	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	80.0	
57237	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
57238	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57239	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
57240	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
57241	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57242	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
57243	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
57244	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
57245	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
57246	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57247	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57248	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57249	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
57250	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
57251	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations A Ø	0	
57252	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
57253	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57254	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	OK	
57255	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57256	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	General Comments	OK	
57257	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57258	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	General Comments	OK	
57259	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
57260	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57261	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57262	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57263	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57264	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57265	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57266	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57267	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57268	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
57269	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
57270	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
57271	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
57272	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
57273	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
57274	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
57275	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
57276	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
57277	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
57278	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
57279	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
57280	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
57281	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
57282	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57283	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57284	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57285	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57286	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57287	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57288	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57289	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57290	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57291	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushing Condition	Good	
57292	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps C Ø	130.0	
57293	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps B Ø	115.0	
57294	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps A Ø	97.0	
57295	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57296	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57297	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushing Condition	Good	
57298	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps C Ø	0.0	
57299	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps B Ø	0.0	
57300	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps A Ø	0.0	
57301	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57302	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
57303	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
57304	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57305	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57306	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
57307	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
57308	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
57309	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
57310	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
57311	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
57312	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
57313	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
57314	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
57315	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
57316	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
57317	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
57318	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
57319	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
57320	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
57321	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
57322	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
57323	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
57324	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
57325	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
57326	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	CAPO00054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
57327	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
57328	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
57329	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
57330	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57331	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57332	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57333	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations	7	
57334	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Unknown Operations	0	
57335	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Tank Paint Condition	Good	
57336	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Switching Operations	1	
57337	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations This Read Vac	6	
57338	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AL	196	
57339	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AF	196	
57340	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Moisture and Leak Free?	y	
57341	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Maintenance Operations	5	
57342	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Grounds in Place?	y	
57343	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	General Comments		
57344	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	General Comments		
57345	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Foundation Condition	Good	
57346	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Follow-up Action Required?	n	
57347	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Follow-up Action Required?	n	
57348	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations Ground	0	
57349	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations C Ø	0	
57350	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations B Ø	0	
57351	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57352	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps A Ø	0.0	
57353	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps B Ø	0.0	
57354	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps C Ø	0.0	
57355	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57356	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57357	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57358	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57359	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations A Ø	0	
57360	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations B Ø	0	
57361	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations C Ø	0	
57362	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations Ground	0	
57363	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
57364	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
57365	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
57366	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57367	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
57368	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
57369	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
57370	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
57371	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Follow-up Action Required?	n	
57372	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Follow-up Action Required?	n	
57373	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	General Comments		
57374	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	General Comments		
57375	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Maintenance Operations	0	
57376	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AF	606	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57377	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AL	606	
57378	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations This Read AM	0	
57379	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Switching Operations	0	
57380	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57381	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57382	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
57383	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
57384	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
57385	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
57386	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
57387	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57388	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
57389	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
57390	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57391	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
57392	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
57393	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
57394	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
57395	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57396	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57397	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
57398	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
57399	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57400	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57401	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57402	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57403	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57404	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	9 Month Operations	31	
57405	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Unknown Operations	0	
57406	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Tank Paint Condition	Good	
57407	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Switching Operations	5	
57408	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
57409	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations This Read Vac	5	
57410	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AL	361	
57411	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AF	361	
57412	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Moisture and Leak Free?	y	
57413	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Maintenance Operations	0	
57414	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Heaters (All) Functioning?	y	
57415	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Grounds in Place?	y	
57416	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	General Comments		
57417	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	General Comments		
57418	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Foundation Condition	Good	
57419	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Follow-up Action Required?	n	
57420	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Follow-up Action Required?	n	
57421	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations Ground	0	
57422	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations C Ø	0	
57423	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations B Ø	0	
57424	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations A Ø	0	
57425	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57426	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57427	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57428	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57429	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57430	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57431	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57432	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57433	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57434	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushing Condition	Good	
57435	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57436	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations	8	
57437	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
57438	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
57439	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
57440	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
57441	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57442	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
57443	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
57444	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps C Ø	0.0	
57445	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps B Ø	0.0	
57446	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps A Ø	0.0	
57447	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57448	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Months Operations	0	
57449	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57450	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57451	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence 25' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57452	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
57453	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
57454	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
57455	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
57456	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
57457	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
57458	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
57459	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
57460	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
57461	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
57462	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
57463	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	General Comments	some top rail and post showing signs of rust as well as fabric	
57464	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
57465	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
57466	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57467	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57468	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57469	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
57470	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
57471	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
57472	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
57473	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	"F
57474	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
57475	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
57476	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
57477	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
57478	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
57479	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
57480	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
57481	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
57482	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	General Comments		
57483	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
57484	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
57485	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57486	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
57487	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
57488	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
57489	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57490	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
57491	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
57492	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	GAP UNDER FENCE BACK OF STATION....some top rail and barb wire rusty	
57493	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
57494	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
57495	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
57496	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
57497	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
57498	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
57499	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
57500	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
57501	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
57502	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
57503	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
57504	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
57505	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	FE000114	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
57506	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
57507	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
57508	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7	
57509	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7	
57510	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
57511	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
57512	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
57513	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
57514	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
57515	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
57516	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
57517	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
57518	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57519	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57520	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57521	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57522	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
57523	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57524	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57525	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
57526	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57527	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	127.0	
57528	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	183.0	
57529	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57530	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57531	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57532	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	6	
57533	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57534	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57535	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
57536	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
57537	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
57538	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
57539	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
57540	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushing Condition	Good	
57541	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps C Ø	0.0	
57542	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps B Ø	0.0	
57543	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps A Ø	0.0	
57544	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations This Read Vac	0	
57545	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AL	124	
57546	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AF	124	
57547	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
57548	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Maintenance Operations	0	
57549	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
57550	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57551	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57552	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57553	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	9 Month Operations	19	
57554	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57555	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57556	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57557	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57558	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments		
57559	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57560	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
57561	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
57562	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	35	°C
57563	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	70	°C
57564	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	.8208	
57565	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
57566	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Top Oil Temperature Present	35	°C
57567	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Top Oil Temperature Max	60	°C
57568	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
57569	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57570	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
57571	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
57572	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
57573	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
57574	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57575	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
57576	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
57577	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57578	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
57579	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
57580	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57581	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
57582	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
57583	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
57584	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57585	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
57586	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	12508.99	kw
57587	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
57588	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
57589	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
57590	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57591	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
57592	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
57593	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57594	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
57595	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
57596	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Trash?	y	
57597	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
57598	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
57599	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
57600	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
57601	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
57602	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	General Comments		
57603	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
57604	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Vegetation	None	
57605	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
57606	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
57607	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
57608	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
57609	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
57610	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
57611	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
57612	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
57613	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
57614	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
57615	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	General Comments		
57616	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
57617	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
57618	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57619	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
57620	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57621	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57622	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57623	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
57624	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
57625	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
57626	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57627	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
57628	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
57629	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
57630	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
57631	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Unknown Operations	0	
57632	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Switching Operations	0	
57633	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations This Read AM	0	
57634	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AL	490	
57635	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AF	490	
57636	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Maintenance Operations	0	
57637	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
57638	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
57639	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
57640	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
57641	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
57642	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57643	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Foundation Condition	Good	
57644	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
57645	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
57646	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
57647	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
57648	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
57649	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
57650	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Operations Since Last Insp	1035	
57651	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
57652	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Min Tap Position	13L	
57653	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Max Tap Position	3R	
57654	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Current Tap Position	6L	
57655	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
57656	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Left Counter	30015	
57657	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Found Counter	30005	
57658	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	General Comments		
57659	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	General Comments		
57660	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
57661	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Follow-up Action Required?	n	
57662	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	General Comments		
57663	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	General Comments		
57664	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Follow-up Action Required?	n	
57665	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
57666	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations Ground	0	
57667	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
57668	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps B Ø	44.0	
57669	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
57670	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
57671	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
57672	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
57673	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
57674	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
57675	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
57676	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57677	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
57678	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
57679	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations C Ø	0	
57680	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations	0	
57681	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57682	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57683	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57684	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps A Ø	0.0	
57685	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	153.0	
57686	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	26.5	%
57687	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	25.29	%
57688	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	13.25	%
57689	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
57690	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations A Ø	0	
57691	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations B Ø	0	
57692	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations C Ø	0	
57693	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Unknown Operations	0	
57694	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Switching Operations	0	
57695	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations This Read AM	1	
57696	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
57697	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
57698	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
57699	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
57700	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
57701	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AL	569	
57702	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AF	569	
57703	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Maintenance Operations	1	
57704	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	General Comments		
57705	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	General Comments		
57706	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
57707	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
57708	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
57709	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
57710	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
57711	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
57712	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57713	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57714	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57715	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57716	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
57717	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Months Operations	13	
57718	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57719	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57720	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Unknown Operations	1	
57721	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
57722	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
57723	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Switching Operations	0	
57724	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations This Read SF6	1	
57725	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AL	352	
57726	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AF	352	
57727	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Num Operations Last 9 Months	5	
57728	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Maintenance Operations	0	
57729	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	General Comments	ok	
57730	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	General Comments		
57731	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Follow-up Action Required?	n	
57732	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Follow-up Action Required?	n	
57733	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Fault Operations	0	
57734	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57735	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57736	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57737	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57738	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
57739	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
57740	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
57741	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
57742	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
57743	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
57744	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
57745	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
57746	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
57747	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
57748	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
57749	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
57750	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps A Ø	0.0	
57751	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Months Operations	6	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
57752	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
57753	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
57754	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
57755	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Grounds in Place?	y	
57756	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	General Comments		
57757	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	General Comments		
57758	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Foundation Condition	Good	
57759	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Follow-up Action Required?	n	
57760	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
57761	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
57762	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
57763	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
57764	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
57765	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations B Ø	0	
57766	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations A Ø	0	
57767	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57768	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57769	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
57770	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
57771	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps C Ø	0.0	
57772	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps B Ø	0.0	
57773	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps A Ø	0.0	
57774	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
57775	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
57776	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
57777	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations	0	
57778	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Unknown Operations	0	
57779	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Switching Operations	0	
57780	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations This Read AM	0	
57781	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AL	316	
57782	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AF	316	
57783	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Maintenance Operations	0	
57784	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	General Comments		
57785	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	General Comments		
57786	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
57787	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
57788	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Months Operations	5	
57789	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57790	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57791	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57792	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps A Ø	675.0	
57793	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps B Ø	650.0	
57794	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps C Ø	650.0	
57795	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57796	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57797	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57798	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57799	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations A Ø	0	
57800	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations B Ø	0	
57801	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations C Ø	0	
57802	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations Ground	0	
57803	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
57804	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations This Read AM	1	
57805	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AL	7	
57806	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AF	7	
57807	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Maintenance Operations	1	
57808	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	General Comments		
57809	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	General Comments		
57810	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Follow-up Action Required?	n	
57811	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
57812	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations Ground	0	
57813	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations C Ø	0	
57814	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations B Ø	0	
57815	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations A Ø	0	
57816	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57817	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57818	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57819	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57820	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps C Ø	0.0	
57821	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps B Ø	0.0	
57822	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps A Ø	0.0	
57823	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57824	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57825	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57826	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57827	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	General Comments		
57828	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	General Comments		
57829	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Maintenance Operations	0	
57830	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AF	532	
57831	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AL	532	
57832	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations This Read AM	0	
57833	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Switching Operations	0	
57834	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Unknown Operations	0	
57835	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Unknown Operations	0	
57836	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Months Operations	1	
57837	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Tank Paint Condition	Good	
57838	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Switching Operations	1	
57839	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
57840	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations This Read Vac	1	
57841	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AL	332	
57842	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations This Read Vac	0	
57843	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AL	178	
57844	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AF	178	
57845	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Maintenance Operations	0	
57846	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	General Comments		
57847	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	General Comments		
57848	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Follow-up Action Required?	n	
57849	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
57850	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57851	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
57852	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Unknown Operations	0	
57853	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Switching Operations	0	
57854	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations This Read SF6	0	
57855	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AL	532	
57856	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AF	532	
57857	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Num Operations Last 9 Months	8	
57858	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Maintenance Operations	0	
57859	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	General Comments	ok	
57860	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	General Comments		
57861	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Follow-up Action Required?	n	
57862	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Follow-up Action Required?	n	
57863	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Fault Operations	0	
57864	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps C Ø	80.0	
57865	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps B Ø	80.0	
57866	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps A Ø	80.0	
57867	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
57868	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
57869	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
57870	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
57871	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
57872	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
57873	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
57874	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	144	
57875	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
57876	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
57877	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	202	
57878	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
57879	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.0	
57880	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.0	
57881	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	192	
57882	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
57883	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
57884	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
57885	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	
57886	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
57887	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	LTC has no oil or is very low.	
57888	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57889	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
57890	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations Ground	0	
57891	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations C Ø	0	
57892	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57893	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
57894	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
57895	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	VRR Time Delay	30	
57896	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120.0	
57897	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120.0	
57898	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	
57899	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	LTC Output Voltage Level	120.0	
57900	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
57901	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCCControl	221-4	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57902	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
57903	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
57904	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
57905	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
57906	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
57907	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
57908	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	1184	
57909	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	*C
57910	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	*C
57911	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	14L	
57912	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	2R	
57913	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	4L	
57914	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
57915	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	6877	
57916	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	6877	
57917	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
57918	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
57919	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
57920	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations C Ø	0	
57921	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations B Ø	0	
57922	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations A Ø	0	
57923	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
57924	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
57925	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
57926	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
57927	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
57928	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
57929	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
57930	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
57931	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
57932	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
57933	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
57934	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
57935	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments		
57936	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
57937	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
57938	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
57939	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
57940	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
57941	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
57942	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
57943	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations Ground	0	
57944	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
57945	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
57946	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
57947	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57948	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57949	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57950	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57951	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps C Ø	0.0	
57952	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps B Ø	0.0	
57953	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps A Ø	0.0	
57954	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
57955	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
57956	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
57957	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Months Operations	1	
57958	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
57959	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC000588	LTCControl	MD-TRANS 3	LTC Control Insp	General Comments		
57960	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LTC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
57961	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
57962	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
57963	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
57964	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
57965	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
57966	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
57967	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
57968	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
57969	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
57970	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
57971	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
57972	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
57973	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	417	
57974	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	417	
57975	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
57976	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
57977	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
57978	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
57979	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
57980	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
57981	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
57982	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
57983	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
57984	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
57985	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
57986	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
57987	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
57988	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
57989	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
57990	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	222.0	
57991	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	106.0	
57992	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	147.0	
57993	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	75.0	
57994	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	268.0	
57995	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	111.0	
57996	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	0	
57997	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
57998	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AF	332	
57999	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Moisture and Leak Free?	y	
58000	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Maintenance Operations	0	
58001	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
58002	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Grounds in Place?	y	
58003	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	General Comments		
58004	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
58005	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
58006	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
58007	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
58008	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
58009	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
58010	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
58011	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
58012	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
58013	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
58014	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	General Comments		
58015	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
58016	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
58017	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
58018	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
58019	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
58020	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
58021	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
58022	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
58023	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Regulator As Left Counter	249186	
58024	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
58025	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
58026	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
58027	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Leaks	None	
58028	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
58029	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
58030	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
58031	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
58032	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
58033	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
58034	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
58035	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
58036	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
58037	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
58038	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
58039	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
58040	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
58041	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
58042	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58043	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58044	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
58045	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
58046	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
58047	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
58048	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
58049	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
58050	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
58051	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58052	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
58053	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	General Comments		
58054	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
58055	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
58056	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
58057	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
58058	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
58059	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
58060	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
58061	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
58062	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27514	
58063	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
58064	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
58065	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Leaks	None	
58066	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
58067	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
58068	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
58069	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
58070	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
58071	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
58072	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	General Comments		
58073	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Foundation Condition	Good	
58074	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Follow-up Action Required?	n	
58075	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Follow-up Action Required?	n	
58076	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations Ground	0	
58077	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	264	
58078	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	264	
58079	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations This Read Vac	1	
58080	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
58081	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	1	
58082	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
58083	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
58084	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
58085	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
58086	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58087	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
58088	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
58089	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58090	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
58091	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58092	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
58093	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	696	
58094	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	39	*C
58095	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	41	*C
58096	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
58097	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
58098	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
58099	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
58100	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
58101	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
58102	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Left Counter	168262	
58103	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Found Counter	168262	
58104	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
58105	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	General Comments		
58106	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
58107	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
58108	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58109	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
58110	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58111	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	529	
58112	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
58113	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
58114	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13L	
58115	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
58116	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
58117	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Left Counter	7110	
58118	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Found Counter	7110	
58119	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
58120	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Months Operations	1	
58121	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58122	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58123	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58124	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps A Ø	0.0	
58125	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps B Ø	0.0	
58126	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58127	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58128	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58129	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58130	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58131	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations A Ø	0	
58132	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations B Ø	0	
58133	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations C Ø	0	
58134	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations Ground	0	
58135	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Follow-up Action Required?	n	
58136	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Follow-up Action Required?	n	
58137	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	General Comments		
58138	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	General Comments		
58139	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Maintenance Operations	0	
58140	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AF	556	
58141	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AL	556	
58142	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations This Read AM	0	
58143	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Switching Operations	0	
58144	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Unknown Operations	0	
58145	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	General Comments		
58146	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
58147	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
58148	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
58149	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
58150	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58151	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
58152	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
58153	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58154	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
58155	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58156	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
58157	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
58158	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
58159	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	398	
58160	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	398	
58161	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	1	
58162	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
58163	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	1	
58164	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations Ground	0	
58165	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Follow-up Action Required?	n	
58166	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Follow-up Action Required?	n	
58167	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	General Comments		
58168	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	General Comments		
58169	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Maintenance Operations	0	
58170	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AF	436	
58171	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AL	436	
58172	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations This Read AM	0	
58173	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Switching Operations	0	
58174	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Unknown Operations	0	
58175	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps A Ø	60.0	
58176	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps B Ø	20.0	
58177	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps C Ø	50.0	
58178	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Equipment Properly Labeled?	y	
58179	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1940	
58180	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
58181	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
58182	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
58183	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
58184	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
58185	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
58186	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
58187	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
58188	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
58189	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
58190	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
58191	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2865.60	kw
58192	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
58193	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
58194	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
58195	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	General Comments		
58196	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	General Comments		
58197	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58198	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
58199	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
58200	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58201	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58202	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
58203	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	2	
58204	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58205	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58206	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58207	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	430.0	
58208	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	430.0	
58209	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	430.0	
58210	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
58211	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58212	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58213	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58214	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58215	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58216	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58217	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58218	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58219	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58220	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations A Ø	0	
58221	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations B Ø	0	
58222	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations C Ø	0	
58223	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations Ground	0	
58224	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
58225	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
58226	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
58227	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	General Comments		
58228	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
58229	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
58230	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
58231	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
58232	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
58233	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
58234	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
58235	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
58236	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
58237	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
58238	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
58239	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
58240	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
58241	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
58242	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58243	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58244	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
58245	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
58246	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
58247	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
58248	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1334	
58249	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
58250	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58251	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
58252	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58253	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
58254	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
58255	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
58256	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
58257	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
58258	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
58259	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
58260	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.8484	
58261	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	60	°C
58262	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	30	°C
58263	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
58264	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
58265	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	1	
58266	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58267	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58268	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58269	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	220.0	
58270	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	220.0	
58271	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	220.0	
58272	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
58273	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58274	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58275	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58276	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58277	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58278	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58279	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58280	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58281	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58282	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
58283	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
58284	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	
58285	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
58286	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
58287	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
58288	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
58289	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
58290	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
58291	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
58292	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
58293	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
58294	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
58295	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	106	
58296	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	106	
58297	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations This Read Vac	0	
58298	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
58299	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	0	
58300	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
58301	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A&B phase I.O.C	
58302	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
58303	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1033	
58304	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1033	
58305	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
58306	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
58307	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
58308	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
58309	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
58310	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
58311	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
58312	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
58313	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
58314	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
58315	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
58316	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	General Comments		
58317	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
58318	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
58319	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
58320	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
58321	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
58322	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
58323	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
58324	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
58325	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
58326	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
58327	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
58328	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence 35' Clearance To Trees?	y	
58329	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
58330	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58331	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
58332	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
58333	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58334	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
58335	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
58336	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
58337	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	12929.62	kw
58338	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
58339	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
58340	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	50	°C
58341	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	30	°C
58342	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
58343	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
58344	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
58345	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
58346	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
58347	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	General Comments		
58348	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
58349	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Found Counter	105388	
58350	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Left Counter	105388	
58351	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58352	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	2	
58353	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58354	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58355	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58356	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	200.0	
58357	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	200.0	
58358	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	200.0	
58359	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
58360	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58361	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58362	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58363	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58364	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58365	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58366	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58367	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58368	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58369	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	
58370	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
58371	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
58372	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
58373	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
58374	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
58375	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
58376	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
58377	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
58378	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	
58379	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
58380	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
58381	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
58382	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	55	
58383	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	55	
58384	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations This Read Vac	0	
58385	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
58386	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	0	
58387	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
58388	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
58389	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
58390	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58391	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations A Ø	0	
58392	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations B Ø	0	
58393	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations C Ø	0	
58394	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations Ground	0	
58395	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
58396	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
58397	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
58398	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
58399	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
58400	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	y	
58401	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
58402	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
58403	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
58404	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Follow-up Action Required?	n	
58405	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	General Comments		
58406	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	General Comments		
58407	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Maintenance Operations	0	
58408	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations C Ø	0	
58409	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations B Ø	0	
58410	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations A Ø	0	
58411	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58412	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58413	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58414	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58415	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AF	368	
58416	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AL	368	
58417	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations This Read AM	0	
58418	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Switching Operations	0	
58419	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Unknown Operations	0	
58420	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	1	
58421	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58422	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58423	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58424	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58425	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58426	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58427	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58428	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58429	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushing Condition	Good	
58430	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps C Ø	0.0	
58431	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps B Ø	0.0	
58432	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps A Ø	0.0	
58433	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58434	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58435	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58436	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations	0	
58437	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58438	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
58439	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
58440	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58441	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
58442	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
58443	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
58444	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
58445	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
58446	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	0.0	
58447	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	0.0	
58448	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	0.0	
58449	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	0.0	
58450	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	0.0	
58451	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	0.0	
58452	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58453	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58454	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58455	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58456	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	
58457	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
58458	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
58459	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
58460	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
58461	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
58462	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
58463	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
58464	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
58465	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	257	
58466	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	257	
58467	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	1	
58468	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps B Ø	0.0	
58469	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps C Ø	0.0	
58470	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58471	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58472	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations B Ø	0	
58473	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations A Ø	0	
58474	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58475	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58476	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58477	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58478	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps C Ø	0.0	
58479	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps B Ø	0.0	
58480	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps A Ø	0.0	
58481	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58482	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58483	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58484	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Months Operations	0	
58485	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
58486	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	General Comments		
58487	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
58488	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
58489	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Operations Counter	4	
58490	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
58491	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
58492	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
58493	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
58494	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
58495	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
58496	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
58497	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
58498	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
58499	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
58500	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Leaks	None	
58501	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58502	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
58503	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
58504	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
58505	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
58506	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
58507	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
58508	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
58509	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
58510	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
58511	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
58512	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
58513	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
58514	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
58515	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
58516	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
58517	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
58518	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
58519	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
58520	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
58521	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
58522	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
58523	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
58524	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
58525	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
58526	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
58527	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
58528	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
58529	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
58530	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
58531	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
58532	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Follow-up Action Required?	n	
58533	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations Ground	0	
58534	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
58535	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
58536	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
58537	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
58538	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
58539	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
58540	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
58541	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps B Ø	0.0	
58542	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps C Ø	0.0	
58543	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58544	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58545	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58546	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
58547	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
58548	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations A Ø	0	
58549	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
58550	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	82.50	
58551	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
58552	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
58553	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
58554	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
58555	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations B Ø	0	
58556	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations C Ø	0	
58557	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations Ground	0	
58558	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Follow-up Action Required?	n	
58559	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Follow-up Action Required?	n	
58560	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Foundation Condition	Good	
58561	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	General Comments		
58562	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	General Comments		
58563	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Grounds in Place?	y	
58564	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Maintenance Operations	0	
58565	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Moisture and Leak Free?	y	
58566	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AF	148	
58567	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AL	148	
58568	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations This Read Vac	0	
58569	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Switching Operations	0	
58570	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Tank Paint Condition	Good	
58571	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Unknown Operations	0	
58572	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
58573	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
58574	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
58575	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Present	28	*C
58576	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Max	52	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58577	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
58578	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
58579	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
58580	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
58581	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	General Comments		
58582	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
58583	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58584	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58585	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58586	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
58587	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
58588	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
58589	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58590	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58591	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58592	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58593	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
58594	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
58595	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
58596	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
58597	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
58598	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
58599	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
58600	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	General Comments		
58601	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	General Comments		
58602	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58603	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
58604	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
58605	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
58606	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
58607	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
58608	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	General Comments		
58609	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
58610	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Vegetation	None	
58611	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
58612	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
58613	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	220	
58614	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	220	
58615	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
58616	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
58617	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
58618	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
58619	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58620	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
58621	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
58622	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
58623	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
58624	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	1	
58625	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
58626	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
58627	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58628	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58629	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58630	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations	2	
58631	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
58632	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
58633	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58634	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58635	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58636	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps A Ø	69.0	
58637	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps B Ø	104.0	
58638	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps C Ø	86.0	
58639	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushing Condition	Good	
58640	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
58641	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58642	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58643	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58644	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58645	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	4	
58646	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58647	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58648	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58649	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58650	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58651	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58652	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58653	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58654	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
58655	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	79.0	
58656	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
58657	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	66.0	
58658	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
58659	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	74.0	
58660	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58661	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
58662	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
58663	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
58664	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
58665	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
58666	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
58667	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
58668	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
58669	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
58670	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
58671	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
58672	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
58673	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
58674	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
58675	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
58676	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
58677	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
58678	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
58679	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
58680	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58681	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58682	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58683	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58684	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
58685	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58686	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58687	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations A Ø	0	
58688	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations B Ø	0	
58689	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations C Ø	0	
58690	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations Ground	0	
58691	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
58692	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Follow-up Action Required?	n	
58693	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	General Comments		
58694	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	General Comments		
58695	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Maintenance Operations	0	
58696	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AF	119	
58697	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AL	119	
58698	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations This Read Vac	0	
58699	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Switching Operations	0	
58700	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Unknown Operations	0	
58701	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
58702	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Trash?	y	
58703	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Switching Operations	0	
58704	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Tank Paint Condition	Good	
58705	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Unknown Operations	0	
58706	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	9 Month Operations	3	
58707	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58708	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58709	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58710	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps A Ø	150.0	
58711	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps B Ø	155.0	
58712	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps C Ø	135.0	
58713	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushing Condition	Good	
58714	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
58715	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
58716	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
58717	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
58718	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
58719	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58720	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58721	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58722	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58723	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
58724	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
58725	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
58726	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
58727	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	142	
58728	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
58729	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.0	
58730	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
58731	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
58732	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
58733	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.0	
58734	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	591	
58735	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
58736	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
58737	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	103	
58738	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
58739	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
58740	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
58741	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
58742	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
58743	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
58744	11/22/2019 13:38	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
58745	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
58746	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations A Ø	0	
58747	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations B Ø	0	
58748	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations C Ø	0	
58749	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations Ground	0	
58750	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Follow-up Action Required?	n	
58751	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Follow-up Action Required?	n	
58752	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Foundation Condition	Good	
58753	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	General Comments		
58754	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	General Comments		
58755	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Grounds in Place?	y	
58756	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Maintenance Operations	0	
58757	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Moisture and Leak Free?	y	
58758	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AF	143	
58759	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AL	143	
58760	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations This Read Vac	0	
58761	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Switching Operations	0	
58762	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Tank Paint Condition	Good	
58763	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
58764	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58765	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
58766	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58767	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1508	
58768	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
58769	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
58770	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
58771	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
58772	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
58773	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58774	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58775	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58776	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	3	
58777	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Months Operations	0	
58778	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
58779	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
58780	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
58781	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
58782	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
58783	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
58784	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58785	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
58786	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
58787	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58788	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
58789	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
58790	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
58791	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
58792	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
58793	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58794	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
58795	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
58796	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58797	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
58798	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
58799	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
58800	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
58801	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58802	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations C Ø	0	
58803	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations B Ø	0	
58804	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations A Ø	0	
58805	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
58806	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
58807	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
58808	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
58809	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
58810	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
58811	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
58812	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps C Ø	95.0	
58813	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps B Ø	90.0	
58814	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps A Ø	95.0	
58815	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
58816	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
58817	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
58818	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations	3	
58819	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
58820	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
58821	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
58822	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
58823	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
58824	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Reading	.5022	
58825	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Foundation Condition	Good	
58826	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	General Comments		
58827	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	General Comments		
58828	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Grounds in Place?	y	
58829	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Maintenance Operations	0	
58830	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Moisture and Leak Free?	y	
58831	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AF	166	
58832	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AL	166	
58833	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations This Read Vac	0	
58834	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
58835	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
58836	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
58837	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
58838	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
58839	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
58840	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
58841	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	VRR Time Delay	30	Seconds
58842	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
58843	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
58844	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
58845	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	LTC Operation Checked?	y	
58846	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	General Comments		
58847	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	Follow-up Action Required?	n	
58848	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	LTC0000657	LTCControl	722-1	LTC Control Insp	All Connections OK?	y	
58849	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
58850	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
58851	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58852	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
58853	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
58854	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58855	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
58856	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
58857	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
58858	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
58859	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
58860	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
58861	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58862	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Follow-up Action Required?	n	
58863	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
58864	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58865	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
58866	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
58867	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
58868	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	11942.06	kw
58869	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
58870	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
58871	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
58872	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
58873	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
58874	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
58875	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
58876	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
58877	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
58878	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
58879	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
58880	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
58881	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
58882	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
58883	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
58884	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
58885	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
58886	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
58887	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
58888	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
58889	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
58890	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
58891	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
58892	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
58893	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	0	
58894	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
58895	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Unknown Operations	0	
58896	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Switching Operations	0	
58897	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
58898	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AL	51	
58899	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
58900	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
58901	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
58902	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
58903	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
58904	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Left Counter	95863	
58905	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Found Counter	95863	
58906	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
58907	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	General Comments		
58908	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
58909	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
58910	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
58911	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
58912	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
58913	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
58914	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
58915	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
58916	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
58917	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
58918	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
58919	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
58920	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
58921	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	3	
58922	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	0	
58923	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	3	
58924	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	525	
58925	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	9 Months Operations	0	
58926	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58927	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58928	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58929	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps A Ø	0.0	
58930	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps B Ø	0.0	
58931	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58932	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
58933	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	735	
58934	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4R	
58935	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
58936	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	84572	
58937	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	84572	
58938	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	tap changer filter at 45 psi, need to change filter	
58939	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
58940	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
58941	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
58942	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps C Ø	0.0	
58943	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58944	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58945	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58946	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58947	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations A Ø	0	
58948	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations B Ø	0	
58949	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations C Ø	0	
58950	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations Ground	0	
58951	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
58952	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Follow-up Action Required?	n	
58953	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	General Comments		
58954	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	General Comments		
58955	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Maintenance Operations	0	
58956	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AF	356	
58957	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AL	356	
58958	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations This Read AM	0	
58959	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Switching Operations	0	
58960	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
58961	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Unknown Operations	0	
58962	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	525	
58963	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
58964	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
58965	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	312	
58966	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	312	
58967	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations This Read AM	0	
58968	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
58969	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
58970	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
58971	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
58972	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
58973	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
58974	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
58975	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1	
58976	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1	
58977	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
58978	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Brk is open and Danger Card is applied	
58979	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
58980	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
58981	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
58982	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
58983	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
58984	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
58985	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
58986	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
58987	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
58988	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
58989	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
58990	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
58991	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
58992	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
58993	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
58994	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
58995	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
58996	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
58997	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
58998	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
58999	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
59000	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	1332	
59001	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
59002	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	13L	
59003	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	2L	
59004	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	6L	
59005	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
59006	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	159191	
59007	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	159191	
59008	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
59009	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments		
59010	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
59011	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
59012	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
59013	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
59014	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	General Comments	brk is open	
59015	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
59016	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	125	
59017	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	125	
59018	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
59019	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
59020	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
59021	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Switching Operations	0	
59022	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps C Ø	0.0	
59023	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps B Ø	0.0	
59024	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps A Ø	0.0	
59025	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59026	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59027	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59028	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Months Operations	0	
59029	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations This Read AM	0	
59030	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
59031	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
59032	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
59033	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
59034	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
59035	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
59036	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
59037	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
59038	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59039	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
59040	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
59041	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
59042	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
59043	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
59044	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
59045	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
59046	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Unknown Operations	0	
59047	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	General Comments		
59048	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
59049	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59050	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
59051	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
59052	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59053	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
59054	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
59055	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59056	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
59057	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
59058	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
59059	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59060	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Months Operations	5	
59061	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59062	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
59063	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
59064	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
59065	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59066	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59067	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø	0.0	
59068	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø Max	1.7	
59069	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
59070	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59071	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59072	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
59073	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø	0.0	
59074	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø Max	1.7	
59075	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø	0.0	
59076	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø Max	1.7	
59077	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59078	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59079	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59080	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59081	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations A Ø	0	
59082	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations B Ø	0	
59083	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations C Ø	0	
59084	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations Ground	0	
59085	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
59086	11/22/2019 11:11	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
59087	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
59088	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
59089	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59090	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59091	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59092	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
59093	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
59094	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
59095	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
59096	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
59097	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
59098	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps A Ø	490.0	
59099	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps B Ø	520.0	
59100	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps C Ø	500.0	
59101	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59102	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
59103	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
59104	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
59105	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
59106	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
59107	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59108	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
59109	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
59110	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
59111	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations A Ø	0	
59112	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations B Ø	0	
59113	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations C Ø	0	
59114	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations Ground	0	
59115	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Follow-up Action Required?	n	
59116	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Follow-up Action Required?	n	
59117	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	354	
59118	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	354	
59119	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
59120	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
59121	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
59122	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
59123	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
59124	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
59125	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
59126	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
59127	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
59128	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	28.64	
59129	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	28.64	
59130	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	28.64	
59131	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59132	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59133	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59134	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps C Ø	0.0	
59135	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps B Ø	0.0	
59136	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps A Ø	0.0	
59137	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59138	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59139	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59140	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	100.0	
59141	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	150.0	
59142	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	150.0	
59143	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	100.0	
59144	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	100.0	
59145	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	150.0	
59146	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
59147	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
59148	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59149	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
59150	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
59151	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59152	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	General Comments		
59153	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	General Comments		
59154	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
59155	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
59156	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
59157	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
59158	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
59159	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
59160	11/22/2019 14:59	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
59161	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AL	361	
59162	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AF	361	
59163	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Maintenance Operations	0	
59164	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	General Comments		
59165	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	General Comments		
59166	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Follow-up Action Required?	n	
59167	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
59168	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations Ground	0	
59169	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations C Ø	0	
59170	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations B Ø	0	
59171	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations A Ø	0	
59172	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59173	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59174	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Unknown Operations	0	
59175	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
59176	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59177	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
59178	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
59179	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	95480	
59180	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	95480	
59181	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
59182	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
59183	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
59184	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
59185	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
59186	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1302	
59187	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
59188	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
59189	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
59190	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Switching Operations	0	
59191	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations This Read Vac	0	
59192	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
59193	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
59194	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
59195	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
59196	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
59197	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
59198	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
59199	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
59200	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments		
59201	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
59202	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
59203	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	3	
59204	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
59205	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	3	
59206	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	9 Month Operations	1	
59207	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
59208	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
59209	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AL	118	
59210	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AF	118	
59211	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Maintenance Operations	0	
59212	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
59213	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
59214	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
59215	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
59216	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
59217	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59218	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
59219	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
59220	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
59221	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
59222	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
59223	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
59224	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	General Comments		
59225	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	General Comments		
59226	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Follow-up Action Required?	n	
59227	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
59228	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
59229	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
59230	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
59231	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
59232	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
59233	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
59234	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
59235	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
59236	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59237	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59238	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
59239	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Leaks	None	
59240	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
59241	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Regulator As Left Counter	84696	
59242	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
59243	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
59244	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
59245	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
59246	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
59247	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
59248	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
59249	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
59250	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	General Comments		
59251	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59252	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
59253	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
59254	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
59255	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
59256	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
59257	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
59258	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
59259	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
59260	11/22/2019 12:39	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
59261	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
59262	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
59263	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Months Operations	0	
59264	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59265	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59266	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59267	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps A Ø	60.0	
59268	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps B Ø	50.0	
59269	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps C Ø	55.0	
59270	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59271	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59272	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59273	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59274	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations A Ø	0	
59275	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations B Ø	0	
59276	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations C Ø	0	
59277	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations Ground	0	
59278	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
59279	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Follow-up Action Required?	n	
59280	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	General Comments		
59281	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	General Comments		
59282	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Maintenance Operations	0	
59283	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AF	546	
59284	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AL	546	
59285	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations This Read AM	0	
59286	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Switching Operations	0	
59287	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
59288	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
59289	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
59290	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Unknown Operations	0	
59291	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
59292	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
59293	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	2	
59294	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
59295	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
59296	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
59297	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
59298	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.7836	
59299	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	58	°C
59300	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	30	°C
59301	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Grounds in Place?	y	
59302	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	General Comments		
59303	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	General Comments		
59304	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Foundation Condition	Good	
59305	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Follow-up Action Required?	n	
59306	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Follow-up Action Required?	n	
59307	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations Ground	0	
59308	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations C Ø	0	
59309	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations B Ø	0	
59310	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations A Ø	0	
59311	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59312	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59313	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59314	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
59315	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
59316	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
59317	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59318	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
59319	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
59320	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
59321	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
59322	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
59323	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
59324	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
59325	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	200.0	
59326	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59327	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Present	30	*C
59328	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Max	60	*C
59329	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
59330	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
59331	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	LTC Totalizer Reading	3615.84	kw
59332	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
59333	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	General Comments		
59334	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	General Comments		
59335	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59336	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
59337	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Follow-up Action Required?	n	
59338	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59339	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
59340	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
59341	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
59342	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
59343	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	799	
59344	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
59345	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
59346	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
59347	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
59348	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Left Counter	10618	
59349	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Found Counter	10618	
59350	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
59351	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59352	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
59353	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
59354	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
59355	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
59356	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
59357	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
59358	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59359	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
59360	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
59361	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59362	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
59363	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59364	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59365	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
59366	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
59367	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
59368	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
59369	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
59370	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
59371	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
59372	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
59373	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
59374	11/22/2019 10:41	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	General Comments		
59375	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59376	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps C Ø	166.0	
59377	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps B Ø	144.0	
59378	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps A Ø	175.0	
59379	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
59380	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Unknown Operations	0	
59381	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Switching Operations	0	
59382	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations This Read AM	0	
59383	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AL	498	
59384	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AF	498	
59385	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Maintenance Operations	0	
59386	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	General Comments		
59387	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	General Comments		
59388	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Follow-up Action Required?	n	
59389	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
59390	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations Ground	0	
59391	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations C Ø	0	
59392	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations B Ø	0	
59393	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations A Ø	0	
59394	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59395	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59396	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59397	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59398	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps C Ø	0.0	
59399	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps B Ø	0.0	
59400	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps A Ø	0.0	
59401	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59402	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59403	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59404	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Months Operations	0	
59405	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
59406	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
59407	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations	1	
59408	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
59409	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1124	
59410	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1124	
59411	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	3	
59412	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	1	
59413	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	2	
59414	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
59415	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
59416	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
59417	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
59418	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
59419	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
59420	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
59421	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
59422	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
59423	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
59424	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	General Comments		
59425	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
59426	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59427	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
59428	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
59429	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59430	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
59431	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
59432	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59433	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
59434	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
59435	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59436	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
59437	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59438	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	250.0	
59439	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	71.0	
59440	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	215.0	
59441	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	61.0	
59442	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	171.0	
59443	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	72.0	
59444	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59445	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59446	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59447	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	3	
59448	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59449	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
59450	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
59451	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
59452	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
59453	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
59454	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	General Comments		
59455	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
59456	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	31.200	millivolts
59457	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
59458	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
59459	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
59460	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
59461	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
59462	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
59463	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	797	
59464	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
59465	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
59466	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	16L	
59467	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
59468	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Left Counter	10744	
59469	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Found Counter	10744	
59470	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
59471	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	General Comments		
59472	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
59473	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
59474	11/22/2019 9:04	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
59475	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	5	
59476	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59477	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59478	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59479	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	50.0	
59480	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	50.0	
59481	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	30.0	
59482	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	30.0	
59483	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	50.0	
59484	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	50.0	
59485	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59486	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
59487	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	19.09	
59488	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	19.09	
59489	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
59490	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
59491	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
59492	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
59493	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
59494	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
59495	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
59496	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.4	amps
59497	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
59498	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
59499	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
59500	11/22/2019 13:42	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
59501	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
59502	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Unknown Operations	0	
59503	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Switching Operations	1	
59504	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Unknown Operations	0	
59505	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Switching Operations	0	
59506	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Unknown Operations	0	
59507	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Switching Operations	0	
59508	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations This Read Vac	1	
59509	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AL	140	
59510	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AF	140	
59511	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Maintenance Operations	0	
59512	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	General Comments		
59513	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	General Comments		
59514	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Follow-up Action Required?	n	
59515	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
59516	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations Ground	0	
59517	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations C Ø	0	
59518	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations B Ø	0	
59519	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations A Ø	0	
59520	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
59521	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
59522	11/22/2019 12:57	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
59523	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
59524	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
59525	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
59526	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
59527	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
59528	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
59529	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	28.64	
59530	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59531	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
59532	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
59533	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
59534	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
59535	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	29	°C
59536	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
59537	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
59538	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	28.64	
59539	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations This Read Vac	0	
59540	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AL	61	
59541	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
59542	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
59543	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	main tank oil level is low. Needs oil. Nitrogen bottle needs to be filled.	
59544	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
59545	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations	2	
59546	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
59547	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
59548	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
59549	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps A Ø	221.0	
59550	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps B Ø	225.0	
59551	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps C Ø	220.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59552	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59553	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
59554	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AF	61	
59555	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
59556	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
59557	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
59558	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
59559	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
59560	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
59561	11/22/2019 14:44	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	28.64	
59562	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	57	*C
59563	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
59564	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
59565	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Maintenance Operations	0	
59566	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	General Comments		
59567	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
59568	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
59569	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	General Comments		
59570	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Maintenance Operations	0	
59571	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AF	51	
59572	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59573	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
59574	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59575	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59576	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
59577	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
59578	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
59579	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
59580	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
59581	11/22/2019 13:52	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
59582	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
59583	11/22/2019 11:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
59584	11/22/2019 15:16	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
59585	11/22/2019 10:45	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
59586	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
59587	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59588	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59589	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59590	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
59591	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
59592	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
59593	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
59594	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99788	
59595	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
59596	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
59597	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99788	
59598	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	98.0	
59599	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59600	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59601	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59602	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59603	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59604	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59605	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59606	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59607	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59608	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59609	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59610	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
59611	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
59612	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59613	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
59614	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
59615	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	General Comments	no fence fabric. tree from U of L maintenance building growing through fence. Fence post extensions are cracked almost through ent	
59616	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
59617	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
59618	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	General Comments	no fence fabric, trees overhanging fence	
59619	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
59620	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
59621	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
59622	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
59623	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
59624	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
59625	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
59626	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD0000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59627	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
59628	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
59629	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
59630	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
59631	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
59632	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
59633	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
59634	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
59635	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
59636	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
59637	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
59638	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59639	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59640	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59641	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	99.0	
59642	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	96.0	
59643	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
59644	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	?	
59645	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
59646	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
59647	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
59648	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
59649	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
59650	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
59651	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59652	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
59653	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Vegetation	None	
59654	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
59655	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
59656	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	General Comments	Door alarms are not functioning	
59657	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
59658	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
59659	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Swept?	y	
59660	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
59661	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
59662	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
59663	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
59664	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
59665	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
59666	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
59667	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
59668	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
59669	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
59670	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
59671	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
59672	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
59673	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
59674	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
59675	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
59676	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59677	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59678	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59679	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59680	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
59681	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	General Comments	There is no spill kit at this station	
59682	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
59683	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
59684	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
59685	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
59686	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
59687	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
59688	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
59689	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
59690	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
59691	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
59692	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
59693	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
59694	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
59695	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59696	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59697	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
59698	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
59699	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
59700	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
59701	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59702	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
59703	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
59704	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
59705	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
59706	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59707	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
59708	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panels Dusted?	n	
59709	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
59710	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
59711	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
59712	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
59713	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
59714	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
59715	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
59716	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
59717	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
59718	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
59719	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	General Comments		
59720	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
59721	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
59722	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Swept?	y	
59723	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
59724	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
59725	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
59726	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
59727	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
59728	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
59729	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
59730	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
59731	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
59732	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
59733	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
59734	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
59735	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
59736	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	General Comments		
59737	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
59738	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59739	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
59740	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
59741	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
59742	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
59743	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
59744	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
59745	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
59746	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	General Comments		
59747	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
59748	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Found Counter	4066	
59749	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Left Counter	4066	
59750	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
59751	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
59752	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59753	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
59754	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
59755	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
59756	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
59757	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
59758	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
59759	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
59760	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Broom on Site?	y	
59761	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
59762	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
59763	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
59764	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
59765	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
59766	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
59767	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Broom on Site?	y	
59768	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
59769	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
59770	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
59771	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
59772	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
59773	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
59774	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
59775	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
59776	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
59777	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
59778	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59779	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
59780	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
59781	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
59782	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
59783	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
59784	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
59785	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
59786	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
59787	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
59788	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
59789	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
59790	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
59791	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
59792	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
59793	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
59794	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTC000491	LTCControl	DE-TRANS 1	LTC Control Insp	General Comments		
59795	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
59796	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
59797	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
59798	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
59799	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
59800	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
59801	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
59802	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
59803	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
59804	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
59805	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
59806	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
59807	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
59808	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
59809	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
59810	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
59811	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
59812	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
59813	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
59814	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
59815	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
59816	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
59817	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
59818	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
59819	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
59820	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
59821	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
59822	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
59823	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
59824	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	General Comments		
59825	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
59826	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
59827	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
59828	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	*C
59829	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	*C
59830	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
59831	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
59832	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59833	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99974	
59834	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99974	
59835	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
59836	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
59837	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
59838	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
59839	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
59840	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
59841	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
59842	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	733	
59843	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
59844	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59845	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	681	
59846	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	681	
59847	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
59848	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
59849	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59850	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
59851	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59852	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59853	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
59854	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
59855	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59856	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59857	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59858	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59859	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59860	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59861	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
59862	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
59863	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
59864	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
59865	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
59866	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
59867	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
59868	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
59869	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.9	amps
59870	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
59871	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
59872	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	General Comments		
59873	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
59874	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
59875	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
59876	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
59877	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
59878	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
59879	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
59880	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
59881	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
59882	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
59883	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
59884	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	572	
59885	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	572	
59886	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
59887	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
59888	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59889	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59890	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59891	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59892	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59893	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59894	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59895	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59896	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59897	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59898	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59899	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59900	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59901	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59902	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59903	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59904	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59905	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59906	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59907	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
59908	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
59909	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
59910	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	703	
59911	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	703	
59912	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59913	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59914	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59915	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
59916	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59917	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59918	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59919	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	185.0	
59920	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	180.0	
59921	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	182.0	
59922	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59923	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
59924	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
59925	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
59926	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
59927	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
59928	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
59929	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
59930	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
59931	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
59932	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
59933	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
59934	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
59935	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
59936	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
59937	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
59938	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
59939	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
59940	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
59941	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
59942	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59943	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
59944	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59945	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59946	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59947	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	28.0	
59948	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	29.0	
59949	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	29.0	
59950	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59951	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59952	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59953	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59954	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59955	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59956	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59957	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59958	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59959	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
59960	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59961	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59962	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59963	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59964	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
59965	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
59966	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59967	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59968	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
59969	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
59970	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
59971	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
59972	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	733	
59973	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
59974	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	44	
59975	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
59976	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
59977	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
59978	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
59979	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
59980	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
59981	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
59982	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	94.0	
59983	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	98.0	
59984	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	97.0	
59985	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
59986	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
59987	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
59988	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
59989	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
59990	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Trash Emptied?	n	
59991	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
59992	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
59993	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
59994	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
59995	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
59996	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
59997	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
59998	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
59999	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
60000	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60001	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
60002	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
60003	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
60004	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60005	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60006	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60007	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60008	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	71.0	
60009	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	74.0	
60010	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	73.0	
60011	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
60012	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60013	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60014	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60015	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
60016	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60017	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	705.0	
60018	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	640.0	
60019	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	658.0	
60020	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60021	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60022	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60023	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60024	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60025	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
60026	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
60027	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	n	
60028	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
60029	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
60030	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
60031	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
60032	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
60033	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
60034	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
60035	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
60036	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	General Comments	TR1 B phase whip not in place	
60037	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
60038	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60039	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60040	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
60041	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	77.0	
60042	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	82.0	
60043	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60044	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60045	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60046	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
60047	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60048	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60049	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
60050	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
60051	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
60052	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
60053	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60054	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60055	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60056	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60057	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60058	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60059	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60060	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60061	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	299	
60062	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	299	
60063	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
60064	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
60065	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
60066	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
60067	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Vegetation	None	
60068	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
60069	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
60070	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
60071	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
60072	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	General Comments	yard is cluttered, under construction	
60073	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60074	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
60075	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
60076	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	43	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60077	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	43	
60078	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
60079	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
60080	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
60081	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
60082	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
60083	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
60084	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
60085	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
60086	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	?	
60087	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
60088	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
60089	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
60090	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
60091	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	General Comments		
60092	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
60093	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
60094	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60095	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60096	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60097	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
60098	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60099	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60100	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60101	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60102	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
60103	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
60104	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
60105	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60106	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	General Comments		
60107	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
60108	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
60109	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
60110	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
60111	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
60112	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
60113	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
60114	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
60115	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
60116	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
60117	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
60118	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
60119	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60120	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60121	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60122	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60123	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60124	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60125	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
60126	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
60127	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
60128	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
60129	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
60130	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
60131	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
60132	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
60133	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
60134	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
60135	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
60136	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
60137	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
60138	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
60139	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
60140	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
60141	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	151	
60142	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	151	
60143	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60144	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60145	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
60146	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
60147	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
60148	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
60149	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
60150	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
60151	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60152	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
60153	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
60154	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
60155	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60156	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60157	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
60158	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60159	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
60160	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
60161	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
60162	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
60163	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
60164	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
60165	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	6594	
60166	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
60167	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
60168	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
60169	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
60170	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
60171	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Left Counter	403391	
60172	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Found Counter	403391	
60173	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
60174	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
60175	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	General Comments	no nitrogen pressure gauge	
60176	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
60177	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
60178	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?		
60179	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
60180	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60181	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60182	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60183	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	81.0	
60184	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	94.0	
60185	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	92.0	
60186	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60187	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60188	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60189	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60190	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60191	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60192	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60193	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60194	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60195	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60196	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60197	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60198	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60199	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	648	
60200	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	648	
60201	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
60202	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60203	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
60204	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
60205	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60206	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60207	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60208	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
60209	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	139.0	
60210	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	128.0	
60211	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60212	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60213	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60214	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60215	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60216	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60217	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
60218	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60219	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60220	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60221	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60222	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60223	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60224	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60225	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60226	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	15	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60227	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	15	
60228	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
60229	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	5	
60230	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60231	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
60232	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
60233	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60234	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60235	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60236	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60237	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60238	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60239	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60240	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60241	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60242	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60243	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60244	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60245	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60246	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7	
60247	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7	
60248	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
60249	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
60250	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60251	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
60252	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
60253	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
60254	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
60255	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
60256	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
60257	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
60258	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
60259	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
60260	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
60261	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
60262	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
60263	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
60264	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
60265	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
60266	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
60267	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
60268	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
60269	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60270	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
60271	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
60272	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
60273	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
60274	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	General Comments		
60275	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
60276	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
60277	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
60278	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60279	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60280	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60281	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60282	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60283	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60284	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60285	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60286	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60287	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60288	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60289	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	31.0	
60290	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	29.0	
60291	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	364	
60292	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	364	
60293	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
60294	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60295	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60296	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
60297	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	31.0	
60298	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60299	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60300	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
60301	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60302	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
60303	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
60304	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
60305	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	?	
60306	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
60307	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	?	
60308	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60309	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
60310	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
60311	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
60312	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
60313	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60314	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
60315	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
60316	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
60317	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
60318	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
60319	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
60320	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60321	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60322	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60323	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60324	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60325	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60326	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60327	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60328	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
60329	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
60330	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.32	%
60331	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.99	%
60332	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
60333	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
60334	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
60335	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
60336	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
60337	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
60338	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
60339	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60340	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
60341	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
60342	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
60343	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60344	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60345	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60346	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	417.0	
60347	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	423.0	
60348	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
60349	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	No nitrogen	
60350	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
60351	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	49.0	VDC
60352	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	49.0	VDC
60353	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
60354	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
60355	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	substation is out	
60356	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	General Comments		
60357	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
60358	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
60359	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
60360	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
60361	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
60362	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
60363	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
60364	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
60365	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60366	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
60367	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
60368	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
60369	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
60370	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	415.0	
60371	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60372	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
60373	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
60374	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	General Comments		
60375	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
60376	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
60377	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
60378	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
60379	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
60380	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
60381	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60382	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
60383	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
60384	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
60385	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
60386	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
60387	11/21/2019 13:36	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
60388	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
60389	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60390	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60391	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60392	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	359.0	
60393	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	282.0	
60394	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	302.0	
60395	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60396	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60397	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60398	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60399	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60400	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60401	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
60402	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60403	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	gone	
60404	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LTC0000284	LTCControl	FL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
60405	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LTC0000284	LTCControl	FL-TRANS 1	LTC Control Insp	General Comments		
60406	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60407	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60408	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
60409	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
60410	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
60411	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LTC0000284	LTCControl	FL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
60412	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60413	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
60414	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
60415	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
60416	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
60417	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
60418	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
60419	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
60420	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
60421	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
60422	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
60423	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	12	
60424	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	12	
60425	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
60426	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
60427	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
60428	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
60429	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
60430	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
60431	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
60432	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
60433	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
60434	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
60435	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
60436	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
60437	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	92.50	
60438	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
60439	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60440	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60441	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
60442	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
60443	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
60444	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
60445	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
60446	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
60447	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60448	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
60449	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
60450	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
60451	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60452	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
60453	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
60454	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
60455	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
60456	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
60457	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60458	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
60459	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
60460	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
60461	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
60462	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
60463	11/25/2019 16:52	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
60464	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
60465	11/21/2019 10:46	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
60466	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
60467	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
60468	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
60469	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60470	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
60471	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
60472	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
60473	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
60474	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	10371	
60475	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60476	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
60477	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
60478	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
60479	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
60480	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
60481	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
60482	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
60483	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
60484	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
60485	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
60486	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Tank Paint Condition	Good	
60487	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Switching Operations	0	
60488	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
60489	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations This Read Vac	0	
60490	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AL	154	
60491	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AF	154	
60492	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
60493	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
60494	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
60495	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60496	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
60497	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
60498	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
60499	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
60500	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
60501	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
60502	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
60503	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
60504	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
60505	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	271.0	
60506	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	295.0	
60507	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60508	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
60509	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
60510	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
60511	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
60512	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
60513	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
60514	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
60515	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
60516	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments	NA	
60517	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60518	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
60519	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
60520	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	97786	
60521	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60522	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
60523	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
60524	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
60525	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
60526	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60527	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
60528	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
60529	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
60530	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
60531	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
60532	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
60533	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
60534	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
60535	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
60536	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
60537	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60538	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
60539	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	NA	
60540	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Unknown Operations	0	
60541	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	283.0	
60542	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
60543	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	487	
60544	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
60545	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
60546	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
60547	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
60548	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
60549	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	General Comments		
60550	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
60551	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
60552	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
60553	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60554	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60555	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
60556	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
60557	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
60558	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	General Comments		
60559	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
60560	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
60561	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Leaks	None	
60562	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60563	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Regulator As Left Counter	36584	
60564	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
60565	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
60566	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
60567	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60568	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60569	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
60570	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
60571	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
60572	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	General Comments		
60573	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
60574	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
60575	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
60576	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
60577	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
60578	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
60579	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
60580	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
60581	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
60582	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
60583	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
60584	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Vegetation	None	
60585	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
60586	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
60587	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
60588	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
60589	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
60590	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
60591	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
60592	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
60593	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
60594	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
60595	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
60596	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
60597	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
60598	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
60599	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60600	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60601	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60602	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
60603	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
60604	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
60605	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
60606	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
60607	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
60608	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
60609	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
60610	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
60611	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
60612	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
60613	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
60614	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
60615	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
60616	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
60617	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60618	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60619	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
60620	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
60621	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
60622	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	0	
60623	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	0	
60624	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
60625	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
60626	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
60627	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
60628	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	240.0	
60629	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	220.0	
60630	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	220.0	
60631	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
60632	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
60633	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
60634	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
60635	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
60636	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Trash?	y	
60637	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
60638	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
60639	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
60640	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
60641	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
60642	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
60643	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
60644	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
60645	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60646	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60647	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
60648	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	1652	
60649	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60650	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
60651	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
60652	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60653	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
60654	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
60655	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
60656	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
60657	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46885	
60658	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60659	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Leaks	None	
60660	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
60661	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
60662	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
60663	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
60664	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
60665	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
60666	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
60667	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
60668	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
60669	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
60670	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
60671	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
60672	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
60673	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
60674	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
60675	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
60676	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60677	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	3	
60678	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
60679	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	3	
60680	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	487	
60681	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
60682	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
60683	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
60684	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
60685	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
60686	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
60687	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	0	
60688	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
60689	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
60690	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
60691	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
60692	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
60693	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
60694	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
60695	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
60696	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
60697	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
60698	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
60699	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
60700	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
60701	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
60702	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
60703	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	General Comments		
60704	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
60705	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
60706	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations	0	
60707	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
60708	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Regulator As Left Counter	40497	
60709	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
60710	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Leaks	None	
60711	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
60712	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
60713	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
60714	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
60715	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
60716	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
60717	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
60718	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
60719	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
60720	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
60721	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
60722	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	General Comments		
60723	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
60724	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
60725	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
60726	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
60727	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
60728	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
60729	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
60730	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
60731	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
60732	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Reading	8832.0000	
60733	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Max	63	°C
60734	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Present	40	°C
60735	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
60736	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
60737	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
60738	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
60739	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
60740	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	1336.32	kw
60741	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
60742	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
60743	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	50	°C
60744	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	50	°C
60745	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-02-14 00:00:00.000000	
60746	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	0	
60747	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	334	
60748	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	334	
60749	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations	2	
60750	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
60751	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
60752	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
60753	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps A Ø	66.0	
60754	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	0	
60755	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
60756	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
60757	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
60758	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
60759	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
60760	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
60761	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
60762	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
60763	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
60764	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
60765	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
60766	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
60767	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
60768	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
60769	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
60770	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
60771	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
60772	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
60773	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
60774	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
60775	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
60776	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
60777	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
60778	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
60779	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
60780	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
60781	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations	0	
60782	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
60783	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
60784	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
60785	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Follow-up Action Required?	n	
60786	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
60787	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
60788	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	General Comments		
60789	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	General Comments		
60790	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
60791	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	LTC Totalizer Reading	158976000.00	kw
60792	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
60793	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
60794	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
60795	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
60796	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
60797	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
60798	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
60799	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
60800	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
60801	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
60802	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	220	
60803	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	220	
60804	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	0	
60805	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
60806	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	0	
60807	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
60808	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
60809	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
60810	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
60811	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
60812	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
60813	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
60814	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
60815	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	0	
60816	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
60817	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
60818	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
60819	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.1392	
60820	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
60821	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
60822	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
60823	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
60824	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
60825	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
60826	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60827	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60828	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
60829	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Max	62	°C
60830	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Present	37	°C
60831	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60832	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
60833	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
60834	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
60835	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
60836	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
60837	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushing Condition	Good	
60838	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
60839	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
60840	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
60841	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
60842	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
60843	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60844	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
60845	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
60846	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
60847	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
60848	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
60849	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
60850	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
60851	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
60852	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
60853	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
60854	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
60855	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	70	°C
60856	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	45	°C
60857	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
60858	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
60859	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
60860	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
60861	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
60862	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
60863	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
60864	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
60865	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
60866	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
60867	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
60868	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	85	°C
60869	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	50	°C
60870	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	78	°C
60871	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	44	°C
60872	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	75	°C
60873	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	55	°C
60874	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Maintenance Operations	0	
60875	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
60876	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Grounds in Place?	y	
60877	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	General Comments		
60878	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	General Comments		
60879	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Foundation Condition	Good	
60880	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Follow-up Action Required?	n	
60881	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Follow-up Action Required?	n	
60882	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations Ground	0	
60883	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations C Ø	0	
60884	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations B Ø	0	
60885	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations A Ø	0	
60886	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
60887	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
60888	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
60889	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
60890	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
60891	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
60892	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
60893	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps A Ø	0.0	
60894	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps B Ø	0.0	
60895	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps C Ø	0.0	
60896	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
60897	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
60898	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
60899	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
60900	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations A Ø	0	
60901	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60902	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
60903	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
60904	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
60905	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
60906	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
60907	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations B Ø	0	
60908	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations C Ø	0	
60909	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
60910	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
60911	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
60912	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
60913	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
60914	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
60915	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
60916	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Unknown Operations	0	
60917	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Tank Paint Condition	Good	
60918	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Switching Operations	0	
60919	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations Ground	0	
60920	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
60921	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Follow-up Action Required?	n	
60922	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	General Comments	NA	
60923	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	General Comments	NA	
60924	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Maintenance Operations	0	
60925	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AF	210	
60926	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AL	210	
60927	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations This Read Vac	0	
60928	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Switching Operations	0	
60929	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Unknown Operations	0	
60930	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
60931	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
60932	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
60933	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60934	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
60935	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
60936	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
60937	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
60938	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
60939	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations This Read Vac	0	
60940	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AL	163	
60941	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AF	163	
60942	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Moisture and Leak Free?	y	
60943	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps B Ø	107.0	
60944	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps C Ø	76.0	
60945	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
60946	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
60947	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
60948	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
60949	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
60950	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
60951	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
60952	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
60953	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushing Condition	Good	
60954	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps C Ø	274.0	
60955	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps B Ø	331.0	
60956	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
60957	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
60958	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
60959	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
60960	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
60961	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
60962	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
60963	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
60964	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
60965	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
60966	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
60967	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
60968	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
60969	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
60970	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
60971	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0508	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	6	
60972	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
60973	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
60974	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
60975	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
60976	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
60977	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
60978	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
60979	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
60980	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
60981	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
60982	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
60983	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
60984	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
60985	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
60986	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
60987	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
60988	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
60989	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
60990	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
60991	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		
60992	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
60993	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
60994	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
60995	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
60996	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
60997	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
60998	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
60999	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
61000	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61001	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
61002	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	6	
61003	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	6	
61004	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
61005	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
61006	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
61007	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
61008	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
61009	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
61010	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
61011	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
61012	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
61013	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
61014	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
61015	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
61016	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61017	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Maintenance Operations	0	
61018	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61019	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Grounds in Place?	y	
61020	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	General Comments		
61021	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	General Comments		
61022	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Foundation Condition	Good	
61023	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Follow-up Action Required?	n	
61024	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Follow-up Action Required?	n	
61025	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations Ground	0	
61026	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations C Ø	0	
61027	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations B Ø	0	
61028	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations A Ø	0	
61029	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61030	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61031	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61032	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61033	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61034	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61035	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61036	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
61037	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
61038	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
61039	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
61040	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
61041	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
61042	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
61043	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
61044	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
61045	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61046	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61047	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61048	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61049	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61050	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61051	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61052	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61053	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
61054	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
61055	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
61056	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
61057	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
61058	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
61059	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
61060	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
61061	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
61062	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
61063	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
61064	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
61065	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
61066	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
61067	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
61068	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
61069	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
61070	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
61071	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
61072	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
61073	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
61074	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
61075	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps A Ø	272.0	
61076	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61077	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61078	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61079	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations	1	
61080	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
61081	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
61082	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
61083	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
61084	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
61085	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
61086	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
61087	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
61088	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
61089	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
61090	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
61091	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
61092	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
61093	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
61094	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
61095	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
61096	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61097	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
61098	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments	NA	
61099	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
61100	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
61101	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
61102	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
61103	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
61104	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
61105	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
61106	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
61107	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
61108	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
61109	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
61110	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
61111	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
61112	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
61113	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
61114	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
61115	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
61116	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
61117	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
61118	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
61119	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
61120	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
61121	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
61122	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
61123	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
61124	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
61125	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	All Connections OK?	y	
61126	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61127	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	General Comments		
61128	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	LTC Operation Checked?	y	
61129	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
61130	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
61131	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
61132	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCCControl	429-1	LTC Control Insp	VRR Time Delay	30	Seconds
61133	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
61134	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
61135	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
61136	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
61137	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
61138	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	4	
61139	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61140	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61141	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61142	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
61143	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
61144	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
61145	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
61146	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61147	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61148	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61149	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61150	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61151	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61152	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61153	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61154	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61155	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
61156	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
61157	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
61158	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
61159	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
61160	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
61161	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
61162	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
61163	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
61164	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
61165	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
61166	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
61167	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps B Ø	181.0	
61168	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps C Ø	153.0	
61169	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushing Condition	Good	
61170	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	0	
61171	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61172	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61173	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61174	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61175	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61176	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000040	LTCCControl	IN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
61177	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000040	LTCCControl	IN-TRANS 1	LTC Control Insp	General Comments	NA	
61178	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000040	LTCCControl	IN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
61179	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000039	LTCCControl	IN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
61180	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000039	LTCCControl	IN-TRANS 2	LTC Control Insp	General Comments	na	
61181	11/20/2019 14:18	Distribution	International Quarterly Inspection	LTCC000039	LTCCControl	IN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
61182	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
61183	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61184	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
61185	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
61186	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	345	
61187	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	345	
61188	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
61189	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61190	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
61191	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
61192	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
61193	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61194	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	663.0	
61195	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
61196	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
61197	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
61198	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
61199	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	700	
61200	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
61201	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61202	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
61203	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	660.0	
61204	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	642.0	
61205	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61206	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61207	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61208	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61209	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
61210	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
61211	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
61212	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
61213	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	2R	
61214	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	1R	
61215	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
61216	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	30621	
61217	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61218	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations This Read Vac	4	
61219	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AL	170	
61220	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AF	179	
61221	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Moisture and Leak Free?	y	
61222	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Maintenance Operations	2	
61223	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61224	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Grounds in Place?	y	
61225	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	General Comments		
61226	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	General Comments		
61227	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Foundation Condition	Good	
61228	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Follow-up Action Required?	n	
61229	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Follow-up Action Required?	n	
61230	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations Ground	0	
61231	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
61232	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	723	
61233	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
61234	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations C Ø	1	
61235	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
61236	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
61237	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
61238	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations B Ø	0	
61239	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations A Ø	0	
61240	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps C Phase V	4.07	
61241	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61242	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61243	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61244	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61245	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
61246	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61247	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61248	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61249	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	463.0	
61250	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	409.0	
61251	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	437.0	
61252	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
61253	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61254	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61255	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61256	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61257	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61258	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
61259	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
61260	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
61261	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61262	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61263	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61264	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61265	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
61266	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations	2	
61267	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61268	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61269	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61270	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps A Ø	161.0	
61271	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
61272	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
61273	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
61274	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
61275	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
61276	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61277	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
61278	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Foundation Condition	Good	
61279	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
61280	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	General Comments	na	
61281	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
61282	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
61283	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
61284	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
61285	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
61286	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
61287	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
61288	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
61289	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
61290	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
61291	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
61292	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
61293	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61294	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61295	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61296	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	138.0	
61297	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	136.0	
61298	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	141.0	
61299	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations B Ø	0	
61300	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations C Ø	0	
61301	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations Ground	0	
61302	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Follow-up Action Required?	n	
61303	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Follow-up Action Required?	n	
61304	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Foundation Condition	Good	
61305	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	General Comments		
61306	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	General Comments		
61307	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Grounds in Place?	y	
61308	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61309	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Maintenance Operations	0	
61310	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Moisture and Leak Free?	y	
61311	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AF	233	
61312	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AL	233	
61313	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations This Read Vac	0	
61314	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61315	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Switching Operations	0	
61316	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Tank Paint Condition	Good	
61317	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Unknown Operations	0	
61318	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
61319	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
61320	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
61321	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
61322	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	902	
61323	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	902	
61324	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
61325	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
61326	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
61327	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
61328	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	All Connections OK?	y	
61329	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	30261	
61330	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
61331	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
61332	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
61333	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
61334	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
61335	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments	NA	
61336	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	NA	
61337	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
61338	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	130	
61339	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	130	
61340	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
61341	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0517	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
61342	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61343	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61344	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
61345	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
61346	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61347	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61348	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61349	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61350	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations A Ø	0	
61351	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61352	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
61353	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
61354	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
61355	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
61356	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
61357	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
61358	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
61359	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
61360	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
61361	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
61362	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
61363	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
61364	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	General Comments	na	
61365	11/20/2019 14:18	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
61366	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
61367	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
61368	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
61369	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
61370	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
61371	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
61372	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
61373	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
61374	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
61375	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
61376	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	General Comments	na	
61377	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
61378	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
61379	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
61380	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
61381	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Vegetation	None	
61382	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
61383	11/20/2019 14:18	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
61384	11/20/2019 14:18	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
61385	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
61386	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
61387	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
61388	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
61389	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	120	
61390	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
61391	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
61392	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
61393	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Follow-up Action Required?	n	
61394	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
61395	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	General Comments		
61396	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	General Comments		
61397	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Found Counter	99130	
61398	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Left Counter	99134	
61399	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
61400	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
61401	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
61402	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
61403	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
61404	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
61405	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
61406	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
61407	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
61408	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Current Tap Position	5L	
61409	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
61410	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
61411	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
61412	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Max Tap Position	1L	
61413	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Min Tap Position	8L	
61414	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	33	*C
61415	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	*C
61416	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Operations Since Last Insp	1218	
61417	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
61418	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
61419	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
61420	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
61421	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Unknown Operations	0	
61422	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Switching Operations	0	
61423	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations This Read Vac	0	
61424	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AL	0	
61425	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AF	154	
61426	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
61427	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	General Comments	NA	
61428	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	General Comments	NA	
61429	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
61430	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Reading	.6560	
61431	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
61432	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
61433	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
61434	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
61435	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
61436	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
61437	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
61438	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
61439	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Present	33	°C
61440	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Max	55	°C
61441	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	3	
61442	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
61443	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61444	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.49	
61445	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61446	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61447	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	2R	
61448	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	4R	
61449	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
61450	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
61451	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	9568	
61452	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	9568	
61453	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
61454	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
61455	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
61456	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
61457	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
61458	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
61459	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	100	
61460	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	100	
61461	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
61462	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, Switch gear and TR are out of service	
61463	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
61464	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
61465	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
61466	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
61467	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
61468	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
61469	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
61470	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61471	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
61472	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61473	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61474	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61475	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
61476	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
61477	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61478	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
61479	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
61480	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
61481	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
61482	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61483	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61484	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61485	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
61486	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
61487	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
61488	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
61489	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
61490	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
61491	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
61492	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
61493	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	138	
61494	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	138	
61495	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	11	
61496	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61497	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
61498	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
61499	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
61500	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
61501	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen, TR is out of service, Oil is seeping from a radiator to the left of the CCC	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
61502	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments	TR is out of service	
61503	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
61504	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
61505	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
61506	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
61507	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
61508	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
61509	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
61510	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
61511	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
61512	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
61513	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
61514	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
61515	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
61516	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
61517	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
61518	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Unknown Operations	0	
61519	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Tank Paint Condition	Good	
61520	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
61521	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
61522	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
61523	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
61524	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
61525	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
61526	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
61527	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
61528	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	na	
61529	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
61530	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
61531	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
61532	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
61533	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
61534	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
61535	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
61536	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
61537	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
61538	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
61539	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
61540	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
61541	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
61542	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
61543	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
61544	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
61545	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
61546	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	270536	
61547	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	270536	
61548	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
61549	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
61550	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4R	
61551	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	9L	
61552	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Switching Operations	1	
61553	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
61554	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
61555	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	LTC Totalizer Reading	3148.80	kw
61556	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
61557	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Follow-up Action Required?	n	
61558	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
61559	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations Ground	0	
61560	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations C Ø	0	
61561	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations B Ø	0	
61562	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations A Ø	0	
61563	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61564	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61565	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61566	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61567	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps C Ø	90.0	
61568	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps B Ø	85.0	
61569	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps A Ø	85.0	
61570	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61571	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61572	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	General Comments		
61573	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	General Comments		
61574	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
61575	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
61576	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
61577	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Follow-up Action Required?	n	
61578	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
61579	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
61580	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61581	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations	0	
61582	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	10	°C
61583	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	80	°C
61584	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	15	°C
61585	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	80	°C
61586	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
61587	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
61588	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
61589	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
61590	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
61591	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
61592	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
61593	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
61594	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
61595	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
61596	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
61597	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
61598	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
61599	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
61600	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
61601	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
61602	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
61603	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
61604	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
61605	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
61606	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
61607	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	10	°C
61608	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	°C
61609	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
61610	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
61611	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	
61612	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
61613	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
61614	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
61615	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61616	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61617	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61618	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
61619	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
61620	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
61621	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
61622	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
61623	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
61624	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
61625	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61626	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61627	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61628	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
61629	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Foundation Condition	Good	
61630	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	General Comments	ok	
61631	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Grounds in Place?	y	
61632	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61633	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
61634	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
61635	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
61636	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
61637	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61638	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
61639	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
61640	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	General Comments		
61641	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	General Comments		
61642	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
61643	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
61644	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
61645	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6808.32	kw
61646	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
61647	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
61648	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Max	59	°C
61649	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
61650	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
61651	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
61652	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
61653	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
61654	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
61655	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
61656	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AF	171	
61657	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
61658	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
61659	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
61660	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
61661	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
61662	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Maintenance Operations	0	
61663	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61664	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Grounds in Place?	y	
61665	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	General Comments		
61666	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
61667	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
61668	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
61669	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	133.0	VDC
61670	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
61671	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
61672	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
61673	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
61674	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
61675	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
61676	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61677	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61678	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61679	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61680	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushing Condition	Good	
61681	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps C Ø	14.0	
61682	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps B Ø	28.0	
61683	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps A Ø	23.0	
61684	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61685	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61686	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61687	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations	8	
61688	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
61689	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	General Comments		
61690	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Negative DC Ground	62.0	VDC
61691	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.0	VDC
61692	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
61693	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
61694	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
61695	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
61696	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
61697	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
61698	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
61699	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
61700	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
61701	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
61702	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
61703	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushing Condition	Good	
61704	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61705	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61706	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61707	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61708	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61709	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61710	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
61711	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Foundation Condition	Good	
61712	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	General Comments	na	
61713	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Grounds in Place?	y	
61714	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61715	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
61716	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61717	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
61718	11/20/2019 14:18	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushing Condition	Good	
61719	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
61720	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	LTC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
61721	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	49	
61722	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	49	
61723	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
61724	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
61725	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
61726	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61727	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
61728	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
61729	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
61730	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
61731	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
61732	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
61733	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
61734	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
61735	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
61736	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
61737	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
61738	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
61739	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
61740	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
61741	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
61742	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
61743	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
61744	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
61745	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	63	
61746	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	63	
61747	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
61748	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, Breaker is off	
61749	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
61750	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
61751	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
61752	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
61753	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
61754	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
61755	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
61756	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
61757	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
61758	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
61759	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
61760	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
61761	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
61762	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	General Comments		
61763	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
61764	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Vegetation	None	
61765	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
61766	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
61767	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
61768	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
61769	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
61770	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
61771	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
61772	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Foundation Condition	Good	
61773	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
61774	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
61775	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	General Comments		
61776	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
61777	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	General Comments		
61778	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	General Comments		
61779	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Foundation Condition	Good	
61780	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Follow-up Action Required?	n	
61781	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Follow-up Action Required?	n	
61782	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations Ground	0	
61783	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations C Ø	0	
61784	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations B Ø	0	
61785	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations A Ø	0	
61786	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61787	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61788	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61789	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61790	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61791	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61792	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61793	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61794	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61795	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushing Condition	Good	
61796	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps C Ø	331.0	
61797	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
61798	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
61799	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
61800	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Reading	1,4184	
61801	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps B Ø	355.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61802	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps A Ø	332.0	
61803	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	0	
61804	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
61805	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations This Read AM	0	
61806	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	541	
61807	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	541	
61808	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	
61809	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments		
61810	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
61811	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
61812	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
61813	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	4	
61814	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
61815	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
61816	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
61817	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
61818	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
61819	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
61820	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
61821	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
61822	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
61823	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
61824	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
61825	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
61826	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
61827	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
61828	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
61829	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
61830	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
61831	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments	Breaker is off	
61832	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
61833	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61834	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
61835	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
61836	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
61837	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
61838	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
61839	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
61840	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
61841	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
61842	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
61843	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
61844	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
61845	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
61846	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61847	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
61848	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
61849	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	225	
61850	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	225	
61851	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
61852	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
61853	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
61854	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
61855	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
61856	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
61857	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
61858	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
61859	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	100.0	
61860	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	20.0	
61861	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	20.0	
61862	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
61863	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
61864	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
61865	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
61866	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
61867	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
61868	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
61869	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Foundation Condition	Good	
61870	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
61871	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
61872	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	General Comments		
61873	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
61874	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
61875	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
61876	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61877	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	170	
61878	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	170	
61879	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
61880	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments	Breaker is off	
61881	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
61882	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
61883	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
61884	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
61885	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
61886	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
61887	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
61888	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
61889	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations	2	
61890	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61891	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61892	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61893	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps A Ø	126.0	
61894	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps B Ø	126.0	
61895	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps C Ø	126.0	
61896	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushing Condition	Good	
61897	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61898	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61899	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61900	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61901	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61902	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61903	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61904	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61905	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
61906	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations A Ø	0	
61907	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations B Ø	0	
61908	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations C Ø	0	
61909	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations Ground	0	
61910	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Follow-up Action Required?	n	
61911	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Follow-up Action Required?	n	
61912	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Foundation Condition	Good	
61913	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	General Comments		
61914	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	General Comments		
61915	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Grounds in Place?	y	
61916	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
61917	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Maintenance Operations	0	
61918	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Moisture and Leak Free?	y	
61919	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AF	228	
61920	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AL	228	
61921	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations This Read Vac	0	
61922	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
61923	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Switching Operations	0	
61924	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Tank Paint Condition	Good	
61925	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Unknown Operations	0	
61926	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	Follow-up Action Required?	n	
61927	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	General Comments		
61928	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	LTC Operation Checked?	y	
61929	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
61930	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
61931	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
61932	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
61933	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000586	LTCControl	833-1	LTC Control Insp	VRR Time Delay	30	Seconds
61934	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
61935	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
61936	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
61937	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61938	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61939	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61940	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61941	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61942	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61943	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61944	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61945	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
61946	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
61947	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
61948	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
61949	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
61950	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
61951	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
61952	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
61953	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
61954	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
61955	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
61956	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Switching Operations	0	
61957	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations This Read Vac	3	
61958	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AL	262	
61959	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AF	262	
61960	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
61961	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Moisture and Leak Free?	y	
61962	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Maintenance Operations	0	
61963	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Grounds in Place?	y	
61964	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	General Comments		
61965	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	General Comments		
61966	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Foundation Condition	Good	
61967	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Follow-up Action Required?	n	
61968	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Follow-up Action Required?	n	
61969	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations Ground	0	
61970	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations C Ø	3	
61971	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations B Ø	0	
61972	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations A Ø	0	
61973	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps C Phase V	12.22	
61974	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
61975	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
61976	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
61977	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
61978	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
61979	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
61980	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
61981	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
61982	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushing Condition	Good	
61983	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps C Ø	96.0	
61984	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps B Ø	87.0	
61985	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps A Ø	86.0	
61986	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
61987	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
61988	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
61989	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	9 Month Operations	6	
61990	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Unknown Operations	0	
61991	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Tank Paint Condition	Good	
61992	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Switching Operations	0	
61993	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations This Read Vac	0	
61994	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AL	171	
61995	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
61996	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
61997	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
61998	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
61999	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
62000	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
62001	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
62002	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
62003	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
62004	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
62005	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
62006	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
62007	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
62008	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
62009	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
62010	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	8	
62011	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62012	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
62013	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
62014	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
62015	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Unknown Operations	0	
62016	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Tank Paint Condition	Good	
62017	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
62018	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
62019	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
62020	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
62021	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
62022	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
62023	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
62024	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
62025	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
62026	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62027	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
62028	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
62029	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
62030	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Trash?	y	
62031	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
62032	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
62033	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
62034	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
62035	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
62036	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
62037	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
62038	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
62039	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
62040	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
62041	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
62042	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
62043	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	General Comments		
62044	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
62045	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
62046	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Foundation Condition	Good	
62047	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
62048	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
62049	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
62050	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
62051	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
62052	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
62053	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
62054	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	General Comments		
62055	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
62056	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
62057	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	186.0	
62058	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62059	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62060	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	*C
62061	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	*C
62062	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	*C
62063	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	*C
62064	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
62065	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
62066	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62067	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62068	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
62069	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62070	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62071	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62072	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62073	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	*C
62074	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	*C
62075	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62076	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	30	
62077	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
62078	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
62079	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
62080	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62081	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
62082	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
62083	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
62084	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
62085	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
62086	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
62087	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
62088	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
62089	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
62090	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
62091	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
62092	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
62093	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
62094	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
62095	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
62096	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
62097	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps B Ø	55.0	
62098	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps C Ø	44.0	
62099	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushing Condition	Good	
62100	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62101	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62102	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	137	
62103	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	137	
62104	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
62105	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
62106	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
62107	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
62108	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
62109	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
62110	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
62111	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
62112	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	NA	
62113	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments	NA	
62114	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
62115	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
62116	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62117	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62118	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
62119	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
62120	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	597	
62121	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	*C
62122	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	*C
62123	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
62124	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
62125	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
62126	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
62127	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Left Counter	48273	
62128	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Found Counter	48273	
62129	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	NA	
62130	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	General Comments	na	
62131	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
62132	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
62133	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	30	
62134	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
62135	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	30	
62136	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	0	
62137	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	54	
62138	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
62139	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	NA	
62140	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments	NA	
62141	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
62142	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62143	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62144	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
62145	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
62146	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62147	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
62148	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62149	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62150	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62151	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
62152	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
62153	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
62154	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
62155	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
62156	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
62157	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
62158	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
62159	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
62160	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
62161	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	335.41	
62162	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	335.41	
62163	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	335.41	
62164	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62165	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	179.0	
62166	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0507	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	181.0	
62167	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
62168	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
62169	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	General Comments		
62170	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
62171	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62172	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62173	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62174	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	360.0	
62175	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	365.0	
62176	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	360.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62177	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
62178	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62179	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
62180	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62181	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62182	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62183	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62184	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62185	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62186	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62187	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
62188	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
62189	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
62190	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
62191	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
62192	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
62193	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
62194	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
62195	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
62196	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
62197	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
62198	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
62199	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
62200	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
62201	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
62202	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
62203	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62204	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
62205	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
62206	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
62207	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
62208	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62209	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62210	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62211	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
62212	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
62213	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
62214	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
62215	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62216	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62217	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62218	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
62219	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
62220	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62221	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
62222	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
62223	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
62224	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
62225	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
62226	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
62227	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
62228	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	3	
62229	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
62230	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
62231	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
62232	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BCH001134	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
62233	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
62234	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
62235	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
62236	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
62237	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
62238	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
62239	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62240	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62241	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62242	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62243	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62244	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62245	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62246	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62247	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62248	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62249	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62250	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62251	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62252	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations B Ø	0	
62253	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations C Ø	0	
62254	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations Ground	0	
62255	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Follow-up Action Required?	n	
62256	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62257	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62258	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
62259	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Operations Since Last Insp	1058	
62260	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Min Tap Position	8L	
62261	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Max Tap Position	6R	
62262	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Current Tap Position	2L	
62263	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Follow-up Action Required?	n	
62264	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Foundation Condition	Good	
62265	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	General Comments		
62266	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	General Comments		
62267	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Grounds in Place?	y	
62268	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
62269	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62270	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
62271	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62272	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
62273	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
62274	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
62275	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
62276	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
62277	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	General Comments		
62278	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Foundation Condition	Good	
62279	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62280	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
62281	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
62282	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	35	°C
62283	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	30	°C
62284	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62285	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62286	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62287	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62288	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
62289	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62290	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62291	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
62292	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.9820	
62293	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	50	°C
62294	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	40	°C
62295	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
62296	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
62297	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Follow-up Action Required?	n	
62298	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Follow-up Action Required?	n	
62299	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations Ground	0	
62300	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations C Ø	0	
62301	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations B Ø	0	
62302	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations A Ø	0	
62303	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62304	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62305	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
62306	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62307	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62308	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62309	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62310	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62311	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62312	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
62313	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62314	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushing Condition	Good	
62315	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps C Ø	218.0	
62316	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps B Ø	218.0	
62317	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps A Ø	218.0	
62318	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62319	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62320	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62321	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations	2	
62322	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
62323	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Trash?	y	
62324	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
62325	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
62326	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62327	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
62328	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
62329	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
62330	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	General Comments		
62331	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
62332	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62333	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62334	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	28	°C
62335	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	47	°C
62336	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
62337	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
62338	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
62339	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
62340	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
62341	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
62342	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.100	millivolts
62343	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
62344	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
62345	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
62346	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
62347	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
62348	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62349	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62350	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	14016.00	kw
62351	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
62352	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
62353	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
62354	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62355	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
62356	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	
62357	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
62358	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
62359	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
62360	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
62361	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
62362	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments	LTC Desiccant is bad needs replaced	
62363	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
62364	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
62365	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
62366	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
62367	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
62368	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
62369	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Present	40	°C
62370	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Max	60	°C
62371	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Reading	.4884	
62372	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
62373	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
62374	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	74684	
62375	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	74684	
62376	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
62377	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5L	
62378	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	861	
62379	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	0	
62380	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	5R	
62381	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	11L	
62382	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	881	
62383	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
62384	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
62385	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Grounds in Place?	y	
62386	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	General Comments		
62387	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
62388	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62389	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
62390	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations	0	
62391	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62392	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62393	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62394	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps A Ø	45.0	
62395	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
62396	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
62397	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
62398	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Present	40	°C
62399	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Max	55	°C
62400	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Reading	.1336	
62401	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
62402	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62403	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62404	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
62405	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62406	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62407	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62408	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62409	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62410	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
62411	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62412	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
62413	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
62414	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62415	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
62416	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
62417	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62418	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62419	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62420	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62421	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62422	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62423	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
62424	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
62425	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Poor	
62426	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
62427	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
62428	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
62429	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
62430	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	n	If no, which cells in comments
62431	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	BAT000177	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
62432	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
62433	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
62434	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	700	
62435	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
62436	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
62437	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
62438	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
62439	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
62440	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Left Counter	57822	
62441	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Found Counter	57822	
62442	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
62443	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Vegetation	None	
62444	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
62445	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62446	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62447	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62448	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	*C
62449	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	*C
62450	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Unknown Operations	0	
62451	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Switching Operations	0	
62452	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations This Read Vac	0	
62453	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AL	158	
62454	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AF	158	
62455	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Maintenance Operations	0	
62456	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	General Comments	NA	
62457	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	General Comments	NA	
62458	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Follow-up Action Required?	n	
62459	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
62460	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations Ground	0	
62461	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations C Ø	0	
62462	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations B Ø	0	
62463	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations A Ø	0	
62464	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62465	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62466	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62467	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62468	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps C Ø	0.0	
62469	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps B Ø	0.0	
62470	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps A Ø	0.0	
62471	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62472	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62473	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62474	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations	0	
62475	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
62476	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
62477	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
62478	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
62479	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	0	
62480	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	0	
62481	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
62482	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
62483	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
62484	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
62485	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
62486	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
62487	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
62488	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
62489	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
62490	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62491	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62492	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
62493	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
62494	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62495	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
62496	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62497	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
62498	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
62499	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
62500	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
62501	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
62502	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
62503	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
62504	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	4	
62505	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62506	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62507	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62508	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	150.0	
62509	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	150.0	
62510	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	150.0	
62511	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
62512	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62513	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62514	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
62515	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
62516	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62517	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
62518	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62519	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62520	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
62521	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62522	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
62523	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
62524	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
62525	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
62526	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
62527	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
62528	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
62529	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
62530	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
62531	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
62532	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
62533	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
62534	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
62535	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
62536	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
62537	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
62538	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
62539	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
62540	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
62541	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
62542	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
62543	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
62544	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
62545	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
62546	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
62547	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
62548	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
62549	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
62550	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	y	
62551	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
62552	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62553	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62554	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62555	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62556	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
62557	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
62558	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
62559	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62560	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
62561	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
62562	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62563	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
62564	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62565	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62566	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62567	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62568	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62569	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62570	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
62571	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
62572	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	22	*C
62573	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	47	*C
62574	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	22	*C
62575	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	47	*C
62576	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
62577	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
62578	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
62579	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
62580	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
62581	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
62582	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
62583	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
62584	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
62585	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
62586	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
62587	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
62588	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
62589	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
62590	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
62591	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
62592	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	3922	
62593	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	3922	
62594	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
62595	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
62596	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	1R	
62597	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
62598	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
62599	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	9	
62600	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
62601	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62602	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62603	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
62604	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
62605	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
62606	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
62607	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
62608	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
62609	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
62610	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
62611	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
62612	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
62613	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
62614	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
62615	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
62616	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
62617	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
62618	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
62619	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
62620	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
62621	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
62622	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
62623	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
62624	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
62625	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
62626	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62627	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
62628	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	*C
62629	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
62630	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
62631	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
62632	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
62633	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
62634	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
62635	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
62636	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	259	
62637	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	259	
62638	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	0	
62639	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62640	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	0	
62641	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
62642	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
62643	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
62644	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
62645	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Present	32	*C
62646	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62647	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62648	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	47	*C
62649	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WLTIC Bushing Dynamic Health	0.00	
62650	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
62651	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62652	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62653	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
62654	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62655	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62656	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62657	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62658	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Present	22	*C
62659	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	*C
62660	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
62661	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
62662	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
62663	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
62664	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
62665	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
62666	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
62667	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments	Main heater is not working in Switchgear	
62668	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
62669	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62670	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62671	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62672	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62673	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62674	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
62675	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
62676	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62677	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62678	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62679	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62680	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62681	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62682	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62683	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
62684	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
62685	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62686	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Follow-up Action Required?	n	
62687	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
62688	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62689	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	General Comments		
62690	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	General Comments		
62691	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
62692	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	LTC Totalizer Reading	8791.20	kw
62693	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62694	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
62695	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Max	0	*C
62696	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
62697	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
62698	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
62699	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
62700	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62701	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
62702	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
62703	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
62704	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
62705	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
62706	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
62707	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
62708	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
62709	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
62710	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
62711	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
62712	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
62713	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
62714	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
62715	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
62716	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	40	*F
62717	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62718	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
62719	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62720	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
62721	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
62722	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
62723	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
62724	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
62725	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	n	
62726	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
62727	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
62728	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
62729	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
62730	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
62731	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
62732	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	y	
62733	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
62734	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments	Replaced 2 4ft bulbs still didn't work, Switch gear is under construction	
62735	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
62736	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
62737	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
62738	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
62739	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
62740	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
62741	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
62742	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
62743	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	All Connections OK?	y	
62744	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	Follow-up Action Required?	n	
62745	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	General Comments		
62746	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	LTC Operation Checked?	y	
62747	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
62748	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
62749	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
62750	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
62751	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	VRR Time Delay	30	Seconds
62752	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
62753	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
62754	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
62755	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62756	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	356	
62757	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	356	
62758	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
62759	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, breaker is off	
62760	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
62761	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
62762	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	45	*F
62763	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
62764	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
62765	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62766	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
62767	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
62768	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
62769	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
62770	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
62771	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	165	
62772	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
62773	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62774	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NA	
62775	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	General Comments	NA	
62776	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62777	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Maintenance Operations	0	
62778	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
62779	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
62780	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
62781	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
62782	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	100.0	
62783	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Moisture and Leak Free?	y	
62784	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AF	253	
62785	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AL	253	
62786	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations This Read Vac	0	
62787	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62788	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Switching Operations	0	
62789	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Tank Paint Condition	Good	
62790	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Unknown Operations	0	
62791	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
62792	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Left Counter	15224	
62793	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Found Counter	15212	
62794	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
62795	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
62796	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
62797	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
62798	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
62799	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
62800	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
62801	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62802	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
62803	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
62804	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
62805	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
62806	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
62807	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
62808	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	General Comments		
62809	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	General Comments		
62810	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
62811	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Follow-up Action Required?	n	
62812	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
62813	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
62814	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62815	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Present	35	°C
62816	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Max	55	°C
62817	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
62818	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
62819	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62820	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	LTC Totalizer Reading	1923.84	kw
62821	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
62822	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	General Comments		
62823	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	General Comments		
62824	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62825	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
62826	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Follow-up Action Required?	n	
62827	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
62828	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62829	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
62830	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
62831	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62832	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62833	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
62834	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	80.0	
62835	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	50.0	
62836	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
62837	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
62838	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
62839	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	4	
62840	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62841	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	40	°C
62842	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
62843	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
62844	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
62845	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
62846	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
62847	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
62848	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62849	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	9185.28	
62850	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	kw
62851	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
62852	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
62853	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
62854	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
62855	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62856	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62857	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
62858	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62859	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
62860	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
62861	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62862	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
62863	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
62864	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62865	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62866	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62867	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62868	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
62869	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
62870	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
62871	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
62872	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
62873	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
62874	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
62875	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62876	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62877	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62878	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
62879	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62880	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62881	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62882	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
62883	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
62884	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
62885	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
62886	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
62887	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
62888	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
62889	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
62890	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
62891	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
62892	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
62893	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
62894	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
62895	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
62896	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62897	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
62898	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
62899	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
62900	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62901	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
62902	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
62903	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2917.76	kw
62904	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
62905	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
62906	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
62907	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
62908	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
62909	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
62910	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
62911	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
62912	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
62913	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62914	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
62915	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
62916	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
62917	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9118	
62918	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
62919	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
62920	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
62921	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
62922	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
62923	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	General Comments	Oil temp and x1 winding gauges do not look right , or drag hands are not working	
62924	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	NA	
62925	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
62926	11/20/2019 14:18	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
62927	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
62928	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
62929	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.9568	
62930	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
62931	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
62932	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
62933	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
62934	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
62935	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
62936	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
62937	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Maintenance Operations	0	
62938	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Moisture and Leak Free?	y	
62939	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	179	
62940	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	179	
62941	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations This Read Vac	1	
62942	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
62943	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	1	
62944	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
62945	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
62946	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
62947	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
62948	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
62949	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
62950	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
62951	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
62952	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
62953	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
62954	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
62955	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
62956	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
62957	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	y	
62958	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
62959	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
62960	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
62961	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
62962	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
62963	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
62964	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
62965	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
62966	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	1	
62967	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
62968	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
62969	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
62970	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
62971	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
62972	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
62973	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
62974	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
62975	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
62976	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
62977	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
62978	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
62979	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
62980	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
62981	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
62982	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
62983	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
62984	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
62985	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
62986	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
62987	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
62988	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
62989	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
62990	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
62991	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
62992	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
62993	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
62994	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
62995	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
62996	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
62997	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
62998	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
62999	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63000	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
63001	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Operations Since Last Insp	979	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63002	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	57	°C
63003	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
63004	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Min Tap Position	8L	
63005	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
63006	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	0	
63007	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
63008	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	0	
63009	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1578	
63010	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1578	
63011	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
63012	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
63013	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63014	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
63015	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
63016	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
63017	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
63018	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
63019	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
63020	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
63021	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
63022	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
63023	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
63024	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Max Tap Position	1L	
63025	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Current Tap Position	5L	
63026	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Follow-up Action Required?	n	
63027	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Follow-up Action Required?	n	
63028	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Foundation Condition	Good	
63029	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	General Comments		
63030	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	General Comments		
63031	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Grounds in Place?	y	
63032	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63033	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Left Counter	44692	
63034	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Found Counter	44688	
63035	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	General Comments		
63036	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	General Comments		
63037	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
63038	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Follow-up Action Required?	n	
63039	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations	1	
63040	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63041	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63042	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63043	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps A Ø	0.0	
63044	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps B Ø	0.0	
63045	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps C Ø	0.0	
63046	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
63047	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63048	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63049	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63050	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
63051	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments		
63052	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63053	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	General Comments		
63054	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63055	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63056	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63057	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63058	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	VRR Time Delay	30	Seconds
63059	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Maintenance Operations	0	
63060	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
63061	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AF	180	
63062	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AL	180	
63063	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations This Read Vac	0	
63064	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Switching Operations	0	
63065	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
63066	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Unknown Operations	0	
63067	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AL	1234.0	VAC
63068	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
63069	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
63070	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	LTC Operation Checked?	y	
63071	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	General Comments		
63072	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	Follow-up Action Required?	n	
63073	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
63074	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
63075	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
63076	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	15	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63077	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63078	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63079	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63080	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	1.0	
63081	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	1.0	
63082	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	1.0	
63083	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63084	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	167.71	
63085	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	167.71	
63086	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	167.71	
63087	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
63088	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
63089	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
63090	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
63091	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
63092	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
63093	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments	NA	
63094	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	NA	
63095	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
63096	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	99974	
63097	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	99974	
63098	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	15	
63099	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
63100	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0509	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	15	
63101	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
63102	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Found Counter	3712	
63103	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	3716	
63104	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63105	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000342	LTCControl	WT-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
63106	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000342	LTCControl	WT-TRANS 5	LTC Control Insp	General Comments		
63107	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000342	LTCControl	WT-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
63108	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
63109	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
63110	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LTC0000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
63111	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	283.0	
63112	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	255.0	
63113	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	246.0	
63114	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
63115	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63116	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63117	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63118	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63119	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
63120	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
63121	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63122	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63123	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63124	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63125	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	
63126	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
63127	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
63128	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
63129	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
63130	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
63131	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	General Comments		
63132	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
63133	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
63134	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		
63135	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
63136	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
63137	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63138	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
63139	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
63140	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	179	
63141	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	179	
63142	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations This Read Vac	0	
63143	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
63144	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
63145	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
63146	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
63147	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63148	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63149	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63150	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63151	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63152	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations B Ø	0	
63153	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations C Ø	0	
63154	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations Ground	0	
63155	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
63156	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Follow-up Action Required?	n	
63157	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
63158	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	General Comments		
63159	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	General Comments		
63160	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
63161	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63162	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
63163	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
63164	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
63165	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
63166	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
63167	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
63168	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
63169	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
63170	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 2	86	psi
63171	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 3	86	psi
63172	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
63173	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Switching Operations	0	
63174	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Tank Paint Condition	Good	
63175	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	3	
63176	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63177	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63178	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63179	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	100.0	
63180	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	82.0	
63181	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	71.0	
63182	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
63183	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63184	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
63185	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
63186	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Trash?	y	
63187	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
63188	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
63189	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	362	
63190	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
63191	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
63192	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
63193	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
63194	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
63195	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
63196	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
63197	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
63198	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
63199	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
63200	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
63201	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
63202	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Broom on Site?	n	
63203	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
63204	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
63205	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
63206	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	620.0	
63207	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	560.0	
63208	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	540.0	
63209	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
63210	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
63211	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
63212	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	7	
63213	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
63214	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63215	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63216	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63217	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
63218	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63219	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63220	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63221	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63222	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	0	
63223	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	0	
63224	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
63225	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
63226	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63227	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
63228	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
63229	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
63230	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	362	
63231	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
63232	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
63233	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
63234	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Ambient Temperature	45	*F
63235	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
63236	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
63237	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63238	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
63239	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
63240	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Fault Operations	0	
63241	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
63242	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Follow-up Action Required?	n	
63243	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Foundation Condition	Good	
63244	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
63245	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	General Comments		
63246	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
63247	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	General Comments		
63248	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
63249	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
63250	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Swept?	n	
63251	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
63252	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
63253	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Evidence of Insects	None	
63254	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
63255	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
63256	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
63257	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
63258	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
63259	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
63260	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
63261	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
63262	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	LTC Operation Checked?	y	
63263	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	General Comments		
63264	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
63265	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTC0000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
63266	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
63267	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
63268	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Grounds in Place?	y	
63269	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Hydraulic Pump Start Cnt Delta	2	
63270	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
63271	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Vegetation	None	
63272	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
63273	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
63274	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	General Comments		
63275	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
63276	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
63277	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
63278	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Hydraulic Pump Start Counter	45	starts
63279	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Maintenance Operations	0	
63280	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
63281	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	1	
63282	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AF	17	
63283	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AL	17	
63284	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations This Read SF6	0	
63285	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
63286	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 1	86	psi
63287	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
63288	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	General Comments		
63289	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
63290	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
63291	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
63292	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
63293	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63294	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63295	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63296	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations A Ø	0	
63297	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations B Ø	0	
63298	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations C Ø	0	
63299	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations Ground	0	
63300	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	General Comments		
63301	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Found Counter	35800	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63302	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Left Counter	35804	
63303	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63304	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Current Tap Position	12L	
63305	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Max Tap Position	6L	
63306	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Min Tap Position	15L	
63307	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
63308	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
63309	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
63310	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
63311	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
63312	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
63313	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
63314	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
63315	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
63316	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
63317	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
63318	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
63319	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
63320	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
63321	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
63322	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
63323	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
63324	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	*C
63325	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	*C
63326	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Operations Since Last Insp	1141	
63327	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
63328	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63329	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
63330	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
63331	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
63332	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	2	
63333	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
63334	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
63335	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
63336	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
63337	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	
63338	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
63339	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
63340	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
63341	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
63342	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
63343	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
63344	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
63345	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
63346	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
63347	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Follow-up Action Required?	n	
63348	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Foundation Condition	Good	
63349	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	General Comments		
63350	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	General Comments		
63351	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Grounds in Place?	y	
63352	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63353	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Maintenance Operations	0	
63354	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
63355	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	General Comments		
63356	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
63357	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Moisture and Leak Free?	y	
63358	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AF	184	
63359	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AL	184	
63360	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations This Read Vac	1	
63361	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
63362	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
63363	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
63364	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
63365	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
63366	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
63367	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
63368	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
63369	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
63370	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
63371	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Switching Operations	1	
63372	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Tank Paint Condition	Good	
63373	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Unknown Operations	0	
63374	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations	2	
63375	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63376	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63377	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63378	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps A Ø	182.0	
63379	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps B Ø	163.0	
63380	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps C Ø	175.0	
63381	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushing Condition	Good	
63382	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63383	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63384	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63385	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63386	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
63387	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63388	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
63389	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
63390	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
63391	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
63392	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
63393	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
63394	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
63395	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
63396	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	General Comments		
63397	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments		
63398	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
63399	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
63400	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, Breaker is off	
63401	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
63402	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	2	
63403	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Follow-up Action Required?	n	
63404	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Evidence of Insects	None	
63405	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
63406	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
63407	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Swept?	y	
63408	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
63409	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
63410	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	General Comments		
63411	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
63412	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Trash Emptied?	n	
63413	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
63414	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
63415	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63416	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63417	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps C Ø	0.0	
63418	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps B Ø	0.0	
63419	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
63420	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
63421	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps A Ø	0.0	
63422	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63423	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63424	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63425	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations	1	
63426	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
63427	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
63428	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
63429	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
63430	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
63431	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
63432	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
63433	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
63434	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
63435	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
63436	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
63437	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
63438	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
63439	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
63440	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
63441	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
63442	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
63443	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
63444	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
63445	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
63446	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
63447	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Heater not working	
63448	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
63449	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
63450	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
63451	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63452	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
63453	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
63454	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
63455	11/20/2019 14:18	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
63456	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
63457	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
63458	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Trash Emptied?	y	
63459	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
63460	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
63461	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
63462	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
63463	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	0	
63464	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	0	
63465	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	0	
63466	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
63467	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
63468	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
63469	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
63470	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
63471	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Evidence of Insects	None	
63472	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
63473	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
63474	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
63475	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63476	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63477	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63478	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63479	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps C Ø	92.0	
63480	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps B Ø	84.0	
63481	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps A Ø	84.0	
63482	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63483	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63484	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
63485	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63486	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations	0	
63487	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	28	°C
63488	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	47	°C
63489	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	5840	
63490	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
63491	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
63492	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	2	
63493	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
63494	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
63495	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
63496	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
63497	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	290.0	
63498	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	250.0	
63499	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	290.0	
63500	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
63501	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
63502	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
63503	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
63504	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Unknown Operations	0	
63505	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Switching Operations	0	
63506	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations This Read Vac	0	
63507	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AL	151	
63508	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AF	151	
63509	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Maintenance Operations	0	
63510	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	General Comments	OPEN	
63511	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	General Comments	NA	
63512	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Follow-up Action Required?	n	
63513	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
63514	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations Ground	0	
63515	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations C Ø	0	
63516	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations B Ø	0	
63517	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63518	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
63519	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	General Comments	NA	
63520	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations A Ø	0	
63521	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63522	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63523	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
63524	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
63525	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Broom on Site?	y	
63526	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63527	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
63528	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
63529	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	334	
63530	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
63531	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Breaker is off	
63532	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
63533	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
63534	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
63535	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
63536	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
63537	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
63538	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
63539	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
63540	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
63541	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
63542	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
63543	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
63544	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
63545	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
63546	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
63547	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
63548	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
63549	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
63550	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
63551	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
63552	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
63553	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
63554	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
63555	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
63556	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
63557	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
63558	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	9977.12	kw
63559	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
63560	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
63561	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If no,note cell #'s
63562	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
63563	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
63564	11/20/2019 14:07	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	General Comments		
63565	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
63566	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
63567	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
63568	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
63569	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
63570	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
63571	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
63572	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
63573	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
63574	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
63575	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
63576	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
63577	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
63578	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
63579	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
63580	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
63581	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
63582	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
63583	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
63584	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
63585	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
63586	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
63587	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
63588	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
63589	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
63590	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
63591	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	727	
63592	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
63593	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
63594	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Unknown Operations	0	
63595	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	727	
63596	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Tank Paint Condition	Good	
63597	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Switching Operations	0	
63598	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
63599	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations This Read Vac	0	
63600	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AL	220	
63601	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63602	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments	IOC A, B and C Phase	
63603	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
63604	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AF	220	
63605	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Moisture and Leak Free?	y	
63606	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Maintenance Operations	0	
63607	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63608	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
63609	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
63610	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
63611	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
63612	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
63613	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	
63614	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
63615	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Swept?	y	
63616	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
63617	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
63618	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	General Comments		
63619	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
63620	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
63621	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panels Dusted?	y	
63622	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
63623	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
63624	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
63625	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panels Dusted?	y	
63626	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
63627	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
63628	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	General Comments	na	
63629	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
63630	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
63631	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Swept?	y	
63632	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
63633	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
63634	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Evidence of Insects	None	
63635	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
63636	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
63637	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
63638	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
63639	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Broom on Site?	y	
63640	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
63641	11/20/2019 14:18	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
63642	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
63643	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
63644	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
63645	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
63646	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
63647	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
63648	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	861	
63649	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
63650	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
63651	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
63652	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
63653	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	334	
63654	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
63655	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	9 Months Operations	0	
63656	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	
63657	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	
63658	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	
63659	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
63660	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	General Comments	NA	
63661	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
63662	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
63663	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
63664	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	
63665	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Maintenance Operations	0	
63666	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
63667	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AF	157	
63668	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
63669	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
63670	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
63671	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
63672	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
63673	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
63674	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
63675	11/20/2019 14:18	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
63676	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63677	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
63678	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
63679	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
63680	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
63681	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
63682	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
63683	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
63684	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
63685	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AL	157	
63686	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations This Read Vac	0	
63687	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
63688	11/22/2019 6:39	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
63689	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Switching Operations	0	
63690	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Unknown Operations	0	
63691	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
63692	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
63693	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
63694	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
63695	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
63696	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
63697	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
63698	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Foundation Condition	Good	
63699	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
63700	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
63701	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	General Comments		
63702	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Switching Operations	0	
63703	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
63704	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
63705	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
63706	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
63707	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
63708	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
63709	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
63710	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
63711	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
63712	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
63713	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
63714	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
63715	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	7L	
63716	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	12L	
63717	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	5L	
63718	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
63719	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
63720	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
63721	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63722	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63723	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
63724	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
63725	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63726	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	4	
63727	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
63728	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	General Comments		
63729	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
63730	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
63731	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
63732	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AF	188	
63733	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AL	188	
63734	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
63735	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
63736	11/20/2019 16:48	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
63737	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
63738	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	*C
63739	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
63740	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
63741	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
63742	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	*C
63743	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	328	
63744	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
63745	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
63746	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
63747	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
63748	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
63749	11/20/2019 9:38	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
63750	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
63751	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63752	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
63753	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
63754	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
63755	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
63756	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
63757	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
63758	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
63759	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
63760	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations Ground	0	
63761	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
63762	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
63763	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63764	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
63765	11/20/2019 12:25	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
63766	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
63767	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
63768	11/20/2019 17:07	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
63769	11/20/2019 11:20	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
63770	11/20/2019 15:02	Distribution	Meldrum Quarterly Inspection	LTC000674	LTCControl	602-1	LTC Control Insp	All Connections OK?	y	
63771	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
63772	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
63773	11/20/2019 14:18	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	General Comments	NA	
63774	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	y	
63775	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
63776	11/20/2019 16:39	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
63777	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LTC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
63778	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LTC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	General Comments		
63779	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LTC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
63780	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
63781	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
63782	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	12823	
63783	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
63784	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
63785	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
63786	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
63787	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
63788	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
63789	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
63790	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
63791	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
63792	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
63793	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
63794	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
63795	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
63796	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
63797	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
63798	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
63799	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
63800	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
63801	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
63802	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
63803	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
63804	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Regulator As Left Counter	13275	
63805	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
63806	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
63807	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
63808	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
63809	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
63810	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Leaks	None	
63811	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
63812	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
63813	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
63814	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
63815	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
63816	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
63817	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
63818	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	General Comments		
63819	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
63820	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
63821	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
63822	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
63823	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
63824	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
63825	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
63826	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTO166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Left Counter	36746	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
63827	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Found Counter	36746	
63828	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
63829	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	General Comments		
63830	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63831	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
63832	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
63833	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
63834	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
63835	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
63836	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Trash?	y	
63837	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
63838	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
63839	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63840	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	291	
63841	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
63842	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
63843	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63844	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
63845	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations	25	
63846	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Left Counter	82091	
63847	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	General Comments		
63848	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
63849	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
63850	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
63851	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
63852	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
63853	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
63854	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
63855	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Found Counter	82091	
63856	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
63857	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	General Comments		
63858	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
63859	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63860	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
63861	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Current Tap Position	4L	
63862	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Max Tap Position	5R	
63863	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Min Tap Position	8L	
63864	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
63865	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
63866	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	General Comments		
63867	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
63868	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Vegetation	None	
63869	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
63870	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
63871	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
63872	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
63873	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
63874	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
63875	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
63876	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
63877	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
63878	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
63879	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
63880	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
63881	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
63882	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
63883	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
63884	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63885	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
63886	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
63887	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	976	
63888	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
63889	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
63890	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0630	
63891	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
63892	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
63893	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
63894	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
63895	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
63896	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
63897	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
63898	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	General Comments		
63899	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
63900	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
63901	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63902	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
63903	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
63904	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
63905	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
63906	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
63907	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
63908	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	300.0	
63909	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	300.0	
63910	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
63911	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
63912	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
63913	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
63914	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
63915	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
63916	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
63917	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
63918	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Trash?	y	
63919	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
63920	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
63921	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
63922	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
63923	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushing Condition	Good	
63924	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps C Ø	150.0	
63925	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps B Ø	150.0	
63926	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps A Ø	150.0	
63927	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
63928	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	31	
63929	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
63930	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
63931	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
63932	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
63933	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
63934	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
63935	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
63936	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
63937	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
63938	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations A Ø	0	
63939	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations B Ø	0	
63940	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations C Ø	0	
63941	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations Ground	0	
63942	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
63943	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
63944	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
63945	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
63946	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1497	
63947	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1497	
63948	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
63949	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Follow-up Action Required?	n	
63950	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Follow-up Action Required?	n	
63951	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Foundation Condition	Good	
63952	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	General Comments		
63953	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	General Comments		
63954	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Grounds in Place?	y	
63955	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Heaters (All) Functioning?	y	
63956	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Maintenance Operations	0	
63957	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Moisture and Leak Free?	y	
63958	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AF	192	
63959	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AL	192	
63960	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
63961	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63962	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
63963	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations	12	
63964	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Tank Paint Condition	Good	
63965	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Switching Operations	0	
63966	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
63967	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations This Read Vac	0	
63968	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
63969	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
63970	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	38	*C
63971	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	56	*C
63972	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
63973	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
63974	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	264.60	kw
63975	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
63976	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
63977	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
63978	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
63979	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments		
63980	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments		
63981	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
63982	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
63983	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
63984	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	General Comments		
63985	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
63986	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Found Counter	9746	
63987	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Left Counter	9746	
63988	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
63989	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6R	
63990	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Max Tap Position	10R	
63991	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5R	
63992	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
63993	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
63994	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
63995	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
63996	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
63997	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
63998	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
63999	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
64000	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64001	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
64002	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
64003	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
64004	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
64005	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
64006	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
64007	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
64008	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64009	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
64010	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64011	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
64012	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64013	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps A Ø	100.0	
64014	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps B Ø	100.0	
64015	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps C Ø	100.0	
64016	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64017	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64018	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64019	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
64020	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
64021	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushing Condition	Good	
64022	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
64023	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Vegetation	None	
64024	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
64025	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	General Comments		
64026	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64027	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64028	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64029	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64030	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
64031	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
64032	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
64033	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
64034	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
64035	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
64036	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
64037	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
64038	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
64039	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
64040	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Moisture and Leak Free?	y	
64041	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Maintenance Operations	0	
64042	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64043	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Grounds in Place?	y	
64044	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	General Comments		
64045	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	General Comments		
64046	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Foundation Condition	Good	
64047	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Follow-up Action Required?	n	
64048	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
64049	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations Ground	0	
64050	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations C Ø	0	
64051	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64052	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations A Ø	0	
64053	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
64054	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
64055	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
64056	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
64057	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
64058	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
64059	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
64060	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
64061	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
64062	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
64063	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
64064	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
64065	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
64066	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
64067	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
64068	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
64069	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
64070	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
64071	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
64072	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64073	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64074	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64075	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64076	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64077	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64078	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64079	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64080	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64081	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	9 Month Operations	36	
64082	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64083	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64084	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64085	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps A Ø	300.0	
64086	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps B Ø	300.0	
64087	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps C Ø	300.0	
64088	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64089	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64090	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64091	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64092	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations A Ø	0	
64093	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations B Ø	0	
64094	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations C Ø	0	
64095	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations Ground	0	
64096	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AL	379	
64097	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations This Read AM	0	
64098	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Switching Operations	0	
64099	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Unknown Operations	0	
64100	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	General Comments		
64101	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Grounds in Place?	y	
64102	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64103	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Maintenance Operations	1	
64104	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Moisture and Leak Free?	y	
64105	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AF	121	
64106	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AL	121	
64107	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations This Read Vac	2	
64108	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64109	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Switching Operations	0	
64110	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Tank Paint Condition	Good	
64111	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Unknown Operations	1	
64112	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64113	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations This Read Vac	1	
64114	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AL	125	
64115	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AF	1125	
64116	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Moisture and Leak Free?	y	
64117	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Maintenance Operations	0	
64118	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64119	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Grounds in Place?	y	
64120	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	General Comments		
64121	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	General Comments		
64122	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Foundation Condition	Good	
64123	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Follow-up Action Required?	n	
64124	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Follow-up Action Required?	n	
64125	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations Ground	0	
64126	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64127	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations B Ø	0	
64128	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations A Ø	0	
64129	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64130	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64131	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64132	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64133	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64134	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64135	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64136	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64137	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64138	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushing Condition	Good	
64139	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps C Ø	200.0	
64140	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps B Ø	200.0	
64141	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps A Ø	200.0	
64142	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64143	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64144	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64145	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations	4	
64146	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Tank Paint Condition	Good	
64147	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Switching Operations	1	
64148	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64149	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations This Read Vac	1	
64150	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AL	126	
64151	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AF	126	
64152	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
64153	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
64154	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	General Comments		
64155	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
64156	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
64157	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
64158	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.6	VDC
64159	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	General Comments		
64160	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
64161	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
64162	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
64163	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
64164	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Max	75	°C
64165	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
64166	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
64167	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
64168	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	General Comments		
64169	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
64170	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
64171	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
64172	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
64173	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64174	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
64175	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
64176	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64177	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
64178	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
64179	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
64180	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
64181	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
64182	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64183	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64184	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
64185	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
64186	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.9	VDC
64187	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.9	VDC
64188	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
64189	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
64190	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
64191	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
64192	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
64193	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
64194	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	
64195	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
64196	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
64197	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
64198	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
64199	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
64200	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
64201	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64202	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
64203	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
64204	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
64205	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	General Comments		
64206	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
64207	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
64208	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Follow-up Action Required?	n	
64209	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Follow-up Action Required?	n	
64210	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
64211	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	75	°C
64212	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations	0	
64213	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64214	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64215	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64216	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps A Ø	0.0	
64217	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps B Ø	0.0	
64218	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps C Ø	0.0	
64219	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64220	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64221	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64222	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64223	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations A Ø	0	
64224	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations B Ø	0	
64225	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations C Ø	0	
64226	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations Ground	0	
64227	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Follow-up Action Required?	n	
64228	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Follow-up Action Required?	n	
64229	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	General Comments		
64230	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	General Comments		
64231	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Maintenance Operations	0	
64232	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AF	131	
64233	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AL	131	
64234	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations This Read Vac	0	
64235	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Switching Operations	0	
64236	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
64237	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	85	°C
64238	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
64239	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	90	°C
64240	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
64241	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
64242	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
64243	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
64244	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
64245	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
64246	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
64247	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
64248	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
64249	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
64250	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
64251	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
64252	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
64253	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
64254	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
64255	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
64256	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
64257	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
64258	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
64259	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
64260	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
64261	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
64262	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
64263	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
64264	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
64265	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64266	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Switching Operations	3	
64267	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Tank Paint Condition	Good	
64268	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Unknown Operations	2	
64269	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Switching Operations	0	
64270	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations This Read Vac	0	
64271	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AL	248	
64272	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AF	248	
64273	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Maintenance Operations	0	
64274	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	General Comments		
64275	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
64276	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64277	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
64278	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
64279	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Operations Counter	302	
64280	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
64281	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	General Comments		
64282	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
64283	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
64284	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
64285	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
64286	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
64287	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.7	
64288	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.4	
64289	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.7	
64290	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	General Comments		
64291	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Follow-up Action Required?	n	
64292	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Follow-up Action Required?	n	
64293	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations Ground	0	
64294	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations C Ø	0	
64295	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations B Ø	0	
64296	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations A Ø	0	
64297	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64298	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64299	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64300	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64301	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps C Ø	80.0	
64302	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps B Ø	80.0	
64303	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps A Ø	80.0	
64304	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64305	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64306	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64307	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations	0	
64308	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64309	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64310	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64311	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64312	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64313	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	General Comments		
64314	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Maintenance Operations	0	
64315	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AF	138	
64316	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AL	138	
64317	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations This Read Vac	0	
64318	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Switching Operations	0	
64319	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
64320	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
64321	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	General Comments		
64322	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
64323	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
64324	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
64325	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
64326	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1225	
64327	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1225	
64328	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
64329	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
64330	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
64331	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
64332	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
64333	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
64334	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
64335	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
64336	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64337	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64338	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64339	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64340	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps A Phase V	32.76	
64341	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps B Phase V	32.76	
64342	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps C Phase V	32.76	
64343	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations A Ø	0	
64344	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations B Ø	0	
64345	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations C Ø	0	
64346	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations Ground	0	
64347	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations	0	
64348	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64349	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64350	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64351	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64352	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps B Ø	0.0	
64353	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps C Ø	0.0	
64354	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64355	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64356	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64357	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64358	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations A Ø	0	
64359	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations B Ø	0	
64360	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations C Ø	0	
64361	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations Ground	0	
64362	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Follow-up Action Required?	n	
64363	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Follow-up Action Required?	n	
64364	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	General Comments		
64365	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Follow-up Action Required?	n	
64366	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Follow-up Action Required?	n	
64367	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Foundation Condition	Good	
64368	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	General Comments		
64369	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	General Comments		
64370	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Grounds in Place?	y	
64371	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64372	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Maintenance Operations	0	
64373	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Moisture and Leak Free?	y	
64374	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AF	158	
64375	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AL	158	
64376	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations This Read Vac	5	
64377	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps B Ø	20.0	
64378	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps A Ø	50.0	
64379	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64380	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64381	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64382	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations	2	
64383	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Tank Paint Condition	Good	
64384	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Switching Operations	1	
64385	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations	3	
64386	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64387	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64388	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64389	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps A Ø	40.0	
64390	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps B Ø	100.0	
64391	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps C Ø	50.0	
64392	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushing Condition	Good	
64393	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64394	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64395	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64396	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64397	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64398	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64399	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps A Phase V	10.19	
64400	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps B Phase V	10.19	
64401	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps C Phase V	10.19	
64402	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations A Ø	0	
64403	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations B Ø	0	
64404	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations C Ø	0	
64405	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations Ground	0	
64406	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Follow-up Action Required?	n	
64407	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
64408	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Follow-up Action Required?	n	
64409	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Foundation Condition	Good	
64410	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	General Comments		
64411	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Months Operations	0	
64412	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
64413	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
64414	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
64415	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps A Ø	100.0	
64416	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps B Ø	150.0	
64417	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps C Ø	130.0	
64418	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
64419	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
64420	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
64421	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
64422	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations A Ø	0	
64423	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations B Ø	0	
64424	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations C Ø	0	
64425	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations Ground	0	
64426	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64427	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Follow-up Action Required?	n	
64428	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	General Comments		
64429	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	General Comments		
64430	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
64431	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Maintenance Operations	0	
64432	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AF	379	
64433	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
64434	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
64435	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Foundation Condition	Good	
64436	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
64437	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	General Comments		
64438	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
64439	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
64440	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
64441	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
64442	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
64443	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
64444	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
64445	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
64446	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
64447	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
64448	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
64449	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
64450	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
64451	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
64452	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64453	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64454	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
64455	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
64456	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
64457	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
64458	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
64459	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
64460	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64461	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
64462	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
64463	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64464	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Follow-up Action Required?	n	
64465	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
64466	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
64467	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
64468	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
64469	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	General Comments		
64470	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
64471	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	LTC Totalizer Reading	10880.64	kw
64472	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
64473	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
64474	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
64475	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Max	70	°C
64476	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Present	40	°C
64477	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
64478	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
64479	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
64480	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
64481	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
64482	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
64483	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
64484	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
64485	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
64486	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
64487	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64488	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushing Condition	Good	
64489	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps C Ø	20.0	
64490	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
64491	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
64492	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
64493	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
64494	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
64495	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
64496	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
64497	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
64498	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
64499	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
64500	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
64501	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	45	*F

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64502	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AF	433	
64503	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AL	433	
64504	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations This Read Vac	14	
64505	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Switching Operations	1	
64506	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps C Ø	100.0	
64507	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps B Ø	100.0	
64508	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps A Ø	100.0	
64509	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64510	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64511	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64512	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations	9	
64513	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Tank Paint Condition	Good	
64514	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Switching Operations	0	
64515	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64516	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations This Read Vac	0	
64517	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AL	91	
64518	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AF	91	
64519	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Moisture and Leak Free?	y	
64520	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Maintenance Operations	0	
64521	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
64522	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
64523	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
64524	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
64525	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
64526	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
64527	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
64528	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
64529	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
64530	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
64531	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
64532	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
64533	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
64534	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
64535	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
64536	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
64537	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	General Comments		
64538	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
64539	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
64540	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.2	VDC
64541	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.2	VDC
64542	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
64543	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7986	
64544	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
64545	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
64546	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
64547	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Landscape Good Condition?	y	
64548	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
64549	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
64550	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64551	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64552	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64553	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushing Condition	Good	
64554	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
64555	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
64556	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
64557	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
64558	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
64559	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
64560	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
64561	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
64562	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
64563	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
64564	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
64565	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
64566	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		
64567	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
64568	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
64569	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
64570	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
64571	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
64572	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
64573	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
64574	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
64575	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
64576	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64577	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
64578	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
64579	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
64580	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
64581	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
64582	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
64583	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
64584	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
64585	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
64586	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
64587	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	General Comments	1407 T needs linkage ground installed.	
64588	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
64589	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
64590	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Foundation Condition	Good	
64591	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
64592	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
64593	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
64594	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
64595	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
64596	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
64597	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
64598	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
64599	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
64600	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
64601	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
64602	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
64603	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
64604	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
64605	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
64606	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
64607	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
64608	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
64609	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
64610	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
64611	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
64612	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
64613	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
64614	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
64615	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	General Comments		
64616	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
64617	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64618	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64619	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
64620	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
64621	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
64622	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
64623	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	General Comments		
64624	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
64625	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Found Counter	22703	
64626	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
64627	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
64628	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
64629	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
64630	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	59885	
64631	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	
64632	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	volts
64633	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
64634	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
64635	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
64636	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1L	
64637	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
64638	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
64639	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
64640	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
64641	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
64642	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
64643	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
64644	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
64645	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
64646	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
64647	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
64648	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
64649	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
64650	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Left Counter	22703	
64651	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64652	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3R	
64653	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	233	
64654	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
64655	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
64656	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
64657	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
64658	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
64659	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
64660	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
64661	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
64662	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
64663	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
64664	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64665	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Grounds in Place?	y	
64666	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	General Comments		
64667	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	General Comments		
64668	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Foundation Condition	Good	
64669	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Follow-up Action Required?	n	
64670	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
64671	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations Ground	0	
64672	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations C Ø	0	
64673	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations B Ø	0	
64674	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations A Ø	0	
64675	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64676	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64677	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64678	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
64679	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
64680	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
64681	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
64682	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	638.88	kw
64683	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
64684	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
64685	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
64686	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	General Comments		
64687	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	General Comments		
64688	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
64689	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
64690	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
64691	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64692	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
64693	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
64694	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64695	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64696	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64697	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
64698	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
64699	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
64700	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
64701	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
64702	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.7	VDC
64703	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
64704	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
64705	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
64706	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
64707	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
64708	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
64709	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
64710	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
64711	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
64712	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
64713	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64714	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64715	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushing Condition	Good	
64716	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps C Ø	180.0	
64717	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps B Ø	180.0	
64718	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps A Ø	180.0	
64719	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64720	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64721	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64722	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations	2	
64723	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
64724	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64725	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64726	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64727	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
64728	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
64729	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
64730	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64731	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
64732	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
64733	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64734	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
64735	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
64736	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
64737	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
64738	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	General Comments		
64739	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
64740	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
64741	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
64742	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
64743	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
64744	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
64745	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
64746	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
64747	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
64748	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Max	47	°C
64749	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Present	34	°C
64750	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
64751	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
64752	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
64753	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
64754	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
64755	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
64756	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
64757	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
64758	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
64759	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	47	°C
64760	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	34	°C
64761	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	47	°C
64762	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	34	°C
64763	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	47	°C
64764	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	34	°C
64765	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Tank Paint Condition	Good	
64766	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Switching Operations	0	
64767	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64768	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
64769	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
64770	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
64771	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
64772	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
64773	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
64774	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
64775	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
64776	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
64777	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Regulator As Left Counter	109225	
64778	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
64779	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
64780	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
64781	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	0	
64782	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
64783	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations This Read Vac	0	
64784	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	278	
64785	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	278	
64786	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
64787	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
64788	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64789	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
64790	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
64791	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
64792	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
64793	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
64794	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	
64795	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
64796	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
64797	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
64798	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
64799	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64800	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64801	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64802	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64803	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64804	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64805	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64806	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64807	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64808	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
64809	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	120.0	
64810	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	110.0	
64811	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	120.0	
64812	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64813	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64814	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64815	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	10	
64816	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Leaks	None	
64817	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
64818	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
64819	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
64820	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
64821	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
64822	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
64823	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
64824	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	General Comments		
64825	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	General Comments		
64826	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Maintenance Operations	13	
64827	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
64828	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AF	135	
64829	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AL	135	
64830	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations This Read Vac	1	
64831	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Switching Operations	0	
64832	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
64833	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Unknown Operations	0	
64834	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Moisture and Leak Free?	y	
64835	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Maintenance Operations	0	
64836	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64837	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Grounds in Place?	y	
64838	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
64839	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
64840	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
64841	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Reading	1.1334	
64842	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Winding Temp Max	0	°C
64843	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Winding Temp Present	0	°C
64844	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
64845	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
64846	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
64847	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
64848	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Trash?	y	
64849	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
64850	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
64851	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
64852	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
64853	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
64854	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
64855	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	General Comments		
64856	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
64857	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Vegetation	None	
64858	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	General Comments		
64859	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	General Comments		
64860	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Foundation Condition	Good	
64861	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Follow-up Action Required?	n	
64862	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
64863	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Follow-up Action Required?	n	
64864	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations Ground	0	
64865	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations C Ø	0	
64866	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations B Ø	0	
64867	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations A Ø	0	
64868	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64869	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64870	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64871	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64872	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64873	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64874	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	44	*F
64875	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
64876	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
64877	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
64878	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
64879	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
64880	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
64881	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
64882	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
64883	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
64884	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
64885	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
64886	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
64887	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
64888	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	General Comments		
64889	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	General Comments		
64890	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
64891	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
64892	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
64893	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
64894	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
64895	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
64896	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64897	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64898	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64899	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
64900	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
64901	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations This Read Vac	0	
64902	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AL	167	
64903	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AF	167	
64904	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	General Comments		
64905	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
64906	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
64907	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
64908	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
64909	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
64910	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
64911	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations	2	
64912	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
64913	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
64914	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
64915	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps A Ø	40.0	
64916	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps B Ø	40.0	
64917	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps C Ø	10.0	
64918	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushing Condition	Good	
64919	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
64920	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
64921	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
64922	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
64923	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
64924	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
64925	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
64926	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
64927	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
64928	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations A Ø	0	
64929	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations B Ø	0	
64930	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations C Ø	0	
64931	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations Ground	0	
64932	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
64933	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Follow-up Action Required?	n	
64934	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Foundation Condition	Good	
64935	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	General Comments		
64936	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	General Comments		
64937	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Grounds in Place?	y	
64938	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
64939	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Maintenance Operations	1	
64940	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
64941	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
64942	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
64943	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
64944	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
64945	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
64946	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
64947	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
64948	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
64949	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
64950	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
64951	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
64952	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
64953	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
64954	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
64955	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
64956	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
64957	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
64958	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
64959	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Leaks	None	
64960	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
64961	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
64962	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4818	
64963	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
64964	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
64965	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
64966	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
64967	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
64968	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
64969	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
64970	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
64971	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	General Comments		
64972	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
64973	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
64974	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
64975	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
64976	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
64977	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
64978	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
64979	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
64980	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
64981	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
64982	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
64983	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
64984	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
64985	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
64986	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
64987	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
64988	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
64989	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
64990	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
64991	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
64992	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
64993	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	gone	
64994	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
64995	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
64996	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Leaks	None	
64997	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
64998	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
64999	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2945	
65000	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
65001	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
65002	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
65003	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65004	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65005	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
65006	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
65007	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
65008	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	General Comments		
65009	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65010	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
65011	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
65012	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65013	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
65014	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65015	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65016	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65017	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65018	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
65019	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
65020	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Leaks	None	
65021	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
65022	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
65023	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4258	
65024	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
65025	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
65026	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65027	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65028	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65029	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
65030	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
65031	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
65032	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
65033	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
65034	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
65035	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
65036	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
65037	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	General Comments		
65038	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
65039	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
65040	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
65041	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
65042	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
65043	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
65044	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1013	
65045	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1013	
65046	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
65047	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	N.O.	
65048	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
65049	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
65050	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
65051	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
65052	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
65053	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
65054	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65055	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	General Comments		
65056	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
65057	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Found Counter	15964	
65058	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Left Counter	15964	
65059	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65060	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Current Tap Position	3L	
65061	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Max Tap Position	3R	
65062	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
65063	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	663	
65064	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
65065	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65066	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65067	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65068	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
65069	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
65070	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
65071	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
65072	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
65073	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
65074	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
65075	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Leaks	None	
65076	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
65077	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
65078	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15301	
65079	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
65080	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
65081	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
65082	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65083	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65084	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
65085	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
65086	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
65087	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	General Comments		
65088	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65089	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
65090	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
65091	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65092	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
65093	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65094	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
65095	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
65096	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
65097	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Follow-up Action Required?	n	
65098	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
65099	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
65100	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	General Comments		
65101	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
65102	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
65103	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	LTC Totalizer Reading	4305.60	kw
65104	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
65105	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
65106	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Max	50	°C
65107	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Present	45	°C
65108	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
65109	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
65110	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
65111	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
65112	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
65113	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
65114	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
65115	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
65116	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Reading	.8970	
65117	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
65118	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
65119	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
65120	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
65121	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
65122	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65123	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65124	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations	18	
65125	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
65126	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
65127	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
65128	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
65129	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
65130	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
65131	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
65132	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
65133	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
65134	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
65135	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
65136	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
65137	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
65138	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
65139	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
65140	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
65141	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
65142	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
65143	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
65144	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
65145	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
65146	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
65147	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
65148	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
65149	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
65150	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
65151	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
65152	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
65153	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
65154	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	General Comments		
65155	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
65156	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
65157	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
65158	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
65159	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	924	
65160	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	924	
65161	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
65162	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
65163	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
65164	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
65165	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
65166	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
65167	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
65168	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
65169	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Follow-up Action Required?	n	
65170	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations Ground	0	
65171	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations C Ø	0	
65172	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations B Ø	0	
65173	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations A Ø	0	
65174	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
65175	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
65176	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65177	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
65178	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
65179	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
65180	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
65181	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
65182	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
65183	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
65184	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
65185	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
65186	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
65187	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	General Comments		
65188	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
65189	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
65190	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
65191	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
65192	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65193	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65194	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65195	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65196	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
65197	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
65198	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	General Comments		
65199	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	General Comments		
65200	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Follow-up Action Required?	n	
65201	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Follow-up Action Required?	n	
65202	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations Ground	0	
65203	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
65204	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
65205	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
65206	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
65207	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
65208	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
65209	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
65210	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
65211	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
65212	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
65213	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
65214	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
65215	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
65216	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
65217	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
65218	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	General Comments		
65219	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	General Comments		
65220	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
65221	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
65222	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
65223	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
65224	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
65225	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
65226	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
65227	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
65228	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
65229	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Switching Operations	0	
65230	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations This Read Vac	0	
65231	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AL	221	
65232	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AF	221	
65233	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Maintenance Operations	0	
65234	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	General Comments	ok	
65235	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	General Comments		
65236	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Follow-up Action Required?	n	
65237	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
65238	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
65239	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
65240	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
65241	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	2200.0	
65242	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	200.0	
65243	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	200.0	
65244	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
65245	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
65246	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
65247	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65248	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65249	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
65250	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
65251	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65252	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
65253	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
65254	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
65255	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
65256	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
65257	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
65258	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65259	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65260	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65261	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps C Ø	0.0	
65262	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps B Ø	0.0	
65263	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps A Ø	0.0	
65264	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65265	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations C Ø	0	
65266	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations B Ø	0	
65267	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations A Ø	0	
65268	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65269	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65270	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65271	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65272	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps C Ø	230.0	
65273	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps B Ø	230.0	
65274	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps A Ø	230.0	
65275	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65276	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65277	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65278	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
65279	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65280	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	General Comments		
65281	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
65282	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Found Counter	29851	
65283	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Left Counter	29851	
65284	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65285	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Current Tap Position	9L	
65286	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Max Tap Position	5R	
65287	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
65288	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
65289	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1244	
65290	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
65291	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65292	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65293	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65294	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations	0	
65295	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
65296	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
65297	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
65298	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
65299	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
65300	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0651	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
65301	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65302	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
65303	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
65304	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65305	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	General Comments		
65306	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
65307	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
65308	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
65309	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65310	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65311	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
65312	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
65313	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Regulator As Left Counter	249664	
65314	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
65315	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Leaks	None	
65316	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
65317	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
65318	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
65319	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
65320	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
65321	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Foundation Condition	Good	
65322	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
65323	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
65324	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	General Comments		
65325	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
65326	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
65327	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
65328	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
65329	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
65330	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
65331	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
65332	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
65333	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
65334	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
65335	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
65336	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
65337	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
65338	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
65339	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
65340	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
65341	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
65342	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
65343	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
65344	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
65345	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
65346	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
65347	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
65348	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
65349	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
65350	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
65351	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
65352	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0654	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
65353	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65354	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps C Ø	470.0	
65355	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps B Ø	470.0	
65356	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps A Ø	470.0	
65357	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65358	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65359	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
65360	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
65361	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
65362	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
65363	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65364	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations	1	
65365	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
65366	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	597.00	kw
65367	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
65368	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
65369	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
65370	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
65371	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
65372	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65373	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65374	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
65375	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
65376	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
65377	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
65378	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
65379	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
65380	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	38.0	
65381	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65382	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65383	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65384	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
65385	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65386	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
65387	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
65388	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	41416	
65389	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	40793	
65390	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65391	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
65392	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
65393	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
65394	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Operations Since Last Insp	2385	
65395	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
65396	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
65397	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
65398	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AL	392	
65399	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AF	392	
65400	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
65401	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
65402	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	General Comments		
65403	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
65404	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65405	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65406	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Operations Since Last Insp	690	
65407	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Min Tap Position	5L	
65408	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Max Tap Position	2R	
65409	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Current Tap Position	1L	
65410	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65411	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Left Counter	155965	
65412	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Found Counter	155965	
65413	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	General Comments		
65414	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	General Comments		
65415	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65416	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Follow-up Action Required?	n	
65417	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations	0	
65418	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9950	
65419	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
65420	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
65421	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
65422	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
65423	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
65424	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
65425	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
65426	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
65427	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
65428	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	General Comments		
65429	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
65430	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
65431	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
65432	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
65433	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
65434	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
65435	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
65436	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
65437	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
65438	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Switching Operations	0	
65439	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations This Read Vac	0	
65440	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AL	243	
65441	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AF	243	
65442	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Maintenance Operations	0	
65443	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	General Comments		
65444	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	General Comments		
65445	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
65446	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
65447	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
65448	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
65449	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations Ground	0	
65450	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
65451	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
65452	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
65453	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65454	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65455	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65456	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
65457	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	General Comments		
65458	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	radiator is showing sign of leaks	
65459	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
65460	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
65461	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
65462	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
65463	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
65464	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
65465	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
65466	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
65467	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
65468	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
65469	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
65470	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
65471	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
65472	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
65473	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
65474	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
65475	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
65476	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65477	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
65478	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
65479	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
65480	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
65481	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
65482	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
65483	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
65484	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
65485	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	General Comments		
65486	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	General Comments		
65487	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
65488	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
65489	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	396.54	kw
65490	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
65491	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
65492	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
65493	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
65494	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
65495	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
65496	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
65497	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
65498	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
65499	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
65500	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
65501	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.6609	
65502	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
65503	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
65504	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
65505	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
65506	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
65507	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
65508	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
65509	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
65510	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
65511	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
65512	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
65513	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
65514	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1L	
65515	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
65516	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
65517	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65518	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65519	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65520	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
65521	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
65522	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
65523	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
65524	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
65525	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
65526	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Min Tap Position	10L	
65527	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Max Tap Position	4L	
65528	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Current Tap Position	10L	
65529	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65530	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Left Counter	220727	
65531	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	General Comments		
65532	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	General Comments		
65533	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
65534	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
65535	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
65536	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
65537	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
65538	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
65539	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Found Counter	220727	
65540	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	General Comments		
65541	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	General Comments		
65542	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65543	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Follow-up Action Required?	n	
65544	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
65545	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
65546	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
65547	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
65548	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
65549	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
65550	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
65551	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65552	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
65553	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
65554	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
65555	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
65556	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
65557	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
65558	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
65559	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
65560	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65561	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65562	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
65563	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
65564	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
65565	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
65566	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
65567	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
65568	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
65569	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
65570	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Vegetation	None	
65571	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
65572	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
65573	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	General Comments		
65574	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
65575	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
65576	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
65577	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
65578	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
65579	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
65580	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Trash?	y	
65581	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
65582	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
65583	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
65584	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
65585	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations	13	
65586	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65587	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65588	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65589	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps A Ø	100.0	
65590	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps B Ø	100.0	
65591	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
65592	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
65593	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
65594	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
65595	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
65596	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
65597	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
65598	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	342	
65599	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	342	
65600	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	42	
65601	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
65602	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
65603	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
65604	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0815	BreakerOil	Retired Distribution	OCB Readings	General Comments	this breaker has been changed out.	
65605	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps C Ø	100.0	
65606	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushing Condition	Good	
65607	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushings Connection/Risers	Good	
65608	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
65609	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65610	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65611	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65612	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65613	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65614	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
65615	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
65616	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Leaks	None	
65617	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
65618	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
65619	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16837	
65620	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
65621	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
65622	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
65623	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65624	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65625	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
65626	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Max Tap Position	10R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65627	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
65628	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	General Comments		
65629	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65630	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
65631	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
65632	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65633	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
65634	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65635	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65636	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65637	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65638	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
65639	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
65640	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Leaks	None	
65641	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
65642	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
65643	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Regulator As Left Counter	16237	
65644	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
65645	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
65646	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
65647	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC000602	LTCControl	ET-TRANS 6	LTC Control Insp	General Comments		
65648	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
65649	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
65650	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65651	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65652	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
65653	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
65654	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
65655	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	General Comments		
65656	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65657	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
65658	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
65659	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65660	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
65661	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65662	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65663	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	7L	
65664	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	3L	
65665	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	5L	
65666	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
65667	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	478078	
65668	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	478078	
65669	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments		
65670	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
65671	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
65672	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
65673	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps A Ø	0.0	
65674	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65675	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65676	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65677	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
65678	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
65679	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
65680	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
65681	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	General Comments		
65682	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Vegetation	None	
65683	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
65684	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
65685	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
65686	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
65687	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
65688	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
65689	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
65690	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	General Comments		
65691	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
65692	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
65693	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
65694	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
65695	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
65696	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
65697	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
65698	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
65699	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
65700	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
65701	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Wood Structures OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65702	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
65703	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
65704	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
65705	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
65706	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
65707	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
65708	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
65709	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
65710	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	General Comments		
65711	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
65712	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
65713	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
65714	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65715	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Paint Condition	Good	
65716	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65717	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65718	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65719	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65720	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations A Ø	0	
65721	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations B Ø	0	
65722	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations C Ø	0	
65723	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations Ground	0	
65724	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Follow-up Action Required?	n	
65725	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Follow-up Action Required?	n	
65726	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Foundation Condition	Good	
65727	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	General Comments		
65728	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	General Comments		
65729	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Grounds in Place?	y	
65730	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Heaters (All) Functioning?	y	
65731	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Maintenance Operations	0	
65732	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Moisture and Leak Free?	y	
65733	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AF	181	
65734	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AL	181	
65735	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations This Read Vac	2	
65736	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
65737	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Switching Operations	2	
65738	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Tank Paint Condition	Good	
65739	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
65740	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.0	
65741	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
65742	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Switching Operations	0	
65743	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations This Read Vac	0	
65744	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AL	143	
65745	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AF	143	
65746	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Maintenance Operations	0	
65747	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	General Comments		
65748	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	General Comments		
65749	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Follow-up Action Required?	n	
65750	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Follow-up Action Required?	n	
65751	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations Ground	0	
65752	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations C Ø	0	
65753	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations B Ø	0	
65754	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations A Ø	0	
65755	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65756	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65757	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65758	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65759	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps C Ø	0.0	
65760	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps B Ø	0.0	
65761	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65762	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65763	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65764	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
65765	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	134	
65766	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
65767	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
65768	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65769	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65770	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
65771	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
65772	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushing Condition	Good	
65773	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps C Ø	77.0	
65774	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps B Ø	80.0	
65775	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps A Ø	103.0	
65776	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
65777	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65778	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65779	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations	2	
65780	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
65781	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
65782	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
65783	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
65784	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	General Comments		
65785	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
65786	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
65787	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
65788	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
65789	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65790	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65791	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
65792	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
65793	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
65794	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
65795	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
65796	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
65797	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
65798	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
65799	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
65800	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	General Comments		
65801	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
65802	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
65803	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
65804	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
65805	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
65806	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
65807	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
65808	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
65809	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
65810	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	General Comments		
65811	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
65812	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
65813	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
65814	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
65815	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations	3	
65816	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65817	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65818	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Grounds in Place?	y	
65819	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	General Comments		
65820	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	General Comments		
65821	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Foundation Condition	Good	
65822	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Follow-up Action Required?	n	
65823	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
65824	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations Ground	0	
65825	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations C Ø	0	
65826	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations B Ø	0	
65827	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations A Ø	0	
65828	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65829	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65830	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65831	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65832	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
65833	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65834	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65835	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
65836	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
65837	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushing Condition	Good	
65838	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps C Ø	111.0	
65839	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps B Ø	156.0	
65840	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps A Ø	90.0	
65841	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65842	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65843	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65844	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations	4	
65845	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Unknown Operations	0	
65846	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
65847	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Switching Operations	0	
65848	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
65849	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations This Read Vac	0	
65850	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AL	152	
65851	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AF	152	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65852	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
65853	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Maintenance Operations	0	
65854	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
65855	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Grounds in Place?	y	
65856	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	General Comments		
65857	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	General Comments		
65858	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Foundation Condition	Good	
65859	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Follow-up Action Required?	n	
65860	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
65861	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations Ground	0	
65862	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations C Ø	0	
65863	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations B Ø	0	
65864	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations A Ø	0	
65865	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65866	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65867	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65868	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65869	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
65870	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Follow-up Action Required?	n	
65871	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Foundation Condition	Good	
65872	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	General Comments		
65873	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	General Comments		
65874	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Grounds in Place?	y	
65875	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Heaters (All) Functioning?	y	
65876	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Maintenance Operations	0	
65877	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Moisture and Leak Free?	y	
65878	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AF	275	
65879	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AL	275	
65880	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations This Read Vac	0	
65881	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
65882	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Switching Operations	0	
65883	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Tank Paint Condition	Good	
65884	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations	0	
65885	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65886	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65887	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65888	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps A Ø	600.0	
65889	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps B Ø	600.0	
65890	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps C Ø	600.0	
65891	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
65892	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
65893	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
65894	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65895	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65896	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
65897	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65898	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65899	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65900	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65901	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
65902	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
65903	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
65904	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations Ground	0	
65905	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
65906	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
65907	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
65908	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	General Comments		
65909	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	General Comments		
65910	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
65911	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
65912	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Maintenance Operations	0	
65913	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
65914	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AF	101	
65915	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AL	101	
65916	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations This Read Vac	0	
65917	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Switching Operations	0	
65918	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
65919	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
65920	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
65921	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65922	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps A Ø	100.0	
65923	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
65924	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Leaks	None	
65925	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
65926	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Regulator As Left Counter	13480	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
65927	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
65928	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
65929	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
65930	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
65931	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
65932	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
65933	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
65934	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
65935	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	General Comments		
65936	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
65937	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	General Comments		
65938	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
65939	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
65940	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
65941	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
65942	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
65943	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
65944	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
65945	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
65946	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
65947	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
65948	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
65949	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
65950	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
65951	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
65952	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
65953	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
65954	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
65955	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
65956	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps B Ø	100.0	
65957	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps C Ø	100.0	
65958	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushing Condition	Good	
65959	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
65960	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
65961	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
65962	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
65963	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
65964	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65965	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65966	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65967	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
65968	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations A Ø	0	
65969	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations B Ø	0	
65970	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations C Ø	0	
65971	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations Ground	0	
65972	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Follow-up Action Required?	n	
65973	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
65974	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
65975	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Equipment Properly Labeled?	y	
65976	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps C Ø	260.0	
65977	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps B Ø	260.0	
65978	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps A Ø	260.0	
65979	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
65980	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
65981	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
65982	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations	0	
65983	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
65984	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
65985	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	824	
65986	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	824	
65987	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
65988	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	IOC A, B and C Phase	
65989	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
65990	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
65991	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
65992	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
65993	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
65994	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
65995	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
65996	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
65997	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
65998	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	130.0	
65999	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	110.0	
66000	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66001	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66002	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66003	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
66004	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
66005	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
66006	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
66007	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
66008	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
66009	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
66010	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	gone	
66011	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
66012	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
66013	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
66014	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
66015	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
66016	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
66017	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
66018	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66019	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66020	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66021	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
66022	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
66023	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
66024	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Yard Patrol Inspection	Barbed Wire Condition OK?	y	
66025	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
66026	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
66027	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
66028	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Trash?	y	
66029	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
66030	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
66031	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
66032	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
66033	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
66034	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
66035	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	General Comments		
66036	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
66037	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
66038	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Vegetation	None	
66039	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
66040	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
66041	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
66042	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
66043	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
66044	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
66045	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
66046	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Foundation Condition	Good	
66047	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
66048	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
66049	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	General Comments		
66050	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
66051	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
66052	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
66053	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
66054	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
66055	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
66056	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
66057	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
66058	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
66059	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
66060	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
66061	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
66062	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Switching Operations	0	
66063	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations This Read Vac	0	
66064	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AL	228	
66065	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AF	228	
66066	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Maintenance Operations	0	
66067	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	General Comments		
66068	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	General Comments		
66069	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Follow-up Action Required?	n	
66070	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Follow-up Action Required?	n	
66071	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations Ground	0	
66072	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations C Ø	0	
66073	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations B Ø	0	
66074	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations A Ø	0	
66075	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66076	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66077	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66078	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66079	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66080	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66081	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations A Ø	0	
66082	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations B Ø	0	
66083	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations C Ø	0	
66084	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations Ground	0	
66085	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
66086	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
66087	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0652	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
66088	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
66089	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Follow-up Action Required?	y	
66090	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Foundation Condition	Good	
66091	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	General Comments		
66092	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	General Comments	Actual Counter, IOC A and B Phase, Breaker Connected Light is not working even after replacing bulb	
66093	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Grounds in Place?	y	
66094	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
66095	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Maintenance Operations	0	
66096	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
66097	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AF	172	
66098	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AL	172	
66099	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations This Read Vac	0	
66100	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
66101	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Switching Operations	0	
66102	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
66103	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
66104	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
66105	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
66106	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Trash?	y	
66107	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
66108	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
66109	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
66110	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
66111	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Unknown Operations	0	
66112	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
66113	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Switching Operations	0	
66114	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
66115	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations This Read Vac	0	
66116	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AL	163	
66117	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
66118	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
66119	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	General Comments		
66120	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
66121	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
66122	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Vegetation	None	
66123	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
66124	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AF	163	
66125	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	
66126	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Maintenance Operations	0	
66127	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
66128	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
66129	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66130	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66131	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66132	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LB0655	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
66133	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	2	
66134	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66135	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66136	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66137	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
66138	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
66139	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
66140	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
66141	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
66142	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66143	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66144	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66145	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	
66146	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66147	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66148	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66149	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66150	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
66151	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66152	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
66153	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
66154	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
66155	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
66156	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
66157	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		
66158	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments		
66159	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
66160	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	0	
66161	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
66162	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	208	
66163	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	208	
66164	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations This Read Vac	0	
66165	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	0	
66166	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
66167	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
66168	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations	21	
66169	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66170	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66171	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66172	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps A Ø	120.0	
66173	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps B Ø	90.0	
66174	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps C Ø	50.0	
66175	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushing Condition	Good	
66176	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
66177	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66178	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66179	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66180	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
66181	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
66182	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
66183	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
66184	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
66185	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
66186	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
66187	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
66188	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
66189	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
66190	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
66191	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
66192	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8454	
66193	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
66194	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
66195	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
66196	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
66197	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
66198	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
66199	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
66200	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
66201	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
66202	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
66203	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
66204	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
66205	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
66206	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
66207	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
66208	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
66209	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
66210	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
66211	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
66212	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
66213	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
66214	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	221	
66215	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
66216	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Current counter on recloser is 221.	
66217	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
66218	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
66219	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
66220	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
66221	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	WX0190	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	24.9	
66222	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
66223	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66224	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66225	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66226	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66227	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66228	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66229	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66230	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
66231	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
66232	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
66233	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
66234	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
66235	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
66236	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	General Comments		
66237	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	General Comments		
66238	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
66239	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
66240	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	387.00	kw
66241	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
66242	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
66243	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
66244	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
66245	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
66246	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
66247	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
66248	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
66249	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
66250	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
66251	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
66252	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
66253	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6450	
66254	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
66255	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
66256	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
66257	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
66258	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
66259	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
66260	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
66261	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
66262	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
66263	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
66264	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
66265	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
66266	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
66267	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
66268	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	General Comments		
66269	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
66270	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
66271	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
66272	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
66273	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
66274	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
66275	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
66276	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
66277	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	General Comments		
66278	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	General Comments		
66279	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
66280	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
66281	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
66282	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2028.96	kw
66283	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Foundation Condition	Good	
66284	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
66285	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
66286	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	General Comments		
66287	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
66288	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
66289	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
66290	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
66291	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
66292	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
66293	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
66294	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
66295	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
66296	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
66297	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
66298	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
66299	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
66300	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
66301	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66302	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations This Read Vac	0	
66303	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AL	148	
66304	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AF	148	
66305	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Maintenance Operations	0	
66306	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	General Comments		
66307	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	General Comments		
66308	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Foundation Condition	Good	
66309	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Follow-up Action Required?	n	
66310	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Follow-up Action Required?	n	
66311	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations Ground	0	
66312	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations C Ø	0	
66313	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations B Ø	0	
66314	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations A Ø	0	
66315	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps C Phase V	2.63	
66316	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps B Phase V	2.63	
66317	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps A Phase V	2.63	
66318	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66319	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
66320	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66321	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66322	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66323	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
66324	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushing Condition	Good	
66325	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps C Ø	60.0	
66326	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps B Ø	60.0	
66327	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps A Ø	60.0	
66328	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66329	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66330	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66331	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations	3	
66332	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
66333	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
66334	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
66335	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
66336	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
66337	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
66338	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
66339	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
66340	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
66341	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
66342	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
66343	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
66344	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
66345	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
66346	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
66347	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	General Comments		
66348	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
66349	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
66350	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AF	283	
66351	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AL	283	
66352	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
66353	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
66354	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
66355	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
66356	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Vent Fans OK?	y	
66357	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
66358	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
66359	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panels Dusted?	y	
66360	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panel Lights OK?	y	
66361	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
66362	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
66363	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Unknown Operations	2	
66364	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Tank Paint Condition	Good	
66365	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Switching Operations	0	
66366	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations This Read Vac	3	
66367	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AL	180	
66368	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AF	180	
66369	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Moisture and Leak Free?	y	
66370	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Maintenance Operations	1	
66371	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
66372	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Grounds in Place?	y	
66373	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	General Comments		
66374	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
66375	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Follow-up Action Required?	n	
66376	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66377	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
66378	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Evidence of Insects	None	
66379	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
66380	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
66381	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
66382	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
66383	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
66384	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
66385	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
66386	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
66387	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
66388	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
66389	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2465.28	kw
66390	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
66391	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
66392	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
66393	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
66394	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
66395	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
66396	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
66397	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
66398	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
66399	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
66400	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
66401	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
66402	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.0272	
66403	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
66404	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
66405	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
66406	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
66407	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
66408	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
66409	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
66410	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
66411	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
66412	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
66413	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
66414	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	179	
66415	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	179	
66416	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
66417	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
66418	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
66419	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
66420	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
66421	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
66422	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
66423	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	206	
66424	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
66425	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
66426	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments		
66427	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
66428	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
66429	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
66430	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
66431	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
66432	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
66433	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
66434	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
66435	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
66436	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
66437	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	
66438	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	831	
66439	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	10L	
66440	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	3L	
66441	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	7L	
66442	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
66443	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	206023	
66444	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	206023	
66445	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
66446	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
66447	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
66448	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
66449	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
66450	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
66451	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66452	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
66453	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
66454	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
66455	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
66456	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
66457	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
66458	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
66459	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
66460	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
66461	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
66462	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
66463	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
66464	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
66465	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations	2	
66466	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66467	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66468	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66469	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
66470	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
66471	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
66472	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66473	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66474	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66475	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66476	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
66477	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
66478	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
66479	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
66480	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
66481	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
66482	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
66483	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
66484	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
66485	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
66486	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
66487	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
66488	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	General Comments		
66489	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	General Comments		
66490	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
66491	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
66492	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
66493	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
66494	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
66495	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Operations Counter	231	
66496	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
66497	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	General Comments		
66498	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
66499	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
66500	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66501	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66502	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66503	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
66504	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
66505	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
66506	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
66507	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
66508	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66509	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66510	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66511	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
66512	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
66513	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
66514	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
66515	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
66516	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
66517	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
66518	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
66519	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
66520	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
66521	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps C Ø	50.6	
66522	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps B Ø	57.7	
66523	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps A Ø	51.4	
66524	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
66525	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
66526	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66527	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
66528	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
66529	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty/loose	
66530	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
66531	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
66532	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
66533	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
66534	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
66535	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
66536	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
66537	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
66538	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
66539	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
66540	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
66541	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
66542	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
66543	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
66544	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	General Comments		
66545	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
66546	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	170	
66547	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	170	
66548	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
66549	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
66550	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
66551	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
66552	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
66553	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
66554	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
66555	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
66556	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
66557	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
66558	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
66559	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments	Replaced 2 danger signs on structure	
66560	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
66561	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
66562	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
66563	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
66564	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
66565	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
66566	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
66567	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
66568	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
66569	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
66570	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
66571	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
66572	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
66573	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
66574	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
66575	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
66576	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
66577	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
66578	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
66579	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
66580	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
66581	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
66582	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
66583	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
66584	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
66585	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
66586	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
66587	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66588	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66589	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66590	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66591	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
66592	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
66593	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
66594	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
66595	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66596	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations A Ø	0	
66597	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations B Ø	0	
66598	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations C Ø	0	
66599	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations Ground	0	
66600	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
66601	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66602	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
66603	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
66604	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	9 Month Operations	15	
66605	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
66606	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66607	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66608	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66609	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
66610	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
66611	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
66612	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
66613	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66614	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66615	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66616	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
66617	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Follow-up Action Required?	n	
66618	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Follow-up Action Required?	n	
66619	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Foundation Condition	Good	
66620	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	General Comments		
66621	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
66622	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	General Comments		
66623	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Grounds in Place?	y	
66624	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
66625	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Maintenance Operations	1	
66626	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Moisture and Leak Free?	y	
66627	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AF	177	
66628	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AL	177	
66629	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations This Read Vac	1	
66630	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
66631	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Switching Operations	0	
66632	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Tank Paint Condition	Good	
66633	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Unknown Operations	0	
66634	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
66635	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
66636	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
66637	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
66638	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
66639	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
66640	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
66641	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	630	
66642	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	630	
66643	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
66644	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	5	
66645	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
66646	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
66647	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
66648	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
66649	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
66650	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
66651	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
66652	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
66653	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	
66654	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
66655	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
66656	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
66657	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66658	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66659	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66660	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
66661	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66662	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66663	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66664	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
66665	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
66666	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
66667	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
66668	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
66669	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
66670	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
66671	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
66672	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations B Ø	0	
66673	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations A Ø	0	
66674	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66675	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66676	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66677	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66678	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps C Ø	0.0	
66679	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps B Ø	0.0	
66680	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps A Ø	0.0	
66681	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66682	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66683	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66684	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
66685	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
66686	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
66687	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
66688	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
66689	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
66690	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
66691	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
66692	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
66693	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
66694	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
66695	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
66696	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
66697	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	216	
66698	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	216	
66699	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations This Read Vac	0	
66700	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	0	
66701	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
66702	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
66703	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
66704	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
66705	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1610	
66706	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
66707	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
66708	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
66709	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
66710	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
66711	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
66712	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
66713	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
66714	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1610	
66715	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
66716	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
66717	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
66718	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
66719	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
66720	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
66721	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
66722	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
66723	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
66724	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
66725	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
66726	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
66727	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
66728	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
66729	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
66730	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
66731	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
66732	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
66733	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
66734	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
66735	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	72793	
66736	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
66737	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
66738	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
66739	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
66740	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
66741	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	9R	
66742	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations	18	
66743	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66744	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66745	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66746	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps A Ø	92.0	
66747	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps B Ø	95.0	
66748	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps C Ø	94.0	
66749	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66750	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66751	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66752	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66753	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations A Ø	0	
66754	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations B Ø	0	
66755	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations C Ø	0	
66756	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
66757	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
66758	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
66759	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
66760	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
66761	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
66762	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
66763	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
66764	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66765	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66766	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
66767	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
66768	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
66769	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
66770	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
66771	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
66772	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
66773	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
66774	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	General Comments		
66775	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
66776	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
66777	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Operations Counter	76	
66778	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
66779	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
66780	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations	0	
66781	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66782	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66783	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66784	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps A Ø	0.0	
66785	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps B Ø	0.0	
66786	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps C Ø	0.0	
66787	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66788	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66789	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66790	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66791	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations A Ø	0	
66792	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations B Ø	0	
66793	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations C Ø	0	
66794	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations Ground	0	
66795	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
66796	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Follow-up Action Required?	n	
66797	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	General Comments		
66798	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	General Comments		
66799	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Maintenance Operations	0	
66800	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AF	170	
66801	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AL	170	
66802	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations This Read Vac	0	
66803	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Switching Operations	0	
66804	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	General Comments		
66805	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
66806	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
66807	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
66808	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
66809	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
66810	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
66811	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
66812	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
66813	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66814	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66815	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66816	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
66817	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	130.0	
66818	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
66819	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66820	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66821	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66822	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
66823	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
66824	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
66825	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
66826	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
66827	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
66828	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
66829	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
66830	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
66831	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66832	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
66833	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
66834	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
66835	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99993	
66836	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99993	
66837	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
66838	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
66839	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
66840	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
66841	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
66842	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
66843	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
66844	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
66845	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
66846	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66847	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66848	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66849	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
66850	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
66851	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
66852	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
66853	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66854	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66855	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
66856	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
66857	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
66858	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
66859	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
66860	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	70.0	
66861	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
66862	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
66863	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
66864	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
66865	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
66866	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
66867	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
66868	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
66869	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
66870	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
66871	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
66872	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
66873	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
66874	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
66875	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
66876	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
66877	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
66878	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
66879	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
66880	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Leaks	None	
66881	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
66882	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Regulator As Left Counter	82757	
66883	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
66884	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
66885	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
66886	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
66887	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
66888	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
66889	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
66890	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
66891	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	General Comments		
66892	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
66893	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
66894	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
66895	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
66896	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
66897	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
66898	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
66899	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
66900	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
66901	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66902	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Foundation Condition	Good	
66903	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
66904	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
66905	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	General Comments		
66906	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
66907	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
66908	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
66909	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
66910	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
66911	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
66912	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1159	
66913	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1159	
66914	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
66915	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	IOC A, B and C Phase	
66916	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
66917	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
66918	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
66919	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
66920	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Leaks	None	
66921	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
66922	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Regulator As Left Counter	85657	
66923	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
66924	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
66925	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
66926	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
66927	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
66928	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
66929	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
66930	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	General Comments		
66931	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
66932	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
66933	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
66934	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
66935	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
66936	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
66937	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
66938	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
66939	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
66940	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
66941	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
66942	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Leaks	None	
66943	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
66944	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Regulator As Left Counter	83318	
66945	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
66946	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
66947	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
66948	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
66949	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
66950	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
66951	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
66952	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	General Comments		
66953	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
66954	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
66955	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66956	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66957	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
66958	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	110.0	
66959	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	120.0	
66960	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	130.0	
66961	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
66962	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
66963	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
66964	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
66965	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
66966	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
66967	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
66968	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
66969	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
66970	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
66971	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	
66972	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
66973	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	2	
66974	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
66975	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
66976	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
66977	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
66978	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
66979	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, IOC B, C phase, TOC C Phase	
66980	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
66981	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	906	
66982	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	906	
66983	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
66984	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
66985	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Switching Operations	0	
66986	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations This Read Vac	0	
66987	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AL	224	
66988	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AF	224	
66989	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Maintenance Operations	0	
66990	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	General Comments		
66991	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	General Comments		
66992	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Follow-up Action Required?	n	
66993	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Follow-up Action Required?	n	
66994	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations Ground	0	
66995	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations C Ø	0	
66996	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations	2	
66997	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
66998	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
66999	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67000	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps A Ø	129.0	
67001	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps B Ø	156.0	
67002	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps C Ø	138.0	
67003	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushing Condition	Good	
67004	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
67005	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
67006	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Leaks	None	
67007	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67008	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Regulator As Left Counter	130368	
67009	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
67010	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
67011	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
67012	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67013	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
67014	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
67015	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
67016	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	General Comments		
67017	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67018	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
67019	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
67020	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67021	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
67022	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67023	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67024	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67025	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67026	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	General Comments		
67027	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
67028	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
67029	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
67030	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67031	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67032	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
67033	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
67034	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Regulator As Left Counter	901564	
67035	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67036	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Leaks	None	
67037	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
67038	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	General Comments	Arrester broke	
67039	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
67040	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
67041	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
67042	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
67043	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	940	
67044	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
67045	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
67046	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
67047	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
67048	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
67049	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Left Counter	377034	
67050	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Found Counter	377034	
67051	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67052	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	General Comments		
67053	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
67054	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
67055	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
67056	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
67057	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
67058	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
67059	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	801	
67060	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
67061	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
67062	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
67063	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
67064	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
67065	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Left Counter	432312	
67066	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Found Counter	432312	
67067	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
67068	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	General Comments		
67069	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
67070	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
67071	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
67072	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
67073	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
67074	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
67075	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
67076	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
67077	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
67078	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
67079	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
67080	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67081	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
67082	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
67083	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	9 Month Operations	10	
67084	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
67085	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
67086	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67087	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67088	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67089	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67090	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
67091	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67092	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
67093	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
67094	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67095	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	General Comments		
67096	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
67097	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
67098	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
67099	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67100	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67101	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
67102	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
67103	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
67104	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
67105	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
67106	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
67107	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
67108	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
67109	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
67110	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
67111	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
67112	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
67113	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
67114	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
67115	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.5	VDC
67116	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
67117	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
67118	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
67119	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
67120	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Regulator As Left Counter	449235	
67121	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67122	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Leaks	None	
67123	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
67124	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
67125	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67126	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67127	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67128	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67129	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
67130	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67131	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
67132	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
67133	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67134	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
67135	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
67136	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	General Comments		
67137	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
67138	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
67139	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
67140	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
67141	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	501	
67142	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	501	
67143	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
67144	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
67145	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
67146	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
67147	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
67148	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
67149	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
67150	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Unknown Operations	0	
67151	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Tank Paint Condition	Good	
67152	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Switching Operations	2	
67153	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
67154	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations This Read Vac	2	
67155	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AL	342	
67156	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AF	342	
67157	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Moisture and Leak Free?	y	
67158	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Maintenance Operations	0	
67159	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Heaters (All) Functioning?	y	
67160	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Grounds in Place?	y	
67161	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Switching Operations	0	
67162	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations This Read Vac	0	
67163	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AL	226	
67164	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AF	226	
67165	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Maintenance Operations	0	
67166	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	General Comments		
67167	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
67168	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	General Comments		
67169	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Follow-up Action Required?	n	
67170	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Follow-up Action Required?	n	
67171	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations Ground	0	
67172	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations C Ø	0	
67173	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations B Ø	0	
67174	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations A Ø	0	
67175	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
67176	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
67177	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
67178	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Equipment Properly Labeled?	y	
67179	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
67180	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Foundation Condition	Good	
67181	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
67182	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
67183	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
67184	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
67185	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
67186	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
67187	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Vegetation	None	
67188	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
67189	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
67190	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67191	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67192	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
67193	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Switching Operations	0	
67194	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations This Read Vac	0	
67195	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AL	140	
67196	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AF	140	
67197	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Maintenance Operations	0	
67198	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	General Comments		
67199	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	General Comments		
67200	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Follow-up Action Required?	n	
67201	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67202	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations Ground	0	
67203	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations C Ø	0	
67204	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations B Ø	0	
67205	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations A Ø	0	
67206	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
67207	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
67208	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
67209	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
67210	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps C Ø	0.0	
67211	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps B Ø	0.0	
67212	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps A Ø	0.0	
67213	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67214	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
67215	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
67216	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations	0	
67217	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
67218	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
67219	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
67220	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
67221	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
67222	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
67223	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
67224	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
67225	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
67226	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	4.6	VDC
67227	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.4	VDC
67228	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
67229	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
67230	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
67231	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
67232	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
67233	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
67234	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
67235	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
67236	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
67237	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
67238	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
67239	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
67240	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
67241	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
67242	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
67243	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
67244	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
67245	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
67246	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67247	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	General Comments		
67248	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen	
67249	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
67250	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
67251	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.3	psi
67252	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Max	70	*C
67253	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Present	30	*C
67254	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67255	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
67256	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67257	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
67258	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
67259	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
67260	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67261	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
67262	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
67263	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	110	*C
67264	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	60	*C
67265	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	105	*C
67266	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	45	*C
67267	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	100	*C
67268	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	50	*C
67269	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
67270	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
67271	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
67272	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
67273	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	General Comments		
67274	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
67275	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
67276	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67277	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
67278	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
67279	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.8	VDC
67280	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
67281	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	General Comments		
67282	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
67283	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
67284	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
67285	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
67286	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
67287	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
67288	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
67289	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
67290	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
67291	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
67292	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
67293	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
67294	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
67295	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
67296	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations Ground	0	
67297	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Follow-up Action Required?	n	
67298	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Follow-up Action Required?	n	
67299	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	General Comments		
67300	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	General Comments		
67301	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Maintenance Operations	0	
67302	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AF	369	
67303	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AL	369	
67304	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations This Read Vac	0	
67305	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Switching Operations	0	
67306	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
67307	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
67308	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
67309	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67310	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
67311	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
67312	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67313	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
67314	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67315	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67316	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67317	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67318	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
67319	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
67320	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
67321	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
67322	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
67323	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
67324	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments		
67325	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
67326	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
67327	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
67328	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
67329	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
67330	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
67331	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
67332	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
67333	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
67334	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
67335	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments		
67336	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
67337	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	None	
67338	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
67339	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
67340	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
67341	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
67342	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
67343	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
67344	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
67345	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
67346	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
67347	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
67348	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67349	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
67350	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67351	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67352	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
67353	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
67354	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
67355	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
67356	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
67357	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
67358	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
67359	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	General Comments		
67360	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
67361	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
67362	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
67363	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
67364	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	19	
67365	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	117	
67366	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	117	
67367	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
67368	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
67369	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
67370	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
67371	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
67372	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
67373	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
67374	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Foundation Condition	Good	
67375	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
67376	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
67377	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
67378	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
67379	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
67380	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
67381	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
67382	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	General Comments		
67383	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
67384	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
67385	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
67386	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
67387	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
67388	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
67389	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
67390	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
67391	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
67392	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
67393	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
67394	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
67395	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
67396	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67397	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67398	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
67399	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
67400	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushing Condition	Good	
67401	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps C Ø	95.0	
67402	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps B Ø	95.0	
67403	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps A Ø	90.0	
67404	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
67405	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
67406	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
67407	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
67408	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
67409	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
67410	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	If no, which cells in comments
67411	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
67412	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
67413	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Unknown Operations	0	
67414	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Tank Paint Condition	Good	
67415	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Switching Operations	0	
67416	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations This Read Vac	2	
67417	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AL	225	
67418	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AF	225	
67419	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Moisture and Leak Free?	y	
67420	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Maintenance Operations	0	
67421	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Grounds in Place?	y	
67422	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	General Comments		
67423	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	General Comments		
67424	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Foundation Condition	Good	
67425	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Follow-up Action Required?	n	
67426	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67427	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations Ground	0	
67428	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations C Ø	1	
67429	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations B Ø	0	
67430	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations A Ø	1	
67431	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps C Phase V	1.31	
67432	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
67433	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps A Phase V	1.31	
67434	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
67435	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
67436	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
67437	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
67438	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
67439	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
67440	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
67441	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
67442	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
67443	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
67444	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
67445	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
67446	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
67447	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
67448	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	General Comments		
67449	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
67450	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
67451	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
67452	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	300.0	
67453	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	280.0	
67454	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
67455	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
67456	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
67457	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67458	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
67459	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
67460	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
67461	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67462	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
67463	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	2.0340	
67464	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
67465	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
67466	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
67467	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67468	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
67469	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
67470	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
67471	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
67472	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
67473	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
67474	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67475	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67476	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
67477	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
67478	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
67479	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
67480	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
67481	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
67482	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
67483	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
67484	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
67485	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
67486	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
67487	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
67488	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
67489	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
67490	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67491	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
67492	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
67493	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
67494	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
67495	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
67496	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67497	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	General Comments		
67498	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle at 0 psi	
67499	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
67500	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
67501	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67502	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
67503	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
67504	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
67505	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67506	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
67507	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67508	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
67509	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
67510	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
67511	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67512	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
67513	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67514	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67515	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67516	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67517	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
67518	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
67519	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Leaks	None	
67520	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67521	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48052	
67522	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
67523	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
67524	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67525	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67526	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
67527	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
67528	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
67529	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	General Comments		
67530	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67531	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
67532	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
67533	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
67534	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Vent Fans OK?	y	
67535	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
67536	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
67537	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
67538	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
67539	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
67540	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67541	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
67542	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
67543	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
67544	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
67545	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
67546	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67547	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
67548	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
67549	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
67550	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	3661.20	kw
67551	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
67552	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
67553	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	45	°C
67554	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	45	°C
67555	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
67556	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67557	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
67558	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67559	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67560	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67561	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67562	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
67563	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67564	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
67565	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67566	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
67567	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Leaks	None	
67568	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67569	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82585	
67570	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
67571	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
67572	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67573	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
67574	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
67575	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
67576	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Regulator As Left Counter	145959	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67577	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67578	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
67579	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Leaks	None	
67580	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
67581	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
67582	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
67583	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
67584	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
67585	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67586	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67587	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
67588	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
67589	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
67590	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	General Comments		
67591	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67592	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
67593	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
67594	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67595	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
67596	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67597	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67598	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67599	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67600	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
67601	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
67602	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
67603	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
67604	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
67605	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
67606	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	General Comments		
67607	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
67608	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
67609	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
67610	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67611	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67612	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67613	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67614	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
67615	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67616	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
67617	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
67618	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67619	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	General Comments		
67620	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
67621	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
67622	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
67623	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
67624	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
67625	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
67626	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
67627	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
67628	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
67629	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
67630	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
67631	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
67632	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
67633	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
67634	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
67635	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
67636	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
67637	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	General Comments		
67638	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
67639	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
67640	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
67641	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
67642	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
67643	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
67644	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
67645	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
67646	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	*F
67647	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
67648	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
67649	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
67650	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
67651	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67652	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
67653	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
67654	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
67655	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
67656	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
67657	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
67658	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
67659	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
67660	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
67661	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
67662	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
67663	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
67664	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
67665	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
67666	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67667	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
67668	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67669	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	General Comments		
67670	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
67671	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
67672	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
67673	11/19/2019 10:09	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67674	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
67675	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Vegetation	None	
67676	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
67677	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	General Comments		
67678	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
67679	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
67680	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
67681	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
67682	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3137.28	kw
67683	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
67684	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
67685	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67686	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
67687	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67688	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
67689	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
67690	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
67691	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67692	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
67693	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
67694	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
67695	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
67696	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
67697	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
67698	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
67699	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
67700	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
67701	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
67702	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
67703	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
67704	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
67705	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
67706	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments		
67707	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
67708	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
67709	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9804	
67710	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
67711	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
67712	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	0	
67713	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
67714	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations This Read Vac	0	
67715	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	248	
67716	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	248	
67717	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
67718	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
67719	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
67720	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
67721	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		
67722	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
67723	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
67724	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
67725	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
67726	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
67727	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
67728	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
67729	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Maintenance Operations	0	
67730	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
67731	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Number of Ops last 9 Months	3	
67732	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AF	510	
67733	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AL	510	
67734	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations This Read Oil	0	
67735	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Switching Operations	0	
67736	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
67737	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
67738	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
67739	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	General Comments		
67740	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	General Comments		
67741	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
67742	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Follow-up Action Required?	n	
67743	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
67744	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Fault Operations	0	
67745	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
67746	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
67747	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67748	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67749	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
67750	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
67751	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
67752	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
67753	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
67754	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
67755	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
67756	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
67757	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps C Ø	0.0	
67758	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps B Ø	0.0	
67759	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps A Ø	0.0	
67760	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
67761	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
67762	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
67763	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67764	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
67765	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
67766	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
67767	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
67768	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
67769	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67770	11/19/2019 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	General Comments		
67771	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
67772	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
67773	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
67774	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Trash?	y	
67775	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
67776	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
67777	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
67778	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
67779	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
67780	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
67781	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	General Comments		
67782	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	10	
67783	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
67784	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
67785	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
67786	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
67787	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
67788	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
67789	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
67790	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
67791	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
67792	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
67793	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	1114	
67794	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Min Tap Position	10L	
67795	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Max Tap Position	5R	
67796	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Current Tap Position	6L	
67797	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
67798	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Left Counter	11972	
67799	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Found Counter	11972	
67800	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	General Comments	LTC oil level is low, Pic is sent to Stinson	
67801	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67802	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
67803	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
67804	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
67805	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
67806	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Door Alarms OK?	y	
67807	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
67808	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
67809	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Leaks	None	
67810	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
67811	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59034	
67812	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
67813	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
67814	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
67815	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
67816	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
67817	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
67818	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
67819	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
67820	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
67821	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
67822	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
67823	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	n	
67824	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
67825	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments		
67826	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
67827	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
67828	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
67829	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
67830	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
67831	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	General Comments		
67832	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
67833	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
67834	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
67835	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
67836	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
67837	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
67838	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
67839	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
67840	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
67841	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
67842	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
67843	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
67844	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
67845	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
67846	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
67847	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
67848	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
67849	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
67850	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
67851	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Present	30	°C
67852	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Max	30	°C
67853	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Present	30	°C
67854	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Max	65	°C
67855	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X1 Winding Temp Present	60	°C
67856	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
67857	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
67858	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Present	30	°C
67859	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Max	50	°C
67860	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
67861	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
67862	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
67863	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
67864	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
67865	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
67866	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
67867	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
67868	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
67869	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
67870	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
67871	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
67872	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
67873	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
67874	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
67875	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
67876	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67877	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
67878	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
67879	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	General Comments		
67880	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Follow-up Action Required?	n	
67881	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
67882	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
67883	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	160.0	
67884	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	170.0	
67885	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	140.0	
67886	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67887	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
67888	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
67889	11/20/2019 8:06	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
67890	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
67891	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
67892	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
67893	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
67894	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
67895	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
67896	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
67897	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
67898	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
67899	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
67900	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
67901	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
67902	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
67903	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
67904	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
67905	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
67906	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
67907	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
67908	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Insulators in Good Condition?	y	
67909	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
67910	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
67911	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
67912	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
67913	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
67914	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
67915	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
67916	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
67917	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
67918	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushing Condition	Good	
67919	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps C Ø	0.0	
67920	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps B Ø	0.0	
67921	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps A Ø	0.0	
67922	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
67923	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
67924	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
67925	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	9 Month Operations	8	
67926	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Tank Paint Condition	Good	
67927	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Switching Operations	0	
67928	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
67929	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations This Read Vac	0	
67930	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AL	21	
67931	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AF	21	
67932	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
67933	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Maintenance Operations	0	
67934	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
67935	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Grounds in Place?	y	
67936	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	General Comments		
67937	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	General Comments		
67938	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Foundation Condition	Good	
67939	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Follow-up Action Required?	n	
67940	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
67941	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations Ground	0	
67942	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations C Ø	0	
67943	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations B Ø	0	
67944	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
67945	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67946	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
67947	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
67948	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67949	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
67950	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67951	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
67952	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Max	38	°C
67953	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
67954	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
67955	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
67956	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	General Comments		
67957	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
67958	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67959	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
67960	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
67961	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
67962	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
67963	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
67964	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67965	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
67966	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
67967	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
67968	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
67969	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
67970	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
67971	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
67972	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
67973	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
67974	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
67975	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
67976	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
67977	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	51	°C
67978	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
67979	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
67980	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
67981	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
67982	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
67983	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
67984	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments		
67985	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments		
67986	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
67987	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
67988	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
67989	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
67990	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
67991	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
67992	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67993	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
67994	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
67995	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
67996	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
67997	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
67998	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
67999	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Leaks	None	
68000	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
68001	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Regulator As Left Counter	81604	
68002	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
68003	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
68004	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
68005	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
68006	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
68007	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
68008	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
68009	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
68010	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	General Comments		
68011	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
68012	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
68013	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
68014	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
68015	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
68016	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
68017	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
68018	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
68019	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
68020	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
68021	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
68022	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
68023	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
68024	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
68025	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
68026	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68027	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
68028	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
68029	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
68030	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Leaks	None	
68031	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
68032	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
68033	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Regulator As Left Counter	91840	
68034	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
68035	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
68036	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
68037	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
68038	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
68039	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
68040	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
68041	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
68042	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	General Comments		
68043	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
68044	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
68045	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
68046	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
68047	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
68048	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
68049	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
68050	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
68051	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
68052	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations A Ø	0	
68053	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68054	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68055	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68056	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68057	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
68058	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68059	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68060	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
68061	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
68062	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Leaks	None	
68063	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
68064	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79466	
68065	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
68066	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
68067	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
68068	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
68069	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
68070	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
68071	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
68072	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
68073	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushing Condition	Good	
68074	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps C Ø	380.0	
68075	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps B Ø	450.0	
68076	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps A Ø	500.0	
68077	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68078	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68079	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68080	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations	0	
68081	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
68082	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
68083	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
68084	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
68085	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
68086	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
68087	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
68088	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
68089	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
68090	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
68091	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
68092	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
68093	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
68094	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
68095	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	General Comments		
68096	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
68097	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
68098	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
68099	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
68100	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
68101	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
68102	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
68103	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
68104	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
68105	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
68106	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
68107	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
68108	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
68109	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
68110	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
68111	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
68112	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
68113	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	General Comments		
68114	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
68115	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
68116	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
68117	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
68118	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
68119	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
68120	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
68121	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
68122	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
68123	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Foundation Condition	Good	
68124	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
68125	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
68126	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	General Comments		
68127	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
68128	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
68129	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
68130	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
68131	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
68132	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
68133	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
68134	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
68135	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
68136	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
68137	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
68138	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
68139	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
68140	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
68141	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
68142	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
68143	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	General Comments		
68144	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
68145	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
68146	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
68147	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
68148	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
68149	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Vegetation	None	
68150	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
68151	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
68152	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
68153	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
68154	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
68155	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
68156	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
68157	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
68158	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
68159	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
68160	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
68161	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
68162	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
68163	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
68164	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
68165	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
68166	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
68167	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Regulator As Left Counter	59603	
68168	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
68169	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Leaks	None	
68170	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
68171	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
68172	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
68173	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Unknown Operations	0	
68174	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Tank Paint Condition	Good	
68175	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Switching Operations	3	
68176	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68177	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations This Read Vac	3	
68178	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AL	140	
68179	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AF	140	
68180	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Moisture and Leak Free?	y	
68181	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Maintenance Operations	0	
68182	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68183	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Grounds in Place?	y	
68184	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	General Comments		
68185	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	General Comments		
68186	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Foundation Condition	Good	
68187	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Follow-up Action Required?	n	
68188	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Follow-up Action Required?	n	
68189	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations Ground	0	
68190	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations C Ø	0	
68191	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations B Ø	0	
68192	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations A Ø	0	
68193	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68194	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68195	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68196	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68197	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Paint Condition	Good	
68198	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68199	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68200	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
68201	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushings Connection/Risers	Good	
68202	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushing Condition	Good	
68203	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps C Ø	170.0	
68204	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps B Ø	150.0	
68205	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps A Ø	170.0	
68206	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68207	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68208	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68209	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations	4	
68210	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
68211	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
68212	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
68213	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
68214	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68215	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps C Ø	260.0	
68216	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps B Ø	260.0	
68217	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps A Ø	260.0	
68218	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68219	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68220	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68221	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations	0	
68222	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
68223	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
68224	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
68225	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
68226	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
68227	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
68228	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
68229	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
68230	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
68231	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
68232	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
68233	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
68234	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
68235	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Switching Operations	0	
68236	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations This Read Vac	0	
68237	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AL	161	
68238	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AF	161	
68239	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Maintenance Operations	0	
68240	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	General Comments		
68241	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	General Comments		
68242	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Follow-up Action Required?	n	
68243	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
68244	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations Ground	0	
68245	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations C Ø	0	
68246	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations B Ø	0	
68247	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations A Ø	0	
68248	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68249	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68250	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68251	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
68252	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps C Ø	230.0	
68253	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps B Ø	230.0	
68254	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps A Ø	230.0	
68255	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68256	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68257	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68258	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations	0	
68259	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
68260	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68261	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
68262	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
68263	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
68264	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
68265	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
68266	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
68267	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68268	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
68269	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
68270	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
68271	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
68272	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
68273	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
68274	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
68275	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
68276	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
68277	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
68278	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
68279	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
68280	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
68281	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Tank Paint Condition	Good	
68282	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Switching Operations	0	
68283	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
68284	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations This Read Vac	0	
68285	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AL	30	
68286	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AF	30	
68287	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Switching Operations	0	
68288	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations This Read Vac	0	
68289	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AL	179	
68290	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AF	179	
68291	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Maintenance Operations	0	
68292	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	General Comments		
68293	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	General Comments		
68294	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
68295	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Maintenance Operations	0	
68296	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68297	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Grounds in Place?	y	
68298	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	General Comments	Actual Counter	
68299	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	General Comments		
68300	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Foundation Condition	Good	
68301	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Follow-up Action Required?	n	
68302	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Follow-up Action Required?	n	
68303	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations Ground	0	
68304	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations C Ø	0	
68305	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations B Ø	0	
68306	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations A Ø	0	
68307	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68308	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68309	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68310	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68311	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
68312	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68313	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68314	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Follow-up Action Required?	n	
68315	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
68316	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations Ground	0	
68317	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations C Ø	0	
68318	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations B Ø	0	
68319	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations A Ø	0	
68320	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68321	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68322	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68323	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations B Ø	0	
68324	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	27	°C
68325	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
68326	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68327	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
68328	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
68329	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	38	°C
68330	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68331	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
68332	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68333	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
68334	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
68335	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68336	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
68337	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68338	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
68339	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
68340	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
68341	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
68342	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	General Comments		
68343	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
68344	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68345	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
68346	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
68347	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
68348	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
68349	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
68350	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
68351	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
68352	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
68353	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps C Ø	0.0	
68354	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations A Ø	0	
68355	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68356	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68357	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68358	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68359	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68360	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68361	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Bushing Condition	Good	
68362	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps C Ø	0.0	
68363	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps B Ø	0.0	
68364	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps A Ø	0.0	
68365	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68366	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
68367	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
68368	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
68369	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations C Ø	0	
68370	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations Ground	0	
68371	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
68372	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Follow-up Action Required?	n	
68373	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	General Comments		
68374	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	General Comments		
68375	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
68376	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Maintenance Operations	0	
68377	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AF	580	
68378	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AL	580	
68379	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations This Read AM	0	
68380	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Switching Operations	0	
68381	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Unknown Operations	0	
68382	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	All Connections OK?	y	
68383	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	Follow-up Action Required?	n	
68384	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	General Comments		
68385	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Operation Checked?	y	
68386	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
68387	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
68388	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	General Comments		
68389	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	General Comments		
68390	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68391	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
68392	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Follow-up Action Required?	n	
68393	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Tank Paint Condition	Good	
68394	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Switching Operations	5	
68395	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations This Read Vac	5	
68396	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AL	289	
68397	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AF	289	
68398	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Moisture and Leak Free?	y	
68399	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations C Ø	0	
68400	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations B Ø	0	
68401	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
68402	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68403	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68404	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68405	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68406	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68407	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68408	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Bushing Condition	Good	
68409	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps C Ø	0.0	
68410	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps B Ø	0.0	
68411	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps A Ø	0.0	
68412	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68413	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68414	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68415	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	9 Month Operations	0	
68416	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Unknown Operations	0	
68417	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Switching Operations	0	
68418	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations This Read Vac	0	
68419	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations Counter AL	53	
68420	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations Counter AF	53	
68421	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68422	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
68423	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
68424	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68425	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Follow-up Action Required?	n	
68426	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
68427	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68428	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	General Comments		
68429	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	General Comments		
68430	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
68431	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	LTC Totalizer Reading	3308.40	kw
68432	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
68433	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
68434	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Max	38	°C
68435	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Present	30	°C
68436	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68437	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
68438	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68439	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
68440	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
68441	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
68442	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68443	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Maintenance Operations	0	
68444	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68445	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
68446	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Grounds in Place?	y	
68447	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	General Comments	In service	
68448	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	General Comments		
68449	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Follow-up Action Required?	n	
68450	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
68451	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
68452	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
68453	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
68454	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	General Comments		
68455	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	General Comments		
68456	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68457	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
68458	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
68459	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68460	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68461	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68462	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68463	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
68464	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	9 Month Operations	27	
68465	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68466	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68467	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68468	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps A Ø	100.0	
68469	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps B Ø	100.0	
68470	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps C Ø	100.0	
68471	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
68472	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
68473	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations Ground	0	
68474	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations C Ø	0	
68475	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
68476	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
68477	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	LTC0000781	LTCControl	610-1	LTC Control Insp	VRR Time Delay	30	Seconds
68478	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
68479	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
68480	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
68481	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
68482	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
68483	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	General Comments		
68484	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68485	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
68486	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68487	11/19/2019 10:56	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
68488	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC0000801	LTCControl	655-1	LTC Control Insp	LTC Operation Checked?	y	
68489	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC0000801	LTCControl	655-1	LTC Control Insp	General Comments		
68490	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC0000801	LTCControl	655-1	LTC Control Insp	Follow-up Action Required?	n	
68491	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC0000801	LTCControl	655-1	LTC Control Insp	All Connections OK?	y	
68492	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
68493	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Reading	.5514	
68494	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
68495	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68496	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68497	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68498	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	9 Month Operations	0	
68499	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	All Connections OK?	y	
68500	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
68501	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	General Comments		
68502	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
68503	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Tank Paint Condition	Good	
68504	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Switching Operations	0	
68505	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
68506	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations This Read Vac	0	
68507	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AL	116	
68508	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AF	116	
68509	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Moisture and Leak Free?	y	
68510	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Maintenance Operations	0	
68511	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68512	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	OK	
68513	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68514	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Grounds in Place?	y	
68515	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	General Comments		
68516	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
68517	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68518	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68519	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
68520	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
68521	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Months Operations	1	
68522	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
68523	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations Ground	0	
68524	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Follow-up Action Required?	n	
68525	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Follow-up Action Required?	n	
68526	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	General Comments		
68527	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	General Comments	12KV TR-9 In service	
68528	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
68529	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Grounds in Place?	y	
68530	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
68531	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Vegetation	None	
68532	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
68533	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
68534	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	General Comments		
68535	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
68536	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
68537	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps A Ø	140.0	
68538	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
68539	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
68540	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
68541	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
68542	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
68543	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Trash?	y	
68544	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
68545	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
68546	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps B Ø	180.0	
68547	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps C Ø	150.0	
68548	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
68549	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
68550	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
68551	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68552	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68553	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Grounds in Place?	y	
68554	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	General Comments		
68555	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	General Comments		
68556	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Foundation Condition	Good	
68557	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Follow-up Action Required?	n	
68558	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Follow-up Action Required?	n	
68559	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations Ground	0	
68560	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations C Ø	0	
68561	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations B Ø	0	
68562	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations A Ø	0	
68563	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68564	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68565	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Bushing Condition	Good	
68566	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68567	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68568	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68569	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
68570	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68571	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68572	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68573	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
68574	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
68575	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushing Condition	Good	
68576	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps C Ø	150.0	
68577	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps B Ø	150.0	
68578	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps A Ø	150.0	
68579	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68580	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68581	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68582	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	9 Month Operations	28	
68583	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68584	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
68585	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
68586	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
68587	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
68588	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	66803	
68589	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
68590	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
68591	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
68592	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
68593	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68594	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68595	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68596	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68597	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68598	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations A Ø	0	
68599	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations B Ø	0	
68600	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations C Ø	0	
68601	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
68602	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1R	
68603	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
68604	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
68605	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
68606	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
68607	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
68608	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
68609	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
68610	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
68611	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
68612	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
68613	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
68614	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
68615	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
68616	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
68617	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
68618	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
68619	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
68620	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68621	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68622	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
68623	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
68624	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC000801	LTCControl	655-1	LTC Control Insp	VRR Time Delay	30	Seconds
68625	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
68626	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68627	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	LTC000801	LTCControl	655-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
68628	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
68629	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68630	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
68631	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68632	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
68633	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
68634	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
68635	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	1377.60	kw
68636	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
68637	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
68638	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	60	°C
68639	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	35	°C
68640	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68641	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
68642	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68643	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
68644	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
68645	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
68646	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	General Comments	OK	
68647	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68648	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68649	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
68650	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.2870	
68651	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
68652	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68653	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Switching Operations	0	
68654	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
68655	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
68656	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	General Comments		
68657	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
68658	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations This Read Vac	0	
68659	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AL	172	
68660	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AF	172	
68661	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Maintenance Operations	0	
68662	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	General Comments		
68663	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	General Comments		
68664	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
68665	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
68666	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations Ground	0	
68667	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
68668	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
68669	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
68670	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68671	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68672	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68673	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68674	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
68675	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
68676	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
68677	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68678	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68679	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
68680	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
68681	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
68682	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
68683	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
68684	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
68685	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7722	
68686	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
68687	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
68688	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
68689	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68690	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68691	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
68692	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
68693	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
68694	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
68695	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
68696	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
68697	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
68698	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
68699	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps C Ø	800.0	
68700	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps B Ø	780.0	
68701	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps A Ø	800.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
68702	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68703	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68704	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68705	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
68706	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
68707	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
68708	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68709	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
68710	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68711	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
68712	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68713	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
68714	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68715	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	36	°C
68716	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	47	°C
68717	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
68718	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
68719	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
68720	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68721	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68722	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
68723	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Foundation Condition	Good	
68724	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
68725	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
68726	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
68727	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
68728	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
68729	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
68730	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Vegetation	None	
68731	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
68732	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	General Comments		
68733	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
68734	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
68735	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
68736	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
68737	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
68738	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
68739	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Trash?	y	
68740	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
68741	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
68742	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
68743	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps B Ø	0.0	
68744	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps A Ø	0.0	
68745	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68746	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68747	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68748	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	9 Month Operations	0	
68749	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Unknown Operations	0	
68750	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Switching Operations	1	
68751	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations This Read Vac	1	
68752	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
68753	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
68754	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
68755	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments		
68756	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments		
68757	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
68758	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
68759	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
68760	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
68761	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations Counter AL	74	
68762	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations Counter AF	74	
68763	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
68764	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
68765	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68766	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68767	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
68768	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
68769	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
68770	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
68771	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Maintenance Operations	0	
68772	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68773	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Grounds in Place?	y	
68774	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68775	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68776	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68777	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
68778	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
68779	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
68780	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
68781	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
68782	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Operations Counter	74	
68783	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
68784	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
68785	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	General Comments		
68786	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
68787	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
68788	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
68789	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68790	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68791	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
68792	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
68793	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Present	38	°C
68794	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Max	52	°C
68795	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68796	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
68797	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
68798	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
68799	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68800	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
68801	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
68802	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
68803	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
68804	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
68805	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
68806	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
68807	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
68808	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
68809	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
68810	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
68811	11/19/2019 12:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
68812	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	95.0	
68813	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
68814	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	110.0	
68815	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
68816	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
68817	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
68818	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
68819	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
68820	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
68821	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
68822	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
68823	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
68824	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments		
68825	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
68826	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
68827	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68828	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
68829	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
68830	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	617.76	kw
68831	11/19/2019 12:14	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
68832	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
68833	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
68834	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
68835	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
68836	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
68837	11/19/2019 11:14	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	6	
68838	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps A Ø	0.0	
68839	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68840	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68841	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68842	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	9 Month Operations	1	
68843	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Unknown Operations	0	
68844	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Switching Operations	0	
68845	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations This Read Vac	0	
68846	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AL	67	
68847	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AF	67	
68848	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Maintenance Operations	0	
68849	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68850	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Grounds in Place?	y	
68851	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	General Comments	In service	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue		AssetInspectionQuestionUnit
68852	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	General Comments		
68853	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Follow-up Action Required?	n	
68854	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
68855	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations Ground	0	
68856	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68857	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations	1	
68858	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	General Comments	In service	
68859	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	General Comments		
68860	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Follow-up Action Required?	n	
68861	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Follow-up Action Required?	n	
68862	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations Ground	0	
68863	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations C Ø	0	
68864	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations B Ø	0	
68865	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
68866	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
68867	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
68868	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
68869	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
68870	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
68871	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations A Ø	0	
68872	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
68873	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
68874	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
68875	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
68876	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
68877	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68878	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Bushing Condition	Good	
68879	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps C Ø	0.0	
68880	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps B Ø	0.0	
68881	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
68882	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68883	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
68884	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68885	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
68886	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68887	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68888	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68889	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68890	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68891	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
68892	11/19/2019 9:16	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
68893	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68894	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
68895	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68896	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
68897	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68898	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68899	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68900	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68901	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68902	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
68903	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
68904	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Months Operations	3	
68905	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
68906	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
68907	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
68908	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps A Ø	170.0	
68909	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps B Ø	160.0	
68910	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps C Ø	140.0	
68911	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
68912	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
68913	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
68914	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
68915	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations A Ø	0	
68916	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations B Ø	0	
68917	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68918	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
68919	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Reading	.7880	
68920	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
68921	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68922	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
68923	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
68924	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
68925	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
68926	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
68927	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
68928	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Present	20	°C
68929	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Max	25	°C
68930	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
68931	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
68932	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	LTC Totalizer Reading	3782.40	kw
68933	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
68934	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
68935	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
68936	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
68937	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
68938	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	General Comments		
68939	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	34337	
68940	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	34344	
68941	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
68942	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	4L	
68943	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
68944	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
68945	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	General Comments		
68946	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
68947	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
68948	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
68949	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
68950	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
68951	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushing Condition	Good	
68952	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	101.0	
68953	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
68954	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
68955	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
68956	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
68957	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
68958	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
68959	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	60.0	
68960	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	97.0	
68961	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
68962	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
68963	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
68964	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	5	
68965	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
68966	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Tank Paint Condition	Good	
68967	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	3	
68968	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations This Read Vac	3	
68969	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	187	
68970	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	187	
68971	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Moisture and Leak Free?	y	
68972	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	0	
68973	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
68974	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Grounds in Place?	y	
68975	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
68976	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	General Comments		
68977	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Foundation Condition	Good	
68978	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
68979	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Follow-up Action Required?	n	
68980	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
68981	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
68982	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
68983	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
68984	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
68985	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
68986	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	60	°C
68987	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	30	°C
68988	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	65	°C
68989	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	35	°C
68990	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	60	°C
68991	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	35	°C
68992	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
68993	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
68994	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
68995	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
68996	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
68997	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
68998	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
68999	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
69000	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
69001	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69002	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
69003	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
69004	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
69005	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
69006	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69007	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69008	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69009	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Tank Paint Condition	Good	
69010	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	5	
69011	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations This Read Vac	5	
69012	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	177	
69013	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	177	
69014	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Moisture and Leak Free?	y	
69015	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	0	
69016	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69017	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Grounds in Place?	y	
69018	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
69019	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	General Comments		
69020	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Foundation Condition	Good	
69021	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	
69022	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Follow-up Action Required?	n	
69023	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
69024	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
69025	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	
69026	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
69027	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69028	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
69029	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushing Condition	Good	
69030	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69031	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69032	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69033	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69034	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69035	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69036	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69037	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69038	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69039	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushing Condition	Good	
69040	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	82.0	
69041	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	58.0	
69042	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	59.0	
69043	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69044	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69045	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69046	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	7	
69047	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
69048	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Tank Paint Condition	Good	
69049	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	3	
69050	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations This Read Vac	3	
69051	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	164	
69052	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	164	
69053	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Moisture and Leak Free?	y	
69054	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	0	
69055	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69056	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Grounds in Place?	y	
69057	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
69058	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	General Comments		
69059	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Foundation Condition	Good	
69060	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69061	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69062	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69063	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69064	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69065	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69066	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Follow-up Action Required?	n	
69067	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	General Comments		
69068	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	General Comments		
69069	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Maintenance Operations	0	
69070	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
69071	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Follow-up Action Required?	n	
69072	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
69073	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AF	141	
69074	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AL	141	
69075	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
69076	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69077	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
69078	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
69079	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69080	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69081	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69082	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69083	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69084	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69085	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	General Comments		
69086	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
69087	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
69088	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations Ground	0	
69089	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations C Ø	0	
69090	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations B Ø	0	
69091	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations A Ø	0	
69092	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69093	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69094	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69095	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69096	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps A Ø	160.0	
69097	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps B Ø	150.0	
69098	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps C Ø	130.0	
69099	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushing Condition	Good	
69100	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69101	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69102	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
69103	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
69104	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
69105	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
69106	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
69107	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
69108	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	50.0	
69109	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
69110	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
69111	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
69112	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
69113	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69114	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69115	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
69116	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
69117	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
69118	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
69119	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
69120	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
69121	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
69122	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
69123	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69124	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69125	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations A Ø	0	
69126	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations B Ø	0	
69127	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations C Ø	0	
69128	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations Ground	0	
69129	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Follow-up Action Required?	n	
69130	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Follow-up Action Required?	y	
69131	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Foundation Condition	Good	
69132	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
69133	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
69134	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	General Comments		
69135	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	General Comments	This is now inservice.	
69136	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
69137	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
69138	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
69139	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
69140	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
69141	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
69142	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
69143	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
69144	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations	0	
69145	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69146	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69147	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69148	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps A Ø	260.0	
69149	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps B Ø	260.0	
69150	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps C Ø	260.0	
69151	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69152	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
69153	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Trash?	y	
69154	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
69155	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
69156	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
69157	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
69158	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
69159	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
69160	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	General Comments		
69161	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69162	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69163	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69164	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69165	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69166	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69167	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushing Condition	Good	
69168	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	104.0	
69169	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	114.0	
69170	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	112.0	
69171	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69172	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
69173	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
69174	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69175	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
69176	11/19/2019 10:15	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69177	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69178	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	7	
69179	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
69180	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
69181	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
69182	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
69183	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
69184	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
69185	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
69186	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
69187	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
69188	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
69189	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
69190	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
69191	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
69192	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
69193	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
69194	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
69195	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
69196	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
69197	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	General Comments		
69198	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	General Comments	signs of old oil leak, Low oil main tank alarm is in and isolated. Oil is noy low.	
69199	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
69200	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Max	60	°C
69201	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Present	30	°C
69202	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
69203	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
69204	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
69205	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
69206	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
69207	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
69208	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
69209	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
69210	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
69211	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
69212	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
69213	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	60.00	
69214	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
69215	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations	6	
69216	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	13L	
69217	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	738	
69218	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
69219	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
69220	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
69221	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
69222	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations This Read Vac	0	
69223	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Switching Operations	0	
69224	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
69225	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69226	11/19/2019 10:56	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69227	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Moisture and Leak Free?	y	
69228	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Maintenance Operations	0	
69229	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69230	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Grounds in Place?	y	
69231	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	General Comments	Actual Counter, IOC A phase	
69232	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	General Comments		
69233	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Foundation Condition	Good	
69234	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Follow-up Action Required?	n	
69235	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
69236	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
69237	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	General Comments		
69238	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
69239	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
69240	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
69241	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
69242	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
69243	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	General Comments		
69244	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
69245	11/19/2019 13:02	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
69246	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
69247	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
69248	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
69249	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
69250	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
69251	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
69252	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
69253	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
69254	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
69255	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
69256	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
69257	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
69258	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
69259	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69260	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Switching Operations	0	
69261	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
69262	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations This Read Vac	0	
69263	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AL	66	
69264	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	9 Month Operations	3	
69265	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69266	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69267	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69268	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
69269	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
69270	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
69271	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps A Ø	170.0	
69272	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps B Ø	170.0	
69273	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps C Ø	170.0	
69274	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushing Condition	Good	
69275	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69276	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69277	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69278	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69279	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69280	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69281	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69282	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69283	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
69284	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations A Ø	0	
69285	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations B Ø	0	
69286	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations C Ø	3	
69287	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AF	66	
69288	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Moisture and Leak Free?	y	
69289	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Maintenance Operations	0	
69290	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69291	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Grounds in Place?	y	
69292	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	General Comments		
69293	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
69294	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
69295	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations Ground	0	
69296	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Follow-up Action Required?	n	
69297	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Follow-up Action Required?	n	
69298	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Foundation Condition	Good	
69299	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
69300	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
69301	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69302	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Foundation Condition	Good	
69303	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Follow-up Action Required?	n	
69304	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	General Comments		
69305	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	General Comments	c phase ioc	
69306	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Grounds in Place?	y	
69307	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69308	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Maintenance Operations	0	
69309	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Moisture and Leak Free?	y	
69310	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AF	205	
69311	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AL	205	
69312	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
69313	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations A Ø	0	
69314	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations B Ø	0	
69315	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations C Ø	0	
69316	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations Ground	0	
69317	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
69318	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Follow-up Action Required?	n	
69319	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	General Comments		
69320	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	General Comments		
69321	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
69322	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Maintenance Operations	0	
69323	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AF	851	
69324	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AL	851	
69325	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations This Read AM	0	
69326	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Switching Operations	0	
69327	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Unknown Operations	0	
69328	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
69329	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
69330	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
69331	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
69332	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
69333	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
69334	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	OK	
69335	11/19/2019 13:47	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
69336	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	General Comments		
69337	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
69338	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Heater is not working in LTC Cabinet. It has voltage	
69339	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
69340	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
69341	11/19/2019 10:38	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
69342	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69343	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Maintenance Operations	0	
69344	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations Counter AF	44	
69345	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations Counter AL	44	
69346	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations This Read Vac	0	
69347	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
69348	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Foundation Condition	Good	
69349	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Follow-up Action Required?	n	
69350	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
69351	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations Ground	0	
69352	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations C Ø	0	
69353	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations B Ø	0	
69354	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations A Ø	0	
69355	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69356	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC000027	LTCControl	415-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
69357	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Switching Operations	0	
69358	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
69359	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
69360	11/19/2019 7:46	Distribution	Ghent City Quarterly Inspection	LTC000027	LTCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
69361	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69362	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69363	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69364	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69365	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69366	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69367	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69368	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69369	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushing Condition	Good	
69370	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps C Ø	30.0	
69371	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps B Ø	50.0	
69372	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps A Ø	50.0	
69373	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Unknown Operations	0	
69374	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
69375	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	General Comments		
69376	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69377	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
69378	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
69379	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
69380	11/19/2019 9:13	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
69381	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69382	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69383	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69384	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations	0	
69385	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Tank Paint Condition	Good	
69386	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
69387	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps B Ø	150.0	
69388	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps A Ø	160.0	
69389	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
69390	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
69391	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
69392	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
69393	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
69394	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
69395	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
69396	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
69397	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
69398	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
69399	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
69400	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
69401	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
69402	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
69403	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
69404	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
69405	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Months Operations	0	
69406	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	General Comments		
69407	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
69408	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	60	°C
69409	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	35	°C
69410	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
69411	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
69412	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	General Comments	OK	
69413	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
69414	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69415	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69416	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps A Ø	0.0	
69417	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps B Ø	0.0	
69418	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps C Ø	0.0	
69419	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69420	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushing Condition	Good	
69421	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps C Ø	80.0	
69422	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps B Ø	90.0	
69423	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69424	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69425	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69426	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps A Ø	90.0	
69427	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69428	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations A Ø	0	
69429	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations B Ø	0	
69430	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations C Ø	0	
69431	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations Ground	0	
69432	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69433	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69434	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69435	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	9 Month Operations	0	
69436	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Tank Paint Condition	Good	
69437	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Switching Operations	0	
69438	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Max	65	°C
69439	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Present	35	°C
69440	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
69441	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
69442	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
69443	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
69444	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
69445	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
69446	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations This Read Vac	0	
69447	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AL	89	
69448	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AF	89	
69449	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
69450	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
69451	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69452	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
69453	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
69454	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
69455	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
69456	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
69457	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
69458	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
69459	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
69460	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
69461	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
69462	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
69463	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
69464	11/19/2019 11:49	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
69465	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations This Read Vac	3	
69466	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
69467	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Switching Operations	0	
69468	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Tank Paint Condition	Good	
69469	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
69470	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations Ground	0	
69471	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations C Ø	0	
69472	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations B Ø	0	
69473	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations A Ø	0	
69474	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69475	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69476	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69477	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69478	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69479	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69480	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1214	
69481	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
69482	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
69483	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
69484	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69485	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
69486	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
69487	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
69488	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
69489	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Unknown Operations	0	
69490	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Switching Operations	0	
69491	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations This Read AM	0	
69492	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AL	404	
69493	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AF	404	
69494	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Maintenance Operations	0	
69495	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps C Ø	130.0	
69496	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
69497	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
69498	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
69499	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
69500	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations A Ø	0	
69501	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations B Ø	0	
69502	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations C Ø	0	
69503	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations Ground	0	
69504	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69505	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69506	11/19/2019 13:43	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations	0	
69507	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2691.36	kw
69508	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
69509	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
69510	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
69511	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
69512	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
69513	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
69514	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
69515	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
69516	11/19/2019 8:40	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
69517	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
69518	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Follow-up Action Required?	n	
69519	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	General Comments		
69520	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	General Comments		
69521	11/19/2019 7:01	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
69522	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
69523	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
69524	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
69525	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
69526	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
69602	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69603	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69604	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69605	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69606	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
69607	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
69608	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
69609	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
69610	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69611	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
69612	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
69613	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
69614	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
69615	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1159	
69616	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1159	
69617	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
69618	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
69619	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
69620	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
69621	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69622	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69623	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69624	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69625	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69626	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69627	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
69628	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
69629	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
69630	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
69631	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69632	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
69633	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	WB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
69634	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
69635	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69636	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
69637	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
69638	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
69639	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
69640	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
69641	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
69642	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
69643	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
69644	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
69645	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
69646	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
69647	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
69648	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
69649	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
69650	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
69651	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
69652	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
69653	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
69654	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
69655	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99955	
69656	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99955	
69657	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
69658	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
69659	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	*F
69660	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
69661	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
69662	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
69663	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
69664	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
69665	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
69666	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
69667	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
69668	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
69669	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
69670	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
69671	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
69672	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
69673	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
69674	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
69675	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
69676	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	3	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69677	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
69678	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
69679	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
69680	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
69681	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
69682	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
69683	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	General Comments		
69684	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
69685	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
69686	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
69687	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	General Comments	OK	
69688	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
69689	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Vegetation	None	
69690	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
69691	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
69692	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
69693	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	General Comments		
69694	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
69695	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
69696	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
69697	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
69698	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
69699	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69700	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushing Condition	Good	
69701	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps C Ø	131.0	
69702	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
69703	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
69704	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.8	VDC
69705	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps B Ø	130.0	
69706	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps A Ø	102.0	
69707	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
69708	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
69709	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
69710	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
69711	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
69712	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
69713	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
69714	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
69715	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
69716	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
69717	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
69718	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
69719	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
69720	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
69721	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Vegetation	None	
69722	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
69723	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
69724	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
69725	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	General Comments	Unit is offline	
69726	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
69727	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
69728	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	General Comments		
69729	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
69730	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
69731	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
69732	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
69733	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
69734	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
69735	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Trash?	y	
69736	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
69737	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
69738	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
69739	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	General Comments		
69740	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
69741	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
69742	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Foundation Condition	Good	
69743	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
69744	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
69745	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
69746	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
69747	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
69748	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
69749	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
69750	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
69751	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69752	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
69753	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
69754	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
69755	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
69756	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
69757	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
69758	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
69759	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
69760	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
69761	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
69762	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
69763	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69764	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
69765	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
69766	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	FE000502	Fence	733-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69767	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Follow-up Action Required?	n	
69768	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
69769	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	General Comments		
69770	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
69771	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	General Comments		
69772	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
69773	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
69774	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Foundation Condition	Good	
69775	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
69776	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
69777	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
69778	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
69779	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
69780	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
69781	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
69782	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
69783	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
69784	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
69785	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
69786	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
69787	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
69788	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
69789	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BCH000596	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
69790	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations	6	
69791	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69792	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69793	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69794	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps A Ø	33.0	
69795	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps B Ø	38.0	
69796	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps C Ø	51.0	
69797	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushing Condition	Good	
69798	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushings Connection/Risers	Good	
69799	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69800	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69801	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
69802	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	5	*C
69803	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	*C
69804	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	5	*C
69805	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	*C
69806	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	5	*C
69807	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	*C
69808	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
69809	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40	
69810	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	*C
69811	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
69812	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	ST000511	Structure	733-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
69813	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	YD000508	Yard	733-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
69814	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69815	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69816	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
69817	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations	5	
69818	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
69819	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
69820	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
69821	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Foundation Condition	Good	
69822	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
69823	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
69824	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	General Comments		
69825	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
69826	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69827	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
69828	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69829	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
69830	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
69831	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
69832	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
69833	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
69834	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
69835	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
69836	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.8	VDC
69837	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	General Comments		
69838	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
69839	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69840	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
69841	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
69842	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
69843	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
69844	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
69845	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
69846	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
69847	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
69848	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
69849	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
69850	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
69851	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
69852	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
69853	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
69854	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
69855	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
69856	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	41	*F
69857	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
69858	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
69859	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
69860	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	LTC Totalizer Reading	3043.44	kw
69861	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
69862	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
69863	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Max	40	°C
69864	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Present	30	°C
69865	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
69866	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
69867	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
69868	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
69869	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
69870	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
69871	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
69872	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
69873	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Reading	.8454	
69874	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
69875	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
69876	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
69877	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
69878	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
69879	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69880	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
69881	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69882	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
69883	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
69884	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
69885	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
69886	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
69887	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
69888	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
69889	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
69890	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
69891	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
69892	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
69893	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
69894	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
69895	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
69896	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
69897	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
69898	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
69899	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
69900	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69901	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence 25' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69902	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Follow-up Action Required?	n	
69903	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations Ground	0	
69904	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations C Ø	0	
69905	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations B Ø	0	
69906	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations A Ø	0	
69907	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
69908	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
69909	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
69910	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
69911	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
69912	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
69913	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	General Comments		
69914	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
69915	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
69916	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
69917	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
69918	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
69919	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
69920	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
69921	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
69922	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
69923	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
69924	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
69925	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
69926	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
69927	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
69928	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	251	
69929	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
69930	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69931	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
69932	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
69933	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
69934	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
69935	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
69936	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
69937	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
69938	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
69939	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
69940	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
69941	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
69942	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
69943	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	18.0	VDC
69944	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
69945	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
69946	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	General Comments		
69947	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Found Counter	267377	
69948	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Left Counter	267377	
69949	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Current Tap Position	7L	
69950	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Present	30	°C
69951	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
69952	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
69953	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
69954	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
69955	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
69956	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
69957	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
69958	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
69959	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
69960	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
69961	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	General Comments		
69962	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
69963	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Max Tap Position	7L	
69964	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Min Tap Position	12L	
69965	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Operations Since Last Insp	2679	
69966	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
69967	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
69968	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
69969	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
69970	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Trash?	y	
69971	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	167	
69972	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	167	
69973	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
69974	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
69975	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
69976	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
69977	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	250.0	
69978	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
69979	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	240.0	
69980	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
69981	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
69982	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
69983	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
69984	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
69985	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
69986	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	General Comments		
69987	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
69988	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
69989	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
69990	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
69991	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Max	40	°C
69992	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
69993	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
69994	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
69995	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	17.58	
69996	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	17.58	
69997	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
69998	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
69999	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70000	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	8	
70001	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
70002	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
70003	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
70004	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
70005	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
70006	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
70007	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
70008	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
70009	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
70010	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
70011	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
70012	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
70013	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
70014	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
70015	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
70016	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
70017	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
70018	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
70019	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
70020	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
70021	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
70022	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
70023	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
70024	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
70025	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
70026	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
70027	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
70028	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
70029	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70030	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
70031	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
70032	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70033	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70034	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70035	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70036	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
70037	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70038	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70039	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
70040	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Max	60	°C
70041	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Present	40	°C
70042	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70043	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
70044	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
70045	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
70046	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70047	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70048	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70049	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
70050	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70051	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70052	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
70053	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
70054	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
70055	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
70056	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
70057	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
70058	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
70059	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
70060	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
70061	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
70062	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
70063	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
70064	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
70065	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
70066	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
70067	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
70068	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
70069	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
70070	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
70071	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	General Comments		
70072	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
70073	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	LTC Totalizer Reading	5814.72	kw
70074	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
70075	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
70076	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Max	35	°C
70077	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	General Comments		
70078	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
70079	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
70080	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
70081	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70082	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
70083	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
70084	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
70085	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70086	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
70087	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
70088	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
70089	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
70090	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
70091	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70092	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Present	27	°C
70093	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70094	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
70095	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70096	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70097	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
70098	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70099	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
70100	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
70101	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
70102	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
70103	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
70104	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
70105	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Vegetation	None	
70106	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps B Ø	120.0	
70107	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps A Ø	120.0	
70108	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
70109	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
70110	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70111	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations	3	
70112	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
70113	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Follow-up Action Required?	n	
70114	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70115	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
70116	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
70117	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
70118	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
70119	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70120	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Follow-up Action Required?	n	
70121	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
70122	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
70123	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	General Comments		
70124	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	General Comments		
70125	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
70126	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	LTC Totalizer Reading	1625.60	kw

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
70127	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
70128	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70129	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
70130	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70131	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
70132	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	General Comments		
70133	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
70134	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
70135	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
70136	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
70137	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
70138	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
70139	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Trash?	y	
70140	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
70141	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
70142	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
70143	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
70144	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	General Comments		
70145	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
70146	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
70147	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70148	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
70149	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
70150	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70151	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
70152	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Present	40	*C
70153	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70154	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
70155	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
70156	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
70157	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
70158	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	General Comments		
70159	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
70160	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70161	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70162	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70163	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Operations Since Last Insp	910	
70164	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Min Tap Position	1L	
70165	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Max Tap Position	6R	
70166	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
70167	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Foundation Condition	Good	
70168	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
70169	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
70170	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
70171	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	General Comments		
70172	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70173	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
70174	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
70175	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
70176	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70177	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
70178	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6342	
70179	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
70180	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70181	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
70182	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
70183	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
70184	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
70185	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
70186	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
70187	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
70188	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Current Tap Position	2R	
70189	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70190	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Left Counter	205717	
70191	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70192	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70193	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70194	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	416	
70195	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
70196	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
70197	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	5L	
70198	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
70199	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70200	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	778214	
70201	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	778202	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
70202	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
70203	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70204	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
70205	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
70206	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
70207	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
70208	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.3	VDC
70209	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70210	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
70211	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
70212	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
70213	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
70214	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
70215	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
70216	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70217	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
70218	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
70219	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
70220	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70221	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
70222	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Reading	.2032	
70223	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
70224	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
70225	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
70226	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
70227	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
70228	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70229	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
70230	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Reading	.8076	
70231	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
70232	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
70233	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70234	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
70235	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70236	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
70237	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
70238	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
70239	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
70240	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
70241	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70242	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
70243	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70244	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70245	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
70246	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
70247	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
70248	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
70249	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
70250	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
70251	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70252	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
70253	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70254	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
70255	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
70256	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
70257	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	General Comments		
70258	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	General Comments		
70259	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
70260	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
70261	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
70262	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1522.08	kw
70263	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
70264	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
70265	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
70266	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations This Read Vac	1	
70267	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Switching Operations	0	
70268	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Tank Paint Condition	Good	
70269	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Unknown Operations	0	
70270	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
70271	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
70272	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
70273	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Trash?	y	
70274	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
70275	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
70276	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
70277	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
70278	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
70279	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
70280	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	General Comments		
70281	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
70282	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Vegetation	None	
70283	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
70284	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
70285	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
70286	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
70287	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
70288	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
70289	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
70290	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
70291	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
70292	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
70293	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
70294	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
70295	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations This Read Vac	1	
70296	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AL	177	
70297	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AF	177	
70298	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Moisture and Leak Free?	y	
70299	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	251	
70300	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
70301	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
70302	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Maintenance Operations	1	
70303	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70304	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Grounds in Place?	y	
70305	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	General Comments		
70306	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	General Comments		
70307	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Foundation Condition	Good	
70308	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Follow-up Action Required?	n	
70309	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Follow-up Action Required?	n	
70310	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations Ground	0	
70311	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations C Ø	0	
70312	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations B Ø	0	
70313	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations A Ø	0	
70314	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
70315	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70316	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70317	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
70318	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
70319	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70320	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
70321	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
70322	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
70323	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Found Counter	211372	
70324	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Left Counter	211372	
70325	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70326	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
70327	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
70328	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
70329	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
70330	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
70331	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
70332	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.1	VDC
70333	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
70334	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
70335	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	942	
70336	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70337	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70338	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
70339	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
70340	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	General Comments		
70341	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	General Comments		
70342	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Found Counter	2126	
70343	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Left Counter	2136	
70344	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70345	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Current Tap Position	8L	
70346	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Max Tap Position	6L	
70347	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Min Tap Position	11L	
70348	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Operations Since Last Insp	543	
70349	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70350	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
70351	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70352	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations A Ø	0	
70353	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations B Ø	0	
70354	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations C Ø	0	
70355	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations Ground	0	
70356	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Follow-up Action Required?	n	
70357	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Follow-up Action Required?	n	
70358	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Foundation Condition	Good	
70359	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
70360	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70361	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
70362	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
70363	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70364	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70365	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70366	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70367	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Unknown Operations	0	
70368	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Tank Paint Condition	Good	
70369	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Switching Operations	0	
70370	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
70371	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
70372	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	General Comments		
70373	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	General Comments		
70374	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Grounds in Place?	y	
70375	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70376	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Maintenance Operations	1	
70377	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Moisture and Leak Free?	y	
70378	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AF	204	
70379	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AL	204	
70380	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
70381	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
70382	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
70383	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
70384	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70385	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
70386	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
70387	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
70388	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
70389	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70390	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70391	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70392	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
70393	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
70394	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
70395	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
70396	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
70397	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
70398	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
70399	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
70400	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
70401	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
70402	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
70403	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
70404	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	General Comments		
70405	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
70406	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
70407	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Foundation Condition	Good	
70408	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
70409	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
70410	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
70411	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
70412	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
70413	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
70414	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
70415	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Vegetation	None	
70416	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
70417	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	General Comments		
70418	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
70419	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
70420	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
70421	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
70422	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
70423	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
70424	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Trash?	y	
70425	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
70426	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
70427	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
70428	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
70429	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	General Comments		
70430	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
70431	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
70432	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70433	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushings Connection/Risers	Good	
70434	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushing Condition	Good	
70435	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps C Ø	120.0	
70436	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70437	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	General Comments		
70438	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	General Comments		
70439	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
70440	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
70441	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	636.48	kw
70442	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
70443	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
70444	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Max	0	*C
70445	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Present	35	*C
70446	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70447	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
70448	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
70449	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
70450	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
70451	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
70452	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
70453	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
70454	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70455	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
70456	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
70457	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70458	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
70459	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5304	
70460	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
70461	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
70462	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
70463	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
70464	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
70465	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
70466	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
70467	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	General Comments		
70468	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	General Comments	max temp needle is broke	
70469	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
70470	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
70471	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
70472	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
70473	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Max	0	*C
70474	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Present	35	*C
70475	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70476	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
70477	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70478	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
70479	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
70480	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
70481	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
70482	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
70483	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
70484	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
70485	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
70486	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
70487	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
70488	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70489	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70490	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70491	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
70492	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	505	
70493	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	505	
70494	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
70495	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
70496	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushing Condition	Good	
70497	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps C Ø	0.0	
70498	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps B Ø	0.0	
70499	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps A Ø	0.0	
70500	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
70501	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70502	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70503	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations	1	
70504	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Grounds in Place?	y	
70505	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	General Comments		
70506	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	General Comments		
70507	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Gauge(s) Condition	Good	
70508	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Foundation Condition	Good	
70509	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Follow-up Action Required?	n	
70510	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Follow-up Action Required?	n	
70511	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Fault Operations	0	
70512	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Equipment Properly Labeled?	y	
70513	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Paint Condition	Good	
70514	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70515	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
70516	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Bushings Connection/Risers	Good	
70517	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Ambient Temperature	50	*F
70518	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations B Ø	0	
70519	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations C Ø	0	
70520	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
70521	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
70522	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
70523	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
70524	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
70525	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
70526	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Operations Counter	173	
70527	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	17.58	
70528	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations Ground	0	
70529	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Follow-up Action Required?	n	
70530	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Follow-up Action Required?	n	
70531	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Foundation Condition	Good	
70532	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.5	VDC
70533	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.5	VDC
70534	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
70535	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
70536	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
70537	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
70538	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Leaks	None	
70539	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
70540	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	General Comments		
70541	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	General Comments		
70542	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Grounds in Place?	y	
70543	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	17.58	
70544	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	17.58	
70545	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70546	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70547	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	35	*C
70548	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	40	*C
70549	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6786	
70550	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Max Tap Position	9L	
70551	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Min Tap Position	3R	
70552	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Operations Since Last Insp	876	
70553	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70554	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
70555	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70556	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70557	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70558	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Grounds in Place?	y	
70559	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	General Comments		
70560	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	General Comments		
70561	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Foundation Condition	Good	
70562	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Follow-up Action Required?	n	
70563	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
70564	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations Ground	0	
70565	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations C Ø	0	
70566	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations B Ø	0	
70567	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations A Ø	0	
70568	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
70569	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
70570	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
70571	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
70572	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC000033	LTCControl	888-1	LTC Control Insp	All Connections OK?	y	
70573	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC000033	LTCControl	888-1	LTC Control Insp	Follow-up Action Required?	n	
70574	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC000033	LTCControl	888-1	LTC Control Insp	General Comments		
70575	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC000033	LTCControl	888-1	LTC Control Insp	LTC Operation Checked?	y	
70576	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC000033	LTCControl	888-1	LTC Control Insp	LTC Output Voltage Level	122.5	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70577	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps A Ø	132.0	
70578	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
70579	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps C Ø	106.0	
70580	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
70581	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
70582	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
70583	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
70584	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
70585	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
70586	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
70587	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
70588	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
70589	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
70590	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70591	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70592	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70593	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70594	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70595	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
70596	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	General Comments		
70597	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
70598	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
70599	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
70600	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
70601	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
70602	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
70603	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
70604	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
70605	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
70606	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70607	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
70608	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70609	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	35 °C	
70610	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	40 °C	
70611	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
70612	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
70613	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6514.56 kw	
70614	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
70615	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0 psi	
70616	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0 amps	
70617	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
70618	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
70619	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
70620	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
70621	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
70622	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
70623	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
70624	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
70625	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
70626	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
70627	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
70628	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Reading	.4240	
70629	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
70630	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70631	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
70632	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
70633	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
70634	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
70635	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
70636	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
70637	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
70638	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
70639	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70640	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70641	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1895	
70642	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
70643	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
70644	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
70645	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70646	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	229663	
70647	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70648	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70649	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
70650	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	General Comments		
70651	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70652	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
70653	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70654	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70655	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70656	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70657	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
70658	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70659	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
70660	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
70661	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
70662	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70663	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70664	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70665	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
70666	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
70667	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	134.0	
70668	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	151.0	
70669	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	144.0	
70670	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
70671	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Months Operations	12	
70672	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
70673	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
70674	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
70675	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps A Ø	20.0	
70676	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps B Ø	20.0	
70677	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps C Ø	20.0	
70678	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
70679	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
70680	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
70681	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations A Ø	0	
70682	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70683	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70684	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70685	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations B Ø	0	
70686	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations C Ø	0	
70687	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations Ground	0	
70688	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Follow-up Action Required?	n	
70689	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.3	VDC
70690	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
70691	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
70692	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	171	
70693	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	171	
70694	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
70695	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
70696	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70697	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
70698	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
70699	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
70700	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
70701	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
70702	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70703	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Maintenance Operations	0	
70704	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
70705	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
70706	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
70707	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	General Comments	IOC A, B and C Phase	
70708	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Maintenance Operations	0	
70709	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AF	31	
70710	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AL	31	
70711	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations This Read AM	0	
70712	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Switching Operations	0	
70713	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Unknown Operations	0	
70714	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
70715	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
70716	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
70717	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
70718	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
70719	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
70720	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
70721	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
70722	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
70723	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
70724	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
70725	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
70726	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70727	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	General Comments		
70728	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	Follow-up Action Required?	n	
70729	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	All Connections OK?	y	
70730	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps C Ø	50.0	
70731	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps B Ø	0.0	
70732	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps A Ø	100.0	
70733	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
70734	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
70735	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
70736	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Months Operations	7	
70737	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Tank Paint Condition	Good	
70738	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Switching Operations	0	
70739	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
70740	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Pressure Indicator	good	
70741	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
70742	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
70743	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Bushing Condition	Good	
70744	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations This Read SF6	0	
70745	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AL	1012	
70746	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AF	1012	
70747	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Num Operations Last 9 Months	13	
70748	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Moisture and Leak Free?	y	
70749	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Maintenance Operations	0	
70750	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Heaters (All) Functioning?	y	
70751	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
70752	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
70753	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
70754	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
70755	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
70756	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
70757	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	General Comments		
70758	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
70759	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
70760	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
70761	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
70762	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	General Comments		
70763	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
70764	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
70765	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
70766	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
70767	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
70768	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
70769	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
70770	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
70771	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AL	240	
70772	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AF	240	
70773	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Maintenance Operations	0	
70774	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	General Comments	IOC A and B Phase	
70775	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Follow-up Action Required?	n	
70776	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations Ground	0	
70777	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations C Ø	0	
70778	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations B Ø	0	
70779	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations A Ø	0	
70780	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
70781	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70782	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
70783	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70784	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations This Read AM	1	
70785	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Switching Operations	0	
70786	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Unknown Operations	1	
70787	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70788	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70789	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70790	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
70791	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
70792	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
70793	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
70794	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
70795	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
70796	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
70797	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
70798	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
70799	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
70800	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
70801	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70802	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Time Delay	30	Seconds
70803	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
70804	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
70805	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
70806	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
70807	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
70808	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
70809	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
70810	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
70811	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
70812	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
70813	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
70814	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
70815	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
70816	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
70817	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
70818	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
70819	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
70820	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
70821	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments		
70822	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
70823	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
70824	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
70825	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
70826	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
70827	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
70828	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Found Counter	2525	
70829	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	General Comments		
70830	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	General Comments		
70831	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
70832	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Follow-up Action Required?	n	
70833	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations	1	
70834	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70835	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
70836	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
70837	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
70838	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
70839	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps A Ø	69.0	
70840	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps B Ø	129.0	
70841	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps C Ø	63.0	
70842	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushing Condition	Good	
70843	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
70844	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70845	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70846	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70847	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70848	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70849	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
70850	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
70851	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
70852	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations A Ø	0	
70853	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
70854	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
70855	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
70856	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
70857	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
70858	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
70859	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
70860	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
70861	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
70862	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
70863	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
70864	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Vent Fan does not work	
70865	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Unknown Operations	0	
70866	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
70867	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Switching Operations	0	
70868	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
70869	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations This Read Vac	1	
70870	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AL	68	
70871	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AF	68	
70872	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
70873	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Maintenance Operations	1	
70874	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
70875	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	General Comments		
70876	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70877	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Found Counter	45143	
70878	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Left Counter	45147	
70879	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70880	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Current Tap Position	3L	
70881	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Regulator As Left Counter	26838	
70882	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
70883	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Leaks	None	
70884	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
70885	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
70886	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
70887	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
70888	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
70889	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
70890	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
70891	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
70892	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Follow-up Action Required?	n	
70893	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
70894	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
70895	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
70896	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
70897	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
70898	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
70899	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
70900	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
70901	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
70902	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	3	
70903	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
70904	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
70905	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
70906	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
70907	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	172	
70908	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	172	
70909	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
70910	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
70911	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
70912	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
70913	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
70914	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
70915	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
70916	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
70917	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
70918	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
70919	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
70920	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
70921	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
70922	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
70923	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
70924	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
70925	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	General Comments		
70926	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
70927	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
70928	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Operations Since Last Insp	43	
70929	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
70930	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Min Tap Position	10L	
70931	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Max Tap Position	6R	
70932	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Current Tap Position	4L	
70933	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
70934	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
70935	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
70936	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Left Counter	2527	
70937	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
70938	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
70939	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
70940	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	985	
70941	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	985	
70942	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
70943	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
70944	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00 %	
70945	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00 %	
70946	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00 %	
70947	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	65.0	
70948	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	63.0	
70949	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	58.0	
70950	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
70951	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
70952	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70953	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70954	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70955	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Leaks	None	
70956	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
70957	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
70958	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Regulator As Left Counter	356181	
70959	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
70960	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
70961	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
70962	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
70963	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
70964	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
70965	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	14	
70966	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70967	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
70968	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
70969	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
70970	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
70971	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	17.58	
70972	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	120.0	
70973	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB000156	BreakerVacuum	786-2541	VCB Readings	Unknown Operations	0	
70974	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
70975	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
70976	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	287	
70977	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	117.0	
70978	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	118.0	
70979	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
70980	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
70981	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
70982	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
70983	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
70984	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
70985	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
70986	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
70987	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
70988	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
70989	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
70990	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
70991	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
70992	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Vegetation	None	
70993	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
70994	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
70995	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
70996	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
70997	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
70998	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
70999	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
71000	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
71001	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
71002	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
71003	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	General Comments		
71004	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
71005	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
71006	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Foundation Condition	Good	
71007	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
71008	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
71009	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
71010	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
71011	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71012	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	General Comments		
71013	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	General Comments		
71014	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
71015	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
71016	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
71017	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	General Comments		
71018	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
71019	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
71020	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
71021	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
71022	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
71023	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
71024	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
71025	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.600	millivolts
71026	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71027	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
71028	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
71029	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	9	
71030	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	36	
71031	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
71032	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
71033	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
71034	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
71035	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	120.0	
71036	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
71037	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
71038	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
71039	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
71040	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
71041	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
71042	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
71043	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
71044	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
71045	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
71046	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
71047	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
71048	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
71049	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
71050	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations A Ø	0	
71051	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations B Ø	0	
71052	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations C Ø	0	
71053	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations Ground	0	
71054	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Follow-up Action Required?	n	
71055	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Follow-up Action Required?	n	
71056	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
71057	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Foundation Condition	Good	
71058	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	General Comments		
71059	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
71060	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
71061	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3	amps
71062	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
71063	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
71064	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	General Comments		
71065	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Grounds in Place?	y	
71066	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Heaters (All) Functioning?	y	
71067	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Maintenance Operations	0	
71068	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Moisture and Leak Free?	y	
71069	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AF	194	
71070	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
71071	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	General Comments		
71072	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
71073	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
71074	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
71075	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
71076	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
71077	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
71078	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AL	194	
71079	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
71080	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
71081	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	10	
71082	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	10	
71083	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
71084	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
71085	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations This Read Vac	0	
71086	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Switching Operations	0	
71087	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Tank Paint Condition	Good	
71088	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Unknown Operations	0	
71089	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	BCH000393	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
71090	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
71091	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
71092	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
71093	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
71094	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
71095	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
71096	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	General Comments		
71097	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Found Counter	44647	
71098	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Left Counter	44647	
71099	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7R	
71100	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	326	
71101	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71102	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
71103	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
71104	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
71105	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Tank Paint Condition	Good	
71106	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Switching Operations	0	
71107	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
71108	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations This Read Vac	0	
71109	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AL	171	
71110	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	287	
71111	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
71112	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
71113	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
71114	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
71115	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
71116	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
71117	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
71118	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
71119	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
71120	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
71121	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
71122	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
71123	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
71124	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
71125	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
71126	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
71127	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
71128	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
71129	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
71130	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
71131	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	400.0	
71132	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
71133	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	400.0	
71134	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
71135	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
71136	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
71137	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
71138	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
71139	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
71140	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	90	Seconds
71141	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AF	171	
71142	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Moisture and Leak Free?	y	
71143	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Maintenance Operations	0	
71144	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
71145	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Grounds in Place?	y	
71146	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	General Comments		
71147	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	General Comments		
71148	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Foundation Condition	Good	
71149	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Follow-up Action Required?	n	
71150	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
71151	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
71152	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
71153	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
71154	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	General Comments	OK	
71155	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
71156	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
71157	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
71158	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71159	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	LTC Totalizer Reading	2544.00	kw
71160	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
71161	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	General Comments		
71162	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	General Comments		
71163	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71164	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
71165	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Readings	Follow-up Action Required?	n	
71166	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71167	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
71168	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
71169	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
71170	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
71171	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
71172	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
71173	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
71174	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71175	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
71176	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71177	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
71178	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
71179	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
71180	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
71181	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
71182	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
71183	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
71184	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
71185	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
71186	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.7	VDC
71187	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.9	VDC
71188	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
71189	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71190	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71191	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
71192	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
71193	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
71194	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
71195	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
71196	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
71197	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
71198	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
71199	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
71200	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
71201	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Follow-up Action Required?	n	
71202	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Follow-up Action Required?	n	
71203	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
71204	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
71205	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
71206	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
71207	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71208	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
71209	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	General Comments	OK	
71210	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
71211	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
71212	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
71213	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
71214	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71215	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71216	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Present	27	*C
71217	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Max	45	*C
71218	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
71219	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
71220	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	229657	
71221	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
71222	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
71223	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
71224	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
71225	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
71226	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	
71227	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
71228	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
71229	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
71230	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
71231	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
71232	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Moisture and Leak Free?	y	
71233	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AF	285	
71234	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AL	285	
71235	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations This Read Vac	0	
71236	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
71237	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Switching Operations	0	
71238	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Tank Paint Condition	Good	
71239	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Unknown Operations	0	
71240	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
71241	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
71242	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
71243	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
71244	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
71245	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
71246	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
71247	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
71248	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
71249	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
71250	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
71251	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71252	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
71253	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71254	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
71255	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	General Comments		
71256	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71257	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
71258	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71259	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
71260	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
71261	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71262	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
71263	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
71264	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
71265	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
71266	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
71267	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
71268	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
71269	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
71270	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
71271	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
71272	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
71273	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
71274	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
71275	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
71276	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
71277	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
71278	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
71279	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
71280	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
71281	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
71282	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
71283	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
71284	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC0000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AF	121.5	VAC
71285	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC0000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AL	121.5	VAC
71286	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	LTC0000033	LTCControl	888-1	LTC Control Insp	VRR Time Delay	60	Seconds
71287	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTC0000025	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
71288	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
71289	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
71290	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTC0000025	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
71291	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
71292	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTC0000025	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments		
71293	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTC0000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
71294	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	LTC0000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.1	VAC
71295	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
71296	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
71297	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
71298	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Trash?	y	
71299	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
71300	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
71301	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
71302	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
71303	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
71304	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
71305	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
71306	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
71307	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
71308	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
71309	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
71310	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	General Comments		
71311	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
71312	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
71313	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
71314	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
71315	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
71316	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
71317	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
71318	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
71319	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
71320	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
71321	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
71322	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
71323	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4014	
71324	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71325	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71326	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71327	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	General Comments	OK	
71328	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
71329	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
71330	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71331	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
71332	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	General Comments		
71333	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
71334	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
71335	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
71336	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
71337	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
71338	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	General Comments		
71339	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
71340	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
71341	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
71342	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
71343	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
71344	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
71345	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
71346	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
71347	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
71348	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
71349	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
71350	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
71351	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
71352	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71353	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
71354	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
71355	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71356	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	General Comments		
71357	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	General Comments		
71358	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
71359	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
71360	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
71361	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2890.08	kw
71362	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
71363	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
71364	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
71365	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
71366	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Foundation Condition	Good	
71367	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
71368	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
71369	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	General Comments		
71370	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
71371	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
71372	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
71373	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
71374	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
71375	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
71376	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
71377	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
71378	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
71379	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
71380	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
71381	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71382	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71383	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71384	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71385	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
71386	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	General Comments		
71387	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
71388	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
71389	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
71390	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
71391	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
71392	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
71393	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Present	38	°C
71394	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
71395	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
71396	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
71397	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
71398	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
71399	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
71400	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
71401	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71402	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
71403	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
71404	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
71405	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
71406	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
71407	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Top Oil Temperature Max	25	°C
71408	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Top Oil Temperature Present	15	°C
71409	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
71410	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8002	
71411	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
71412	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
71413	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
71414	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Clear of Trash?	y	
71415	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
71416	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
71417	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
71418	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
71419	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
71420	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
71421	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	General Comments	out of service	
71422	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
71423	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
71424	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Vegetation	None	
71425	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector YD000255	Yard	648-Yard	648-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
71426	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Max	32	°C
71427	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
71428	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic BAT001178	Battery	Retired Distribution	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
71429	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic BAT001178	Battery	Retired Distribution	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
71430	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic BAT001178	Battery	Retired Distribution	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
71431	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic BAT001178	Battery	Retired Distribution	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
71432	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	General Comments		
71433	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	General Comments		
71434	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Grounds in Place?	y	
71435	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Heaters (All) Functioning?	y	
71436	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Maintenance Operations	1	
71437	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Moisture and Leak Free?	y	
71438	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AF	1541	
71439	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AL	1541	
71440	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations This Read Vac	4	
71441	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
71442	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71443	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
71444	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71445	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71446	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71447	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71448	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
71449	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
71450	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
71451	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71452	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71453	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
71454	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
71455	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
71456	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
71457	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
71458	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
71459	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
71460	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71461	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
71462	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
71463	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71464	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	General Comments		
71465	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	General Comments		
71466	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
71467	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
71468	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
71469	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
71470	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5761.44	kw
71471	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
71472	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
71473	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
71474	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
71475	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
71476	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71477	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71478	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
71479	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
71480	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
71481	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71482	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
71483	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
71484	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71485	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	General Comments		
71486	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
71487	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Leaks	None	
71488	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
71489	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71490	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Regulator As Left Counter	270016	
71491	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
71492	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
71493	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
71494	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71495	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71496	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
71497	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
71498	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
71499	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	General Comments		
71500	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71501	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
71502	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71503	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	counters we dine wrongnlast time	
71504	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
71505	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
71506	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	411	
71507	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
71508	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
71509	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	461	
71510	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.0	
71511	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	29.3	
71512	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.0	
71513	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	383	
71514	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
71515	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Leaks	None	
71516	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
71517	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71518	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Regulator As Left Counter	143157	
71519	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
71520	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
71521	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
71522	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71523	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71524	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
71525	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
71526	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
71527	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	General Comments		
71528	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71529	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
71530	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
71531	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71532	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
71533	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71534	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71535	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71536	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71537	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
71538	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
71539	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Leaks	None	
71540	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
71541	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71542	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34377	
71543	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
71544	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
71545	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
71546	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71547	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71548	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
71549	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
71550	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
71551	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
71552	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71553	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
71554	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
71555	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71556	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
71557	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71558	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71559	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71560	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71561	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
71562	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations	3	
71563	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71564	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
71565	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Switching Operations	0	
71566	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Tank Paint Condition	Good	
71567	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Unknown Operations	3	
71568	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
71569	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
71570	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
71571	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Leaks	None	
71572	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71573	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Regulator As Left Counter	68689	
71574	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
71575	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
71576	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
71577	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71578	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71579	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
71580	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
71581	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
71582	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	General Comments		
71583	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71584	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
71585	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
71586	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71587	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
71588	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71589	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71590	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71591	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71592	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
71593	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
71594	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Leaks	None	
71595	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71596	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Regulator As Left Counter	74451	
71597	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
71598	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
71599	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
71600	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71601	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71602	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
71603	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
71604	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
71605	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	General Comments		
71606	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71607	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
71608	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
71609	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71610	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
71611	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71612	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71613	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71614	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71615	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
71616	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2016-02-17 00:00:00.000000	
71617	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
71618	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
71619	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
71620	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
71621	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
71622	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BAT001178	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
71623	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
71624	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
71625	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
71626	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
71627	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Foundation Condition	Good	
71628	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
71629	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
71630	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Leaks	None	
71631	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
71632	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71633	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Regulator As Left Counter	566432	
71634	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
71635	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
71636	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
71637	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71638	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71639	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
71640	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
71641	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
71642	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	General Comments		
71643	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71644	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
71645	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71646	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
71647	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71648	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71649	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71650	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71651	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
71652	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71653	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71654	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71655	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71656	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
71657	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71658	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
71659	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
71660	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71661	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	General Comments		
71662	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
71663	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
71664	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Min Tap Position	1R	
71665	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71666	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71667	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
71668	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
71669	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
71670	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Regulator As Left Counter	74606	
71671	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71672	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Leaks	None	
71673	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
71674	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Unknown Operations	0	
71675	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Tank Paint Condition	Good	
71676	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Switching Operations	3	
71677	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
71678	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations This Read Vac	3	
71679	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AL	494	
71680	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AF	494	
71681	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Moisture and Leak Free?	y	
71682	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Maintenance Operations	0	
71683	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Grounds in Place?	y	
71684	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	General Comments		
71685	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	General Comments		
71686	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Foundation Condition	Good	
71687	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Follow-up Action Required?	n	
71688	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Follow-up Action Required?	n	
71689	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71690	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71691	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
71692	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
71693	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
71694	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
71695	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71696	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44878	
71697	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
71698	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
71699	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
71700	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71701	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
71702	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
71703	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
71704	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
71705	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
71706	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71707	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
71708	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
71709	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71710	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
71711	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71712	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71713	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71714	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71715	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
71716	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
71717	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
71718	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
71719	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
71720	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	0	
71721	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
71722	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	301	
71723	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	301	
71724	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations This Read Vac	0	
71725	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	0	
71726	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
71727	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
71728	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations	4	
71729	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71730	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
71731	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
71732	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps A Ø	20.0	
71733	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps B Ø	10.0	
71734	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps C Ø	20.0	
71735	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushing Condition	Good	
71736	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushings Connection/Risers	Good	
71737	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
71738	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
71739	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
71740	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Paint Condition	Good	
71741	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Equipment Properly Labeled?	y	
71742	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps A Phase V	5.24	
71743	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps B Phase V	5.24	
71744	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps C Phase V	5.24	
71745	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations A Ø	0	
71746	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations B Ø	0	
71747	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations C Ø	0	
71748	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations Ground	0	
71749	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Follow-up Action Required?	n	
71750	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Follow-up Action Required?	n	
71751	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
71752	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
71753	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Broom on Site?	y	
71754	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
71755	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
71756	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
71757	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
71758	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
71759	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
71760	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
71761	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
71762	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
71763	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
71764	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
71765	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
71766	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
71767	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
71768	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
71769	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
71770	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
71771	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
71772	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
71773	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
71774	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
71775	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
71776	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
71777	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71778	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Regulator As Left Counter	65207	
71779	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
71780	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
71781	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
71782	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71783	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71784	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
71785	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
71786	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
71787	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	General Comments		
71788	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71789	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
71790	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
71791	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71792	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
71793	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71794	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71795	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71796	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71797	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
71798	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
71799	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Leaks	None	
71800	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71801	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Regulator As Left Counter	69827	
71802	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
71803	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
71804	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
71805	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71806	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71807	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
71808	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
71809	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
71810	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	General Comments		
71811	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71812	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
71813	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations Ground	0	
71814	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations C Ø	0	
71815	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations B Ø	0	
71816	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations A Ø	0	
71817	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
71818	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
71819	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
71820	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Equipment Properly Labeled?	y	
71821	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Paint Condition	Good	
71822	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
71823	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Leaks	None	
71824	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
71825	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Regulator As Left Counter	35863	
71826	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
71827	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
71828	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
71829	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
71830	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
71831	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panels Dusted?	y	
71832	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
71833	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
71834	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	General Comments		
71835	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
71836	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
71837	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Swept?	y	
71838	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
71839	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
71840	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
71841	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Evidence of Insects	None	
71842	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
71843	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
71844	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
71845	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
71846	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
71847	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
71848	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
71849	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
71850	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
71851	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
71852	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
71853	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
71854	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
71855	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
71856	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
71857	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
71858	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
71859	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
71860	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
71861	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
71862	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
71863	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
71864	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
71865	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushings Connection/Risers	Good	
71866	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushing Condition	Good	
71867	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps C Ø	300.0	
71868	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps B Ø	300.0	
71869	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps A Ø	300.0	
71870	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
71871	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
71872	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71873	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	BB0411	BreakerVacuum	733-2536	VCB Readings	9 Month Operations	9	
71874	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
71875	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
71876	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
71877	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
71878	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
71879	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
71880	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
71881	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
71882	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	General Comments		
71883	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	General Comments		
71884	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
71885	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
71886	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
71887	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
71888	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
71889	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
71890	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
71891	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
71892	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
71893	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
71894	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
71895	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
71896	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
71897	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
71898	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
71899	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
71900	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
71901	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
71902	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
71903	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
71904	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
71905	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
71906	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
71907	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
71908	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
71909	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
71910	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
71911	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
71912	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
71913	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
71914	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
71915	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
71916	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
71917	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
71918	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
71919	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
71920	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
71921	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
71922	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
71923	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
71924	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
71925	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	849	
71926	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	849	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
71927	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
71928	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
71929	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
71930	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
71931	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
71932	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
71933	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
71934	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	General Comments		
71935	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
71936	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
71937	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	*F
71938	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
71939	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
71940	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	General Comments		
71941	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
71942	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
71943	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	General Comments		
71944	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
71945	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
71946	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
71947	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
71948	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
71949	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
71950	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
71951	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
71952	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
71953	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
71954	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
71955	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
71956	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
71957	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
71958	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
71959	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
71960	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
71961	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
71962	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0728	
71963	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
71964	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
71965	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
71966	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
71967	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
71968	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
71969	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
71970	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
71971	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
71972	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
71973	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
71974	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	LTC0000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
71975	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
71976	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
71977	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
71978	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
71979	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Present	35	*C
71980	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Max	35	*C
71981	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
71982	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
71983	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5149.44	kw
71984	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
71985	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
71986	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
71987	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Operations Counter	215	
71988	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
71989	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
71990	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	General Comments	Battery test failed. Batteries are charged to 25.5 but the sel is showing a battery problem.	
71991	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
71992	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
71993	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
71994	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
71995	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
71996	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
71997	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
71998	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
71999	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
72000	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72001	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72002	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
72003	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
72004	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0396	
72005	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
72006	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	52	°C
72007	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	52	°C
72008	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72009	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
72010	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
72011	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Reading	.5334	
72012	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
72013	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72014	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
72015	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
72016	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72017	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72018	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
72019	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72020	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Present	35	°C
72021	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Max	45	°C
72022	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
72023	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
72024	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1474	
72025	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1474	
72026	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
72027	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
72028	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
72029	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
72030	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
72031	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
72032	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
72033	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
72034	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
72035	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
72036	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
72037	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
72038	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
72039	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
72040	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
72041	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
72042	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
72043	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
72044	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
72045	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
72046	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
72047	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
72048	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72049	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72050	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
72051	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72052	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
72053	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
72054	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	31.68	kw
72055	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
72056	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
72057	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
72058	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
72059	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	General Comments		
72060	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
72061	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	233	
72062	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
72063	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
72064	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	245	
72065	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.7	
72066	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.1	
72067	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.8	
72068	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	253	
72069	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
72070	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
72071	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
72072	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72073	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72074	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
72075	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
72076	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
72077	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
72078	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
72079	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72080	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72081	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
72082	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72083	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
72084	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
72085	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
72086	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
72087	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
72088	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
72089	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	General Comments		
72090	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	General Comments		
72091	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72092	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
72093	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
72094	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
72095	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72096	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
72097	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
72098	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72099	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	General Comments		
72100	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	General Comments		
72101	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
72102	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
72103	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
72104	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2527.20	kw
72105	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
72106	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
72107	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
72108	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
72109	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72110	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
72111	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72112	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72113	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
72114	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
72115	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72116	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
72117	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0530	
72118	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
72119	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72120	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72121	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
72122	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72123	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72124	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72125	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Trash?	y	
72126	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
72127	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
72128	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
72129	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
72130	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Leaks	None	
72131	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72132	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Regulator As Left Counter	60723	
72133	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
72134	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
72135	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
72136	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72137	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72138	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
72139	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
72140	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
72141	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	General Comments		
72142	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72143	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
72144	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
72145	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72146	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
72147	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72148	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72149	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72150	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72151	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
72152	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
72153	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72154	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72155	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72156	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72157	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
72158	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72159	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
72160	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
72161	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72162	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	General Comments		
72163	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
72164	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
72165	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
72166	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72167	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72168	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
72169	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
72170	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
72171	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Regulator As Left Counter	102917	
72172	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72173	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Leaks	None	
72174	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
72175	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
72176	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
72177	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
72178	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
72179	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
72180	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
72181	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72182	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	38267	
72183	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
72184	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
72185	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps A Ø	80.0	
72186	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps B Ø	20.0	
72187	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps C Ø	10.0	
72188	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushing Condition	Good	
72189	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
72190	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
72191	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
72192	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
72193	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
72194	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
72195	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps A Phase V	1.75	
72196	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps B Phase V	3.49	
72197	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps C Phase V	1.75	
72198	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations A Ø	0	
72199	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations B Ø	1	
72200	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations C Ø	0	
72201	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations Ground	0	
72202	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Follow-up Action Required?	n	
72203	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Follow-up Action Required?	n	
72204	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Foundation Condition	Good	
72205	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	General Comments		
72206	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	General Comments		
72207	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Grounds in Place?	y	
72208	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
72209	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Maintenance Operations	1	
72210	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Moisture and Leak Free?	y	
72211	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AF	29	
72212	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AL	29	
72213	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations This Read Vac	3	
72214	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Switching Operations	0	
72215	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Tank Paint Condition	Good	
72216	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Unknown Operations	1	
72217	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Months Operations	3	
72218	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
72219	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
72220	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
72221	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps A Ø	100.0	
72222	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps B Ø	100.0	
72223	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps C Ø	100.0	
72224	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
72225	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
72226	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72227	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations A Ø	0	
72228	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations B Ø	0	
72229	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations C Ø	0	
72230	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations Ground	0	
72231	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Follow-up Action Required?	n	
72232	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	General Comments	IOC B and C Phase	
72233	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Maintenance Operations	0	
72234	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AF	112	
72235	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AL	112	
72236	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations This Read AM	1	
72237	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Switching Operations	0	
72238	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Unknown Operations	1	
72239	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
72240	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Vegetation	None	
72241	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
72242	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	General Comments		
72243	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
72244	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72245	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72246	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
72247	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
72248	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
72249	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
72250	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
72251	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
72252	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
72253	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
72254	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
72255	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
72256	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
72257	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
72258	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72259	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72260	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72261	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72262	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72263	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
72264	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
72265	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
72266	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
72267	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
72268	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
72269	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
72270	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
72271	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
72272	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
72273	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
72274	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
72275	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
72276	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
72277	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
72278	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
72279	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
72280	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
72281	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
72282	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
72283	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
72284	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Trash?	y	
72285	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72286	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72287	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72288	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72289	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72290	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
72291	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	General Comments		
72292	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
72293	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
72294	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Vegetation	None	
72295	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
72296	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
72297	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
72298	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
72299	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Negative DC Ground	19.0	VDC
72300	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	General Comments		
72301	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72302	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
72303	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
72304	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
72305	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
72306	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
72307	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
72308	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
72309	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
72310	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72311	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72312	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	4L	
72313	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	9L	
72314	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
72315	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
72316	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72317	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
72318	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
72319	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72320	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
72321	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72322	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72323	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72324	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72325	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
72326	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
72327	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
72328	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
72329	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
72330	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
72331	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
72332	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
72333	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
72334	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
72335	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
72336	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
72337	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
72338	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
72339	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
72340	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Operations Counter	58	
72341	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
72342	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
72343	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	General Comments	counters A 235 B 237 C 258	
72344	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
72345	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
72346	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
72347	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
72348	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
72349	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
72350	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
72351	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
72352	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
72353	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps C Ø	14.0	
72354	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
72355	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
72356	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
72357	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
72358	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
72359	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
72360	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
72361	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
72362	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
72363	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
72364	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
72365	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
72366	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
72367	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
72368	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
72369	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
72370	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
72371	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
72372	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations	1	
72373	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
72374	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
72375	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
72376	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Operations Since Last Insp	951	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72377	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Min Tap Position	3L		
72378	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Max Tap Position	8L		
72379	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Current Tap Position	7L		
72380	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good		
72381	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Left Counter	78648		
72382	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Found Counter	78645		
72383	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	General Comments			
72384	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	General Comments			
72385	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
72386	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectic C0451	LTCMechanism	733-1	LTC Counter Readings	Follow-up Action Required?	n		
72387	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
72388	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72389	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72390	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72391	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72392	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
72393	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72394	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
72395	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
72396	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72397	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	General Comments		
72398	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
72399	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
72400	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
72401	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72402	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72403	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
72404	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
72405	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7 volts	
72406	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Regulator As Left Counter	57228	
72407	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72408	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
72409	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Leaks	None	
72410	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
72411	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
72412	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
72413	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	571	
72414	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	571	
72415	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
72416	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
72417	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
72418	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
72419	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
72420	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
72421	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
72422	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
72423	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
72424	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
72425	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
72426	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
72427	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
72428	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
72429	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
72430	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	70.0	
72431	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00 %	
72432	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00 %	
72433	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps A Ø	145.0	
72434	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps B Ø	145.0	
72435	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps C Ø	145.0	
72436	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushing Condition	Good	
72437	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
72438	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72439	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72440	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72441	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72442	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
72443	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72444	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
72445	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
72446	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72447	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	General Comments	ok	
72448	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
72449	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
72450	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
72451	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72452	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72453	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Unknown Operations	0	
72454	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Tank Paint Condition	Good	
72455	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
72456	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
72457	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
72458	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61499	
72459	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72460	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Leaks	None	
72461	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
72462	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Switching Operations	0	
72463	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations This Read Vac	1	
72464	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AL	151	
72465	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AF	151	
72466	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Moisture and Leak Free?	y	
72467	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Maintenance Operations	1	
72468	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
72469	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Grounds in Place?	y	
72470	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	General Comments		
72471	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	General Comments		
72472	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Foundation Condition	Good	
72473	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Follow-up Action Required?	n	
72474	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Follow-up Action Required?	n	
72475	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations Ground	0	
72476	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations C Ø	0	
72477	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations B Ø	0	
72478	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations A Ø	0	
72479	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
72480	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
72481	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
72482	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
72483	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
72484	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
72485	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
72486	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
72487	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
72488	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushing Condition	Good	
72489	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps C Ø	100.0	
72490	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps B Ø	90.0	
72491	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps A Ø	110.0	
72492	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
72493	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	General Comments		
72494	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
72495	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Vegetation	None	
72496	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
72497	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	General Comments		
72498	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Grounds in Place?	y	
72499	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
72500	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Maintenance Operations	1	
72501	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Moisture and Leak Free?	y	
72502	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AF	80	
72503	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AL	80	
72504	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations This Read Vac	1	
72505	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Switching Operations	0	
72506	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Tank Paint Condition	Good	
72507	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Unknown Operations	0	
72508	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations	3	
72509	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
72510	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
72511	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
72512	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps A Ø	40.0	
72513	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps B Ø	43.0	
72514	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps C Ø	36.0	
72515	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushing Condition	Good	
72516	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushings Connection/Risers	Good	
72517	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
72518	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
72519	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
72520	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Paint Condition	Good	
72521	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Equipment Properly Labeled?	y	
72522	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
72523	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
72524	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
72525	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations A Ø	0	
72526	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
72527	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations C Ø	0		
72528	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations Ground	0		
72529	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Follow-up Action Required?	n		
72530	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Readings	Follow-up Action Required?	n		
72531	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Foundation Condition	Good		
72532	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	General Comments			
72533	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Grounds in Place?	y		
72534	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Heaters (All) Functioning?	y		
72535	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7128	
72536	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
72537	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72538	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
72539	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
72540	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
72541	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Leaks	None	
72542	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72543	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Regulator As Left Counter	102009	
72544	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
72545	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
72546	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
72547	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72548	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72549	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
72550	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
72551	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
72552	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	General Comments		
72553	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72554	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
72555	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
72556	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC0000120	LTCControl	ET-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
72557	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC0000120	LTCControl	ET-TRANS 2	LTC Control Insp	General Comments		
72558	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LTC0000120	LTCControl	ET-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
72559	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
72560	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
72561	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
72562	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
72563	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Vegetation	None	
72564	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
72565	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	General Comments		
72566	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
72567	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72568	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72569	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72570	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72571	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72572	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Trash?	y	
72573	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
72574	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
72575	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
72576	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	General Comments		
72577	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
72578	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
72579	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
72580	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
72581	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
72582	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
72583	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
72584	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
72585	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
72586	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
72587	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
72588	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
72589	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
72590	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
72591	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
72592	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
72593	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
72594	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
72595	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
72596	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
72597	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
72598	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
72599	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations A Ø	0	
72600	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations B Ø	0	
72601	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations C Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
72602	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations Ground	0	
72603	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
72604	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Follow-up Action Required?	n	
72605	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Foundation Condition	Good	
72606	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	General Comments		
72607	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
72608	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
72609	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
72610	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Trash?	y	
72611	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72612	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72613	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72614	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72615	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72616	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
72617	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
72618	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	418	
72619	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	418	
72620	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
72621	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
72622	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
72623	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
72624	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
72625	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
72626	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
72627	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
72628	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
72629	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
72630	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
72631	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
72632	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
72633	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
72634	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
72635	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
72636	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
72637	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Unknown Operations	0	
72638	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Switching Operations	0	
72639	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations This Read AM	0	
72640	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AL	204	
72641	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AF	204	
72642	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Maintenance Operations	0	
72643	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	General Comments	IOC A and B Phase	
72644	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Follow-up Action Required?	n	
72645	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations Ground	0	
72646	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations C Ø	0	
72647	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations B Ø	0	
72648	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations A Ø	0	
72649	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
72650	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
72651	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
72652	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps C Ø	20.0	
72653	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps B Ø	20.0	
72654	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps A Ø	20.0	
72655	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
72656	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
72657	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
72658	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Months Operations	10	
72659	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
72660	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72661	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72662	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72663	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72664	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
72665	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72666	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
72667	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
72668	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72669	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
72670	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
72671	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	9L	
72672	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	4L	
72673	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72674	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72675	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
72676	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72677	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
72678	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	37752	
72679	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
72680	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72681	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
72682	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
72683	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72684	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	General Comments		
72685	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	General Comments		
72686	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
72687	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
72688	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
72689	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
72690	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
72691	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
72692	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
72693	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72694	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
72695	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72696	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72697	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
72698	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
72699	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72700	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
72701	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72702	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72703	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
72704	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
72705	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
72706	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
72707	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
72708	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Reading	.5202	
72709	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
72710	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72711	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
72712	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
72713	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72714	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72715	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
72716	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72717	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Present	30	°C
72718	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Max	40	°C
72719	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
72720	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
72721	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	LTC Totalizer Reading	4993.92	kw
72722	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
72723	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	General Comments		
72724	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	General Comments		
72725	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72726	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
72727	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	Follow-up Action Required?	n	
72728	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72729	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
72730	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
72731	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72732	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
72733	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
72734	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
72735	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
72736	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72737	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
72738	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
72739	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	W0321	WithLTC	648-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
72740	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
72741	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
72742	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
72743	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72744	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
72745	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
72746	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
72747	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Leaks	None	
72748	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72749	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Regulator As Left Counter	57401	
72750	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
72751	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72752	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
72753	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72754	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72755	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
72756	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
72757	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
72758	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	General Comments		
72759	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72760	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
72761	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
72762	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72763	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
72764	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72765	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72766	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72767	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72768	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
72769	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
72770	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
72771	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.0005	
72772	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
72773	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72774	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
72775	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
72776	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72777	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72778	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
72779	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72780	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
72781	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	40	°C
72782	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
72783	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
72784	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	1.20	kw
72785	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
72786	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	General Comments		
72787	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
72788	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72789	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
72790	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
72791	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72792	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72793	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
72794	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
72795	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
72796	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
72797	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
72798	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
72799	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
72800	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
72801	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations	2	
72802	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
72803	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72804	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
72805	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
72806	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
72807	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
72808	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Leaks	None	
72809	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	47	°F
72810	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
72811	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
72812	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
72813	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
72814	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
72815	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
72816	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
72817	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
72818	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
72819	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
72820	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
72821	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
72822	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
72823	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
72824	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
72825	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
72826	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72827	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
72828	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
72829	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
72830	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
72831	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
72832	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
72833	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
72834	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
72835	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
72836	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
72837	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
72838	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
72839	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
72840	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
72841	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
72842	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
72843	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
72844	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
72845	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
72846	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
72847	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
72848	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
72849	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
72850	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Operational?	y	
72851	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Condition	Good	
72852	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
72853	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
72854	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
72855	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	General Comments		
72856	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
72857	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
72858	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
72859	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Operational?	y	
72860	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Condition	Good	
72861	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
72862	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
72863	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
72864	11/20/2019 12:11	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
72865	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
72866	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	General Comments		
72867	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
72868	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
72869	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
72870	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
72871	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
72872	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
72873	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
72874	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
72875	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29145	
72876	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
72877	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Leaks	None	
72878	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
72879	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Unknown Operations	0	
72880	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Tank Paint Condition	Good	
72881	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Switching Operations	0	
72882	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
72883	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations This Read Vac	1	
72884	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AL	216	
72885	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AF	216	
72886	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Moisture and Leak Free?	y	
72887	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Maintenance Operations	1	
72888	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Heaters (All) Functioning?	y	
72889	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Grounds in Place?	y	
72890	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	General Comments		
72891	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	General Comments		
72892	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Foundation Condition	Good	
72893	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Follow-up Action Required?	n	
72894	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Follow-up Action Required?	n	
72895	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations Ground	0	
72896	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations C Ø	0	
72897	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations B Ø	0	
72898	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations A Ø	0	
72899	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
72900	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
72901	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72902	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Equipment Properly Labeled?	y		
72903	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Paint Condition	Good		
72904	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Internal Condition?	Clean		
72905	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Heaters Functioning?	y		
72906	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
72907	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushings Connection/Risers	Good		
72908	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushing Condition	Good		
72909	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Readings	Amps C Ø	25.0		
72910	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Readings	Amps B Ø	23.0		
72911	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Readings	Amps A Ø	24.0		
72912	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
72913	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
72914	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
72915	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y		
72916	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y		
72917	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y		
72918	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y		
72919	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y		
72920	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y		
72921	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Ties Intact?	y		
72922	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Follow-up Action Required?	n		
72923	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y		
72924	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
72925	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n		
72926	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good		
72927	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y		
72928	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts	
72929	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	38983		
72930	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset		
72931	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None		
72932	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good		
72933	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Equipment Properly Labeled?	y		
72934	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
72935	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
72936	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
72937	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations A Ø	0		
72938	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations B Ø	0		
72939	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations C Ø	0		
72940	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations Ground	0		
72941	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Follow-up Action Required?	n		
72942	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Follow-up Action Required?	n		
72943	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Foundation Condition	Good		
72944	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	General Comments			
72945	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	General Comments			
72946	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Grounds in Place?	y		
72947	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Heaters (All) Functioning?	y		
72948	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Maintenance Operations	1		
72949	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Moisture and Leak Free?	y		
72950	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AF	177		
72951	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AL	177		
72952	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Operations This Read Vac	1		
72953	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Switching Operations	0		
72954	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Tank Paint Condition	Good		
72955	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection BK000726	BreakerVacuum	888-0437	VCB Readings	Unknown Operations	0		
72956	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushing Condition	Good		
72957	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good		
72958	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y		
72959	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean		
72960	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good		
72961	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Current Tap Position	2L		
72962	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y		
72963	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n		
72964	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Foundation Condition	Good		
72965	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good		
72966	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	General Comments			
72967	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Grounds in Place?	y		
72968	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral		
72969	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Min Tap Position	8L		
72970	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y		
72971	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y		
72972	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Oil Level	Good		
72973	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y		
72974	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts	
72975	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30659		
72976	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
72977	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Leaks	None	
72978	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
72979	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
72980	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
72981	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
72982	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
72983	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
72984	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
72985	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
72986	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
72987	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
72988	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
72989	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
72990	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
72991	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
72992	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
72993	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
72994	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.3	VDC
72995	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.3	VDC
72996	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	General Comments		
72997	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
72998	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
72999	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
73000	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
73001	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
73002	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
73003	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
73004	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
73005	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	3	
73006	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73007	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
73008	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
73009	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	154.0	
73010	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	150.0	
73011	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	147.0	
73012	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
73013	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
73014	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
73015	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
73016	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
73017	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
73018	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
73019	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
73020	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
73021	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
73022	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	0	
73023	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	0	
73024	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
73025	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
73026	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
73027	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
73028	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
73029	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
73030	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
73031	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
73032	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73033	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47394	
73034	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
73035	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
73036	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
73037	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73038	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73039	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	1R	
73040	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	9L	
73041	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
73042	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
73043	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73044	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
73045	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73046	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73047	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
73048	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73049	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73050	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
73051	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	General Comments	no 911 signage	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
73052	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
73053	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
73054	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
73055	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
73056	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Trash?	y	
73057	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
73058	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
73059	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
73060	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
73061	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
73062	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
73063	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	General Comments		
73064	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
73065	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Vegetation	None	
73066	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
73067	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73068	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
73069	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
73070	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73071	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73072	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73073	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73074	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
73075	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73076	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73077	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
73078	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73079	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	General Comments		
73080	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
73081	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
73082	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
73083	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73084	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73085	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
73086	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
73087	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
73088	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19210	
73089	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73090	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Leaks	None	
73091	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
73092	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73093	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73094	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	BreakerVacuum	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73095	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000611	BreakerVacuum	648-1761	BreakerVacuum	VCB Readings	9 Month Operations	2	
73096	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73097	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73098	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73099	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73100	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73101	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	General Comments		
73102	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73103	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73104	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73105	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73106	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73107	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
73108	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
73109	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73110	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73111	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73112	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
73113	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73114	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
73115	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73116	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73117	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73118	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73119	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
73120	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73121	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73122	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73123	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73124	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
73125	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
73126	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73127	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
73128	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
73129	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
73130	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
73131	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
73132	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Maintenance Operations	1	
73133	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Patrol Inspection	Moisture and Leak Free?	y	
73134	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Operations Counter AF	211	
73135	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Operations Counter AL	211	
73136	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Operations This Read Vac	1	
73137	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
73138	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Switching Operations	0	
73139	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Patrol Inspection	Tank Paint Condition	Good	
73140	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector BK000720		BreakerVacuum	648-1762	VCB Readings	Unknown Operations	0	
73141	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations	2	
73142	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73143	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
73144	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
73145	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps A Ø	120.0	
73146	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps B Ø	140.0	
73147	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps C Ø	110.0	
73148	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushing Condition	Good	
73149	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
73150	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
73151	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
73152	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
73153	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
73154	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
73155	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
73156	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
73157	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
73158	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations A Ø	0	
73159	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations B Ø	0	
73160	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations C Ø	0	
73161	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations Ground	0	
73162	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
73163	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Follow-up Action Required?	n	
73164	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Foundation Condition	Good	
73165	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	General Comments		
73166	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	General Comments		
73167	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Grounds in Place?	y	
73168	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
73169	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Maintenance Operations	1	
73170	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
73171	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AF	133	
73172	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AL	133	
73173	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations This Read Vac	1	
73174	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73175	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73176	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
73177	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73178	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73179	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73180	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73181	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
73182	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
73183	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
73184	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
73185	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
73186	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
73187	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
73188	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
73189	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
73190	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1710.72	kw
73191	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
73192	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
73193	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
73194	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	General Comments		
73195	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	General Comments		
73196	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73197	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
73198	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
73199	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73200	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
73201	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73202	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73203	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73204	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73205	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
73206	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
73207	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73208	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
73209	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73210	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73211	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73212	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73213	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73214	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73215	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73216	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	General Comments		
73217	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73218	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73219	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73220	11/18/2019 14:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73221	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
73222	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Leaks	None	
73223	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73224	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Regulator As Left Counter	94079	
73225	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
73226	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
73227	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
73228	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73229	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73230	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
73231	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
73232	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
73233	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	General Comments		
73234	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73235	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
73236	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73237	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
73238	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
73239	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73240	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
73241	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73242	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73243	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73244	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73245	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
73246	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
73247	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73248	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73249	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73250	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73251	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
73252	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73253	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73254	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
73255	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
73256	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Leaks	None	
73257	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73258	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51669	
73259	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
73260	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
73261	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
73262	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73263	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73264	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
73265	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
73266	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
73267	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	General Comments		
73268	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73269	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
73270	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73271	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73272	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
73273	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73274	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73275	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73276	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73277	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
73278	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73279	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
73280	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations	1	
73281	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73282	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
73283	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
73284	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps A Ø	305.0	
73285	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps B Ø	323.0	
73286	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps C Ø	344.0	
73287	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushing Condition	Good	
73288	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
73289	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
73290	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
73291	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
73292	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
73293	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
73294	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	10L	
73295	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	5L	
73296	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73297	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73298	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Switching Operations	0	
73299	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
73300	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Unknown Operations	0	
73301	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
73302	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Leaks	None	
73303	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73304	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Regulator As Left Counter	133937	
73305	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
73306	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
73307	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
73308	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73309	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73310	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
73311	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
73312	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
73313	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	General Comments		
73314	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73315	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
73316	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
73317	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73318	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
73319	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73320	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73321	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73322	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73323	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
73324	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
73325	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Leaks	None	
73326	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73327	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Regulator As Left Counter	255744	
73328	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
73329	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
73330	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
73331	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73332	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73333	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
73334	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
73335	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
73336	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	General Comments		
73337	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73338	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
73339	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
73340	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73341	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
73342	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Bad	
73343	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73344	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73345	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73346	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
73347	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
73348	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Leaks	None	
73349	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73350	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Regulator As Left Counter	199786	
73351	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73352	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
73353	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
73354	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73355	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73356	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
73357	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
73358	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
73359	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	General Comments		
73360	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
73361	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
73362	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
73363	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
73364	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
73365	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
73366	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
73367	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
73368	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations A Ø	0	
73369	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations B Ø	0	
73370	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations C Ø	0	
73371	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations Ground	0	
73372	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
73373	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Follow-up Action Required?	n	
73374	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
73375	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73376	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73377	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73378	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73379	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73380	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73381	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73382	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
73383	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
73384	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
73385	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
73386	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
73387	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
73388	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
73389	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
73390	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
73391	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
73392	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
73393	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73394	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
73395	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73396	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	General Comments		
73397	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73398	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73399	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73400	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73401	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73402	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
73403	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
73404	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
73405	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
73406	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
73407	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
73408	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73409	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73410	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
73411	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC000308	LTCControl	786-1	LTC Control Insp	LTC Operation Checked?	y	
73412	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC000308	LTCControl	786-1	LTC Control Insp	General Comments		
73413	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC000308	LTCControl	786-1	LTC Control Insp	Follow-up Action Required?	n	
73414	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC000308	LTCControl	786-1	LTC Control Insp	All Connections OK?	y	
73415	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73416	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
73417	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
73418	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
73419	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
73420	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Foundation Condition	Good	
73421	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	General Comments		
73422	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	General Comments		
73423	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Grounds in Place?	y	
73424	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Heaters (All) Functioning?	y	
73425	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Maintenance Operations	1	
73426	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC000825	LTCControl	640-1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
73427	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	Follow-up Action Required?	n	
73428	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	General Comments		
73429	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	LTC Operation Checked?	y	
73430	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
73431	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Trash?	y	
73432	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
73433	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
73434	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
73435	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations	2	
73436	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
73437	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
73438	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
73439	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps A Ø	25.0	
73440	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps B Ø	30.0	
73441	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps C Ø	45.0	
73442	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushing Condition	Good	
73443	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushings Connection/Risers	Good	
73444	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
73445	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
73446	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
73447	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Paint Condition	Good	
73448	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
73449	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
73450	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
73451	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Max	70	*C
73452	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
73453	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
73454	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2655.36	kw
73455	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
73456	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
73457	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
73458	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	General Comments		
73459	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	General Comments		
73460	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73461	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
73462	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
73463	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73464	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
73465	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
73466	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73467	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73468	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73469	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
73470	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
73471	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
73472	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
73473	11/18/2019 16:06	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
73474	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
73475	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
73476	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
73477	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
73478	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
73479	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	244	
73480	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	244	
73481	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
73482	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
73483	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
73484	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73485	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73486	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73487	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Aring Horns Good Condition?	y	
73488	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73489	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
73490	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
73491	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
73492	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
73493	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
73494	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
73495	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
73496	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
73497	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
73498	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
73499	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
73500	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
73501	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
73502	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Reading	.9444	
73503	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Max	38	°C
73504	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Present	20	°C
73505	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
73506	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
73507	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73508	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
73509	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
73510	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73511	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
73512	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
73513	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
73514	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
73515	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Broom on Site?	y	
73516	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
73517	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
73518	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
73519	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
73520	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Evidence of Insects	None	
73521	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
73522	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	n	
73523	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Swept?	y	
73524	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
73525	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
73526	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
73527	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	General Comments	Control House is under construction. one 8ft bulb not working in control house. replaced both bulbs still same thing	
73528	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
73529	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
73530	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panels Dusted?	y	
73531	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
73532	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
73533	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
73534	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Trash Emptied?	y	
73535	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
73536	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73537	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73538	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
73539	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
73540	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
73541	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
73542	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
73543	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
73544	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73545	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73546	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
73547	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
73548	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
73549	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
73550	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
73551	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73552	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
73553	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
73554	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
73555	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
73556	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
73557	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73558	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	General Comments	It is 39 degrees Fahrenheit outside and the oil temp is 15 degrees Celcius and there is a group of fans on with both fans switches in au	
73559	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	General Comments	Thermal Load Guage has hand broken. Pic sent to Stinson	
73560	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
73561	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
73562	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
73563	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
73564	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Unknown Operations	0	
73565	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Tank Paint Condition	Good	
73566	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Switching Operations	0	
73567	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations This Read Vac	1	
73568	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AL	55	
73569	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AF	55	
73570	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Unknown Operations	0	
73571	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
73572	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
73573	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
73574	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Moisture and Leak Free?	y	
73575	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
73576	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73577	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
73578	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
73579	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
73580	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
73581	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Operations Counter	55	
73582	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
73583	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
73584	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
73585	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
73586	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
73587	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
73588	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
73589	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
73590	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	LTC0000825	LTCControl	640-1	LTC Control Insp	VRR Time Delay	30	Seconds
73591	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	All Connections OK?	y	
73592	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	Follow-up Action Required?	n	
73593	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	General Comments		
73594	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	LTC Operation Checked?	y	
73595	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
73596	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
73597	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
73598	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	LTC0000827	LTCControl	496-1	LTC Control Insp	VRR Time Delay	30	Seconds
73599	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	General Comments		
73600	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
73601	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
73602	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
73603	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
73604	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
73605	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
73606	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
73607	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
73608	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
73609	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps C Ø	99.0	
73610	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps B Ø	114.0	
73611	11/18/2019 11:04	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps A Ø	109.0	
73612	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	VRR Time Delay	30	Seconds
73613	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
73614	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
73615	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
73616	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	LTC Output Voltage Level	119.9	VAC
73617	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	LTC Operation Checked?	y	
73618	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	General Comments		
73619	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	Follow-up Action Required?	n	
73620	11/18/2019 13:03	Distribution	Mid Valley Simpsonville Quarterly Inspectio	LTC0000669	LTCControl	733-1	LTC Control Insp	All Connections OK?	y	
73621	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
73622	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.9288	
73623	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
73624	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
73625	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
73626	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
73627	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
73628	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
73629	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
73630	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
73631	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	50	°C
73632	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
73633	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
73634	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
73635	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	2972.16	kw
73636	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
73637	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
73638	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
73639	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73640	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
73641	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
73642	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73643	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	General Comments		
73644	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	General Comments		
73645	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
73646	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
73647	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
73648	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
73649	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
73650	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
73651	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73652	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.1	VDC
73653	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.1	VDC
73654	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
73655	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
73656	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73657	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
73658	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
73659	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
73660	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	General Comments		
73661	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
73662	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
73663	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73664	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73665	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73666	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73667	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73668	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73669	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73670	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	General Comments		
73671	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73672	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73673	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73674	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73675	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73676	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73677	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73678	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
73679	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	ST000262	Structure	648-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73680	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
73681	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
73682	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
73683	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	600.48	kw
73684	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
73685	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
73686	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
73687	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
73688	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
73689	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
73690	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
73691	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
73692	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
73693	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
73694	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
73695	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
73696	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7506	
73697	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
73698	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
73699	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
73700	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
73701	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
73702	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
73703	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
73704	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
73705	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
73706	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
73707	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
73708	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
73709	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
73710	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
73711	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
73712	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73713	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73714	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
73715	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
73716	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
73717	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73718	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73719	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
73720	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73721	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
73722	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
73723	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73724	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	General Comments		
73725	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
73726	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73727	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Leaks	None	
73728	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73729	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Regulator As Left Counter	69236	
73730	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
73731	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
73732	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73733	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73734	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
73735	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
73736	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
73737	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54932	
73738	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Leaks	None	
73739	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
73740	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
73741	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
73742	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Trash?	y	
73743	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
73744	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
73745	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
73746	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
73747	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
73748	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
73749	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	General Comments		
73750	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
73751	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Vegetation	None	
73752	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
73753	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
73754	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
73755	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
73756	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73757	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73758	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73759	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
73760	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
73761	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
73762	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
73763	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73764	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73765	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
73766	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
73767	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
73768	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
73769	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73770	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
73771	11/18/2019 11:36	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
73772	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	General Comments		
73773	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
73774	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
73775	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
73776	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73777	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
73778	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73779	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73780	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73781	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73782	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
73783	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73784	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73785	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	General Comments		
73786	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73787	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73788	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73789	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73790	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
73791	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
73792	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
73793	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
73794	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
73795	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
73796	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Vegetation	None	
73797	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
73798	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	General Comments		
73799	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
73800	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
73801	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
73802	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73803	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	General Comments		
73804	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	General Comments		
73805	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
73806	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	Follow-up Action Required?	n		
73807	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
73808	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	General Comments			
73809	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	General Comments			
73810	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Found Counter	7887		
73811	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Left Counter	7895		
73812	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good		
73813	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Current Tap Position	2R		
73814	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Max Tap Position	3R		
73815	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
73816	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
73817	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
73818	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
73819	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
73820	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
73821	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
73822	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Present	27	*C
73823	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Min Tap Position	1L		
73824	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Operations Since Last Insp	1066		
73825	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good		
73826	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Counter Readings	Reset Tap Drag Hands	Reset		
73827	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good		
73828	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
73829	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
73830	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
73831	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
73832	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73833	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73834	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73835	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73836	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73837	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73838	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
73839	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
73840	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	General Comments		
73841	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
73842	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
73843	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Foundation Condition	Good	
73844	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	LTC Totalizer Reading	9066.24	kw
73845	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
73846	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
73847	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
73848	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Max	38	*C
73849	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Present	20	*C
73850	11/18/2019 10:17	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
73851	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
73852	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
73853	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
73854	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.3	VDC
73855	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
73856	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
73857	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
73858	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
73859	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	39	*F
73860	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
73861	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
73862	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
73863	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
73864	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
73865	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
73866	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
73867	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
73868	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	General Comments		
73869	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
73870	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	114	
73871	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.9	
73872	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.6	
73873	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.7	
73874	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	137	
73875	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
73876	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73877	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	109	
73878	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
73879	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
73880	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
73881	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
73882	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
73883	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
73884	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
73885	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
73886	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	All Connections OK?	y	
73887	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	Follow-up Action Required?	n	
73888	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	General Comments		
73889	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Operation Checked?	y	
73890	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
73891	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	General Comments	counter done wrong last time	
73892	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Output Voltage Level	1241.0	VAC
73893	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
73894	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
73895	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
73896	11/18/2019 14:27	Distribution	Morganfield Industrial Quarterly Inspector	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Time Delay	30	Seconds
73897	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
73898	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
73899	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
73900	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8298	
73901	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
73902	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
73903	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73904	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73905	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
73906	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
73907	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
73908	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
73909	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73910	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
73911	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
73912	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73913	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Follow-up Action Required?	n	
73914	11/18/2019 10:17	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
73915	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
73916	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
73917	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
73918	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
73919	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
73920	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
73921	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
73922	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
73923	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
73924	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
73925	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
73926	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
73927	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
73928	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
73929	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
73930	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
73931	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
73932	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
73933	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
73934	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
73935	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
73936	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
73937	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
73938	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47344	
73939	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
73940	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
73941	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
73942	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
73943	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
73944	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Vegetation	None	
73945	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
73946	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	General Comments		
73947	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
73948	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
73949	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
73950	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
73951	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
73952	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
73953	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Trash?	y	
73954	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
73955	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
73956	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
73957	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
73958	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
73959	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
73960	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
73961	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
73962	11/18/2019 13:18	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
73963	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
73964	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
73965	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
73966	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
73967	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	General Comments		
73968	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
73969	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Leaks	None	
73970	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
73971	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Operations Counter	1020	
73972	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
73973	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
73974	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	General Comments		
73975	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
73976	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
73977	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
73978	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
73979	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
73980	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
73981	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
73982	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
73983	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
73984	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
73985	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
73986	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
73987	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	General Comments		
73988	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
73989	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	General Comments		
73990	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
73991	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
73992	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
73993	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
73994	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
73995	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
73996	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
73997	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
73998	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	General Comments		
73999	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
74000	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
74001	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
74002	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
74003	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
74004	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
74005	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
74006	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
74007	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
74008	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
74009	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
74010	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
74011	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
74012	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
74013	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
74014	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
74015	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
74016	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
74017	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
74018	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
74019	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
74020	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
74021	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
74022	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
74023	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
74024	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
74025	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
74026	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
74027	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
74028	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
74029	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
74030	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
74031	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
74032	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
74033	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
74034	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
74035	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
74036	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
74037	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
74038	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	General Comments		
74039	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
74040	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
74041	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Foundation Condition	Good	
74042	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74043	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74044	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74045	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74046	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
74047	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
74048	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
74049	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	General Comments		
74050	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
74051	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
74052	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
74053	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
74054	11/18/2019 11:36	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
74055	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
74056	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
74057	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
74058	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
74059	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	General Comments		
74060	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	General Comments		
74061	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
74062	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Leaks	None	
74063	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
74064	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
74065	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
74066	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
74067	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
74068	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
74069	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
74070	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
74071	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
74072	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
74073	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
74074	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
74075	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
74076	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
74077	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
74078	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
74079	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
74080	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
74081	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
74082	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
74083	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
74084	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
74085	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
74086	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
74087	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
74088	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
74089	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
74090	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
74091	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Operations Since Last Insp	1148	
74092	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
74093	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
74094	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
74095	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
74096	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
74097	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Min Tap Position	12L	
74098	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Max Tap Position	3L	
74099	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Current Tap Position	6L	
74100	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
74101	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Left Counter	4063	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74102	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Found Counter	4057	
74103	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	General Comments		
74104	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	General Comments		
74105	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
74106	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Follow-up Action Required?	n	
74107	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
74108	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
74109	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
74110	11/18/2019 8:50	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
74111	11/18/2019 12:51	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	General Comments		
74112	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
74113	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
74114	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
74115	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
74116	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
74117	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
74118	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
74119	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	General Comments		
74120	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
74121	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
74122	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
74123	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1018.08	kw
74124	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
74125	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
74126	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
74127	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
74128	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
74129	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
74130	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
74131	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
74132	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
74133	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
74134	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
74135	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
74136	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
74137	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
74138	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
74139	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
74140	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	General Comments		
74141	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
74142	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
74143	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
74144	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
74145	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps C Ø	28.4	
74146	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
74147	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
74148	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Present	28	°C
74149	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
74150	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4242	
74151	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
74152	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
74153	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
74154	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
74155	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
74156	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
74157	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
74158	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
74159	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
74160	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
74161	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Follow-up Action Required?	n	
74162	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
74163	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
74164	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	General Comments		
74165	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	General Comments		
74166	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
74167	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	LTC Totalizer Reading	2560.32	kw
74168	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
74169	11/18/2019 15:04	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
74170	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps B Ø	22.5	
74171	11/18/2019 12:49	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps A Ø	18.9	
74172	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
74173	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
74174	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
74175	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
74176	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
74177	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
74178	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
74179	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
74180	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Regulator As Left Counter	53156	
74181	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
74182	11/18/2019 15:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
74183	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
74184	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
74185	11/18/2019 13:58	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
74186	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
74187	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
74188	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
74189	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
74190	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
74191	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
74192	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
74193	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	General Comments		
74194	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
74195	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
74196	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Foundation Condition	Good	
74197	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74198	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushing Condition	Good	
74199	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74200	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74201	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74202	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74203	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74204	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74205	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74206	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74207	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load Y2 Max	70	%
74208	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74209	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations A Ø	0	
74210	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations B Ø	0	
74211	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations C Ø	0	
74212	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AF	124	
74213	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
74214	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations This Read Vac	1	
74215	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
74216	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
74217	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
74218	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
74219	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
74220	11/18/2019 9:04	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
74221	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Switching Operations	0	
74222	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
74223	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Maintenance Operations	1	
74224	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74225	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load X2 Max	70	%
74226	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
74227	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
74228	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Grounds in Place?	y	
74229	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations Ground	0	
74230	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Found Counter	205705	
74231	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	General Comments		
74232	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	General Comments		
74233	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	General Comments		
74234	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
74235	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
74236	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
74237	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	General Comments		
74238	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
74239	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
74240	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
74241	11/18/2019 10:19	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Follow-up Action Required?	n	
74242	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
74243	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
74244	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
74245	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Follow-up Action Required?	n	
74246	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Foundation Condition	Good	
74247	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
74248	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74249	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74250	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74251	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74252	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
74253	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
74254	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	General Comments		
74255	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
74256	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
74257	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
74258	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
74259	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
74260	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
74261	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
74262	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
74263	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
74264	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
74265	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AL	124	
74266	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations	2	
74267	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74268	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74269	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74270	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
74271	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
74272	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
74273	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps A Ø	110.0	
74274	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Leaks	None	
74275	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
74276	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
74277	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
74278	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
74279	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps B Ø	120.0	
74280	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
74281	11/22/2019 6:37	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
74282	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
74283	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
74284	11/18/2019 9:17	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Regulator As Left Counter	13384	
74285	11/18/2019 13:38	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps C Ø	140.0	
74286	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
74287	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
74288	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
74289	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
74290	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
74291	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
74292	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
74293	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
74294	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
74295	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
74296	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
74297	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
74298	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
74299	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.4	VDC
74300	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
74301	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
74302	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
74303	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.4	VDC
74304	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
74305	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
74306	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	3	
74307	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	181	
74308	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	181	
74309	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
74310	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
74311	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
74312	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
74313	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	1	
74314	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
74315	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	2	
74316	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
74317	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74318	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
74319	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	72.0	
74320	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	91.0	
74321	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	67.0	
74322	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74323	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74324	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74325	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	25	
74326	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74327	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
74328	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74329	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74330	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74331	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74332	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74333	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
74334	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
74335	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
74336	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
74337	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
74338	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
74339	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74340	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
74341	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
74342	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
74343	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
74344	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
74345	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
74346	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
74347	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
74348	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
74349	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
74350	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
74351	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	63.0	
74352	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
74353	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
74354	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
74355	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
74356	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	170	
74357	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
74358	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
74359	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
74360	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Positive DC Ground	68.3	VDC
74361	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
74362	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
74363	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Negative DC Ground	71.5	VDC
74364	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	General Comments		
74365	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
74366	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
74367	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
74368	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
74369	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
74370	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
74371	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
74372	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
74373	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	139.0	VDC
74374	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.9	AMPS
74375	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	*F
74376	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
74377	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
74378	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	139.9	VDC
74379	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	139.9	VDC
74380	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
74381	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
74382	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
74383	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	float voltage checked during equalizing	
74384	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
74385	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74386	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74387	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
74388	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
74389	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
74390	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
74391	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
74392	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
74393	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74394	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
74395	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
74396	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	General Comments		
74397	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	General Comments		
74398	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
74399	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
74400	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
74401	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74402	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
74403	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Foundation Condition	Good	
74404	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Follow-up Action Required?	n	
74405	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Follow-up Action Required?	n	
74406	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations Ground	0	
74407	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
74408	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
74409	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
74410	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
74411	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
74412	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
74413	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
74414	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
74415	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
74416	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
74417	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
74418	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
74419	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
74420	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
74421	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
74422	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	General Comments		
74423	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
74424	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Vegetation	None	
74425	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
74426	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
74427	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
74428	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
74429	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	General Comments		
74430	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
74431	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
74432	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74433	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74434	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74435	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74436	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Foundation Condition	Good	
74437	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
74438	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
74439	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74440	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74441	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74442	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74443	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74444	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74445	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Follow-up Action Required?	n	
74446	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Follow-up Action Required?	n	
74447	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Fault Operations	0	
74448	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
74449	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
74450	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
74451	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74452	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
74453	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
74454	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Ambient Temperature	34	*F
74455	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
74456	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
74457	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	29.0	VDC
74458	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
74459	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
74460	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
74461	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
74462	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
74463	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
74464	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Trash?	y	
74465	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
74466	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
74467	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
74468	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Broom on Site?	y	
74469	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
74470	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
74471	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Trash?	y	
74472	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
74473	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
74474	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
74475	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
74476	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
74477	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	General Comments		
74478	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Vegetation	None	
74479	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Grounds in Place?	y	
74480	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	General Comments		
74481	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	General Comments		
74482	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Foundation Condition	Good	
74483	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Follow-up Action Required?	n	
74484	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Follow-up Action Required?	n	
74485	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74486	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations C Ø	0	
74487	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations B Ø	0	
74488	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations A Ø	0	
74489	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74490	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74491	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74492	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74493	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74494	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74495	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74496	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74497	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74498	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushing Condition	Good	
74499	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	340.0	
74500	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	350.0	
74501	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	330.0	
74502	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74503	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74504	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74505	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	3	
74506	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74507	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74508	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74509	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
74510	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
74511	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
74512	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
74513	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
74514	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
74515	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
74516	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
74517	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
74518	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74519	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
74520	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Foundation Condition	Good	
74521	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
74522	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
74523	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
74524	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74525	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
74526	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Follow-up Action Required?	n	
74527	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
74528	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Comments		
74529	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Ambient Temp	32	*F
74530	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74531	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74532	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
74533	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
74534	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74535	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
74536	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
74537	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Ambient Temperature	34	*F
74538	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Tank Paint Condition	Good	
74539	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Switching Operations	0	
74540	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
74541	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
74542	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
74543	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations This Read SF6	0	
74544	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AL	27	
74545	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74546	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74547	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74548	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74549	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations A Ø	0	
74550	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations B Ø	0	
74551	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74552	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations Ground	0	
74553	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
74554	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Follow-up Action Required?	n	
74555	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Foundation Condition	Good	
74556	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	General Comments		
74557	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	General Comments		
74558	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Grounds in Place?	y	
74559	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74560	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Maintenance Operations	0	
74561	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Moisture and Leak Free?	y	
74562	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AF	192	
74563	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AL	192	
74564	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations This Read Vac	0	
74565	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
74566	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Evidence of Insects	None	
74567	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
74568	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
74569	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Swept?	n	
74570	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
74571	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
74572	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	General Comments		
74573	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
74574	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
74575	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panels Dusted?	y	
74576	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations	10	
74577	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74578	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74579	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74580	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps A Ø	46.0	
74581	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps B Ø	43.0	
74582	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps C Ø	62.0	
74583	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushing Condition	Good	
74584	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74585	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
74586	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
74587	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Switching Operations	0	
74588	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Tank Paint Condition	Good	
74589	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Unknown Operations	0	
74590	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
74591	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AF	27	
74592	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Tank Paint Condition	Good	
74593	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Switching Operations	0	
74594	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
74595	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
74596	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
74597	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
74598	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
74599	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
74600	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations This Read SF6	0	
74601	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AL	40	
74602	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AF	40	
74603	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Num Operations Last 9 Months	1	
74604	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
74605	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Maintenance Operations	0	
74606	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
74607	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
74608	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
74609	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
74610	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Grounds in Place?	y	
74611	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	General Comments	y	
74612	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
74613	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74614	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
74615	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
74616	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	
74617	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
74618	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
74619	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
74620	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
74621	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Broom on Site?	n	
74622	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
74623	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
74624	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
74625	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
74626	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	736	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
74627	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
74628	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	736	
74629	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
74630	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
74631	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
74632	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
74633	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	General Comments		
74634	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
74635	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Foundation Condition	Good	
74636	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Follow-up Action Required?	n	
74637	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Follow-up Action Required?	n	
74638	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations	4	
74639	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74640	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74641	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74642	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps A Ø	87.0	
74643	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps B Ø	90.0	
74644	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps C Ø	125.0	
74645	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushing Condition	Good	
74646	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74647	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74648	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74649	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74650	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74651	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Fault Operations	0	
74652	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	General Comments		
74653	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
74654	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps B Ø	62.0	
74655	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps C Ø	70.0	
74656	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushing Condition	Good	
74657	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74658	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74659	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74660	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74661	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
74662	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
74663	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
74664	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
74665	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
74666	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
74667	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
74668	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Broom on Site?	y	
74669	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
74670	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
74671	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
74672	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
74673	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
74674	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Evidence of Insects	None	
74675	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
74676	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
74677	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
74678	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Swept?	y	
74679	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
74680	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
74681	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74682	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74683	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74684	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Unknown Operations	0	
74685	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Tank Paint Condition	Good	
74686	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Switching Operations	0	
74687	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations This Read Vac	2	
74688	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AL	178	
74689	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AF	178	
74690	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Moisture and Leak Free?	y	
74691	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Maintenance Operations	2	
74692	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74693	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	General Comments		
74694	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	y	
74695	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
74696	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
74697	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
74698	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
74699	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	1	
74700	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panels Dusted?	y	
74701	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74702	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
74703	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
74704	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
74705	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BCH001158	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
74706	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
74707	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations This Read Vac	1	
74708	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99956	
74709	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99956	
74710	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
74711	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
74712	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Num Operations Last 9 Months	2	
74713	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
74714	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
74715	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
74716	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
74717	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
74718	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
74719	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
74720	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
74721	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
74722	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74723	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74724	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74725	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74726	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74727	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps A Phase V	9.62	
74728	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps B Phase V	9.62	
74729	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
74730	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations A Ø	0	
74731	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations B Ø	0	
74732	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations C Ø	0	
74733	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations Ground	0	
74734	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Follow-up Action Required?	n	
74735	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Follow-up Action Required?	n	
74736	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Foundation Condition	Good	
74737	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	General Comments		
74738	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	General Comments		
74739	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Grounds in Place?	y	
74740	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Heaters (All) Functioning?	y	
74741	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Maintenance Operations	0	
74742	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Moisture and Leak Free?	y	
74743	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AF	191	
74744	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AL	191	
74745	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations This Read Vac	5	
74746	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Switching Operations	3	
74747	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Maintenance Operations	0	
74748	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
74749	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
74750	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
74751	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Operations Since Last Insp	1564	
74752	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Min Tap Position	15L	
74753	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Max Tap Position	2R	
74754	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Current Tap Position	7L	
74755	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
74756	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Tank Paint Condition	Good	
74757	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Unknown Operations	2	
74758	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	9 Month Operations	5	
74759	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Left Counter	30712	
74760	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Found Counter	30704	
74761	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	General Comments		
74762	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	General Comments		
74763	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
74764	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74765	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74766	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74767	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps A Ø	69.0	
74768	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Follow-up Action Required?	n	
74769	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
74770	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Grounds in Place?	y	
74771	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	General Comments	y	
74772	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	General Comments		
74773	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	Follow-up Action Required?	n	
74774	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	All Connections OK?	y	
74775	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations A Ø	0	
74776	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74777	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations C Ø	0	
74778	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations Ground	0	
74779	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Follow-up Action Required?	n	
74780	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Follow-up Action Required?	n	
74781	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Foundation Condition	Good	
74782	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	General Comments		
74783	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	General Comments		
74784	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Grounds in Place?	y	
74785	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Maintenance Operations	0	
74786	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74787	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
74788	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	All Identified and Legible?	y	
74789	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
74790	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Vegetation	None	
74791	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
74792	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	General Comments	Drive is washed out on coal road	
74793	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
74794	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
74795	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
74796	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
74797	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
74798	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Trash?	y	
74799	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
74800	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
74801	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
74802	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Moisture and Leak Free?	y	
74803	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AF	192	
74804	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AL	192	
74805	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations This Read Vac	0	
74806	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Switching Operations	0	
74807	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Tank Paint Condition	Good	
74808	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Unknown Operations	0	
74809	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations	2	
74810	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
74811	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
74812	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
74813	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
74814	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
74815	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
74816	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
74817	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
74818	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
74819	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
74820	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
74821	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
74822	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	General Comments		
74823	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
74824	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
74825	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
74826	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
74827	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
74828	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	General Comments		
74829	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Negative DC Ground	2.3	VDC
74830	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Positive DC Ground	2.2	VDC
74831	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
74832	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
74833	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
74834	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.2	
74835	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.1	
74836	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps A Ø	.2	
74837	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	VRR Time Delay	30	Seconds
74838	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
74839	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
74840	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
74841	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	LTC Operation Checked?	y	
74842	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	General Comments		
74843	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	Follow-up Action Required?	n	
74844	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
74845	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
74846	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	LTC0000647	LTCControl	694-1	LTC Control Insp	All Connections OK?	y	
74847	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
74848	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17576	
74849	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
74850	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
74851	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74852	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
74853	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74854	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps A Ø	176.0	
74855	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps B Ø	169.0	
74856	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps C Ø	175.0	
74857	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	
74858	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
74859	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	0	
74860	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations This Read Vac	0	
74861	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	275	
74862	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushing Condition	Good	
74863	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74864	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74865	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74866	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74867	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74868	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74869	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74870	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74871	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74872	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	VRR Time Delay	30	Seconds
74873	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
74874	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
74875	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
74876	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTC000721	LTCControl	724-2	LTC Control Insp	LTC Operation Checked?	y	
74877	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
74878	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
74879	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Evidence of Insects	None	
74880	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
74881	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
74882	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Swept?	y	
74883	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
74884	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
74885	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	General Comments		
74886	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
74887	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Trash Emptied?	y	
74888	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
74889	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
74890	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74891	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74892	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74893	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74894	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74895	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74896	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
74897	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	95.0	
74898	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	80.0	
74899	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	100.0	
74900	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74901	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74902	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74903	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	8	
74904	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
74905	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
74906	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
74907	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
74908	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74909	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74910	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74911	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations A Ø	0	
74912	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations B Ø	0	
74913	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations C Ø	0	
74914	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations Ground	0	
74915	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Follow-up Action Required?	n	
74916	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Follow-up Action Required?	n	
74917	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Foundation Condition	Good	
74918	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	General Comments		
74919	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	General Comments		
74920	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Grounds in Place?	y	
74921	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Maintenance Operations	0	
74922	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Moisture and Leak Free?	y	
74923	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AF	211	
74924	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AL	211	
74925	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations This Read Vac	1	
74926	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Switching Operations	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
74927	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Tank Paint Condition	Good	
74928	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Unknown Operations	0	
74929	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
74930	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Foundation Condition	Good	
74931	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
74932	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
74933	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
74934	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	275	
74935	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
74936	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
74937	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
74938	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
74939	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	General Comments		
74940	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
74941	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
74942	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	
74943	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
74944	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
74945	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
74946	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
74947	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
74948	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
74949	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
74950	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps A Ø	177.0	
74951	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps B Ø	153.0	
74952	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74953	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74954	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74955	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
74956	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
74957	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
74958	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps C Ø	144.0	
74959	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushing Condition	Good	
74960	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
74961	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
74962	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
74963	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
74964	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
74965	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Operations Since Last Insp	1570	
74966	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
74967	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
74968	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Min Tap Position	10L	
74969	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Max Tap Position	2R	
74970	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Current Tap Position	6L	
74971	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
74972	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Left Counter	11980	
74973	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Found Counter	11975	
74974	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	General Comments		
74975	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	General Comments		
74976	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
74977	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Follow-up Action Required?	n	
74978	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
74979	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
74980	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Broom on Site?	y	
74981	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
74982	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
74983	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
74984	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
74985	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
74986	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
74987	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
74988	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
74989	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
74990	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
74991	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
74992	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
74993	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
74994	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
74995	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
74996	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
74997	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panels Dusted?	y	
74998	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
74999	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
75000	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	General Comments		
75001	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75002	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
75003	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Swept?	y	
75004	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
75005	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
75006	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Evidence of Insects	None	
75007	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
75008	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
75009	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
75010	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
75011	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
75012	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
75013	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
75014	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
75015	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	4270	
75016	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
75017	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
75018	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Unknown Operations	0	
75019	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Tank Paint Condition	Good	
75020	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Switching Operations	0	
75021	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations This Read Vac	2	
75022	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AL	185	
75023	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AF	185	
75024	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Moisture and Leak Free?	y	
75025	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Maintenance Operations	0	
75026	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Heaters (All) Functioning?	y	
75027	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Grounds in Place?	y	
75028	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	General Comments		
75029	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	General Comments		
75030	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Foundation Condition	Good	
75031	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Follow-up Action Required?	n	
75032	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
75033	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations Ground	0	
75034	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
75035	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
75036	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
75037	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
75038	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
75039	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
75040	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
75041	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
75042	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
75043	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	General Comments		
75044	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
75045	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
75046	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
75047	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
75048	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
75049	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
75050	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
75051	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
75052	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
75053	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
75054	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
75055	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
75056	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
75057	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
75058	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	General Comments		
75059	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
75060	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
75061	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
75062	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
75063	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
75064	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
75065	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
75066	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75067	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
75068	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75069	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
75070	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
75071	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
75072	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
75073	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
75074	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
75075	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
75076	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18831	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75077	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
75078	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
75079	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Leaks	None	
75080	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
75081	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
75082	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
75083	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75084	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	General Comments		
75085	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75086	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75087	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
75088	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
75089	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
75090	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
75091	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
75092	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	3	
75093	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations This Read Vac	3	
75094	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	186	
75095	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	186	
75096	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
75097	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	0	
75098	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
75099	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
75100	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
75101	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
75102	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
75103	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
75104	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
75105	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
75106	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	0	
75107	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	0	
75108	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	0	
75109	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75110	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75111	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75112	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75113	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75114	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75115	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75116	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75117	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75118	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
75119	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	201.0	
75120	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	200.0	
75121	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	187.0	
75122	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75123	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75124	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75125	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	7	
75126	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
75127	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
75128	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations	1	
75129	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75130	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75131	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Operations Counter	126	
75132	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
75133	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	General Comments		
75134	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
75135	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
75136	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
75137	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
75138	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
75139	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations C Ø	0	
75140	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations B Ø	1	
75141	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations A Ø	1	
75142	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75143	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps B Phase V	5.46	
75144	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps A Phase V	5.46	
75145	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75146	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75147	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75148	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75149	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75150	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75151	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushing Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75152	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps C Ø	61.0	
75153	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps B Ø	44.0	
75154	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps A Ø	44.0	
75155	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75156	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75157	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75158	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations	8	
75159	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
75160	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
75161	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
75162	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
75163	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
75164	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
75165	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	General Comments		
75166	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
75167	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
75168	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
75169	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
75170	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
75171	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
75172	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
75173	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
75174	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17848	
75175	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
75176	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
75177	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Leaks	None	
75178	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
75179	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
75180	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
75181	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
75182	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
75183	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
75184	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
75185	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
75186	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
75187	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
75188	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
75189	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	General Comments		
75190	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
75191	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
75192	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
75193	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
75194	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
75195	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
75196	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
75197	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Foundation Condition	Good	
75198	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75199	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75200	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	General Comments	recloser bypass fuses ok...highside fuse is frayed	
75201	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75202	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
75203	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
75204	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75205	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
75206	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75207	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
75208	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
75209	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
75210	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
75211	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
75212	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
75213	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
75214	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
75215	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
75216	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
75217	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
75218	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
75219	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
75220	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
75221	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
75222	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
75223	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
75224	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTC0000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
75225	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTC0000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
75226	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTC0000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75227	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
75228	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
75229	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
75230	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
75231	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
75232	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
75233	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
75234	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
75235	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75236	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75237	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75238	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75239	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75240	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75241	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75242	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75243	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75244	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Found Counter	97315	
75245	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	General Comments		
75246	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	General Comments		
75247	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
75248	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Follow-up Action Required?	n	
75249	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
75250	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
75251	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	General Comments		
75252	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Foundation Condition	Good	
75253	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
75254	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
75255	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
75256	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
75257	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
75258	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
75259	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
75260	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
75261	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
75262	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
75263	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
75264	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
75265	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
75266	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
75267	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
75268	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
75269	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
75270	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
75271	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
75272	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
75273	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
75274	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
75275	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
75276	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
75277	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
75278	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
75279	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
75280	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
75281	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	General Comments		
75282	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
75283	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
75284	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
75285	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
75286	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Trash?	y	
75287	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
75288	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
75289	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
75290	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
75291	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
75292	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	General Comments		
75293	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
75294	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Vegetation	None	
75295	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
75296	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
75297	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Max Tap Position	1L	
75298	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Current Tap Position	6L	
75299	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
75300	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Left Counter	70049	
75301	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps B Ø	180.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
75302	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps A Ø	180.0	
75303	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75304	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75305	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75306	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations	-1	
75307	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
75308	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	*F
75309	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
75310	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
75311	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
75312	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Trash Emptied?	n	
75313	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
75314	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Found Counter	70045	
75315	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	General Comments		
75316	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	General Comments		
75317	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
75318	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Follow-up Action Required?	n	
75319	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Foundation Condition	Good	
75320	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Follow-up Action Required?	n	
75321	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Follow-up Action Required?	n	
75322	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations Ground	0	
75323	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations C Ø	0	
75324	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations B Ø	0	
75325	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations A Ø	0	
75326	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75327	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75328	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	9 Month Operations	4	
75329	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75330	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75331	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75332	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps A Ø	0.0	
75333	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps B Ø	5.0	
75334	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps C Ø	5.0	
75335	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushing Condition	Good	
75336	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75337	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75338	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75339	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75340	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75341	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75342	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75343	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75344	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75345	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations A Ø	0	
75346	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations B Ø	0	
75347	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations C Ø	0	
75348	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations Ground	0	
75349	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
75350	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	100.0	
75351	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	130.0	
75352	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	120.0	
75353	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75354	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75355	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75356	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	16	
75357	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
75358	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
75359	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Positive DC Ground	42.2	VDC
75360	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Negative DC Ground	74.8	VDC
75361	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	General Comments		
75362	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
75363	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
75364	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
75365	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
75366	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
75367	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Unknown Operations	0	
75368	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Tank Paint Condition	Good	
75369	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Switching Operations	2	
75370	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations This Read Vac	2	
75371	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AL	185	
75372	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AF	185	
75373	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Moisture and Leak Free?	y	
75374	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Maintenance Operations	0	
75375	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Heaters (All) Functioning?	y	
75376	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75377	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	General Comments		
75378	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	General Comments		
75379	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
75380	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Follow-up Action Required?	n	
75381	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Follow-up Action Required?	n	
75382	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations Ground	0	
75383	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations C Ø	0	
75384	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations B Ø	0	
75385	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations A Ø	0	
75386	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75387	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75388	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75389	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75390	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75391	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75392	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75393	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75394	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75395	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushing Condition	Good	
75396	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps C Ø	170.0	
75397	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
75398	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
75399	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
75400	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Operations Since Last Insp	1042	
75401	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Min Tap Position	7L	
75402	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
75403	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
75404	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
75405	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75406	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
75407	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
75408	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Present	24	°C
75409	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Max	32	°C
75410	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Reading	.5180	
75411	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
75412	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
75413	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
75414	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
75415	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
75416	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75417	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
75418	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
75419	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75420	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
75421	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75422	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
75423	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
75424	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75425	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
75426	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75427	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75428	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
75429	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
75430	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
75431	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
75432	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Present	24	°C
75433	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Max	32	°C
75434	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
75435	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
75436	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
75437	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	LTC Totalizer Reading	9324.00	kw
75438	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
75439	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	General Comments		
75440	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	General Comments		
75441	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75442	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
75443	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
75444	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
75445	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
75446	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
75447	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	67	
75448	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
75449	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
75450	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
75451	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75452	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
75453	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Left Counter	328094	
75454	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
75455	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	
75456	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
75457	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
75458	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
75459	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
75460	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
75461	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
75462	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
75463	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
75464	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
75465	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75466	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
75467	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
75468	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	29	°C
75469	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	45	°C
75470	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	All Connections OK?	y	
75471	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	Follow-up Action Required?	n	
75472	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	General Comments		
75473	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Operation Checked?	y	
75474	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
75475	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
75476	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
75477	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Time Delay	60	Seconds
75478	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
75479	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
75480	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	1024.80	kw
75481	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
75482	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
75483	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
75484	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
75485	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
75486	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
75487	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
75488	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
75489	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
75490	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
75491	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
75492	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
75493	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75494	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
75495	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75496	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
75497	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments	asdded 2 lbs nitrogen	
75498	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		
75499	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75500	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
75501	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
75502	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75503	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
75504	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
75505	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75506	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
75507	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
75508	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
75509	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
75510	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75511	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
75512	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
75513	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	General Comments		
75514	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75515	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75516	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Foundation Condition	Good	
75517	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
75518	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
75519	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
75520	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
75521	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
75522	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
75523	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AF	736	
75524	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Moisture and Leak Free?	y	
75525	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Maintenance Operations	0	
75526	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75527	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Grounds in Place?	y	
75528	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	General Comments		
75529	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
75530	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
75531	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
75532	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
75533	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
75534	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
75535	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
75536	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
75537	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	65	
75538	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
75539	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
75540	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
75541	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
75542	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
75543	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Left Counter	378596	
75544	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Found Counter	378596	
75545	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
75546	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	General Comments		
75547	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
75548	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
75549	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
75550	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
75551	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
75552	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Operations Since Last Insp	898	
75553	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Min Tap Position	11L	
75554	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Max Tap Position	2L	
75555	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
75556	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
75557	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Current Tap Position	5L	
75558	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
75559	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Left Counter	97327	
75560	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Found Counter	328094	
75561	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
75562	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	General Comments		
75563	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
75564	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
75565	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
75566	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
75567	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
75568	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
75569	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
75570	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
75571	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
75572	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
75573	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Follow-up Action Required?	n	
75574	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75575	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
75576	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
75577	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
75578	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
75579	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments		
75580	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
75581	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
75582	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
75583	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
75584	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
75585	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
75586	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
75587	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
75588	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
75589	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
75590	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
75591	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off groundleft corner post of station is washing out
75592	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
75593	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75594	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
75595	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
75596	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75597	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
75598	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
75599	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Unknown Operations	0	
75600	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Tank Paint Condition	Good	
75601	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	7	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
75602	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	7	
75603	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	165	
75604	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	165	
75605	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Switching Operations	0	
75606	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75607	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations This Read Vac	0	
75608	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AL	736	
75609	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
75610	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
75611	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75612	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75613	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	137	
75614	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	137	
75615	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
75616	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Follow-up Action Required?	n	
75617	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Foundation Condition	Good	
75618	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	General Comments		
75619	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	General Comments		
75620	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
75621	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Grounds in Place?	y	
75622	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
75623	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Maintenance Operations	1	
75624	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
75625	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
75626	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
75627	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
75628	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
75629	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
75630	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AF	49	
75631	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AL	49	
75632	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations This Read Vac	1	
75633	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Switching Operations	0	
75634	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
75635	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75636	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
75637	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
75638	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	37	°C
75639	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	55	°C
75640	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
75641	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
75642	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	168.48	kw
75643	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
75644	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
75645	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	General Comments		
75646	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75647	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
75648	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
75649	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75650	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
75651	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
75652	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75653	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
75654	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
75655	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
75656	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
75657	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75658	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75659	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
75660	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
75661	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Tank Paint Condition	Good	
75662	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Unknown Operations	0	
75663	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
75664	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
75665	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
75666	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
75667	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
75668	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations Ground	0	
75669	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations C Ø	0	
75670	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations B Ø	0	
75671	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations A Ø	0	
75672	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75673	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75674	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75675	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75676	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75677	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75678	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75679	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75680	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75681	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushing Condition	Good	
75682	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps C Ø	180.0	
75683	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps B Ø	140.0	
75684	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps A Ø	160.0	
75685	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75686	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75687	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75688	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations	10	
75689	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-1Y 12KV BUS TIE	VCB Readings	9 Month Operations	4	
75690	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
75691	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
75692	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
75693	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75694	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
75695	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
75696	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
75697	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
75698	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
75699	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206.00	
75700	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
75701	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
75702	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
75703	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
75704	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75705	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
75706	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
75707	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75708	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75709	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75710	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75711	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
75712	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
75713	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
75714	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
75715	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	.0936	
75716	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
75717	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
75718	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
75719	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
75720	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
75721	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75722	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
75723	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75724	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75725	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	9 Month Operations	0	
75726	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Tank Paint Condition	Good	
75727	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75728	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Moisture and Leak Free?	y	
75729	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Grounds in Place?	y	
75730	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	General Comments		
75731	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Foundation Condition	Good	
75732	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
75733	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75734	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75735	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75736	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75737	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75738	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Tank Paint Condition	Good	
75739	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75740	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Moisture and Leak Free?	y	
75741	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Grounds in Place?	y	
75742	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	General Comments		
75743	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Foundation Condition	Good	
75744	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
75745	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75746	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75747	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75748	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75749	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75750	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Unknown Operations	0	
75751	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75752	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
75753	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
75754	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
75755	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
75756	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	General Comments	Fence grounds missing on two sides, will replace today. Fence fabric and some rail are getting rusty as well as barbwire...fence is 6 foot	
75757	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
75758	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
75759	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
75760	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
75761	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
75762	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
75763	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Foundation Condition	Good	
75764	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75765	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75766	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	General Comments	1st pole is marked to be replaced	
75767	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75768	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
75769	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75770	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
75771	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75772	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
75773	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
75774	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Tank Paint Condition	Good	
75775	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Switching Operations	0	
75776	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75777	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations This Read Vac	0	
75778	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	General Comments		
75779	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
75780	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
75781	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
75782	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
75783	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
75784	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
75785	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
75786	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
75787	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75788	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75789	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75790	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75791	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75792	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75793	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75794	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75795	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
75796	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
75797	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
75798	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75799	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75800	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75801	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	1	
75802	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Unknown Operations	0	
75803	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
75804	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Switching Operations	0	
75805	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75806	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations This Read Vac	0	
75807	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AL	119	
75808	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AF	119	
75809	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
75810	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Maintenance Operations	0	
75811	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Grounds In Place?	y	
75812	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	General Comments		
75813	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	General Comments		
75814	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
75815	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
75816	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
75817	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations Ground	0	
75818	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
75819	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
75820	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
75821	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75822	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75823	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75824	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75825	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75826	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
75827	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75828	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75829	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps C Ø	138.0	
75830	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps B Ø	117.0	
75831	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps A Ø	121.0	
75832	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75833	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75834	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
75835	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
75836	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
75837	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
75838	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
75839	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
75840	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
75841	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
75842	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
75843	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
75844	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
75845	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
75846	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
75847	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
75848	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
75849	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	General Comments		
75850	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
75851	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
75852	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Foundation Condition	Good	
75853	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
75854	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
75855	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
75856	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
75857	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
75858	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Present	31	°C
75859	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
75860	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
75861	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
75862	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
75863	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
75864	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	General Comments		
75865	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	General Comments		
75866	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75867	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
75868	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
75869	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75870	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75871	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75872	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75873	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations	1	
75874	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75875	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75876	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75877	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps A Ø	326.0	
75878	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps B Ø	295.0	
75879	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps C Ø	284.0	
75880	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushing Condition	Good	
75881	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75882	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75883	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75884	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75885	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75886	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75887	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75888	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Moisture and Leak Free?	y	
75889	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AF	52	
75890	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AL	52	
75891	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations This Read Vac	1	
75892	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Switching Operations	0	
75893	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Tank Paint Condition	Good	
75894	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3210	
75895	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
75896	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
75897	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
75898	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
75899	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
75900	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
75901	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
75902	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Present	31	°C
75903	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Max	47	°C
75904	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
75905	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
75906	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Unknown Operations	0	
75907	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations	1	
75908	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75909	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75910	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75911	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps A Ø	30.0	
75912	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps B Ø	34.0	
75913	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps C Ø	32.0	
75914	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushing Condition	Good	
75915	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
75916	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
75917	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75918	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75919	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
75920	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
75921	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
75922	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75923	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	385.20	kw
75924	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
75925	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
75926	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	General Comments		
75927	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	General Comments		
75928	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
75929	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
75930	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
75931	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
75932	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
75933	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
75934	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75935	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75936	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
75937	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
75938	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
75939	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
75940	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
75941	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
75942	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75943	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
75944	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75945	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75946	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations A Ø	0	
75947	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations B Ø	0	
75948	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations C Ø	0	
75949	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations Ground	0	
75950	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Follow-up Action Required?	n	
75951	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Unknown Operations	0	
75952	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
75953	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Switching Operations	0	
75954	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
75955	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
75956	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AL	127	
75957	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AF	127	
75958	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
75959	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
75960	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
75961	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	General Comments		
75962	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Unknown Operations	0	
75963	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Tank Paint Condition	Good	
75964	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Switching Operations	5	
75965	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations This Read Vac	5	
75966	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	General Comments		
75967	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
75968	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
75969	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
75970	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
75971	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
75972	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
75973	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
75974	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
75975	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75976	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
75977	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
75978	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
75979	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
75980	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
75981	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
75982	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps C Ø	0.0	
75983	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps B Ø	0.0	
75984	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps A Ø	0.0	
75985	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
75986	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
75987	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
75988	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AL	260	
75989	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AF	260	
75990	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Moisture and Leak Free?	y	
75991	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Maintenance Operations	0	
75992	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Grounds in Place?	y	
75993	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	General Comments		
75994	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	General Comments		
75995	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Foundation Condition	Good	
75996	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Follow-up Action Required?	n	
75997	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Follow-up Action Required?	n	
75998	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
75999	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76000	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations A Ø	0	
76001	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations B Ø	0	
76002	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations C Ø	0	
76003	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations Ground	0	
76004	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Follow-up Action Required?	n	
76005	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Follow-up Action Required?	n	
76006	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Foundation Condition	Good	
76007	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	General Comments		
76008	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	General Comments		
76009	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Grounds in Place?	y	
76010	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76011	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Maintenance Operations	0	
76012	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
76013	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AF	220	
76014	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AL	220	
76015	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations This Read Vac	0	
76016	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Switching Operations	0	
76017	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Tank Paint Condition	Good	
76018	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Unknown Operations	0	
76019	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
76020	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
76021	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
76022	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
76023	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
76024	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
76025	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Vegetation	None	
76026	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
76027	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	General Comments		
76028	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
76029	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
76030	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
76031	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
76032	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
76033	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
76034	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Trash?	y	
76035	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
76036	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
76037	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
76038	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	General Comments		
76039	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
76040	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
76041	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
76042	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
76043	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
76044	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
76045	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
76046	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
76047	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
76048	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
76049	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
76050	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
76051	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
76052	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76053	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
76054	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
76055	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
76056	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	General Comments		
76057	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
76058	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
76059	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
76060	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Follow-up Action Required?	n	
76061	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
76062	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
76063	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	General Comments		
76064	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	General Comments		
76065	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
76066	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	LTC Totalizer Reading	5515.20	kw
76067	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
76068	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
76069	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Max	28	°C
76070	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Present	26	°C
76071	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
76072	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
76073	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
76074	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
76075	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
76076	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
76077	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
76078	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
76079	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Reading	1.1490	
76080	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
76081	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
76082	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
76083	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
76084	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
76085	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
76086	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
76087	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
76088	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	General Comments		
76089	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
76090	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
76091	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
76092	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
76093	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
76094	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Vegetation	None	
76095	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
76096	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	General Comments		
76097	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Foundation Condition	Good	
76098	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
76099	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76100	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76101	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76102	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76103	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76104	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76105	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushing Condition	Good	
76106	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Unknown Operations	0	
76107	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Tank Paint Condition	Good	
76108	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
76109	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
76110	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
76111	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
76112	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
76113	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
76114	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
76115	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
76116	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	n	
76117	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
76118	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
76119	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
76120	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	General Comments		
76121	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
76122	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
76123	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
76124	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
76125	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
76126	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
76127	11/15/2019 14:46	Distribution	Harrigate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
76128	11/15/2019 14:46	Distribution	Harrigate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
76129	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	All Connections OK?	y	
76130	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	Follow-up Action Required?	n	
76131	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76132	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76133	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 inches?	y	
76134	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
76135	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
76136	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	General Comments		
76137	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	LTC Operation Checked?	y	
76138	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
76139	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
76140	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
76141	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTC000747	LTCControl	005-5	LTC Control Insp	VRR Time Delay	30	Seconds
76142	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
76143	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76144	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
76145	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Tank Paint Condition	Good	
76146	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76147	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Moisture and Leak Free?	y	
76148	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76149	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Grounds in Place?	y	
76150	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
76151	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
76152	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
76153	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
76154	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
76155	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
76156	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
76157	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
76158	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
76159	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
76160	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
76161	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
76162	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
76163	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76164	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	General Comments		
76165	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
76166	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76167	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Maintenance Operations	0	
76168	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
76169	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AF	138	
76170	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AL	138	
76171	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations This Read Vac	0	
76172	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76173	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Switching Operations	0	
76174	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
76175	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76176	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76177	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76178	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76179	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushing Condition	Good	
76180	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps C Ø	0.0	
76181	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Unknown Operations	0	
76182	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushing Condition	Good	
76183	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76184	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76185	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76186	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76187	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76188	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76189	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
76190	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Foundation Condition	Good	
76191	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	General Comments		
76192	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Grounds in Place?	y	
76193	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76194	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Moisture and Leak Free?	y	
76195	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76196	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Tank Paint Condition	Good	
76197	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushing Condition	Good	
76198	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76199	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76200	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76201	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76202	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76203	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76204	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
76205	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Foundation Condition	Good	
76206	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	General Comments		
76207	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Grounds in Place?	y	
76208	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76209	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Moisture and Leak Free?	y	
76210	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76211	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Tank Paint Condition	Good	
76212	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps B Ø	0.0	
76213	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps A Ø	0.0	
76214	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76215	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76216	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76217	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	9 Month Operations	0	
76218	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Switching Operations	0	
76219	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76220	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations This Read Vac	0	
76221	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AL	135	
76222	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AF	135	
76223	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Moisture and Leak Free?	y	
76224	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Maintenance Operations	0	
76225	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76226	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Grounds in Place?	y	
76227	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	General Comments		
76228	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations	0	
76229	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76230	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76231	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76232	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps A Ø	400.0	
76233	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	390.0	
76234	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps C Ø	400.0	
76235	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
76236	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76237	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76238	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76239	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76240	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76241	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76242	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76243	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76244	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76245	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
76246	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
76247	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
76248	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations Ground	0	
76249	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
76250	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
76251	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
76252	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	General Comments		
76253	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	General Comments		
76254	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
76255	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
76256	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	General Comments		
76257	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
76258	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	12.5	VAC
76259	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
76260	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
76261	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	LTC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
76262	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Foundation Condition	Good	
76263	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Follow-up Action Required?	n	
76264	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Follow-up Action Required?	n	
76265	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations Ground	0	
76266	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations C Ø	0	
76267	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations B Ø	0	
76268	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations A Ø	0	
76269	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76270	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76271	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76272	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76273	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76274	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations This Read Vac	0	
76275	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AL	133	
76276	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AF	133	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
76277	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Moisture and Leak Free?	y	
76278	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Maintenance Operations	0	
76279	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Grounds in Place?	y	
76280	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	General Comments		
76281	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	General Comments		
76282	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Foundation Condition	Good	
76283	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Follow-up Action Required?	n	
76284	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
76285	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations Ground	0	
76286	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations C Ø	0	
76287	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations B Ø	0	
76288	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	6L	
76289	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
76290	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3L	
76291	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
76292	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Left Counter	30852	
76293	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Found Counter	30852	
76294	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
76295	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	General Comments		
76296	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
76297	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
76298	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
76299	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Leaks	None	
76300	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
76301	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Operations Counter	13	
76302	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
76303	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
76304	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	General Comments		
76305	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
76306	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
76307	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
76308	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
76309	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
76310	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
76311	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations A Ø	0	
76312	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76313	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76314	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76315	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76316	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76317	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76318	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76319	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76320	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps C Ø	0.0	
76321	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps B Ø	0.0	
76322	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps A Ø	0.0	
76323	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76324	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76325	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76326	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations	0	
76327	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
76328	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AL	141	
76329	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AF	141	
76330	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Moisture and Leak Free?	y	
76331	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Maintenance Operations	0	
76332	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Grounds in Place?	y	
76333	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	General Comments		
76334	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	General Comments		
76335	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Foundation Condition	Good	
76336	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Follow-up Action Required?	n	
76337	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
76338	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	General Comments		
76339	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
76340	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
76341	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
76342	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
76343	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
76344	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
76345	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations Ground	0	
76346	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations C Ø	0	
76347	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations B Ø	0	
76348	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations A Ø	0	
76349	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76350	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76351	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76352	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76353	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
76354	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
76355	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1890	
76356	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
76357	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76358	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76359	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76360	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76361	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps C Ø	0.0	
76362	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps B Ø	0.0	
76363	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps A Ø	0.0	
76364	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76365	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76366	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76367	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations	0	
76368	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Tank Paint Condition	Good	
76369	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76370	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Moisture and Leak Free?	y	
76371	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Grounds in Place?	y	
76372	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	General Comments		
76373	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Foundation Condition	Good	
76374	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
76375	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76376	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76377	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76378	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76379	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76380	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Unknown Operations	0	
76381	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Tank Paint Condition	Good	
76382	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Switching Operations	0	
76383	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
76384	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
76385	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	General Comments		
76386	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
76387	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
76388	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
76389	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
76390	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
76391	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
76392	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
76393	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
76394	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
76395	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
76396	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	General Comments		
76397	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
76398	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	All Connections OK?	y	
76399	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	Follow-up Action Required?	n	
76400	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	General Comments		
76401	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	LTC Operation Checked?	y	
76402	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
76403	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
76404	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
76405	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTC000744	LTCControl	669-2	LTC Control Insp	VRR Time Delay	30	Seconds
76406	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
76407	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
76408	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76409	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76410	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76411	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76412	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76413	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76414	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76415	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76416	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76417	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
76418	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence >'5' Clearance To Trees?	y	
76419	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
76420	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
76421	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
76422	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
76423	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
76424	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
76425	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
76426	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
76427	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
76428	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	General Comments		
76429	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
76430	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
76431	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
76432	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
76433	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
76434	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
76435	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	General Comments	Adjusted thermostat on heater	
76436	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
76437	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
76438	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
76439	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
76440	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
76441	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps C Ø	43.0	
76442	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps B Ø	45.0	
76443	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
76444	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
76445	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
76446	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
76447	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
76448	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
76449	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
76450	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
76451	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
76452	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
76453	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
76454	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
76455	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
76456	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
76457	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
76458	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
76459	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
76460	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
76461	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
76462	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
76463	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
76464	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
76465	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
76466	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
76467	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
76468	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
76469	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
76470	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
76471	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76472	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
76473	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	22	
76474	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	22	
76475	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
76476	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
76477	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76478	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
76479	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
76480	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
76481	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
76482	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
76483	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
76484	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
76485	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
76486	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
76487	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
76488	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
76489	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
76490	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
76491	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
76492	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
76493	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
76494	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
76495	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
76496	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
76497	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
76498	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
76499	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
76500	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
76501	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76502	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
76503	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
76504	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
76505	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
76506	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
76507	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
76508	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	General Comments		
76509	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	General Comments		
76510	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
76511	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
76512	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
76513	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
76514	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76515	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76516	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76517	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76518	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76519	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76520	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations A Ø	0	
76521	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations B Ø	0	
76522	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations C Ø	0	
76523	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations Ground	0	
76524	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Follow-up Action Required?	n	
76525	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Follow-up Action Required?	n	
76526	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Foundation Condition	Good	
76527	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	General Comments		
76528	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	General Comments		
76529	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Grounds in Place?	y	
76530	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Maintenance Operations	0	
76531	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Moisture and Leak Free?	y	
76532	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AF	283	
76533	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AL	283	
76534	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations This Read Vac	4	
76535	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76536	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
76537	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76538	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76539	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
76540	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
76541	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
76542	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
76543	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
76544	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
76545	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
76546	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	VRR Time Delay	60	Seconds
76547	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Follow-up Action Required?	n	
76548	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	15	
76549	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
76550	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
76551	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
76552	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
76553	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
76554	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
76555	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
76556	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
76557	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
76558	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
76559	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
76560	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
76561	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
76562	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
76563	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
76564	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
76565	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
76566	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
76567	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
76568	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	General Comments	Brand new batteries and charger, will be connected to new breaker when it is installed. Charger and batteries will be wired up in the r	
76569	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
76570	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	All Connections OK?	y	
76571	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	Follow-up Action Required?	n	
76572	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	General Comments		
76573	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	LTC Operation Checked?	y	
76574	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
76575	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
76576	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	LTC0000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76577	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
76578	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
76579	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Vegetation	None	
76580	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
76581	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	General Comments		
76582	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
76583	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
76584	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
76585	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
76586	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations	21	
76587	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76588	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76589	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76590	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps A Ø	145.0	
76591	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps B Ø	165.0	
76592	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps C Ø	200.0	
76593	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushing Condition	Good	
76594	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
76595	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
76596	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
76597	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76598	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76599	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76600	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
76601	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Trash?	y	
76602	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
76603	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
76604	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
76605	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
76606	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
76607	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
76608	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2708	
76609	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
76610	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
76611	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
76612	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
76613	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
76614	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
76615	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
76616	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
76617	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	General Comments		
76618	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	General Comments		
76619	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
76620	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
76621	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	90.51	kw
76622	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
76623	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
76624	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
76625	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Unknown Operations	0	
76626	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Switching Operations	0	
76627	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations This Read AM	0	
76628	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AL	363	
76629	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AF	363	
76630	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Maintenance Operations	0	
76631	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
76632	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
76633	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
76634	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
76635	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
76636	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
76637	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
76638	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
76639	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
76640	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
76641	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
76642	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
76643	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	General Comments		
76644	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
76645	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
76646	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Foundation Condition	Good	
76647	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
76648	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
76649	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	General Comments		
76650	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	General Comments		
76651	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76652	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
76653	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
76654	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
76655	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations Ground	0	
76656	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations C Ø	0	
76657	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations B Ø	0	
76658	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
76659	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	General Comments		
76660	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	General Comments	LTC to drag hand shaft seal is seeping oil	
76661	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Found Counter	5355	
76662	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Switching Operations	4	
76663	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Tank Paint Condition	Good	
76664	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Unknown Operations	0	
76665	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Left Counter	5357	
76666	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
76667	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Current Tap Position	5L	
76668	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Max Tap Position	3L	
76669	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Min Tap Position	12L	
76670	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Operations Since Last Insp	754	
76671	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
76672	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
76673	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
76674	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
76675	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
76676	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
76677	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
76678	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
76679	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
76680	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
76681	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BCH001022	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
76682	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
76683	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
76684	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
76685	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
76686	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
76687	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
76688	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
76689	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
76690	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
76691	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
76692	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
76693	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
76694	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
76695	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
76696	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	VRR Time Delay	30	Seconds
76697	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
76698	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
76699	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
76700	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
76701	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	LTC Operation Checked?	y	
76702	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	General Comments		
76703	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	Follow-up Action Required?	n	
76704	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTC0000619	LTCControl	197-5	LTC Control Insp	All Connections OK?	y	
76705	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4066.56	kw
76706	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
76707	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
76708	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Max	60	*C
76709	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Present	35	*C
76710	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
76711	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
76712	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
76713	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76714	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76715	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76716	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76717	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76718	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76719	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
76720	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
76721	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
76722	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
76723	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
76724	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
76725	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
76726	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
76727	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
76728	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
76729	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
76730	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
76731	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
76732	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
76733	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
76734	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
76735	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
76736	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
76737	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
76738	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
76739	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
76740	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
76741	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
76742	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
76743	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
76744	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
76745	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
76746	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
76747	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
76748	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
76749	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
76750	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76751	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
76752	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
76753	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
76754	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
76755	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
76756	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
76757	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
76758	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
76759	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	55	
76760	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	55	
76761	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations This Read Vac	1	
76762	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
76763	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	1	
76764	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
76765	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
76766	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
76767	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
76768	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
76769	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
76770	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
76771	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Evidence of Insects	None	
76772	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
76773	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
76774	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Swept?	y	
76775	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
76776	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
76777	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
76778	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
76779	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
76780	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
76781	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
76782	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
76783	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
76784	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
76785	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
76786	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
76787	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	General Comments		
76788	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
76789	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
76790	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
76791	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
76792	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
76793	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
76794	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	2	
76795	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76796	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76797	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76798	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
76799	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
76800	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	80.0	
76801	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76802	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
76803	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
76804	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	750	
76805	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
76806	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	1L	
76807	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	8L	
76808	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	7L	
76809	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
76810	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	270566	
76811	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
76812	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	General Comments	Trees within 5 ft and also over hanging limbs.	
76813	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
76814	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
76815	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
76816	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
76817	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	90.0	
76818	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	100.0	
76819	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
76820	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76821	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76822	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76823	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
76824	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
76825	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
76826	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
76827	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
76828	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
76829	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
76830	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
76831	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
76832	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
76833	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
76834	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
76835	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
76836	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
76837	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
76838	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
76839	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
76840	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	General Comments	(1) TOWER LEG FOUNDATION CRUMBLING	
76841	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
76842	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
76843	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Foundation Condition	Good	
76844	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
76845	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
76846	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
76847	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
76848	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
76849	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
76850	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
76851	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
76852	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
76853	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
76854	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
76855	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
76856	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
76857	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
76858	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
76859	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
76860	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
76861	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
76862	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
76863	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
76864	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
76865	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
76866	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
76867	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
76868	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
76869	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
76870	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
76871	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
76872	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
76873	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
76874	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
76875	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
76876	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	106	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76877	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	106	
76878	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
76879	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
76880	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
76881	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
76882	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
76883	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
76884	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
76885	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	1.7490	
76886	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
76887	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
76888	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
76889	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
76890	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
76891	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Follow-up Action Required?	n	
76892	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
76893	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
76894	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	General Comments		
76895	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	General Comments		
76896	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
76897	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	LTC Totalizer Reading	3395.52	kw
76898	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
76899	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
76900	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Max	50	°C
76901	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Present	30	°C
76902	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
76903	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
76904	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
76905	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
76906	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
76907	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
76908	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
76909	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
76910	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Reading	.2358	
76911	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
76912	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
76913	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	270560	
76914	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
76915	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
76916	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
76917	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
76918	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
76919	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
76920	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
76921	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
76922	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	25	°C
76923	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
76924	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
76925	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	12592.80	kw
76926	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
76927	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
76928	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
76929	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
76930	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
76931	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
76932	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
76933	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps B Ø	0.0	
76934	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps A Ø	0.0	
76935	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
76936	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
76937	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
76938	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	9 Month Operations	1	
76939	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Unknown Operations	0	
76940	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Tank Paint Condition	Good	
76941	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Switching Operations	0	
76942	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations This Read Vac	0	
76943	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AL	173	
76944	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AF	173	
76945	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Moisture and Leak Free?	y	
76946	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Maintenance Operations	0	
76947	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76948	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Grounds in Place?	y	
76949	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	General Comments		
76950	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	General Comments		
76951	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
76952	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Follow-up Action Required?	n	
76953	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Follow-up Action Required?	n	
76954	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations Ground	0	
76955	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations C Ø	0	
76956	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations B Ø	0	
76957	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations A Ø	0	
76958	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
76959	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
76960	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
76961	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
76962	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
76963	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
76964	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
76965	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
76966	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
76967	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushing Condition	Good	
76968	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps C Ø	233.0	
76969	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps B Ø	242.0	
76970	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps A Ø	224.0	
76971	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
76972	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
76973	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
76974	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	9 Month Operations	0	
76975	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Unknown Operations	0	
76976	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Tank Paint Condition	Good	
76977	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Switching Operations	0	
76978	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations This Read Vac	0	
76979	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AL	192	
76980	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AF	192	
76981	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Moisture and Leak Free?	y	
76982	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Maintenance Operations	0	
76983	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Heaters (All) Functioning?	y	
76984	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Grounds in Place?	y	
76985	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	General Comments		
76986	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	General Comments		
76987	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Foundation Condition	Good	
76988	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Left Counter	277622	
76989	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Found Counter	277612	
76990	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	General Comments		
76991	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	General Comments		
76992	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
76993	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Follow-up Action Required?	n	
76994	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
76995	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
76996	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
76997	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Operations Since Last Insp	1189	
76998	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	5	
76999	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Min Tap Position	8L	
77000	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Max Tap Position	5R	
77001	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Current Tap Position	1L	
77002	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
77003	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Left Counter	26752	
77004	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Found Counter	26752	
77005	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	General Comments		
77006	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	General Comments		
77007	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
77008	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Follow-up Action Required?	n	
77009	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
77010	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
77011	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
77012	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
77013	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
77014	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
77015	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
77016	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
77017	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
77018	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AF	164	
77019	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
77020	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Maintenance Operations	0	
77021	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77022	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
77023	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	General Comments		
77024	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	General Comments		
77025	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
77026	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77027	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
77028	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations Ground	0	
77029	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations C Ø	0	
77030	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations B Ø	0	
77031	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations A Ø	0	
77032	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77033	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77034	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77035	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77036	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77037	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77038	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77039	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77040	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77041	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
77042	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps C Ø	0.0	
77043	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77044	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77045	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77046	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77047	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77048	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77049	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77050	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77051	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushing Condition	Good	
77052	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps C Ø	198.0	
77053	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps B Ø	220.0	
77054	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps A Ø	195.0	
77055	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77056	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77057	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77058	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations	2	
77059	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Present	20	*C
77060	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Max	50	*C
77061	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
77062	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
77063	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	LTC Totalizer Reading	9567.36	kw
77064	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77065	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	General Comments		
77066	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	General Comments		
77067	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77068	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77069	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Follow-up Action Required?	n	
77070	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77071	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
77072	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
77073	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77074	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77075	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77076	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77077	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77078	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77079	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77080	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77081	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77082	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations A Ø	0	
77083	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77084	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
77085	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77086	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77087	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations B Ø	0	
77088	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations C Ø	0	
77089	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations Ground	0	
77090	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Follow-up Action Required?	n	
77091	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Follow-up Action Required?	n	
77092	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Foundation Condition	Good	
77093	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	General Comments		
77094	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	General Comments		
77095	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Grounds in Place?	y	
77096	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77097	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Maintenance Operations	1	
77098	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Follow-up Action Required?	n	
77099	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Follow-up Action Required?	n	
77100	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations Ground	0	
77101	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77102	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations B Ø	0	
77103	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations A Ø	0	
77104	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77105	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77106	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77107	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77108	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77109	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77110	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77111	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77112	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77113	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushing Condition	Good	
77114	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps C Ø	195.0	
77115	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps B Ø	169.0	
77116	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps A Ø	176.0	
77117	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77118	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77119	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77120	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations	1	
77121	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
77122	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
77123	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Reading	.9966	
77124	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
77125	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77126	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77127	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
77128	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77129	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77130	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77131	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77132	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Unknown Operations	0	
77133	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Tank Paint Condition	Good	
77134	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Switching Operations	0	
77135	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
77136	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations This Read Vac	0	
77137	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AL	170	
77138	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AF	170	
77139	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Moisture and Leak Free?	y	
77140	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Maintenance Operations	0	
77141	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77142	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Grounds in Place?	y	
77143	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	General Comments		
77144	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	General Comments		
77145	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Foundation Condition	Good	
77146	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Follow-up Action Required?	n	
77147	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Follow-up Action Required?	n	
77148	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations Ground	0	
77149	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations C Ø	0	
77150	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations B Ø	0	
77151	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations A Ø	0	
77152	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77153	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
77154	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
77155	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
77156	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
77157	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
77158	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Foundation Condition	Good	
77159	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
77160	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
77161	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	General Comments	ok	
77162	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
77163	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
77164	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
77165	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
77166	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
77167	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
77168	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
77169	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
77170	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
77171	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
77172	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
77173	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
77174	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
77175	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	General Comments		
77176	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77177	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
77178	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
77179	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
77180	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
77181	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
77182	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
77183	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
77184	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
77185	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
77186	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
77187	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
77188	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
77189	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
77190	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
77191	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
77192	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
77193	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
77194	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Operations Since Last Insp	1657	
77195	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
77196	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
77197	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
77198	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-2.0	psi
77199	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Min Tap Position	13L	
77200	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Max Tap Position	4R	
77201	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Current Tap Position	5L	
77202	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
77203	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Left Counter	11393	
77204	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Found Counter	11385	
77205	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	General Comments		
77206	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	General Comments		
77207	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
77208	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations A Ø	0	
77209	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
77210	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
77211	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
77212	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
77213	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
77214	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
77215	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps C Ø	25.0	
77216	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps B Ø	25.0	
77217	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps A Ø	25.0	
77218	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
77219	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
77220	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
77221	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Months Operations	0	
77222	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Present	17	°C
77223	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77224	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
77225	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77226	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77227	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
77228	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
77229	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77230	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
77231	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3017	
77232	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
77233	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
77234	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Vegetation	None	
77235	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
77236	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
77237	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
77238	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
77239	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Trash?	y	
77240	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
77241	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
77242	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
77243	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
77244	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
77245	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
77246	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	General Comments	ok	
77247	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
77248	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	General Comments	SPR no longer in service. Under frequency is being monitored by the SEL's	
77249	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
77250	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
77251	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77252	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
77253	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
77254	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
77255	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Trash?	y	
77256	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
77257	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
77258	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
77259	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
77260	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Vegetation	None	
77261	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
77262	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
77263	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77264	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Grounds in Place?	y	
77265	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	General Comments		
77266	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	General Comments		
77267	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Foundation Condition	Good	
77268	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Follow-up Action Required?	n	
77269	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Follow-up Action Required?	n	
77270	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations Ground	0	
77271	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations C Ø	0	
77272	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations B Ø	0	
77273	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations A Ø	0	
77274	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77275	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77276	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77277	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77278	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77279	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77280	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77281	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77282	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77283	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushing Condition	Good	
77284	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps C Ø	320.0	
77285	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps B Ø	334.0	
77286	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps A Ø	325.0	
77287	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77288	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77289	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77290	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations	1	
77291	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Unknown Operations	0	
77292	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
77293	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Switching Operations	0	
77294	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations This Read Vac	0	
77295	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AL	164	
77296	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps A Ø	31.0	
77297	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps B Ø	33.0	
77298	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps C Ø	34.0	
77299	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushing Condition	Good	
77300	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
77301	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
77302	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
77303	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
77304	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
77305	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
77306	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
77307	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
77308	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
77309	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
77310	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
77311	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
77312	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
77313	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Operations Since Last Insp	1250	
77314	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Min Tap Position	6L	
77315	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Max Tap Position	5R	
77316	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Current Tap Position	2L	
77317	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
77318	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Follow-up Action Required?	n	
77319	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Unknown Operations	0	
77320	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Tank Paint Condition	Good	
77321	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Switching Operations	0	
77322	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations This Read Vac	0	
77323	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AL	0	
77324	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AF	372	
77325	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Moisture and Leak Free?	y	
77326	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77327	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Grounds in Place?	y	
77328	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	General Comments		
77329	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	General Comments		
77330	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Foundation Condition	Good	
77331	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Follow-up Action Required?	n	
77332	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Follow-up Action Required?	n	
77333	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations Ground	0	
77334	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations C Ø	0	
77335	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations B Ø	0	
77336	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations A Ø	0	
77337	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77338	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77339	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77340	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77341	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77342	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77343	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77344	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77345	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77346	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushing Condition	Good	
77347	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps C Ø	0.0	
77348	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps B Ø	0.0	
77349	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps A Ø	0.0	
77350	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77351	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77352	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77353	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations	2	
77354	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
77355	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
77356	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
77357	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
77358	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
77359	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
77360	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	General Comments		
77361	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
77362	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations	1	
77363	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77364	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77365	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77366	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Unknown Operations	0	
77367	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Tank Paint Condition	Good	
77368	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Switching Operations	0	
77369	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations This Read Vac	0	
77370	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AL	207	
77371	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AF	207	
77372	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
77373	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Maintenance Operations	0	
77374	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
77375	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
77376	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
77377	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Warning Signs OK?	y	
77378	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
77379	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
77380	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
77381	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Reading	.6910	
77382	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Max	50	°C
77383	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Present	35	°C
77384	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
77385	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
77386	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
77387	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
77388	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
77389	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	216	
77390	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	216	
77391	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
77392	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
77393	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77394	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
77395	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
77396	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
77397	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
77398	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
77399	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
77400	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
77401	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77402	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
77403	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
77404	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77405	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77406	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77407	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77408	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77409	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77410	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77411	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77412	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77413	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
77414	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
77415	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
77416	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
77417	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77418	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77419	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77420	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
77421	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
77422	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Vegetation	None	
77423	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
77424	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
77425	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
77426	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
77427	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
77428	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
77429	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
77430	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
77431	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
77432	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
77433	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
77434	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
77435	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
77436	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
77437	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
77438	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
77439	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
77440	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
77441	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	CAP000007	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Good	
77442	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
77443	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
77444	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Current Tap Position	10L	
77445	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
77446	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
77447	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
77448	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
77449	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	General Comments		
77450	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
77451	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Max Tap Position	8L	
77452	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Min Tap Position	14L	
77453	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
77454	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
77455	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
77456	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
77457	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
77458	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Regulator As Left Counter	192093	
77459	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
77460	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Leaks	None	
77461	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
77462	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
77463	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
77464	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
77465	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Cap Bank CT in Good Condition?	y	
77466	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
77467	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
77468	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
77469	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
77470	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Foundation Condition	Good	
77471	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
77472	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
77473	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	General Comments		
77474	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
77475	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
77476	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77477	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77478	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77479	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77480	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
77481	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
77482	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
77483	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
77484	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
77485	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
77486	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
77487	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	General Comments		
77488	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
77489	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
77490	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
77491	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
77492	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
77493	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
77494	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
77495	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
77496	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
77497	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
77498	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
77499	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
77500	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
77501	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
77502	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
77503	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
77504	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
77505	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
77506	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
77507	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
77508	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
77509	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
77510	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
77511	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
77512	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
77513	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
77514	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
77515	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
77516	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
77517	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
77518	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
77519	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
77520	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	302145	
77521	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
77522	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
77523	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
77524	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
77525	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
77526	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	General Comments		
77527	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
77528	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	General Comments		
77529	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
77530	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
77531	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
77532	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
77533	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
77534	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
77535	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Trash?	y	
77536	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
77537	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
77538	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
77539	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
77540	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	General Comments	no 911 signage and station needs to be vermint guarded	
77541	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
77542	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
77543	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
77544	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
77545	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
77546	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
77547	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
77548	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
77549	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
77550	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
77551	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77552	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
77553	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
77554	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
77555	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
77556	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Reading	.6114	
77557	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
77558	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77559	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77560	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
77561	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77562	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77563	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77564	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77565	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Present	25	°C
77566	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Max	55	°C
77567	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
77568	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
77569	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	LTC Totalizer Reading	5869.44	kw
77570	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77571	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	General Comments		
77572	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	General Comments		
77573	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77574	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77575	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Follow-up Action Required?	n	
77576	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77577	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
77578	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77579	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77580	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77581	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77582	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77583	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77584	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77585	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77586	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations A Ø	0	
77587	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations B Ø	0	
77588	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps A Ø	103.0	
77589	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps B Ø	111.0	
77590	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps C Ø	103.0	
77591	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
77592	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
77593	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
77594	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
77595	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
77596	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
77597	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations C Ø	0	
77598	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations Ground	0	
77599	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Follow-up Action Required?	n	
77600	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Follow-up Action Required?	n	
77601	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Foundation Condition	Good	
77602	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	General Comments		
77603	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	General Comments		
77604	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Grounds in Place?	y	
77605	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77606	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Maintenance Operations	0	
77607	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Moisture and Leak Free?	y	
77608	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AF	178	
77609	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AL	178	
77610	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations This Read Vac	0	
77611	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Switching Operations	0	
77612	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Tank Paint Condition	Good	
77613	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Unknown Operations	0	
77614	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
77615	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	General Comments		
77616	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
77617	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
77618	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
77619	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
77620	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
77621	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
77622	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps C Ø	122.0	
77623	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushing Condition	Good	
77624	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
77625	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
77626	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77627	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	General Comments	ok	
77628	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
77629	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77630	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77631	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77632	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations	5	
77633	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
77634	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
77635	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
77636	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
77637	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
77638	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
77639	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77640	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
77641	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
77642	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77643	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
77644	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
77645	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77646	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	General Comments		
77647	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	General Comments		
77648	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
77649	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
77650	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
77651	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4127.04	kw
77652	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
77653	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
77654	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
77655	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
77656	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77657	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
77658	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77659	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77660	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
77661	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
77662	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations	2	
77663	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77664	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77665	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
77666	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7196	
77667	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77668	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77669	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps A Ø	109.0	
77670	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps B Ø	105.0	
77671	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations	10	
77672	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
77673	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
77674	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
77675	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps A Ø	130.0	
77676	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps B Ø	130.0	
77677	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps C Ø	130.0	
77678	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushing Condition	Good	
77679	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77680	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
77681	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
77682	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
77683	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
77684	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
77685	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
77686	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
77687	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
77688	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
77689	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
77690	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2680	
77691	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
77692	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
77693	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
77694	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
77695	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77696	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77697	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
77698	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77699	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
77700	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
77701	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77702	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Follow-up Action Required?	n	
77703	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77704	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77705	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	General Comments		
77706	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	General Comments		
77707	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77708	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	LTC Totalizer Reading	12438.00	kw
77709	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
77710	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
77711	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
77712	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
77713	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77714	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77715	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77716	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77717	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
77718	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77719	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77720	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
77721	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
77722	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
77723	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
77724	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
77725	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
77726	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
77727	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
77728	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
77729	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
77730	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
77731	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
77732	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Operations Counter	309	
77733	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
77734	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
77735	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
77736	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
77737	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
77738	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
77739	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
77740	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
77741	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
77742	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
77743	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
77744	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
77745	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
77746	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
77747	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
77748	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
77749	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
77750	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
77751	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
77752	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
77753	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
77754	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations A Ø	0	
77755	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations B Ø	0	
77756	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations C Ø	0	
77757	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations Ground	0	
77758	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Follow-up Action Required?	n	
77759	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Follow-up Action Required?	n	
77760	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Foundation Condition	Good	
77761	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	General Comments		
77762	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	General Comments		
77763	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Grounds in Place?	y	
77764	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
77765	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Maintenance Operations	0	
77766	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Moisture and Leak Free?	y	
77767	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AF	183	
77768	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AL	183	
77769	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations This Read Vac	0	
77770	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Switching Operations	0	
77771	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Tank Paint Condition	Good	
77772	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Unknown Operations	0	
77773	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
77774	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
77775	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
77776	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77777	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
77778	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
77779	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
77780	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
77781	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
77782	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
77783	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
77784	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77785	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77786	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77787	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
77788	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
77789	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
77790	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Present	42	°C
77791	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77792	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77793	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
77794	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
77795	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
77796	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
77797	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
77798	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
77799	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
77800	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
77801	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
77802	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
77803	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
77804	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77805	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77806	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
77807	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
77808	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
77809	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77810	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77811	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
77812	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Reading	.6720	
77813	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
77814	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
77815	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
77816	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
77817	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
77818	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
77819	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	63799	
77820	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
77821	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
77822	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
77823	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
77824	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
77825	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
77826	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
77827	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
77828	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77829	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77830	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
77831	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
77832	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
77833	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
77834	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
77835	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
77836	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
77837	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
77838	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
77839	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
77840	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
77841	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	19	
77842	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
77843	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
77844	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments		
77845	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
77846	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
77847	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
77848	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
77849	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
77850	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
77851	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
77852	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
77853	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
77854	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Max	65	°C
77855	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
77856	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
77857	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Vegetation	None	
77858	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
77859	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	General Comments		
77860	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
77861	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
77862	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
77863	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
77864	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
77865	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
77866	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Trash?	y	
77867	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
77868	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
77869	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
77870	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77871	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	General Comments		
77872	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Unknown Operations	0	
77873	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Tank Paint Condition	Good	
77874	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Switching Operations	0	
77875	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
77876	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations This Read Vac	0	
77877	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AL	186	
77878	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AF	186	
77879	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	General Comments		
77880	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77881	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77882	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Follow-up Action Required?	n	
77883	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77884	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	LTC Totalizer Reading	7153.92	kw
77885	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
77886	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
77887	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Max	40	°C
77888	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Present	25	°C
77889	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77890	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77891	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77892	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77893	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
77894	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77895	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77896	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
77897	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Reading	.7452	
77898	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
77899	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
77900	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
77901	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
77902	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
77903	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
77904	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
77905	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
77906	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
77907	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
77908	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Moisture and Leak Free?	y	
77909	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
77910	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
77911	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
77912	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
77913	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
77914	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
77915	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
77916	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
77917	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
77918	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
77919	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
77920	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
77921	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
77922	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	General Comments		
77923	11/15/2019 9:48	Distribution	Walker Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
77924	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
77925	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
77926	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
77927	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
77928	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	562	
77929	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
77930	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	285927	
77931	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
77932	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
77933	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	
77934	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Months Operations	0	
77935	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
77936	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
77937	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
77938	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
77939	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
77940	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
77941	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
77942	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
77943	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
77944	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
77945	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
77946	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
77947	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
77948	11/15/2019 13:13	Distribution	Fies City Quarterly Inspection	R1116	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
77949	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
77950	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Reading	.7200	
77951	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
77952	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
77953	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
77954	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
77955	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
77956	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
77957	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
77958	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
77959	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Present	25	*C
77960	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Max	48	*C
77961	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
77962	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
77963	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	LTC Totalizer Reading	5184.00	kw
77964	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77965	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	General Comments		
77966	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	General Comments		
77967	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77968	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77969	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Follow-up Action Required?	n	
77970	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77971	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
77972	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
77973	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77974	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
77975	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
77976	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
77977	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
77978	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
77979	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
77980	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Follow-up Action Required?	n	
77981	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
77982	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
77983	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	General Comments		
77984	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	General Comments		
77985	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
77986	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	General Comments		
77987	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Follow-up Action Required?	n	
77988	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
77989	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations Ground	0	
77990	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations C Ø	0	
77991	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations B Ø	0	
77992	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations A Ø	0	
77993	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
77994	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
77995	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
77996	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
77997	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps C Ø	150.0	
77998	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps B Ø	150.0	
77999	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps A Ø	160.0	
78000	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
78001	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78002	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
78003	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Months Operations	0	
78004	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
78005	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
78006	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
78007	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
78008	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
78009	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
78010	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
78011	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
78012	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
78013	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
78014	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
78015	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
78016	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
78017	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	79.0	
78018	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	81.0	
78019	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	79.0	
78020	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78021	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78022	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78023	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78024	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78025	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78026	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78027	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78028	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
78029	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78030	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78031	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
78032	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
78033	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78034	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	45	°C
78035	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	25	°C
78036	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	40	°C
78037	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments		
78038	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	87780	
78039	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	87783	
78040	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
78041	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	4L	
78042	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	6R	
78043	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
78044	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
78045	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	8L	
78046	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
78047	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	495	
78048	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
78049	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
78050	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
78051	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
78052	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
78053	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
78054	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
78055	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
78056	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
78057	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
78058	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
78059	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
78060	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
78061	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
78062	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	General Comments		
78063	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Unknown Operations	0	
78064	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Switching Operations	0	
78065	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations This Read AM	0	
78066	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AL	416	
78067	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AF	416	
78068	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Maintenance Operations	0	
78069	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
78070	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	General Comments		
78071	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
78072	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
78073	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
78074	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	35	
78075	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
78076	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78077	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments		
78078	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
78079	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
78080	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Foundation Condition	Good	
78081	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
78082	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
78083	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
78084	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
78085	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
78086	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
78087	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
78088	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	
78089	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	
78090	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	
78091	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
78092	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78093	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
78094	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
78095	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
78096	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
78097	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
78098	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Reading	.5844	
78099	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
78100	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
78101	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78102	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
78103	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78104	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78105	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78106	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Present	42	
78107	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Max	54	
78108	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
78109	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
78110	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	
78111	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78112	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	LTC Totalizer Reading	2805.12	
78113	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
78114	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78115	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78116	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78117	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78118	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78119	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78120	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78121	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
78122	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
78123	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78124	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Follow-up Action Required?	n	
78125	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78126	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78127	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	General Comments		
78128	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	General Comments		
78129	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78130	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
78131	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
78132	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
78133	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	LTC Totalizer Reading	6451.20	
78134	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78135	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
78136	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
78137	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments		
78138	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
78139	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	20	
78140	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	30	
78141	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	50	
78142	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	
78143	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	
78144	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	
78145	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	35	
78146	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78147	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78148	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
78149	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
78150	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78151	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78152	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	50	°C
78153	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	30	°C
78154	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	70	°C
78155	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	20	°C
78156	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
78157	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
78158	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
78159	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78160	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78161	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78162	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78163	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
78164	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78165	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
78166	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
78167	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78168	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	General Comments	ok	
78169	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
78170	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
78171	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
78172	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78173	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78174	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
78175	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
78176	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
78177	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
78178	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
78179	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
78180	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
78181	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
78182	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
78183	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
78184	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
78185	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Regulator As Left Counter	96965	
78186	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78187	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Leaks	None	
78188	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
78189	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
78190	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
78191	11/15/2019 11:44	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
78192	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
78193	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
78194	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
78195	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
78196	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
78197	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
78198	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
78199	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
78200	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
78201	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
78202	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
78203	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	100333	
78204	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	100344	
78205	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
78206	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	11L	
78207	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	4L	
78208	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	15L	
78209	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	985	
78210	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
78211	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations A Ø	0	
78212	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations B Ø	0	
78213	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations C Ø	0	
78214	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations Ground	0	
78215	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Follow-up Action Required?	n	
78216	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Follow-up Action Required?	n	
78217	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Foundation Condition	Good	
78218	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	General Comments		
78219	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	General Comments		
78220	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Grounds in Place?	y	
78221	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Maintenance Operations	0	
78222	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Moisture and Leak Free?	y	
78223	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AF	174	
78224	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AL	174	
78225	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations This Read Vac	3	
78226	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78227	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
78228	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps A Ø	100.0	
78229	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps B Ø	140.0	
78230	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps C Ø	190.0	
78231	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushing Condition	Good	
78232	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
78233	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
78234	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
78235	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
78236	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
78237	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
78238	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
78239	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
78240	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
78241	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Switching Operations	3	
78242	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC0000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
78243	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
78244	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
78245	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
78246	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
78247	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
78248	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
78249	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
78250	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
78251	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
78252	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
78253	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
78254	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
78255	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
78256	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
78257	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Gap under fence at one corner, but has strands of barbwire at bottom of fence at this area. Tree at one corner has branches growing	
78258	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
78259	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC0000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
78260	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78261	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78262	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78263	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78264	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78265	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78266	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78267	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78268	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
78269	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78270	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
78271	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
78272	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
78273	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
78274	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
78275	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
78276	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
78277	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
78278	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
78279	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
78280	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
78281	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
78282	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
78283	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	In cabinet batteries at 53 VDC.	
78284	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Grounds in Place?	y	
78285	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Maintenance Operations	0	
78286	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Moisture and Leak Free?	y	
78287	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Operations Counter AF	4	
78288	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	4	
78289	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
78290	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
78291	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Tank Paint Condition	Good	
78292	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Regulator Patrol Inspection	Good	
78293	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
78294	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
78295	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78296	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
78297	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
78298	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	General Comments		
78299	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	General Comments		
78300	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Grounds in Place?	y	
78301	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection			

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78302	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78303	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
78304	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78305	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78306	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
78307	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
78308	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
78309	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Follow-up Action Required?	n	
78310	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Follow-up Action Required?	n	
78311	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Foundation Condition	Good	
78312	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	General Comments		
78313	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	General Comments		
78314	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Grounds in Place?	y	
78315	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Maintenance Operations	0	
78316	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Moisture and Leak Free?	y	
78317	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Maintenance Operations	0	
78318	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Moisture and Leak Free?	y	
78319	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AF	267	
78320	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AL	267	
78321	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations This Read Vac	7	
78322	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
78323	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Switching Operations	7	
78324	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Tank Paint Condition	Good	
78325	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Unknown Operations	0	
78326	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
78327	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78328	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78329	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78330	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78331	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
78332	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78333	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
78334	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
78335	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78336	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
78337	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
78338	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
78339	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
78340	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78341	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78342	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
78343	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
78344	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Tank Paint Condition	Good	
78345	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Unknown Operations	0	
78346	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations	6	
78347	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
78348	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
78349	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
78350	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps A Ø	50.0	
78351	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps B Ø	60.0	
78352	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps C Ø	65.0	
78353	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushing Condition	Good	
78354	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
78355	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
78356	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
78357	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
78358	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
78359	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
78360	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations A Ø	0	
78361	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations B Ø	0	
78362	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations C Ø	0	
78363	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations Ground	0	
78364	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Follow-up Action Required?	n	
78365	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Follow-up Action Required?	n	
78366	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Foundation Condition	Good	
78367	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
78368	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
78369	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
78370	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations A Ø	0	
78371	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations B Ø	0	
78372	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations C Ø	0	
78373	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations Ground	0	
78374	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78375	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78376	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78377	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
78378	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78379	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
78380	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
78381	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78382	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
78383	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
78384	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6L	
78385	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
78386	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78387	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78388	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
78389	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
78390	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
78391	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	225717	
78392	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78393	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
78394	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
78395	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
78396	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
78397	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
78398	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
78399	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
78400	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushing Condition	Good	
78401	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
78402	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
78403	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
78404	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
78405	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
78406	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
78407	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
78408	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
78409	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
78410	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78411	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	108289	
78412	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
78413	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
78414	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
78415	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78416	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78417	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
78418	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
78419	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
78420	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
78421	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78422	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
78423	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
78424	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78425	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
78426	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78427	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78428	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78429	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78430	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
78431	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
78432	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
78433	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AL	272	
78434	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AF	272	
78435	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
78436	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
78437	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	General Comments		
78438	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
78439	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
78440	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
78441	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
78442	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
78443	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
78444	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
78445	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
78446	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
78447	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
78448	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
78449	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
78450	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
78451	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78452	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
78453	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
78454	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
78455	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
78456	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
78457	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
78458	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
78459	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
78460	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
78461	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
78462	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
78463	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
78464	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
78465	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	General Comments		
78466	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
78467	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
78468	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Foundation Condition	Good	
78469	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
78470	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	General Comments		
78471	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
78472	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
78473	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Foundation Condition	Good	
78474	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
78475	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
78476	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
78477	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
78478	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
78479	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
78480	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
78481	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
78482	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
78483	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Trash?	y	
78484	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
78485	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
78486	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
78487	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
78488	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
78489	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
78490	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	General Comments		
78491	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
78492	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
78493	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
78494	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
78495	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Vegetation	None	
78496	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
78497	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
78498	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
78499	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations	9	
78500	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
78501	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
78502	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.7520	
78503	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
78504	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
78505	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78506	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
78507	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations	25	
78508	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
78509	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
78510	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
78511	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78512	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78513	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78514	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	30	*C
78515	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	40	*C
78516	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
78517	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78518	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	7219.20	kw
78519	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78520	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
78521	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
78522	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78523	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78524	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
78525	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78526	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78527	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
78528	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78529	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78530	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78531	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78532	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78533	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78534	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78535	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78536	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78537	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
78538	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
78539	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
78540	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
78541	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
78542	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
78543	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
78544	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
78545	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
78546	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
78547	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	LTC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
78548	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
78549	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
78550	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
78551	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
78552	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
78553	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
78554	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	DB0034	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
78555	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
78556	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
78557	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
78558	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
78559	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
78560	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
78561	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
78562	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78563	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	124751	
78564	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
78565	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
78566	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
78567	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78568	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78569	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
78570	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
78571	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
78572	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		
78573	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78574	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
78575	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
78576	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
78577	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
78578	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
78579	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
78580	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78581	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
78582	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78583	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78584	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78585	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78586	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
78587	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
78588	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
78589	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
78590	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
78591	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
78592	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
78593	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
78594	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	LTC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
78595	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps C Ø	85.0	
78596	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps B Ø	120.0	
78597	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps A Ø	100.0	
78598	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
78599	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78600	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
78601	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78602	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Unknown Operations	0	
78603	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Tank Paint Condition	Good	
78604	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Switching Operations	0	
78605	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations This Read Vac	1	
78606	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AL	179	
78607	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AF	179	
78608	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Moisture and Leak Free?	y	
78609	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Maintenance Operations	0	
78610	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Grounds in Place?	y	
78611	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	General Comments		
78612	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	General Comments		
78613	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Foundation Condition	Good	
78614	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Follow-up Action Required?	n	
78615	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Follow-up Action Required?	n	
78616	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations Ground	0	
78617	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations C Ø	0	
78618	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations B Ø	1	
78619	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations A Ø	0	
78620	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
78621	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps B Phase V	3.95	
78622	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
78623	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	11793.60	kw
78624	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78625	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	15.0	psi
78626	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	55	°C
78627	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	45	°C
78628	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78629	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78630	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78631	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
78632	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
78633	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
78634	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	4	
78635	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
78636	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
78637	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments		
78638	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
78639	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
78640	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
78641	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
78642	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
78643	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
78644	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
78645	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
78646	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
78647	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
78648	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
78649	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
78650	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
78651	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	General Comments		
78652	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78653	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	LTC Totalizer Reading	6174.72	kw
78654	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78655	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
78656	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Max	30	°C
78657	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Present	30	°C
78658	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78659	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78660	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78661	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
78662	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
78663	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78664	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
78665	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
78666	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Reading	.6432	
78667	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
78668	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
78669	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78670	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78671	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78672	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78673	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78674	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78675	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
78676	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78677	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
78678	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
78679	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
78680	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
78681	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
78682	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
78683	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
78684	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
78685	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
78686	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
78687	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
78688	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1	
78689	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
78690	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
78691	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
78692	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78693	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
78694	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Panels Dusted?	y	
78695	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
78696	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
78697	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	y	
78698	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
78699	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
78700	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
78701	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
78702	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
78703	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
78704	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78705	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78706	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
78707	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
78708	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
78709	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31914	
78710	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78711	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
78712	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
78713	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78714	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Follow-up Action Required?	n	
78715	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78716	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78717	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	General Comments		
78718	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	General Comments		
78719	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78720	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
78721	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
78722	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
78723	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Regulator As Left Counter	156198	
78724	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78725	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Leaks	None	
78726	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
78727	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78728	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	LTC Totalizer Reading	10742.40	kw
78729	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78730	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
78731	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Max	80	°C
78732	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Present	40	°C
78733	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Equipment Properly Labeled?	y	
78734	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Paint Condition	Good	
78735	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
78736	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78737	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78738	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78739	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
78740	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
78741	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78742	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
78743	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
78744	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Reading	1.1190	
78745	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
78746	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
78747	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushings Connection/Risers	Good	
78748	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushing Condition	Good	
78749	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps C Ø	85.0	
78750	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps B Ø	50.0	
78751	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps A Ø	55.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
78752	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
78753	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
78754	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Broom on Site?	y	
78755	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
78756	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
78757	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
78758	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
78759	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
78760	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
78761	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
78762	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
78763	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
78764	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
78765	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
78766	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78767	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78768	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78769	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78770	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
78771	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78772	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78773	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78774	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78775	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Current Tap Position	15L	
78776	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78777	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
78778	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78779	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78780	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78781	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78782	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
78783	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
78784	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
78785	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78786	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	General Comments		
78787	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
78788	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Max Tap Position	8L	
78789	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
78790	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78791	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78792	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78793	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78794	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78795	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78796	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
78797	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
78798	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78799	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
78800	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
78801	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78802	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
78803	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	332766	
78804	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
78805	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
78806	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
78807	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78808	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78809	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
78810	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
78811	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Reading	.7932	
78812	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
78813	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
78814	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
78815	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
78816	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
78817	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
78818	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
78819	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
78820	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Present	24	°C
78821	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
78822	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
78823	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
78824	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
78825	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78826	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78827	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
78828	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Leaks	None	
78829	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
78830	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78831	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Regulator As Left Counter	121481	
78832	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
78833	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
78834	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
78835	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78836	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78837	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
78838	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
78839	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Max	24	°C
78840	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
78841	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
78842	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	LTC Totalizer Reading	7614.72	kw
78843	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
78844	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	General Comments		
78845	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	General Comments		
78846	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78847	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78848	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Follow-up Action Required?	n	
78849	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78850	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
78851	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
78852	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78853	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78854	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
78855	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	46615	
78856	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
78857	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
78858	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0388	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
78859	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AF	189	
78860	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AL	189	
78861	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations This Read Vac	3	
78862	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Switching Operations	3	
78863	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Tank Paint Condition	Good	
78864	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
78865	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
78866	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78867	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	309076	
78868	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
78869	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
78870	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
78871	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78872	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78873	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
78874	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
78875	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
78876	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
78877	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
78878	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Trash?	y	
78879	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
78880	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
78881	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
78882	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
78883	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
78884	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
78885	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	General Comments		
78886	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
78887	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
78888	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Vegetation	None	
78889	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
78890	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
78891	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
78892	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78893	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
78894	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
78895	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78896	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
78897	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78898	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78899	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78900	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78901	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78902	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
78903	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
78904	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78905	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78906	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Regulator As Left Counter	295121	
78907	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
78908	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
78909	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
78910	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78911	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78912	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
78913	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
78914	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
78915	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	General Comments		
78916	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78917	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
78918	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
78919	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
78920	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78921	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
78922	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78923	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78924	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
78925	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
78926	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
78927	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
78928	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
78929	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
78930	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
78931	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
78932	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
78933	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	16	
78934	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
78935	11/15/2019 14:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
78936	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
78937	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78938	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78939	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78940	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78941	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78942	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78943	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78944	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
78945	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
78946	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
78947	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
78948	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
78949	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Follow-up Action Required?	n	
78950	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
78951	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
78952	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	General Comments		
78953	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	18.0	
78954	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
78955	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
78956	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
78957	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
78958	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
78959	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
78960	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
78961	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
78962	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
78963	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
78964	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	General Comments	indication gauge not working.	
78965	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78966	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
78967	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Follow-up Action Required?	y	
78968	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78969	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
78970	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
78971	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78972	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78973	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78974	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
78975	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
78976	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
78977	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
78978	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
78979	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Leaks	None	
78980	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
78981	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
78982	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
78983	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
78984	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
78985	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Unknown Operations	0	
78986	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Regulator As Left Counter	167758	
78987	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
78988	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
78989	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
78990	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
78991	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
78992	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
78993	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
78994	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
78995	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	General Comments		
78996	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
78997	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
78998	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
78999	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79000	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
79001	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79002	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
79003	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79004	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79005	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
79006	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
79007	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Leaks	None	
79008	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79009	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79010	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79011	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79012	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79013	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79014	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79015	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79016	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79017	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
79018	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
79019	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
79020	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
79021	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
79022	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
79023	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
79024	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
79025	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
79026	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
79027	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
79028	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
79029	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
79030	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
79031	11/15/2019 13:32	Distribution	Shelbyville East Quarterly Inspection	BAT000406	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
79032	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79033	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79034	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79035	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
79036	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79037	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
79038	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79039	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79040	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
79041	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
79042	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79043	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	*C
79044	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	35	*C
79045	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
79046	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
79047	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	584.64	kw
79048	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
79049	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
79050	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
79051	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79052	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
79053	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79054	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
79055	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
79056	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79057	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79058	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79059	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79060	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79061	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79062	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
79063	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
79064	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79065	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	General Comments		
79066	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	General Comments		
79067	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
79068	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
79069	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
79070	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	350.64	kw
79071	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
79072	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
79073	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps C Ø	112.0	
79074	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps B Ø	118.0	
79075	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps A Ø	120.0	
79076	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79077	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79078	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79079	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations	2	
79080	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.4872	
79081	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
79082	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79083	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79084	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
79085	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
79086	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79087	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
79088	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79089	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79090	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79091	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79092	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
79093	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2922	
79094	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
79095	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
79096	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
79097	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	316365	
79098	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
79099	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
79100	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
79101	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
79102	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
79103	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
79104	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
79105	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
79106	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
79107	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
79108	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
79109	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
79110	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
79111	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79112	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79113	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
79114	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
79115	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
79116	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
79117	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
79118	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
79119	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
79120	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
79121	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
79122	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
79123	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
79124	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
79125	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
79126	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79127	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
79128	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
79129	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
79130	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
79131	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79132	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
79133	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79134	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
79135	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
79136	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	*C
79137	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
79138	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
79139	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
79140	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
79141	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	General Comments		
79142	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
79143	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79144	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
79145	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
79146	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79147	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Unknown Operations	0	
79148	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Tank Paint Condition	Good	
79149	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Switching Operations	0	
79150	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
79151	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations This Read Vac	0	
79152	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AL	166	
79153	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AF	166	
79154	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Moisture and Leak Free?	y	
79155	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Maintenance Operations	0	
79156	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
79157	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Grounds in Place?	y	
79158	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	General Comments		
79159	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	General Comments		
79160	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Foundation Condition	Good	
79161	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Follow-up Action Required?	n	
79162	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
79163	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0204	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
79164	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
79165	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
79166	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
79167	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
79168	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
79169	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
79170	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
79171	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Counter not working	
79172	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
79173	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
79174	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
79175	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	404	
79176	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	404	
79177	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
79178	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
79179	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
79180	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
79181	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
79182	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
79183	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
79184	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
79185	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
79186	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
79187	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
79188	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
79189	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
79190	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
79191	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
79192	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
79193	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
79194	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
79195	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
79196	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
79197	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
79198	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
79199	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
79200	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
79201	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79202	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
79203	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
79204	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
79205	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
79206	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	General Comments	ok	
79207	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
79208	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
79209	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
79210	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79211	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
79212	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79213	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
79214	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
79215	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
79216	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
79217	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
79218	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
79219	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
79220	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
79221	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
79222	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
79223	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
79224	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
79225	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
79226	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79227	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79228	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79229	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Max	25	°C
79230	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Present	0	°C
79231	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
79232	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
79233	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
79234	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
79235	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
79236	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
79237	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
79238	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
79239	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
79240	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	General Comments		
79241	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
79242	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
79243	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
79244	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79245	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
79246	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79247	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
79248	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79249	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79250	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
79251	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
79252	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
79253	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
79254	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
79255	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	104910	
79256	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
79257	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
79258	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
79259	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
79260	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
79261	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
79262	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
79263	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
79264	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
79265	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
79266	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
79267	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Leaks	None	
79268	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
79269	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
79270	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Regulator As Left Counter	291562	
79271	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
79272	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
79273	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
79274	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
79275	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
79276	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79277	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
79278	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
79279	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
79280	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
79281	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
79282	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
79283	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
79284	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
79285	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
79286	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
79287	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
79288	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
79289	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
79290	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
79291	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
79292	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
79293	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
79294	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
79295	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
79296	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
79297	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
79298	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
79299	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
79300	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
79301	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
79302	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
79303	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
79304	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
79305	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
79306	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
79307	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
79308	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
79309	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
79310	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
79311	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
79312	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
79313	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	34	
79314	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
79315	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
79316	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
79317	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Heaters (All) Functioning?	y	
79318	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Grounds in Place?	y	
79319	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	General Comments		
79320	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	General Comments		
79321	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Foundation Condition	Good	
79322	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Follow-up Action Required?	n	
79323	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Follow-up Action Required?	n	
79324	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations Ground	0	
79325	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations C Ø	0	
79326	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations B Ø	0	
79327	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations A Ø	0	
79328	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79329	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79330	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79331	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79332	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79333	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79334	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79335	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79336	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79337	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushing Condition	Good	
79338	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
79339	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
79340	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
79341	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Min Tap Position	15L	
79342	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Max Tap Position	6L	
79343	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
79344	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	General Comments		
79345	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
79346	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
79347	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
79348	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79349	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Current Tap Position	10L	
79350	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79351	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79352	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79353	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79354	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
79355	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
79356	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Leaks	None	
79357	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
79358	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Regulator As Left Counter	124153	
79359	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
79360	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79361	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79362	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79363	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
79364	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
79365	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0110	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
79366	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
79367	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
79368	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79369	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
79370	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
79371	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
79372	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
79373	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
79374	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
79375	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79376	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79377	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
79378	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
79379	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
79380	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
79381	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
79382	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
79383	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
79384	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
79385	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
79386	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
79387	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
79388	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
79389	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
79390	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
79391	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.3	
79392	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.8	
79393	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.3	
79394	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
79395	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
79396	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
79397	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
79398	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
79399	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
79400	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
79401	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	282	
79402	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
79403	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
79404	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
79405	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79406	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	VRR Time Delay	30	Seconds
79407	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
79408	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
79409	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
79410	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	LTC Operation Checked?	y	
79411	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	General Comments		
79412	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	Follow-up Action Required?	n	
79413	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCCControl	197-6	LTC Control Insp	All Connections OK?	y	
79414	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
79415	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Leaks	None	
79416	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
79417	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Regulator As Left Counter	122275	
79418	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
79419	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
79420	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Maintenance Operations	0	
79421	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79422	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
79423	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6308	
79424	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
79425	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
79426	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79427	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Trash?	n	
79428	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
79429	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79430	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79431	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79432	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
79433	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
79434	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
79435	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
79436	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
79437	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
79438	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
79439	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	General Comments	Yard is under Construction. Yard light by the Control house is going on and off, and the light by TR1 is not working	
79440	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
79441	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
79442	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
79443	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
79444	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
79445	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
79446	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Vegetation	None	
79447	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
79448	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79449	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
79450	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79451	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
79452	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
79453	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
79454	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
79455	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2609.28	kw
79456	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
79457	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	181	
79458	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
79459	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.0	
79460	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.0	
79461	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	323	
79462	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
79463	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
79464	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	282	
79465	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
79466	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
79467	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
79468	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
79469	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
79470	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	323	
79471	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
79472	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
79473	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
79474	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
79475	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
79476	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
79477	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
79478	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
79479	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
79480	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
79481	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79482	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79483	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
79484	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
79485	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
79486	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps C Ø	105.0	
79487	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps B Ø	100.0	
79488	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps A Ø	133.0	
79489	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
79490	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
79491	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
79492	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
79493	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
79494	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	294	
79495	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	294	
79496	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
79497	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
79498	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
79499	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
79500	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
79501	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79502	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
79503	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
79504	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
79505	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
79506	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
79507	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
79508	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
79509	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79510	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79511	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79512	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79513	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79514	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79515	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79516	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79517	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79518	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
79519	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
79520	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	168.0	
79521	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	170.0	
79522	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79523	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79524	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
79525	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
79526	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
79527	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
79528	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
79529	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
79530	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
79531	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
79532	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
79533	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
79534	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
79535	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79536	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79537	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	3.04	
79538	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79539	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79540	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79541	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79542	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79543	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79544	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
79545	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
79546	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
79547	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
79548	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79549	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79550	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79551	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	309	
79552	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
79553	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
79554	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
79555	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
79556	11/15/2019 12:35	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	General Comments		
79557	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
79558	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79559	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79560	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79561	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
79562	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
79563	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Vegetation	None	
79564	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
79565	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
79566	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	General Comments		
79567	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
79568	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
79569	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
79570	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
79571	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
79572	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
79573	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Trash?	y	
79574	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
79575	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
79576	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79577	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
79578	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
79579	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
79580	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
79581	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
79582	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
79583	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
79584	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Operations Since Last Insp	867	
79585	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Min Tap Position	13L	
79586	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Max Tap Position	2L	
79587	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Current Tap Position	7L	
79588	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
79589	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Left Counter	110984	
79590	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Found Counter	110981	
79591	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	General Comments	Counter counted 3 steps but LTC stepped 4	
79592	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	General Comments		
79593	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
79594	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Follow-up Action Required?	n	
79595	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
79596	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
79597	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
79598	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	1184	
79599	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	7L	
79600	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	7R	
79601	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	3L	
79602	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
79603	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	371142	
79604	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	371130	
79605	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	General Comments	oil is just below 25	
79606	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
79607	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
79608	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
79609	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
79610	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
79611	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
79612	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
79613	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
79614	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
79615	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	General Comments	ok	
79616	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
79617	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79618	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
79619	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
79620	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79621	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
79622	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
79623	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
79624	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1728	
79625	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1728	
79626	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
79627	11/15/2019 15:14	Distribution	Calloway Quarterly Inspection	MB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
79628	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
79629	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
79630	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79631	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79632	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushing Condition	Good	
79633	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps C Ø	95.0	
79634	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps B Ø	55.0	
79635	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps A Ø	70.0	
79636	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79637	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79638	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79639	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations	6	
79640	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79641	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79642	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
79643	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
79644	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
79645	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
79646	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79647	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
79648	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
79649	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
79650	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79651	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79652	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79653	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
79654	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
79655	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
79656	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
79657	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
79658	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
79659	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
79660	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	General Comments		
79661	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
79662	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79663	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
79664	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
79665	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79666	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
79667	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
79668	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79669	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
79670	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
79671	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8604	
79672	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
79673	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79674	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79675	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79676	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79677	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
79678	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79679	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Follow-up Action Required?	n	
79680	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations Ground	0	
79681	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations C Ø	0	
79682	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations B Ø	0	
79683	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations A Ø	0	
79684	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79685	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79686	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79687	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79688	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79689	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79690	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79691	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79692	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79693	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushing Condition	Good	
79694	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps C Ø	120.0	
79695	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps B Ø	135.0	
79696	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps A Ø	115.0	
79697	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79698	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79699	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79700	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations	7	
79701	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Unknown Operations	0	
79702	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Tank Paint Condition	Good	
79703	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Switching Operations	0	
79704	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations This Read Vac	0	
79705	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AL	165	
79706	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AF	166	
79707	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Moisture and Leak Free?	y	
79708	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Maintenance Operations	0	
79709	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Grounds in Place?	y	
79710	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	General Comments		
79711	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	General Comments		
79712	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Foundation Condition	Good	
79713	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Follow-up Action Required?	n	
79714	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Follow-up Action Required?	n	
79715	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations Ground	0	
79716	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations C Ø	0	
79717	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations B Ø	0	
79718	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations A Ø	0	
79719	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79720	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79721	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79722	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79723	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79724	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79725	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79726	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79727	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
79728	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
79729	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
79730	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
79731	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
79732	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
79733	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations A Ø	0	
79734	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations B Ø	0	
79735	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations C Ø	0	
79736	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
79737	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations Ground	0	
79738	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Follow-up Action Required?	n	
79739	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Follow-up Action Required?	n	
79740	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Foundation Condition	Good	
79741	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	General Comments		
79742	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	General Comments		
79743	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Grounds in Place?	y	
79744	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Heaters (All) Functioning?	y	
79745	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Maintenance Operations	0	
79746	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Moisture and Leak Free?	y	
79747	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AF	136	
79748	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AL	136	
79749	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations This Read Vac	0	
79750	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Switching Operations	0	
79751	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Tank Paint Condition	Good	
79752	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Unknown Operations	0	
79753	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
79754	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	37.50	
79755	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2064.96	kw
79756	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
79757	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
79758	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Audible arcing when getting Amp readings on line side.	
79759	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
79760	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
79761	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
79762	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
79763	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
79764	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79765	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
79766	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
79767	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79768	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
79769	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Loose Connections	
79770	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
79771	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	62.4	
79772	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	58.8	
79773	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	50.2	
79774	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
79775	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Leaks	None	
79776	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
79777	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Operations Counter	489	
79778	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
79779	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
79780	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	General Comments		
79781	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
79782	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
79783	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
79784	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Unknown Operations	0	
79785	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Switching Operations	0	
79786	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations This Read AM	0	
79787	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AL	411	
79788	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AF	411	
79789	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Maintenance Operations	0	
79790	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
79791	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	General Comments		
79792	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	General Comments		
79793	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Follow-up Action Required?	n	
79794	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
79795	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations Ground	0	
79796	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations C Ø	0	
79797	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations B Ø	0	
79798	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations A Ø	0	
79799	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
79800	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
79801	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79802	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
79803	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps C Ø	100.0	
79804	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps B Ø	50.0	
79805	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps A Ø	50.0	
79806	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
79807	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
79808	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79809	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79810	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
79811	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
79812	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
79813	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
79814	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	129	
79815	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
79816	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
79817	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
79818	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Months Operations	2	
79819	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	87	°C
79820	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations	5	
79821	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
79822	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
79823	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
79824	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps A Ø	150.0	
79825	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps B Ø	130.0	
79826	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps C Ø	200.0	
79827	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushing Condition	Good	
79828	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushings Connection/Risers	Good	
79829	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
79830	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79831	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
79832	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Paint Condition	Good	
79833	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Equipment Properly Labeled?	y	
79834	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
79835	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
79836	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
79837	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
79838	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
79839	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
79840	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
79841	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
79842	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
79843	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
79844	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
79845	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
79846	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
79847	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
79848	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
79849	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
79850	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
79851	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
79852	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
79853	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
79854	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
79855	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
79856	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
79857	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
79858	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
79859	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
79860	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
79861	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
79862	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
79863	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
79864	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	General Comments		
79865	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
79866	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	General Comments		
79867	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	General Comments		
79868	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
79869	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Follow-up Action Required?	n	
79870	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
79871	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
79872	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
79873	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Operations Since Last Insp	997	
79874	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Min Tap Position	5L	
79875	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Max Tap Position	8L	
79876	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Current Tap Position	5L	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
79877	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
79878	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Left Counter	7528	
79879	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Found Counter	7525	
79880	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	General Comments		
79881	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	General Comments		
79882	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
79883	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Follow-up Action Required?	n	
79884	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
79885	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
79886	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
79887	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79888	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
79889	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
79890	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
79891	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
79892	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
79893	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
79894	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
79895	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
79896	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79897	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
79898	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
79899	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
79900	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79901	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
79902	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
79903	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.1476	
79904	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
79905	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
79906	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
79907	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
79908	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
79909	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
79910	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
79911	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	38	°C
79912	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
79913	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
79914	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.6552	
79915	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
79916	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
79917	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
79918	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	General Comments		
79919	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
79920	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
79921	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
79922	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
79923	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
79924	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Trash?	y	
79925	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
79926	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
79927	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
79928	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	General Comments		
79929	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	General Comments		
79930	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
79931	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
79932	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
79933	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
79934	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
79935	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	General Comments		
79936	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
79937	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
79938	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Current Tap Position	8L	
79939	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
79940	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
79941	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
79942	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
79943	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
79944	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
79945	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Trash?	y	
79946	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
79947	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
79948	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
79949	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
79950	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
79951	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
79952	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
79953	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
79954	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
79955	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
79956	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
79957	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
79958	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
79959	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
79960	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
79961	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
79962	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
79963	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
79964	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	General Comments		
79965	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
79966	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
79967	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
79968	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
79969	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
79970	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
79971	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
79972	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
79973	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
79974	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
79975	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	101931	
79976	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	101931	
79977	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
79978	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	2L	
79979	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	8R	
79980	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	7L	
79981	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	908	
79982	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
79983	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
79984	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
79985	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Left Counter	22159	
79986	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Found Counter	22159	
79987	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	General Comments	Area under gate washed out from rain.	
79988	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
79989	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Vegetation	None	
79990	11/15/2019 14:46	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
79991	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
79992	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	FE000395	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
79993	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
79994	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
79995	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	General Comments		
79996	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
79997	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
79998	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
79999	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
80000	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
80001	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
80002	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
80003	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
80004	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
80005	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
80006	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
80007	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
80008	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
80009	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps A Ø	74.0	
80010	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80011	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
80012	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
80013	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
80014	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
80015	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
80016	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
80017	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
80018	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
80019	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80020	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
80021	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
80022	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
80023	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
80024	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
80025	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
80026	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80027	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
80028	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
80029	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
80030	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
80031	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
80032	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
80033	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	General Comments		
80034	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
80035	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
80036	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
80037	11/15/2019 11:44	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
80038	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
80039	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
80040	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	168.0	
80041	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
80042	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130.0	
80043	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80044	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80045	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80046	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
80047	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	General Comments		
80048	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	LTC Operation Checked?	y	
80049	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
80050	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80051	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80052	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	VRR Time Delay	30	Seconds
80053	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80054	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80055	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80056	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Operations Since Last Insp	4320	
80057	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
80058	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80059	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
80060	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
80061	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
80062	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
80063	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Max Tap Position	10L	
80064	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Current Tap Position	6L	
80065	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80066	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Left Counter	86950	
80067	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Found Counter	86945	
80068	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	General Comments		
80069	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Follow-up Action Required?	n	
80070	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80071	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	General Comments		
80072	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
80073	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	265.68	kw
80074	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
80075	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
80076	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations Ground	0	
80077	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
80078	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Follow-up Action Required?	n	
80079	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	General Comments		
80080	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	General Comments		
80081	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
80082	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Maintenance Operations	0	
80083	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AF	193	
80084	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AL	193	
80085	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations This Read AM	0	
80086	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Switching Operations	0	
80087	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Unknown Operations	0	
80088	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
80089	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
80090	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
80091	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
80092	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
80093	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	204	
80094	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	
80095	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.0	
80096	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.0	
80097	11/15/2019 14:18	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
80098	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
80099	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
80100	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Operations Counter	65	
80101	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80102	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
80103	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	General Comments	ok	
80104	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
80105	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WLT Bushing Dynamic Health	0.00	
80106	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	110	°C
80107	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	53	°C
80108	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	100	°C
80109	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	53	°C
80110	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	105	°C
80111	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
80112	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
80113	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
80114	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80115	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
80116	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
80117	11/15/2019 12:33	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
80118	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	All Connections OK?	y	
80119	11/15/2019 9:59	Distribution	Lockport Quarterly Inspection	LTC000504	LTCControl	591-1	LTC Control Insp	Follow-up Action Required?	n	
80120	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
80121	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
80122	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
80123	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
80124	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
80125	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	23	
80126	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	23	
80127	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
80128	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
80129	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
80130	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
80131	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
80132	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
80133	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
80134	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
80135	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
80136	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
80137	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
80138	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
80139	11/15/2019 13:36	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
80140	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
80141	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
80142	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
80143	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
80144	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
80145	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80146	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80147	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80148	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80149	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
80150	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80151	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Left Counter	79113	
80152	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Found Counter	79113	
80153	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
80154	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	General Comments		
80155	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80156	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
80157	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
80158	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
80159	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
80160	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
80161	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
80162	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
80163	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
80164	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
80165	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Foundation Condition	Good	
80166	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
80167	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
80168	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80169	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80170	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
80171	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
80172	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
80173	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
80174	11/15/2019 13:29	Distribution	East Stone Gap Quarterly Inspection	LTC000528	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
80175	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
80176	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80177	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
80178	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
80179	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
80180	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
80181	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations B Ø	0	
80182	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations C Ø	0	
80183	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
80184	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
80185	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
80186	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
80187	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
80188	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
80189	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
80190	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
80191	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
80192	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
80193	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
80194	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps A Ø	150.0	
80195	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
80196	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
80197	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
80198	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	General Comments		
80199	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
80200	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
80201	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps B Ø	200.0	
80202	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps C Ø	150.0	
80203	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
80204	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
80205	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
80206	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
80207	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
80208	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
80209	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
80210	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
80211	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
80212	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
80213	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
80214	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
80215	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
80216	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
80217	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
80218	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Regulator As Left Counter	64358	
80219	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
80220	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Leaks	None	
80221	11/15/2019 13:51	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
80222	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
80223	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
80224	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
80225	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
80226	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
80227	11/15/2019 10:47	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
80228	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
80229	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
80230	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
80231	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations A Ø	0	
80232	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6L	
80233	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Max Tap Position	2R	
80234	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Current Tap Position	3L	
80235	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80236	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	General Comments		
80237	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
80238	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
80239	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80240	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80241	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80242	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Operations Since Last Insp	1668	
80243	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	General Comments		
80244	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Found Counter	186950	
80245	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
80246	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Min Tap Position	4L	
80247	11/15/2019 10:56	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Max Tap Position	16R	
80248	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
80249	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
80250	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
80251	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80252	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Present	19	°C
80253	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
80254	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
80255	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
80256	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
80257	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
80258	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
80259	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
80260	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
80261	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
80262	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
80263	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
80264	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
80265	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	24.17	
80266	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
80267	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Max	51	°C
80268	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Min Tap Position	10L	
80269	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Max Tap Position	1R	
80270	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Current Tap Position	6L	
80271	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80272	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
80273	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
80274	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
80275	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
80276	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
80277	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
80278	11/15/2019 14:25	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
80279	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
80280	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Left Counter	186958	
80281	11/15/2019 14:55	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
80282	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
80283	11/15/2019 10:50	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
80284	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Vegetation	None	
80285	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80286	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	General Comments		
80287	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
80288	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
80289	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
80290	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	General Comments	Crossarm rotten and 2 poles rotten at the bottom	
80291	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
80292	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
80293	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
80294	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
80295	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
80296	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80297	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
80298	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
80299	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
80300	11/15/2019 11:13	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
80301	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
80302	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80303	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80304	11/15/2019 9:42	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
80305	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
80306	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80307	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Operations Since Last Insp	236	
80308	11/15/2019 11:46	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Follow-up Action Required?	n	
80309	11/15/2019 13:39	Distribution	Newtown Quarterly Inspection	LTC0000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
80310	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
80311	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
80312	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
80313	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
80314	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
80315	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
80316	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
80317	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
80318	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Foundation Condition	Good	
80319	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
80320	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
80321	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Follow-up Action Required?	n	
80322	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations Ground	0	
80323	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations C Ø	0	
80324	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
80325	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80326	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80327	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80328	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
80329	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80330	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
80331	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
80332	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Trash?	y	
80333	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
80334	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
80335	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
80336	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
80337	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Follow-up Action Required?	n	
80338	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Foundation Condition	Good	
80339	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	General Comments		
80340	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	General Comments		
80341	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Grounds in Place?	y	
80342	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
80343	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Maintenance Operations	0	
80344	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
80345	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AF	163	
80346	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80347	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80348	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
80349	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80350	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations A Ø	0	
80351	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations B Ø	0	
80352	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
80353	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
80354	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations C Ø	0	
80355	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations Ground	0	
80356	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
80357	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
80358	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
80359	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
80360	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Maintenance Operations	0	
80361	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Grounds in Place?	y	
80362	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	General Comments		
80363	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	General Comments		
80364	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Foundation Condition	Good	
80365	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Follow-up Action Required?	n	
80366	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Follow-up Action Required?	n	
80367	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
80368	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Moisture and Leak Free?	y	
80369	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations Counter AF	200	
80370	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations Counter AL	200	
80371	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations This Read Vac	0	
80372	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Switching Operations	0	
80373	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Tank Paint Condition	Good	
80374	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
80375	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Maintenance Operations	0	
80376	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	9 Month Operations	0	
80377	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
80378	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80379	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80380	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80381	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps A Ø	245.0	
80382	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps B Ø	205.0	
80383	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Unknown Operations	0	
80384	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	9 Month Operations	0	
80385	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80386	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80387	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80388	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
80389	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps A Ø	153.0	
80390	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps B Ø	164.0	
80391	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps C Ø	178.0	
80392	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushing Condition	Good	
80393	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushings Connection/Risers	Good	
80394	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80395	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
80396	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80397	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Paint Condition	Good	
80398	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80399	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps C Ø	225.0	
80400	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushing Condition	Good	
80401	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80402	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
80403	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
80404	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80405	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
80406	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
80407	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
80408	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
80409	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
80410	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
80411	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
80412	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
80413	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
80414	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
80415	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	30	
80416	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	30	
80417	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
80418	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
80419	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
80420	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
80421	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
80422	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
80423	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
80424	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80425	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
80426	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80427	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
80428	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80429	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80430	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80431	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
80432	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
80433	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	General Comments		
80434	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80435	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
80436	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
80437	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
80438	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
80439	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
80440	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
80441	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
80442	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations A Ø	0	
80443	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations B Ø	0	
80444	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
80445	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
80446	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
80447	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
80448	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	54	°C
80449	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
80450	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
80451	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
80452	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
80453	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Leaks	None	
80454	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
80455	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Operations Counter	1380	
80456	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
80457	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
80458	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
80459	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
80460	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
80461	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
80462	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	13	°C
80463	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	50	°C
80464	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
80465	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
80466	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	9 Month Operations	16	
80467	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty A Ph V	.68	%
80468	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
80469	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty C Ph V	1.02	%
80470	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps A Ø	202.0	
80471	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps B Ø	185.0	
80472	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps C Ø	194.0	
80473	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
80474	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
80475	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	General Comments		
80476	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80477	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
80478	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
80479	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
80480	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
80481	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
80482	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
80483	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
80484	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
80485	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80486	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80487	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
80488	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Found Counter	147363	
80489	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Oil Leak at connection on the side of the LTC filter. Pic Sent to Stinson	
80490	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	General Comments		
80491	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
80492	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
80493	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Left Counter	147363	
80494	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80495	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
80496	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
80497	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
80498	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
80499	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1037	
80500	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
80501	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80502	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80503	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80504	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
80505	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80506	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80507	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	9	
80508	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80509	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80510	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80511	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	170.0	
80512	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	160.0	
80513	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	180.0	
80514	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
80515	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
80516	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
80517	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
80518	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
80519	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
80520	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
80521	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Trash?	y	
80522	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
80523	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
80524	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
80525	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
80526	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
80527	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
80528	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
80529	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
80530	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
80531	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
80532	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80533	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
80534	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80535	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
80536	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80537	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80538	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.59	
80539	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80540	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
80541	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	1	
80542	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
80543	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
80544	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
80545	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
80546	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
80547	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
80548	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Unknown Operations	0	
80549	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Tank Paint Condition	Good	
80550	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Switching Operations	0	
80551	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80552	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations This Read Vac	0	
80553	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
80554	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
80555	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
80556	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
80557	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
80558	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AL	163	
80559	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	grate under radiator needs support on one side	
80560	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
80561	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80562	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
80563	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
80564	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
80565	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
80566	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
80567	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
80568	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Unknown Operations	0	
80569	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Tank Paint Condition	Good	
80570	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Switching Operations	0	
80571	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations This Read Vac	0	
80572	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AL	196	
80573	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AF	196	
80574	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Moisture and Leak Free?	y	
80575	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
80576	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
80577	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
80578	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
80579	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	General Comments		
80580	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80581	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations A Ø	0	
80582	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations B Ø	0	
80583	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations C Ø	0	
80584	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations Ground	0	
80585	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Follow-up Action Required?	n	
80586	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	General Comments		
80587	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
80588	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
80589	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
80590	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Vegetation	None	
80591	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
80592	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
80593	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Maintenance Operations	6	
80594	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AF	323	
80595	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AL	323	
80596	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations This Read Vac	11	
80597	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Switching Operations	5	
80598	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Unknown Operations	0	
80599	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
80600	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
80601	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
80602	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
80603	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
80604	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	19	°C
80605	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	53	°C
80606	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
80607	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
80608	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
80609	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
80610	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
80611	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
80612	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
80613	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
80614	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
80615	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
80616	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
80617	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
80618	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps B Ø	90.0	
80619	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
80620	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
80621	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
80622	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
80623	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Vegetation	None	
80624	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
80625	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
80626	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80627	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	General Comments		
80628	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
80629	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
80630	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80631	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
80632	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80633	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80634	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80635	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
80636	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	911	
80637	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	*C
80638	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	11	*C
80639	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
80640	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
80641	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
80642	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80643	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	13003	
80644	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	13003	
80645	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
80646	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
80647	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
80648	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
80649	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
80650	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
80651	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
80652	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
80653	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
80654	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
80655	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
80656	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
80657	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Trash?	y	
80658	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
80659	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
80660	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
80661	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
80662	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	General Comments		
80663	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
80664	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
80665	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
80666	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
80667	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
80668	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
80669	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80670	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations	0	
80671	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80672	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80673	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80674	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps A Ø	523.0	
80675	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps B Ø	532.0	
80676	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps C Ø	510.0	
80677	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushing Condition	Good	
80678	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
80679	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
80680	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
80681	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
80682	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
80683	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
80684	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
80685	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80686	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80687	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations A Ø	0	
80688	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
80689	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
80690	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
80691	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
80692	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
80693	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
80694	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
80695	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
80696	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	17	
80697	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	219	
80698	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	219	
80699	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	23	
80700	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
80701	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80702	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Follow-up Action Required?	n	
80703	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	General Comments		
80704	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
80705	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Follow-up Action Required?	n	
80706	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80707	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	General Comments		
80708	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	General Comments		
80709	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Found Counter	16972	
80710	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Left Counter	16972	
80711	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80712	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Current Tap Position	8L	
80713	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
80714	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
80715	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
80716	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
80717	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
80718	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
80719	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
80720	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
80721	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
80722	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
80723	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
80724	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Min Tap Position	11L	
80725	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	*C
80726	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	*C
80727	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Operations Since Last Insp	453	
80728	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80729	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
80730	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80731	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80732	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	General Comments		
80733	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
80734	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
80735	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
80736	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
80737	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
80738	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80739	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	VRR Time Delay	30	Seconds
80740	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80741	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80742	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
80743	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
80744	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	LTC Operation Checked?	y	
80745	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	General Comments		
80746	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	Follow-up Action Required?	n	
80747	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	LTC000162	LTCControl	449-1	LTC Control Insp	All Connections OK?	y	
80748	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
80749	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
80750	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
80751	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
80752	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
80753	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
80754	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
80755	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
80756	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
80757	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	49	*C
80758	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	*C
80759	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
80760	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
80761	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
80762	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
80763	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
80764	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
80765	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
80766	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
80767	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
80768	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
80769	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
80770	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
80771	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
80772	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
80773	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	49	*C
80774	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	18	*C
80775	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
80776	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
80777	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	49	°C
80778	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Unknown Operations	0	
80779	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Tank Paint Condition	Good	
80780	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
80781	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
80782	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
80783	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
80784	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
80785	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
80786	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
80787	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
80788	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
80789	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
80790	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
80791	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
80792	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
80793	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
80794	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Switching Operations	0	
80795	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations This Read Vac	0	
80796	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AL	161	
80797	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
80798	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
80799	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
80800	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
80801	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AF	161	
80802	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
80803	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
80804	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80805	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
80806	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	18	°C
80807	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	49	°C
80808	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
80809	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	18	°C
80810	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Maintenance Operations	0	
80811	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	49	°C
80812	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	18	°C
80813	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps C Ø	0.0	
80814	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps B Ø	0.0	
80815	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps A Ø	0.0	
80816	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
80817	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
80818	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
80819	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Months Operations	2	
80820	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Follow-up Action Required?	n	
80821	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Foundation Condition	Good	
80822	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	General Comments		
80823	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	General Comments		
80824	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Grounds in Place?	y	
80825	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
80826	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations B Ø	0	
80827	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations C Ø	0	
80828	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations Ground	0	
80829	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Follow-up Action Required?	n	
80830	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Unknown Operations	1	
80831	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Switching Operations	0	
80832	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations This Read AM	1	
80833	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AL	0	
80834	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AF	99980	
80835	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
80836	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
80837	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
80838	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
80839	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
80840	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
80841	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80842	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
80843	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
80844	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	General Comments	Tr 1 is off line	
80845	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	General Comments		
80846	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
80847	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
80848	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
80849	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
80850	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
80851	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80852	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
80853	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
80854	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
80855	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
80856	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
80857	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
80858	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
80859	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
80860	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
80861	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
80862	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
80863	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
80864	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
80865	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
80866	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
80867	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
80868	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
80869	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
80870	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
80871	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
80872	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
80873	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
80874	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
80875	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
80876	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
80877	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
80878	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
80879	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
80880	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
80881	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
80882	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	General Comments		
80883	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	Follow-up Action Required?	n	
80884	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	LTC000580	LTCControl	695-1	LTC Control Insp	All Connections OK?	y	
80885	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments		
80886	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
80887	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
80888	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
80889	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
80890	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro bottle will need to be replaced soon	
80891	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
80892	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
80893	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
80894	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
80895	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
80896	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80897	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
80898	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
80899	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
80900	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80901	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80902	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
80903	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
80904	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
80905	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	9 Month Operations	2	
80906	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
80907	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
80908	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
80909	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
80910	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
80911	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	General Comments		
80912	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
80913	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
80914	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Foundation Condition	Good	
80915	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
80916	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
80917	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
80918	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
80919	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
80920	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
80921	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
80922	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
80923	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
80924	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Bottle is at 0 Psi, Bottle needs Nitrogen, top left Fan on Rad near CCC is not working	
80925	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
80926	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
80927	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
80928	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
80929	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
80930	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80931	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80932	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80933	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Operations Since Last Insp	1495	
80934	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
80935	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
80936	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Min Tap Position	8L	
80937	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Max Tap Position	4R	
80938	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
80939	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
80940	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
80941	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
80942	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
80943	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
80944	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
80945	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
80946	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80947	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	General Comments	ok	
80948	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	Unit is running	
80949	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
80950	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
80951	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80952	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Left Counter	51997	
80953	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Found Counter	51992	
80954	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	General Comments		
80955	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	General Comments		
80956	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80957	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Found Counter	7453	
80958	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Left Counter	7453	
80959	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
80960	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Follow-up Action Required?	n	
80961	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
80962	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
80963	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
80964	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
80965	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
80966	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
80967	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	General Comments		
80968	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
80969	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
80970	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Vegetation	None	
80971	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
80972	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
80973	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
80974	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
80975	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
80976	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Unknown Operations	0	
80977	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Tank Paint Condition	Good	
80978	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Switching Operations	1	
80979	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations This Read Vac	1	
80980	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AL	201	
80981	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AF	201	
80982	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Moisture and Leak Free?	y	
80983	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Maintenance Operations	0	
80984	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Unknown Operations	0	
80985	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Switching Operations	5	
80986	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations This Read Vac	10	
80987	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AL	239	
80988	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AF	239	
80989	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Maintenance Operations	5	
80990	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	General Comments		
80991	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Follow-up Action Required?	n	
80992	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations Ground	0	
80993	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations C Ø	0	
80994	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations B Ø	0	
80995	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations A Ø	0	
80996	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
80997	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
80998	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
80999	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments	min tap position is sticking but will reset	
81000	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	12363	
81001	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	12363	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81002	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
81003	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
81004	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
81005	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81006	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Grounds in Place?	y	
81007	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	General Comments		
81008	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	General Comments		
81009	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Foundation Condition	Good	
81010	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Follow-up Action Required?	n	
81011	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Follow-up Action Required?	n	
81012	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations Ground	0	
81013	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations C Ø	0	
81014	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations B Ø	0	
81015	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations A Ø	0	
81016	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81017	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81018	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81019	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81020	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81021	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81022	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81023	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81024	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81025	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushing Condition	Good	
81026	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps C Ø	174.0	
81027	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps B Ø	182.0	
81028	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps A Ø	194.0	
81029	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
81030	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	13	°C
81031	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
81032	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	651	
81033	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81034	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Follow-up Action Required?	n	
81035	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
81036	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
81037	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	General Comments		
81038	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	General Comments		
81039	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
81040	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	12156.48	kw
81041	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
81042	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty B Ph V	1.34	%
81043	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
81044	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
81045	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	30	°C
81046	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	20	°C
81047	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
81048	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
81049	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
81050	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty A Ph V	2.42	%
81051	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	9 Month Operations	19	
81052	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
81053	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
81054	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
81055	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
81056	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
81057	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
81058	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
81059	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
81060	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
81061	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81062	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81063	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
81064	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
81065	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
81066	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
81067	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
81068	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
81069	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
81070	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
81071	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
81072	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
81073	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	.8442	
81074	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	40	°C
81075	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	20	°C
81076	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81077	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
81078	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
81079	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	General Comments		
81080	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
81081	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
81082	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
81083	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
81084	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
81085	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1663	
81086	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1663	
81087	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
81088	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
81089	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
81090	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
81091	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
81092	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
81093	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0144	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
81094	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	28	
81095	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.89	%
81096	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.89	%
81097	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.89	%
81098	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
81099	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
81100	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
81101	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81102	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	1017	
81103	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
81104	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
81105	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	13L	
81106	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	2L	
81107	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	5L	
81108	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
81109	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	38931	
81110	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	38931	
81111	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
81112	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
81113	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
81114	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
81115	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81116	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81117	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81118	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps Ø	250.0	
81119	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps B Ø	290.0	
81120	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
81121	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
81122	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
81123	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
81124	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
81125	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
81126	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
81127	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	414	
81128	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
81129	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
81130	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
81131	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
81132	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	All Connections OK?	y	
81133	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
81134	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	General Comments	In Service	
81135	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
81136	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
81137	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
81138	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
81139	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
81140	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LTC0000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Time Delay	30	Seconds
81141	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps Ø	320.0	
81142	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty C Ph V	1.07	%
81143	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
81144	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81145	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81146	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
81147	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81148	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81149	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81150	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
81151	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81152	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
81153	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
81154	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
81155	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
81156	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
81157	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
81158	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
81159	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
81160	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
81161	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
81162	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	General Comments		
81163	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
81164	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
81165	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Operations Counter	1110	
81166	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
81167	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Leaks	None	
81168	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
81169	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
81170	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
81171	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
81172	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations B Ø	0	
81173	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations C Ø	0	
81174	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations Ground	0	
81175	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps C Ø	99.0	
81176	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81177	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81178	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81179	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations A Ø	0	
81180	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations B Ø	0	
81181	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations C Ø	0	
81182	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations Ground	0	
81183	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Follow-up Action Required?	n	
81184	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	General Comments		
81185	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Maintenance Operations	10	
81186	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AF	80	
81187	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AL	80	
81188	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations This Read Vac	17	
81189	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Switching Operations	7	
81190	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Unknown Operations	0	
81191	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Follow-up Action Required?	n	
81192	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Follow-up Action Required?	n	
81193	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	General Comments		
81194	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	General Comments		
81195	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
81196	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Maintenance Operations	0	
81197	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AF	745	
81198	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
81199	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
81200	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
81201	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
81202	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
81203	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
81204	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81205	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81206	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
81207	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81208	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
81209	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81210	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81211	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
81212	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
81213	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
81214	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
81215	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
81216	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81217	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Follow-up Action Required?	n	
81218	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
81219	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
81220	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	General Comments		
81221	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	General Comments		
81222	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
81223	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	LTC Totalizer Reading	9002.88	kw
81224	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
81225	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
81226	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81227	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
81228	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
81229	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
81230	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
81231	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
81232	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
81233	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
81234	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Top Oil Temperature Present	20	°C
81235	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
81236	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81237	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81238	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81239	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81240	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations A Ø	0	
81241	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations B Ø	0	
81242	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations C Ø	0	
81243	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations Ground	0	
81244	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Follow-up Action Required?	n	
81245	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Follow-up Action Required?	n	
81246	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
81247	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
81248	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
81249	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
81250	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81251	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81252	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81253	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
81254	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81255	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81256	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
81257	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Foundation Condition	Good	
81258	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	General Comments		
81259	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	General Comments		
81260	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Grounds in Place?	y	
81261	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81262	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Maintenance Operations	0	
81263	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Moisture and Leak Free?	y	
81264	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
81265	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
81266	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
81267	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations A Ø	0	
81268	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AF	171	
81269	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AL	171	
81270	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Switching Operations	1	
81271	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Tank Paint Condition	Good	
81272	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Unknown Operations	0	
81273	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations This Read Vac	0	
81274	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
81275	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Switching Operations	0	
81276	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Tank Paint Condition	Good	
81277	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Unknown Operations	0	
81278	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
81279	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
81280	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	9 Month Operations	22	
81281	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty A Ph V	15.36	%
81282	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty B Ph V	16.82	%
81283	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty C Ph V	16.82	%
81284	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps A Ø	150.0	
81285	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps B Ø	90.0	
81286	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
81287	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
81288	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
81289	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
81290	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Foundation Condition	Good	
81291	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
81292	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
81293	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	General Comments		
81294	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
81295	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
81296	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
81297	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
81298	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
81299	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
81300	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
81301	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81302	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	General Comments		
81303	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
81304	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
81305	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
81306	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
81307	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
81308	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
81309	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
81310	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
81311	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
81312	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
81313	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
81314	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
81315	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
81316	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
81317	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
81318	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
81319	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
81320	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
81321	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
81322	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
81323	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
81324	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
81325	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
81326	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
81327	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
81328	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
81329	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
81330	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
81331	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	
81332	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
81333	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
81334	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
81335	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
81336	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
81337	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
81338	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
81339	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
81340	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
81341	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
81342	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81343	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81344	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
81345	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81346	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
81347	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	General Comments		
81348	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
81349	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
81350	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
81351	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
81352	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
81353	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
81354	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
81355	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
81356	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
81357	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
81358	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
81359	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
81360	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
81361	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
81362	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
81363	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
81364	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
81365	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
81366	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
81367	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
81368	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
81369	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
81370	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
81371	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
81372	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
81373	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
81374	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
81375	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
81376	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81377	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
81378	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
81379	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
81380	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
81381	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
81382	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81383	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
81384	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
81385	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	General Comments	ok	
81386	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
81387	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81388	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81389	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
81390	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
81391	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Reading	.9378	
81392	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Max	60	°C
81393	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Present	35	°C
81394	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
81395	11/14/2019 13:40	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
81396	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
81397	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
81398	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
81399	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
81400	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
81401	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
81402	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
81403	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
81404	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
81405	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
81406	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
81407	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
81408	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	General Comments		
81409	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
81410	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
81411	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Foundation Condition	Good	
81412	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
81413	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
81414	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
81415	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
81416	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
81417	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
81418	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
81419	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	General Comments		
81420	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
81421	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
81422	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
81423	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
81424	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
81425	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
81426	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
81427	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
81428	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
81429	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
81430	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
81431	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
81432	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
81433	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
81434	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
81435	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
81436	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
81437	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
81438	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
81439	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
81440	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
81441	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
81442	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
81443	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
81444	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	General Comments		
81445	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
81446	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Max Tap Position	13L	
81447	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
81448	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
81449	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81450	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81451	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81452	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81453	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81454	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81455	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
81456	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
81457	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
81458	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
81459	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81460	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Follow-up Action Required?	n	
81461	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
81462	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
81463	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	General Comments		
81464	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	General Comments		
81465	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
81466	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	LTC Totalizer Reading	4947.84	kw
81467	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
81468	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
81469	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Max	55	°C
81470	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Present	30	°C
81471	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
81472	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
81473	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
81474	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
81475	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
81476	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
81477	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
81478	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
81479	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Reading	.5154	
81480	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
81481	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
81482	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
81483	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
81484	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	VRR Time Delay	30	Seconds
81485	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
81486	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
81487	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
81488	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
81489	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT00027	WithLTC	540-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
81490	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations	2	
81491	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81492	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81493	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81494	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps A Ø	160.0	
81495	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps B Ø	167.0	
81496	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
81497	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
81498	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
81499	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81500	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81501	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81502	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81503	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81504	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81505	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
81506	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
81507	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
81508	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
81509	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81510	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	All Connections OK?	y	
81511	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	Follow-up Action Required?	n	
81512	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	General Comments		
81513	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	LTC Operation Checked?	y	
81514	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000032	LTCControl	540-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
81515	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
81516	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
81517	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
81518	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
81519	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
81520	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
81521	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
81522	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
81523	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
81524	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
81525	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
81526	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81527	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	General Comments		
81528	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
81529	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Max Tap Position	12L	
81530	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
81531	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
81532	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
81533	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
81534	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
81535	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
81536	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24616	
81537	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
81538	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
81539	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Leaks	None	
81540	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
81541	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
81542	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
81543	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
81544	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
81545	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
81546	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
81547	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
81548	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
81549	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
81550	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
81551	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	General Comments		
81552	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
81553	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Max Tap Position	13L	
81554	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
81555	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
81556	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
81557	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
81558	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
81559	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
81560	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19759	
81561	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
81562	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
81563	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Leaks	None	
81564	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Reading	10170	
81565	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
81566	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
81567	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
81568	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
81569	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
81570	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
81571	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
81572	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
81573	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
81574	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
81575	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Months Operations	1	
81576	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
81577	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
81578	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
81579	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps A Ø	0.0	
81580	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
81581	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
81582	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
81583	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Present	30	°C
81584	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps B Ø	0.0	
81585	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps C Ø	0.0	
81586	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
81587	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
81588	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
81589	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations	3	
81590	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81591	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81592	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81593	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps A Ø	12.0	
81594	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps B Ø	16.0	
81595	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps C Ø	13.0	
81596	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushing Condition	Good	
81597	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81598	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Max	45	°C
81599	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
81600	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Follow-up Action Required?	n	
81601	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81602	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
81603	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
81604	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
81605	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
81606	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Follow-up Action Required?	n	
81607	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Foundation Condition	Good	
81608	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	General Comments		
81609	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	General Comments		
81610	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Grounds in Place?	y	
81611	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81612	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Maintenance Operations	0	
81613	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Moisture and Leak Free?	y	
81614	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AF	184	
81615	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AL	184	
81616	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations This Read Vac	1	
81617	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
81618	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	LTC Totalizer Reading	14644.80	kw
81619	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
81620	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	General Comments		
81621	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	General Comments		
81622	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
81623	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
81624	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Follow-up Action Required?	n	
81625	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81626	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81627	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81628	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81629	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81630	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	.9858	
81631	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
81632	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	30	°C
81633	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
81634	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	General Comments		
81635	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
81636	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
81637	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
81638	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
81639	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
81640	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
81641	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
81642	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
81643	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
81644	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
81645	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
81646	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
81647	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
81648	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
81649	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81650	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81651	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81652	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81653	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
81654	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	40	°C
81655	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
81656	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
81657	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	9463.68	kw
81658	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments		
81659	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
81660	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
81661	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	All Connections OK?	y	
81662	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	Follow-up Action Required?	n	
81663	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	General Comments		
81664	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	LTC Operation Checked?	y	
81665	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
81666	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
81667	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
81668	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps C Ø	157.0	
81669	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushing Condition	Good	
81670	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
81671	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
81672	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
81673	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Regulator As Left Counter	22306	
81674	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
81675	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
81676	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Leaks	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81677	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
81678	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81679	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81680	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81681	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81682	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81683	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81684	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81685	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81686	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81687	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations A Ø	0	
81688	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	LTC000693	LTCControl	540-1	LTC Control Insp	VRR Time Delay	30	Seconds
81689	11/14/2019 9:02	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
81690	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations B Ø	0	
81691	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations C Ø	0	
81692	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations Ground	0	
81693	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
81694	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Present	40	°C
81695	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Max	50	°C
81696	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations A Ø	0	
81697	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations B Ø	0	
81698	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations C Ø	0	
81699	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations Ground	0	
81700	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Follow-up Action Required?	n	
81701	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Follow-up Action Required?	n	
81702	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Foundation Condition	Good	
81703	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	General Comments		
81704	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	General Comments		
81705	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations This Read AM	0	
81706	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Switching Operations	0	
81707	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations	4	
81708	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81709	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81710	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
81711	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
81712	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
81713	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
81714	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
81715	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
81716	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
81717	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
81718	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
81719	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments		
81720	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
81721	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
81722	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
81723	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
81724	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81725	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
81726	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Grounds in Place?	y	
81727	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81728	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Maintenance Operations	0	
81729	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Moisture and Leak Free?	y	
81730	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AF	200	
81731	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AL	200	
81732	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
81733	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations This Read Vac	1	
81734	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Switching Operations	1	
81735	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Tank Paint Condition	Good	
81736	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Unknown Operations	0	
81737	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
81738	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
81739	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
81740	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
81741	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
81742	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
81743	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps A Ø	0.0	
81744	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps B Ø	0.0	
81745	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps C Ø	0.0	
81746	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
81747	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81748	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81749	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81750	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81751	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81752	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81753	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81754	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81755	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81756	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations A Ø	0	
81757	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations B Ø	0	
81758	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations C Ø	0	
81759	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations Ground	0	
81760	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
81761	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	General Comments		
81762	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
81763	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
81764	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations	2	
81765	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
81766	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
81767	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
81768	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps A Ø	65	
81769	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps B Ø	65	
81770	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps C Ø	65	
81771	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps A Phase V	0	
81772	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps B Phase V	0	
81773	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps C Phase V	0	
81774	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations A Ø	0	
81775	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations B Ø	0	
81776	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations C Ø	0	
81777	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations Ground	0	
81778	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Follow-up Action Required?	n	
81779	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	General Comments		
81780	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Maintenance Operations	0	
81781	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AF	184	
81782	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AL	184	
81783	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations This Read Vac	0	
81784	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Switching Operations	0	
81785	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Unknown Operations	0	
81786	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
81787	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
81788	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81789	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
81790	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
81791	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
81792	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
81793	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81794	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81795	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81796	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81797	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81798	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81799	11/15/2019 7:37	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
81800	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	34	
81801	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
81802	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
81803	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
81804	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations	2	
81805	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81806	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81807	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81808	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps A Ø	163.0	
81809	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
81810	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
81811	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps B Ø	166.0	
81812	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps C Ø	170.0	
81813	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushing Condition	Good	
81814	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81815	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81816	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AL	745	
81817	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81818	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81819	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81820	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81821	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81822	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81823	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81824	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81825	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81826	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
81827	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Off-line-Distribution	VCB Readings	9 Month Operations	10	
81828	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
81829	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
81830	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
81831	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
81832	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Follow-up Action Required?	n	
81833	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	General Comments		
81834	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
81835	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
81836	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
81837	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
81838	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
81839	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7620.48	kw
81840	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
81841	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
81842	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
81843	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
81844	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	General Comments		
81845	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	General Comments		
81846	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
81847	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
81848	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
81849	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
81850	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
81851	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
81852	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
81853	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
81854	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
81855	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81856	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
81857	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
81858	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
81859	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
81860	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
81861	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	9 Month Operations	0	
81862	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
81863	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
81864	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
81865	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps A Ø	17.0	
81866	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps B Ø	18.0	
81867	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps C Ø	17.0	
81868	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushing Condition	Good	
81869	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81870	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81871	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81872	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81873	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81874	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81875	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81876	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81877	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81878	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations A Ø	0	
81879	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations B Ø	0	
81880	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations C Ø	0	
81881	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations Ground	0	
81882	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Follow-up Action Required?	n	
81883	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Follow-up Action Required?	n	
81884	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Foundation Condition	Good	
81885	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	General Comments		
81886	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	General Comments		
81887	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Grounds in Place?	y	
81888	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
81889	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Follow-up Action Required?	n	
81890	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
81891	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	General Comments		
81892	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	General Comments		
81893	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
81894	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81895	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Maintenance Operations	0	
81896	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
81897	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AF	178	
81898	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AL	178	
81899	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations This Read Vac	0	
81900	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Switching Operations	0	
81901	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81902	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Unknown Operations	0	
81903	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Unknown Operations	0	
81904	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
81905	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Operations Since Last Insp	3676	
81906	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Min Tap Position	6L	
81907	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Max Tap Position	2L	
81908	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Current Tap Position	9L	
81909	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Left Counter	6495	
81910	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Found Counter	6495	
81911	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	General Comments		
81912	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Follow-up Action Required?	n	
81913	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
81914	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
81915	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
81916	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
81917	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
81918	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	405	
81919	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	405	
81920	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Present	29	°C
81921	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
81922	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
81923	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
81924	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
81925	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
81926	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
81927	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
81928	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
81929	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
81930	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
81931	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
81932	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
81933	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
81934	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
81935	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81936	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81937	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
81938	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
81939	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
81940	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7938	
81941	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
81942	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
81943	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
81944	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
81945	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
81946	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
81947	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
81948	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81949	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
81950	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
81951	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	70.0	
81952	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
81953	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
81954	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
81955	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
81956	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Operations Since Last Insp	985	
81957	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
81958	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
81959	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
81960	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Min Tap Position	3L	
81961	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Max Tap Position	14L	
81962	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Current Tap Position	6L	
81963	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
81964	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Left Counter	17393	
81965	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Found Counter	17390	
81966	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
81967	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
81968	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
81969	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
81970	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
81971	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
81972	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
81973	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
81974	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	General Comments	Yard is under Construction	
81975	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
81976	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
81977	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
81978	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
81979	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
81980	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
81981	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
81982	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
81983	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
81984	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
81985	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
81986	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
81987	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
81988	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
81989	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
81990	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
81991	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
81992	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
81993	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
81994	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
81995	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	General Comments		
81996	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	General Comments		
81997	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
81998	11/14/2019 14:18	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Follow-up Action Required?	n	
81999	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82000	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
82001	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
82002	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
82003	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82004	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82005	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82006	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82007	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?		
82008	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
82009	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
82010	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
82011	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
82012	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82013	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
82014	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
82015	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
82016	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
82017	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
82018	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
82019	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
82020	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
82021	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.8	psi
82022	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
82023	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
82024	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
82025	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
82026	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
82027	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
82028	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
82029	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
82030	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
82031	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
82032	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
82033	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	34	
82034	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
82035	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
82036	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	BCH000391	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
82037	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
82038	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
82039	11/14/2019 11:49	Distribution	Waco Quarterly Inspection	CB0179	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
82040	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
82041	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
82042	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82043	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
82044	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
82045	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
82046	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
82047	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
82048	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Unit is offline, Oil leak around the PRD, pic sent to Stinson, transformer needs Nitrogen	
82049	11/18/2019 8:15	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
82050	11/14/2019 10:54	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
82051	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	340	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82052	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
82053	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
82054	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
82055	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
82056	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	350	
82057	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.89	%
82058	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	140	
82059	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
82060	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
82061	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
82062	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	140	
82063	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps Ø	340	
82064	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82065	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82066	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82067	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
82068	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.89	%
82069	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
82070	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
82071	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
82072	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
82073	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
82074	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82075	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82076	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82077	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82078	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82079	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82080	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
82081	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
82082	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
82083	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
82084	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
82085	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
82086	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	164.0	
82087	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	156.0	
82088	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	161.0	
82089	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
82090	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
82091	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
82092	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
82093	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
82094	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
82095	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
82096	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
82097	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	24	
82098	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
82099	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
82100	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
82101	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
82102	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
82103	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	99977	
82104	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	99977	
82105	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations This Read AM	0	
82106	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
82107	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Unknown Operations	0	
82108	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
82109	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
82110	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
82111	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82112	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82113	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82114	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82115	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
82116	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82117	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
82118	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Follow-up Action Required?	n	
82119	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	General Comments		
82120	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
82121	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
82122	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Follow-up Action Required?	n	
82123	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
82124	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	General Comments		
82125	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	General Comments	Actual Counter	
82126	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82127	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AF	872	
82128	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTCC000823	LTCCControl	376-1	LTC Control Insp	All Connections OK?	y	
82129	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
82130	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
82131	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
82132	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AL	872	
82133	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations This Read Vac	0	
82134	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
82135	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
82136	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
82137	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
82138	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
82139	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
82140	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
82141	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
82142	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Present	30	°C
82143	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
82144	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	General Comments		
82145	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
82146	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
82147	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
82148	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	360.0	
82149	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	340.0	
82150	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	340.0	
82151	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82152	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82153	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82154	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
82155	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Unknown Operations	0	
82156	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Switching Operations	0	
82157	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	General Comments		
82158	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
82159	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	LTC Totalizer Reading	2947.20	kw
82160	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Max	40	°C
82161	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
82162	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
82163	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
82164	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
82165	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
82166	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
82167	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
82168	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
82169	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations Ground	0	
82170	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
82171	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
82172	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Trash?	y	
82173	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
82174	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
82175	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	General Comments		
82176	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	General Comments		
82177	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Maintenance Operations	0	
82178	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AF	147	
82179	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
82180	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
82181	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
82182	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
82183	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
82184	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
82185	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
82186	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
82187	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AL	147	
82188	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations This Read Vac	0	
82189	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Switching Operations	0	
82190	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Unknown Operations	0	
82191	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
82192	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Leaks	None	
82193	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	General Comments		
82194	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
82195	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
82196	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
82197	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
82198	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
82199	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
82200	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
82201	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82202	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
82203	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
82204	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Regulator As Left Counter	339505	
82205	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations Ground	0	
82206	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations C Ø	0	
82207	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations B Ø	0	
82208	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations A Ø	0	
82209	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82210	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82211	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82212	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82213	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps C Ø	123.0	
82214	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps B Ø	125.0	
82215	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps A Ø	103.0	
82216	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82217	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82218	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82219	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations	7	
82220	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations	0	
82221	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82222	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82223	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82224	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
82225	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
82226	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	30	°C
82227	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
82228	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
82229	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
82230	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
82231	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
82232	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps A Ø	583.0	
82233	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps B Ø	596.0	
82234	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps C Ø	629.0	
82235	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82236	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82237	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82238	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82239	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
82240	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
82241	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Reading	.9210	
82242	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
82243	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
82244	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
82245	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
82246	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Vegetation	None	
82247	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	General Comments		
82248	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
82249	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
82250	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
82251	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
82252	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations C Ø	0	
82253	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations B Ø	0	
82254	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations A Ø	0	
82255	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
82256	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82257	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82258	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82259	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82260	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82261	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
82262	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
82263	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
82264	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
82265	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
82266	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
82267	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
82268	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
82269	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
82270	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
82271	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
82272	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
82273	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
82274	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
82275	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	460.0	
82276	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	440.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82277	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	480.0	
82278	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
82279	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
82280	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
82281	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82282	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82283	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
82284	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
82285	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	0	
82286	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
82287	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
82288	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
82289	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
82290	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
82291	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
82292	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
82293	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
82294	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
82295	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
82296	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
82297	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
82298	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
82299	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
82300	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
82301	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
82302	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82303	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	General Comments		
82304	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Follow-up Action Required?	n	
82305	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
82306	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations Ground	0	
82307	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
82308	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
82309	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments		
82310	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
82311	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
82312	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	50	
82313	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	50	
82314	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
82315	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	0	
82316	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
82317	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
82318	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
82319	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
82320	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
82321	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
82322	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	General Comments		
82323	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
82324	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	General Comments	VC change no target	
82325	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
82326	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
82327	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82328	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82329	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82330	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
82331	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
82332	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
82333	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
82334	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
82335	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82336	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82337	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
82338	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
82339	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
82340	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
82341	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
82342	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
82343	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
82344	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
82345	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
82346	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	General Comments		
82347	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
82348	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
82349	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82350	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
82351	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	84	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82352	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	84	
82353	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
82354	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
82355	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82356	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
82357	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Foundation Condition	Good	
82358	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
82359	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
82360	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82361	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
82362	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Unknown Operations	0	
82363	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Switching Operations	3	
82364	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations This Read Vac	3	
82365	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AL	229	
82366	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AF	229	
82367	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Maintenance Operations	0	
82368	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	General Comments		
82369	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC000823	LTCControl	376-1	LTC Control Insp	General Comments		
82370	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC000823	LTCControl	376-1	LTC Control Insp	Follow-up Action Required?	n	
82371	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
82372	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
82373	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
82374	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
82375	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Broom on Site?	y	
82376	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
82377	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
82378	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
82379	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
82380	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
82381	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82382	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
82383	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
82384	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	220	
82385	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
82386	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
82387	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
82388	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	220	
82389	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
82390	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82391	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
82392	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
82393	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
82394	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Maintenance Operations	0	
82395	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AF	466	
82396	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AL	466	
82397	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations This Read AM	0	
82398	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Switching Operations	0	
82399	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
82400	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
82401	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
82402	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
82403	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82404	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
82405	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	36.0	VDC
82406	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
82407	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Unknown Operations	0	
82408	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
82409	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
82410	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
82411	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
82412	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
82413	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
82414	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
82415	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
82416	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
82417	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
82418	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Swept?	y	
82419	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
82420	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
82421	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
82422	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
82423	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
82424	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
82425	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
82426	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82427	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
82428	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
82429	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
82430	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
82431	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
82432	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
82433	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
82434	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Foundation Condition	Good	
82435	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
82436	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
82437	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	General Comments		
82438	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
82439	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
82440	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
82441	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
82442	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
82443	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
82444	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
82445	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
82446	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
82447	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82448	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82449	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82450	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0190	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82451	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
82452	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
82453	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
82454	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
82455	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
82456	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
82457	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
82458	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
82459	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
82460	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
82461	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
82462	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
82463	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
82464	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
82465	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC0000823	LTCControl	376-1	LTC Control Insp	VRR Time Delay	60	Seconds
82466	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC0000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
82467	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC0000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
82468	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC0000823	LTCControl	376-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
82469	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	LTC0000823	LTCControl	376-1	LTC Control Insp	LTC Operation Checked?	y	
82470	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
82471	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82472	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
82473	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
82474	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
82475	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
82476	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Foundation Condition	Good	
82477	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
82478	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Tank Paint Condition	Good	
82479	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82480	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
82481	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
82482	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
82483	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
82484	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Moisture and Leak Free?	y	
82485	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82486	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Grounds in Place?	y	
82487	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	General Comments		
82488	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Foundation Condition	Good	
82489	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Follow-up Action Required?	n	
82490	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82491	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82492	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82493	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82494	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82495	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82496	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushing Condition	Good	
82497	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
82498	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	General Comments		
82499	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
82500	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
82501	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82502	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
82503	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
82504	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
82505	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
82506	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
82507	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
82508	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
82509	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
82510	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
82511	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
82512	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
82513	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
82514	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	General Comments		
82515	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
82516	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Unknown Operations	0	
82517	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Tank Paint Condition	Good	
82518	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Switching Operations	0	
82519	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82520	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations This Read Vac	0	
82521	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AL	99741	
82522	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AF	99741	
82523	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
82524	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	VRR Time Delay	30	Seconds
82525	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
82526	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
82527	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
82528	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	LTC Operation Checked?	y	
82529	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	General Comments		
82530	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	Follow-up Action Required?	n	
82531	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	LTC000855	LTCControl	402-1	LTC Control Insp	All Connections OK?	y	
82532	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Maintenance Operations	0	
82533	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Grounds in Place?	y	
82534	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	General Comments		
82535	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	General Comments		
82536	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Foundation Condition	Good	
82537	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Follow-up Action Required?	n	
82538	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Follow-up Action Required?	n	
82539	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations Ground	0	
82540	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations C Ø	0	
82541	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations B Ø	0	
82542	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations A Ø	0	
82543	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82544	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
82545	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
82546	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
82547	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
82548	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
82549	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
82550	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
82551	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.0580	
82552	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations This Read Vac	0	
82553	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AL	183	
82554	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
82555	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
82556	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
82557	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Unknown Operations	0	
82558	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Switching Operations	0	
82559	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations This Read Vac	0	
82560	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AL	312	
82561	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AF	312	
82562	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Maintenance Operations	0	
82563	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	General Comments		
82564	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Follow-up Action Required?	n	
82565	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations Ground	0	
82566	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations C Ø	0	
82567	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations B Ø	0	
82568	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations A Ø	0	
82569	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82570	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82571	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82572	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps C Ø	290.0	
82573	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps B Ø	240.0	
82574	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps A Ø	320.0	
82575	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty C Ph V	1.02	%
82576	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty B Ph V	.34	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82577	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty A Ph V	.68	%
82578	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	9 Month Operations	5	
82579	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
82580	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
82581	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
82582	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82583	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82584	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
82585	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AF	183	
82586	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
82587	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Maintenance Operations	0	
82588	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82589	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
82590	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	General Comments		
82591	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	General Comments		
82592	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
82593	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
82594	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82595	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
82596	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
82597	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	289	
82598	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	289	
82599	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations This Read Vac	0	
82600	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82601	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	0	
82602	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
82603	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
82604	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
82605	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
82606	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations Ground	0	
82607	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
82608	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
82609	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
82610	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82611	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82612	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
82613	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
82614	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
82615	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
82616	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82617	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
82618	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps C Ø	104.0	
82619	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps B Ø	101.0	
82620	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps A Ø	91.0	
82621	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82622	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82623	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82624	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations	0	
82625	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Unknown Operations	0	
82626	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Tank Paint Condition	Good	
82627	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Switching Operations	0	
82628	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82629	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations This Read Vac	0	
82630	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AL	248	
82631	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AF	248	
82632	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Moisture and Leak Free?	y	
82633	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Maintenance Operations	0	
82634	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82635	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Grounds in Place?	y	
82636	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	General Comments		
82637	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	General Comments		
82638	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Foundation Condition	Good	
82639	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Follow-up Action Required?	n	
82640	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Follow-up Action Required?	n	
82641	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations Ground	0	
82642	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations C Ø	0	
82643	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations B Ø	0	
82644	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	96	
82645	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps A Ø	20	
82646	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps B Ø	20	
82647	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps C Ø	20	
82648	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	102	
82649	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
82650	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
82651	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	110	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82652	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
82653	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
82654	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
82655	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	General Comments		
82656	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
82657	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
82658	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
82659	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations A Ø	0	
82660	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82661	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82662	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82663	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82664	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82665	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82666	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82667	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82668	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82669	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushing Condition	Good	
82670	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps C Ø	0.0	
82671	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps B Ø	0.0	
82672	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps A Ø	0.0	
82673	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82674	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82675	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82676	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations	1	
82677	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
82678	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	150	°C
82679	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
82680	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
82681	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
82682	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82683	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
82684	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
82685	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
82686	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
82687	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82688	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82689	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82690	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82691	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82692	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82693	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82694	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82695	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82696	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushing Condition	Good	
82697	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps C Ø	600.0	
82698	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps B Ø	540.0	
82699	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps A Ø	620.0	
82700	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82701	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82702	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82703	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations	1	
82704	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Ambient Temp	26	°F
82705	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
82706	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
82707	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
82708	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
82709	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
82710	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
82711	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
82712	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
82713	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
82714	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	General Comments		
82715	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
82716	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
82717	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
82718	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
82719	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Vegetation	None	
82720	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
82721	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Time Delay	30	Seconds
82722	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
82723	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
82724	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
82725	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Operation Checked?	y	
82726	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82727	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	Follow-up Action Required?	n	
82728	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	All Connections OK?	y	
82729	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations	5	
82730	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82731	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82732	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82733	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps A Ø	108.0	
82734	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps B Ø	90.0	
82735	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps C Ø	130.0	
82736	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82737	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82738	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82739	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82740	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations A Ø	0	
82741	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations B Ø	0	
82742	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations C Ø	0	
82743	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
82744	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
82745	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
82746	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	General Comments		
82747	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments	Actual Counter	
82748	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
82749	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	157	
82750	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	157	
82751	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations This Read Vac	0	
82752	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	0	
82753	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	0	
82754	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82755	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82756	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82757	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82758	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82759	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82760	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
82761	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
82762	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
82763	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	General Comments		
82764	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
82765	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
82766	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Vegetation	None	
82767	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
82768	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
82769	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
82770	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	General Comments		
82771	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
82772	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
82773	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
82774	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
82775	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
82776	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
82777	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Trash?	y	
82778	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
82779	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
82780	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
82781	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
82782	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
82783	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
82784	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
82785	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
82786	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
82787	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
82788	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	196	
82789	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	196	
82790	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
82791	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
82792	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
82793	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
82794	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
82795	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
82796	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
82797	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82798	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82799	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82800	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
82801	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82802	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
82803	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.89	%
82804	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.89	%
82805	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.89	%
82806	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
82807	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
82808	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
82809	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	General Comments		
82810	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
82811	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
82812	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
82813	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
82814	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
82815	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
82816	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
82817	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
82818	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
82819	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
82820	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
82821	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
82822	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
82823	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
82824	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
82825	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
82826	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
82827	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
82828	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
82829	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
82830	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
82831	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
82832	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
82833	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Leaks	None	
82834	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
82835	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
82836	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
82837	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
82838	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	General Comments		
82839	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
82840	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
82841	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
82842	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
82843	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Regulator As Left Counter	100801	
82844	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
82845	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
82846	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
82847	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
82848	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
82849	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
82850	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
82851	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
82852	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	General Comments		
82853	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
82854	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
82855	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
82856	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
82857	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
82858	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
82859	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
82860	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
82861	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
82862	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
82863	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
82864	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
82865	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
82866	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82867	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
82868	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
82869	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
82870	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
82871	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
82872	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82873	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
82874	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
82875	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
82876	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
82877	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
82878	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
82879	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
82880	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	General Comments		
82881	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
82882	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	80	°C
82883	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
82884	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
82885	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
82886	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
82887	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
82888	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
82889	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
82890	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
82891	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
82892	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
82893	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
82894	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
82895	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
82896	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
82897	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
82898	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
82899	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
82900	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	90	°C
82901	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
82902	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	95	°C
82903	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	10	°C
82904	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82905	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82906	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82907	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82908	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
82909	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
82910	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
82911	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
82912	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
82913	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
82914	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
82915	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
82916	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82917	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82918	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
82919	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	145.0	
82920	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
82921	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	4	
82922	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82923	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82924	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82925	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	60.0	
82926	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	60.0	
82927	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	65.0	
82928	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
82929	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
82930	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
82931	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
82932	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82933	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82934	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82935	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
82936	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
82937	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
82938	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
82939	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B Ø	0	
82940	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C Ø	0	
82941	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
82942	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
82943	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
82944	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
82945	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
82946	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
82947	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
82948	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
82949	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
82950	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.200	millivolts
82951	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A5 Found Float Voltage	53.4	VDC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
82952	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
82953	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	7.7	amps
82954	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
82955	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
82956	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	General Comments		
82957	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
82958	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
82959	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
82960	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Unknown Operations	0	
82961	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
82962	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Switching Operations	0	
82963	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82964	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
82965	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
82966	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
82967	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
82968	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
82969	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
82970	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
82971	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	3385.60	kw
82972	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
82973	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
82974	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
82975	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
82976	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
82977	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
82978	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
82979	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
82980	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82981	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
82982	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
82983	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
82984	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
82985	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
82986	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
82987	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
82988	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
82989	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
82990	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
82991	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
82992	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
82993	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
82994	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
82995	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029698	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
82996	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029698	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	General Comments		
82997	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029698	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
82998	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029698	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
82999	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029699	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83000	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029699	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	General Comments		
83001	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029699	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83002	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029699	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83003	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029700	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83004	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029700	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	General Comments		
83005	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029700	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83006	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029700	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83007	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029701	RelayMicroprocessor	790-0531 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83008	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029701	RelayMicroprocessor	790-0531 Panel	Relay Microprocessor DC Circuit Check	General Comments		
83009	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029701	RelayMicroprocessor	790-0531 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83010	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029701	RelayMicroprocessor	790-0531 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83011	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029721	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83012	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029721	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	General Comments		
83013	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029721	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83014	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029721	RelayMicroprocessor	897-2472 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83015	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029722	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83016	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029722	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	General Comments		
83017	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029722	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83018	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029722	RelayMicroprocessor	Retired Distribution	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83019	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029723	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83020	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029723	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	General Comments		
83021	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029723	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83022	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029723	RelayMicroprocessor	897-2509 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83023	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029724	RelayMicroprocessor	897-2511 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
83024	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1146	
83025	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1146	
83026	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83027	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
83028	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
83029	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029724	RelayMicroprocessor	897-2511 Panel	Relay Microprocessor DC Circuit Check	General Comments		
83030	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029724	RelayMicroprocessor	897-2511 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
83031	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	RLY029724	RelayMicroprocessor	897-2511 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
83032	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
83033	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
83034	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
83035	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
83036	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
83037	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
83038	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
83039	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0293	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
83040	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
83041	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
83042	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
83043	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
83044	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
83045	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
83046	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83047	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83048	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0219	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83049	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Maintenance Operations	0	
83050	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Moisture and Leak Free?	y	
83051	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AF	182	
83052	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AL	182	
83053	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	General Comments		
83054	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83055	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
83056	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83057	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	25	°C
83058	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	40	°C
83059	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
83060	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
83061	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	39801600.00	kw
83062	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
83063	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
83064	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations This Read Vac	0	
83065	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
83066	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Switching Operations	0	
83067	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Tank Paint Condition	Good	
83068	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Unknown Operations	0	
83069	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83070	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83071	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
83072	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
83073	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
83074	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
83075	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
83076	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83077	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	General Comments		
83078	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
83079	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
83080	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
83081	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83082	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
83083	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
83084	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83085	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
83086	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
83087	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83088	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83089	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
83090	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations Ground	0	
83091	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Follow-up Action Required?	n	
83092	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
83093	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
83094	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
83095	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
83096	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
83097	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
83098	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83099	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
83100	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
83101	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83102	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83103	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83104	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83105	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
83106	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
83107	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
83108	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	General Comments		
83109	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83110	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
83111	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
83112	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Follow-up Action Required?	n	
83113	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Foundation Condition	Good	
83114	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83115	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	General Comments		
83116	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	General Comments		
83117	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Grounds in Place?	y	
83118	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Heaters (All) Functioning?	y	
83119	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	VRR Time Delay	30	Seconds
83120	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
83121	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
83122	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
83123	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	LTC Operation Checked?	y	
83124	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	General Comments		
83125	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	Follow-up Action Required?	n	
83126	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTC000358	LTCControl	897-2	LTC Control Insp	All Connections OK?	y	
83127	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
83128	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Vegetation	None	
83129	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83130	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83131	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
83132	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
83133	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83134	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83135	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83136	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations A Ø	0	
83137	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations B Ø	0	
83138	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations C Ø	0	
83139	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations Ground	0	
83140	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Follow-up Action Required?	n	
83141	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Follow-up Action Required?	n	
83142	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Foundation Condition	Good	
83143	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	General Comments		
83144	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	General Comments		
83145	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Grounds in Place?	y	
83146	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
83147	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
83148	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
83149	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
83150	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
83151	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
83152	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
83153	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
83154	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	606	
83155	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	606	
83156	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
83157	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
83158	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
83159	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
83160	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
83161	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
83162	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
83163	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
83164	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
83165	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
83166	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
83167	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
83168	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
83169	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83170	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83171	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83172	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83173	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83174	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
83175	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
83176	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83177	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83178	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83179	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
83180	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
83181	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83182	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83183	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
83184	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83185	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83186	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
83187	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83188	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	22	*C
83189	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	*C
83190	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
83191	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
83192	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
83193	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
83194	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
83195	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
83196	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
83197	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Trash?	y	
83198	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
83199	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
83200	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
83201	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations	0	
83202	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
83203	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
83204	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
83205	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	320.0	
83206	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps B Ø	320.0	
83207	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps C Ø	260.0	
83208	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushing Condition	Good	
83209	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
83210	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
83211	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
83212	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
83213	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
83214	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Vegetation	None	
83215	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
83216	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
83217	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
83218	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	General Comments	Yard light by HI 6660 is not working. The dome light socket looks burnt changed buld nothing happened	
83219	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
83220	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
83221	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
83222	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
83223	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
83224	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
83225	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
83226	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
83227	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
83228	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations This Read AM	0	
83229	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AL	776	
83230	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AF	776	
83231	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Maintenance Operations	0	
83232	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	General Comments		
83233	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	General Comments		
83234	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Follow-up Action Required?	n	
83235	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Follow-up Action Required?	n	
83236	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations Ground	0	
83237	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations C Ø	0	
83238	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations B Ø	0	
83239	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations A Ø	0	
83240	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
83241	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
83242	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
83243	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
83244	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps C Ø	86.0	
83245	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps B Ø	88.0	
83246	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps A Ø	87.0	
83247	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
83248	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
83249	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
83250	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Months Operations	36	
83251	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83252	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations A Ø	0	
83253	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations B Ø	0	
83254	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
83255	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
83256	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
83257	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
83258	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
83259	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
83260	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
83261	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
83262	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
83263	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	General Comments		
83264	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
83265	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
83266	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
83267	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
83268	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
83269	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
83270	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
83271	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
83272	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10063	
83273	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
83274	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
83275	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Leaks	None	
83276	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations	8	
83277	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
83278	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
83279	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
83280	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps A Ø	58.0	
83281	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps B Ø	63.0	
83282	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps C Ø	72.0	
83283	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushing Condition	Good	
83284	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
83285	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
83286	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
83287	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
83288	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
83289	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
83290	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83291	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83292	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Unknown Operations	0	
83293	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Switching Operations	0	
83294	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
83295	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83296	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
83297	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
83298	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
83299	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
83300	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
83301	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		
83302	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83303	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
83304	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
83305	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
83306	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83307	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
83308	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
83309	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
83310	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
83311	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
83312	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		
83313	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
83314	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
83315	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
83316	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
83317	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
83318	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
83319	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Reading	4146.0000	
83320	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
83321	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83322	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
83323	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
83324	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
83325	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
83326	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83327	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
83328	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
83329	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
83330	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
83331	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
83332	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
83333	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
83334	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations B Ø	0	
83335	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations C Ø	0	
83336	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations C Ø	0	
83337	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations Ground	0	
83338	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Follow-up Action Required?	n	
83339	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Follow-up Action Required?	n	
83340	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Foundation Condition	Good	
83341	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	General Comments		
83342	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	General Comments		
83343	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Grounds in Place?	y	
83344	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
83345	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Maintenance Operations	0	
83346	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Moisture and Leak Free?	y	
83347	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AF	254	
83348	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AL	254	
83349	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations This Read Vac	0	
83350	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
83351	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Switching Operations	0	
83352	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Tank Paint Condition	Good	
83353	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Unknown Operations	0	
83354	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations	0	
83355	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
83356	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
83357	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
83358	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps A Ø	31.0	
83359	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps B Ø	33.0	
83360	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps C Ø	32.0	
83361	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushing Condition	Good	
83362	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
83363	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
83364	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
83365	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
83366	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
83367	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
83368	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83369	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83370	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83371	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations A Ø	0	
83372	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
83373	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
83374	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
83375	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
83376	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83377	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83378	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	HI Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
83379	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	HI Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
83380	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	HI Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
83381	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Unknown Operations	1	
83382	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Switching Operations	0	
83383	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations This Read AM	1	
83384	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AL	774	
83385	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AF	774	
83386	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Maintenance Operations	0	
83387	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	General Comments		
83388	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	General Comments		
83389	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Follow-up Action Required?	n	
83390	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Follow-up Action Required?	n	
83391	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
83392	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
83393	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	189	
83394	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
83395	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
83396	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
83397	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
83398	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
83399	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
83400	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
83401	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	HI Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83402	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
83403	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
83404	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
83405	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
83406	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
83407	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
83408	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
83409	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
83410	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
83411	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
83412	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
83413	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
83414	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
83415	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
83416	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
83417	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
83418	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
83419	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
83420	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
83421	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
83422	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
83423	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
83424	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
83425	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
83426	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
83427	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
83428	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations	4	
83429	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
83430	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
83431	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
83432	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
83433	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
83434	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
83435	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
83436	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
83437	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
83438	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
83439	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
83440	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
83441	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
83442	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
83443	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
83444	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
83445	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
83446	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
83447	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
83448	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
83449	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
83450	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
83451	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
83452	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	General Comments		
83453	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
83454	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
83455	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
83456	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
83457	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
83458	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
83459	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
83460	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC0000686	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
83461	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC0000686	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
83462	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations Ground	0	
83463	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
83464	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Follow-up Action Required?	n	
83465	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
83466	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
83467	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
83468	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
83469	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Operations Since Last Insp	1223	
83470	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
83471	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
83472	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
83473	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
83474	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Min Tap Position	12L	
83475	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Max Tap Position	7L	
83476	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Current Tap Position	6L	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83477	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
83478	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Left Counter	136070	
83479	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Found Counter	136070	
83480	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	General Comments		
83481	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps B Ø	67.0	
83482	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	General Comments		
83483	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
83484	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Follow-up Action Required?	n	
83485	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	General Comments		
83486	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	General Comments	Actual Counter	
83487	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Maintenance Operations	0	
83488	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AF	826	
83489	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AL	826	
83490	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations This Read Vac	0	
83491	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Switching Operations	0	
83492	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Unknown Operations	0	
83493	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83494	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83495	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
83496	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Months Operations	33	
83497	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
83498	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps A Ø	74.0	
83499	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
83500	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
83501	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps A Ø	112.0	
83502	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps B Ø	106.0	
83503	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps C Ø	86.0	
83504	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
83505	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83506	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83507	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83508	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations A Ø	0	
83509	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations B Ø	0	
83510	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations C Ø	0	
83511	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
83512	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
83513	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
83514	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
83515	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
83516	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
83517	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
83518	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
83519	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
83520	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
83521	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
83522	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
83523	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83524	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
83525	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83526	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83527	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
83528	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations Ground	0	
83529	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations C Ø	0	
83530	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations B Ø	0	
83531	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations A Ø	0	
83532	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
83533	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
83534	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
83535	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
83536	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
83537	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps C Phase AM	8.00	
83538	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps B Phase AM	8.00	
83539	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps A Phase AM	8.00	
83540	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
83541	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps C Ø	74.0	
83542	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations This Read Vac	0	
83543	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
83544	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Switching Operations	0	
83545	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Tank Paint Condition	Good	
83546	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Unknown Operations	0	
83547	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
83548	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
83549	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
83550	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Trash?	y	
83551	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83552	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
83553	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
83554	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
83555	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
83556	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	General Comments		
83557	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
83558	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Vegetation	None	
83559	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
83560	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
83561	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
83562	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
83563	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
83564	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
83565	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
83566	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
83567	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
83568	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83569	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83570	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83571	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83572	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
83573	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0779	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
83574	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83575	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83576	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
83577	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83578	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83579	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
83580	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83581	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	10	°C
83582	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
83583	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
83584	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
83585	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
83586	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
83587	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
83588	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
83589	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
83590	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	155.0	
83591	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	170.0	
83592	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	165.0	
83593	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
83594	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
83595	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
83596	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
83597	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
83598	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
83599	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
83600	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
83601	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
83602	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AL	136070	
83603	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AF	136070	
83604	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
83605	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
83606	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
83607	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
83608	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Reset Tap Drag Hands	Unable to Reset	
83609	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Min Tap Position	12L	
83610	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Max Tap Position	6L	
83611	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	General Comments		
83612	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
83613	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
83614	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
83615	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
83616	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
83617	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Current Tap Position	7L	
83618	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	All Connections OK?	y	
83619	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
83620	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Maintenance Operations	0	
83621	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
83622	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AF	42	
83623	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AL	42	
83624	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000049	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
83625	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000049	Yard	897-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
83626	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000049	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83627	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
83628	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
83629	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
83630	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
83631	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	General Comments		
83632	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
83633	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
83634	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
83635	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
83636	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
83637	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
83638	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
83639	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
83640	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
83641	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
83642	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
83643	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
83644	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
83645	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
83646	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
83647	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
83648	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
83649	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	General Comments		
83650	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
83651	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
83652	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Operations Counter	3	
83653	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
83654	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Leaks	None	
83655	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
83656	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
83657	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
83658	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
83659	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
83660	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
83661	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
83662	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
83663	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
83664	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
83665	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
83666	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
83667	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
83668	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
83669	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
83670	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
83671	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
83672	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
83673	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
83674	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83675	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83676	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83677	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83678	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
83679	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0778	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
83680	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
83681	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83682	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83683	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83684	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83685	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
83686	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	General Comments		
83687	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
83688	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
83689	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
83690	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
83691	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
83692	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
83693	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
83694	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83695	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83696	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
83697	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
83698	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
83699	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
83700	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
83701	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
83702	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	General Comments		
83703	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
83704	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Ambient Temp	27	*F
83705	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
83706	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
83707	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
83708	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
83709	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
83710	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
83711	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
83712	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
83713	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	23	*F
83714	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
83715	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
83716	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
83717	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
83718	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
83719	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
83720	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
83721	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
83722	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	YD000427	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
83723	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
83724	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
83725	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
83726	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83727	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
83728	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
83729	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83730	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
83731	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
83732	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
83733	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
83734	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
83735	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83736	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83737	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83738	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
83739	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
83740	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	ST000430	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
83741	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
83742	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
83743	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
83744	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
83745	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
83746	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
83747	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
83748	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	408	
83749	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
83750	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
83751	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	431	
83752	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
83753	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
83754	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
83755	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
83756	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
83757	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
83758	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Operations Counter	450	
83759	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
83760	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83761	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
83762	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
83763	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
83764	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
83765	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	General Comments		
83766	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
83767	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
83768	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
83769	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
83770	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
83771	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.4	
83772	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps B Ø	32.4	
83773	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps A Ø	96.8	
83774	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1030	
83775	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
83776	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83777	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
83778	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83779	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
83780	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
83781	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83782	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	General Comments		
83783	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
83784	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
83785	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
83786	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83787	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83788	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83789	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
83790	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
83791	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
83792	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	238	
83793	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
83794	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
83795	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
83796	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
83797	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
83798	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Left Counter	411203	
83799	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Found Counter	411203	
83800	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
83801	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	General Comments		
83802	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
83803	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
83804	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
83805	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
83806	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
83807	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
83808	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
83809	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
83810	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
83811	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
83812	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
83813	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
83814	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83815	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83816	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
83817	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
83818	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
83819	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
83820	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
83821	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	General Comments		
83822	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83823	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
83824	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Foundation Condition	Good	
83825	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
83826	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83827	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
83828	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
83829	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
83830	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
83831	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
83832	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
83833	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
83834	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	General Comments		
83835	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
83836	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
83837	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
83838	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15R	
83839	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
83840	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
83841	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Left Counter	189289	
83842	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Found Counter	189289	
83843	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
83844	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	General Comments		
83845	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
83846	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
83847	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
83848	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
83849	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
83850	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
83851	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	896	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
83852	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
83853	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
83854	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
83855	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
83856	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Left Counter	26328	
83857	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Found Counter	26328	
83858	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
83859	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	General Comments		
83860	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
83861	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
83862	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
83863	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
83864	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
83865	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
83866	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
83867	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
83868	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
83869	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
83870	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
83871	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
83872	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	General Comments		
83873	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	General Comments		
83874	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Follow-up Action Required?	n	
83875	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
83876	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations Ground	0	
83877	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations C Ø	0	
83878	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations B Ø	0	
83879	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations A Ø	0	
83880	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
83881	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
83882	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
83883	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
83884	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps C Ø	140.0	
83885	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps B Ø	100.0	
83886	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps A Ø	115.0	
83887	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
83888	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
83889	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
83890	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Months Operations	11	
83891	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
83892	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Leaks	None	
83893	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
83894	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Regulator As Left Counter	265330	
83895	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
83896	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
83897	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
83898	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
83899	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
83900	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
83901	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
83902	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
83903	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	General Comments		
83904	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
83905	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
83906	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
83907	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Follow-up Action Required?	n	
83908	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations Ground	0	
83909	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations C Ø	0	
83910	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations B Ø	0	
83911	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations A Ø	0	
83912	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
83913	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
83914	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty	
83915	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
83916	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
83917	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
83918	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
83919	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
83920	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	C0160	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
83921	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
83922	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
83923	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
83924	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
83925	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
83926	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
83927	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
83928	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
83929	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
83930	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0197	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
83931	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
83932	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
83933	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
83934	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
83935	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
83936	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
83937	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps C Ø	180.0	
83938	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps B Ø	200.0	
83939	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps A Ø	160.0	
83940	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
83941	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
83942	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
83943	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Months Operations	0	
83944	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
83945	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
83946	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
83947	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Unknown Operations	0	
83948	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Switching Operations	0	
83949	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations This Read AM	0	
83950	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AL	171	
83951	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AF	171	
83952	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Maintenance Operations	0	
83953	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
83954	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
83955	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
83956	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
83957	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
83958	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
83959	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Foundation Condition	Good	
83960	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
83961	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
83962	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	General Comments		
83963	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
83964	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
83965	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
83966	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
83967	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
83968	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
83969	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
83970	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
83971	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
83972	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
83973	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
83974	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	General Comments		
83975	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
83976	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
83977	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
83978	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
83979	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
83980	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
83981	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
83982	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
83983	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
83984	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
83985	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
83986	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
83987	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
83988	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
83989	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
83990	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
83991	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
83992	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
83993	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
83994	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
83995	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
83996	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
83997	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps C Ø	355.0	
83998	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps B Ø	370.0	
83999	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps A Ø	360.0	
84000	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty C Ph V	1.07	%
84001	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty B Ph V	1.34	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84002	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty A Ph V	2.42	%
84003	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	9 Month Operations	11	
84004	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
84005	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
84006	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
84007	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
84008	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
84009	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
84010	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
84011	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
84012	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Leaks	None	
84013	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
84014	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4216	
84015	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
84016	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
84017	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
84018	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
84019	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
84020	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
84021	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
84022	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
84023	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
84024	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
84025	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
84026	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
84027	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
84028	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
84029	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
84030	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
84031	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
84032	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
84033	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
84034	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	General Comments		
84035	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
84036	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
84037	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
84038	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
84039	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2947	
84040	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
84041	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	General Comments		
84042	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
84043	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
84044	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84045	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84046	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84047	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
84048	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
84049	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	130.0	
84050	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
84051	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84052	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84053	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84054	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84055	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84056	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84057	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
84058	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
84059	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
84060	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
84061	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
84062	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
84063	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
84064	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
84065	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
84066	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
84067	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
84068	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
84069	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
84070	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
84071	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
84072	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
84073	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	52	
84074	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	52	
84075	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
84076	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84077	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
84078	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
84079	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84080	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84081	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84082	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84083	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
84084	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
84085	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84086	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	General Comments		
84087	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	General Comments		
84088	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
84089	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
84090	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	235.76	kw
84091	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
84092	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
84093	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
84094	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
84095	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84096	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
84097	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
84098	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84099	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
84100	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84101	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
84102	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
84103	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
84104	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
84105	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
84106	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
84107	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
84108	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
84109	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
84110	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
84111	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	80258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7614	
84112	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
84113	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
84114	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
84115	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
84116	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
84117	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
84118	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE00067	Fence	386-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
84119	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE00067	Fence	386-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
84120	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE00067	Fence	386-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
84121	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE00067	Fence	386-Fence	Fence Patrol Inspection	General Comments	trees growing over the fence on the right hand side of the station.	
84122	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE00067	Fence	386-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
84123	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
84124	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
84125	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
84126	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
84127	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
84128	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
84129	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
84130	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
84131	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
84132	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
84133	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
84134	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
84135	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
84136	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
84137	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
84138	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
84139	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	82420	
84140	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
84141	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
84142	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
84143	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
84144	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
84145	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
84146	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
84147	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
84148	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panels Dusted?	y	
84149	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
84150	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
84151	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
84152	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
84153	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
84154	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Swept?	y	
84155	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
84156	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
84157	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Evidence of Insects	None	
84158	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
84159	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
84160	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
84161	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0220	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
84162	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	0	
84163	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
84164	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
84165	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	154	
84166	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	154	
84167	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
84168	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
84169	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
84170	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
84171	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
84172	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
84173	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
84174	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
84175	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
84176	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84177	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84178	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84179	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84180	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
84181	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	2.0	
84182	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	3.0	
84183	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84184	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84185	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84186	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	1	
84187	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
84188	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
84189	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
84190	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
84191	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
84192	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
84193	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
84194	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
84195	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
84196	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
84197	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
84198	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
84199	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
84200	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
84201	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
84202	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	General Comments		
84203	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
84204	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
84205	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
84206	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
84207	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
84208	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
84209	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
84210	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
84211	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Tank Paint Condition	Good	
84212	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
84213	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Moisture and Leak Free?	y	
84214	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
84215	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Grounds in Place?	y	
84216	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	General Comments		
84217	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Foundation Condition	Good	
84218	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Follow-up Action Required?	n	
84219	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	87	
84220	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps A Ø	35	
84221	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps B Ø	24	
84222	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps C Ø	24	
84223	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	84	
84224	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
84225	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
84226	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	63	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84227	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
84228	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
84229	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
84230	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LTC0000432	LTCControl	HI-TRANS 1	LTC Control Insp	General Comments	ok	
84231	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LTC0000432	LTCControl	HI-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
84232	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
84233	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
84234	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
84235	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	460	
84236	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	5L	
84237	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	9L	
84238	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84239	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84240	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84241	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
84242	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations	7	
84243	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84244	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84245	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84246	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps A Ø	149.0	
84247	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps B Ø	154.0	
84248	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps C Ø	157.0	
84249	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84250	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84251	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84252	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84253	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations A Ø	0	
84254	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations B Ø	0	
84255	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations C Ø	0	
84256	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations Ground	0	
84257	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
84258	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Follow-up Action Required?	n	
84259	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	General Comments		
84260	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	General Comments	Actual Counter	
84261	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
84262	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	General Comments		
84263	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
84264	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
84265	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Maintenance Operations	0	
84266	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AF	194	
84267	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AL	194	
84268	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations This Read Vac	0	
84269	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Switching Operations	0	
84270	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Unknown Operations	0	
84271	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	All Connections OK?	y	
84272	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	Follow-up Action Required?	n	
84273	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	General Comments		
84274	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	LTC Operation Checked?	y	
84275	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
84276	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
84277	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
84278	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	LTC0000350	LTCControl	638-1	LTC Control Insp	VRR Time Delay	30	Seconds
84279	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
84280	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
84281	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
84282	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
84283	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
84284	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
84285	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84286	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
84287	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
84288	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
84289	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
84290	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
84291	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
84292	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
84293	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
84294	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
84295	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
84296	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
84297	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
84298	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
84299	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84300	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
84301	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84302	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
84303	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
84304	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
84305	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
84306	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
84307	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
84308	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
84309	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
84310	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84311	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
84312	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
84313	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84314	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	General Comments		
84315	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	General Comments		
84316	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
84317	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
84318	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
84319	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
84320	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1370.52	kw
84321	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
84322	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
84323	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84324	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84325	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	6L	
84326	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
84327	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	69551	
84328	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	69545	
84329	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
84330	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
84331	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
84332	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
84333	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
84334	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
84335	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
84336	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
84337	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
84338	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
84339	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
84340	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
84341	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
84342	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
84343	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
84344	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
84345	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
84346	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
84347	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
84348	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
84349	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
84350	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
84351	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	
84352	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	111933	volts
84353	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
84354	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
84355	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
84356	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
84357	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84358	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushing Condition	Good	
84359	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	General Comments		
84360	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
84361	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
84362	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
84363	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
84364	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	General Comments		
84365	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
84366	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84367	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
84368	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84369	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
84370	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
84371	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
84372	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
84373	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	900	
84374	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5448	
84375	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
84376	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84377	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
84378	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	General Comments		
84379	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
84380	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Unknown Operations	0	
84381	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations A Ø	1	
84382	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Switching Operations	0	
84383	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations This Read Vac	0	
84384	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AL	660	
84385	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AF	660	
84386	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Maintenance Operations	0	
84387	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	General Comments		
84388	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	General Comments		
84389	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Follow-up Action Required?	n	
84390	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
84391	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations Ground	0	
84392	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations C Ø	0	
84393	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations B Ø	0	
84394	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations A Ø	0	
84395	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84396	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84397	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84398	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84399	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps C Ø	147.0	
84400	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps B Ø	152.0	
84401	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps A Ø	146.0	
84402	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84403	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84404	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84405	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations	18	
84406	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
84407	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
84408	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
84409	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
84410	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
84411	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Vegetation	None	
84412	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
84413	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84414	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
84415	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84416	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
84417	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
84418	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84419	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
84420	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
84421	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
84422	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
84423	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84424	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
84425	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations B Ø	1	
84426	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations C Ø	0	
84427	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations Ground	0	
84428	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Follow-up Action Required?	n	
84429	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Follow-up Action Required?	n	
84430	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
84431	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
84432	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
84433	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
84434	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
84435	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
84436	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
84437	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
84438	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AF	62	
84439	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Moisture and Leak Free?	y	
84440	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Maintenance Operations	0	
84441	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Heaters (All) Functioning?	y	
84442	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Grounds in Place?	y	
84443	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	General Comments		
84444	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	General Comments		
84445	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Foundation Condition	Good	
84446	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Follow-up Action Required?	n	
84447	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Follow-up Action Required?	n	
84448	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations Ground	0	
84449	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations C Ø	0	
84450	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations B Ø	0	
84451	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
84452	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84453	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84454	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84455	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84456	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84457	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84458	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84459	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84460	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84461	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushing Condition	Good	
84462	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps C Ø	130.0	
84463	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	General Comments		
84464	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps B Ø	110.0	
84465	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps A Ø	120.0	
84466	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84467	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84468	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Grounds in Place?	y	
84469	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Maintenance Operations	0	
84470	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Moisture and Leak Free?	y	
84471	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AF	158	
84472	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AL	158	
84473	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations This Read Vac	0	
84474	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Switching Operations	0	
84475	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushing Condition	Good	
84476	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps C Ø	65.0	
84477	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps B Ø	60.0	
84478	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps A Ø	68.0	
84479	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84480	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84481	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84482	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	9 Month Operations	-1	
84483	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84484	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	9 Month Operations	6	
84485	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Tank Paint Condition	Good	
84486	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Unknown Operations	0	
84487	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	9 Month Operations	2	
84488	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84489	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84490	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84491	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps A Ø	250.0	
84492	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps B Ø	225.0	
84493	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
84494	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
84495	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps C Ø	240.0	
84496	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushing Condition	Good	
84497	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84498	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Found Counter	102815	
84499	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	General Comments	5 digit counter rolled over	
84500	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Follow-up Action Required?	n	
84501	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
84502	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
84503	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84504	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84505	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84506	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84507	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84508	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps A Phase V	5.99	
84509	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps B Phase V	5.99	
84510	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84511	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
84512	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
84513	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
84514	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
84515	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
84516	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	General Comments		
84517	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
84518	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
84519	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
84520	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Trash?	y	
84521	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
84522	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
84523	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
84524	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
84525	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
84526	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84527	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	General Comments		
84528	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
84529	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
84530	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Vegetation	None	
84531	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
84532	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
84533	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	General Comments		
84534	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Follow-up Action Required?	n	
84535	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
84536	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
84537	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	General Comments	counter not working at times Mxorder created	
84538	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Found Counter	82752	
84539	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Left Counter	82752	
84540	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
84541	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Current Tap Position	6L	
84542	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Max Tap Position	2L	
84543	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Min Tap Position	6L	
84544	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Operations Since Last Insp	684	
84545	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
84546	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
84547	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
84548	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
84549	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84550	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushing Condition	Good	
84551	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps C Ø	120	
84552	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps B Ø	129	
84553	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps A Ø	167	
84554	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84555	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84556	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84557	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	9 Month Operations	0	
84558	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
84559	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
84560	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
84561	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
84562	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
84563	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	12938	
84564	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
84565	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
84566	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
84567	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
84568	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
84569	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
84570	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
84571	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
84572	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
84573	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
84574	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
84575	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
84576	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
84577	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
84578	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
84579	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
84580	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
84581	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LTC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	ok	
84582	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LTC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
84583	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
84584	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
84585	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
84586	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
84587	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
84588	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	General Comments		
84589	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
84590	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
84591	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
84592	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
84593	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
84594	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
84595	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
84596	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
84597	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
84598	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	General Comments		
84599	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
84600	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
84601	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
84602	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Foundation Condition	Good	
84603	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	General Comments		
84604	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	General Comments		
84605	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Grounds in Place?	y	
84606	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Maintenance Operations	0	
84607	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Moisture and Leak Free?	y	
84608	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AF	160	
84609	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AL	160	
84610	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations This Read Vac	2	
84611	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Switching Operations	0	
84612	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Tank Paint Condition	Good	
84613	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Unknown Operations	0	
84614	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
84615	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
84616	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
84617	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
84618	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
84619	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
84620	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
84621	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
84622	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
84623	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
84624	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
84625	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
84626	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
84627	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
84628	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84629	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
84630	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84631	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
84632	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
84633	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
84634	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
84635	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
84636	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
84637	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
84638	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
84639	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
84640	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
84641	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
84642	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
84643	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	General Comments		
84644	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84645	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
84646	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84647	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
84648	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
84649	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84650	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
84651	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
84652	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
84653	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
84654	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84655	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
84656	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
84657	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
84658	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
84659	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84660	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84661	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84662	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84663	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
84664	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
84665	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
84666	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
84667	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
84668	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
84669	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
84670	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
84671	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
84672	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations Ground	0	
84673	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Follow-up Action Required?	n	
84674	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Follow-up Action Required?	n	
84675	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Foundation Condition	Good	
84676	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84677	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Months Operations	0	
84678	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
84679	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
84680	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
84681	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps A Ø	25.0	
84682	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps B Ø	25.0	
84683	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps C Ø	25.0	
84684	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
84685	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
84686	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
84687	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Operations Since Last Insp	600	
84688	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Min Tap Position	5L	
84689	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Max Tap Position	11L	
84690	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
84691	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
84692	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
84693	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations A Ø	0	
84694	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations B Ø	0	
84695	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations C Ø	0	
84696	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations Ground	0	
84697	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
84698	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Follow-up Action Required?	n	
84699	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Current Tap Position	8L	
84700	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
84701	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Left Counter	63153	
84702	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Found Counter	63150	
84703	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
84704	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
84705	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84706	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
84707	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84708	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
84709	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
84710	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
84711	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	General Comments		
84712	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
84713	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
84714	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
84715	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84716	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushing Condition	Good	
84717	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps C Ø	50	
84718	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps B Ø	50	
84719	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	General Comments		
84720	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	General Comments		
84721	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
84722	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Maintenance Operations	0	
84723	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AF	486	
84724	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Follow-up Action Required?	n	
84725	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Follow-up Action Required?	n	
84726	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations Ground	0	
84727	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations C Ø	0	
84728	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations B Ø	0	
84729	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations A Ø	0	
84730	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84731	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84732	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84733	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84734	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C80287	BreakerVacuum	897-2511	VCB Readings	Fault Operations B Ø	0	
84735	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C80287	BreakerVacuum	897-2511	VCB Readings	Fault Operations A Ø	0	
84736	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
84737	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
84738	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
84739	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
84740	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
84741	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84742	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84743	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84744	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84745	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84746	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations A Ø	0	
84747	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations B Ø	0	
84748	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations C Ø	0	
84749	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations Ground	0	
84750	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Follow-up Action Required?	n	
84751	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
84752	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Foundation Condition	Good	
84753	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	General Comments		
84754	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	General Comments		
84755	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Grounds in Place?	y	
84756	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Maintenance Operations	0	
84757	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Moisture and Leak Free?	y	
84758	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AF	190	
84759	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AL	190	
84760	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations This Read Vac	0	
84761	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Switching Operations	0	
84762	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Tank Paint Condition	Good	
84763	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Unknown Operations	0	
84764	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	9 Month Operations	0	
84765	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84766	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84767	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84768	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps A Ø	155.0	
84769	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps B Ø	120.0	
84770	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps C Ø	140.0	
84771	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushing Condition	Good	
84772	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84773	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84774	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84775	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84776	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84777	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84778	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84779	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84780	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84781	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations A Ø	0	
84782	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations B Ø	0	
84783	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations C Ø	0	
84784	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84785	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Tank Paint Condition	Good	
84786	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Switching Operations	0	
84787	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations This Read Vac	0	
84788	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AL	151	
84789	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AF	151	
84790	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Moisture and Leak Free?	y	
84791	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Maintenance Operations	0	
84792	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Grounds in Place?	y	
84793	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	General Comments		
84794	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	General Comments		
84795	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Foundation Condition	Good	
84796	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Follow-up Action Required?	n	
84797	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Follow-up Action Required?	n	
84798	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations Ground	0	
84799	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations C Ø	0	
84800	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations B Ø	0	
84801	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations A Ø	0	
84802	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84803	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84804	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84805	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84806	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
84807	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
84808	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84809	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
84810	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
84811	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84812	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	General Comments		
84813	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	General Comments		
84814	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	General Comments		
84815	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	General Comments		
84816	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
84817	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Follow-up Action Required?	n	
84818	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
84819	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84820	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84821	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84822	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
84823	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
84824	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
84825	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
84826	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84827	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84828	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84829	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84830	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84831	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84832	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84833	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84834	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84835	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
84836	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
84837	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
84838	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
84839	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	490.32	kw
84840	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
84841	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
84842	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
84843	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
84844	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
84845	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
84846	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
84847	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
84848	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	General Comments		
84849	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
84850	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
84851	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
84852	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
84853	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
84854	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
84855	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
84856	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
84857	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
84858	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
84859	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
84860	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
84861	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
84862	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
84863	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
84864	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
84865	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
84866	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
84867	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	3223	
84868	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	322	
84869	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
84870	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
84871	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
84872	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
84873	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
84874	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
84875	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
84876	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
84877	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Left Counter	2819	
84878	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AL	62	
84879	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84880	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84881	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84882	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84883	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84884	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84885	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
84886	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
84887	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
84888	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
84889	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
84890	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
84891	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps A Ø	50	
84892	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
84893	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
84894	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
84895	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	9 Month Operations	0	
84896	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Unknown Operations	0	
84897	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Tank Paint Condition	Good	
84898	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Switching Operations	0	
84899	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations This Read Vac	0	
84900	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AL	152	
84901	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AF	152	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84902	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Moisture and Leak Free?	y	
84903	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Maintenance Operations	0	
84904	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Grounds in Place?	y	
84905	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	General Comments		
84906	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	General Comments		
84907	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Foundation Condition	Good	
84908	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Follow-up Action Required?	n	
84909	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Follow-up Action Required?	n	
84910	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations Ground	0	
84911	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations C Ø	0	
84912	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations B Ø	0	
84913	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations A Ø	0	
84914	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
84915	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	General Comments		
84916	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
84917	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
84918	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
84919	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
84920	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AL	486	
84921	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations This Read AM	0	
84922	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Switching Operations	0	
84923	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Unknown Operations	0	
84924	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84925	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Unknown Operations	0	
84926	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Tank Paint Condition	Good	
84927	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Switching Operations	0	
84928	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
84929	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations This Read Vac	0	
84930	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84931	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
84932	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
84933	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
84934	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
84935	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
84936	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Operations Since Last Insp	4058	
84937	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Min Tap Position	1L	
84938	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Max Tap Position	10R	
84939	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
84940	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Current Tap Position	1R	
84941	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
84942	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
84943	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps C Ø	120.0	
84944	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps B Ø	100.0	
84945	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps A Ø	165.0	
84946	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty C Ph V	16.82	%
84947	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty B Ph V	16.82	%
84948	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty A Ph V	15.36	%
84949	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	9 Month Operations	5	
84950	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
84951	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84952	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84953	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
84954	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
84955	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
84956	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
84957	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
84958	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
84959	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
84960	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
84961	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
84962	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
84963	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
84964	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
84965	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
84966	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84967	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
84968	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84969	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84970	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
84971	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
84972	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	C0251	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
84973	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTC000053	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
84974	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTC000053	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
84975	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTC000053	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
84976	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTC000053	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
84977	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
84978	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
84979	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
84980	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	LTCC000053	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
84981	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	LTC Totalizer Reading	8542.80	kw
84982	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
84983	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	General Comments		
84984	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	General Comments		
84985	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
84986	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
84987	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Follow-up Action Required?	n	
84988	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
84989	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
84990	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
84991	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
84992	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
84993	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
84994	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
84995	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
84996	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
84997	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Maintenance Operations	0	
84998	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AF	302	
84999	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
85000	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
85001	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AL	302	
85002	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations This Read AM	0	
85003	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Switching Operations	0	
85004	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Unknown Operations	0	
85005	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Unknown Operations	0	
85006	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Switching Operations	0	
85007	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations This Read AM	0	
85008	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AL	421	
85009	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AF	421	
85010	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Maintenance Operations	0	
85011	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	General Comments	Actual Counter	
85012	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
85013	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
85014	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
85015	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	General Comments		
85016	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
85017	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
85018	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
85019	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
85020	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
85021	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
85022	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
85023	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
85024	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
85025	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
85026	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
85027	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
85028	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
85029	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
85030	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
85031	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
85032	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
85033	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
85034	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
85035	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
85036	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
85037	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85038	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps C Ø	0.0	
85039	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
85040	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
85041	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
85042	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Present	15	*C
85043	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
85044	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
85045	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
85046	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
85047	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
85048	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
85049	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
85050	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
85051	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
85052	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
85053	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
85054	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
85055	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85056	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85057	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85058	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85059	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85060	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85061	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85062	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85063	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	General Comments		
85064	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85065	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85066	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Vegetation	None	
85067	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85068	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
85069	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
85070	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
85071	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
85072	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations Ground	0	
85073	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
85074	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
85075	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
85076	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.44	%
85077	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	4.76	%
85078	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	4.08	%
85079	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
85080	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	25.0	
85081	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	15.0	
85082	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
85083	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
85084	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
85085	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
85086	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	General Comments		
85087	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	General Comments		
85088	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Max	19	°C
85089	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Reading	4746	
85090	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
85091	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85092	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85093	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
85094	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85095	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85096	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85097	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85098	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Present	24	°C
85099	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Max	30	°C
85100	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
85101	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
85102	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
85103	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
85104	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
85105	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Operations Since Last Insp	982	
85106	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
85107	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Min Tap Position	8L	
85108	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Max Tap Position	1R	
85109	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Current Tap Position	5L	
85110	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
85111	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Left Counter	33656	
85112	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Found Counter	33656	
85113	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	General Comments		
85114	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AL	306	
85115	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
85116	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
85117	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
85118	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
85119	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85120	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
85121	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
85122	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
85123	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
85124	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
85125	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
85126	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85127	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
85128	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
85129	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
85130	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
85131	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
85132	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
85133	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	General Comments		
85134	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	General Comments		
85135	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
85136	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Follow-up Action Required?	n	
85137	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
85138	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
85139	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85140	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85141	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85142	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85143	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85144	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	General Comments		
85145	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
85146	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
85147	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
85148	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85149	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
85150	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Vegetation	None	
85151	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85152	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
85153	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85154	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	General Comments		
85155	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Grounds in Place?	y	
85156	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
85157	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
85158	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
85159	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85160	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
85161	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85162	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
85163	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85164	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
85165	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85166	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85167	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
85168	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	General Comments	ok	
85169	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
85170	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations This Read Vac	0	
85171	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
85172	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Tank Paint Condition	Good	
85173	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
85174	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
85175	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	General Comments		
85176	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
85177	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	General Comments		
85178	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
85179	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
85180	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
85181	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
85182	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	General Comments		
85183	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
85184	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
85185	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
85186	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
85187	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
85188	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85189	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85190	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85191	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85192	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85193	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85194	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85195	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	General Comments		
85196	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
85197	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85198	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85199	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Vegetation	None	
85200	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85201	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
85202	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
85203	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
85204	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
85205	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
85206	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
85207	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
85208	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
85209	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
85210	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps C Ø	323.0	
85211	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps B Ø	314.0	
85212	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps A Ø	315.0	
85213	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
85214	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
85215	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
85216	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Months Operations	0	
85217	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85218	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85219	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
85220	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
85221	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
85222	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
85223	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
85224	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
85225	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
85226	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	General Comments		
85227	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
85228	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
85229	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
85230	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
85231	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
85232	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
85233	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
85234	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
85235	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
85236	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
85237	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
85238	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
85239	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	General Comments		
85240	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
85241	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
85242	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AF	306	
85243	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
85244	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	129	
85245	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	129	
85246	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0184	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
85247	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushing Condition	Good	
85248	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85249	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
85250	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
85251	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
85252	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
85253	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
85254	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
85255	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
85256	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
85257	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
85258	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
85259	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
85260	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
85261	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
85262	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
85263	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
85264	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
85265	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
85266	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
85267	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
85268	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
85269	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
85270	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
85271	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85272	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Unknown Operations	0	
85273	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Switching Operations	0	
85274	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations This Read AM	0	
85275	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Operations Since Last Insp	581	
85276	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
85277	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	10	*C
85278	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Min Tap Position	10L	
85279	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Max Tap Position	6L	
85280	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
85281	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
85282	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
85283	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Max	47	*C
85284	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Present	20	*C
85285	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
85286	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
85287	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85288	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
85289	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
85290	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
85291	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
85292	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
85293	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
85294	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	General Comments	chu-con replacing barb wire today	
85295	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
85296	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Ambient Temp	15	*F
85297	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
85298	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85299	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85300	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85301	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85302	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85303	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85304	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85305	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85306	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	General Comments	Mxorder made for bad light.	
85307	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
85308	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
85309	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
85310	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
85311	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
85312	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
85313	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
85314	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
85315	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
85316	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
85317	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
85318	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	General Comments		
85319	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
85320	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85321	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85322	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85323	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85324	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85325	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85326	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85327	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85328	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	General Comments		
85329	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85330	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85331	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Vegetation	None	
85332	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
85333	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
85334	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
85335	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
85336	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
85337	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
85338	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
85339	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
85340	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85341	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85342	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85343	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85344	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85345	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85346	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85347	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85348	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85349	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85350	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
85351	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Ambient Temp	23	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85352	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85353	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85354	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
85355	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
85356	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85357	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Follow-up Action Required?	n	
85358	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
85359	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
85360	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85361	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
85362	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	General Comments		
85363	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
85364	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Max	55	°C
85365	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Present	20	°C
85366	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85367	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
85368	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
85369	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85370	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85371	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85372	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85373	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85374	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
85375	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
85376	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85377	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
85378	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Follow-up Action Required?	n	
85379	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
85380	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
85381	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Foundation Condition	Good	
85382	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
85383	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
85384	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	General Comments		
85385	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
85386	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
85387	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
85388	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
85389	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
85390	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	9 Month Operations	-1	
85391	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
85392	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
85393	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
85394	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85395	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85396	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85397	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85398	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85399	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
85400	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
85401	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Left Counter	13724	
85402	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Found Counter	13724	
85403	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	General Comments		
85404	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	General Comments		
85405	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
85406	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Follow-up Action Required?	n	
85407	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85408	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
85409	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85410	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
85411	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85412	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
85413	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
85414	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85415	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85416	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85417	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85418	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85419	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85420	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85421	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85422	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Grounds in Place?	y	
85423	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	General Comments		
85424	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Foundation Condition	Good	
85425	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Follow-up Action Required?	n	
85426	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85427	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
85428	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
85429	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
85430	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
85431	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85432	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushing Condition	Good	
85433	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
85434	11/13/2019 13:29	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
85435	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Months Operations	6	
85436	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
85437	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
85438	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85439	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85440	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
85441	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Reading	1.5772	
85442	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Max	70	*C
85443	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Present	45	*C
85444	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
85445	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
85446	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Follow-up Action Required?	n	
85447	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Foundation Condition	Good	
85448	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
85449	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps A Ø	0.0	
85450	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps B Ø	0.0	
85451	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
85452	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
85453	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
85454	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
85455	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
85456	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
85457	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Foundation Condition	Good	
85458	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
85459	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
85460	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
85461	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
85462	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Foundation Condition OK?	y	
85463	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
85464	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
85465	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	FE000490	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
85466	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	General Comments		
85467	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
85468	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
85469	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
85470	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
85471	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
85472	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
85473	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
85474	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
85475	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
85476	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85477	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
85478	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
85479	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85480	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85481	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
85482	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
85483	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85484	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Max	55	*C
85485	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Present	20	*C
85486	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85487	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
85488	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Tank Paint Condition	Good	
85489	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AL	758	
85490	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AF	758	
85491	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Maintenance Operations	0	
85492	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	General Comments		
85493	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	General Comments		
85494	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Follow-up Action Required?	n	
85495	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85496	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85497	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	General Comments		
85498	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	General Comments		
85499	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85500	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	LTC Totalizer Reading	22711.68	kw
85501	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
85502	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
85503	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Max	35	°C
85504	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Present	25	°C
85505	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
85506	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
85507	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85508	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85509	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85510	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85511	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
85512	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Follow-up Action Required?	n	
85513	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations Ground	0	
85514	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations C Ø	0	
85515	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations B Ø	0	
85516	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations A Ø	0	
85517	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
85518	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
85519	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
85520	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
85521	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps C Ø	9.0	
85522	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps B Ø	8.0	
85523	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps A Ø	6.0	
85524	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
85525	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
85526	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
85527	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Months Operations	27	
85528	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
85529	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Moisture and Leak Free?	y	
85530	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
85531	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Current Tap Position	7L	
85532	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
85533	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85534	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Vegetation	None	
85535	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85536	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85537	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
85538	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	General Comments		
85539	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85540	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85541	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
85542	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85543	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85544	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85545	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85546	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
85547	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
85548	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
85549	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
85550	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85551	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85552	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85553	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85554	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
85555	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85556	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	General Comments		
85557	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	General Comments		
85558	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
85559	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
85560	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	9.72	kw
85561	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
85562	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
85563	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85564	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
85565	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85566	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85567	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
85568	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
85569	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
85570	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
85571	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
85572	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
85573	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
85574	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
85575	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
85576	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85577	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85578	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
85579	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
85580	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
85581	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
85582	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
85583	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
85584	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
85585	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
85586	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
85587	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
85588	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
85589	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	General Comments		
85590	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
85591	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
85592	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Foundation Condition	Good	
85593	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
85594	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
85595	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85596	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
85597	11/13/2019 13:15	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0162	
85598	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
85599	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
85600	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
85601	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
85602	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
85603	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
85604	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
85605	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
85606	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
85607	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
85608	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85609	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
85610	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
85611	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
85612	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
85613	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
85614	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
85615	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
85616	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
85617	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85618	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	LTC Totalizer Reading	20234.88	kw
85619	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85620	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
85621	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
85622	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	90	°C
85623	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
85624	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85625	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	General Comments		
85626	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
85627	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
85628	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
85629	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
85630	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
85631	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	General Comments		
85632	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
85633	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BAT000434	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
85634	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85635	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85636	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
85637	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
85638	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
85639	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	General Comments		
85640	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
85641	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
85642	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
85643	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
85644	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	All Connections OK?	y	
85645	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	Follow-up Action Required?	n	
85646	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	General Comments		
85647	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	LTC Operation Checked?	y	
85648	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
85649	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
85650	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
85651	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	LTC000754	LTCControl	585-1	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
85652	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
85653	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
85654	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
85655	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
85656	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85657	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
85658	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
85659	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	15.0	
85660	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
85661	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
85662	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
85663	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
85664	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
85665	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85666	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85667	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
85668	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
85669	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
85670	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85671	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85672	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	General Comments	gauges will not reset and liquid temp gauge glass is broken	
85673	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
85674	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85675	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85676	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
85677	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
85678	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
85679	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
85680	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
85681	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
85682	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85683	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
85684	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
85685	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85686	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85687	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85688	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85689	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85690	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
85691	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
85692	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
85693	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
85694	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
85695	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1279	
85696	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
85697	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
85698	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
85699	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
85700	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	3243	
85701	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	3243	
85702	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
85703	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
85704	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
85705	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
85706	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
85707	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
85708	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
85709	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
85710	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
85711	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
85712	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Paint Condition	Good	
85713	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Equipment Properly Labeled?	y	
85714	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Follow-up Action Required?	n	
85715	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Foundation Condition	Good	
85716	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	General Comments		
85717	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Grounds in Place?	y	
85718	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Moisture and Leak Free?	y	
85719	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Tank Paint Condition	Good	
85720	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations	2	
85721	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty A Ph V	0	%
85722	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty B Ph V	0	%
85723	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty C Ph V	0	%
85724	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps A Ø	75	
85725	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps B Ø	90	
85726	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps C Ø	100	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85727	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushing Condition	Good	
85728	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85729	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
85730	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
85731	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
85732	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
85733	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
85734	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
85735	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
85736	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
85737	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
85738	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
85739	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
85740	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
85741	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
85742	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
85743	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
85744	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
85745	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
85746	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	85	*C
85747	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
85748	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85749	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85750	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments		
85751	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
85752	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85753	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85754	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
85755	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	General Comments	winding temp gauge max is stuck and will not reset	
85756	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85757	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85758	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
85759	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	*C
85760	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
85761	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
85762	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
85763	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
85764	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
85765	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
85766	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
85767	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
85768	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
85769	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	190.0	
85770	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	250.0	
85771	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
85772	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
85773	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	190.0	
85774	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
85775	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
85776	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
85777	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
85778	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
85779	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	*C
85780	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	*C
85781	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	*C
85782	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	*C
85783	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	*C
85784	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	*C
85785	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
85786	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
85787	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85788	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85789	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
85790	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85791	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85792	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	General Comments		
85793	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	General Comments		
85794	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85795	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85796	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Follow-up Action Required?	n	
85797	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85798	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85799	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85800	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85801	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85802	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85803	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
85804	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
85805	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	General Comments		
85806	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
85807	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Operations Counter	79	
85808	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
85809	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
85810	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
85811	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
85812	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Trash?	y	
85813	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
85814	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
85815	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
85816	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
85817	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
85818	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
85819	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	General Comments		
85820	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
85821	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
85822	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Vegetation	None	
85823	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
85824	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
85825	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
85826	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Present	45	*C
85827	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Max	45	*C
85828	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Reading	1.4052	
85829	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
85830	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85831	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85832	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
85833	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85834	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85835	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85836	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85837	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Present	50	*C
85838	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Max	50	*C
85839	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
85840	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	General Comments		
85841	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
85842	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Found Counter	586080	
85843	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Left Counter	586080	
85844	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
85845	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
85846	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
85847	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
85848	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
85849	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
85850	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
85851	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85852	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85853	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85854	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Foundation Condition	Good	
85855	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Follow-up Action Required?	n	
85856	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
85857	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
85858	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
85859	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	General Comments		
85860	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Grounds in Place?	y	
85861	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	PT Free of Leaks?	y	
85862	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Oil Level	Good	
85863	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
85864	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
85865	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
85866	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
85867	11/13/2019 16:58	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Amps A Ø	44.1	
85868	11/13/2019 10:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Paint Condition	Good	
85869	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
85870	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
85871	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Reading	.6786	
85872	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
85873	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85874	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85875	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
85876	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85877	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85878	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85879	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Present	15	°C
85880	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Max	48	°C
85881	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
85882	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85883	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	LTC Totalizer Reading	1628.64	kw
85884	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85885	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
85886	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	General Comments		
85887	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
85888	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
85889	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
85890	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
85891	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
85892	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
85893	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
85894	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
85895	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
85896	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
85897	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
85898	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
85899	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85900	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
85901	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
85902	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Reading	.7152	
85903	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
85904	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
85905	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
85906	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
85907	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
85908	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
85909	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
85910	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
85911	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Present	30	°C
85912	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Max	45	°C
85913	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
85914	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
85915	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	LTC Totalizer Reading	12873.60	kw
85916	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
85917	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
85918	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
85919	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
85920	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
85921	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
85922	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
85923	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
85924	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
85925	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
85926	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
85927	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
85928	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
85929	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
85930	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
85931	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
85932	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
85933	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85934	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
85935	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
85936	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
85937	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
85938	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
85939	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
85940	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
85941	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
85942	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
85943	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
85944	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
85945	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
85946	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	General Comments		
85947	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
85948	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
85949	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Foundation Condition	Good	
85950	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
85951	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
85952	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
85953	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
85954	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
85955	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
85956	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
85957	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
85958	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BCH000593	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
85959	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
85960	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
85961	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
85962	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85963	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85964	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85965	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushing Condition	Good	
85966	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85967	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
85968	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
85969	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
85970	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
85971	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
85972	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
85973	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
85974	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
85975	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
85976	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
85977	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
85978	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
85979	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
85980	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85981	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85982	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85983	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
85984	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
85985	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Follow-up Action Required?	n	
85986	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85987	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
85988	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
85989	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85990	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
85991	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
85992	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
85993	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
85994	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
85995	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
85996	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
85997	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
85998	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
85999	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
86000	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
86001	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
86002	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
86003	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
86004	11/13/2019 14:43	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
86005	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
86006	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
86007	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
86008	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
86009	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
86010	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
86011	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
86012	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
86013	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
86014	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	springcharged
86015	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
86016	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
86017	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.		springcharged
86018	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
86019	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	47	
86020	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
86021	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
86022	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
86023	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
86024	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
86025	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
86026	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86027	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
86028	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
86029	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
86030	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
86031	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
86032	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
86033	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	30.0	VDC
86034	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
86035	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	BAT001315	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
86036	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
86037	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	47	
86038	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
86039	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
86040	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
86041	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
86042	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	CB0221	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
86043	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Foundation Condition	Good	
86044	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Follow-up Action Required?	n	
86045	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Follow-up Action Required?	n	
86046	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
86047	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
86048	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations Ground	0	
86049	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations C Ø	0	
86050	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations B Ø	0	
86051	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations A Ø	0	
86052	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86053	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86054	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86055	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
86056	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	General Comments		
86057	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
86058	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
86059	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
86060	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
86061	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
86062	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
86063	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
86064	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
86065	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
86066	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
86067	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
86068	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	General Comments		
86069	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
86070	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
86071	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
86072	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86073	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86074	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
86075	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
86076	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86077	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86078	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86079	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86080	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86081	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86082	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushing Condition	Good	
86083	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	0	
86084	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	0	
86085	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations This Read AM	0	
86086	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	0	
86087	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	661	
86088	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Maintenance Operations	0	
86089	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	General Comments	A and C phase not showing current.	
86090	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	General Comments		
86091	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Follow-up Action Required?	y	
86092	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Follow-up Action Required?	n	
86093	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
86094	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
86095	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
86096	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52708	
86097	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86098	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86099	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Leaks	None	
86100	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
86101	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86102	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations C Ø	0	
86103	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations B Ø	0	
86104	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations A Ø	0	
86105	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
86106	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
86107	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86108	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86109	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86110	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps A Phase V	0	
86111	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LTC000598	LTCControl	HI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
86112	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Follow-up Action Required?	n	
86113	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
86114	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	General Comments		
86115	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	General Comments		
86116	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Found Counter	5869	
86117	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Left Counter	5874	
86118	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
86119	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Current Tap Position	5L	
86120	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Max Tap Position	9L	
86121	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Min Tap Position	2L	
86122	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Operations Since Last Insp	890	
86123	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
86124	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
86125	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
86126	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
86127	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LTC000598	LTCControl	HI-TRANS 2	LTC Control Insp	General Comments	ok	
86128	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps B Phase V	0	
86129	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps C Phase V	0	
86130	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations A Ø	0	
86131	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations B Ø	0	
86132	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations C Ø	0	
86133	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations Ground	0	
86134	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Follow-up Action Required?	n	
86135	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Follow-up Action Required?	n	
86136	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Foundation Condition	Good	
86137	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	General Comments		
86138	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
86139	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
86140	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	General Comments		
86141	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Grounds in Place?	y	
86142	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Maintenance Operations	0	
86143	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Moisture and Leak Free?	y	
86144	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AF	191	
86145	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AL	191	
86146	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations This Read Vac	0	
86147	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Switching Operations	0	
86148	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Tank Paint Condition	Good	
86149	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Unknown Operations	0	
86150	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Unknown Operations	0	
86151	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Tank Paint Condition	Good	
86152	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Switching Operations	0	
86153	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations This Read Vac	0	
86154	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AL	152	
86155	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AF	152	
86156	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Moisture and Leak Free?	y	
86157	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Maintenance Operations	0	
86158	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Grounds in Place?	y	
86159	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
86160	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86161	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86162	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86163	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86164	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
86165	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86166	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
86167	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
86168	11/12/2019 9:37	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86169	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	General Comments		
86170	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	General Comments		
86171	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
86172	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
86173	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
86174	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86175	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86176	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86177	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Switching Operations	0	
86178	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations This Read Vac	0	
86179	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AL	63	
86180	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AF	63	
86181	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Unknown Operations	0	
86182	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Tank Paint Condition	Good	
86183	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Switching Operations	0	
86184	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
86185	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations This Read Vac	0	
86186	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AL	170	
86187	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AF	170	
86188	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Moisture and Leak Free?	y	
86189	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Maintenance Operations	0	
86190	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Heaters (All) Functioning?	y	
86191	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Grounds in Place?	y	
86192	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	General Comments		
86193	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	General Comments		
86194	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Foundation Condition	Good	
86195	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
86196	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	0	
86197	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Maintenance Operations	0	
86198	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	General Comments		
86199	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Follow-up Action Required?	n	
86200	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations Ground	0	
86201	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations C Ø	0	
86202	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations This Read Vac	3	
86203	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	647	
86204	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	647	
86205	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	0	
86206	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
86207	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments		
86208	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	
86209	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
86210	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
86211	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	9 Month Operations	0	
86212	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86213	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86214	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86215	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps A Ø	185.0	
86216	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps B Ø	175.0	
86217	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	0	
86218	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
86219	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	3	
86220	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86221	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86222	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
86223	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86224	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	224.0	
86225	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	228.0	
86226	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	248.0	
86227	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86228	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86229	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86230	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	8	
86231	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps C Ø	130.0	
86232	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushing Condition	Good	
86233	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86234	11/13/2019 12:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86235	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
86236	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
86237	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps C Ø	0.0	
86238	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
86239	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
86240	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	.9550	
86241	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
86242	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	52	*C
86243	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	55	*C
86244	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	9168.00	kw
86245	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments		
86246	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
86247	8/5/2019 13:39	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
86248	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
86249	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
86250	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps B Ø	220.0	
86251	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86252	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
86253	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
86254	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
86255	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Months Operations	0	
86256	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps C Ø	127	
86257	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps B Ø	132	
86258	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps A Ø	142	
86259	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86260	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86261	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86262	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	9 Month Operations	0	
86263	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
86264	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
86265	11/13/2019 11:17	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
86266	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Unknown Operations	0	
86267	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
86268	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
86269	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
86270	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
86271	11/13/2019 15:39	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
86272	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
86273	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
86274	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
86275	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	General Comments		
86276	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen	
86277	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
86278	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
86279	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
86280	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
86281	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
86282	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
86283	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
86284	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
86285	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
86286	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
86287	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
86288	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
86289	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
86290	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
86291	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
86292	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
86293	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
86294	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
86295	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
86296	11/13/2019 13:50	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
86297	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
86298	11/13/2019 9:50	Distribution	Yellow Rock North Quarterly Inspection	R0347	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86299	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
86300	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
86301	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
86302	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
86303	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
86304	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
86305	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
86306	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
86307	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
86308	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
86309	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
86310	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
86311	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
86312	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
86313	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
86314	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	1	
86315	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	1	
86316	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	
86317	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
86318	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	
86319	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
86320	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
86321	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments		
86322	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments	A and B phase IOC	
86323	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	0	
86324	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	691	
86325	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	691	
86326	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86327	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
86328	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Unknown Operations	0	
86329	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Switching Operations	0	
86330	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations This Read AM	0	
86331	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AL	622	
86332	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AF	622	
86333	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Maintenance Operations	0	
86334	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
86335	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	General Comments	VC change no target	
86336	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	General Comments		
86337	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Follow-up Action Required?	n	
86338	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
86339	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations Ground	0	
86340	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations C Ø	0	
86341	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations B Ø	0	
86342	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations A Ø	0	
86343	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
86344	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
86345	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
86346	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
86347	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps C Ø	180.0	
86348	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps B Ø	150.0	
86349	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps A Ø	110.0	
86350	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
86351	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
86352	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	27	*F
86353	11/14/2019 8:15	Distribution	Lagrange East Quarterly Inspection	BAT000579	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
86354	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
86355	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
86356	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
86357	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
86358	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
86359	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
86360	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
86361	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
86362	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
86363	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
86364	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
86365	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
86366	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
86367	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
86368	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
86369	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	23	*C
86370	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	*C
86371	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
86372	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
86373	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
86374	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
86375	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
86376	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
86377	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
86378	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
86379	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
86380	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
86381	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
86382	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
86383	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
86384	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
86385	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
86386	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
86387	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
86388	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
86389	11/13/2019 13:20	Distribution	Lagrange Penal Quarterly Inspection	BAT000590	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
86390	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
86391	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
86392	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
86393	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
86394	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
86395	11/13/2019 11:54	Distribution	Bear Track Quarterly Inspection	T0496	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
86396	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	5	
86397	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
86398	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
86399	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
86400	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	200.0	
86401	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	100.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
86402	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	200.0	
86403	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
86404	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
86405	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
86406	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
86407	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	369	
86408	11/13/2019 13:31	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	369	
86409	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
86410	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
86411	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
86412	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
86413	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
86414	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
86415	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
86416	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
86417	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
86418	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
86419	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
86420	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
86421	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
86422	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
86423	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
86424	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
86425	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
86426	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
86427	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
86428	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
86429	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
86430	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
86431	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	General Comments		
86432	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
86433	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
86434	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
86435	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
86436	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
86437	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	9 Months Operations	0	
86438	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
86439	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
86440	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
86441	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Operations Counter	164	
86442	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
86443	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	General Comments		
86444	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
86445	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
86446	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
86447	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
86448	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
86449	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
86450	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
86451	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
86452	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	General Comments		
86453	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
86454	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
86455	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86456	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
86457	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations This Read AM	2	
86458	11/18/2019 12:25	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86459	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	0	
86460	11/13/2019 16:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
86461	11/13/2019 14:44	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
86462	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
86463	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
86464	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
86465	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
86466	11/14/2019 6:23	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
86467	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps A Ø	0.0	
86468	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86469	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps B Ø	0.0	
86470	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Bushing Condition	Good	
86471	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
86472	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps C Ø	0.0	
86473	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps C Ø	202.0	
86474	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
86475	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86476	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86477	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86478	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86479	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86480	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations B Ø	0	
86481	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations A Ø	0	
86482	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86483	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86484	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86485	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86486	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	General Comments		
86487	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations A Ø	0	
86488	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86489	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86490	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
86491	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86492	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86493	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86494	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations Ground	0	
86495	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Follow-up Action Required?	n	
86496	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Follow-up Action Required?	n	
86497	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps B Ø	27.0	
86498	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps C Ø	20.0	
86499	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
86500	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
86501	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	853	
86502	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
86503	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	10L	
86504	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	4L	
86505	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations C Ø	0	
86506	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations B Ø	0	
86507	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86508	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
86509	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Follow-up Action Required?	n	
86510	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Foundation Condition	Good	
86511	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	General Comments		
86512	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	General Comments		
86513	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Grounds in Place?	y	
86514	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Maintenance Operations	0	
86515	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86516	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86517	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86518	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
86519	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Max Tap Position	16L	
86520	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Foundation Condition	Good	
86521	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	General Comments		
86522	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
86523	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	5L	
86524	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
86525	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	General Comments		
86526	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Grounds in Place?	y	
86527	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Maintenance Operations	0	
86528	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Moisture and Leak Free?	y	
86529	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86530	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AF	228	
86531	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	95523	
86532	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	95523	
86533	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
86534	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	General Comments		
86535	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
86536	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Follow-up Action Required?	n	
86537	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushing Condition	Good	
86538	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86539	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86540	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86541	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86542	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86543	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86544	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations A Ø	0	
86545	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86546	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86547	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86548	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86549	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86550	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86551	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86552	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86553	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86554	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86555	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations This Read Vac	0	
86556	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86557	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86558	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AL	124	
86559	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AF	124	
86560	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Moisture and Leak Free?	y	
86561	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86562	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86563	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushing Condition	Good	
86564	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	9 Month Operations	1	
86565	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Follow-up Action Required?	n	
86566	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps C Ø	15.0	
86567	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps B Ø	7.0	
86568	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps A Ø	15.0	
86569	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86570	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations Ground	0	
86571	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations C Ø	0	
86572	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations B Ø	0	
86573	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations A Ø	0	
86574	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86575	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86576	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
86577	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86578	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AL	228	
86579	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Foundation Condition	Good	
86580	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Follow-up Action Required?	n	
86581	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Follow-up Action Required?	n	
86582	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations Ground	0	
86583	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations C Ø	0	
86584	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations B Ø	0	
86585	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations A Ø	0	
86586	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86587	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86588	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86589	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86590	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86591	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86592	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations C Ø	0	
86593	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations Ground	0	
86594	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Unknown Operations	0	
86595	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Tank Paint Condition	Good	
86596	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Switching Operations	0	
86597	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Moisture and Leak Free?	y	
86598	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86599	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86600	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AF	201	
86601	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AL	201	
86602	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations	5	
86603	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Unknown Operations	0	
86604	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Tank Paint Condition	Good	
86605	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Switching Operations	6	
86606	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Follow-up Action Required?	n	
86607	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Foundation Condition	Good	
86608	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	General Comments		
86609	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	General Comments		
86610	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Grounds in Place?	y	
86611	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Maintenance Operations	0	
86612	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Follow-up Action Required?	n	
86613	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Follow-up Action Required?	n	
86614	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Foundation Condition	Good	
86615	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	General Comments		
86616	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	General Comments		
86617	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Grounds in Place?	y	
86618	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC0000576	LTCControl	TE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
86619	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC0000576	LTCControl	TE-TRANS 1	LTC Control Insp	General Comments		
86620	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC0000576	LTCControl	TE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
86621	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Maintenance Operations	0	
86622	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Moisture and Leak Free?	y	
86623	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AF	209	
86624	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AL	209	
86625	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations This Read Vac	0	
86626	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86627	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
86628	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AF	156	
86629	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Tank Paint Condition	Good	
86630	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AL	156	
86631	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations This Read Vac	5	
86632	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
86633	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations This Read Vac	6	
86634	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86635	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86636	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86637	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
86638	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	General Comments		
86639	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	General Comments		
86640	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations Ground	0	
86641	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations C Ø	0	
86642	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86643	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	1	
86644	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	1	
86645	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations B Ø	0	
86646	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations A Ø	0	
86647	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86648	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86649	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86650	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86651	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86652	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86653	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
86654	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
86655	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Follow-up Action Required?	n	
86656	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
86657	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Foundation Condition	Good	
86658	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	General Comments		
86659	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
86660	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Grounds in Place?	y	
86661	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86662	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86663	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86664	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations B Ø	0	
86665	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations A Ø	0	
86666	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86667	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
86668	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
86669	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Moisture and Leak Free?	y	
86670	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	202	
86671	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	202	
86672	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations This Read Vac	3	
86673	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	1	
86674	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Tank Paint Condition	Good	
86675	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
86676	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86677	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86678	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
86679	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
86680	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
86681	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
86682	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
86683	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
86684	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
86685	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
86686	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
86687	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
86688	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
86689	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
86690	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86691	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86692	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86693	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86694	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushing Condition	Good	
86695	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86696	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86697	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86698	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86699	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
86700	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Leaks	None	
86701	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
86702	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86703	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Regulator As Left Counter	46831	
86704	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
86705	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
86706	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Oil Level	Good	
86707	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86708	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86709	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Min Tap Position	3L	
86710	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Max Tap Position	3R	
86711	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Grounds in Place?	y	
86712	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	General Comments		
86713	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86714	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Foundation Condition	Good	
86715	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
86716	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86717	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Current Tap Position	1R	
86718	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86719	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86720	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
86721	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
86722	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86723	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86724	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86725	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86726	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushing Condition	Good	
86727	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Follow-up Action Required?	n	
86728	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	General Comments		
86729	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	General Comments		
86730	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Maintenance Operations	0	
86731	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AF	296	
86732	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AL	296	
86733	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations This Read Vac	0	
86734	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Switching Operations	0	
86735	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Unknown Operations	0	
86736	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Follow-up Action Required?	n	
86737	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations Ground	0	
86738	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations C Ø	0	
86739	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Follow-up Action Required?	n	
86740	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps C Ø	110.0	
86741	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps B Ø	128.0	
86742	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps A Ø	202.0	
86743	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86744	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86745	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86746	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations	7	
86747	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
86748	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
86749	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Leaks	None	
86750	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86751	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86752	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Regulator As Left Counter	122520	
86753	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
86754	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
86755	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
86756	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86757	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86758	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
86759	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
86760	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86761	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86762	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86763	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
86764	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
86765	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86766	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	General Comments		
86767	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
86768	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86769	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86770	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86771	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86772	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
86773	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86774	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushing Condition	Good	
86775	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps C Ø	206.0	
86776	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
86777	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86778	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86779	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86780	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86781	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
86782	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
86783	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
86784	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
86785	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	General Comments		
86786	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86787	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
86788	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
86789	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86790	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
86791	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
86792	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	General Comments		
86793	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	General Comments		
86794	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
86795	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
86796	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
86797	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
86798	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2888.64	kw
86799	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
86800	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
86801	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
86802	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
86803	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Vegetation	None	
86804	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
86805	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
86806	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	General Comments		
86807	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
86808	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
86809	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
86810	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
86811	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
86812	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
86813	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Trash?	y	
86814	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
86815	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
86816	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
86817	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
86818	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
86819	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
86820	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86821	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86822	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
86823	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
86824	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
86825	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
86826	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
86827	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
86828	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
86829	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Leaks	None	
86830	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86831	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86832	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Regulator As Left Counter	206344	
86833	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2036	
86834	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
86835	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
86836	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
86837	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86838	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86839	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
86840	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushing Condition	Good	
86841	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
86842	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
86843	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
86844	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
86845	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
86846	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
86847	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
86848	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86849	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86850	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
86851	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86852	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
86853	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180.0	
86854	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	190.0	
86855	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	200.0	
86856	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86857	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
86858	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
86859	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86860	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	General Comments		
86861	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
86862	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
86863	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Min Tap Position	2L	
86864	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86865	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86866	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
86867	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
86868	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
86869	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Regulator As Left Counter	131651	
86870	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86871	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86872	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Leaks	None	
86873	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
86874	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
86875	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86876	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86877	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86878	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86879	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
86880	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86881	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
86882	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
86883	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86884	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	General Comments		
86885	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
86886	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
86887	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
86888	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86889	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86890	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
86891	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
86892	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
86893	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
86894	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
86895	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
86896	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Current Tap Position	2R	
86897	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
86898	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
86899	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
86900	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
86901	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
86902	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
86903	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
86904	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	215	
86905	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	215	
86906	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
86907	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
86908	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Maintenance Operations	0	
86909	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Grounds in Place?	y	
86910	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	General Comments		
86911	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	General Comments		
86912	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Foundation Condition	Good	
86913	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Follow-up Action Required?	n	
86914	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Follow-up Action Required?	n	
86915	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations Ground	0	
86916	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations C Ø	0	
86917	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations B Ø	0	
86918	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations A Ø	0	
86919	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86920	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86921	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86922	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86923	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Paint Condition	Good	
86924	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
86925	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
86926	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
86927	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushings Connection/Risers	Good	
86928	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushing Condition	Good	
86929	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps C Ø	2.0	
86930	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps B Ø	2.0	
86931	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps A Ø	2.0	
86932	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86933	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86934	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86935	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations	2	
86936	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
86937	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
86938	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
86939	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Readings	General Comments		
86940	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	CB0096	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
86941	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	4	
86942	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86943	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86944	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86945	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	31.0	
86946	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Moisture and Leak Free?	y	
86947	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Maintenance Operations	0	
86948	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Grounds in Place?	y	
86949	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	General Comments		
86950	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	General Comments		
86951	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Foundation Condition	Good	
86952	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Follow-up Action Required?	n	
86953	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
86954	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Leaks	None	
86955	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86956	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86957	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Regulator As Left Counter	49430	
86958	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
86959	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
86960	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Oil Level	Good	
86961	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
86962	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
86963	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Min Tap Position	3L	
86964	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Max Tap Position	3R	
86965	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Grounds in Place?	y	
86966	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	General Comments		
86967	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
86968	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	57.0	
86969	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	45.0	
86970	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushing Condition	Good	
86971	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Foundation Condition	Good	
86972	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations	3	
86973	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
86974	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
86975	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
86976	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps A Ø	381.0	
86977	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps B Ø	390.0	
86978	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps C Ø	391.0	
86979	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
86980	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
86981	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
86982	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
86983	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations A Ø	0	
86984	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations B Ø	0	
86985	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations C Ø	0	
86986	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations Ground	0	
86987	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
86988	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
86989	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
86990	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Current Tap Position	2R	
86991	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
86992	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
86993	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Regulator As Left Counter	148534	
86994	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
86995	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
86996	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Leaks	None	
86997	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
86998	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Grounds in Place?	y	
86999	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Maintenance Operations	0	
87000	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Moisture and Leak Free?	y	
87001	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AF	175	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
87002	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AL	175	
87003	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations This Read Vac	0	
87004	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Switching Operations	0	
87005	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Tank Paint Condition	Good	
87006	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Unknown Operations	0	
87007	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations	1	
87008	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87009	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87010	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87011	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps A Ø	150.0	
87012	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps B Ø	234.0	
87013	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps B Ø	225.0	
87014	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps A Ø	145.0	
87015	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87016	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87017	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87018	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	9 Month Operations	0	
87019	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Unknown Operations	0	
87020	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Tank Paint Condition	Good	
87021	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Switching Operations	0	
87022	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations This Read Vac	0	
87023	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AL	185	
87024	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AF	185	
87025	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations B Ø	0	
87026	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations C Ø	0	
87027	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations Ground	0	
87028	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Follow-up Action Required?	n	
87029	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Follow-up Action Required?	n	
87030	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Foundation Condition	Good	
87031	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	General Comments		
87032	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	General Comments		
87033	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Grounds in Place?	y	
87034	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Maintenance Operations	0	
87035	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Moisture and Leak Free?	y	
87036	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AF	198	
87037	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AL	198	
87038	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations This Read Vac	4	
87039	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Switching Operations	4	
87040	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Tank Paint Condition	Good	
87041	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Unknown Operations	0	
87042	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
87043	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
87044	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Min Tap Position	6R	
87045	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Max Tap Position	16L	
87046	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
87047	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	General Comments		
87048	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
87049	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
87050	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
87051	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
87052	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
87053	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Follow-up Action Required?	n	
87054	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Follow-up Action Required?	n	
87055	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Foundation Condition	Good	
87056	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	General Comments		
87057	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	General Comments		
87058	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Grounds in Place?	y	
87059	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
87060	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Maintenance Operations	0	
87061	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Moisture and Leak Free?	y	
87062	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AF	301	
87063	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AL	301	
87064	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations This Read Vac	0	
87065	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
87066	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Switching Operations	0	
87067	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Tank Paint Condition	Good	
87068	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Unknown Operations	0	
87069	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
87070	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
87071	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
87072	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
87073	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
87074	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
87075	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Leaks	None	
87076	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87077	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
87078	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
87079	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87080	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87081	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87082	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	18.0	
87083	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	25.0	
87084	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	8.0	
87085	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
87086	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87087	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87088	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87089	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87090	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87091	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87092	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87093	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87094	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87095	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
87096	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
87097	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
87098	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
87099	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
87100	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
87101	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
87102	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
87103	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
87104	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
87105	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
87106	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
87107	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	194	
87108	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	194	
87109	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
87110	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
87111	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
87112	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
87113	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
87114	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Present	10	°C
87115	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
87116	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Current Tap Position	7L	
87117	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
87118	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Left Counter	79140	
87119	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Found Counter	79135	
87120	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	General Comments		
87121	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	General Comments		
87122	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
87123	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Follow-up Action Required?	n	
87124	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
87125	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
87126	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
87127	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
87128	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
87129	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
87130	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
87131	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
87132	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
87133	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
87134	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
87135	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
87136	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
87137	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
87138	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
87139	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
87140	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	General Comments		
87141	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
87142	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
87143	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
87144	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
87145	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
87146	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
87147	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
87148	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
87149	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Regulator As Left Counter	4585	
87150	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
87151	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87152	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Leaks	None	
87153	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
87154	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
87155	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
87156	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
87157	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
87158	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
87159	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
87160	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
87161	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
87162	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
87163	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Leaks	None	
87164	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations	1	
87165	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87166	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87167	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87168	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps A Ø	1.0	
87169	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps B Ø	0.0	
87170	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps C Ø	1.0	
87171	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushing Condition	Good	
87172	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87173	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87174	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87175	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87176	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87177	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87178	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87179	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87180	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87181	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations A Ø	0	
87182	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations B Ø	0	
87183	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations C Ø	0	
87184	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations Ground	0	
87185	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
87186	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
87187	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
87188	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
87189	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
87190	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
87191	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
87192	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
87193	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
87194	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
87195	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
87196	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
87197	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
87198	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
87199	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Present	38	*C
87200	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	4	
87201	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87202	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87203	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87204	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	240.0	
87205	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	240.0	
87206	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	240.0	
87207	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
87208	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87209	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87210	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87211	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87212	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87213	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87214	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87215	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87216	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
87217	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
87218	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
87219	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Trash?	y	
87220	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
87221	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
87222	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
87223	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
87224	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
87225	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
87226	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87227	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
87228	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
87229	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
87230	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Vegetation	None	
87231	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
87232	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
87233	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
87234	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
87235	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
87236	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
87237	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
87238	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Foundation Condition	Good	
87239	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
87240	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
87241	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	General Comments		
87242	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
87243	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
87244	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
87245	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
87246	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
87247	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
87248	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
87249	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
87250	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
87251	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
87252	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
87253	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
87254	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87255	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations A Ø	0	
87256	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations B Ø	0	
87257	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations C Ø	0	
87258	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations Ground	0	
87259	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Follow-up Action Required?	n	
87260	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Follow-up Action Required?	n	
87261	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Foundation Condition	Good	
87262	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
87263	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
87264	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0210	
87265	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
87266	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
87267	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
87268	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
87269	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Regulator As Left Counter	121006	
87270	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
87271	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
87272	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
87273	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
87274	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
87275	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
87276	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
87277	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
87278	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	General Comments		
87279	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
87280	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
87281	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
87282	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
87283	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
87284	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
87285	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
87286	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
87287	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
87288	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
87289	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
87290	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Leaks	None	
87291	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
87292	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
87293	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Regulator As Left Counter	102684	
87294	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
87295	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
87296	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
87297	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
87298	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
87299	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
87300	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
87301	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87302	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	General Comments		
87303	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
87304	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
87305	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
87306	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
87307	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
87308	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
87309	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
87310	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
87311	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
87312	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
87313	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
87314	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
87315	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
87316	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
87317	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
87318	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
87319	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
87320	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
87321	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	220.50	kw
87322	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
87323	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
87324	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
87325	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
87326	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	General Comments		
87327	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	General Comments		
87328	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
87329	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
87330	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
87331	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
87332	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
87333	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
87334	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
87335	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
87336	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
87337	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
87338	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87339	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87340	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87341	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations A Ø	0	
87342	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations B Ø	0	
87343	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations C Ø	0	
87344	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations Ground	0	
87345	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Follow-up Action Required?	n	
87346	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Follow-up Action Required?	n	
87347	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Foundation Condition	Good	
87348	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	General Comments		
87349	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	General Comments		
87350	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Grounds in Place?	y	
87351	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
87352	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Maintenance Operations	0	
87353	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
87354	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AF	44	
87355	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AL	44	
87356	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations This Read Vac	0	
87357	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
87358	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Switching Operations	0	
87359	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Tank Paint Condition	Good	
87360	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Unknown Operations	0	
87361	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	All Connections OK?	y	
87362	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	Follow-up Action Required?	n	
87363	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	General Comments		
87364	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	LTC Operation Checked?	y	
87365	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
87366	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
87367	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
87368	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	LTC000778	LTCControl	072-6	LTC Control Insp	VRR Time Delay	60	Seconds
87369	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
87370	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
87371	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
87372	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
87373	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
87374	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
87375	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
87376	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87377	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
87378	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
87379	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
87380	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
87381	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	General Comments		
87382	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
87383	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
87384	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Foundation Condition	Good	
87385	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
87386	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
87387	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
87388	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
87389	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
87390	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
87391	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
87392	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	General Comments		
87393	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
87394	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
87395	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
87396	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
87397	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
87398	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
87399	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
87400	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
87401	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
87402	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
87403	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
87404	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
87405	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
87406	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
87407	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
87408	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
87409	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Reading	.6000	
87410	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
87411	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
87412	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations	1	
87413	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87414	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87415	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87416	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps A Ø	306.0	
87417	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps B Ø	340.0	
87418	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps C Ø	281.0	
87419	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87420	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87421	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87422	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87423	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations A Ø	0	
87424	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations B Ø	0	
87425	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations C Ø	0	
87426	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations Ground	0	
87427	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
87428	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Follow-up Action Required?	n	
87429	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	General Comments		
87430	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	General Comments		
87431	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Maintenance Operations	0	
87432	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AF	232	
87433	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AL	232	
87434	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations This Read Vac	0	
87435	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Switching Operations	0	
87436	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Unknown Operations	0	
87437	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations	2	
87438	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87439	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87440	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87441	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps A Ø	39.0	
87442	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps B Ø	67.0	
87443	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps C Ø	61.0	
87444	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushing Condition	Good	
87445	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87446	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87447	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87448	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87449	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87450	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87451	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87452	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87453	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87454	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations A Ø	0	
87455	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations B Ø	0	
87456	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations C Ø	0	
87457	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations Ground	0	
87458	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Follow-up Action Required?	n	
87459	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Follow-up Action Required?	n	
87460	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Foundation Condition	Good	
87461	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	General Comments		
87462	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	General Comments		
87463	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Grounds in Place?	y	
87464	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Maintenance Operations	0	
87465	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Moisture and Leak Free?	y	
87466	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AF	182	
87467	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AL	182	
87468	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations This Read Vac	0	
87469	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Switching Operations	0	
87470	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Tank Paint Condition	Good	
87471	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Unknown Operations	0	
87472	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	3	
87473	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87474	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87475	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87476	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps A Ø	470.0	
87477	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps B Ø	470.0	
87478	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps C Ø	470.0	
87479	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushing Condition	Good	
87480	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87481	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87482	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87483	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87484	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87485	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87486	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
87487	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
87488	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
87489	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	General Comments		
87490	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
87491	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
87492	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
87493	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
87494	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
87495	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
87496	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
87497	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
87498	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87499	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87500	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
87501	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
87502	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
87503	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
87504	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
87505	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
87506	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
87507	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
87508	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
87509	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
87510	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.5	amps
87511	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
87512	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
87513	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
87514	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
87515	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
87516	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
87517	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
87518	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
87519	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
87520	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Broom on Site?	y	
87521	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
87522	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
87523	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
87524	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
87525	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
87526	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Evidence of Insects	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87527	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
87528	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
87529	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Swept?	y	
87530	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
87531	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
87532	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	General Comments		
87533	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
87534	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
87535	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panels Dusted?	y	
87536	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Trash Emptied?	y	
87537	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
87538	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
87539	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
87540	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
87541	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
87542	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
87543	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
87544	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
87545	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
87546	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
87547	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
87548	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
87549	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
87550	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
87551	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
87552	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
87553	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BCH000265	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
87554	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
87555	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
87556	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
87557	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Operations Since Last Insp	1032	
87558	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Min Tap Position	14L	
87559	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Max Tap Position	6L	
87560	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
87561	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
87562	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
87563	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
87564	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
87565	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
87566	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
87567	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
87568	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
87569	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
87570	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
87571	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
87572	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
87573	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
87574	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
87575	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Unknown Operations	0	
87576	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Switching Operations	0	
87577	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
87578	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Leaks	None	
87579	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
87580	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
87581	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Regulator As Left Counter	68534	
87582	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
87583	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
87584	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
87585	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
87586	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
87587	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
87588	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Max Tap Position	3L	
87589	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
87590	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	General Comments		
87591	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
87592	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
87593	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
87594	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
87595	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
87596	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
87597	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
87598	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
87599	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
87600	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
87601	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations This Read AM	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
87602	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AL	1018	
87603	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AF	1018	
87604	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Maintenance Operations	0	
87605	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	General Comments	A/B Phase IOC, A Phase HSI	
87606	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	General Comments		
87607	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Follow-up Action Required?	n	
87608	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Follow-up Action Required?	n	
87609	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations Ground	0	
87610	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations C Ø	0	
87611	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations B Ø	2	
87612	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations A Ø	2	
87613	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
87614	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
87615	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
87616	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
87617	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps C Ø	49.0	
87618	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps B Ø	53.0	
87619	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps A Ø	47.0	
87620	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
87621	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
87622	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
87623	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Months Operations	15	
87624	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
87625	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
87626	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
87627	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
87628	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
87629	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
87630	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
87631	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	22	
87632	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	22	
87633	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
87634	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BB0139	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
87635	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
87636	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
87637	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Unknown Operations	0	
87638	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Switching Operations	0	
87639	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
87640	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
87641	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
87642	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
87643	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
87644	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
87645	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
87646	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
87647	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
87648	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
87649	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Follow-up Action Required?	n	
87650	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
87651	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
87652	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	General Comments		
87653	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	General Comments	Transformer needs paint	
87654	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
87655	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	LTC Totalizer Reading	6112.80	kw
87656	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
87657	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
87658	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Max	55	°C
87659	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Present	30	°C
87660	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
87661	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
87662	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
87663	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
87664	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
87665	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
87666	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
87667	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
87668	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Reading	.8490	
87669	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
87670	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
87671	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
87672	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AL	222	
87673	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AF	222	
87674	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Maintenance Operations	0	
87675	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	General Comments		
87676	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
87677	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
87678	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
87679	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
87680	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
87681	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
87682	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
87683	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87684	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87685	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87686	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87687	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps C Ø	1001.0	
87688	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps B Ø	1025.0	
87689	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps A Ø	1032.0	
87690	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87691	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87692	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87693	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations	0	
87694	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations	12	
87695	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87696	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87697	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87698	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps A Ø	50.0	
87699	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps B Ø	39.0	
87700	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps C Ø	39.0	
87701	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushing Condition	Good	
87702	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87703	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87704	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87705	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
87706	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
87707	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
87708	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	937	
87709	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Follow-up Action Required?	n	
87710	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Follow-up Action Required?	n	
87711	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Foundation Condition	Good	
87712	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	General Comments		
87713	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	General Comments		
87714	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Grounds in Place?	y	
87715	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
87716	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Maintenance Operations	0	
87717	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Moisture and Leak Free?	y	
87718	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AF	393	
87719	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AL	393	
87720	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations This Read Vac	0	
87721	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
87722	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Switching Operations	0	
87723	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Tank Paint Condition	Good	
87724	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Unknown Operations	0	
87725	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
87726	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
87727	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
87728	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
87729	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
87730	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
87731	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
87732	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
87733	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
87734	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
87735	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
87736	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	635	
87737	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	635	
87738	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
87739	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
87740	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
87741	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
87742	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
87743	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
87744	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
87745	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	General Comments		
87746	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	General Comments		
87747	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
87748	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTC0000700	LTCControl	338-1	LTC Control Insp	VRR Time Delay	60	Seconds
87749	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTC0000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
87750	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTC0000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
87751	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTC0000700	LTCControl	338-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87752	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCCControl	338-1	LTC Control Insp	LTC Operation Checked?	y	
87753	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCCControl	338-1	LTC Control Insp	General Comments		
87754	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCCControl	338-1	LTC Control Insp	Follow-up Action Required?	n	
87755	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCCControl	338-1	LTC Control Insp	All Connections OK?	y	
87756	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
87757	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
87758	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
87759	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3231.36	kw
87760	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
87761	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
87762	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Max	20	°C
87763	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
87764	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
87765	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
87766	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
87767	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
87768	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
87769	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
87770	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
87771	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
87772	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
87773	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
87774	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
87775	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
87776	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
87777	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
87778	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
87779	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
87780	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
87781	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
87782	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6732	
87783	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
87784	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
87785	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
87786	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
87787	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-5TA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
87788	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
87789	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-5TA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
87790	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
87791	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
87792	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
87793	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
87794	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
87795	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
87796	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	General Comments		
87797	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
87798	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
87799	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
87800	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-5TA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
87801	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-5TA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
87802	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations	6	
87803	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87804	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87805	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87806	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps A Ø	30.0	
87807	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps B Ø	30.0	
87808	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps C Ø	30.0	
87809	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushing Condition	Good	
87810	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87811	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87812	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87813	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87814	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87815	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87816	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87817	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87818	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87819	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations A Ø	0	
87820	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations B Ø	0	
87821	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations C Ø	0	
87822	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations Ground	0	
87823	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Follow-up Action Required?	n	
87824	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Follow-up Action Required?	n	
87825	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Foundation Condition	Good	
87826	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
87827	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	General Comments		
87828	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Grounds in Place?	y	
87829	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Maintenance Operations	0	
87830	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
87831	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AF	273	
87832	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AL	273	
87833	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations This Read Vac	2	
87834	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Switching Operations	2	
87835	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Tank Paint Condition	Good	
87836	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Unknown Operations	0	
87837	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations	6	
87838	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Switching Operations	11	
87839	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Tank Paint Condition	Good	
87840	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Unknown Operations	0	
87841	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations	7	
87842	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87843	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87844	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87845	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps A Ø	0.0	
87846	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps B Ø	0.0	
87847	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps C Ø	16.0	
87848	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushing Condition	Good	
87849	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
87850	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
87851	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
87852	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87853	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
87854	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
87855	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
87856	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps A Ø	27.0	
87857	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	10L	
87858	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
87859	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
87860	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
87861	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
87862	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
87863	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
87864	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
87865	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
87866	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	2L	
87867	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	4L	
87868	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
87869	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	111766	
87870	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	111766	
87871	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
87872	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
87873	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
87874	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
87875	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Months Operations	2	
87876	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
87877	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
87878	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
87879	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps A Ø	216.0	
87880	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps B Ø	212.0	
87881	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps C Ø	218.0	
87882	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
87883	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
87884	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
87885	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
87886	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations B Ø	0	
87887	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations C Ø	0	
87888	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations Ground	0	
87889	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Follow-up Action Required?	n	
87890	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Follow-up Action Required?	n	
87891	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	General Comments		
87892	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	General Comments		
87893	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
87894	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
87895	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Maintenance Operations	0	
87896	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AF	760	
87897	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AL	760	
87898	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations This Read AM	0	
87899	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Switching Operations	0	
87900	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Unknown Operations	0	
87901	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	*F

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
87902	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
87903	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
87904	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
87905	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
87906	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
87907	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
87908	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
87909	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
87910	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
87911	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
87912	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
87913	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
87914	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations A Ø	0	
87915	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations B Ø	0	
87916	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations C Ø	0	
87917	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations Ground	0	
87918	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Follow-up Action Required?	n	
87919	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Follow-up Action Required?	n	
87920	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Foundation Condition	Good	
87921	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	General Comments		
87922	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	General Comments		
87923	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Grounds in Place?	y	
87924	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Maintenance Operations	0	
87925	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Moisture and Leak Free?	y	
87926	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AF	202	
87927	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AL	202	
87928	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations This Read Vac	11	
87929	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	General Comments		
87930	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
87931	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
87932	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
87933	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
87934	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
87935	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
87936	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Vegetation	None	
87937	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
87938	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
87939	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
87940	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	General Comments		
87941	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
87942	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
87943	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
87944	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
87945	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
87946	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
87947	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Trash?	y	
87948	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
87949	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
87950	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
87951	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
87952	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
87953	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
87954	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	General Comments		
87955	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
87956	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
87957	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
87958	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
87959	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
87960	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
87961	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
87962	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
87963	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
87964	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
87965	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
87966	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
87967	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
87968	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
87969	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	General Comments		
87970	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
87971	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
87972	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
87973	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
87974	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
87975	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
87976	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
87977	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
87978	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
87979	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
87980	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
87981	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
87982	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
87983	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
87984	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
87985	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
87986	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
87987	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
87988	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
87989	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
87990	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
87991	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
87992	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
87993	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
87994	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
87995	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
87996	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
87997	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
87998	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
87999	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	BAT000190	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
88000	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
88001	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
88002	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
88003	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
88004	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
88005	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
88006	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
88007	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
88008	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
88009	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
88010	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
88011	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Max	48	*C
88012	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
88013	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
88014	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	LTC Totalizer Reading	1440.00	kw
88015	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
88016	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	General Comments		
88017	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	General Comments		
88018	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
88019	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Follow-up Action Required?	n	
88020	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
88021	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
88022	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
88023	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Leaks	None	
88024	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
88025	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
88026	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Regulator As Left Counter	62672	
88027	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
88028	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
88029	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
88030	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
88031	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
88032	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Min Tap Position	7L	
88033	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Max Tap Position	3L	
88034	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
88035	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	General Comments		
88036	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
88037	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
88038	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
88039	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
88040	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
88041	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
88042	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
88043	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
88044	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
88045	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
88046	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	General Comments		
88047	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
88048	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
88049	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Foundation Condition	Good	
88050	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
88051	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88052	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
88053	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
88054	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
88055	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
88056	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
88057	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
88058	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
88059	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88060	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88061	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88062	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
88063	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88064	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
88065	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88066	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
88067	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
88068	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88069	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
88070	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
88071	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	840	
88072	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	840	
88073	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations This Read Vac	0	
88074	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88075	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	0	
88076	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
88077	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
88078	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
88079	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
88080	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations This Read Vac	0	
88081	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88082	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Switching Operations	0	
88083	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Tank Paint Condition	Good	
88084	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Unknown Operations	0	
88085	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
88086	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
88087	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
88088	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Trash?	y	
88089	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
88090	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
88091	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
88092	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
88093	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
88094	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
88095	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	General Comments		
88096	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
88097	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
88098	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
88099	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Vegetation	None	
88100	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
88101	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
88102	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
88103	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
88104	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
88105	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
88106	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
88107	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Foundation Condition	Good	
88108	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
88109	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
88110	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	General Comments		
88111	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
88112	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
88113	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
88114	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
88115	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88116	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
88117	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88118	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
88119	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88120	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88121	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88122	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
88123	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
88124	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	0	
88125	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
88126	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88127	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
88128	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
88129	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
88130	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
88131	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
88132	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
88133	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations	1	
88134	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88135	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88136	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88137	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps A Ø	75.0	
88138	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps B Ø	96.0	
88139	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps C Ø	81.0	
88140	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushing Condition	Good	
88141	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88142	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88143	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88144	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88145	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88146	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88147	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88148	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88149	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88150	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations A Ø	0	
88151	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations B Ø	0	
88152	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations C Ø	0	
88153	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations Ground	0	
88154	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
88155	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
88156	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
88157	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
88158	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
88159	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88160	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
88161	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88162	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88163	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88164	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88165	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
88166	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
88167	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
88168	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
88169	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
88170	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
88171	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	General Comments		
88172	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	General Comments		
88173	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
88174	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
88175	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
88176	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
88177	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1696.32	kw
88178	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
88179	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
88180	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
88181	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
88182	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
88183	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
88184	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
88185	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
88186	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
88187	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
88188	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
88189	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
88190	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7068	
88191	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
88192	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
88193	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
88194	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
88195	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
88196	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
88197	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations	4	
88198	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88199	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88200	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88201	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
88202	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps B Ø	0.0	
88203	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps C Ø	0.0	
88204	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushing Condition	Good	
88205	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88206	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88207	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88208	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88209	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88210	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88211	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88212	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88213	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88214	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations A Ø	0	
88215	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations B Ø	0	
88216	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations C Ø	0	
88217	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations Ground	0	
88218	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Follow-up Action Required?	n	
88219	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Follow-up Action Required?	n	
88220	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Foundation Condition	Good	
88221	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	General Comments		
88222	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	General Comments		
88223	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Grounds in Place?	y	
88224	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88225	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Maintenance Operations	0	
88226	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Moisture and Leak Free?	y	
88227	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AF	375	
88228	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AL	375	
88229	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	General Comments		
88230	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
88231	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Found Counter	196390	
88232	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
88233	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
88234	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
88235	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
88236	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
88237	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
88238	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
88239	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
88240	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
88241	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
88242	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
88243	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Unknown Operations	0	
88244	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Switching Operations	0	
88245	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
88246	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AL	99966	
88247	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
88248	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
88249	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
88250	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
88251	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
88252	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	General Comments		
88253	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
88254	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
88255	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Foundation Condition	Good	
88256	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
88257	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
88258	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
88259	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
88260	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
88261	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
88262	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
88263	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
88264	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AF	99966	
88265	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
88266	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	General Comments		
88267	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	General Comments		
88268	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
88269	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
88270	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
88271	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
88272	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
88273	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
88274	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
88275	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
88276	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88277	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
88278	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
88279	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	General Comments		
88280	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
88281	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	All Connections OK?	y	
88282	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	Follow-up Action Required?	n	
88283	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	General Comments		
88284	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	LTC Operation Checked?	y	
88285	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
88286	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
88287	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
88288	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88289	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88290	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88291	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
88292	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
88293	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
88294	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
88295	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
88296	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
88297	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
88298	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.81	
88299	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88300	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
88301	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88302	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88303	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88304	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?		
88305	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88306	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88307	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
88308	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
88309	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	72.0	
88310	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	72.0	
88311	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88312	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88313	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88314	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	25	
88315	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Unknown Operations	0	
88316	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Tank Paint Condition	Good	
88317	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Switching Operations	0	
88318	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88319	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations This Read Vac	0	
88320	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AL	315	
88321	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
88322	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	LTC000132	LTCControl	592-1	LTC Control Insp	VRR Time Delay	30	Seconds
88323	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
88324	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
88325	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	General Comments		If no, which cells in comments
88326	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
88327	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1882	
88328	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
88329	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
88330	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
88331	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
88332	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
88333	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
88334	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
88335	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
88336	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
88337	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
88338	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps C Ø	374.0	
88339	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps B Ø	376.0	
88340	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps A Ø	395.0	
88341	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
88342	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
88343	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
88344	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Months Operations	0	
88345	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
88346	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AF	315	
88347	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Moisture and Leak Free?	y	
88348	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Maintenance Operations	0	
88349	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88350	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Grounds in Place?	y	
88351	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88352	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	General Comments		
88353	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Foundation Condition	Good	
88354	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Follow-up Action Required?	n	
88355	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Follow-up Action Required?	n	
88356	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations Ground	0	
88357	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
88358	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88359	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88360	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88361	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
88362	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	48.0	
88363	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
88364	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
88365	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88366	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88367	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88368	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88369	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
88370	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
88371	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	General Comments		
88372	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
88373	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88374	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
88375	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC000364	LTCControl	TE-TRANS 2	LTC Control Insp	General Comments		
88376	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LTC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
88377	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations C Ø	0	
88378	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations B Ø	0	
88379	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations A Ø	0	
88380	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88381	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88382	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88383	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88384	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88385	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88386	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
88387	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
88388	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
88389	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
88390	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
88391	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Left Counter	196390	
88392	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
88393	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
88394	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	
88395	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
88396	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2891	
88397	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
88398	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
88399	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88400	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88401	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88402	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
88403	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
88404	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
88405	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
88406	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
88407	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
88408	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Leaks	None	
88409	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
88410	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
88411	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Regulator As Left Counter	6487	
88412	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
88413	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
88414	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Oil Level	Good	
88415	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
88416	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
88417	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Min Tap Position	3L	
88418	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Max Tap Position	2R	
88419	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Grounds in Place?	y	
88420	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	General Comments		
88421	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
88422	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Foundation Condition	Good	
88423	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
88424	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
88425	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Current Tap Position	1R	
88426	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88427	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
88428	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
88429	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
88430	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushing Condition	Good	
88431	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
88432	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88433	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88434	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
88435	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
88436	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
88437	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
88438	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
88439	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
88440	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
88441	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
88442	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
88443	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
88444	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
88445	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
88446	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
88447	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
88448	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	General Comments		
88449	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
88450	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
88451	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Swept?	y	
88452	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
88453	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
88454	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
88455	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
88456	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
88457	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
88458	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
88459	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Broom on Site?	y	
88460	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
88461	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
88462	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
88463	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88464	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88465	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88466	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	144.0	
88467	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	144.0	
88468	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
88469	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
88470	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88471	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88472	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88473	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88474	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88475	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88476	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88477	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88478	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88479	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
88480	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
88481	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
88482	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
88483	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
88484	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
88485	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
88486	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88487	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88488	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88489	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
88490	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88491	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88492	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88493	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88494	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88495	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
88496	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88497	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	22	
88498	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	22	
88499	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
88500	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88501	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
88502	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88503	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88504	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
88505	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
88506	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
88507	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.1	VDC
88508	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	General Comments		
88509	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
88510	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
88511	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
88512	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
88513	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
88514	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
88515	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
88516	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	23	*F
88517	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
88518	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
88519	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	General Comments		
88520	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
88521	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
88522	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
88523	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
88524	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
88525	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
88526	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
88527	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
88528	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
88529	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
88530	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
88531	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
88532	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
88533	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
88534	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
88535	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
88536	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
88537	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
88538	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
88539	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
88540	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
88541	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
88542	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
88543	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
88544	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
88545	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
88546	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
88547	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
88548	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
88549	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88550	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
88551	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
88552	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
88553	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Ambient Temp	19	*F
88554	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88555	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88556	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88557	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88558	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88559	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88560	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88561	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88562	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
88563	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	168.0	
88564	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	192.0	
88565	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	168.0	
88566	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88567	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88568	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88569	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
88570	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88571	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	10	
88572	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
88573	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
88574	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
88575	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Operations Since Last Insp	944	
88576	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
88577	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Min Tap Position	11L	
88578	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Max Tap Position	3L	
88579	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Current Tap Position	6L	
88580	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
88581	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Left Counter	40354	
88582	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Found Counter	40350	
88583	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	General Comments		
88584	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	General Comments		
88585	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
88586	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Follow-up Action Required?	n	
88587	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	331	
88588	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	331	
88589	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88590	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88591	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	36	
88592	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88593	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
88594	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
88595	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
88596	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	212	
88597	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	212	
88598	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
88599	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88600	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
88601	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88602	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88603	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
88604	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
88605	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
88606	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
88607	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
88608	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds
88609	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
88610	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
88611	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
88612	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
88613	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
88614	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	General Comments		
88615	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
88616	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	LTC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	
88617	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
88618	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
88619	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
88620	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
88621	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Vegetation	None	
88622	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
88623	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
88624	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
88625	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
88626	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	General Comments		
88627	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
88628	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
88629	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
88630	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
88631	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
88632	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
88633	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
88634	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
88635	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88636	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88637	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	10	
88638	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88639	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	28	
88640	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	956	
88641	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	956	
88642	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88643	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	18	
88644	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88645	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88646	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88647	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
88648	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
88649	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88650	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88651	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
88652	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88653	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88654	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88655	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88656	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	LTC Totalizer Reading	6589.44	kw
88657	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
88658	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Operations Counter	22	
88659	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
88660	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
88661	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	General Comments		
88662	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
88663	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
88664	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
88665	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
88666	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
88667	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
88668	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
88669	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
88670	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88671	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
88672	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
88673	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
88674	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
88675	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
88676	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
88677	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
88678	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
88679	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Present	25	°C
88680	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Max	35	°C
88681	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Reading	.6006	
88682	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
88683	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
88684	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
88685	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
88686	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations	2	
88687	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88688	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
88689	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
88690	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
88691	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
88692	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Present	32	°C
88693	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Max	41	°C
88694	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
88695	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
88696	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	LTC Totalizer Reading	10810.80	kw
88697	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
88698	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	General Comments		
88699	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	General Comments		
88700	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
88701	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations	10	
88702	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88703	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Grounds in Place?	y	
88704	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	General Comments		
88705	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	General Comments		
88706	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Foundation Condition	Good	
88707	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Follow-up Action Required?	n	
88708	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Follow-up Action Required?	n	
88709	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations Ground	0	
88710	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations C Ø	0	
88711	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations B Ø	0	
88712	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations A Ø	0	
88713	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88714	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88715	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
88716	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88717	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88718	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88719	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
88720	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
88721	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
88722	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
88723	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88724	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88725	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88726	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88727	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
88728	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88729	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
88730	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88731	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
88732	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88733	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88734	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88735	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
88736	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
88737	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
88738	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Follow-up Action Required?	n	
88739	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
88740	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
88741	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	General Comments		
88742	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	General Comments		
88743	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
88744	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88745	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88746	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88747	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88748	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88749	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88750	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	120.0	
88751	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	160.0	
88752	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	160.0	
88753	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushing Condition	Good	
88754	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations C Ø	0	
88755	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations Ground	0	
88756	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Follow-up Action Required?	n	
88757	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
88758	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
88759	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps C Ø	130.0	
88760	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps B Ø	136.0	
88761	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps A Ø	115.0	
88762	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
88763	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Max	60	°C
88764	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Present	35	°C
88765	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
88766	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Unknown Operations	0	
88767	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Tank Paint Condition	Good	
88768	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Switching Operations	1	
88769	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88770	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations This Read Vac	1	
88771	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AL	316	
88772	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AF	316	
88773	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Moisture and Leak Free?	y	
88774	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Maintenance Operations	0	
88775	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88776	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
88777	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
88778	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
88779	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
88780	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
88781	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
88782	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
88783	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Reading	.6864	
88784	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
88785	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
88786	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Grounds in Place?	y	
88787	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	General Comments		
88788	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	General Comments		
88789	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Foundation Condition	Good	
88790	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Follow-up Action Required?	n	
88791	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88792	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88793	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88794	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88795	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88796	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88797	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88798	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushing Condition	Good	
88799	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps C Ø	23.0	
88800	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps B Ø	17.0	
88801	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps A Ø	19.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88802	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88803	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88804	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88805	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations	1	
88806	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
88807	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Follow-up Action Required?	n	
88808	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
88809	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
88810	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
88811	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
88812	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
88813	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
88814	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
88815	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
88816	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88817	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88818	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88819	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
88820	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
88821	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88822	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	143	
88823	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	143	
88824	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
88825	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88826	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
88827	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88828	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88829	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
88830	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
88831	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
88832	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
88833	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
88834	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
88835	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88836	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88837	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps A Ø	142.0	
88838	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps B Ø	187.0	
88839	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps C Ø	129.0	
88840	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushing Condition	Good	
88841	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88842	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88843	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88844	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88845	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88846	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88847	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88848	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88849	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88850	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88851	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88852	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
88853	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
88854	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
88855	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
88856	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Follow-up Action Required?	n	
88857	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations A Ø	0	
88858	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations B Ø	0	
88859	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
88860	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88861	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88862	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
88863	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushing Condition	Good	
88864	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps C Ø	210.0	
88865	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps B Ø	180.0	
88866	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps A Ø	220.0	
88867	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
88868	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Leaks	None	
88869	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
88870	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
88871	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Regulator As Left Counter	155420	
88872	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
88873	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88874	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88875	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
88876	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
88877	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
88878	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
88879	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
88880	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
88881	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
88882	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
88883	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
88884	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	General Comments		
88885	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
88886	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
88887	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
88888	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
88889	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps C Ø	171.0	
88890	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps B Ø	126.0	
88891	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps A Ø	162.0	
88892	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
88893	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
88894	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
88895	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	General Comments		
88896	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
88897	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
88898	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
88899	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
88900	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
88901	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
88902	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
88903	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
88904	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
88905	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
88906	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
88907	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
88908	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
88909	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
88910	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
88911	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
88912	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Vegetation	None	
88913	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
88914	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	General Comments		
88915	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
88916	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
88917	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
88918	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
88919	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
88920	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
88921	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
88922	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
88923	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
88924	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
88925	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
88926	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
88927	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
88928	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
88929	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
88930	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Trash?	y	
88931	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
88932	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
88933	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
88934	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1304	
88935	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1304	
88936	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
88937	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88938	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
88939	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
88940	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
88941	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Unknown Operations	0	
88942	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Switching Operations	0	
88943	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
88944	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
88945	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations This Read Vac	0	
88946	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AL	394	
88947	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AF	394	
88948	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Maintenance Operations	0	
88949	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	General Comments		
88950	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	General Comments		
88951	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
88952	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
88953	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
88954	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
88955	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
88956	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
88957	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
88958	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
88959	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations Ground	0	
88960	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations C Ø	0	
88961	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations B Ø	0	
88962	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations A Ø	0	
88963	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
88964	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations This Read Vac	0	
88965	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AL	318	
88966	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AF	318	
88967	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Moisture and Leak Free?	y	
88968	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Maintenance Operations	0	
88969	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
88970	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Tank Paint Condition	Good	
88971	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	0	
88972	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
88973	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations This Read Vac	0	
88974	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	378	
88975	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	378	
88976	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Moisture and Leak Free?	y	
88977	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
88978	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Grounds in Place?	y	
88979	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
88980	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	General Comments		
88981	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Foundation Condition	Good	
88982	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	
88983	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Unknown Operations	0	
88984	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Tank Paint Condition	Good	
88985	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Switching Operations	0	
88986	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations This Read Vac	0	
88987	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AL	92	
88988	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AF	92	
88989	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Moisture and Leak Free?	y	
88990	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Maintenance Operations	0	
88991	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Grounds in Place?	y	
88992	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	General Comments		
88993	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	General Comments		
88994	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Foundation Condition	Good	
88995	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Follow-up Action Required?	n	
88996	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Follow-up Action Required?	n	
88997	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations Ground	0	
88998	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations C Ø	0	
88999	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations B Ø	0	
89000	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations A Ø	0	
89001	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89002	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89003	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89004	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89005	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89006	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89007	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89008	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
89009	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89010	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushing Condition	Good	
89011	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps C Ø	2.0	
89012	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps B Ø	2.0	
89013	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps A Ø	2.0	
89014	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89015	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89016	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89017	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
89018	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89019	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations	8	
89020	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	11	
89021	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
89022	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89023	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89024	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations	9	
89025	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89026	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89027	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
89028	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
89029	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89030	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps A Ø	186.0	
89031	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps B Ø	173.0	
89032	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps C Ø	204.0	
89033	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
89034	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	General Comments		
89035	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89036	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
89037	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
89038	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
89039	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
89040	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
89041	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
89042	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
89043	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
89044	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89045	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
89046	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
89047	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
89048	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
89049	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
89050	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89051	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89052	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations A Ø	0	
89053	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations B Ø	0	
89054	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations C Ø	0	
89055	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations Ground	0	
89056	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
89057	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Follow-up Action Required?	n	
89058	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	General Comments		
89059	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	General Comments		
89060	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Maintenance Operations	0	
89061	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AF	568	
89062	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AL	568	
89063	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations This Read Vac	0	
89064	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Switching Operations	0	
89065	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Unknown Operations	0	
89066	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Unknown Operations	0	
89067	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Tank Paint Condition	Good	
89068	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Switching Operations	0	
89069	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
89070	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89071	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89072	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89073	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Present	12	°C
89074	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Max	38	°C
89075	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
89076	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89077	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	LTC Totalizer Reading	4636.80	kw
89078	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89079	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	General Comments		
89080	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	General Comments		
89081	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89082	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89083	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Follow-up Action Required?	n	
89084	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89085	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
89086	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
89087	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89088	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89089	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89090	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
89091	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Reading	.4194	
89092	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
89093	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89094	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89095	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8082	
89096	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
89097	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
89098	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
89099	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89100	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
89101	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89102	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89103	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89104	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
89105	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89106	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Follow-up Action Required?	n	
89107	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
89108	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	General Comments		
89109	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	General Comments		
89110	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Found Counter	245665	
89111	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Left Counter	245670	
89112	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89113	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Current Tap Position	8L	
89114	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Max Tap Position	5L	
89115	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Min Tap Position	12L	
89116	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89117	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
89118	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTC0000792	LTCControl	094-5	LTC Control Insp	All Connections OK?	y	
89119	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTC0000792	LTCControl	094-5	LTC Control Insp	Follow-up Action Required?	n	
89120	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
89121	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89122	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	LTC Totalizer Reading	7549.20	kw
89123	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89124	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89125	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	General Comments		
89126	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	General Comments		
89127	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89128	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89129	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89130	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89131	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89132	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89133	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
89134	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89135	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
89136	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
89137	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89138	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
89139	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89140	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89141	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89142	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Follow-up Action Required?	n	
89143	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89144	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
89145	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
89146	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89147	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
89148	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89149	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89150	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89151	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89152	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89153	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
89154	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	General Comments		
89155	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89156	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	85	°C
89157	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	5	°C
89158	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89159	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
89160	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Max	75	°C
89161	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89162	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
89163	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
89164	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
89165	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
89166	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Current Tap Position	5L	
89167	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	52	
89168	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89169	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89170	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89171	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
89172	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
89173	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	1120.0	
89174	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
89175	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89176	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89177	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89178	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89179	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89180	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89181	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89182	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89183	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89184	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
89185	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
89186	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
89187	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89188	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89189	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89190	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
89191	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
89192	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
89193	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
89194	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
89195	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
89196	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
89197	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
89198	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
89199	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
89200	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
89201	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
89202	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	212	
89203	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	212	
89204	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
89205	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
89206	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
89207	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
89208	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Operations Since Last Insp	922	
89209	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89210	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
89211	11/12/2019 13:03	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
89212	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89213	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89214	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89215	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89216	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
89217	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89218	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89219	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
89220	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Max	40	°C
89221	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Present	40	°C
89222	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
89223	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
89224	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
89225	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
89226	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	0	°C
89227	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	95	°C
89228	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89229	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
89230	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
89231	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1939.68	kw
89232	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
89233	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
89234	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
89235	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	95	°C
89236	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	15	°C
89237	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89238	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89239	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89240	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89241	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89242	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89243	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89244	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89245	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89246	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	General Comments		
89247	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Operation Checked?	y	
89248	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
89249	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
89250	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
89251	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89252	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Follow-up Action Required?	n	
89253	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
89254	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations C Ø	2	
89255	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations Ground	0	
89256	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
89257	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
89258	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	General Comments		
89259	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
89260	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Found Counter	184636	
89261	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps B Ø	126.0	
89262	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Follow-up Action Required?	n	
89263	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Follow-up Action Required?	n	
89264	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	General Comments		
89265	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	General Comments		
89266	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Maintenance Operations	0	
89267	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AF	645	
89268	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AL	645	
89269	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations This Read AM	6	
89270	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Switching Operations	0	
89271	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Unknown Operations	0	
89272	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
89273	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
89274	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps A Ø	156.0	
89275	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
89276	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
89277	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
89278	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
89279	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Evidence of Insects	None	
89280	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
89281	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
89282	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Swept?	y	
89283	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
89284	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
89285	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
89286	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	General Comments		
89287	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
89288	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Panels Dusted?	n	
89289	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
89290	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
89291	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
89292	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
89293	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Months Operations	13	
89294	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Left Counter	184636	
89295	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
89296	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
89297	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
89298	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
89299	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
89300	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	23	*F
89301	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
89302	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
89303	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
89304	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
89305	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
89306	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
89307	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps C Ø	118.0	
89308	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
89309	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
89310	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
89311	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
89312	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations A Ø	2	
89313	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
89314	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
89315	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
89316	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations B Ø	2	
89317	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	General Comments		
89318	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
89319	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
89320	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
89321	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
89322	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
89323	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Leaks	None	
89324	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
89325	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
89326	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14761	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89327	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
89328	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
89329	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
89330	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
89331	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
89332	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
89333	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
89334	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
89335	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	General Comments		
89336	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
89337	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
89338	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
89339	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
89340	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
89341	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
89342	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
89343	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
89344	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
89345	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
89346	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89347	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89348	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
89349	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89350	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89351	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
89352	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Reading	.3220	
89353	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Max	38	°C
89354	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Present	16	°C
89355	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
89356	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
89357	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
89358	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
89359	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
89360	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	General Comments		
89361	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
89362	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
89363	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
89364	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
89365	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
89366	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
89367	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
89368	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
89369	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
89370	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	General Comments		
89371	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
89372	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
89373	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
89374	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
89375	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
89376	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
89377	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
89378	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
89379	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Tank Paint Condition	Good	
89380	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	0	
89381	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
89382	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations This Read Vac	0	
89383	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	287	
89384	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	287	
89385	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
89386	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
89387	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
89388	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
89389	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
89390	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
89391	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89392	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
89393	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Foundation Condition	Good	
89394	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
89395	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
89396	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	General Comments		
89397	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
89398	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
89399	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
89400	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
89401	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89402	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
89403	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
89404	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
89405	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
89406	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
89407	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
89408	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
89409	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	General Comments		
89410	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
89411	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
89412	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
89413	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89414	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
89415	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89416	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89417	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89418	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89419	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
89420	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
89421	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
89422	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
89423	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
89424	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
89425	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
89426	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
89427	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
89428	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
89429	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
89430	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Present	24	°C
89431	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
89432	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Max	45	°C
89433	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
89434	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
89435	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
89436	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
89437	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89438	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
89439	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
89440	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
89441	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
89442	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
89443	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
89444	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
89445	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
89446	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
89447	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
89448	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Vegetation	None	
89449	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
89450	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
89451	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	General Comments		
89452	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
89453	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
89454	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
89455	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
89456	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
89457	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
89458	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
89459	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Trash?	y	
89460	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
89461	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
89462	11/12/2019 15:45	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
89463	11/12/2019 15:19	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
89464	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Switching Operations	5	
89465	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Tank Paint Condition	Good	
89466	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Unknown Operations	0	
89467	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
89468	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
89469	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	9	
89470	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89471	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89472	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89473	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5680.80	kw
89474	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
89475	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
89476	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89477	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
89478	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	General Comments		
89479	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	General Comments		
89480	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89481	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
89482	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
89483	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89484	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
89485	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	120.0	
89486	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	120.0	
89487	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	120.0	
89488	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushing Condition	Good	
89489	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
89490	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
89491	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
89492	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
89493	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
89494	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
89495	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
89496	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89497	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89498	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89499	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89500	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89501	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89502	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89503	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
89504	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations	0	
89505	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89506	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89507	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89508	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps A Ø	0.0	
89509	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps B Ø	0.0	
89510	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89511	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
89512	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
89513	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps C Ø	0.0	
89514	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89515	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89516	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89517	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
89518	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Regulator As Left Counter	68423	
89519	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
89520	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations This Read Vac	0	
89521	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Switching Operations	0	
89522	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Tank Paint Condition	Good	
89523	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Unknown Operations	0	
89524	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Leaks	None	
89525	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7890	
89526	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
89527	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89528	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
89529	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
89530	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89531	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89532	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
89533	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89534	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Present	12	°C
89535	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
89536	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
89537	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
89538	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
89539	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
89540	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
89541	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
89542	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
89543	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
89544	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
89545	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
89546	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
89547	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
89548	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
89549	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
89550	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
89551	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89552	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	General Comments		
89553	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
89554	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Max Tap Position	16L	
89555	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Min Tap Position	6L	
89556	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
89557	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
89558	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
89559	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
89560	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	
89561	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Regulator As Left Counter	99342	
89562	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
89563	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Leaks	None	
89564	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
89565	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
89566	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
89567	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
89568	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89569	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89570	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89571	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89572	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89573	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89574	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89575	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
89576	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89577	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
89578	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
89579	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
89580	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
89581	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
89582	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
89583	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
89584	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
89585	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
89586	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Leaks	None	
89587	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
89588	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Operations Counter	1451	
89589	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
89590	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
89591	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	General Comments		
89592	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
89593	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
89594	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
89595	11/12/2019 14:02	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
89596	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Regulator As Left Counter	24763	
89597	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
89598	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
89599	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Leaks	None	
89600	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
89601	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Grounds in Place?	y	
89602	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
89603	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Operations Since Last Insp	1059	
89604	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	General Comments		
89605	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Foundation Condition	Good	
89606	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
89607	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Follow-up Action Required?	n	
89608	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
89609	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
89610	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	
89611	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	0	
89612	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89613	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89614	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89615	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
89616	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89617	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
89618	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
89619	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
89620	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89621	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89622	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89623	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89624	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
89625	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
89626	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89627	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89628	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
89629	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	General Comments		
89630	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	General Comments		
89631	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89632	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
89633	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
89634	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89635	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
89636	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Unknown Operations	0	
89637	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Switching Operations	0	
89638	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
89639	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
89640	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
89641	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
89642	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	General Comments		
89643	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89644	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
89645	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
89646	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
89647	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
89648	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
89649	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	General Comments		
89650	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	General Comments		
89651	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Found Counter	6106	
89652	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89653	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89654	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
89655	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Left Counter	6110	
89656	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89657	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Current Tap Position	8L	
89658	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Max Tap Position	16L	
89659	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Min Tap Position	6L	
89660	11/12/2019 14:48	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
89661	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
89662	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	General Comments		
89663	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89664	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89665	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
89666	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
89667	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
89668	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
89669	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
89670	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89671	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89672	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89673	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
89674	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
89675	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
89676	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89677	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
89678	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Moisture and Leak Free?	y	
89679	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
89680	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Heaters (All) Functioning?	y	
89681	11/12/2019 15:09	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
89682	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
89683	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89684	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
89685	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89686	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations This Read Vac	0	
89687	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AL	149	
89688	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	General Comments		
89689	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
89690	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
89691	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
89692	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
89693	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89694	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89695	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89696	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89697	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
89698	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
89699	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
89700	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
89701	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89702	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89703	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AF	149	
89704	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Maintenance Operations	0	
89705	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	General Comments		
89706	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	General Comments		
89707	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Follow-up Action Required?	n	
89708	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89709	11/12/2019 12:57	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89710	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
89711	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	*C
89712	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
89713	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Follow-up Action Required?	n	
89714	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations Ground	0	
89715	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations C Ø	0	
89716	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations B Ø	0	
89717	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations A Ø	0	
89718	11/12/2019 13:53	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89719	11/12/2019 12:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89720	11/12/2019 10:16	Distribution	Brodhead Quarterly Inspection	FE00488	Fence	849-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
89721	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89722	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89723	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	LTC Totalizer Reading	4913.28	kw
89724	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations	6	
89725	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89726	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Present	22	*C
89727	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89728	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
89729	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
89730	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
89731	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89732	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
89733	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
89734	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89735	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
89736	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2982	
89737	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
89738	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations	1	
89739	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations	1	
89740	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
89741	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89742	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89743	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
89744	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89745	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89746	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89747	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps A Ø	150.0	
89748	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89749	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	General Comments		
89750	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	General Comments		
89751	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89752	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89753	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89754	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89755	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
89756	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89757	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
89758	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
89759	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
89760	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
89761	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	715.68	kw
89762	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	General Comments		
89763	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
89764	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
89765	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
89766	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89767	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
89768	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
89769	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89770	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
89771	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Follow-up Action Required?	n	
89772	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations Ground	0	
89773	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations C Ø	0	
89774	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations B Ø	0	
89775	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations A Ø	0	
89776	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
89777	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89778	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89779	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
89780	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89781	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89782	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
89783	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89784	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
89785	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89786	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushing Condition	Good	
89787	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps C Ø	10.0	
89788	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps B Ø	10.0	
89789	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps A Ø	10.0	
89790	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89791	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89792	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89793	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89794	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	General Comments		
89795	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	General Comments		
89796	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Found Counter	101108	
89797	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Left Counter	101116	
89798	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89799	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
89800	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89801	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89802	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89803	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89804	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
89805	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
89806	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
89807	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
89808	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89809	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
89810	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89811	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
89812	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
89813	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89814	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
89815	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7518	
89816	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
89817	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
89818	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
89819	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
89820	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
89821	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89822	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89823	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
89824	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89825	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89826	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89827	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89828	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89829	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89830	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
89831	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
89832	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
89833	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89834	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89835	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89836	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89837	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89838	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
89839	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
89840	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89841	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89842	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89843	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	0	
89844	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Tank Paint Condition	Good	
89845	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
89846	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
89847	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
89848	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
89849	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
89850	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
89851	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89852	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations This Read Vac	0	
89853	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
89854	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89855	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
89856	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
89857	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
89858	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Operations Since Last Insp	393	
89859	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89860	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Follow-up Action Required?	n	
89861	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
89862	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Foundation Condition	Good	
89863	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	General Comments		
89864	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
89865	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Grounds in Place?	y	
89866	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Heaters (All) Functioning?	y	
89867	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
89868	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Moisture and Leak Free?	y	
89869	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	210	
89870	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	210	
89871	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
89872	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
89873	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
89874	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
89875	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89876	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Follow-up Action Required?	n	
89877	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
89878	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	TV Winding Temp Present	25	°C
89879	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Max	22	°C
89880	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
89881	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89882	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89883	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89884	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
89885	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	General Comments		
89886	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	General Comments		
89887	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
89888	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
89889	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
89890	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3608.64	kw
89891	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
89892	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
89893	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
89894	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
89895	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Reading	.5118	
89896	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
89897	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
89898	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
89899	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
89900	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	General Comments		
89901	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89902	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps A Ø	100.0	
89903	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps B Ø	103.0	
89904	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89905	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89906	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Current Tap Position	7L	
89907	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Max Tap Position	4R	
89908	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
89909	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Min Tap Position	8L	
89910	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Follow-up Action Required?	n	
89911	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89912	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps C Ø	110.0	
89913	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushing Condition	Good	
89914	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Top Oil Temperature Present	26	°C
89915	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Top Oil Temperature Max	54	°C
89916	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89917	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89918	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
89919	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89920	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89921	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushings Connection/Risers	Good	
89922	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
89923	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
89924	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
89925	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Paint Condition	Good	
89926	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
89927	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
89928	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
89929	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89930	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	33	°C
89931	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	82	°C
89932	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	33	°C
89933	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	83	°C
89934	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
89935	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
89936	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
89937	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
89938	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Current Tap Position	8L	
89939	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Max Tap Position	5L	
89940	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Min Tap Position	12L	
89941	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Operations Since Last Insp	847	
89942	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Found Counter	219096	
89943	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Left Counter	219104	
89944	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89945	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Current Tap Position	16R	
89946	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Max Tap Position	16R	
89947	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89948	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
89949	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
89950	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
89951	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
89952	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89953	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Operations Since Last Insp	1545	
89954	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Min Tap Position	16R	
89955	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
89956	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
89957	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Reading	.8994	
89958	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
89959	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
89960	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
89961	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
89962	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
89963	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
89964	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
89965	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
89966	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Present	40	°C
89967	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Max	80	°C
89968	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Unknown Operations	0	
89969	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Tank Paint Condition	Good	
89970	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Switching Operations	0	
89971	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	General Comments		
89972	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
89973	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
89974	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	LTC Totalizer Reading	11174.40	kw
89975	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
89976	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
89977	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
89978	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations This Read Vac	2	
89979	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AL	40	
89980	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AF	40	
89981	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Moisture and Leak Free?	y	
89982	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
89983	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
89984	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
89985	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
89986	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
89987	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
89988	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
89989	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
89990	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Left Counter	130572	
89991	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
89992	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Current Tap Position	5L	
89993	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Max Tap Position	1L	
89994	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Min Tap Position	10L	
89995	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
89996	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Operations Since Last Insp	728	
89997	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
89998	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
89999	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90000	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90001	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
90002	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	General Comments		
90003	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90004	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	LTC Totalizer Reading	10103.04	kw
90005	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90006	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
90007	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Max	35	°C
90008	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Present	30	°C
90009	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90010	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90011	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90012	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90013	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90014	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90015	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90016	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
90017	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Reading	1.0524	
90018	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Max	35	°C
90019	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Present	28	°C
90020	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
90021	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
90022	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90023	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90024	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushing Condition	Good	
90025	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps C Ø	216.0	
90026	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps B Ø	222.0	
90027	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps A Ø	233.0	
90028	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90029	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90030	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90031	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations	31	
90032	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	VRR Time Delay	30	Seconds
90033	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90034	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90035	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
90036	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	LTC Operation Checked?	y	
90037	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	General Comments		
90038	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	Follow-up Action Required?	n	
90039	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	LTC0000130	LTCControl	432-1	LTC Control Insp	All Connections OK?	y	
90040	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
90041	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Follow-up Action Required?	n	
90042	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90043	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	General Comments		
90044	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	General Comments	Tap position indicator not working, transformer will have to come out of service to do a TTR to find correct tap position and fix.	
90045	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Follow-up Action Required?	n	
90046	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90047	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	General Comments		
90048	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	General Comments		
90049	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Found Counter	115632	
90050	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Left Counter	115637	
90051	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90052	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Moisture and Leak Free?	y	
90053	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Maintenance Operations	0	
90054	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Grounds in Place?	y	
90055	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	General Comments		
90056	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	General Comments		
90057	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Foundation Condition	Good	
90058	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Follow-up Action Required?	n	
90059	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Follow-up Action Required?	n	
90060	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations Ground	0	
90061	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations C Ø	0	
90062	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations B Ø	0	
90063	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90064	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations	10	
90065	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90066	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90067	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90068	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps A Ø	20.0	
90069	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps B Ø	20.0	
90070	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations A Ø	1	
90071	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90072	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Max	58	°C
90073	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Present	28	°C
90074	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90075	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps C Ø	20.0	
90076	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90077	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90078	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90079	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90080	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90081	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushing Condition	Good	
90082	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90083	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90084	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90085	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90086	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90087	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
90088	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Reading	1.1640	
90089	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Max	55	°C
90090	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Present	28	°C
90091	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
90092	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
90093	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90094	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
90095	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90096	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	General Comments		
90097	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	General Comments		
90098	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Foundation Condition	Good	
90099	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Follow-up Action Required?	n	
90100	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Follow-up Action Required?	n	
90101	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations Ground	0	
90102	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations C Ø	1	
90103	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations B Ø	0	
90104	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations A Ø	1	
90105	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
90106	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90107	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
90108	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90109	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90110	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90111	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90112	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
90113	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90114	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90115	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90116	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90117	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90118	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Follow-up Action Required?	n	
90119	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations	8	
90120	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90121	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90122	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90123	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps A Ø	230.0	
90124	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps B Ø	235.0	
90125	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps C Ø	225.0	
90126	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushing Condition	Good	
90127	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90128	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90129	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90130	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	LTC Totalizer Reading	8634.24	kw
90131	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90132	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	General Comments		
90133	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	General Comments		
90134	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90135	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90136	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90137	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90138	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90139	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90140	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Present	31	°C
90141	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
90142	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
90143	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
90144	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90145	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90146	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90147	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Maintenance Operations	0	
90148	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
90149	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Grounds in Place?	y	
90150	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Switching Operations	0	
90151	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90152	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations This Read Vac	1	
90153	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AL	808	
90154	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AF	808	
90155	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	General Comments		
90156	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
90157	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90158	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90159	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
90160	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90161	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90162	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90163	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90164	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
90165	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90166	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90167	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90168	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90169	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90170	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90171	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90172	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90173	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
90174	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
90175	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
90176	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
90177	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
90178	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
90179	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	100	°C
90180	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Switching Operations	0	
90181	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations This Read Vac	0	
90182	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AL	164	
90183	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AF	164	
90184	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Maintenance Operations	0	
90185	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	General Comments		
90186	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
90187	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
90188	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
90189	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
90190	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90191	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90192	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTC000547	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
90193	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90194	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
90195	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	General Comments		
90196	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Follow-up Action Required?	n	
90197	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
90198	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations Ground	0	
90199	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
90200	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90201	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Follow-up Action Required?	n	
90202	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90203	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90204	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	General Comments		
90205	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	General Comments		
90206	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90207	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	LTC Totalizer Reading	15955.20	kw
90208	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90209	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
90210	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations C Ø	0	
90211	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations B Ø	0	
90212	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations A Ø	0	
90213	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Max	55	°C
90214	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
90215	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90216	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments		
90217	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	General Comments		
90218	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	295795	
90219	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	295799	
90220	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	3L	
90221	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	11L	
90222	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	3L	
90223	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	1068	
90224	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90225	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90226	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
90227	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
90228	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
90229	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90230	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90231	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90232	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90233	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90234	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
90235	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	General Comments		
90236	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90237	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
90238	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
90239	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90240	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
90241	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
90242	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90243	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90244	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
90245	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
90246	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
90247	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
90248	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
90249	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
90250	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
90251	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90252	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90253	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	LTC0000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
90254	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	General Comments		
90255	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	General Comments		
90256	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
90257	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
90258	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
90259	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
90260	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
90261	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90262	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Foundation Condition	Good	
90263	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Follow-up Action Required?	n	
90264	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Follow-up Action Required?	n	
90265	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations Ground	0	
90266	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations C Ø	0	
90267	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations B Ø	0	
90268	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations A Ø	0	
90269	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90270	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90271	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90272	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90273	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90274	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90275	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90276	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90277	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90278	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90279	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90280	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90281	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90282	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90283	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	LTC0000545	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
90284	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90285	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90286	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90287	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90288	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90289	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90290	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90291	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
90292	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Unknown Operations	0	
90293	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90294	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90295	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
90296	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
90297	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	852.00	kw
90298	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
90299	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
90300	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
90301	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
90302	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90303	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90304	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90305	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90306	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90307	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90308	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90309	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90310	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90311	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90312	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90313	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Follow-up Action Required?	n	
90314	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90315	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90316	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
90317	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
90318	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90319	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
90320	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
90321	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90322	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90323	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90324	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90325	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
90326	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Follow-up Action Required?	n	
90327	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90328	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	General Comments		
90329	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Unknown Operations	0	
90330	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Switching Operations	0	
90331	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations This Read Vac	0	
90332	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AL	139	
90333	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AF	139	
90334	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Maintenance Operations	0	
90335	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	General Comments		
90336	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	General Comments		
90337	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
90338	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
90339	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
90340	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
90341	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
90342	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
90343	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90344	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90345	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90346	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90347	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps C Ø	723.0	
90348	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps B Ø	744.0	
90349	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps A Ø	794.0	
90350	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90351	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90352	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90353	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations	0	
90354	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	General Comments		
90355	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Found Counter	130566	
90356	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90357	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90358	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90359	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Follow-up Action Required?	n	
90360	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90361	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90362	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90363	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90364	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90365	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90366	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps C Ø	167.0	
90367	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90368	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps B Ø	170.0	
90369	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90370	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90371	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
90372	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90373	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90374	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
90375	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Reading	1.1080	
90376	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Max	60	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90377	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
90378	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
90379	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps A Ø	172.0	
90380	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90381	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90382	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90383	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Follow-up Action Required?	n	
90384	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations	0	
90385	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90386	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	General Comments		
90387	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	General Comments		
90388	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Found Counter	65108	
90389	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Left Counter	65111	
90390	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90391	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
90392	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Max Tap Position	5L	
90393	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Min Tap Position	12L	
90394	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
90395	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	55	°C
90396	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Operations Since Last Insp	876	
90397	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90398	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90399	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90400	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Unknown Operations	0	
90401	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Tank Paint Condition	Good	
90402	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Max	51	°C
90403	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Present	22	°C
90404	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
90405	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
90406	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3550	
90407	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
90408	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90409	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
90410	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
90411	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90412	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90413	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
90414	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90415	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
90416	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
90417	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	General Comments		
90418	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Found Counter	96053	
90419	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations	7	
90420	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90421	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90422	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90423	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps A Ø	113.0	
90424	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps B Ø	52.0	
90425	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps C Ø	63.0	
90426	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90427	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90428	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90429	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90430	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations A Ø	0	
90431	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations B Ø	0	
90432	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations C Ø	0	
90433	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations Ground	0	
90434	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
90435	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Follow-up Action Required?	n	
90436	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	General Comments		
90437	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	General Comments	Actual Counter	
90438	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Maintenance Operations	0	
90439	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Left Counter	96060	
90440	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90441	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Current Tap Position	8L	
90442	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Max Tap Position	6L	
90443	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Min Tap Position	11L	
90444	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
90445	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Operations Since Last Insp	283	
90446	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90447	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90448	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90449	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LTC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
90450	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AF	179	
90451	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AL	179	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90452	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations This Read Vac	0	
90453	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Switching Operations	0	
90454	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Unknown Operations	0	
90455	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1517	
90456	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
90457	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90458	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90459	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90460	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations Ground	0	
90461	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Follow-up Action Required?	n	
90462	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Follow-up Action Required?	n	
90463	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Foundation Condition	Good	
90464	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	General Comments		
90465	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	General Comments		
90466	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Grounds in Place?	y	
90467	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
90468	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Maintenance Operations	0	
90469	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Moisture and Leak Free?	y	
90470	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AF	96	
90471	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AL	96	
90472	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations This Read Vac	0	
90473	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
90474	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Switching Operations	0	
90475	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations	4	
90476	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90477	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90478	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Tank Paint Condition	Good	
90479	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Unknown Operations	0	
90480	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Follow-up Action Required?	n	
90481	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
90482	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
90483	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Present	45	°C
90484	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Max	55	°C
90485	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations	4	
90486	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90487	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Reading	.6348	
90488	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
90489	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90490	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90491	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Time Delay	30	Seconds
90492	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
90493	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90494	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	General Comments		
90495	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
90496	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Found Counter	37300	
90497	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Left Counter	37300	
90498	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90499	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
90500	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
90501	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
90502	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
90503	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	18	°C
90504	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	58	°C
90505	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations	4	
90506	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90507	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90508	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90509	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps A Ø	20.0	
90510	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps B Ø	40.0	
90511	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps C Ø	20.0	
90512	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushing Condition	Good	
90513	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90514	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90515	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90516	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90517	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90518	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90519	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90520	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90521	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90522	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations A Ø	0	
90523	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations B Ø	0	
90524	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations C Ø	0	
90525	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	All Connections OK?	y	
90526	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90527	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	General Comments		
90528	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	LTC Operation Checked?	y	
90529	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
90530	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
90531	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
90532	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
90533	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
90534	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
90535	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
90536	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
90537	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
90538	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
90539	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
90540	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
90541	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
90542	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
90543	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	General Comments		
90544	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
90545	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
90546	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Foundation Condition	Good	
90547	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
90548	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
90549	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
90550	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
90551	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
90552	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
90553	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
90554	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	General Comments		
90555	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
90556	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
90557	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCCControl	838-1	LTC Control Insp	VRR Time Delay	30	Seconds
90558	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Follow-up Action Required?	n	
90559	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90560	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	General Comments		
90561	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90562	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90563	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90564	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations A Ø	0	
90565	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations B Ø	0	
90566	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations C Ø	0	
90567	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations Ground	0	
90568	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Follow-up Action Required?	n	
90569	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Follow-up Action Required?	n	
90570	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Foundation Condition	Good	
90571	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	General Comments		
90572	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	General Comments		
90573	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Grounds in Place?	y	
90574	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCCControl	609-1	LTC Control Insp	VRR Time Delay	30	Seconds
90575	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCCControl	609-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
90576	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCCControl	609-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
90577	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Follow-up Action Required?	n	
90578	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Follow-up Action Required?	n	
90579	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Operations Ground	0	
90580	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Operations C Ø	0	
90581	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Operations B Ø	0	
90582	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Operations A Ø	0	
90583	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90584	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90585	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90586	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90587	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90588	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90589	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90590	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90591	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90592	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushing Condition	Good	
90593	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Amps C Ø	20.0	
90594	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Amps B Ø	40.0	
90595	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Amps A Ø	60.0	
90596	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90597	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90598	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90599	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B80263	BreakerVacuum	600-0475	VCB Readings	9 Month Operations	4	
90600	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCCControl	609-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
90601	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCCControl	609-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90602	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Operation Checked?	y	
90603	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	General Comments		
90604	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Follow-up Action Required?	n	
90605	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	All Connections OK?	y	
90606	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
90607	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90608	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90609	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90610	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
90611	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Follow-up Action Required?	n	
90612	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90613	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	General Comments		
90614	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	General Comments		
90615	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Found Counter	56211	
90616	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Left Counter	56219	
90617	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90618	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Current Tap Position	1R	
90619	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90620	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps A Ø	50.0	
90621	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps B Ø	20.0	
90622	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps C Ø	20.0	
90623	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushing Condition	Good	
90624	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90625	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90626	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90627	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90628	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90629	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Max Tap Position	3R	
90630	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Min Tap Position	9L	
90631	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Operations Since Last Insp	1505	
90632	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
90633	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90634	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90635	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90636	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90637	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90638	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90639	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90640	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
90641	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
90642	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Present	40	°C
90643	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Max	40	°C
90644	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
90645	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90646	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	LTC Totalizer Reading	11426.40	kw
90647	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90648	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	General Comments		
90649	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	General Comments		
90650	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90651	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90652	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90653	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	General Comments		
90654	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	General Comments		
90655	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Found Counter	16235	
90656	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Left Counter	16241	
90657	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90658	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Current Tap Position	9L	
90659	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Max Tap Position	14L	
90660	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Min Tap Position	2L	
90661	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Operations Since Last Insp	791	
90662	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90663	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90664	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90665	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Unknown Operations	0	
90666	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Tank Paint Condition	Good	
90667	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Switching Operations	0	
90668	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
90669	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations This Read Vac	0	
90670	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations	10	
90671	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90672	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AL	103	
90673	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AF	103	
90674	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90675	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90676	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps A Ø	120.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90677	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps B Ø	180.0	
90678	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps C Ø	120.0	
90679	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushing Condition	Good	
90680	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90681	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90682	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90683	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90684	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90685	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Moisture and Leak Free?	y	
90686	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Maintenance Operations	0	
90687	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Heaters (All) Functioning?	y	
90688	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Grounds in Place?	y	
90689	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	General Comments		
90690	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	General Comments		
90691	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Foundation Condition	Good	
90692	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Follow-up Action Required?	n	
90693	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90694	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90695	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90696	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90697	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90698	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90699	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90700	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90701	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90702	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90703	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90704	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90705	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90706	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90707	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90708	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
90709	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
90710	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
90711	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90712	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90713	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Follow-up Action Required?	n	
90714	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90715	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	General Comments		
90716	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Operations Since Last Insp	141	
90717	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
90718	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Min Tap Position	9L	
90719	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Max Tap Position	1L	
90720	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Current Tap Position	3L	
90721	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
90722	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Left Counter	250386	
90723	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Found Counter	250380	
90724	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	General Comments		
90725	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	General Comments		
90726	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
90727	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Follow-up Action Required?	n	
90728	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations	0	
90729	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90730	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90731	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	General Comments		
90732	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90733	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	LTC Totalizer Reading	3801.60	kw
90734	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90735	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90736	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps A Ø	223.0	
90737	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps B Ø	232.0	
90738	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps C Ø	225.0	
90739	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90740	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90741	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90742	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90743	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations A Ø	0	
90744	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations B Ø	0	
90745	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations C Ø	0	
90746	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations Ground	0	
90747	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
90748	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Follow-up Action Required?	n	
90749	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	General Comments		
90750	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	General Comments		
90751	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90752	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AF	187	
90753	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AL	187	
90754	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations This Read Vac	0	
90755	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Switching Operations	0	
90756	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Unknown Operations	0	
90757	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
90758	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
90759	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Max	30	°C
90760	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Present	20	°C
90761	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
90762	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90763	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90764	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90765	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90766	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
90767	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Max	50	°C
90768	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Reading	.9260	
90769	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
90770	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90771	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90772	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90773	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90774	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90775	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90776	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90777	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Max	40	°C
90778	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
90779	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
90780	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90781	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90782	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90783	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
90784	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
90785	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90786	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
90787	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
90788	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90789	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	General Comments		
90790	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	General Comments		
90791	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
90792	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
90793	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
90794	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2666.40	kw
90795	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
90796	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
90797	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
90798	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
90799	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
90800	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
90801	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90802	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90803	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
90804	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
90805	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90806	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
90807	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1110	
90808	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations	1	
90809	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90810	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90811	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90812	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps A Ø	255.0	
90813	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps B Ø	235.0	
90814	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps C Ø	255.0	
90815	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushing Condition	Good	
90816	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90817	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90818	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90819	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90820	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90821	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90822	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90823	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90824	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90825	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations A Ø	0	
90826	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90827	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations C Ø	0	
90828	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations Ground	0	
90829	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Follow-up Action Required?	n	
90830	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Follow-up Action Required?	n	
90831	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Foundation Condition	Good	
90832	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	General Comments		
90833	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	General Comments		
90834	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Grounds in Place?	y	
90835	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
90836	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Maintenance Operations	0	
90837	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
90838	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AF	149	
90839	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AL	149	
90840	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations This Read Vac	1	
90841	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Switching Operations	1	
90842	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Tank Paint Condition	Good	
90843	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Unknown Operations	0	
90844	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90845	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90846	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90847	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90848	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90849	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90850	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Foundation Condition	Good	
90851	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Follow-up Action Required?	n	
90852	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Follow-up Action Required?	n	
90853	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Fault Operations	0	
90854	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
90855	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
90856	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90857	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90858	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
90859	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
90860	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Oil Level	Good	
90861	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Condition	Good	
90862	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
90863	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations C Ø	0	
90864	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations Ground	0	
90865	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Follow-up Action Required?	n	
90866	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Follow-up Action Required?	n	
90867	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Foundation Condition	Good	
90868	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	General Comments		
90869	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	General Comments		
90870	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90871	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90872	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90873	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90874	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90875	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
90876	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90877	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Grounds in Place?	y	
90878	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Maintenance Operations	1	
90879	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Moisture and Leak Free?	y	
90880	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AF	409	
90881	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AL	409	
90882	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations This Read Vac	1	
90883	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
90884	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Switching Operations	0	
90885	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Tank Paint Condition	Good	
90886	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Unknown Operations	0	
90887	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90888	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90889	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90890	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Follow-up Action Required?	n	
90891	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90892	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90893	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	General Comments		
90894	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	General Comments		
90895	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90896	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	LTC Totalizer Reading	4250.88	kw
90897	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90898	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
90899	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Max	60	°C
90900	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Present	40	°C
90901	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
90902	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
90903	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
90904	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
90905	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Pressure OK?	y	
90906	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Leaks	None	
90907	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
90908	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
90909	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
90910	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
90911	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90912	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90913	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
90914	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Reading	.5904	
90915	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
90916	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTC0000355	LTCControl	687-1	LTC Control Insp	All Connections OK?	y	
90917	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTC0000355	LTCControl	687-1	LTC Control Insp	Follow-up Action Required?	n	
90918	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTC0000355	LTCControl	687-1	LTC Control Insp	General Comments		
90919	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTC0000355	LTCControl	687-1	LTC Control Insp	LTC Operation Checked?	y	
90920	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
90921	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	LTC0000355	LTCControl	687-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
90922	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
90923	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
90924	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	LTC Totalizer Reading	13334.40	kw
90925	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
90926	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	General Comments		
90927	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	General Comments		
90928	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
90929	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
90930	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Follow-up Action Required?	n	
90931	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
90932	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
90933	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
90934	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
90935	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
90936	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
90937	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
90938	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Reading	.5280	
90939	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Max	30	°C
90940	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Present	20	°C
90941	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
90942	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
90943	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
90944	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
90945	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
90946	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
90947	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
90948	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
90949	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90950	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90951	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90952	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations	10	
90953	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
90954	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
90955	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
90956	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps A Ø	343.0	
90957	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps B Ø	348.0	
90958	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps C Ø	362.0	
90959	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushing Condition	Good	
90960	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
90961	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
90962	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
90963	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
90964	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
90965	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
90966	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
90967	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
90968	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
90969	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
90970	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
90971	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
90972	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations A Ø	0	
90973	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations B Ø	0	
90974	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Unknown Operations	0	
90975	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Paint Condition	Good	
90976	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
90977	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
90978	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
90979	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
90980	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Switching Operations	0	
90981	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
90982	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
90983	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-02-18 00:00:00.000000	
90984	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations This Read Oil	0	
90985	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AL	55	
90986	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AF	55	
90987	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Number of Ops last 9 Months	0	
90988	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
90989	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Maintenance Operations	0	
90990	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
90991	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Grounds in Place?	y	
90992	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	General Comments		
90993	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	General Comments		
90994	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
90995	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
90996	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
90997	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
90998	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
90999	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Foundation Condition	Good	
91000	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Follow-up Action Required?	n	
91001	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Follow-up Action Required?	n	
91002	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations Ground	0	
91003	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AL	480	
91004	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AF	480	
91005	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Moisture and Leak Free?	y	
91006	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
91007	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
91008	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
91009	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	775	
91010	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	775	
91011	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
91012	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91013	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
91014	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
91015	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
91016	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
91017	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
91018	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
91019	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
91020	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
91021	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
91022	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
91023	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
91024	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
91025	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
91026	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
91027	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
91028	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
91029	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	General Comments		
91030	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
91031	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91032	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations A Ø	0	
91033	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations B Ø	0	
91034	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations C Ø	0	
91035	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations Ground	0	
91036	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Follow-up Action Required?	n	
91037	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Maintenance Operations	3	
91038	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Grounds in Place?	y	
91039	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
91040	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
91041	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	General Comments		
91042	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
91043	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
91044	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	LTC Totalizer Reading	4043.52	kw
91045	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
91046	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
91047	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Max	65	°C
91048	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations C Ø	0	
91049	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations B Ø	0	
91050	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations A Ø	0	
91051	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91052	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91053	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91054	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91055	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91056	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91057	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91058	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91059	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91060	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushing Condition	Good	
91061	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps C Ø	150.0	
91062	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps B Ø	180.0	
91063	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Present	35	°C
91064	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91065	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
91066	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91067	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	15.0	
91068	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	15.0	
91069	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	15.0	
91070	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
91071	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91072	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91073	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91074	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91075	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91076	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
91077	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
91078	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
91079	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
91080	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
91081	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
91082	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
91083	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
91084	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	283.52	kw
91085	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
91086	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
91087	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	49	°C
91088	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
91089	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91090	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
91091	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91092	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
91093	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
91094	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Unknown Operations	0	
91095	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Tank Paint Condition	Good	
91096	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Switching Operations	0	
91097	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91098	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations This Read Vac	0	
91099	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AL	338	
91100	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AF	338	
91101	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
91102	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
91103	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3544	
91104	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
91105	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
91106	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
91107	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
91108	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
91109	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
91110	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
91111	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
91112	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
91113	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
91114	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
91115	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
91116	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Follow-up Action Required?	n	
91117	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Unknown Operations	0	
91118	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Tank Paint Condition	Good	
91119	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Switching Operations	0	
91120	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91121	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations This Read Vac	3	
91122	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Moisture and Leak Free?	y	
91123	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Maintenance Operations	0	
91124	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Heaters (All) Functioning?	y	
91125	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Grounds in Place?	y	
91126	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91127	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	General Comments		
91128	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91129	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91130	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91131	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91132	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
91133	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
91134	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
91135	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
91136	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
91137	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
91138	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
91139	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
91140	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91141	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
91142	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
91143	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
91144	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
91145	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
91146	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Reading	.4548	
91147	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Follow-up Action Required?	n	
91148	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
91149	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
91150	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
91151	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91152	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
91153	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91154	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
91155	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	49	°C
91156	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
91157	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
91158	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Max	30	°C
91159	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Present	30	°C
91160	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
91161	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
91162	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Unknown Operations	0	
91163	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Tank Paint Condition	Good	
91164	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Switching Operations	0	
91165	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91166	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations This Read Vac	0	
91167	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AL	247	
91168	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AF	247	
91169	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Moisture and Leak Free?	y	
91170	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Maintenance Operations	0	
91171	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Grounds in Place?	y	
91172	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	General Comments		
91173	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	General Comments		
91174	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Foundation Condition	Good	
91175	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	General Comments		
91176	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	General Comments		
91177	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Grounds in Place?	y	
91178	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Heaters (All) Functioning?	y	
91179	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Maintenance Operations	0	
91180	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Moisture and Leak Free?	y	
91181	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AF	97	
91182	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AL	97	
91183	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations This Read Vac	0	
91184	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91185	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Switching Operations	0	
91186	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Tank Paint Condition	Good	
91187	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Unknown Operations	0	
91188	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Present	20	°C
91189	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Max	35	°C
91190	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3594	
91191	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
91192	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
91193	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
91194	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
91195	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
91196	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91197	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
91198	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Foundation Condition	Good	
91199	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Follow-up Action Required?	n	
91200	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91201	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Present	28	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91202	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Max	40	°C	
91203	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00		
91204	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00		
91205	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1725.12	kw	
91206	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00		
91207	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi	
91208	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
91209	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y		
91210	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KT0048	NonLTC	027-5	NonLTC Transformer Readings	General Comments			
91211	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
91212	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
91213	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
91214	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200		
91215	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Reading	.5616		
91216	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00		
91217	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00		
91218	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y		
91219	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Foundation Condition	Good		
91220	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Follow-up Action Required?	n		
91221	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y		
91222	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y		
91223	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y		
91224	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y		
91225	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Structure	838-Structure	Structure Patrol Inspection	All Identified and Legible?	y		
91226	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Yard Lights Working?	y		
91227	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Vegetation	None		
91228	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y		
91229	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y		
91230	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y		
91231	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good		
91232	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y		
91233	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	General Comments			
91234	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Follow-up Action Required?	n		
91235	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y		
91236	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y		
91237	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y		
91238	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good		
91239	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Clear of Trash?	y		
91240	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n		
91241	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Condition	Good		
91242	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
91243	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good		
91244	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
91245	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		
91246	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
91247	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Clear of Obstacles?	y		
91248	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y		
91249	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Yard	838-Yard	Yard Patrol Inspection	Ambient Temp	55	°F	
91250	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y		
91251	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	General Comments			
91252	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y		
91253	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y		
91254	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
91255	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y		
91256	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Follow-up Action Required?	n		
91257	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Ties Intact?	y		
91258	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y		
91259	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y		
91260	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y		
91261	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y		
91262	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y		
91263	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y		
91264	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	Fence	838-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
91265	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
91266	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
91267	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Condition	Good		
91268	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Operational?	y		
91269	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
91270	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Readings	Follow-up Action Required?	n		
91271	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Foundation Condition	Good		
91272	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
91273	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	General Comments			
91274	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Readings	General Comments			
91275	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Patrol Inspection	Grounds in Place?	y		
91276	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	WithLTC	844-2	LTC Transformer Readings	LTC Totalizer Reading	6549.12	kw	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91277	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
91278	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
91279	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Max	52	°C
91280	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Present	30	°C
91281	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
91282	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
91283	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91284	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations C Ø	0	
91285	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations Ground	0	
91286	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Follow-up Action Required?	n	
91287	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
91288	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
91289	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	General Comments		
91290	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
91291	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Found Counter	320205	
91292	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Left Counter	320205	
91293	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
91294	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
91295	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Follow-up Action Required?	n	
91296	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Unknown Operations	0	
91297	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Switching Operations	0	
91298	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
91299	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
91300	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AL	155	
91301	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AF	155	
91302	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Maintenance Operations	0	
91303	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
91304	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
91305	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	108	
91306	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
91307	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
91308	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
91309	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
91310	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	General Comments	Actual Counter	
91311	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Months Operations	1	
91312	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	General Comments		
91313	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
91314	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
91315	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
91316	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
91317	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
91318	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
91319	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91320	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91321	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91322	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91323	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps C Ø	0.0	
91324	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps B Ø	0.0	
91325	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps A Ø	0.0	
91326	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91327	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91328	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91329	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	9 Month Operations	0	
91330	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	General Comments		
91331	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	General Comments		
91332	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Maintenance Operations	0	
91333	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AF	246	
91334	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AL	246	
91335	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations This Read Vac	0	
91336	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Switching Operations	0	
91337	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Unknown Operations	0	
91338	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
91339	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
91340	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
91341	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps A Ø	270.0	
91342	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps B Ø	50.0	
91343	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps C Ø	130.0	
91344	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
91345	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
91346	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
91347	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
91348	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations A Ø	0	
91349	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations B Ø	0	
91350	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations C Ø	0	
91351	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91352	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
91353	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Follow-up Action Required?	n	
91354	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	General Comments		
91355	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	General Comments	n	
91356	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
91357	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
91358	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
91359	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Maintenance Operations	0	
91360	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Moisture and Leak Free?	y	
91361	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AF	297	
91362	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AL	297	
91363	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations This Read Vac	0	
91364	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91365	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Switching Operations	0	
91366	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Tank Paint Condition	Good	
91367	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Unknown Operations	0	
91368	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
91369	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
91370	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
91371	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91372	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91373	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91374	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91375	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91376	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91377	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91378	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Follow-up Action Required?	n	
91379	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
91380	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	General Comments		
91381	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	General Comments		
91382	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Found Counter	49554	
91383	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Left Counter	49554	
91384	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
91385	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91386	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91387	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
91388	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
91389	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
91390	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
91391	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
91392	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
91393	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
91394	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
91395	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
91396	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
91397	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
91398	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
91399	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
91400	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	879	
91401	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	879	
91402	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
91403	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91404	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
91405	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
91406	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
91407	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Current Tap Position	8L	
91408	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Max Tap Position	5L	
91409	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Min Tap Position	11L	
91410	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
91411	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Operations Since Last Insp	1027	
91412	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
91413	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
91414	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
91415	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations	16	
91416	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91417	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91418	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91419	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps A Ø	75.0	
91420	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps B Ø	98.0	
91421	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps C Ø	83.0	
91422	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91423	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91424	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91425	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91426	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
91427	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations B Ø	0	
91428	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	145.0	
91429	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
91430	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91431	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91432	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91433	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91434	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
91435	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
91436	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	General Comments	Yard is a muddy mess due to some recent work at the station.	
91437	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
91438	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
91439	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
91440	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
91441	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
91442	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Trash?	y	
91443	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
91444	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
91445	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91446	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91447	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91448	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91449	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91450	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
91451	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
91452	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
91453	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
91454	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
91455	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
91456	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
91457	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
91458	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
91459	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
91460	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
91461	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
91462	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
91463	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	861	
91464	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	861	
91465	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
91466	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91467	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
91468	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
91469	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91470	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91471	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps A Ø	120.0	
91472	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps B Ø	120.0	
91473	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps C Ø	120.0	
91474	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushing Condition	Good	
91475	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91476	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91477	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91478	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91479	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91480	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91481	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91482	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91483	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
91484	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
91485	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91486	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
91487	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
91488	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
91489	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
91490	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
91491	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
91492	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
91493	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
91494	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
91495	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
91496	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
91497	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	0927	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
91498	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91499	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91500	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
91501	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91502	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AF	360	
91503	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AL	360	
91504	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations This Read AM	0	
91505	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Switching Operations	0	
91506	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Unknown Operations	0	
91507	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations	8	
91508	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91509	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91510	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91511	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps A Ø	60.0	
91512	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps B Ø	120.0	
91513	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps C Ø	100.0	
91514	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushing Condition	Good	
91515	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91516	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91517	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91518	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91519	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91520	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91521	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91522	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91523	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91524	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations A Ø	0	
91525	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations B Ø	0	
91526	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations C Ø	0	
91527	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91528	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91529	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91530	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91531	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations A Ø	0	
91532	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations B Ø	0	
91533	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations C Ø	0	
91534	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations Ground	0	
91535	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Follow-up Action Required?	n	
91536	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Follow-up Action Required?	n	
91537	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Foundation Condition	Good	
91538	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	General Comments		
91539	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	General Comments		
91540	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Grounds in Place?	y	
91541	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
91542	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Maintenance Operations	0	
91543	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Moisture and Leak Free?	y	
91544	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AF	420	
91545	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AL	420	
91546	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations Ground	0	
91547	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations This Read Vac	0	
91548	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91549	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Switching Operations	0	
91550	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Tank Paint Condition	Good	
91551	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Unknown Operations	0	
91552	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Follow-up Action Required?	n	
91553	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Follow-up Action Required?	n	
91554	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Foundation Condition	Good	
91555	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	General Comments		
91556	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	General Comments		
91557	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Grounds in Place?	y	
91558	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Maintenance Operations	0	
91559	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Moisture and Leak Free?	y	
91560	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AF	684	
91561	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AL	684	
91562	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations This Read Vac	0	
91563	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
91564	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Switching Operations	0	
91565	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Tank Paint Condition	Good	
91566	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Unknown Operations	0	
91567	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
91568	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91569	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91570	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91571	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	145.0	
91572	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	145.0	
91573	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
91574	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
91575	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	General Comments		
91576	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
91577	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
91578	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Operations Counter	9	
91579	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
91580	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Leaks	None	
91581	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91582	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations	1	
91583	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
91584	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
91585	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	General Comments		
91586	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
91587	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
91588	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
91589	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
91590	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
91591	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
91592	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
91593	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Trash?	y	
91594	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
91595	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
91596	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
91597	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
91598	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
91599	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
91600	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
91601	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
91602	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
91603	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
91604	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.1	VDC
91605	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.1	VDC
91606	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
91607	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
91608	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
91609	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
91610	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
91611	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
91612	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	General Comments		
91613	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
91614	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Vegetation	None	
91615	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
91616	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
91617	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
91618	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
91619	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
91620	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
91621	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
91622	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AF	141	
91623	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AL	141	
91624	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations This Read Vac	0	
91625	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Switching Operations	0	
91626	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Tank Paint Condition	Good	
91627	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Unknown Operations	0	
91628	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps C Ø	290.0	
91629	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps B Ø	289.0	
91630	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps A Ø	277.0	
91631	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91632	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91633	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91634	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations	1	
91635	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
91636	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
91637	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	General Comments		
91638	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
91639	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
91640	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Operations Counter	52	
91641	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
91642	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Leaks	None	
91643	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
91644	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
91645	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
91646	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
91647	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
91648	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
91649	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
91650	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
91651	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Current Tap Position	6L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91652	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y		
91653	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n		
91654	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Foundation Condition	Good		
91655	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good		
91656	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	General Comments			
91657	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Grounds in Place?	y		
91658	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Max Tap Position	2L		
91659	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Min Tap Position	12L		
91660	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y		
91661	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y		
91662	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Oil Level	Good		
91663	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y		
91664	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts	
91665	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Regulator As Left Counter	22483		
91666	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset		
91667	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good		
91668	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Leaks	None		
91669	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good		
91670	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y		
91671	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y		
91672	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y		
91673	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Surge Arrester Condition	Blown		
91674	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good		
91675	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None		
91676	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	547		
91677	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y		
91678	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments			
91679	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n		
91680	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y		
91681	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good		
91682	11/11/2019 15:22	Distribution	Andover Quarterly Inspection DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good		
91683	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
91684	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y		
91685	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y		
91686	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y		
91687	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y		
91688	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y		
91689	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y		
91690	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Ties Intact?	y		
91691	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Follow-up Action Required?	n		
91692	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y		
91693	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
91694	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y		
91695	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y		
91696	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	General Comments			
91697	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection FE000373	Fence	441-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y		
91698	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Ambient Temp	55	*F	
91699	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y		
91700	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Obstacles?	y		
91701	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Trash?	y		
91702	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y		
91703	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good		
91704	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y		
91705	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y		
91706	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y		
91707	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Follow-up Action Required?	n		
91708	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	General Comments			
91709	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y		
91710	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y		
91711	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Vegetation	None		
91712	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection YD000379	Yard	441-Yard	Yard Patrol Inspection	Yard Lights Working?	y		
91713	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y		
91714	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y		
91715	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y		
91716	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y		
91717	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y		
91718	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None		
91719	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y		
91720	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Foundation Condition	Good		
91721	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y		
91722	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y		
91723	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	General Comments	Lightning arrester on middle phase of line side circuit 4641 is blown.		
91724	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Ground Connections Intact?	y		
91725	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y		
91726	11/12/2019 7:21	Distribution	Wise Quarterly Inspection ST000011	Structure	337-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
91727	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
91728	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
91729	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
91730	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
91731	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
91732	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
91733	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps A Ø	18.0	
91734	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
91735	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps C Ø	9.0	
91736	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
91737	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
91738	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
91739	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
91740	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
91741	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
91742	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
91743	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
91744	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
91745	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
91746	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	General Comments		
91747	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
91748	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
91749	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Operations Counter	58	
91750	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
91751	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Leaks	None	
91752	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
91753	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
91754	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
91755	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	General Comments		
91756	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	All Connections OK?	y	
91757	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Area Ambient Temp	60	"F
91758	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
91759	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
91760	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
91761	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
91762	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
91763	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
91764	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
91765	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	General Comments		
91766	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
91767	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
91768	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
91769	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
91770	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
91771	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Leaks	None	
91772	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
91773	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
91774	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Regulator As Left Counter	20851	
91775	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
91776	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
91777	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
91778	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
91779	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
91780	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Min Tap Position	12L	
91781	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
91782	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
91783	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	General Comments		
91784	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
91785	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
91786	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
91787	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
91788	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
91789	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
91790	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
91791	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
91792	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
91793	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
91794	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations This Read Vac	1	
91795	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AL	173	
91796	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AF	173	
91797	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
91798	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Leaks	None	
91799	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
91800	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
91801	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35311	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
91802	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
91803	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
91804	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Maintenance Operations	0	
91805	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Grounds in Place?	y	
91806	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	General Comments		
91807	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	General Comments		
91808	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Foundation Condition	Good	
91809	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Follow-up Action Required?	n	
91810	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Follow-up Action Required?	n	
91811	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations Ground	0	
91812	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
91813	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
91814	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
91815	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
91816	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
91817	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
91818	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
91819	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
91820	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
91821	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	11L	
91822	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
91823	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
91824	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
91825	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
91826	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
91827	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
91828	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
91829	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
91830	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
91831	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
91832	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
91833	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
91834	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
91835	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Unknown Operations	0	
91836	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
91837	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
91838	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
91839	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
91840	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
91841	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
91842	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
91843	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
91844	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Tank Paint Condition	Good	
91845	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Switching Operations	1	
91846	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Foundation Condition	Good	
91847	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Follow-up Action Required?	n	
91848	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Follow-up Action Required?	n	
91849	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations Ground	0	
91850	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations C Ø	0	
91851	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations B Ø	0	
91852	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations A Ø	0	
91853	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91854	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91855	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91856	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91857	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91858	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91859	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91860	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91861	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91862	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushing Condition	Good	
91863	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps C Ø	58.0	
91864	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps B Ø	62.0	
91865	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps A Ø	60.0	
91866	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91867	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91868	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations B Ø	0	
91869	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations A Ø	0	
91870	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91871	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91872	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91873	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91874	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91875	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91876	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
91877	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91878	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91879	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushing Condition	Good	
91880	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Maintenance Operations	0	
91881	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Moisture and Leak Free?	y	
91882	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AF	144	
91883	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AL	144	
91884	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations This Read Vac	0	
91885	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Switching Operations	0	
91886	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Tank Paint Condition	Good	
91887	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Unknown Operations	0	
91888	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	9 Month Operations	0	
91889	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91890	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91891	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91892	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps A Ø	11.0	
91893	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps B Ø	9.0	
91894	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps C Ø	13.0	
91895	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushing Condition	Good	
91896	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91897	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91898	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91899	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91900	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91901	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91902	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91903	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91904	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91905	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations A Ø	0	
91906	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations B Ø	0	
91907	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations C Ø	0	
91908	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations Ground	0	
91909	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Follow-up Action Required?	n	
91910	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Follow-up Action Required?	n	
91911	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Foundation Condition	Good	
91912	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	General Comments		
91913	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	General Comments		
91914	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Grounds in Place?	y	
91915	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Maintenance Operations	0	
91916	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Moisture and Leak Free?	y	
91917	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	General Comments		
91918	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
91919	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
91920	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
91921	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
91922	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
91923	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
91924	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
91925	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
91926	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
91927	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
91928	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
91929	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps B Ø	6.0	
91930	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
91931	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
91932	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
91933	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
91934	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	9 Month Operations	0	
91935	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
91936	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
91937	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
91938	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps A Ø	256.0	
91939	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps B Ø	237.0	
91940	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps C Ø	220.0	
91941	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushing Condition	Good	
91942	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
91943	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
91944	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
91945	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
91946	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
91947	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
91948	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
91949	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
91950	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
91951	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
91952	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations B Ø	0	
91953	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations C Ø	0	
91954	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations Ground	0	
91955	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Follow-up Action Required?	n	
91956	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Follow-up Action Required?	n	
91957	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Foundation Condition	Good	
91958	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	General Comments		
91959	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	General Comments		
91960	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Grounds in Place?	y	
91961	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
91962	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
91963	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
91964	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
91965	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
91966	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations C Ø	0	
91967	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
91968	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
91969	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
91970	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
91971	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
91972	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
91973	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	General Comments	Cir 277 has 1 blown lightning arrester	
91974	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
91975	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
91976	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Foundation Condition	Good	
91977	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
91978	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
91979	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
91980	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
91981	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
91982	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
91983	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
91984	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
91985	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
91986	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
91987	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
91988	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
91989	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
91990	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
91991	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
91992	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
91993	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
91994	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
91995	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
91996	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
91997	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
91998	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Swept?	y	
91999	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
92000	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
92001	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
92002	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
92003	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
92004	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
92005	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
92006	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Broom on Site?	y	
92007	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
92008	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
92009	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
92010	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
92011	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
92012	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	16L	
92013	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
92014	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
92015	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92016	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	General Comments		
92017	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
92018	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
92019	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92020	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	General Comments		
92021	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92022	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
92023	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
92024	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92025	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92026	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
92027	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92028	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92029	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92030	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92031	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
92032	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
92033	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92034	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
92035	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
92036	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
92037	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
92038	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
92039	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
92040	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
92041	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
92042	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	General Comments		
92043	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
92044	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
92045	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
92046	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
92047	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Follow-up Action Required?	n	
92048	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
92049	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
92050	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	General Comments		
92051	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	General Comments		
92052	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
92053	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Totalizer Reading	14508.48	kw
92054	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
92055	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
92056	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
92057	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Max	48	°C
92058	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Present	32	°C
92059	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
92060	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
92061	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
92062	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
92063	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
92064	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
92065	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
92066	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	9 Month Operations	0	
92067	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92068	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92069	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92070	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps A Ø	80.0	
92071	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
92072	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
92073	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
92074	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Reading	.9520	
92075	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Max	54	°C
92076	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Present	34	°C
92077	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
92078	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
92079	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Follow-up Action Required?	n	
92080	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
92081	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
92082	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
92083	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
92084	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
92085	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
92086	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	General Comments		
92087	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	General Comments		
92088	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Found Counter	100278	
92089	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Left Counter	100283	
92090	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
92091	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Current Tap Position	3L	
92092	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Max Tap Position	6R	
92093	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Min Tap Position	16L	
92094	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
92095	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
92096	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
92097	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Operations Since Last Insp	5332	
92098	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps B Ø	84.0	
92099	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps C Ø	80.0	
92100	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushing Condition	Good	
92101	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92102	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92103	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92104	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92105	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92106	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92107	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92108	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92109	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92110	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations A Ø	0	
92111	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations B Ø	0	
92112	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations C Ø	0	
92113	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations Ground	0	
92114	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
92115	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
92116	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
92117	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	108959	
92118	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
92119	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
92120	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
92121	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
92122	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92123	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
92124	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
92125	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
92126	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
92127	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
92128	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
92129	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
92130	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
92131	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments		
92132	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
92133	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
92134	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
92135	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
92136	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92137	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
92138	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
92139	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
92140	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	54121	
92141	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
92142	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
92143	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
92144	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
92145	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
92146	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
92147	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
92148	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Operations Counter	1771	
92149	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
92150	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Leaks	None	
92151	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
92152	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
92153	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Leaks	None	
92154	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
92155	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
92156	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Regulator As Left Counter	19522	
92157	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
92158	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
92159	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
92160	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92161	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	General Comments		
92162	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
92163	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
92164	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK0064	BreakerVacuum	312-4645	VCB Readings	Maintenance Operations	0	
92165	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
92166	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
92167	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92168	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	General Comments	Fabric is rusty, couple of spots at bottom of fence with 4 inch gaps .	
92169	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92170	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
92171	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Follow-up Action Required?	n	
92172	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Foundation Condition	Good	
92173	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	General Comments		
92174	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	General Comments		
92175	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Grounds in Place?	y	
92176	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92177	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Moisture and Leak Free?	y	
92178	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AF	158	
92179	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AL	158	
92180	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations This Read Vac	0	
92181	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Switching Operations	0	
92182	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Tank Paint Condition	Good	
92183	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Unknown Operations	0	
92184	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
92185	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
92186	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92187	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
92188	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
92189	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
92190	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
92191	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
92192	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
92193	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
92194	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
92195	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	General Comments		
92196	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
92197	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
92198	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
92199	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
92200	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92201	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
92202	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
92203	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
92204	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12559	
92205	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
92206	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Unknown Operations	0	
92207	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Switching Operations	0	
92208	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations This Read AM	0	
92209	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AL	512	
92210	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AF	512	
92211	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Maintenance Operations	0	
92212	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
92213	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
92214	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
92215	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations	0	
92216	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92217	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92218	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92219	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps A Ø	160.0	
92220	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps B Ø	160.0	
92221	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps C Ø	200.0	
92222	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushing Condition	Good	
92223	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92224	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92225	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92226	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92227	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92228	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92229	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92230	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92231	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92232	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations A Ø	0	
92233	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations B Ø	0	
92234	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations C Ø	0	
92235	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations Ground	0	
92236	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Follow-up Action Required?	n	
92237	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
92238	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations	1	
92239	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps A Ø	109.0	
92240	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps B Ø	113.0	
92241	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps C Ø	90.0	
92242	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushing Condition	Good	
92243	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92244	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92245	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92246	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92247	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92248	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92249	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92250	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92251	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92252	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations A Ø	0	
92253	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations B Ø	0	
92254	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations C Ø	0	
92255	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations Ground	0	
92256	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Follow-up Action Required?	n	
92257	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Follow-up Action Required?	n	
92258	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Foundation Condition	Good	
92259	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	General Comments		
92260	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	General Comments		
92261	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Grounds in Place?	y	
92262	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
92263	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
92264	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
92265	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
92266	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AL	122	
92267	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations This Read Vac	0	
92268	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
92269	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Switching Operations	0	
92270	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Tank Paint Condition	Good	
92271	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Unknown Operations	0	
92272	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
92273	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
92274	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
92275	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
92276	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92277	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92278	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
92279	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92280	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92281	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92282	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92283	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
92284	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
92285	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92286	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
92287	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
92288	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
92289	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
92290	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	All Connections OK?	y	
92291	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	Follow-up Action Required?	n	
92292	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	General Comments		
92293	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	LTC Operation Checked?	y	
92294	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
92295	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
92296	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
92297	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC0000765	LTCControl	844-1	LTC Control Insp	VRR Time Delay	45	Seconds
92298	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
92299	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
92300	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
92301	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
92302	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
92303	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
92304	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
92305	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
92306	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
92307	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
92308	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
92309	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
92310	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
92311	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
92312	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
92313	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
92314	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
92315	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
92316	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	General Comments		
92317	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	General Comments		
92318	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Follow-up Action Required?	n	
92319	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
92320	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations Ground	0	
92321	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations C Ø	0	
92322	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations A Ø	0	
92323	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations B Ø	0	
92324	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
92325	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
92326	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92327	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
92328	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps C Ø	135.0	
92329	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps B Ø	120.0	
92330	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps A Ø	180.0	
92331	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
92332	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	4.27	%
92333	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
92334	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Months Operations	4	
92335	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
92336	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
92337	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
92338	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
92339	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Leaks	None	
92340	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
92341	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
92342	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92343	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
92344	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
92345	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
92346	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	General Comments		
92347	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
92348	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
92349	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
92350	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
92351	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
92352	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
92353	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
92354	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
92355	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
92356	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AF	122	
92357	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
92358	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
92359	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
92360	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
92361	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	157	
92362	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Unknown Operations	0	
92363	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Tank Paint Condition	Good	
92364	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Switching Operations	0	
92365	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations This Read Vac	0	
92366	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AL	172	
92367	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AF	172	
92368	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
92369	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Maintenance Operations	0	
92370	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Grounds in Place?	y	
92371	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	General Comments		
92372	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	General Comments		
92373	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Foundation Condition	Good	
92374	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Follow-up Action Required?	n	
92375	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Follow-up Action Required?	n	
92376	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations Ground	0	
92377	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations C Ø	0	
92378	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations B Ø	0	
92379	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations A Ø	0	
92380	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92381	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	volts
92382	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
92383	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92384	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
92385	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
92386	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	
92387	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	107419	
92388	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
92389	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
92390	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
92391	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92392	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92393	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92394	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92395	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92396	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92397	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92398	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92399	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushing Condition	Good	
92400	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps C Ø	468.0	
92401	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps B Ø	440.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92402	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps A Ø	450.0	
92403	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92404	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92405	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92406	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations	0	
92407	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations	1	
92408	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92409	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92410	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AL	251	
92411	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations This Read Vac	0	
92412	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
92413	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Switching Operations	0	
92414	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Tank Paint Condition	Good	
92415	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Unknown Operations	0	
92416	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
92417	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.0	
92418	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Ambient Temperature	50	*F
92419	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
92420	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
92421	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Foundation Condition	Good	
92422	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
92423	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
92424	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
92425	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
92426	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
92427	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92428	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
92429	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
92430	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Follow-up Action Required?	n	
92431	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Foundation Condition	Good	
92432	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
92433	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	General Comments	y	
92434	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Grounds in Place?	y	
92435	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
92436	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
92437	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
92438	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
92439	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
92440	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Tank Paint Condition	Good	
92441	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
92442	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
92443	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
92444	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92445	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	General Comments		
92446	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92447	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
92448	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
92449	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92450	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92451	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
92452	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92453	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92454	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92455	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92456	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
92457	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
92458	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92459	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	General Comments		
92460	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	General Comments		
92461	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Foundation Condition	Good	
92462	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Follow-up Action Required?	n	
92463	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Follow-up Action Required?	n	
92464	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations Ground	0	
92465	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations C Ø	0	
92466	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations B Ø	0	
92467	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations A Ø	0	
92468	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92469	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92470	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92471	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92472	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92473	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92474	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
92475	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
92476	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92477	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panels Dusted?	y	
92478	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
92479	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
92480	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	General Comments		
92481	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
92482	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
92483	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Swept?	y	
92484	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
92485	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
92486	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Evidence of Insects	None	
92487	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
92488	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
92489	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
92490	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
92491	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Unknown Operations	0	
92492	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Switching Operations	0	
92493	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations This Read AM	0	
92494	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AL	396	
92495	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AF	396	
92496	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Maintenance Operations	0	
92497	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
92498	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	General Comments		
92499	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	General Comments		
92500	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Follow-up Action Required?	n	
92501	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
92502	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations Ground	0	
92503	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations C Ø	0	
92504	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations B Ø	0	
92505	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations A Ø	0	
92506	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
92507	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
92508	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
92509	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
92510	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
92511	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
92512	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
92513	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
92514	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Foundation Condition	Good	
92515	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
92516	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	General Comments		
92517	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
92518	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
92519	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
92520	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
92521	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.6	
92522	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.3	
92523	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps C Ø	45.0	
92524	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
92525	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
92526	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
92527	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
92528	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
92529	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	General Comments		
92530	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
92531	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Operations Counter	105	
92532	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
92533	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
92534	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
92535	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
92536	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
92537	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
92538	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
92539	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
92540	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92541	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps A Ø	80.0	
92542	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps B Ø	74.0	
92543	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps C Ø	77.0	
92544	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushing Condition	Good	
92545	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92546	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92547	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92548	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92549	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Unknown Operations	0	
92550	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Tank Paint Condition	Good	
92551	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
92552	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations This Read Vac	0	
92553	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AL	191	
92554	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AF	191	
92555	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Moisture and Leak Free?	y	
92556	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Maintenance Operations	0	
92557	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Grounds in Place?	y	
92558	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
92559	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92560	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92561	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
92562	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92563	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92564	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92565	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92566	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
92567	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
92568	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92569	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
92570	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
92571	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
92572	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
92573	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
92574	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
92575	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
92576	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
92577	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
92578	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
92579	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92580	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
92581	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Leaks	None	
92582	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
92583	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Operations Counter	9	
92584	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
92585	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
92586	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	General Comments		
92587	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
92588	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
92589	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations	1	
92590	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92591	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92592	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92593	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps A Ø	640.0	
92594	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps B Ø	640.0	
92595	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps C Ø	640.0	
92596	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushing Condition	Good	
92597	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92598	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
92599	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
92600	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
92601	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
92602	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
92603	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
92604	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
92605	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
92606	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
92607	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
92608	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
92609	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
92610	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
92611	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92612	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
92613	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
92614	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92615	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92616	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92617	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92618	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
92619	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92620	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92621	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
92622	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
92623	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92624	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	General Comments		
92625	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92626	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
92627	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
92628	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
92629	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
92630	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	139	
92631	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
92632	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
92633	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
92634	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
92635	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
92636	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
92637	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
92638	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.3	
92639	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
92640	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
92641	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
92642	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
92643	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
92644	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
92645	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
92646	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
92647	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
92648	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
92649	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
92650	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
92651	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BCH000268	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
92652	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92653	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
92654	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92655	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
92656	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Follow-up Action Required?	n	
92657	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Follow-up Action Required?	n	
92658	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Foundation Condition	Good	
92659	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	General Comments		
92660	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	General Comments		
92661	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Grounds in Place?	y	
92662	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
92663	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
92664	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
92665	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
92666	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
92667	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments		
92668	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
92669	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
92670	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
92671	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
92672	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
92673	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments		
92674	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
92675	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
92676	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
92677	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
92678	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
92679	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
92680	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
92681	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
92682	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
92683	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
92684	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
92685	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
92686	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
92687	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
92688	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
92689	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	General Comments		
92690	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	182	
92691	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
92692	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
92693	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	165	
92694	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
92695	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
92696	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments		
92697	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
92698	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
92699	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
92700	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
92701	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92702	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Maintenance Operations	0	
92703	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
92704	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AF	251	
92705	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
92706	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	11R	
92707	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92708	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92709	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92710	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Paint Condition	Bad	
92711	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92712	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92713	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92714	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92715	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
92716	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
92717	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
92718	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
92719	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
92720	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
92721	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
92722	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	General Comments		
92723	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
92724	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
92725	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
92726	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
92727	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
92728	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
92729	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
92730	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
92731	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
92732	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
92733	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
92734	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
92735	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
92736	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92737	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
92738	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
92739	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
92740	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	16R	
92741	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
92742	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
92743	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
92744	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
92745	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
92746	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
92747	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
92748	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps C Ø	62.0	
92749	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps B Ø	41.0	
92750	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
92751	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations A Ø	0	
92752	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations B Ø	0	
92753	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations C Ø	0	
92754	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations Ground	0	
92755	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	235	
92756	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Moisture and Leak Free?	y	
92757	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
92758	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
92759	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Grounds in Place?	y	
92760	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
92761	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
92762	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
92763	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
92764	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
92765	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	General Comments		
92766	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Foundation Condition	Good	
92767	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	General Comments		
92768	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
92769	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
92770	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
92771	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Vegetation	None	
92772	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
92773	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
92774	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
92775	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
92776	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
92777	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
92778	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
92779	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
92780	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
92781	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
92782	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
92783	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
92784	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
92785	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	General Comments		
92786	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
92787	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
92788	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Operations Counter	1933	
92789	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
92790	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Leaks	None	
92791	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
92792	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
92793	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
92794	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
92795	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
92796	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
92797	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
92798	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
92799	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
92800	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
92801	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
92802	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
92803	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
92804	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
92805	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
92806	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
92807	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
92808	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
92809	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	General Comments		
92810	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
92811	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
92812	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
92813	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
92814	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
92815	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
92816	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Tank Paint Condition	Good	
92817	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Unknown Operations	0	
92818	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Foundation Condition	Good	
92819	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Follow-up Action Required?	n	
92820	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Follow-up Action Required?	n	
92821	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
92822	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
92823	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations Ground	0	
92824	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations C Ø	0	
92825	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations B Ø	0	
92826	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations A Ø	0	
92827	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92828	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92829	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92830	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92831	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92832	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92833	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92834	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92835	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92836	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushing Condition	Good	
92837	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps C Ø	38.0	
92838	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps B Ø	40.0	
92839	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps A Ø	36.0	
92840	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92841	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92842	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92843	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations	22	
92844	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	0	
92845	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Tank Paint Condition	Good	
92846	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	0	
92847	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
92848	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Trash?	y	
92849	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
92850	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
92851	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
92852	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	235	
92853	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92854	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	2	
92855	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
92856	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	General Comments		
92857	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
92858	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps C Ø	60.0	
92859	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps B Ø	39.0	
92860	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps A Ø	38.0	
92861	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92862	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92863	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92864	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations	2	
92865	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Unknown Operations	0	
92866	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Tank Paint Condition	Good	
92867	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Switching Operations	0	
92868	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
92869	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
92870	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Operations Counter	482	
92871	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
92872	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	General Comments		
92873	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
92874	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
92875	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
92876	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
92877	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
92878	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.7	
92879	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations This Read Vac	0	
92880	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AL	177	
92881	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AF	177	
92882	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Moisture and Leak Free?	y	
92883	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Maintenance Operations	0	
92884	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Grounds in Place?	y	
92885	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	General Comments		
92886	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	General Comments		
92887	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
92888	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
92889	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
92890	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
92891	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
92892	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
92893	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
92894	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
92895	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
92896	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
92897	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
92898	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
92899	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
92900	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
92901	11/11/2019 14:14	Distribution	Brush Creek Quarterly Inspection	MR0085	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
92902	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
92903	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
92904	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
92905	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
92906	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
92907	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
92908	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
92909	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
92910	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
92911	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
92912	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
92913	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
92914	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
92915	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
92916	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
92917	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
92918	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
92919	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
92920	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
92921	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	General Comments		
92922	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
92923	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
92924	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
92925	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
92926	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
92927	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
92928	11/11/2019 15:12	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
92929	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92930	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushing Condition	Good	
92931	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
92932	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Follow-up Action Required?	n	
92933	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
92934	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
92935	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	0	
92936	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	0	
92937	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92938	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92939	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92940	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92941	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92942	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92943	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92944	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92945	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92946	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushing Condition	Good	
92947	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	63.0	
92948	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	59.0	
92949	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	54.0	
92950	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92951	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92952	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations A Ø	0	
92953	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92954	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92955	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations B Ø	0	
92956	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92957	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushing Condition	Good	
92958	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps C Ø	419.0	
92959	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps B Ø	415.0	
92960	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps A Ø	421.0	
92961	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations C Ø	0	
92962	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92963	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92964	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92965	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations	4	
92966	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	9 Month Operations	0	
92967	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
92968	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
92969	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
92970	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps A Ø	240.0	
92971	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps B Ø	193.0	
92972	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps C Ø	223.0	
92973	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushing Condition	Good	
92974	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
92975	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
92976	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
92977	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
92978	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Unknown Operations	0	
92979	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Tank Paint Condition	Good	
92980	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Switching Operations	0	
92981	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations This Read Vac	0	
92982	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
92983	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
92984	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
92985	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
92986	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
92987	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations A Ø	0	
92988	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations B Ø	0	
92989	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations C Ø	0	
92990	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations Ground	0	
92991	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Follow-up Action Required?	n	
92992	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Follow-up Action Required?	n	
92993	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Foundation Condition	Good	
92994	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	General Comments		
92995	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	General Comments		
92996	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Grounds in Place?	y	
92997	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Maintenance Operations	0	
92998	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Moisture and Leak Free?	y	
92999	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AF	170	
93000	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AL	170	
93001	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93002	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
93003	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps C Ø	120.0	
93004	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps B Ø	175.0	
93005	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps A Ø	120.0	
93006	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
93007	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
93008	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
93009	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Months Operations	24	
93010	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93011	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Unknown Operations	0	
93012	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Tank Paint Condition	Good	
93013	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Switching Operations	0	
93014	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations This Read Vac	0	
93015	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AL	178	
93016	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AF	178	
93017	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Moisture and Leak Free?	y	
93018	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Maintenance Operations	0	
93019	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
93020	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Leaks	None	
93021	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93022	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1343	
93023	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
93024	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
93025	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93026	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93027	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
93028	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
93029	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
93030	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	General Comments		
93031	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93032	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
93033	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
93034	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93035	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
93036	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93037	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93038	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93039	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93040	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
93041	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93042	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Vegetation	None	
93043	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
93044	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93045	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93046	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93047	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93048	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93049	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93050	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AF	188	
93051	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Moisture and Leak Free?	y	
93052	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Maintenance Operations	0	
93053	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Grounds in Place?	y	
93054	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	General Comments		
93055	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	General Comments		
93056	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Foundation Condition	Good	
93057	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Follow-up Action Required?	n	
93058	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Follow-up Action Required?	n	
93059	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations Ground	0	
93060	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations C Ø	0	
93061	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations B Ø	0	
93062	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations A Ø	0	
93063	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93064	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93065	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93066	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93067	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93068	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93069	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93070	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93071	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Moisture and Leak Free?	y	
93072	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Maintenance Operations	0	
93073	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Grounds in Place?	y	
93074	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	General Comments		
93075	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	General Comments		
93076	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations Ground	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93077	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Follow-up Action Required?	n	
93078	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Follow-up Action Required?	n	
93079	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Foundation Condition	Good	
93080	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	General Comments		
93081	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	General Comments		
93082	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Grounds in Place?	y	
93083	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Maintenance Operations	0	
93084	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
93085	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AF	177	
93086	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AL	177	
93087	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations This Read Vac	0	
93088	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Switching Operations	0	
93089	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93090	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93091	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93092	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93093	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	General Comments		
93094	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93095	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
93096	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93097	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
93098	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
93099	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations This Read Vac	0	
93100	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Switching Operations	0	
93101	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Tank Paint Condition	Good	
93102	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Unknown Operations	0	
93103	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Grounds in Place?	y	
93104	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	General Comments		
93105	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	General Comments		
93106	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Foundation Condition	Good	
93107	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Follow-up Action Required?	n	
93108	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Follow-up Action Required?	n	
93109	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations Ground	0	
93110	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations C Ø	0	
93111	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations B Ø	0	
93112	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations A Ø	0	
93113	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93114	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93115	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93116	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93117	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93118	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93119	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93120	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93121	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AL	195	
93122	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AF	195	
93123	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
93124	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	General Comments		
93125	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
93126	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
93127	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
93128	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
93129	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93130	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
93131	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93132	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93133	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
93134	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
93135	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
93136	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushing Condition	Good	
93137	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps C Ø	52.0	
93138	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps B Ø	64.0	
93139	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps A Ø	73.0	
93140	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93141	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
93142	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93143	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations	1	
93144	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Unknown Operations	0	
93145	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Tank Paint Condition	Good	
93146	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Switching Operations	1	
93147	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations This Read Vac	1	
93148	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AL	188	
93149	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Foundation Condition	Good	
93150	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Follow-up Action Required?	n	
93151	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93152	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations Ground	0	
93153	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations C Ø	0	
93154	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations B Ø	0	
93155	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations A Ø	0	
93156	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93157	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93158	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93159	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93160	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93161	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93162	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93163	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93164	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
93165	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushing Condition	Good	
93166	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps C Ø	160.0	
93167	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps B Ø	100.0	
93168	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps A Ø	100.0	
93169	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93170	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
93171	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93172	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations	0	
93173	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
93174	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
93175	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
93176	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
93177	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
93178	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
93179	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6955.20	kw
93180	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
93181	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
93182	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
93183	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
93184	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
93185	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	General Comments		
93186	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	General Comments		
93187	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
93188	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
93189	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93190	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
93191	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	General Comments		
93192	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
93193	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
93194	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
93195	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
93196	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
93197	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
93198	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
93199	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
93200	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
93201	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
93202	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
93203	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
93204	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Evidence of Insects	None	
93205	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
93206	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	General Comments		
93207	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93208	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
93209	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
93210	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
93211	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
93212	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
93213	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
93214	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
93215	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93216	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93217	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	General Comments		
93218	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93219	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93220	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93221	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93222	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93223	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
93224	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
93225	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
93226	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93227	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93228	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	General Comments		
93229	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
93230	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
93231	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93232	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
93233	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
93234	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93235	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93236	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Time Delay	30	Seconds
93237	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
93238	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
93239	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93240	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
93241	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
93242	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
93243	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
93244	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
93245	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
93246	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Unknown Operations	0	
93247	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Tank Paint Condition	Good	
93248	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Switching Operations	0	
93249	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
93250	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations This Read Vac	0	
93251	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AL	226	
93252	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AF	226	
93253	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
93254	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Maintenance Operations	0	
93255	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Grounds in Place?	y	
93256	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	General Comments		
93257	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	General Comments		
93258	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93259	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
93260	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
93261	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
93262	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93263	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
93264	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93265	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93266	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
93267	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
93268	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
93269	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
93270	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	General Comments		
93271	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
93272	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
93273	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Foundation Condition	Good	
93274	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
93275	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
93276	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
93277	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
93278	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
93279	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
93280	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93281	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Vegetation	None	
93282	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
93283	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
93284	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
93285	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
93286	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	General Comments		
93287	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
93288	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
93289	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
93290	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
93291	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93292	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
93293	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93294	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93295	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
93296	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
93297	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	General Comments		
93298	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93299	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93300	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93301	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93302	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	General Comments		
93303	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
93304	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
93305	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
93306	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
93307	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	LTC Operation Checked?	y	
93308	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
93309	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93310	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93311	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93312	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
93313	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
93314	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Foundation Condition	Good	
93315	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
93316	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
93317	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	General Comments		
93318	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
93319	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
93320	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
93321	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
93322	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
93323	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
93324	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
93325	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
93326	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
93327	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
93328	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
93329	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
93330	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
93331	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
93332	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
93333	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
93334	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
93335	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
93336	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
93337	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
93338	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
93339	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
93340	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
93341	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
93342	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
93343	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
93344	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
93345	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
93346	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
93347	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
93348	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
93349	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
93350	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
93351	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
93352	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
93353	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93354	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
93355	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93356	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
93357	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
93358	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
93359	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
93360	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
93361	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93362	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93363	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93364	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93365	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93366	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	General Comments		
93367	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
93368	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
93369	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93370	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	General Comments		
93371	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
93372	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
93373	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
93374	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93375	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93376	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93377	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
93378	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
93379	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47961	
93380	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93381	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
93382	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Leaks	None	
93383	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
93384	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93385	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	All Connections OK?	y	
93386	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	Follow-up Action Required?	n	
93387	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	General Comments		
93388	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	LTC Operation Checked?	y	
93389	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
93390	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
93391	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
93392	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	LTC0000852	LTCControl	600-1	LTC Control Insp	VRR Time Delay	30	Seconds
93393	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	General Comments		
93394	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	General Comments		
93395	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Grounds in Place?	y	
93396	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Heaters (All) Functioning?	y	
93397	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Maintenance Operations	0	
93398	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Moisture and Leak Free?	y	
93399	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AF	183	
93400	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps A Ø	80.0	
93401	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93402	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
93403	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93404	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	9 Month Operations	1	
93405	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AL	183	
93406	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations This Read Vac	1	
93407	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
93408	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Switching Operations	1	
93409	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Tank Paint Condition	Good	
93410	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Unknown Operations	0	
93411	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
93412	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
93413	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
93414	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
93415	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93416	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93417	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93418	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	General Comments		
93419	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93420	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
93421	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps B Ø	72.0	
93422	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations	2	
93423	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93424	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
93425	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93426	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps A Ø	65.0	
93427	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps B Ø	87.0	
93428	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
93429	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
93430	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
93431	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Good	
93432	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps C Ø	33.0	
93433	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushing Condition	Good	
93434	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
93435	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
93436	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93437	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93438	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93439	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93440	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
93441	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty.	
93442	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
93443	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
93444	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
93445	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
93446	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
93447	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
93448	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
93449	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
93450	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
93451	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93452	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
93453	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
93454	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
93455	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93456	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93457	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93458	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93459	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93460	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93461	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93462	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations A Ø	0	
93463	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations B Ø	0	
93464	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations C Ø	0	
93465	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations Ground	0	
93466	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Follow-up Action Required?	n	
93467	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Follow-up Action Required?	n	
93468	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Foundation Condition	Good	
93469	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
93470	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93471	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93472	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93473	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93474	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
93475	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93476	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
93477	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
93478	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
93479	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
93480	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
93481	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
93482	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
93483	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
93484	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
93485	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
93486	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
93487	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
93488	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93489	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93490	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
93491	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
93492	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
93493	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
93494	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93495	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
93496	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
93497	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93498	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
93499	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93500	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93501	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93502	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93503	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
93504	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
93505	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Leaks	None	
93506	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93507	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Regulator As Left Counter	132208	
93508	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
93509	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
93510	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
93511	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93512	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
93513	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Present	25	*C
93514	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Max	48	*C
93515	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3312	
93516	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	21000	
93517	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
93518	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
93519	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
93520	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
93521	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93522	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
93523	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
93524	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
93525	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	General Comments		
93526	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
93527	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
93528	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Swept?	y	
93529	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
93530	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
93531	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93532	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
93533	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
93534	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
93535	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
93536	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
93537	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
93538	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
93539	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
93540	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	General Comments		
93541	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93542	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
93543	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
93544	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93545	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93546	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Broom on Site?	y	
93547	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
93548	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93549	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
93550	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
93551	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
93552	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93553	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
93554	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
93555	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
93556	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panels Dusted?	y	
93557	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
93558	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
93559	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	General Comments		
93560	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
93561	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
93562	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
93563	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93564	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	34041	
93565	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
93566	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
93567	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
93568	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
93569	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Evidence of Insects	None	
93570	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
93571	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
93572	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Swept?	y	
93573	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
93574	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
93575	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	General Comments		
93576	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
93577	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Trash Emptied?	y	
93578	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
93579	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
93580	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93581	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93582	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
93583	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93584	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
93585	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
93586	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
93587	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
93588	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
93589	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
93590	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
93591	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
93592	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93593	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
93594	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93595	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93596	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93597	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93598	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
93599	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93600	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
93601	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
93602	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93603	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	General Comments		
93604	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
93605	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
93606	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
93607	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93608	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Vegetation	None	
93609	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
93610	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
93611	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
93612	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
93613	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
93614	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	General Comments		
93615	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
93616	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
93617	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93618	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93619	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93620	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
93621	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
93622	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
93623	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
93624	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
93625	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
93626	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
93627	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
93628	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
93629	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
93630	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
93631	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
93632	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
93633	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
93634	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
93635	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
93636	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
93637	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
93638	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Foundation Condition	Good	
93639	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
93640	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
93641	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Leaks	None	
93642	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
93643	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
93644	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
93645	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
93646	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
93647	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
93648	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
93649	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
93650	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
93651	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
93652	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	General Comments		
93653	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
93654	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
93655	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
93656	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
93657	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93658	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
93659	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
93660	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
93661	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
93662	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93663	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	General Comments		
93664	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
93665	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
93666	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
93667	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
93668	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
93669	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
93670	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
93671	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
93672	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
93673	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
93674	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93675	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
93676	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93677	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93678	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
93679	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
93680	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93681	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
93682	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93683	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps A Ø	140.0	
93684	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps B Ø	160.0	
93685	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Broom on Site?	y	
93686	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
93687	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
93688	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
93689	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
93690	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
93691	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
93692	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
93693	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
93694	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
93695	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
93696	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	VRR Time Delay	45	Seconds
93697	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
93698	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
93699	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
93700	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93701	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Vegetation	None	
93702	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
93703	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	General Comments		
93704	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
93705	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
93706	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
93707	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
93708	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93709	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93710	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93711	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
93712	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
93713	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps C Ø	140.0	
93714	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushing Condition	Good	
93715	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
93716	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93717	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
93718	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
93719	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
93720	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
93721	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
93722	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
93723	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93724	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93725	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93726	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93727	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Unknown Operations	0	
93728	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Tank Paint Condition	Good	
93729	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Switching Operations	0	
93730	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
93731	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations This Read Vac	3	
93732	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AL	465	
93733	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AF	465	
93734	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Moisture and Leak Free?	y	
93735	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Maintenance Operations	0	
93736	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
93737	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Grounds in Place?	y	
93738	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	General Comments		
93739	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	General Comments		
93740	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Foundation Condition	Good	
93741	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Follow-up Action Required?	n	
93742	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Follow-up Action Required?	n	
93743	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations Ground	0	
93744	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations C Ø	2	
93745	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations B Ø	0	
93746	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations A Ø	1	
93747	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps C Phase V	8.87	
93748	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93749	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
93750	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
93751	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93752	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
93753	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
93754	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
93755	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
93756	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
93757	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
93758	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
93759	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
93760	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
93761	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
93762	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93763	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93764	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
93765	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93766	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
93767	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
93768	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
93769	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
93770	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	General Comments		
93771	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
93772	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Vegetation	None	
93773	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
93774	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
93775	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
93776	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
93777	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93778	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
93779	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
93780	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Regulator As Left Counter	81646	
93781	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93782	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Leaks	None	
93783	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
93784	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
93785	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
93786	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
93787	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Foundation Condition	Good	
93788	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
93789	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
93790	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	General Comments		
93791	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
93792	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
93793	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
93794	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
93795	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
93796	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
93797	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
93798	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
93799	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	All Connections OK?	y	
93800	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	Follow-up Action Required?	n	
93801	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	General Comments		
93802	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	LTC Operation Checked?	y	
93803	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
93804	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	LTC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
93805	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
93806	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Foundation Condition	Good	
93807	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
93808	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations	12	
93809	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
93810	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
93811	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93812	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	General Comments		
93813	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
93814	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
93815	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
93816	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93817	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93818	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
93819	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
93820	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
93821	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Regulator As Left Counter	195246	
93822	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
93823	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Leaks	None	
93824	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
93825	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
93826	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
93827	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
93828	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps A Ø	59.0	
93829	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps B Ø	57.0	
93830	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps C Ø	57.0	
93831	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushing Condition	Good	
93832	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
93833	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
93834	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
93835	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
93836	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
93837	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
93838	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
93839	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
93840	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	General Comments		
93841	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
93842	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
93843	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
93844	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations A Ø	0	
93845	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations B Ø	0	
93846	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations C Ø	0	
93847	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations Ground	0	
93848	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
93849	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
93850	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Operations Counter	240	
93851	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
93852	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	General Comments		
93853	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
93854	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
93855	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
93856	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
93857	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
93858	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps C Ø	58.8	
93859	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93860	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
93861	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
93862	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
93863	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93864	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	
93865	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If low, note cell #'s
93866	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
93867	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
93868	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
93869	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
93870	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
93871	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
93872	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
93873	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
93874	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
93875	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
93876	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
93877	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
93878	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
93879	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
93880	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
93881	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
93882	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
93883	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
93884	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
93885	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.5	VDC
93886	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.6	VDC
93887	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
93888	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
93889	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
93890	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
93891	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
93892	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
93893	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
93894	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
93895	11/12/2019 7:21	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
93896	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
93897	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
93898	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
93899	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	General Comments		
93900	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	Follow-up Action Required?	n	
93901	11/11/2019 11:51	Distribution	Richmond East Quarterly Inspection	LTC000694	LTCControl	829-1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
93902	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
93903	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
93904	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
93905	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
93906	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
93907	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
93908	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
93909	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
93910	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
93911	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
93912	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	General Comments		
93913	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
93914	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
93915	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
93916	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Trash?	y	
93917	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
93918	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
93919	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
93920	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
93921	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
93922	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	General Comments		
93923	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
93924	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Switching Operations	0	
93925	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Tank Paint Condition	Good	
93926	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Unknown Operations	0	
93927	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
93928	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
93929	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panels Dusted?	y	
93930	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
93931	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
93932	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	General Comments		
93933	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
93934	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
93935	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Swept?	y	
93936	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
93937	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
93938	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Evidence of Insects	None	
93939	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
93940	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Leaks	None	
93941	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
93942	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Operations Counter	96	
93943	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
93944	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
93945	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	General Comments		
93946	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
93947	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
93948	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
93949	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
93950	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
93951	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
93952	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
93953	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
93954	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
93955	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
93956	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
93957	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
93958	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
93959	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
93960	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
93961	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
93962	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
93963	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
93964	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
93965	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
93966	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
93967	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
93968	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Regulator As Left Counter	94234	
93969	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps B Ø	51.8	
93970	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps A Ø	24.2	
93971	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Follow-up Action Required?	n	
93972	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Follow-up Action Required?	n	
93973	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Foundation Condition	Good	
93974	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	General Comments		
93975	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	General Comments		
93976	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
93977	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
93978	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
93979	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
93980	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
93981	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
93982	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
93983	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
93984	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
93985	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
93986	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
93987	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
93988	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
93989	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	General Comments		
93990	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
93991	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Grounds in Place?	y	
93992	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Maintenance Operations	0	
93993	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Moisture and Leak Free?	y	
93994	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AF	335	
93995	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AL	335	
93996	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations This Read Vac	0	
93997	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
93998	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
93999	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94000	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94001	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94002	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
94003	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
94004	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94005	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94006	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94007	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94008	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
94009	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94010	11/11/2019 8:19	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
94011	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94012	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94013	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Vegetation	None	
94014	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
94015	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
94016	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	General Comments		
94017	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
94018	11/11/2019 9:48	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
94019	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations	9	
94020	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94021	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94022	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94023	11/11/2019 10:37	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94024	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps B Ø	196.0	
94025	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps C Ø	194.0	
94026	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	General Comments		
94027	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	General Comments		
94028	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
94029	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
94030	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
94031	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
94032	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
94033	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
94034	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	General Comments		
94035	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Foundation Condition	Good	
94036	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Follow-up Action Required?	n	
94037	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Follow-up Action Required?	n	
94038	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations Ground	0	
94039	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations C Ø	0	
94040	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
94041	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
94042	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
94043	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations B Ø	0	
94044	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations A Ø	0	
94045	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
94046	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	General Comments		
94047	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AF	153	
94048	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Maintenance Operations	0	
94049	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	General Comments		
94050	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	General Comments		
94051	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94052	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
94053	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations Ground	0	
94054	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations C Ø	0	
94055	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations B Ø	0	
94056	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations A Ø	0	
94057	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94058	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94059	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94060	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94061	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	General Comments		
94062	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
94063	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
94064	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
94065	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
94066	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
94067	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
94068	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
94069	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
94070	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
94071	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
94072	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
94073	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
94074	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
94075	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
94076	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
94077	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	General Comments		
94078	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
94079	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
94080	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Foundation Condition	Good	
94081	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
94082	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94083	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94084	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94085	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94086	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94087	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
94088	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
94089	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
94090	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94091	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94092	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94093	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94094	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94095	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	General Comments		
94096	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
94097	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
94098	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
94099	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	General Comments		
94100	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94101	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
94102	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Switching Operations	0	
94103	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Tank Paint Condition	Good	
94104	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Unknown Operations	0	
94105	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
94106	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
94107	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
94108	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
94109	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1978	
94110	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1978	
94111	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
94112	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
94113	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
94114	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
94115	11/11/2019 14:27	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
94116	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
94117	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
94118	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments	CANT READ COUNTER	
94119	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
94120	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
94121	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	y	
94122	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
94123	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
94124	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
94125	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
94126	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	B80238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94127	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94128	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94129	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94130	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94131	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94132	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94133	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94134	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94135	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94136	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
94137	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	640.0	
94138	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	640.0	
94139	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	620.0	
94140	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94141	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94142	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
94143	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
94144	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
94145	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94146	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
94147	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94148	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94149	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94150	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94151	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
94152	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
94153	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
94154	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
94155	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
94156	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
94157	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	no in service yet	
94158	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
94159	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
94160	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Moisture and Leak Free?	y	
94161	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Maintenance Operations	0	
94162	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Grounds in Place?	y	
94163	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations	0	
94164	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
94165	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94166	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94167	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps A Ø	213.0	
94168	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
94169	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
94170	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
94171	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
94172	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
94173	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
94174	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
94175	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
94176	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
94177	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
94178	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
94179	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
94180	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
94181	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
94182	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	CAPO00017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
94183	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94184	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94185	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
94186	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
94187	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
94188	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
94189	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94190	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94191	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94192	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Vegetation	None	
94193	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
94194	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
94195	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
94196	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
94197	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	General Comments		
94198	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94199	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94200	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94201	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94202	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94203	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94204	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94205	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94206	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
94207	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
94208	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
94209	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
94210	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
94211	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
94212	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
94213	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
94214	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
94215	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
94216	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
94217	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
94218	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
94219	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
94220	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
94221	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94222	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
94223	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94224	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
94225	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
94226	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	General Comments		
94227	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94228	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
94229	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94230	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94231	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94232	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94233	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94234	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94235	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94236	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94237	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	General Comments		
94238	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
94239	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Vegetation	None	
94240	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
94241	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Vegetation	None	
94242	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94243	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94244	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
94245	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94246	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94247	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94248	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
94249	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
94250	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
94251	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
94252	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	General Comments	High side structure pad is crumbling.	
94253	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
94254	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
94255	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
94256	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
94257	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
94258	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
94259	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
94260	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
94261	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
94262	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
94263	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
94264	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
94265	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
94266	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Grounds in Place?	y	
94267	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Maintenance Operations	0	
94268	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Moisture and Leak Free?	y	
94269	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AF	440	
94270	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AL	440	
94271	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations This Read Vac	1	
94272	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Switching Operations	1	
94273	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Tank Paint Condition	Good	
94274	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Unknown Operations	0	
94275	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	9 Month Operations	16	
94276	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94277	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94278	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
94279	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Leaks	None	
94280	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
94281	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
94282	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33217	
94283	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
94284	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
94285	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
94286	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94287	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94288	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
94289	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
94290	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
94291	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	General Comments		
94292	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94293	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
94294	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
94295	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94296	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
94297	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94298	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps A Ø	0.0	
94299	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps B Ø	0.0	
94300	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
94301	11/11/2019 11:06	Distribution	Corbin East Quarterly Inspection	BAT000193	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
94302	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps C Ø	0.0	
94303	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushing Condition	Good	
94304	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94305	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94306	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94307	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94308	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94309	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94310	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94311	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94312	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94313	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Follow-up Action Required?	n	
94314	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Foundation Condition	Good	
94315	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	General Comments		
94316	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Unknown Operations	0	
94317	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Switching Operations	0	
94318	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations This Read Vac	0	
94319	11/13/2019 13:41	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AL	153	
94320	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94321	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
94322	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
94323	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94324	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	General Comments		
94325	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
94326	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
94327	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94328	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
94329	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94330	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
94331	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94332	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Min Tap Position	13L	
94333	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
94334	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
94335	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	General Comments		
94336	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94337	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
94338	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
94339	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94340	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Current Tap Position	8L	
94341	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94342	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94343	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94344	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94345	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94346	11/11/2019 15:22	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
94347	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
94348	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94349	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94350	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94351	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94352	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
94353	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94354	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	General Comments	Barb wire starting to rust.	
94355	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
94356	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
94357	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations A Ø	0	
94358	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94359	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94360	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94361	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
94362	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94363	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
94364	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94365	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
94366	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
94367	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
94368	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
94369	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
94370	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Moisture and Leak Free?	y	
94371	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Maintenance Operations	0	
94372	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
94373	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
94374	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
94375	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
94376	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
94377	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
94378	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	General Comments		
94379	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
94380	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
94381	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Foundation Condition	Good	
94382	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
94383	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Grounds in Place?	y	
94384	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	General Comments		
94385	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	General Comments		
94386	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94387	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Foundation Condition	Good	
94388	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
94389	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Follow-up Action Required?	n	
94390	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Follow-up Action Required?	n	
94391	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations Ground	0	
94392	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations C Ø	0	
94393	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
94394	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations C Ø	0	
94395	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations B Ø	0	
94396	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94397	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94398	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94399	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94400	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94401	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
94402	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94403	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94404	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Vegetation	None	
94405	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
94406	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	General Comments		
94407	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94408	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94409	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94410	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94411	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94412	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94413	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94414	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94415	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94416	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	General Comments		
94417	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000043	Yard	600-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
94418	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94419	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94420	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94421	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94422	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
94423	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
94424	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94425	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations Ground	0	
94426	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94427	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94428	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94429	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
94430	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
94431	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Leaks	None	
94432	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
94433	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
94434	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Regulator As Left Counter	160295	
94435	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
94436	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94437	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94438	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushing Condition	Good	
94439	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations This Read Vac	1	
94440	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AL	241	
94441	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AF	241	
94442	11/11/2019 11:51	Distribution	Versailles Bypass Quarterly Inspection	BB0238	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
94443	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps C Ø	60.0	
94444	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
94445	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps B Ø	59.0	
94446	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps A Ø	50.0	
94447	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Leaks	None	
94448	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
94449	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94450	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94451	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94452	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
94453	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
94454	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
94455	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
94456	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
94457	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
94458	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94459	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94460	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94461	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94462	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94463	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushing Condition	Good	
94464	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps C Ø	78.0	
94465	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AF	165	
94466	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AL	165	
94467	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations This Read Vac	0	
94468	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
94469	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	9 Month Operations	0	
94470	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Unknown Operations	0	
94471	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Tank Paint Condition	Good	
94472	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Switching Operations	0	
94473	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations This Read Vac	0	
94474	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AL	144	
94475	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AF	144	
94476	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Moisture and Leak Free?	y	
94477	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Maintenance Operations	0	
94478	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Grounds in Place?	y	
94479	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	General Comments		
94480	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	General Comments		
94481	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Foundation Condition	Good	
94482	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Follow-up Action Required?	n	
94483	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
94484	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
94485	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Follow-up Action Required?	n	
94486	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94487	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94488	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
94489	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
94490	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
94491	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
94492	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
94493	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	n	
94494	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
94495	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
94496	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
94497	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
94498	11/11/2019 12:07	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Vegetation	None	
94499	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations B Ø	0	
94500	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations A Ø	0	
94501	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94502	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
94503	11/11/2019 15:41	Distribution	Hale Quarterly Inspection	BAT000134	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
94504	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Unknown Operations	0	
94505	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94506	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94507	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	General Comments		
94508	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
94509	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
94510	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
94511	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94512	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94513	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
94514	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
94515	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
94516	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Regulator As Left Counter	118584	
94517	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
94518	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
94519	11/11/2019 12:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
94520	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Tank Paint Condition	Good	
94521	11/11/2019 15:22	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Switching Operations	1	
94522	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
94523	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94524	11/11/2019 15:24	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94525	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94526	11/11/2019 13:04	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94527	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	7	
94528	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments		
94529	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94530	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
94531	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
94532	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
94533	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94534	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
94535	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94536	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
94537	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4798	
94538	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
94539	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
94540	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps B Ø	60.0	
94541	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps A Ø	60.0	
94542	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps C Ø	60.0	
94543	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
94544	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
94545	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94546	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
94547	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
94548	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
94549	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
94550	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
94551	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		
94552	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
94553	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
94554	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94555	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	General Comments		
94556	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
94557	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Leaks	None	
94558	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
94559	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15353	
94560	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
94561	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
94562	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
94563	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94564	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94565	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
94566	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
94567	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
94568	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
94569	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94570	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
94571	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
94572	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94573	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
94574	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94575	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94576	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94577	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
94578	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
94579	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
94580	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
94581	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94582	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	General Comments		
94583	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
94584	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Follow-up Action Required?	n	
94585	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
94586	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
94587	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
94588	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
94589	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
94590	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
94591	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
94592	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
94593	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
94594	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
94595	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
94596	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
94597	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
94598	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
94599	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
94600	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
94601	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
94602	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
94603	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Unknown Operations	0	
94604	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Tank Paint Condition	Good	
94605	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Switching Operations	0	
94606	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
94607	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations This Read Vac	0	
94608	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AL	343	
94609	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AF	343	
94610	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Moisture and Leak Free?	y	
94611	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Maintenance Operations	0	
94612	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Heaters (All) Functioning?	y	
94613	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
94614	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94615	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Follow-up Action Required?	n	
94616	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Follow-up Action Required?	n	
94617	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Grounds in Place?	y	
94618	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	General Comments		
94619	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Foundation Condition	Good	
94620	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	General Comments		
94621	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
94622	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Leaks	None	
94623	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94624	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
94625	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
94626	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94627	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94628	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushing Condition	Good	
94629	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94630	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94631	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94632	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94633	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94634	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94635	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
94636	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
94637	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
94638	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
94639	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
94640	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
94641	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	11.0	
94642	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
94643	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	9.0	
94644	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
94645	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.1810	
94646	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94647	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94648	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94649	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94650	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94651	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94652	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations B Ø	0	
94653	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations C Ø	0	
94654	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations Ground	0	
94655	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
94656	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
94657	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
94658	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
94659	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
94660	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
94661	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
94662	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
94663	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
94664	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
94665	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
94666	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
94667	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
94668	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Operations Since Last Insp	248	
94669	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
94670	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Min Tap Position	8L	
94671	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Max Tap Position	6L	
94672	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Current Tap Position	6L	
94673	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
94674	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Left Counter	259104	
94675	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Found Counter	259104	
94676	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	144.80	kw
94677	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
94678	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
94679	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
94680	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		
94681	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
94682	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
94683	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
94684	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94685	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
94686	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
94687	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94688	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations	2	
94689	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
94690	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94691	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
94692	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps A Ø	0.0	
94693	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
94694	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
94695	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	General Comments		
94696	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
94697	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
94698	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Foundation Condition	Good	
94699	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
94700	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94701	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94702	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94703	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
94704	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94705	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94706	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps B Ø	0.0	
94707	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps C Ø	0.0	
94708	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushing Condition	Good	
94709	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushings Connection/Risers	Good	
94710	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
94711	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Vegetation	None	
94712	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2020-05-17 00:00:00.000000	
94713	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
94714	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
94715	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
94716	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
94717	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
94718	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
94719	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
94720	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
94721	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
94722	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
94723	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
94724	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
94725	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	General Comments		
94726	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94727	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94728	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94729	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94730	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94731	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94732	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
94733	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
94734	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Paint Condition	Good	
94735	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Equipment Properly Labeled?	y	
94736	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
94737	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
94738	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
94739	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
94740	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
94741	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
94742	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
94743	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
94744	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
94745	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
94746	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
94747	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
94748	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
94749	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
94750	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
94751	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
94752	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
94753	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
94754	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
94755	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
94756	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
94757	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
94758	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
94759	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
94760	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94761	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94762	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
94763	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
94764	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
94765	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
94766	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94767	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
94768	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
94769	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94770	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Follow-up Action Required?	n	
94771	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
94772	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
94773	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	General Comments		
94774	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	General Comments		
94775	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
94776	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	LTC Totalizer Reading	1824.00	kw
94777	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
94778	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
94779	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Max	25	°C
94780	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Present	25	°C
94781	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
94782	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
94783	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
94784	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
94785	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
94786	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
94787	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
94788	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
94789	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
94790	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
94791	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
94792	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTCC000057	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
94793	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94794	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
94795	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
94796	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94797	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94798	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
94799	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
94800	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
94801	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
94802	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
94803	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
94804	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
94805	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
94806	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
94807	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
94808	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
94809	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
94810	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
94811	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
94812	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
94813	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
94814	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
94815	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
94816	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
94817	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
94818	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
94819	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
94820	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
94821	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
94822	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
94823	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
94824	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
94825	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
94826	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
94827	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
94828	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
94829	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
94830	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
94831	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
94832	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
94833	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
94834	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
94835	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
94836	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
94837	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
94838	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations A Ø	0	
94839	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations B Ø	0	
94840	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations C Ø	0	
94841	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations Ground	0	
94842	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Follow-up Action Required?	n	
94843	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Follow-up Action Required?	n	
94844	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Foundation Condition	Good	
94845	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	General Comments		
94846	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	General Comments	0	
94847	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Grounds in Place?	y	
94848	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Heaters (All) Functioning?	y	
94849	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Maintenance Operations	0	
94850	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Moisture and Leak Free?	y	
94851	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
94852	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
94853	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Reading	.1900	
94854	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
94855	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
94856	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
94857	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
94858	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
94859	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
94860	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
94861	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Trash?	y	
94862	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
94863	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
94864	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94865	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	General Comments		
94866	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
94867	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
94868	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94869	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
94870	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94871	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
94872	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
94873	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
94874	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
94875	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94876	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94877	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94878	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
94879	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
94880	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
94881	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
94882	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
94883	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTC000057	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
94884	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTC000057	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
94885	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	LTC000057	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
94886	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AF	198	
94887	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AL	198	
94888	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations This Read Vac	0	
94889	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
94890	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
94891	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
94892	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
94893	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
94894	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
94895	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
94896	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
94897	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
94898	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
94899	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
94900	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
94901	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
94902	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
94903	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
94904	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
94905	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
94906	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
94907	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43197	
94908	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
94909	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
94910	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
94911	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Switching Operations	0	
94912	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Tank Paint Condition	Good	
94913	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Unknown Operations	0	
94914	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
94915	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
94916	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
94917	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations	7	
94918	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
94919	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94920	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
94921	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94922	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
94923	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
94924	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94925	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94926	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94927	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
94928	11/10/2019 10:55	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
94929	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
94930	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
94931	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
94932	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94933	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94934	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94935	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
94936	11/8/2019 10:44	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
94937	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
94938	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
94939	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps C Ø	131.0	
94940	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps B Ø	149.0	
94941	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps A Ø	110.0	
94942	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
94943	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
94944	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
94945	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
94946	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
94947	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
94948	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
94949	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
94950	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
94951	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
94952	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
94953	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
94954	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	36	°C
94955	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
94956	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	72	°C
94957	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
94958	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
94959	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	3133.44	kw
94960	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
94961	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
94962	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	General Comments		
94963	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
94964	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
94965	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
94966	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94967	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
94968	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
94969	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94970	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
94971	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
94972	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
94973	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
94974	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94975	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
94976	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94977	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
94978	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
94979	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
94980	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
94981	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
94982	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
94983	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
94984	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
94985	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
94986	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
94987	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
94988	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
94989	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
94990	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
94991	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
94992	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
94993	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
94994	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	
94995	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
94996	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
94997	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
94998	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.6528	
94999	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
95000	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
95001	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
95002	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
95003	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
95004	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
95005	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
95006	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
95007	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
95008	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
95009	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
95010	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
95011	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
95012	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
95013	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
95014	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
95015	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
95016	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
95017	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
95018	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95019	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
95020	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	General Comments		
95021	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	48904	
95022	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	48913	
95023	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95024	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
95025	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	2L	
95026	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	8R	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95027	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	8L	
95028	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
95029	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	1693	
95030	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
95031	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95032	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
95033	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95034	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95035	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
95036	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95037	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95038	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95039	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95040	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
95041	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
95042	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
95043	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
95044	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
95045	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95046	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	50	
95047	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95048	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95049	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95050	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95051	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
95052	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
95053	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments		
95054	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
95055	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
95056	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
95057	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
95058	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
95059	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations	10	
95060	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95061	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95062	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
95063	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps A Ø	5.0	
95064	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps B Ø	5.0	
95065	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps C Ø	5.0	
95066	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushing Condition	Good	
95067	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
95068	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
95069	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
95070	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
95071	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
95072	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
95073	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
95074	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
95075	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
95076	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	361358	
95077	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
95078	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
95079	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
95080	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
95081	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Unknown Operations	0	
95082	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushings Connection/Risers	Good	
95083	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
95084	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Tank Paint Condition	Good	
95085	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	VRR Time Delay	60	Seconds
95086	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
95087	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
95088	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
95089	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
95090	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
95091	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
95092	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
95093	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments		
95094	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
95095	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	LTC Operation Checked?	y	
95096	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Paint Condition	Good	
95097	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95098	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95099	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95100	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95101	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95102	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	Follow-up Action Required?	n	
95103	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	LTC0000656	LTCControl	534-1	LTC Control Insp	All Connections OK?	y	
95104	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Switching Operations	2	
95105	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
95106	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations This Read Vac	2	
95107	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	36	
95108	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	36	
95109	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
95110	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
95111	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
95112	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
95113	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments		
95114	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations A Ø	0	
95115	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations B Ø	0	
95116	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations C Ø	0	
95117	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations Ground	0	
95118	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
95119	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
95120	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
95121	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95122	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
95123	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
95124	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
95125	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
95126	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
95127	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
95128	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
95129	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
95130	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
95131	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
95132	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95133	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95134	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95135	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95136	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
95137	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95138	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
95139	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95140	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
95141	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
95142	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
95143	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
95144	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
95145	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
95146	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
95147	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
95148	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
95149	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
95150	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
95151	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
95152	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
95153	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
95154	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
95155	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	3866.40	kw
95156	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
95157	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
95158	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
95159	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	General Comments		
95160	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
95161	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95162	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	General Comments		
95163	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	General Comments		
95164	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Found Counter	37102	
95165	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Left Counter	37112	
95166	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95167	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Current Tap Position	3R	
95168	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Max Tap Position	7R	
95169	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
95170	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	LTC0000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
95171	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
95172	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
95173	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Max	61	°C
95174	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
95175	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
95176	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95177	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
95178	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
95179	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
95180	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
95181	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
95182	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
95183	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
95184	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Present	47	*C
95185	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
95186	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
95187	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
95188	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
95189	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Min Tap Position	4L	
95190	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Operations Since Last Insp	1748	
95191	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95192	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
95193	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95194	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95195	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
95196	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
95197	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
95198	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Reading	.5370	
95199	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
95200	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Moisture and Leak Free?	y	
95201	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AF	171	
95202	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AL	171	
95203	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations This Read Vac	1	
95204	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
95205	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Switching Operations	1	
95206	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Tank Paint Condition	Good	
95207	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Unknown Operations	0	
95208	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
95209	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
95210	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
95211	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
95212	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
95213	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
95214	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
95215	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
95216	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
95217	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
95218	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
95219	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
95220	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
95221	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushings Connection/Risers	Good	
95222	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushing Condition	Good	
95223	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
95224	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
95225	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95226	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95227	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
95228	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95229	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95230	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95231	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95232	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
95233	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
95234	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
95235	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
95236	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
95237	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95238	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
95239	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
95240	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
95241	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
95242	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95243	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
95244	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
95245	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	General Comments		
95246	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
95247	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
95248	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
95249	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
95250	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
95251	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
95252	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
95253	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
95254	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
95255	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
95256	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
95257	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Leaks	None	
95258	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	General Comments		
95259	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	General Comments		
95260	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
95261	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
95262	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
95263	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
95264	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
95265	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
95266	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
95267	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
95268	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
95269	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	cells 6, 8,13 and 15 have cracks on top	
95270	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
95271	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
95272	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
95273	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
95274	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
95275	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
95276	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
95277	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
95278	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
95279	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
95280	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
95281	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
95282	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
95283	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
95284	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Grounds in Place?	y	
95285	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
95286	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Maintenance Operations	0	
95287	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
95288	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
95289	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
95290	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	10	
95291	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95292	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95293	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
95294	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	120.0	
95295	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	120.0	
95296	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	60.0	
95297	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
95298	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	General Comments		
95299	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
95300	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
95301	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
95302	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
95303	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
95304	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
95305	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
95306	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
95307	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
95308	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	
95309	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
95310	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
95311	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
95312	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
95313	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95314	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95315	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95316	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95317	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	
95318	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
95319	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
95320	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
95321	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
95322	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
95323	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
95324	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	General Comments		
95325	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
95326	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95327	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
95328	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
95329	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Regulator As Left Counter	403108	
95330	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
95331	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95332	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95333	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95334	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95335	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps C Ø	10.0	
95336	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps B Ø	0.0	
95337	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps A Ø	0.0	
95338	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
95339	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95340	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95341	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations	3	
95342	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Paint Condition	Good	
95343	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95344	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
95345	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
95346	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95347	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
95348	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
95349	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
95350	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
95351	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
95352	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
95353	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
95354	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
95355	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
95356	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations This Read Vac	0	
95357	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	45	
95358	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
95359	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	General Comments		
95360	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
95361	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
95362	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Vegetation	None	
95363	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95364	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
95365	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
95366	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
95367	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
95368	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
95369	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
95370	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	45	
95371	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
95372	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
95373	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
95374	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
95375	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
95376	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95377	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
95378	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
95379	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95380	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95381	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
95382	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
95383	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
95384	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
95385	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
95386	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	325.44	kw
95387	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
95388	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95389	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95390	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95391	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95392	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95393	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
95394	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
95395	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
95396	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	51	*C
95397	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
95398	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
95399	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
95400	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	29	*C
95401	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
95402	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
95403	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
95404	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
95405	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
95406	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
95407	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
95408	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1356	
95409	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
95410	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
95411	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
95412	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
95413	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
95414	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
95415	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
95416	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
95417	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
95418	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
95419	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
95420	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
95421	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
95422	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
95423	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95424	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Foundation Condition	Good	
95425	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95426	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
95427	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
95428	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
95429	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
95430	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
95431	11/8/2019 13:39	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
95432	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
95433	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
95434	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
95435	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
95436	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
95437	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
95438	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95439	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95440	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
95441	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95442	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95443	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95444	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95445	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95446	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	General Comments		
95447	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
95448	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Vegetation	None	
95449	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95450	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95451	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95452	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95453	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95454	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Leaks	None	
95455	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
95456	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
95457	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	General Comments	barbwire rusty ,large gap in back of lot, and back right post is washed out.	
95458	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
95459	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
95460	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
95461	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Regulator As Left Counter	192001	
95462	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
95463	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
95464	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
95465	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
95466	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
95467	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
95468	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
95469	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
95470	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
95471	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
95472	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
95473	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
95474	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	48	
95475	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
95476	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
95477	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	36	
95478	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps C Ø	3.5	
95479	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.6	
95480	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.8	
95481	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	44	
95482	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
95483	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Locks Functioning?	y	
95484	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
95485	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
95486	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
95487	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Foundation Condition	Good	
95488	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Follow-up Action Required?	n	
95489	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Follow-up Action Required?	n	
95490	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations Ground	0	
95491	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations C Ø	0	
95492	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations B Ø	0	
95493	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
95494	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
95495	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
95496	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
95497	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
95498	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
95499	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95500	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95501	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95502	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations A Ø	0	
95503	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95504	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95505	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95506	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95507	11/8/2019 12:21	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95508	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
95509	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95510	11/8/2019 10:19	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
95511	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
95512	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments		
95513	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
95514	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
95515	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
95516	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
95517	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
95518	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
95519	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
95520	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	LTC Operation Checked?	y	
95521	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	General Comments		
95522	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	Follow-up Action Required?	n	
95523	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	All Connections OK?	y	
95524	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
95525	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
95526	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	LTC000773	LTCControl	696-1	LTC Control Insp	VRR Time Delay	30	Seconds
95527	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
95528	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
95529	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
95530	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
95531	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
95532	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
95533	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
95534	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
95535	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
95536	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
95537	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
95538	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
95539	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95540	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Current Tap Position	5L	
95541	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Max Tap Position	3L	
95542	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Min Tap Position	12L	
95543	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
95544	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments	checked breakers but heater not working	
95545	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
95546	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
95547	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95548	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95549	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
95550	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95551	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95552	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95553	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
95554	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
95555	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
95556	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
95557	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
95558	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
95559	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
95560	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
95561	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
95562	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
95563	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
95564	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
95565	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Operations Since Last Insp	873	
95566	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
95567	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95568	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95569	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95570	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95571	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95572	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95573	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95574	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
95575	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
95576	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
95577	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	General Comments		
95578	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	82355	
95579	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	82361	
95580	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95581	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	4L	
95582	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	2L	
95583	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	11L	
95584	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	406	
95585	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95586	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95587	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
95588	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Unknown Operations	0	
95589	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Switching Operations	0	
95590	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
95591	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95592	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AL	235	
95593	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AF	235	
95594	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Maintenance Operations	0	
95595	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	General Comments		
95596	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	General Comments		
95597	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
95598	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
95599	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
95600	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
95601	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
95602	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
95603	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
95604	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
95605	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95606	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95607	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95608	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95609	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
95610	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
95611	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95612	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95613	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
95614	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
95615	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95616	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95617	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95618	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
95619	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
95620	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
95621	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
95622	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95623	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95624	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95625	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95626	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95627	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
95628	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
95629	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95630	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Left Counter	715266	
95631	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Found Counter	715259	
95632	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	General Comments		
95633	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	General Comments		
95634	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95635	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Follow-up Action Required?	n	
95636	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	8	
95637	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95638	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95639	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
95640	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95641	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95642	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95643	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
95644	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95645	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95646	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
95647	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
95648	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments		
95649	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
95650	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
95651	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
95652	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
95653	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
95654	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95655	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
95656	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95657	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95658	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95659	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
95660	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
95661	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95662	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95663	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations	2	
95664	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
95665	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
95666	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
95667	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
95668	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
95669	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
95670	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
95671	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
95672	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
95673	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
95674	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
95675	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
95676	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
95677	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
95678	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95679	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95680	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95681	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
95682	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	9 Month Operations	0	
95683	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
95684	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
95685	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
95686	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps A Ø	18.0	
95687	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	884	
95688	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	9L	
95689	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	2L	
95690	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	3L	
95691	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps B Ø	18.0	
95692	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps C Ø	18.0	
95693	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
95694	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
95695	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
95696	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
95697	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
95698	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95699	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Foundation Condition	Good	
95700	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95701	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95702	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95703	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95704	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	8774	
95705	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	8774	
95706	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
95707	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
95708	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
95709	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
95710	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
95711	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95712	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
95713	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
95714	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
95715	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
95716	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
95717	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
95718	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
95719	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	385.0	
95720	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	343.0	
95721	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	385.0	
95722	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
95723	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
95724	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
95725	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
95726	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
95727	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
95728	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
95729	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
95730	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
95731	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
95732	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
95733	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
95734	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
95735	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
95736	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
95737	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Broom on Site?	y	
95738	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
95739	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
95740	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95741	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Vegetation	None	
95742	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
95743	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
95744	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	General Comments		
95745	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95746	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95747	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Follow-up Action Required?	n	
95748	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Follow-up Action Required?	n	
95749	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95750	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95751	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95752	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95753	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95754	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95755	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
95756	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1496	
95757	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
95758	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Foundation Condition	Good	
95759	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	General Comments		
95760	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	General Comments		
95761	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Grounds in Place?	y	
95762	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Heaters (All) Functioning?	y	
95763	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Maintenance Operations	0	
95764	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Moisture and Leak Free?	y	
95765	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AF	175	
95766	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AL	175	
95767	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations This Read Vac	1	
95768	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
95769	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Switching Operations	0	
95770	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Tank Paint Condition	Good	
95771	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Unknown Operations	0	
95772	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	15R	
95773	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
95774	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95775	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	13959	
95776	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	13952	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
95777	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
95778	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
95779	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95780	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95781	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95782	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95783	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	578	
95784	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
95785	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
95786	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
95787	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95788	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Left Counter	51978	
95789	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Found Counter	51978	
95790	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
95791	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	General Comments		
95792	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95793	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
95794	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
95795	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
95796	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	
95797	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
95798	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
95799	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	
95800	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	
95801	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	
95802	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	
95803	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
95804	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
95805	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments		
95806	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	
95807	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	
95808	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
95809	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
95810	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
95811	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
95812	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
95813	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	186	
95814	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	186	
95815	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
95816	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	General Comments		
95817	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
95818	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
95819	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
95820	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
95821	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
95822	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
95823	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
95824	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
95825	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95826	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95827	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95828	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	32.0	
95829	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	47.0	
95830	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	38.0	
95831	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
95832	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
95833	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
95834	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	0	
95835	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
95836	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
95837	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
95838	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95839	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
95840	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95841	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95842	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95843	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
95844	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
95845	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
95846	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95847	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Vegetation	None	
95848	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
95849	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
95850	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	General Comments		
95851	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95852	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95853	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95854	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95855	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95856	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
95857	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95858	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95859	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
95860	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
95861	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Broom on Site?	y	
95862	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
95863	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
95864	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
95865	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
95866	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
95867	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
95868	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
95869	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
95870	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
95871	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
95872	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
95873	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
95874	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
95875	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Swept?	y	
95876	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
95877	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
95878	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	General Comments		
95879	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
95880	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
95881	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
95882	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
95883	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
95884	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
95885	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
95886	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
95887	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
95888	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
95889	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
95890	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
95891	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
95892	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
95893	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	General Comments		
95894	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
95895	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
95896	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
95897	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
95898	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
95899	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95900	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
95901	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95902	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95903	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
95904	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Vegetation	None	
95905	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
95906	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
95907	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
95908	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
95909	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
95910	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
95911	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
95912	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
95913	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
95914	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
95915	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
95916	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
95917	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
95918	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
95919	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
95920	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	706	
95921	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	General Comments		
95922	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95923	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95924	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95925	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95926	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
95927	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
95928	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95929	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95930	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
95931	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
95932	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
95933	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
95934	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Operations Since Last Insp	2079	
95935	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Min Tap Position	7L	
95936	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Max Tap Position	1L	
95937	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Current Tap Position	3L	
95938	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
95939	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Left Counter	7031	
95940	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Found Counter	7031	
95941	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	General Comments		
95942	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	General Comments		
95943	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95944	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Follow-up Action Required?	n	
95945	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	706	
95946	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
95947	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
95948	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
95949	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
95950	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	General Comments		
95951	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
95952	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
95953	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
95954	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
95955	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
95956	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Trash?	y	
95957	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
95958	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
95959	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
95960	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
95961	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	General Comments		
95962	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
95963	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
95964	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
95965	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
95966	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
95967	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
95968	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
95969	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
95970	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
95971	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
95972	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Reading	.4908	
95973	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Max	65	*C
95974	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Present	30	*C
95975	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
95976	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
95977	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Follow-up Action Required?	n	
95978	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
95979	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	General Comments		
95980	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	General Comments	only one side reset	
95981	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Found Counter	12040	
95982	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Left Counter	12050	
95983	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
95984	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
95985	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
95986	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
95987	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
95988	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
95989	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
95990	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
95991	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
95992	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
95993	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
95994	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
95995	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	36.0	
95996	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
95997	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
95998	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
95999	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96000	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
96001	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
96002	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
96003	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
96004	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
96005	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
96006	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
96007	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	General Comments		
96008	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
96009	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	136	
96010	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	136	
96011	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
96012	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
96013	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
96014	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
96015	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments	fence is old, and looks rough	
96016	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
96017	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
96018	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
96019	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
96020	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	y	
96021	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
96022	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
96023	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
96024	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
96025	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
96026	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments		
96027	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Vegetation	None	
96028	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
96029	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
96030	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
96031	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
96032	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
96033	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
96034	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96035	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96036	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96037	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96038	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96039	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96040	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
96041	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.9084	
96042	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	0	*C
96043	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	0	*C
96044	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
96045	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
96046	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	852	
96047	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	852	
96048	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
96049	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
96050	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
96051	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
96052	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
96053	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	158	
96054	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	158	
96055	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
96056	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96057	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	0	
96058	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
96059	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
96060	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96061	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
96062	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
96063	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
96064	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
96065	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
96066	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
96067	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
96068	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
96069	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
96070	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
96071	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96072	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96073	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96074	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96075	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96076	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96077	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96078	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96079	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96080	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
96081	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
96082	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	321.0	
96083	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
96084	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96085	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96086	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96087	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
96088	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96089	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96090	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96091	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96092	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Follow-up Action Required?	n	
96093	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96094	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96095	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	General Comments		
96096	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	General Comments		
96097	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96098	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	LTC Totalizer Reading	7067.52	kw
96099	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96100	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
96101	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Max	60	°C
96102	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Present	30	°C
96103	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96104	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96105	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96106	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96107	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96108	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Follow-up Action Required?	n	
96109	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96110	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96111	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	General Comments		
96112	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	General Comments		
96113	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96114	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	LTC Totalizer Reading	6220.80	kw
96115	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96116	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
96117	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Max	45	°C
96118	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Present	45	°C
96119	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96120	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96121	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96122	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96123	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96124	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96125	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96126	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
96127	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Reading	.6480	
96128	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
96129	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
96130	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
96131	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
96132	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
96133	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
96134	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
96135	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
96136	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	General Comments		
96137	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
96138	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
96139	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96140	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
96141	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
96142	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	59	
96143	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	59	
96144	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
96145	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96146	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
96147	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
96148	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
96149	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
96150	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
96151	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96152	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96153	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
96154	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
96155	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
96156	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
96157	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
96158	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
96159	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
96160	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
96161	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
96162	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
96163	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
96164	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
96165	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments		
96166	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
96167	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
96168	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
96169	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
96170	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
96171	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
96172	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
96173	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
96174	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
96175	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
96176	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	General Comments		
96177	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
96178	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
96179	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
96180	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
96181	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
96182	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
96183	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
96184	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
96185	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
96186	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
96187	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
96188	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
96189	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Current Tap Position	7L	
96190	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Max Tap Position	4L	
96191	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Min Tap Position	12L	
96192	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
96193	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	°C
96194	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Operations Since Last Insp	2848	
96195	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
96196	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
96197	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
96198	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
96199	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
96200	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96201	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96202	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96203	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
96204	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
96205	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
96206	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
96207	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96208	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96209	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96210	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
96211	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96212	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96213	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96214	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96215	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96216	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
96217	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
96218	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
96219	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
96220	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
96221	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
96222	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
96223	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
96224	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
96225	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
96226	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence 25' Clearance To Trees?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96227	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
96228	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
96229	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
96230	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
96231	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
96232	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96233	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96234	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96235	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
96236	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
96237	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
96238	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
96239	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96240	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96241	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96242	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96243	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96244	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	General Comments		
96245	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	General Comments		
96246	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Grounds in Place?	y	
96247	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96248	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Maintenance Operations	0	
96249	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Moisture and Leak Free?	y	
96250	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AF	189	
96251	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AL	189	
96252	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AL	109	
96253	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations This Read Vac	0	
96254	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Switching Operations	0	
96255	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Unknown Operations	0	
96256	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96257	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96258	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96259	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96260	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps C Ø	50.0	
96261	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps B Ø	49.0	
96262	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps A Ø	49.0	
96263	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96264	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations This Read Vac	0	
96265	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96266	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Switching Operations	0	
96267	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Tank Paint Condition	Good	
96268	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Unknown Operations	0	
96269	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
96270	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
96271	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
96272	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
96273	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96274	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96275	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96276	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96277	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96278	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96279	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96280	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96281	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations	1	
96282	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
96283	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
96284	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
96285	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BK000420	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
96286	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96287	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96288	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96289	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96290	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96291	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96292	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	0	
96293	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96294	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96295	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96296	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	44.0	
96297	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	35.0	
96298	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	Retired Distribution	Retired Distribution	VCB Readings	Unknown Operations	0	
96299	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	Retired Distribution	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
96300	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	Retired Distribution	Retired Distribution	VCB Readings	Switching Operations	4	
96301	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	Retired Distribution	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96302	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
96303	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
96304	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
96305	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
96306	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96307	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
96308	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	47	
96309	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	47	
96310	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
96311	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
96312	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96313	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
96314	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
96315	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
96316	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
96317	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
96318	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
96319	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
96320	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
96321	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
96322	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	187	
96323	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	187	
96324	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
96325	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
96326	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
96327	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
96328	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
96329	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
96330	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
96331	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
96332	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
96333	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	General Comments		
96334	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
96335	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
96336	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
96337	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
96338	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	9 Month Operations	3	
96339	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96340	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96341	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96342	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps A Ø	0.0	
96343	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps B Ø	0.0	
96344	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps C Ø	0.0	
96345	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96346	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96347	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96348	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96349	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations A Ø	0	
96350	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations B Ø	0	
96351	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations C Ø	0	
96352	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations Ground	0	
96353	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
96354	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
96355	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	General Comments		
96356	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	General Comments		
96357	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Maintenance Operations	0	
96358	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AF	109	
96359	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations	3	
96360	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96361	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96362	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96363	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps A Ø	87.0	
96364	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps B Ø	110.0	
96365	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps C Ø	82.0	
96366	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushing Condition	Good	
96367	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96368	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96369	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96370	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
96371	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96372	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96373	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96374	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96375	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96376	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96377	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations B Ø	0	
96378	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations C Ø	0	
96379	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations Ground	0	
96380	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Follow-up Action Required?	n	
96381	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Follow-up Action Required?	n	
96382	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Foundation Condition	Good	
96383	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen	
96384	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96385	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	59	°C
96386	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	39	°C
96387	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96388	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
96389	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
96390	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
96391	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
96392	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96393	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
96394	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
96395	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96396	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96397	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96398	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96399	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96400	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96401	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96402	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
96403	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
96404	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
96405	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96406	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96407	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
96408	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96409	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96410	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96411	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96412	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96413	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96414	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96415	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96416	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96417	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96418	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96419	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96420	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96421	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96422	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
96423	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
96424	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
96425	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
96426	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
96427	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
96428	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	60	°C
96429	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	40	°C
96430	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96431	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96432	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96433	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96434	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96435	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96436	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96437	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
96438	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.2740	
96439	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
96440	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
96441	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Follow-up Action Required?	n	
96442	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96443	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96444	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	General Comments		
96445	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	General Comments		
96446	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96447	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	8720.64	kw
96448	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96449	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
96450	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	45	°C
96451	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	30	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96452	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96453	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
96454	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
96455	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
96456	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
96457	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
96458	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
96459	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96460	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
96461	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
96462	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
96463	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
96464	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
96465	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
96466	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Foundation Condition	Good	
96467	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
96468	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
96469	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
96470	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
96471	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
96472	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96473	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96474	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
96475	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96476	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96477	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96478	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96479	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96480	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
96481	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96482	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96483	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	General Comments		
96484	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
96485	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96486	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96487	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96488	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96489	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
96490	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96491	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96492	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96493	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
96494	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
96495	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	General Comments		
96496	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
96497	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
96498	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
96499	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
96500	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
96501	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
96502	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
96503	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
96504	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	6115.20	kw
96505	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96506	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96507	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96508	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96509	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96510	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96511	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96512	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96513	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96514	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
96515	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96516	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96517	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96518	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
96519	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
96520	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96521	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96522	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	General Comments		
96523	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B Ø	0	
96524	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C Ø	0	
96525	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
96526	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96527	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
96528	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	General Comments		
96529	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments		
96530	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	0	
96531	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	203	
96532	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	203	
96533	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations This Read Vac	0	
96534	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	0	
96535	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
96536	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
96537	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Unknown Operations	0	
96538	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Switching Operations	0	
96539	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations This Read Vac	0	
96540	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AL	125	
96541	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AF	125	
96542	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
96543	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
96544	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
96545	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
96546	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Chipped	
96547	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96548	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96549	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96550	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96551	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
96552	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
96553	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96554	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments		
96555	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
96556	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
96557	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
96558	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10.00	kw
96559	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
96560	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
96561	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
96562	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
96563	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
96564	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
96565	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
96566	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
96567	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
96568	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
96569	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
96570	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
96571	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
96572	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
96573	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
96574	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
96575	11/7/2019 13:26	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0250	
96576	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
96577	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
96578	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
96579	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
96580	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
96581	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
96582	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
96583	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
96584	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
96585	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
96586	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
96587	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
96588	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
96589	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
96590	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	1	
96591	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96592	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations This Read Vac	1	
96593	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	512	
96594	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	512	
96595	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
96596	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
96597	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
96598	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
96599	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Left Counter	20414	
96600	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Found Counter	20414	
96601	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
96602	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	General Comments		
96603	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
96604	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
96605	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
96606	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
96607	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
96608	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
96609	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
96610	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
96611	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
96612	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
96613	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
96614	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
96615	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
96616	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
96617	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
96618	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
96619	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96620	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96621	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96622	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96623	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96624	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96625	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96626	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96627	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96628	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96629	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96630	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
96631	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96632	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96633	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
96634	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	General Comments		
96635	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96636	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96637	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
96638	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
96639	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
96640	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
96641	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96642	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96643	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96644	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96645	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96646	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96647	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96648	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
96649	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
96650	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
96651	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
96652	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	General Comments		
96653	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Maintenance Operations	0	
96654	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AF	669	
96655	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AL	669	
96656	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations This Read Vac	1	
96657	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Switching Operations	0	
96658	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Unknown Operations	1	
96659	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
96660	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
96661	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
96662	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	ST000362	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
96663	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	5	
96664	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96665	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96666	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96667	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A Ø	0.0	
96668	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B Ø	0.0	
96669	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C Ø	0.0	
96670	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96671	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96672	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96673	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96674	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A Ø	0	
96675	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
96676	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96677	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
96678	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96679	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96680	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96681	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96682	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96683	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
96684	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96685	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96686	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96687	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
96688	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	40.0	
96689	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Grounds in Place?	y	
96690	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	General Comments		
96691	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	General Comments		
96692	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Foundation Condition	Good	
96693	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Follow-up Action Required?	n	
96694	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Follow-up Action Required?	n	
96695	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations Ground	0	
96696	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations C Ø	0	
96697	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations B Ø	0	
96698	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations A Ø	0	
96699	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96700	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96701	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96702	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96703	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
96704	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
96705	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
96706	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
96707	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
96708	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushing Condition	Good	
96709	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96710	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	General Comments		
96711	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Follow-up Action Required?	n	
96712	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Follow-up Action Required?	n	
96713	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations Ground	0	
96714	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations C Ø	0	
96715	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations B Ø	0	
96716	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations A Ø	0	
96717	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
96718	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	40.0	
96719	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	40.0	
96720	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96721	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96722	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96723	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	9	
96724	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	142	
96725	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
96726	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
96727	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
96728	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
96729	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
96730	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
96731	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96732	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps C Ø	180.0	
96733	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps B Ø	200.0	
96734	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps A Ø	190.0	
96735	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96736	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96737	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96738	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
96739	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations	2	
96740	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Maintenance Operations	0	
96741	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	General Comments		
96742	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	General Comments		
96743	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
96744	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
96745	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
96746	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
96747	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
96748	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations Ground	0	
96749	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
96750	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
96751	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96752	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
96753	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
96754	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
96755	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
96756	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
96757	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
96758	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
96759	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
96760	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
96761	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	FE000292	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
96762	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
96763	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Vegetation	None	
96764	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
96765	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	General Comments		
96766	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
96767	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
96768	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
96769	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
96770	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
96771	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
96772	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Trash?	y	
96773	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
96774	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
96775	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
96776	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
96777	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
96778	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96779	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
96780	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
96781	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments		
96782	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
96783	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
96784	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	n	
96785	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
96786	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	0	
96787	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
96788	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
96789	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Vegetation	None	
96790	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Unknown Operations	0	
96791	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Switching Operations	0	
96792	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations This Read Vac	0	
96793	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AL	662	
96794	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AF	662	
96795	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Maintenance Operations	0	
96796	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	General Comments		
96797	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Unknown Operations	0	
96798	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Tank Paint Condition	Good	
96799	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Switching Operations	2	
96800	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
96801	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations This Read Vac	7	
96802	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AL	153	
96803	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AF	146	
96804	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Moisture and Leak Free?	y	
96805	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Maintenance Operations	5	
96806	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
96807	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2020-02-19 00:00:00.000000	
96808	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
96809	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
96810	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	General Comments		
96811	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
96812	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
96813	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
96814	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
96815	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
96816	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
96817	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Trash?	y	
96818	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
96819	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
96820	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
96821	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
96822	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
96823	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
96824	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
96825	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
96826	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
96827	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
96828	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	51	°C
96829	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96830	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
96831	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	47	°C
96832	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
96833	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96834	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96835	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96836	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96837	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
96838	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96839	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96840	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
96841	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
96842	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
96843	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	50	
96844	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	50	
96845	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
96846	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
96847	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
96848	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
96849	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
96850	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Regulator As Left Counter	12844	
96851	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
96852	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
96853	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Tank Leaks	None	
96854	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
96855	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
96856	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
96857	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
96858	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
96859	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
96860	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
96861	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
96862	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
96863	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
96864	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
96865	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
96866	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
96867	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
96868	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
96869	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
96870	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	35	°C
96871	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	120	°C
96872	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	55	°C
96873	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
96874	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
96875	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
96876	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	°C
96877	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	240.0	
96878	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
96879	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
96880	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
96881	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
96882	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
96883	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
96884	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Min Tap Position	13L	
96885	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Max Tap Position	6L	
96886	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	55	°C
96887	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96888	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	General Comments		
96889	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
96890	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96891	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96892	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
96893	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96894	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
96895	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
96896	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96897	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
96898	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96899	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96900	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96901	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
96902	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96903	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96904	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	132	°C
96905	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
96906	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
96907	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
96908	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
96909	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
96910	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
96911	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
96912	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
96913	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
96914	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
96915	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
96916	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
96917	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
96918	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
96919	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
96920	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
96921	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
96922	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
96923	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
96924	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
96925	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
96926	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
96927	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
96928	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
96929	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
96930	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
96931	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
96932	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
96933	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
96934	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
96935	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
96936	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
96937	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
96938	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
96939	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
96940	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
96941	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
96942	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
96943	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
96944	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
96945	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
96946	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
96947	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
96948	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
96949	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
96950	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
96951	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
96952	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
96953	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
96954	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
96955	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
96956	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
96957	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
96958	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
96959	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
96960	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
96961	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
96962	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
96963	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
96964	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
96965	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
96966	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	
96967	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
96968	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
96969	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
96970	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
96971	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
96972	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
96973	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
96974	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
96975	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
96976	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
96977	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
96978	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
96979	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
96980	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Unknown Operations	0	
96981	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Switching Operations	0	
96982	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Unknown Operations	0	
96983	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
96984	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
96985	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
96986	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
96987	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations	2	
96988	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
96989	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
96990	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
96991	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps A Ø	0.0	
96992	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps B Ø	0.0	
96993	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps C Ø	0.0	
96994	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
96995	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
96996	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
96997	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
96998	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
96999	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000285	LTCControl	FH-TRANS 1	LTC Control Insp	General Comments		
97000	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
97001	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations A Ø	0	
97002	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations B Ø	0	
97003	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
97004	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Unknown Operations	0	
97005	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Switching Operations	0	
97006	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations This Read Vac	0	
97007	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AL	186	
97008	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AF	186	
97009	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Maintenance Operations	0	
97010	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	General Comments		
97011	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	General Comments		
97012	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
97013	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
97014	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations Ground	0	
97015	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
97016	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
97017	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
97018	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97019	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97020	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97021	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97022	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps C Ø	517.0	
97023	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps B Ø	509.0	
97024	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps A Ø	474.0	
97025	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97026	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97027	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
97028	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
97029	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
97030	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
97031	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	General Comments		
97032	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
97033	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
97034	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
97035	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
97036	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
97037	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations C Ø	0	
97038	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations Ground	0	
97039	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97040	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	9 Month Operations	0	
97041	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97042	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97043	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
97044	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97045	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	458	
97046	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	12	*C
97047	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	*C
97048	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Follow-up Action Required?	n	
97049	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Follow-up Action Required?	n	
97050	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	General Comments		
97051	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97052	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
97053	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
97054	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	9L	
97055	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97056	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
97057	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
97058	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations	0	
97059	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97060	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97061	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97062	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps A Ø	0.0	
97063	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps B Ø	0.0	
97064	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps C Ø	0.0	
97065	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97066	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97067	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97068	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97069	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations A Ø	0	
97070	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations B Ø	0	
97071	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations C Ø	0	
97072	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations Ground	0	
97073	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Follow-up Action Required?	n	
97074	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Follow-up Action Required?	n	
97075	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	General Comments		
97076	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	General Comments		
97077	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Maintenance Operations	0	
97078	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AF	131	
97079	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations Ground	0	
97080	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations C Ø	0	
97081	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations B Ø	0	
97082	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations A Ø	0	
97083	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97084	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97085	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97086	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97087	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97088	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97089	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
97090	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
97091	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushing Condition	Good	
97092	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps C Ø	300.0	
97093	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps B Ø	321.0	
97094	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps A Ø	300.0	
97095	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97096	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97097	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97098	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations	1	
97099	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
97100	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
97101	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	General Comments		
97102	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
97103	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
97104	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
97105	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AL	131	
97106	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations This Read Vac	0	
97107	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Grounds in Place?	y	
97108	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	General Comments		
97109	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
97110	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Foundation Condition	Good	
97111	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
97112	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
97113	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Current Tap Position	8L	
97114	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
97115	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
97116	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
97117	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
97118	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	KR0042	Regulator	845-2458 C-Line	Regulator Patrol Inspection	Bushing Condition	Good	
97119	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Follow-up Action Required?	n	
97120	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Follow-up Action Required?	n	
97121	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Foundation Condition	Good	
97122	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	General Comments		
97123	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	General Comments		
97124	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Grounds in Place?	y	
97125	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
97126	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97127	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Moisture and Leak Free?	y	
97128	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AF	344	
97129	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AL	344	
97130	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations This Read Vac	0	
97131	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Switching Operations	0	
97132	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Tank Paint Condition	Good	
97133	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps C Ø	75.0	
97134	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97135	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97136	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97137	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97138	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations A Ø	0	
97139	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations B Ø	0	
97140	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations C Ø	0	
97141	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations Ground	0	
97142	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
97143	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Follow-up Action Required?	n	
97144	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	General Comments		
97145	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	General Comments		
97146	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Maintenance Operations	0	
97147	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AF	651	
97148	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AL	651	
97149	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations This Read Vac	0	
97150	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Switching Operations	0	
97151	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Unknown Operations	0	
97152	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
97153	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
97154	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
97155	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
97156	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
97157	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
97158	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Foundation Condition	Good	
97159	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
97160	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
97161	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	General Comments		
97162	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
97163	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
97164	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
97165	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
97166	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
97167	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
97168	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
97169	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
97170	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
97171	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
97172	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
97173	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
97174	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	12	
97175	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
97176	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
97177	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	General Comments		
97178	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	12	
97179	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	378	
97180	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	378	
97181	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
97182	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	General Comments		
97183	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
97184	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
97185	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
97186	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
97187	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
97188	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
97189	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
97190	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97191	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97192	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97193	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97194	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
97195	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
97196	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
97197	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97198	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97199	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97200	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	17	
97201	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97202	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97203	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97204	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97205	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Follow-up Action Required?	n	
97206	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
97207	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	General Comments		
97208	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Tank Paint Condition	Good	
97209	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps B Ø	196.0	
97210	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps A Ø	194.0	
97211	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97212	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97213	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97214	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations	2	
97215	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
97216	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
97217	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
97218	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
97219	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
97220	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
97221	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
97222	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
97223	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
97224	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
97225	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
97226	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
97227	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
97228	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
97229	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations	5	
97230	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
97231	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
97232	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1017	
97233	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97234	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
97235	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
97236	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
97237	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
97238	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97239	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97240	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
97241	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
97242	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
97243	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
97244	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
97245	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
97246	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1860	
97247	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
97248	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
97249	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
97250	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
97251	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
97252	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
97253	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
97254	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
97255	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
97256	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
97257	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
97258	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	446.40	kw
97259	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
97260	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
97261	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
97262	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
97263	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	General Comments		
97264	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
97265	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
97266	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
97267	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
97268	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
97269	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
97270	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
97271	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
97272	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
97273	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
97274	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
97275	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
97276	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97277	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
97278	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
97279	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations	15	
97280	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97281	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97282	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97283	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps A Ø	71.0	
97284	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps B Ø	69.0	
97285	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AL	19	
97286	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations This Read Vac	2	
97287	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Switching Operations	0	
97288	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Unknown Operations	2	
97289	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
97290	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	General Comments		
97291	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
97292	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
97293	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
97294	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
97295	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
97296	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
97297	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
97298	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
97299	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
97300	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
97301	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
97302	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
97303	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
97304	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
97305	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
97306	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
97307	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
97308	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
97309	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
97310	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
97311	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
97312	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
97313	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
97314	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
97315	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
97316	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
97317	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
97318	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
97319	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
97320	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
97321	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
97322	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
97323	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
97324	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
97325	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
97326	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
97327	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps A Ø	130.0	
97328	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps B Ø	130.0	
97329	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps C Ø	130.0	
97330	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushing Condition	Good	
97331	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushings Connection/Risers	Good	
97332	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
97333	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
97334	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97335	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97336	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97337	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
97338	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97339	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97340	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
97341	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
97342	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
97343	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
97344	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
97345	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
97346	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
97347	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
97348	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations A Ø	1	
97349	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations B Ø	0	
97350	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations C Ø	0	
97351	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97352	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	General Comments		
97353	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
97354	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations Ground	0	
97355	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
97356	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Swept?	y	
97357	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
97358	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
97359	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
97360	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
97361	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Switching Operations	0	
97362	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
97363	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations This Read Vac	0	
97364	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AL	148	
97365	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AF	148	
97366	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
97367	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Maintenance Operations	0	
97368	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
97369	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Grounds in Place?	y	
97370	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	General Comments		
97371	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	General Comments		
97372	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Foundation Condition	Good	
97373	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC0000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
97374	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC0000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
97375	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Follow-up Action Required?	n	
97376	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Follow-up Action Required?	n	
97377	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations Ground	0	
97378	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations C Ø	0	
97379	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations B Ø	0	
97380	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations A Ø	0	
97381	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97382	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97383	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97384	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97385	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97386	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97387	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
97388	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
97389	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
97390	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushing Condition	Good	
97391	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps C Ø	235.0	
97392	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps B Ø	277.0	
97393	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps A Ø	234.0	
97394	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97395	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations	6	
97396	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97397	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Found Counter	219860	
97398	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Left Counter	219867	
97399	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97400	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Current Tap Position	3L	
97401	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Max Tap Position	8L	
97402	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Min Tap Position	2R	
97403	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Operations Since Last Insp	2522	
97404	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97405	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
97406	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97407	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97408	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
97409	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
97410	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
97411	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
97412	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
97413	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97414	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97415	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps A Ø	140.0	
97416	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps B Ø	160.0	
97417	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps C Ø	140.0	
97418	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97419	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
97420	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC0000054	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
97421	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC0000054	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
97422	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC0000054	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
97423	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
97424	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
97425	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations A Ø	0	
97426	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97427	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations C Ø	0	
97428	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations Ground	0	
97429	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Follow-up Action Required?	n	
97430	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Follow-up Action Required?	n	
97431	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	General Comments		
97432	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC000054	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
97433	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC000054	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
97434	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	LTC000054	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
97435	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	General Comments		
97436	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Maintenance Operations	0	
97437	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AF	19	
97438	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
97439	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
97440	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
97441	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
97442	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
97443	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
97444	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	General Comments		
97445	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
97446	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
97447	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
97448	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
97449	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
97450	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
97451	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
97452	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
97453	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
97454	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
97455	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
97456	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
97457	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
97458	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
97459	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
97460	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
97461	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97462	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97463	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97464	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps A Ø	669.0	
97465	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps B Ø	593.0	
97466	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps C Ø	585.0	
97467	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97468	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
97469	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
97470	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
97471	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
97472	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
97473	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
97474	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations Ground	0	
97475	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
97476	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
97477	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	General Comments		
97478	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	General Comments		
97479	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Maintenance Operations	0	
97480	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AF	173	
97481	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AL	173	
97482	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations This Read Vac	1	
97483	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Switching Operations	0	
97484	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Unknown Operations	1	
97485	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
97486	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
97487	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
97488	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
97489	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
97490	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
97491	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
97492	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
97493	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
97494	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000042	LTCControl	FH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
97495	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000042	LTCControl	FH-TRANS 2	LTC Control Insp	General Comments		
97496	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTC000042	LTCControl	FH-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
97497	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC0000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
97498	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC0000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments		
97499	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC0000445	LTCControl	GL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
97500	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC0000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	116.7	VAC
97501	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC0000446	LTCControl	GL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97502	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	General Comments		
97503	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
97504	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load Y2 Max	0	%
97505	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load X2 Max	0	%
97506	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load H2 Max	0	%
97507	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Present	25	*C
97508	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Max	25	*C
97509	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
97510	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
97511	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
97512	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
97513	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
97514	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
97515	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97516	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97517	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97518	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97519	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	YD000359	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	45	*F
97520	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
97521	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
97522	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
97523	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
97524	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
97525	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
97526	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
97527	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
97528	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments		
97529	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
97530	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
97531	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
97532	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
97533	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
97534	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
97535	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
97536	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
97537	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
97538	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
97539	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
97540	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
97541	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps C Ø	0.0	
97542	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps B Ø	0.0	
97543	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps A Ø	0.0	
97544	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97545	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97546	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97547	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations	0	
97548	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97549	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97550	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations	10	
97551	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
97552	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
97553	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
97554	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
97555	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
97556	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
97557	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
97558	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Present	40	*C
97559	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
97560	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
97561	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
97562	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
97563	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
97564	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations	1	
97565	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
97566	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
97567	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
97568	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
97569	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
97570	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
97571	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Foundation Condition	Good	
97572	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
97573	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
97574	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	General Comments		
97575	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	General Comments		
97576	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97577	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
97578	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
97579	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
97580	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
97581	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
97582	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
97583	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
97584	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
97585	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	General Comments		
97586	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
97587	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
97588	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
97589	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
97590	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
97591	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Left Counter	51899	
97592	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97593	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	15L	
97594	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
97595	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
97596	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
97597	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
97598	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Unknown Operations	0	
97599	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Switching Operations	0	
97600	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations This Read Vac	0	
97601	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AL	798	
97602	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AF	798	
97603	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Maintenance Operations	0	
97604	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	General Comments	Actual counter	
97605	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	General Comments		
97606	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
97607	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
97608	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
97609	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
97610	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
97611	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Unknown Operations	1	
97612	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Follow-up Action Required?	n	
97613	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Follow-up Action Required?	n	
97614	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations Ground	0	
97615	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations C Ø	0	
97616	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations B Ø	0	
97617	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations A Ø	0	
97618	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97619	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97620	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97621	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97622	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps C Ø	200.0	
97623	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps B Ø	200.0	
97624	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps A Ø	200.0	
97625	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97626	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97627	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97628	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations	5	
97629	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Switching Operations	0	
97630	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations This Read Vac	1	
97631	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AL	150	
97632	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AF	150	
97633	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Maintenance Operations	0	
97634	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	General Comments		
97635	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	General Comments		
97636	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Follow-up Action Required?	n	
97637	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
97638	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
97639	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
97640	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
97641	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
97642	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
97643	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
97644	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
97645	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
97646	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
97647	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
97648	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
97649	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations Ground	0	
97650	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	General Comments		
97651	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97652	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
97653	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
97654	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Foundation Condition	Good	
97655	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
97656	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	General Comments		
97657	11/7/2019 10:39	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
97658	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations C Ø	0	
97659	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations B Ø	0	
97660	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations A Ø	0	
97661	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
97662	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
97663	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
97664	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97665	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps C Ø	181.0	
97666	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Unknown Operations	0	
97667	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Switching Operations	0	
97668	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations This Read Vac	0	
97669	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AL	249	
97670	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AF	249	
97671	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Maintenance Operations	0	
97672	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	General Comments	Actual Counter	
97673	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	General Comments		
97674	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Follow-up Action Required?	n	
97675	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
97676	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations Ground	0	
97677	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations C Ø	0	
97678	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations B Ø	0	
97679	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations A Ø	0	
97680	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
97681	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
97682	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	General Comments		
97683	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	General Comments		
97684	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
97685	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Follow-up Action Required?	n	
97686	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
97687	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
97688	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
97689	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
97690	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
97691	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
97692	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
97693	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
97694	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
97695	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97696	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97697	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97698	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97699	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps C Ø	133.0	
97700	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps B Ø	117.0	
97701	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps A Ø	198.0	
97702	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97703	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97704	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97705	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations	9	
97706	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
97707	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
97708	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
97709	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
97710	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
97711	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
97712	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
97713	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
97714	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
97715	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
97716	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
97717	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
97718	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
97719	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	General Comments		
97720	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
97721	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
97722	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
97723	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
97724	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
97725	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
97726	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97727	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
97728	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
97729	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
97730	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
97731	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
97732	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
97733	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	General Comments		
97734	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
97735	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Found Counter	51899	
97736	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
97737	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	General Comments		
97738	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
97739	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
97740	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
97741	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
97742	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
97743	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
97744	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
97745	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
97746	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	General Comments		
97747	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
97748	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
97749	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
97750	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97751	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97752	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97753	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97754	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97755	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97756	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
97757	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
97758	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
97759	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
97760	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
97761	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
97762	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
97763	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97764	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97765	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
97766	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Found Counter	31764	
97767	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Left Counter	31764	
97768	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97769	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
97770	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
97771	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
97772	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	235	
97773	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97774	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
97775	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97776	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97777	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
97778	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
97779	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	General Comments		
97780	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
97781	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Found Counter	84018	
97782	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Left Counter	84018	
97783	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97784	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
97785	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
97786	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
97787	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1046	
97788	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97789	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
97790	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97791	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97792	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97793	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
97794	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
97795	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
97796	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
97797	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
97798	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	202	
97799	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	201	
97800	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
97801	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97802	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
97803	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
97804	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	General Comments		
97805	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		TR-2 low oil level in LTC alarm is in and isolated, TR-2 needs oil in the LTC compartment
97806	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Found Counter	106098	
97807	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Left Counter	106098	
97808	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
97809	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	14L	
97810	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
97811	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
97812	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
97813	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1037	
97814	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
97815	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
97816	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
97817	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
97818	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Unknown Operations	0	
97819	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Oil Level	Good	
97820	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Leaks	None	
97821	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Switching Operations	0	
97822	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations This Read Oil	0	
97823	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AL	517	
97824	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AF	517	
97825	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Number of Ops last 9 Months	2	
97826	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Maintenance Operations	0	
97827	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	General Comments		
97828	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	General Comments		
97829	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Follow-up Action Required?	n	
97830	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Follow-up Action Required?	n	
97831	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Fault Operations	0	
97832	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Equipment Properly Labeled?	y	
97833	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps C Ø	0.0	
97834	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps B Ø	0.0	
97835	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps A Ø	0.0	
97836	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
97837	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
97838	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
97839	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
97840	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
97841	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
97842	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
97843	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps B Ø	60.0	
97844	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps C Ø	20.0	
97845	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushing Condition	Good	
97846	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushings Connection/Risers	Good	
97847	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
97848	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
97849	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97850	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97851	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97852	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97853	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97854	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97855	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations A Ø	0	
97856	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations B Ø	0	
97857	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations C Ø	0	
97858	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations Ground	0	
97859	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Follow-up Action Required?	n	
97860	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
97861	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
97862	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
97863	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	113	
97864	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	113	
97865	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
97866	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Not in service	
97867	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
97868	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
97869	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
97870	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
97871	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
97872	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
97873	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
97874	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
97875	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
97876	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
97877	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
97878	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
97879	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
97880	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
97881	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
97882	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
97883	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
97884	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
97885	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Follow-up Action Required?	n	
97886	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Foundation Condition	Good	
97887	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	General Comments		
97888	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	General Comments		
97889	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Grounds in Place?	y	
97890	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Heaters (All) Functioning?	y	
97891	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Maintenance Operations	0	
97892	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Moisture and Leak Free?	y	
97893	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
97894	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Unknown Operations	0	
97895	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Switching Operations	0	
97896	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations This Read Vac	0	
97897	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AL	122	
97898	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AF	122	
97899	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Maintenance Operations	0	
97900	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	General Comments		
97901	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	General Comments		
97902	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Follow-up Action Required?	n	
97903	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Follow-up Action Required?	n	
97904	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations Ground	0	
97905	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations C Ø	0	
97906	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations B Ø	0	
97907	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations A Ø	0	
97908	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97909	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97910	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97911	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97912	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps C Ø	0.0	
97913	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps B Ø	0.0	
97914	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps A Ø	0.0	
97915	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97916	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97917	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97918	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations	0	
97919	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Unknown Operations	0	
97920	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Tank Paint Condition	Good	
97921	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Switching Operations	0	
97922	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations This Read Vac	0	
97923	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AL	173	
97924	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AF	173	
97925	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Moisture and Leak Free?	y	
97926	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Maintenance Operations	0	
97927	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Grounds in Place?	y	
97928	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	General Comments		
97929	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	General Comments		
97930	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Foundation Condition	Good	
97931	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Follow-up Action Required?	n	
97932	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Follow-up Action Required?	n	
97933	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations Ground	0	
97934	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations C Ø	0	
97935	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations B Ø	0	
97936	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations A Ø	0	
97937	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97938	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97939	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations	4	
97940	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
97941	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
97942	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
97943	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps A Ø	20.0	
97944	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
97945	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
97946	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
97947	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
97948	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
97949	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
97950	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
97951	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
97952	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
97953	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
97954	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
97955	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
97956	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
97957	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
97958	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
97959	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
97960	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
97961	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
97962	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
97963	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
97964	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	221	
97965	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
97966	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
97967	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
97968	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
97969	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
97970	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
97971	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
97972	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97973	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
97974	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97975	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	5	
97976	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	5	
97977	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations This Read Vac	0	
97978	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	0	
97979	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
97980	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
97981	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97982	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
97983	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97984	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
97985	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97986	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
97987	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97988	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
97989	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
97990	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
97991	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
97992	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
97993	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
97994	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AF	130	
97995	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AL	130	
97996	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations This Read Vac	0	
97997	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Switching Operations	0	
97998	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Unknown Operations	0	
97999	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
98000	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
98001	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
98002	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
98003	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
98004	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
98005	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
98006	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
98007	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
98008	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
98009	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
98010	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
98011	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
98012	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BAT001366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
98013	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Follow-up Action Required?	n	
98014	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
98015	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	General Comments		
98016	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments		
98017	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
98018	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
98019	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
98020	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
98021	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
98022	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
98023	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	5	
98024	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98025	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98026	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98027	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
98028	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
98029	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
98030	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98031	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
98032	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
98033	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
98034	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98035	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
98036	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98037	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98038	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98039	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
98040	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	90.0	
98041	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
98042	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
98043	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98044	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0329	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98045	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
98046	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
98047	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
98048	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
98049	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
98050	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
98051	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	General Comments		
98052	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
98053	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
98054	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
98055	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
98056	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
98057	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
98058	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
98059	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98060	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
98061	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
98062	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
98063	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
98064	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
98065	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
98066	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98067	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
98068	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
98069	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
98070	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
98071	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
98072	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
98073	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	42	
98074	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	42	
98075	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
98076	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
98077	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
98078	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
98079	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
98080	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
98081	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
98082	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
98083	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
98084	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
98085	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
98086	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
98087	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
98088	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
98089	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
98090	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	90.0	
98091	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
98092	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
98093	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
98094	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
98095	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
98096	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
98097	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
98098	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
98099	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	4	
98100	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98101	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
98102	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98103	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	0.0	
98104	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	0.0	
98105	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	0.0	
98106	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98107	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98108	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98109	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98110	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
98111	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
98112	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
98113	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
98114	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Follow-up Action Required?	n	
98115	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
98116	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	General Comments		
98117	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments		
98118	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	0	
98119	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	203	
98120	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	203	
98121	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations This Read Vac	0	
98122	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	0	
98123	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
98124	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	General Comments		
98125	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
98126	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	196	
98127	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	196	
98128	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
98129	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
98130	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	1	
98131	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
98132	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	68	°C
98133	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
98134	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	67	°C
98135	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
98136	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	67	°C
98137	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
98138	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
98139	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
98140	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
98141	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
98142	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
98143	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
98144	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
98145	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
98146	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
98147	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
98148	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	9 Month Operations	5	
98149	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98150	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98151	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98152	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.8928	
98153	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Winding Temp Max	0	°C
98154	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Winding Temp Present	0	°C
98155	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps A Ø	50.0	
98156	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps B Ø	38.0	
98157	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps C Ø	42.0	
98158	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushing Condition	Good	
98159	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98160	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98161	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98162	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98163	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98164	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98165	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98166	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98167	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98168	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations A Ø	0	
98169	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations B Ø	0	
98170	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations C Ø	0	
98171	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations Ground	0	
98172	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Follow-up Action Required?	n	
98173	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Follow-up Action Required?	n	
98174	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Foundation Condition	Good	
98175	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	General Comments		
98176	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98177	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Grounds in Place?	y	
98178	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Maintenance Operations	0	
98179	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Moisture and Leak Free?	y	
98180	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AF	206	
98181	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AL	206	
98182	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations This Read Vac	0	
98183	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Switching Operations	0	
98184	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Tank Paint Condition	Good	
98185	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Unknown Operations	0	
98186	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations	18	
98187	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98188	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98189	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98190	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps A Ø	86.0	
98191	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps B Ø	92.0	
98192	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps C Ø	99.0	
98193	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98194	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98195	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98196	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
98197	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Foundation Condition	Good	
98198	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
98199	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	General Comments		
98200	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Grounds in Place?	y	
98201	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Max Tap Position	6L	
98202	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Min Tap Position	13L	
98203	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
98204	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
98205	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
98206	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
98207	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
98208	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Regulator As Left Counter	29282	
98209	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
98210	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
98211	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Tank Leaks	None	
98212	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
98213	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
98214	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
98215	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
98216	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98217	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
98218	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
98219	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
98220	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
98221	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98222	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
98223	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
98224	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
98225	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
98226	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
98227	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
98228	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
98229	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	new nitrogen bottle	
98230	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
98231	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
98232	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
98233	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1900	psi
98234	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
98235	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	9374.40	kw
98236	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
98237	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
98238	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
98239	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
98240	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
98241	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
98242	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
98243	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
98244	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
98245	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
98246	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
98247	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Maintenance Operations	0	
98248	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
98249	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AF	178	
98250	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AL	178	
98251	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations This Read Vac	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98252	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Switching Operations	0	
98253	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Unknown Operations	1	
98254	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations	1	
98255	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98256	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98257	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98258	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps A Ø	121.0	
98259	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps B Ø	135.0	
98260	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps C Ø	131.0	
98261	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98262	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98263	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98264	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98265	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98266	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98267	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98268	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98269	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
98270	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
98271	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
98272	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
98273	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98274	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BCH000494	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
98275	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98276	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations A Ø	0	
98277	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations B Ø	0	
98278	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations C Ø	0	
98279	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations Ground	0	
98280	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
98281	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Follow-up Action Required?	n	
98282	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	General Comments		
98283	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	General Comments		
98284	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
98285	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Maintenance Operations	0	
98286	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Moisture and Leak Free?	y	
98287	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AF	162	
98288	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AL	162	
98289	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations This Read Vac	0	
98290	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Switching Operations	0	
98291	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Unknown Operations	0	
98292	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations	1	
98293	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations	0	
98294	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98295	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98296	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98297	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98298	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98299	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98300	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98301	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations A Ø	0	
98302	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations B Ø	0	
98303	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations C Ø	0	
98304	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations Ground	0	
98305	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
98306	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Follow-up Action Required?	n	
98307	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	General Comments		
98308	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	General Comments		
98309	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
98310	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Maintenance Operations	0	
98311	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
98312	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AF	224	
98313	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AL	224	
98314	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations This Read Vac	0	
98315	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Switching Operations	0	
98316	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98317	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
98318	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
98319	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
98320	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
98321	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98322	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BCH000529	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
98323	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Unknown Operations	0	
98324	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations	1	
98325	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98326	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98327	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98328	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps A Ø	38.0	
98329	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps B Ø	44.0	
98330	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps C Ø	32.0	
98331	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98332	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98333	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98334	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98335	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98336	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
98337	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
98338	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
98339	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations A Ø	0	
98340	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations B Ø	0	
98341	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations C Ø	0	
98342	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations Ground	0	
98343	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
98344	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Follow-up Action Required?	n	
98345	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	General Comments		
98346	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	General Comments		
98347	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Follow-up Action Required?	n	
98348	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations Ground	0	
98349	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations C Ø	0	
98350	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations B Ø	0	
98351	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations A Ø	0	
98352	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98353	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98354	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98355	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98356	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98357	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98358	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98359	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98360	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98361	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
98362	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	257.0	
98363	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
98364	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
98365	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	General Comments		
98366	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs to be replaced	
98367	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Found Counter	131932	
98368	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Left Counter	131932	
98369	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
98370	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
98371	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
98372	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
98373	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1193	
98374	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
98375	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
98376	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
98377	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
98378	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	275.0	
98379	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	268.0	
98380	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98381	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98382	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98383	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	2	
98384	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Unknown Operations	0	
98385	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Tank Paint Condition	Good	
98386	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Switching Operations	4	
98387	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
98388	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations This Read Vac	4	
98389	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AL	182	
98390	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AF	182	
98391	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Moisture and Leak Free?	y	
98392	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Maintenance Operations	0	
98393	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
98394	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Grounds in Place?	y	
98395	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	General Comments		
98396	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	General Comments		
98397	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AF	249	
98398	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AL	249	
98399	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations This Read Vac	0	
98400	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
98401	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98402	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Tank Paint Condition	Good	
98403	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Unknown Operations	0	
98404	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98405	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98406	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98407	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98408	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98409	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Winding Temp Max	60	*C
98410	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
98411	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
98412	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
98413	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
98414	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
98415	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
98416	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
98417	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
98418	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
98419	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
98420	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
98421	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
98422	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98423	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98424	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
98425	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98426	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98427	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
98428	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	432.0	
98429	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	440.0	
98430	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	437.0	
98431	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98432	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98433	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98434	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	2	
98435	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
98436	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
98437	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Switching Operations	0	
98438	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations This Read Vac	0	
98439	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AL	185	
98440	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AF	185	
98441	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Moisture and Leak Free?	y	
98442	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Maintenance Operations	0	
98443	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Grounds in Place?	y	
98444	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	General Comments		
98445	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	General Comments		
98446	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Foundation Condition	Good	
98447	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Follow-up Action Required?	n	
98448	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
98449	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
98450	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98451	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
98452	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Bushing Condition	Good	
98453	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
98454	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
98455	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
98456	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
98457	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Current Tap Position	9L	
98458	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
98459	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Follow-up Action Required?	n	
98460	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Foundation Condition	Good	
98461	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
98462	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	General Comments		
98463	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Grounds in Place?	y	
98464	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Max Tap Position	5L	
98465	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Min Tap Position	12L	
98466	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
98467	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
98468	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Oil Level	Good	
98469	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Operation Checked?	y	
98470	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
98471	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Regulator As Left Counter	37559	
98472	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
98473	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
98474	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Tank Leaks	None	
98475	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
98476	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
98477	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
98478	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
98479	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
98480	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
98481	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
98482	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
98483	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
98484	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
98485	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
98486	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
98487	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
98488	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
98489	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BAT000493	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
98490	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1479	Regulator	845-2458 B-Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
98491	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Bushing Condition		
98492	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
98493	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
98494	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
98495	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
98496	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Current Tap Position	9L	
98497	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	R1481	Regulator	845-2458 A-Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
98498	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Foundation Condition	Good	
98499	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Follow-up Action Required?	n	
98500	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Follow-up Action Required?	n	
98501	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations Ground	0	
98502	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations C Ø	0	
98503	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations B Ø	0	
98504	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations A Ø	0	
98505	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98506	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98507	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98508	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98509	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98510	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98511	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98512	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98513	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98514	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushing Condition	Good	
98515	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps C Ø	60.0	
98516	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps B Ø	60.0	
98517	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps A Ø	60.0	
98518	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98519	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98520	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98521	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations	13	
98522	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	0	
98523	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98524	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98525	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98526	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
98527	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
98528	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
98529	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98530	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98531	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98532	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98533	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
98534	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
98535	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
98536	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
98537	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
98538	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
98539	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
98540	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
98541	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
98542	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	110	
98543	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	110	
98544	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
98545	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
98546	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
98547	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98548	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
98549	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC0000459	LTCControl	854-1	LTC Control Insp	LTC Operation Checked?	y	
98550	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations This Read Vac	1	
98551	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
98552	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCCControl	854-1	LTC Control Insp	General Comments		
98553	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCCControl	854-1	LTC Control Insp	Follow-up Action Required?	n	
98554	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
98555	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98556	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
98557	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98558	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCCControl	854-1	LTC Control Insp	All Connections OK?	y	
98559	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Unknown Operations	1	
98560	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
98561	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98562	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations	5	
98563	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98564	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98565	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98566	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps A Ø	300.0	
98567	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps B Ø	300.0	
98568	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps C Ø	340.0	
98569	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98570	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
98571	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
98572	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
98573	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations A Ø	0	
98574	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations B Ø	0	
98575	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations C Ø	0	
98576	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations Ground	0	
98577	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Follow-up Action Required?	n	
98578	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Follow-up Action Required?	n	
98579	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	General Comments		
98580	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	General Comments		
98581	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Maintenance Operations	0	
98582	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AF	43	
98583	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
98584	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
98585	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
98586	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Trash?	y	
98587	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
98588	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
98589	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
98590	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
98591	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
98592	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
98593	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	General Comments		
98594	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
98595	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
98596	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
98597	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Vegetation	None	
98598	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
98599	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98600	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98601	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps A Ø	753.0	
98602	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps B Ø	736.0	
98603	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps C Ø	725.0	
98604	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98605	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98606	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98607	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98608	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
98609	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
98610	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
98611	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
98612	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
98613	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
98614	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	General Comments		
98615	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	General Comments		
98616	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Maintenance Operations	0	
98617	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AF	163	
98618	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AL	163	
98619	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
98620	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Switching Operations	0	
98621	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Unknown Operations	0	
98622	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations	2	
98623	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98624	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98625	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98626	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps A Ø	800.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
98627	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps B Ø	800.0	
98628	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps C Ø	800.0	
98629	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98630	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
98631	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
98632	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
98633	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
98634	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
98635	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
98636	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
98637	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
98638	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
98639	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	General Comments		
98640	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	General Comments		
98641	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Maintenance Operations	0	
98642	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AF	428	
98643	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AL	428	
98644	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC000459	LTCControl	854-1	LTC Control Insp	VRR Time Delay	30	Seconds
98645	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
98646	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
98647	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC000459	LTCControl	854-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
98648	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	LTC000459	LTCControl	854-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
98649	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Foundation Condition	Good	
98650	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	General Comments		
98651	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	General Comments		
98652	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Grounds in Place?	y	
98653	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
98654	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Maintenance Operations	0	
98655	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Moisture and Leak Free?	y	
98656	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AF	322	
98657	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AL	322	
98658	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations This Read Vac	0	
98659	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
98660	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
98661	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	General Comments		
98662	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98663	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
98664	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
98665	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
98666	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
98667	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98668	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
98669	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
98670	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
98671	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
98672	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	General Comments		
98673	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
98674	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
98675	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Switching Operations	0	
98676	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Tank Paint Condition	Good	
98677	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Unknown Operations	0	
98678	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
98679	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
98680	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
98681	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98682	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
98683	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
98684	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
98685	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
98686	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98687	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
98688	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
98689	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
98690	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
98691	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
98692	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
98693	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
98694	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
98695	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98696	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98697	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
98698	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
98699	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
98700	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
98701	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
98702	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
98703	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
98704	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
98705	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Foundation Condition	Good	
98706	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
98707	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
98708	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	General Comments		
98709	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
98710	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
98711	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
98712	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
98713	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
98714	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
98715	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
98716	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
98717	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
98718	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
98719	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
98720	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
98721	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AL	43	
98722	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations This Read Vac	2	
98723	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Switching Operations	0	
98724	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Unknown Operations	2	
98725	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
98726	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
98727	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations	9	
98728	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98729	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98730	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98731	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps A Ø	40.0	
98732	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps B Ø	40.0	
98733	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps C Ø	40.0	
98734	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushing Condition	Good	
98735	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
98736	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
98737	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
98738	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
98739	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
98740	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98741	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98742	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98743	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98744	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations A Ø	0	
98745	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations B Ø	0	
98746	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations C Ø	0	
98747	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations Ground	0	
98748	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Follow-up Action Required?	n	
98749	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Follow-up Action Required?	n	
98750	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
98751	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
98752	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
98753	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
98754	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
98755	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
98756	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
98757	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Unknown Operations	0	
98758	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Switching Operations	0	
98759	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations This Read Vac	0	
98760	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AL	285	
98761	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AF	285	
98762	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Maintenance Operations	0	
98763	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	General Comments		
98764	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	General Comments		
98765	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Follow-up Action Required?	n	
98766	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
98767	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations Ground	0	
98768	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations C Ø	0	
98769	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations B Ø	0	
98770	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations A Ø	0	
98771	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
98772	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
98773	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
98774	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
98775	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps C Ø	82.0	
98776	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps B Ø	80.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98777	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps A Ø	89.0	
98778	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98779	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98780	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98781	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations	1	
98782	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
98783	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
98784	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
98785	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Foundation Condition	Good	
98786	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
98787	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	General Comments		
98788	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
98789	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
98790	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
98791	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
98792	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
98793	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
98794	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
98795	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
98796	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
98797	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
98798	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
98799	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
98800	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
98801	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
98802	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
98803	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
98804	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
98805	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
98806	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
98807	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
98808	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
98809	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	General Comments		
98810	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
98811	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
98812	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
98813	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
98814	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
98815	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
98816	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
98817	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
98818	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1320	
98819	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1320	
98820	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
98821	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
98822	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
98823	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
98824	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
98825	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
98826	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
98827	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
98828	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
98829	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
98830	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
98831	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
98832	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
98833	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	40.0	
98834	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
98835	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
98836	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
98837	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
98838	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
98839	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
98840	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
98841	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
98842	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
98843	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
98844	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds In Place?	y	
98845	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
98846	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
98847	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
98848	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
98849	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
98850	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
98851	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98852	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
98853	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
98854	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
98855	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
98856	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
98857	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
98858	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
98859	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
98860	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
98861	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
98862	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
98863	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
98864	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
98865	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
98866	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
98867	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
98868	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
98869	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
98870	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
98871	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
98872	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
98873	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR-1 needs nitrogen	
98874	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	General Comments		
98875	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
98876	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
98877	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
98878	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
98879	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
98880	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
98881	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98882	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
98883	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
98884	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
98885	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
98886	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
98887	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98888	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
98889	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
98890	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
98891	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
98892	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	General Comments		
98893	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98894	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
98895	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
98896	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
98897	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
98898	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.300	millivolts
98899	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	9 Month Operations	0	
98900	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98901	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
98902	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence >S' Clearance To Trees?	y	
98903	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
98904	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
98905	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
98906	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
98907	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
98908	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
98909	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
98910	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
98911	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
98912	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
98913	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
98914	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	General Comments		
98915	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
98916	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
98917	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
98918	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
98919	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Trash?	y	
98920	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
98921	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
98922	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
98923	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
98924	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
98925	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
98926	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
98927	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
98928	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
98929	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
98930	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Vegetation	None	
98931	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
98932	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
98933	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	General Comments		
98934	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
98935	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
98936	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
98937	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
98938	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
98939	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
98940	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
98941	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
98942	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
98943	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
98944	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	General Comments		
98945	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
98946	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
98947	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
98948	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
98949	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
98950	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
98951	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
98952	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AF	191	
98953	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AL	191	
98954	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations This Read Vac	0	
98955	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Switching Operations	0	
98956	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Unknown Operations	0	
98957	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
98958	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
98959	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
98960	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
98961	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
98962	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
98963	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
98964	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
98965	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
98966	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
98967	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
98968	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
98969	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
98970	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
98971	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Follow-up Action Required?	n	
98972	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
98973	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
98974	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	General Comments		
98975	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	General Comments		
98976	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
98977	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	LTC Totalizer Reading	13467.60	kw
98978	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
98979	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
98980	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Max	45	°C
98981	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Present	45	°C
98982	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
98983	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
98984	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
98985	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
98986	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
98987	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
98988	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
98989	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
98990	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Reading	.7482	
98991	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Max	60	°C
98992	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Present	45	°C
98993	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
98994	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
98995	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations	0	
98996	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
98997	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
98998	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
98999	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps A Ø	0.0	
99000	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps B Ø	12.0	
99001	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99002	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
99003	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
99004	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
99005	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
99006	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
99007	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
99008	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
99009	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
99010	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	General Comments		
99011	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
99012	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
99013	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
99014	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
99015	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
99016	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
99017	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
99018	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
99019	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
99020	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
99021	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
99022	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
99023	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
99024	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC000407	LTCControl	GL-TRANS 3	LTC Control Insp	VRR Base Voltage AF	116.0	VAC
99025	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
99026	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC000407	LTCControl	GL-TRANS 3	LTC Control Insp	General Comments		
99027	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LTC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
99028	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LTC000404	LTCControl	BY-TRANS 1	LTC Control Insp	General Comments	ok	
99029	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LTC000404	LTCControl	BY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
99030	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
99031	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
99032	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	General Comments	We don't get the ripple reading anymore, needs to be removed from insp.	
99033	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations	4	
99034	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99035	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99036	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99037	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps A Ø	0.0	
99038	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps B Ø	0.0	
99039	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps C Ø	0.0	
99040	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99041	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99042	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99043	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99044	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations A Ø	0	
99045	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations B Ø	0	
99046	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations C Ø	0	
99047	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations Ground	0	
99048	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Follow-up Action Required?	n	
99049	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Follow-up Action Required?	n	
99050	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	General Comments		
99051	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	General Comments		
99052	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Maintenance Operations	0	
99053	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99054	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
99055	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Reading	.5562	
99056	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Max	40	°C
99057	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99058	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99059	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations A Ø	0	
99060	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations B Ø	0	
99061	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations C Ø	0	
99062	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations Ground	0	
99063	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
99064	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Follow-up Action Required?	n	
99065	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	General Comments		
99066	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	General Comments		
99067	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Maintenance Operations	0	
99068	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AF	223	
99069	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AL	223	
99070	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations This Read Vac	0	
99071	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Switching Operations	0	
99072	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Present	20	°C
99073	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99074	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
99075	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
99076	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99077	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Operations Since Last Insp	512	
99078	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
99079	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
99080	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Min Tap Position	12L	
99081	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Max Tap Position	5L	
99082	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Current Tap Position	9L	
99083	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
99084	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Left Counter	27271	
99085	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Found Counter	27262	
99086	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	General Comments		
99087	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	General Comments		
99088	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
99089	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Follow-up Action Required?	n	
99090	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	1	
99091	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99092	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99093	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99094	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	272.0	
99095	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	262.0	
99096	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	268.0	
99097	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99098	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99099	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Unknown Operations	0	
99100	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99101	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99102	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
99103	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99104	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99105	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99106	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99107	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations A Ø	0	
99108	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations B Ø	0	
99109	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations C Ø	0	
99110	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations Ground	0	
99111	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Follow-up Action Required?	n	
99112	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations	3	
99113	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99114	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99115	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99116	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps A Ø	81.0	
99117	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps B Ø	77.0	
99118	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps C Ø	70.0	
99119	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99120	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99121	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Follow-up Action Required?	n	
99122	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	General Comments		
99123	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	General Comments		
99124	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Maintenance Operations	0	
99125	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
99126	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
99127	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
99128	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
99129	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
99130	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
99131	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
99132	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
99133	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
99134	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
99135	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
99136	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
99137	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Follow-up Action Required?	n	
99138	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
99139	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99140	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	General Comments		
99141	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	General Comments		
99142	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99143	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	LTC Totalizer Reading	5339.52	kw
99144	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99145	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
99146	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Max	25	°C
99147	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Present	25	°C
99148	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99149	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99150	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99151	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99152	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
99153	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99154	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
99155	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
99156	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
99157	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
99158	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
99159	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
99160	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
99161	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
99162	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
99163	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99164	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
99165	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	General Comments		
99166	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99167	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99168	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
99169	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
99170	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Max	49	°C
99171	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Present	21	°C
99172	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99173	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99174	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99175	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
99176	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
99177	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	6	
99178	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99179	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99180	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99181	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
99182	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	47	°C
99183	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	21	°C
99184	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	47	°C
99185	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	21	°C
99186	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	49	°C
99187	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	21	°C
99188	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
99189	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
99190	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
99191	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
99192	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99193	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
99194	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
99195	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99196	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	6819.84	kw
99197	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99198	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
99199	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	70	°C
99200	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	20	°C
99201	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99202	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99203	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99204	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
99205	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
99206	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BCH000575	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
99207	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
99208	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
99209	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
99210	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
99211	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
99212	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
99213	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
99214	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
99215	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
99216	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
99217	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
99218	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	General Comments		
99219	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
99220	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
99221	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
99222	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	0	
99223	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
99224	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
99225	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
99226	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99227	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations This Read Vac	0	
99228	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	200	
99229	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	200	
99230	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	0	
99231	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments		
99232	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	General Comments		
99233	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
99234	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
99235	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
99236	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
99237	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
99238	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
99239	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99240	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99241	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99242	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99243	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	0.0	
99244	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	0.0	
99245	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	0.0	
99246	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99247	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99248	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99249	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
99250	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
99251	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
99252	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
99253	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
99254	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
99255	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
99256	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
99257	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
99258	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
99259	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
99260	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
99261	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
99262	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
99263	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
99264	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
99265	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
99266	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
99267	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
99268	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
99269	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
99270	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
99271	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
99272	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
99273	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
99274	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Vegetation	None	
99275	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
99276	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
99277	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
99278	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
99279	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	General Comments		
99280	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
99281	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
99282	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
99283	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
99284	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
99285	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
99286	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
99287	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
99288	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
99289	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
99290	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
99291	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
99292	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
99293	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
99294	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
99295	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
99296	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
99297	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
99298	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
99299	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
99300	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
99301	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99302	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
99303	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	General Comments		
99304	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
99305	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
99306	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
99307	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99308	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99309	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
99310	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
99311	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
99312	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
99313	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	General Comments		
99314	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
99315	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
99316	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
99317	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Broom on Site?	y	
99318	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
99319	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
99320	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
99321	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
99322	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
99323	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
99324	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
99325	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
99326	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	CAPO00015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
99327	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
99328	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7104	
99329	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
99330	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
99331	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
99332	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
99333	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
99334	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
99335	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99336	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
99337	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
99338	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
99339	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
99340	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
99341	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
99342	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
99343	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Swept?	y	
99344	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
99345	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
99346	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	General Comments	Light switch at door by tr2 is bent. Pic sent to Stinson	
99347	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
99348	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
99349	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
99350	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
99351	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
99352	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
99353	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
99354	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
99355	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
99356	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations B Ø	0	
99357	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations A Ø	0	
99358	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99359	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99360	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99361	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99362	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Paint Condition	Good	
99363	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
99364	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
99365	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
99366	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushings Connection/Risers	Good	
99367	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushing Condition	Good	
99368	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps C Ø	5.0	
99369	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps B Ø	5.0	
99370	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps A Ø	5.0	
99371	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99372	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99373	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99374	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations	2	
99375	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
99376	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	The heater in SEC-2 SWGR would not come on, checked ACB, was on & not tripped	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99377	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
99378	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
99379	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
99380	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
99381	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99382	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99383	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99384	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
99385	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
99386	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
99387	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
99388	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
99389	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
99390	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
99391	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
99392	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
99393	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
99394	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
99395	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
99396	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
99397	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	0.0	
99398	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	0.0	
99399	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99400	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99401	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99402	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	5	
99403	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
99404	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
99405	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
99406	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Unknown Operations	0	
99407	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Switching Operations	0	
99408	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations This Read Vac	0	
99409	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AL	131	
99410	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AF	131	
99411	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Maintenance Operations	0	
99412	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Follow-up Action Required?	n	
99413	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
99414	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	General Comments		
99415	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	General Comments		
99416	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Found Counter	11065	
99417	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Left Counter	11070	
99418	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Current Tap Position	8L	
99419	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Max Tap Position	14L	
99420	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
99421	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
99422	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Operations Since Last Insp	929	
99423	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
99424	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
99425	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
99426	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
99427	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	General Comments		
99428	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Foundation Condition	Good	
99429	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Follow-up Action Required?	n	
99430	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
99431	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
99432	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
99433	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
99434	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
99435	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
99436	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Follow-up Action Required?	n	
99437	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations Ground	0	
99438	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations C Ø	0	
99439	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
99440	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 1 Resistance Set 1	0.0	Micro Ohms
99441	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 2 Resistance Set 1	0.0	Micro Ohms
99442	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 3 Resistance Set 1	0.0	Micro Ohms
99443	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
99444	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
99445	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
99446	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
99447	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
99448	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
99449	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
99450	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
99451	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99452	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
99453	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
99454	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
99455	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
99456	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
99457	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
99458	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
99459	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
99460	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
99461	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
99462	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	General Comments		
99463	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	General Comments		
99464	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
99465	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
99466	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
99467	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
99468	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
99469	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	30	
99470	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	31	
99471	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
99472	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
99473	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
99474	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
99475	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
99476	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
99477	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
99478	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations Ground	0	
99479	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
99480	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
99481	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
99482	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
99483	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
99484	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
99485	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	253	
99486	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
99487	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
99488	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
99489	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
99490	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
99491	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
99492	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
99493	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
99494	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
99495	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
99496	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
99497	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
99498	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
99499	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
99500	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
99501	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
99502	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
99503	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
99504	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
99505	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99506	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99507	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99508	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99509	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
99510	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
99511	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
99512	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
99513	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
99514	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
99515	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
99516	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
99517	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
99518	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
99519	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
99520	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
99521	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
99522	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
99523	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
99524	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments		
99525	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99526	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99527	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
99528	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
99529	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
99530	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
99531	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
99532	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99533	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99534	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99535	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
99536	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
99537	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
99538	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	LTC Totalizer Reading	10389.60	kw
99539	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99540	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
99541	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Max	55	°C
99542	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Present	45	°C
99543	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99544	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99545	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99546	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
99547	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99548	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99549	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
99550	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Reading	.5772	
99551	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Max	55	°C
99552	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Present	40	°C
99553	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99554	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
99555	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
99556	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
99557	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
99558	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
99559	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
99560	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
99561	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
99562	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
99563	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
99564	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
99565	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
99566	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
99567	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	28	°C
99568	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
99569	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	All Connections OK?	y	
99570	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	Follow-up Action Required?	n	
99571	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	General Comments		
99572	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	LTC Operation Checked?	y	
99573	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
99574	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
99575	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
99576	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	LTC000811	LTCControl	670-1	LTC Control Insp	VRR Time Delay	30	Seconds
99577	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	28	°C
99578	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
99579	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
99580	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99581	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99582	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99583	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
99584	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
99585	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Follow-up Action Required?	n	
99586	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
99587	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99588	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	General Comments		
99589	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	General Comments		
99590	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99591	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
99592	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0024	
99593	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
99594	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
99595	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
99596	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
99597	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
99598	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
99599	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
99600	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
99601	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	31	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99602	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	46	°C
99603	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
99604	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99605	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	11.52	kw
99606	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99607	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
99608	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	
99609	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	0	
99610	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations This Read Vac	0	
99611	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	216	
99612	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	216	
99613	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Maintenance Operations	0	
99614	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	General Comments		
99615	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	General Comments		
99616	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Follow-up Action Required?	n	
99617	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Follow-up Action Required?	n	
99618	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations Ground	0	
99619	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations C Ø	0	
99620	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations B Ø	0	
99621	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations A Ø	0	
99622	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99623	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99624	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
99625	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
99626	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
99627	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
99628	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
99629	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
99630	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
99631	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
99632	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
99633	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
99634	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Unknown Operations	0	
99635	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Tank Paint Condition	Good	
99636	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Switching Operations	0	
99637	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
99638	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations This Read Vac	0	
99639	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AL	211	
99640	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AF	211	
99641	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Moisture and Leak Free?	y	
99642	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Maintenance Operations	0	
99643	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Heaters (All) Functioning?	y	
99644	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Grounds in Place?	y	
99645	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	General Comments		
99646	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99647	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99648	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps C Ø	0.0	
99649	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
99650	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
99651	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	26	°C
99652	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	65	°C
99653	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
99654	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR-2 needs nitrogen	
99655	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	General Comments		
99656	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
99657	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
99658	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
99659	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
99660	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
99661	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
99662	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
99663	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
99664	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	General Comments		
99665	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
99666	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
99667	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
99668	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
99669	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
99670	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
99671	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
99672	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Foundation Condition	Good	
99673	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
99674	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
99675	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
99676	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99677	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	General Comments		
99678	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
99679	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
99680	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
99681	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
99682	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
99683	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
99684	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
99685	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
99686	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
99687	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
99688	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
99689	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
99690	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
99691	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations This Read Vac	0	
99692	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Switching Operations	0	
99693	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Tank Paint Condition	Good	
99694	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Unknown Operations	0	
99695	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
99696	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
99697	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
99698	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	General Comments		
99699	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
99700	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
99701	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
99702	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
99703	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
99704	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
99705	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
99706	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
99707	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
99708	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.6	VDC
99709	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.4	VDC
99710	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
99711	11/7/2019 13:30	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
99712	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Unknown Operations	0	
99713	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Switching Operations	0	
99714	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations This Read Vac	0	
99715	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AL	475	
99716	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AF	475	
99717	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Maintenance Operations	0	
99718	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	General Comments		
99719	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	General Comments		
99720	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Follow-up Action Required?	n	
99721	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LTC0000521	LTCControl	BY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
99722	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LTC0000521	LTCControl	BY-TRANS 2	LTC Control Insp	General Comments		
99723	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LTC0000521	LTCControl	BY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
99724	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Follow-up Action Required?	n	
99725	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations Ground	0	
99726	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations C Ø	0	
99727	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations B Ø	0	
99728	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations A Ø	0	
99729	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99730	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99731	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99732	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99733	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
99734	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
99735	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
99736	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
99737	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	242	
99738	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC0000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
99739	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC0000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
99740	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
99741	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
99742	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
99743	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
99744	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
99745	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
99746	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
99747	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
99748	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	LTC0000200	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
99749	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps B Ø	125.0	
99750	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps C Ø	120.0	
99751	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99752	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushings Connection/Risers	Good	
99753	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
99754	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
99755	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
99756	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Paint Condition	Good	
99757	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99758	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99759	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99760	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99761	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations A Ø	0	
99762	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations B Ø	0	
99763	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations C Ø	0	
99764	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations Ground	0	
99765	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Follow-up Action Required?	n	
99766	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Follow-up Action Required?	n	
99767	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Foundation Condition	Good	
99768	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	General Comments		
99769	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	General Comments		
99770	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Grounds in Place?	y	
99771	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Maintenance Operations	0	
99772	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Moisture and Leak Free?	y	
99773	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AF	211	
99774	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AL	211	
99775	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99776	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
99777	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments		
99778	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
99779	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
99780	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
99781	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
99782	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
99783	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
99784	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	General Comments		
99785	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
99786	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
99787	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
99788	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
99789	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
99790	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
99791	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
99792	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
99793	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
99794	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
99795	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
99796	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
99797	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
99798	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	47	*F
99799	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
99800	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
99801	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
99802	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
99803	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
99804	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
99805	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
99806	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
99807	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
99808	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
99809	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
99810	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
99811	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
99812	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
99813	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
99814	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99815	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99816	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99817	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps C Ø	195.0	
99818	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps B Ø	189.0	
99819	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps A Ø	153.0	
99820	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99821	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99822	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99823	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations	5	
99824	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
99825	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
99826	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99827	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
99828	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1360	
99829	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
99830	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
99831	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
99832	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
99833	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
99834	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
99835	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
99836	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Left Counter	37106	
99837	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Found Counter	37106	
99838	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
99839	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
99840	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
99841	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
99842	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	242	
99843	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
99844	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
99845	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
99846	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
99847	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
99848	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
99849	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
99850	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
99851	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
99852	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
99853	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
99854	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
99855	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
99856	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
99857	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99858	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99859	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	214	
99860	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AF	214	
99861	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Maintenance Operations	0	
99862	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	General Comments		
99863	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
99864	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99865	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99866	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
99867	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99868	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps C Ø	0.0	
99869	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps B Ø	0.0	
99870	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps A Ø	0.0	
99871	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99872	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99873	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99874	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations	0	
99875	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
99876	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	General Comments		
99877	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
99878	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
99879	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
99880	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
99881	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
99882	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
99883	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
99884	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
99885	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
99886	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
99887	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
99888	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
99889	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
99890	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
99891	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	General Comments		
99892	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Maintenance Operations	0	
99893	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AF	283	
99894	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AL	283	
99895	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations This Read Vac	2	
99896	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Switching Operations	0	
99897	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Unknown Operations	2	
99898	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
99899	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
99900	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
99901	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
99902	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
99903	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
99904	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations	14	
99905	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99906	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99907	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99908	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps A Ø	141.0	
99909	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps B Ø	126.0	
99910	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps C Ø	113.0	
99911	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
99912	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
99913	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
99914	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
99915	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations A Ø	0	
99916	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations B Ø	0	
99917	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
99918	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
99919	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
99920	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
99921	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	General Comments		
99922	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
99923	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
99924	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Operations Counter	196	
99925	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
99926	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
99927	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations C Ø	0	
99928	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations Ground	0	
99929	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
99930	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Follow-up Action Required?	n	
99931	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	General Comments		
99932	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
99933	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
99934	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
99935	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
99936	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
99937	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
99938	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
99939	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
99940	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
99941	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	0	
99942	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations This Read Vac	0	
99943	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
99944	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
99945	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
99946	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
99947	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
99948	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	
99949	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Follow-up Action Required?	n	
99950	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
99951	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	General Comments		
99952	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments		
99953	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99954	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99955	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99956	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	5	
99957	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
99958	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
99959	11/7/2019 11:38	Distribution	Kuhlman Quarterly Inspection	BCH000507	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
99960	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
99961	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
99962	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
99963	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
99964	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
99965	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
99966	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
99967	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations	2	
99968	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
99969	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
99970	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
99971	11/6/2019 7:57	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps A Ø	140.0	
99972	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
99973	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
99974	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
99975	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
99976	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
99977	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	LTC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
99978	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	0	
99979	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	186	
99980	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	186	
99981	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations This Read Vac	0	
99982	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	0	
99983	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
99984	11/7/2019 10:56	Distribution	Midway Quarterly Inspection	BB0328	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
99985	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
99986	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
99987	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
99988	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
99989	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	All Connections OK?	y	
99990	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	Follow-up Action Required?	n	
99991	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	General Comments		
99992	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	LTC Operation Checked?	y	
99993	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
99994	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
99995	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	General Comments		
99996	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
99997	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	LTC000722	LTCControl	545-1	LTC Control Insp	VRR Time Delay	30	Seconds
99998	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
99999	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
100000	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
100001	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
100002	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
100003	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	General Comments		
100004	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
100005	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Follow-up Action Required?	n	
100006	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Follow-up Action Required?	n	
100007	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	
100008	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
100009	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
100010	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
100011	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100012	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100013	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100014	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100015	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	0.0	
100016	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	0.0	
100017	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	0.0	
100018	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	5	
100019	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100020	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100021	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100022	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A Ø	0.0	
100023	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B Ø	0.0	
100024	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C Ø	0.0	
100025	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100026	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100027	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
100028	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
100029	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
100030	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
100031	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
100032	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations This Read Vac	0	
100033	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	186	
100034	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	186	
100035	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
100036	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments		
100037	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	General Comments		
100038	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
100039	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Follow-up Action Required?	n	
100040	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	
100041	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
100042	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
100043	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	0	
100044	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100045	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100046	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100047	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100048	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
100049	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
100050	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
100051	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100052	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100053	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100054	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	5	
100055	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Winding Temp Max	40	°C
100056	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
100057	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100058	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
100059	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
100060	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	328	
100061	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Follow-up Action Required?	n	
100062	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
100063	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	General Comments		
100064	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments		
100065	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	0	
100066	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	189	
100067	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	329	
100068	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	189	
100069	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations This Read Vac	0	
100070	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	0	
100071	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
100072	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
100073	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
100074	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
100075	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
100076	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
100077	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
100078	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
100079	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
100080	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
100081	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100082	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100083	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100084	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100085	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100086	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushing Condition	Good	
100087	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps C Ø	212.0	
100088	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps B Ø	209.0	
100089	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps A Ø	200.0	
100090	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Switching Operations	0	
100091	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Unknown Operations	0	
100092	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
100093	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
100094	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
100095	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
100096	11/7/2019 14:25	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
100097	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	5	
100098	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100099	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100100	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100101	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
100102	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100103	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100104	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100105	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
100106	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	90.0	
100107	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
100108	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
100109	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
100110	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100111	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100112	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100113	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100114	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100115	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
100116	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
100117	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
100118	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
100119	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
100120	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
100121	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
100122	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
100123	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
100124	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
100125	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100126	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
100127	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
100128	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
100129	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
100130	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100131	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100132	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	
100133	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
100134	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
100135	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
100136	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
100137	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
100138	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
100139	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
100140	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
100141	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
100142	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
100143	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	35	°C
100144	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	0	
100145	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100146	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100147	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100148	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100149	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
100150	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
100151	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
100152	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
100153	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
100154	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
100155	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
100156	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panels Dusted?	y	
100157	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
100158	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
100159	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	General Comments		
100160	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
100161	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
100162	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Swept?	y	
100163	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
100164	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
100165	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Evidence of Insects	None	
100166	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
100167	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	General Comments		
100168	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
100169	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
100170	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
100171	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	General Comments		
100172	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
100173	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Maintenance Operations	0	
100174	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AF	662	
100175	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AL	662	
100176	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
100177	11/7/2019 12:39	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
100178	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
100179	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
100180	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
100181	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
100182	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
100183	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
100184	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
100185	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
100186	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps C Ø	114.0	
100187	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps B Ø	96.0	
100188	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations This Read Vac	1	
100189	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Switching Operations	1	
100190	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Unknown Operations	0	
100191	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps A Ø	82.0	
100192	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	1	
100193	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100194	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100195	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100196	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	262.0	
100197	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	246.0	
100198	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	247.0	
100199	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100200	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100201	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100202	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100203	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
100204	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
100205	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
100206	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
100207	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
100208	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
100209	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	General Comments		
100210	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments		
100211	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
100212	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	198	
100213	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	198	
100214	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations This Read Vac	0	
100215	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	0	
100216	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100217	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100218	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100219	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations	2	
100220	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Unknown Operations	1	
100221	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
100222	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
100223	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
100224	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
100225	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
100226	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
100227	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
100228	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
100229	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
100230	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
100231	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Switching Operations	0	
100232	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations This Read Vac	1	
100233	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AL	197	
100234	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AF	197	
100235	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Maintenance Operations	0	
100236	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	General Comments		
100237	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	General Comments		
100238	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Follow-up Action Required?	n	
100239	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
100240	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
100241	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
100242	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
100243	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
100244	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
100245	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
100246	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
100247	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations Ground	0	
100248	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations C Ø	0	
100249	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations B Ø	0	
100250	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations A Ø	0	
100251	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
100252	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
100253	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
100254	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100255	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps C Ø	171.0	
100256	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps B Ø	173.0	
100257	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps A Ø	171.0	
100258	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100259	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100260	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
100261	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
100262	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
100263	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
100264	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
100265	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100266	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations	2	
100267	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
100268	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
100269	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
100270	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
100271	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Leaks	None	
100272	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
100273	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Operations Counter	189	
100274	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
100275	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
100276	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100277	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
100278	11/7/2019 10:13	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
100279	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
100280	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100281	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Maintenance Operations	0	
100282	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100283	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100284	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100285	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps A Ø	480.0	
100286	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps B Ø	480.0	
100287	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps C Ø	480.0	
100288	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	General Comments		
100289	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	General Comments		
100290	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Follow-up Action Required?	n	
100291	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Follow-up Action Required?	n	
100292	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations Ground	0	
100293	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations C Ø	0	
100294	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations B Ø	0	
100295	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations A Ø	0	
100296	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100297	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100298	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100299	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100300	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps C Ø	258.0	
100301	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps B Ø	257.0	
100302	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps A Ø	265.0	
100303	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100304	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100305	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100306	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations	1	
100307	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushing Condition	Good	
100308	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100309	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100310	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100311	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100312	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100313	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100314	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
100315	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
100316	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
100317	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
100318	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100319	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100320	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100321	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations A Ø	0	
100322	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations B Ø	0	
100323	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations C Ø	0	
100324	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations Ground	0	
100325	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Follow-up Action Required?	n	
100326	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Follow-up Action Required?	n	
100327	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Foundation Condition	Good	
100328	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	General Comments		
100329	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	General Comments		
100330	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Grounds in Place?	y	
100331	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100332	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	General Comments	Yard light by TR 2 is not working need small bucket truck	
100333	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Maintenance Operations	0	
100334	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
100335	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AF	18	
100336	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AL	18	
100337	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100338	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps A Ø	0.0	
100339	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps B Ø	0.0	
100340	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps C Ø	0.0	
100341	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations This Read Vac	0	
100342	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	297	
100343	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	297	
100344	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
100345	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
100346	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100347	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
100348	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
100349	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
100350	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Unknown Operations	0	
100351	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100352	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations This Read Vac	0	
100353	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AL	168	
100354	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AF	168	
100355	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
100356	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
100357	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
100358	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
100359	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
100360	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
100361	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
100362	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
100363	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
100364	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
100365	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
100366	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
100367	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
100368	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
100369	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
100370	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
100371	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
100372	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	General Comments		
100373	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
100374	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
100375	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
100376	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
100377	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
100378	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
100379	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
100380	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
100381	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
100382	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
100383	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
100384	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
100385	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
100386	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
100387	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
100388	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	
100389	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
100390	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
100391	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
100392	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	General Comments		
100393	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
100394	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
100395	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
100396	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
100397	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
100398	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Vegetation	None	
100399	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
100400	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
100401	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
100402	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Vegetation	None	
100403	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
100404	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
100405	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
100406	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
100407	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
100408	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
100409	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Foundation Condition	Good	
100410	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Maintenance Operations	0	
100411	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AF	138	
100412	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AL	138	
100413	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
100414	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
100415	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
100416	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
100417	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
100418	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
100419	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	General Comments		
100420	11/7/2019 9:45	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
100421	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Unknown Operations	0	
100422	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Tank Paint Condition	Good	
100423	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Switching Operations	0	
100424	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations This Read Vac	0	
100425	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AL	195	
100426	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AF	195	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100427	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Moisture and Leak Free?	y	
100428	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Maintenance Operations	0	
100429	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Grounds in Place?	y	
100430	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	General Comments		
100431	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	General Comments		
100432	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Foundation Condition	Good	
100433	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Follow-up Action Required?	n	
100434	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Follow-up Action Required?	n	
100435	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
100436	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	General Comments	MOD Box 138kv heater is not working	
100437	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
100438	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
100439	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
100440	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations Ground	0	
100441	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations C Ø	0	
100442	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations B Ø	0	
100443	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations A Ø	0	
100444	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100445	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100446	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100447	11/7/2019 11:25	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100448	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations This Read Vac	0	
100449	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
100450	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
100451	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
100452	11/7/2019 11:22	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
100453	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
100454	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
100455	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
100456	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A Ø	0	
100457	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B Ø	0	
100458	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C Ø	0	
100459	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
100460	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100461	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100462	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100463	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100464	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100465	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100466	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100467	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100468	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100469	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
100470	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
100471	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
100472	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
100473	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
100474	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
100475	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100476	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100477	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100478	11/7/2019 12:04	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	10	
100479	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations	22	
100480	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100481	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100482	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100483	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps A Ø	98.0	
100484	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps B Ø	99.0	
100485	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps C Ø	100.0	
100486	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100487	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100488	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100489	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100490	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations A Ø	0	
100491	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations B Ø	0	
100492	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations C Ø	0	
100493	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations Ground	0	
100494	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
100495	11/7/2019 9:38	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Follow-up Action Required?	n	
100496	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Switching Operations	0	
100497	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Tank Paint Condition	Good	
100498	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Unknown Operations	0	
100499	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100500	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100501	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
100502	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations A Ø	0	
100503	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations B Ø	0	
100504	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations C Ø	0	
100505	11/7/2019 13:10	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations This Read Vac	0	
100506	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations Ground	0	
100507	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Follow-up Action Required?	n	
100508	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Follow-up Action Required?	n	
100509	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	General Comments		
100510	11/7/2019 13:37	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	General Comments		
100511	11/7/2019 12:20	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
100512	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
100513	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
100514	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
100515	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
100516	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
100517	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
100518	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
100519	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
100520	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.4	VDC
100521	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
100522	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
100523	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?		
100524	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	*F
100525	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
100526	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100527	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100528	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps A Ø	240.0	
100529	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100530	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Switching Operations	0	
100531	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps B Ø	240.0	
100532	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps C Ø	240.0	
100533	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushing Condition	Good	
100534	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100535	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100536	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Months Operations	6	
100537	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100538	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100539	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100540	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations	9	
100541	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations This Read AM	0	
100542	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps C Ø	113.0	
100543	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps B Ø	140.0	
100544	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
100545	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100546	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps A Ø	250.0	
100547	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps B Ø	320.0	
100548	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AL	423	
100549	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AF	423	
100550	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Maintenance Operations	0	
100551	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	General Comments		
100552	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	General Comments		
100553	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100554	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Follow-up Action Required?	n	
100555	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Follow-up Action Required?	n	
100556	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations C Ø	0	
100557	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations B Ø	0	
100558	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations A Ø	0	
100559	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100560	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps C Ø	360.0	
100561	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
100562	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100563	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
100564	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100565	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
100566	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100567	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations A Ø	0	
100568	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations B Ø	0	
100569	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations C Ø	0	
100570	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations Ground	0	
100571	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
100572	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
100573	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	General Comments		
100574	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps A Ø	112.0	
100575	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
100576	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
100577	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100578	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
100579	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps C Ø	150.0	
100580	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps A Ø	240.0	
100581	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps B Ø	200.0	
100582	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100583	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
100584	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Follow-up Action Required?	n	
100585	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
100586	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
100587	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
100588	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
100589	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1466	
100590	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
100591	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
100592	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
100593	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
100594	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
100595	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
100596	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
100597	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
100598	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
100599	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
100600	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
100601	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
100602	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
100603	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
100604	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
100605	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
100606	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Months Operations	0	
100607	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100608	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100609	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100610	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps A Ø	0.0	
100611	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Left Counter	7863	
100612	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Found Counter	7863	
100613	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
100614	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	General Comments		
100615	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
100616	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
100617	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
100618	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps B Ø	0.0	
100619	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps C Ø	0.0	
100620	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
100621	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100622	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
100623	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
100624	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
100625	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
100626	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
100627	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
100628	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	General Comments		
100629	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	General Comments		
100630	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Found Counter	7834	
100631	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Left Counter	7841	
100632	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
100633	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Current Tap Position	8L	
100634	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
100635	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Min Tap Position	11L	
100636	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Operations Since Last Insp	791	
100637	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
100638	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
100639	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
100640	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
100641	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
100642	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	General Comments		
100643	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
100644	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
100645	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Swept?	y	
100646	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
100647	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
100648	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
100649	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
100650	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
100651	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
100652	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations	5	
100653	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100654	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps C Ø	180.0	
100655	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushing Condition	Good	
100656	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100657	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100658	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100659	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100660	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100661	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100662	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100663	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100664	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
100665	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
100666	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100667	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations A Ø	0	
100668	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations B Ø	0	
100669	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations C Ø	0	
100670	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations Ground	0	
100671	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Follow-up Action Required?	n	
100672	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Follow-up Action Required?	n	
100673	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Foundation Condition	Good	
100674	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	General Comments		
100675	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	General Comments		
100676	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Grounds in Place?	y	
100677	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100678	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Maintenance Operations	0	
100679	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Moisture and Leak Free?	y	
100680	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AF	120	
100681	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AL	120	
100682	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations This Read Vac	0	
100683	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Switching Operations	0	
100684	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Tank Paint Condition	Good	
100685	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Unknown Operations	0	
100686	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
100687	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	All Connections OK?	y	
100688	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	Follow-up Action Required?	n	
100689	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	General Comments		
100690	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	LTC Operation Checked?	y	
100691	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
100692	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
100693	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
100694	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	LTC0000784	LTCControl	699-1	LTC Control Insp	VRR Time Delay	30	Seconds
100695	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
100696	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
100697	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
100698	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
100699	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
100700	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
100701	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
100702	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
100703	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
100704	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Months Operations	1	
100705	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100706	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100707	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	General Comments		
100708	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
100709	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Unknown Operations	0	
100710	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Switching Operations	0	
100711	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations This Read AM	1	
100712	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AL	272	
100713	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AF	272	
100714	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Maintenance Operations	0	
100715	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	General Comments	B Phase IOC	
100716	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	General Comments		
100717	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Follow-up Action Required?	n	
100718	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Follow-up Action Required?	n	
100719	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations Ground	0	
100720	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations C Ø	0	
100721	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations B Ø	1	
100722	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations A Ø	0	
100723	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100724	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
100725	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100726	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100727	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps C Ø	100.0	
100728	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps B Ø	180.0	
100729	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
100730	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
100731	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
100732	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
100733	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
100734	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
100735	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
100736	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
100737	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
100738	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
100739	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
100740	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
100741	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
100742	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BAT000095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
100743	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
100744	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
100745	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
100746	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
100747	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
100748	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
100749	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
100750	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
100751	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
100752	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
100753	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
100754	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
100755	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
100756	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
100757	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
100758	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
100759	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
100760	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
100761	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
100762	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
100763	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
100764	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
100765	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
100766	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
100767	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
100768	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
100769	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
100770	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Unknown Operations	0	
100771	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Switching Operations	0	
100772	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations This Read AM	0	
100773	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AL	217	
100774	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AF	217	
100775	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Maintenance Operations	0	
100776	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
100777	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	General Comments		
100778	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	General Comments		
100779	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Follow-up Action Required?	n	
100780	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
100781	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations Ground	0	
100782	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations C Ø	0	
100783	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations B Ø	0	
100784	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations A Ø	0	
100785	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100786	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
100787	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100788	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
100789	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps C Ø	200.0	
100790	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps B Ø	160.0	
100791	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps A Ø	190.0	
100792	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100793	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100794	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100795	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	9 Months Operations	0	
100796	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
100797	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
100798	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations	18	
100799	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100800	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100801	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100802	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps A Ø	180.0	
100803	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps B Ø	180.0	
100804	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Maintenance Operations	0	
100805	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	General Comments		
100806	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	General Comments		
100807	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Follow-up Action Required?	n	
100808	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Unknown Operations	0	
100809	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Tank Paint Condition	Good	
100810	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Switching Operations	1	
100811	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations This Read Vac	1	
100812	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
100813	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
100814	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
100815	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1434	
100816	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
100817	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
100818	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
100819	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
100820	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AL	156	
100821	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AF	156	
100822	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AL	99933	
100823	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations This Read AM	0	
100824	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Switching Operations	0	
100825	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Unknown Operations	0	
100826	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
100827	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Maintenance Operations	0	
100828	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100829	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Grounds in Place?	y	
100830	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	General Comments		
100831	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	General Comments		
100832	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Foundation Condition	Good	
100833	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Follow-up Action Required?	n	
100834	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Follow-up Action Required?	n	
100835	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations Ground	0	
100836	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations C Ø	0	
100837	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations B Ø	0	
100838	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations A Ø	0	
100839	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100840	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
100841	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations Ground	0	
100842	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations C Ø	0	
100843	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations B Ø	0	
100844	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations A Ø	0	
100845	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
100846	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100847	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100848	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100849	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Unknown Operations	0	
100850	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Switching Operations	0	
100851	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations This Read Vac	0	
100852	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AL	693	
100853	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AF	693	
100854	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Maintenance Operations	0	
100855	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	General Comments		
100856	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Months Operations	1	
100857	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100858	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100859	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100860	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100861	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Unknown Operations	0	
100862	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	General Comments		
100863	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Follow-up Action Required?	n	
100864	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
100865	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100866	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
100867	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
100868	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations Ground	0	
100869	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations C Ø	0	
100870	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations B Ø	0	
100871	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations A Ø	0	
100872	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100873	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100874	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100875	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100876	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100877	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Broom on Site?	y	
100878	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
100879	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps A Ø	235.0	
100880	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100881	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
100882	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
100883	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Months Operations	4	
100884	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.4	VDC
100885	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.4	VDC
100886	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
100887	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
100888	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
100889	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	General Comments		
100890	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
100891	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps A Ø	180.0	
100892	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps B Ø	210.0	
100893	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps C Ø	210.0	
100894	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
100895	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
100896	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
100897	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
100898	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	General Comments		
100899	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
100900	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Found Counter	102743	
100901	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Left Counter	102743	
100902	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
100903	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
100904	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000219	LTCControl	CW-TRANS 1	LTC Control Insp	General Comments		
100905	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
100906	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
100907	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
100908	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
100909	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
100910	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations A Ø	0	
100911	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations B Ø	0	
100912	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations C Ø	0	
100913	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
100914	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
100915	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
100916	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
100917	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
100918	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
100919	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations Ground	0	
100920	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
100921	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Follow-up Action Required?	n	
100922	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	General Comments		
100923	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	General Comments		
100924	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
100925	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Maintenance Operations	0	
100926	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AF	99933	
100927	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
100928	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
100929	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
100930	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
100931	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
100932	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
100933	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
100934	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	General Comments		
100935	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
100936	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
100937	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
100938	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
100939	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
100940	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
100941	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
100942	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
100943	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
100944	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
100945	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
100946	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
100947	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
100948	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
100949	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Unknown Operations	0	
100950	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Switching Operations	0	
100951	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
100952	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AL	2007	
100953	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AF	2007	
100954	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100955	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
100956	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
100957	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations	5	
100958	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Unknown Operations	0	
100959	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Tank Paint Condition	Good	
100960	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Switching Operations	0	
100961	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations This Read Vac	0	
100962	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AL	196	
100963	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AF	196	
100964	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Moisture and Leak Free?	y	
100965	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Maintenance Operations	0	
100966	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Heaters (All) Functioning?	y	
100967	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Grounds in Place?	y	
100968	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	General Comments		
100969	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	General Comments		
100970	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Foundation Condition	Good	
100971	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Follow-up Action Required?	n	
100972	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Follow-up Action Required?	n	
100973	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations Ground	0	
100974	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations C Ø	0	
100975	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations B Ø	0	
100976	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations A Ø	0	
100977	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
100978	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
100979	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
100980	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100981	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
100982	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
100983	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
100984	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
100985	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
100986	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushing Condition	Good	
100987	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps C Ø	82.0	
100988	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
100989	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
100990	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	General Comments		
100991	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps B Ø	97.0	
100992	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps A Ø	87.0	
100993	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
100994	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	*C
100995	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
100996	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	General Comments		
100997	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
100998	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
100999	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
101000	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Unknown Operations	0	
101001	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Switching Operations	0	
101002	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations This Read Vac	0	
101003	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AL	621	
101004	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AF	621	
101005	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Maintenance Operations	0	
101006	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	General Comments		
101007	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	General Comments		
101008	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Follow-up Action Required?	n	
101009	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Follow-up Action Required?	n	
101010	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations Ground	0	
101011	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations C Ø	0	
101012	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations B Ø	0	
101013	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations A Ø	0	
101014	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101015	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101016	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101017	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101018	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps C Ø	85.0	
101019	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps B Ø	93.0	
101020	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps A Ø	108.0	
101021	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
101022	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101023	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
101024	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	9 Month Operations	18	
101025	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
101026	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101027	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
101028	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
101029	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
101030	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
101031	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
101032	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations	4	
101033	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
101034	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101035	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AF	411	
101036	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AL	411	
101037	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations This Read Vac	0	
101038	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Switching Operations	0	
101039	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Unknown Operations	0	
101040	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
101041	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	General Comments		
101042	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
101043	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
101044	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
101045	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
101046	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
101047	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
101048	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
101049	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
101050	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
101051	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
101052	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
101053	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
101054	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
101055	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Unknown Operations	0	
101056	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Switching Operations	0	
101057	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
101058	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AL	112	
101059	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AF	112	
101060	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
101061	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	General Comments		
101062	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	General Comments		
101063	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
101064	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
101065	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
101066	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
101067	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
101068	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
101069	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
101070	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
101071	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
101072	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
101073	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations	0	
101074	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
101075	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101076	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps A Ø	66.0	
101077	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps B Ø	75.0	
101078	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Unknown Operations	0	
101079	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Switching Operations	0	
101080	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations This Read AM	0	
101081	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AL	345	
101082	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AF	345	
101083	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Maintenance Operations	0	
101084	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	General Comments		
101085	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	General Comments		
101086	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Follow-up Action Required?	n	
101087	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
101088	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations Ground	0	
101089	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations C Ø	0	
101090	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations B Ø	0	
101091	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations A Ø	0	
101092	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
101093	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
101094	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
101095	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
101096	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps C Ø	550.0	
101097	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps B Ø	560.0	
101098	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps A Ø	565.0	
101099	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
101100	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
101101	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101102	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Months Operations	10	
101103	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps C Ø	88.0	
101104	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101105	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101106	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101107	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101108	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations A Ø	0	
101109	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations B Ø	0	
101110	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations C Ø	0	
101111	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations Ground	0	
101112	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
101113	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Follow-up Action Required?	n	
101114	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	General Comments		
101115	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	General Comments		
101116	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Maintenance Operations	0	
101117	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
101118	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
101119	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
101120	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
101121	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
101122	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
101123	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Present	30	°C
101124	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Max	95	°C
101125	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
101126	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
101127	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	LTC Totalizer Reading	5788.80	kw
101128	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
101129	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	General Comments		
101130	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	General Comments		
101131	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
101132	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
101133	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Follow-up Action Required?	n	
101134	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101135	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
101136	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
101137	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101138	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
101139	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
101140	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
101141	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
101142	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101143	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101144	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
101145	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
101146	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
101147	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
101148	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
101149	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
101150	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
101151	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
101152	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
101153	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
101154	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	General Comments		
101155	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
101156	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
101157	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
101158	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
101159	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
101160	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
101161	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
101162	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
101163	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
101164	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
101165	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
101166	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
101167	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
101168	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
101169	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
101170	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
101171	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
101172	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101173	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101174	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
101175	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	General Comments		
101176	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101177	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
101178	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
101179	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Trash?	y	
101180	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
101181	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
101182	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
101183	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
101184	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
101185	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
101186	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	General Comments		
101187	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
101188	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
101189	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Vegetation	None	
101190	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
101191	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
101192	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
101193	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
101194	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
101195	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
101196	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
101197	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Foundation Condition	Good	
101198	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	General Comments		
101199	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
101200	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
101201	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
101202	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
101203	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
101204	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
101205	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
101206	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
101207	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
101208	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	General Comments		
101209	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
101210	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
101211	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
101212	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
101213	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
101214	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
101215	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
101216	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
101217	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
101218	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
101219	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
101220	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
101221	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
101222	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	*C
101223	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	*C
101224	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
101225	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
101226	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
101227	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
101228	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
101229	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
101230	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
101231	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
101232	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
101233	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	85	*C
101234	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	55	*C
101235	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	*C
101236	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	*C
101237	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	*C
101238	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
101239	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
101240	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
101241	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
101242	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
101243	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Reading	.4020	
101244	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
101245	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
101246	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
101247	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
101248	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
101249	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
101250	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
101251	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101252	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
101253	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
101254	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
101255	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
101256	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
101257	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
101258	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
101259	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Max	100	°C
101260	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Present	40	°C
101261	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
101262	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
101263	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
101264	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
101265	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101266	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
101267	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
101268	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101269	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
101270	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
101271	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
101272	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
101273	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
101274	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	General Comments		
101275	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
101276	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
101277	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
101278	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
101279	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
101280	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
101281	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101282	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
101283	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
101284	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101285	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101286	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101287	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101288	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101289	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
101290	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
101291	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
101292	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
101293	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Months Operations	2	
101294	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
101295	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
101296	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
101297	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
101298	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
101299	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
101300	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
101301	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
101302	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
101303	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
101304	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
101305	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
101306	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
101307	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
101308	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
101309	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
101310	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
101311	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
101312	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
101313	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
101314	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
101315	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Max	69	°C
101316	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Unknown Operations	0	
101317	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Switching Operations	0	
101318	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations This Read Vac	0	
101319	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AL	246	
101320	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AF	246	
101321	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
101322	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
101323	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
101324	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps A Ø	400.0	
101325	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps B Ø	350.0	
101326	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps C Ø	420.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101327	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
101328	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	244	
101329	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	244	
101330	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
101331	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
101332	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	General Comments		
101333	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
101334	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000543	LTCControl	CW-TRANS 2	LTC Control Insp	General Comments		
101335	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Unknown Operations	0	
101336	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Switching Operations	0	
101337	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations This Read AM	0	
101338	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AL	377	
101339	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AF	377	
101340	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Maintenance Operations	0	
101341	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
101342	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	General Comments		
101343	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	General Comments		
101344	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Follow-up Action Required?	n	
101345	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
101346	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations Ground	0	
101347	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LTC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
101348	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
101349	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
101350	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	358	
101351	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
101352	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
101353	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
101354	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
101355	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	General Comments		
101356	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
101357	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
101358	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Found Counter	488698	
101359	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Left Counter	488698	
101360	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
101361	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
101362	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
101363	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
101364	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
101365	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
101366	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
101367	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
101368	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
101369	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101370	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101371	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
101372	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
101373	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
101374	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
101375	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
101376	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
101377	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
101378	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
101379	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
101380	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
101381	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
101382	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
101383	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	General Comments		
101384	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
101385	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
101386	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
101387	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
101388	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
101389	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
101390	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
101391	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101392	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
101393	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Vegetation	None	
101394	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
101395	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
101396	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	78	°C
101397	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	31	°C
101398	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	79	°C
101399	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
101400	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
101401	11/6/2019 22:47	Distribution	Gaubert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101402	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	General Comments		
101403	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
101404	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
101405	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
101406	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
101407	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
101408	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
101409	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	*C
101410	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	81	*C
101411	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
101412	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
101413	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
101414	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
101415	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
101416	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
101417	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Maintenance Operations	0	
101418	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
101419	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
101420	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
101421	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
101422	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	*C
101423	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
101424	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
101425	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	General Comments		
101426	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
101427	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
101428	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Vegetation	None	
101429	11/6/2019 22:47	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
101430	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	General Comments		
101431	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	General Comments		
101432	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Follow-up Action Required?	n	
101433	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
101434	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations Ground	0	
101435	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations C Ø	0	
101436	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations B Ø	0	
101437	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations A Ø	0	
101438	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101439	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101440	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101441	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101442	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps C Ø	2.0	
101443	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps B Ø	1.0	
101444	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps A Ø	2.0	
101445	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
101446	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
101447	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.2	VDC
101448	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.2	VDC
101449	11/6/2019 11:58	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
101450	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	31	*C
101451	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
101452	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
101453	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
101454	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
101455	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	General Comments		
101456	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
101457	11/6/2019 13:14	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	69	*C
101458	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101459	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
101460	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
101461	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
101462	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
101463	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
101464	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
101465	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
101466	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations A Ø	0	
101467	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations B Ø	0	
101468	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations C Ø	0	
101469	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations Ground	0	
101470	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
101471	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Follow-up Action Required?	n	
101472	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
101473	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
101474	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	152.0	
101475	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Unknown Operations	0	
101476	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101477	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AL	372	
101478	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations This Read AM	0	
101479	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	General Comments		
101480	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	General Comments		
101481	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
101482	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Maintenance Operations	0	
101483	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AF	372	
101484	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
101485	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
101486	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	5.78	%
101487	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	866.0	
101488	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	875.0	
101489	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101490	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
101491	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
101492	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
101493	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
101494	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	General Comments		
101495	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
101496	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
101497	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
101498	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	27	
101499	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3433	
101500	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3433	
101501	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
101502	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
101503	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
101504	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
101505	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
101506	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
101507	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
101508	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
101509	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
101510	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
101511	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
101512	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
101513	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Operations Since Last Insp	1877	
101514	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
101515	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Min Tap Position	4L	
101516	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
101517	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Current Tap Position	4L	
101518	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
101519	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Left Counter	7666	
101520	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps C Ø	859.0	
101521	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101522	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
101523	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
101524	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
101525	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
101526	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101527	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Unknown Operations	0	
101528	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Tank Paint Condition	Good	
101529	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Switching Operations	0	
101530	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
101531	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations This Read Vac	0	
101532	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101533	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
101534	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
101535	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Found Counter	7652	
101536	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
101537	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
101538	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101539	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
101540	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
101541	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps C Ø	60.0	
101542	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps B Ø	70.0	
101543	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps A Ø	90.0	
101544	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
101545	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
101546	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
101547	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Months Operations	0	
101548	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	152.0	
101549	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	152.0	
101550	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
101551	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	5	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101552	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	19.93	%
101553	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
101554	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
101555	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.39	
101556	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101557	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	9.39	
101558	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101559	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
101560	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
101561	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	40.0	
101562	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	27.0	
101563	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	48.0	
101564	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101565	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
101566	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
101567	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101568	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
101569	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	3	
101570	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
101571	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
101572	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
101573	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
101574	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
101575	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
101576	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments	B Phase IOC	
101577	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
101578	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	216	
101579	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	216	
101580	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	3	
101581	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
101582	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
101583	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
101584	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
101585	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
101586	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
101587	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
101588	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
101589	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
101590	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
101591	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
101592	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0134	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
101593	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	1	
101594	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
101595	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.0770	
101596	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
101597	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
101598	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
101599	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
101600	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
101601	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	343	
101602	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	343	
101603	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
101604	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
101605	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
101606	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
101607	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
101608	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
101609	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
101610	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
101611	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
101612	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
101613	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
101614	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	319	
101615	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	319	
101616	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
101617	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
101618	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
101619	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
101620	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
101621	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
101622	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
101623	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
101624	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
101625	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
101626	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101627	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
101628	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101629	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101630	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101631	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
101632	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
101633	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
101634	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
101635	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
101636	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
101637	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
101638	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	0	
101639	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
101640	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	0	
101641	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	694	
101642	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	694	
101643	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
101644	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments		
101645	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
101646	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
101647	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
101648	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101649	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101650	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
101651	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
101652	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
101653	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
101654	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
101655	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	201	
101656	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	201	
101657	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
101658	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments	N/O	
101659	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
101660	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
101661	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
101662	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
101663	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
101664	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
101665	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101666	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
101667	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
101668	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101669	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
101670	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
101671	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
101672	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
101673	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101674	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101675	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101676	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
101677	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
101678	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
101679	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	30.8	%
101680	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	30.8	%
101681	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	30.8	%
101682	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	6	
101683	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
101684	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
101685	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
101686	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3446.40	kw
101687	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
101688	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
101689	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	63	°C
101690	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
101691	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
101692	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
101693	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
101694	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
101695	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
101696	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
101697	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
101698	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	69.36	%
101699	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	74.14	%
101700	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
101701	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101702	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	General Comments		
101703	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
101704	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	74.94	%
101705	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	212.0	
101706	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	197.0	
101707	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	206.0	
101708	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101709	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101710	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101711	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
101712	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
101713	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
101714	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
101715	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101716	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	96.0	
101717	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	96.0	
101718	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	96.0	
101719	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
101720	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
101721	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
101722	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	575	
101723	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	575	
101724	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
101725	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
101726	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Unknown Operations	0	
101727	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
101728	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
101729	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1315	
101730	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1315	
101731	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
101732	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
101733	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
101734	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
101735	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	General Comments		
101736	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
101737	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
101738	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
101739	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
101740	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
101741	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
101742	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
101743	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	51-A-T...51-C-T	
101744	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
101745	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
101746	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
101747	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
101748	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
101749	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
101750	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
101751	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	0	
101752	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	0	
101753	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
101754	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
101755	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
101756	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
101757	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	17.0	
101758	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	13.0	
101759	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	19.0	
101760	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
101761	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	4.82	%
101762	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
101763	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	9	
101764	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
101765	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
101766	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
101767	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
101768	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101769	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
101770	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0169	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
101771	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
101772	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
101773	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101774	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101775	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101776	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	68.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
101777	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	72.0	
101778	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	73.0	
101779	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
101780	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
101781	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
101782	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	2	
101783	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
101784	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
101785	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
101786	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
101787	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
101788	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
101789	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
101790	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
101791	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
101792	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
101793	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
101794	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1006	
101795	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0127	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1006	
101796	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
101797	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
101798	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	292	
101799	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	291	
101800	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0125	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
101801	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	13	
101802	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
101803	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
101804	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
101805	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	814	
101806	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	814	
101807	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
101808	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
101809	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
101810	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	n	
101811	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
101812	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	General Comments		
101813	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments		
101814	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Found Counter	271653	
101815	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Left Counter	271662	
101816	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
101817	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
101818	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
101819	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
101820	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
101821	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101822	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
101823	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
101824	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
101825	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
101826	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
101827	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
101828	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
101829	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
101830	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
101831	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Unknown Operations	0	
101832	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
101833	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	38	°C
101834	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	63	°C
101835	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
101836	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
101837	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101838	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
101839	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
101840	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101841	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
101842	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
101843	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
101844	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
101845	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101846	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101847	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
101848	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
101849	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
101850	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
101851	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	480.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101852	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	480.0	
101853	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
101854	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	300.0	
101855	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	300.0	
101856	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
101857	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7224	
101858	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
101859	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
101860	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
101861	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	1	
101862	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
101863	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
101864	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
101865	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101866	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101867	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	90.0	
101868	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	104.0	
101869	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	80.0	
101870	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
101871	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
101872	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	17.54	%
101873	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	6	
101874	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
101875	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
101876	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
101877	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
101878	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	342.0	
101879	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	351.0	
101880	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
101881	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
101882	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
101883	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
101884	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
101885	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	314.0	
101886	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
101887	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
101888	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
101889	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
101890	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
101891	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
101892	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
101893	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
101894	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
101895	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
101896	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Follow-up Action Required?	n	
101897	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
101898	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	General Comments		
101899	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
101900	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
101901	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
101902	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
101903	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
101904	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
101905	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
101906	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
101907	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
101908	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
101909	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
101910	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	232899	
101911	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	59.02	%
101912	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	43.36	%
101913	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	150.0	
101914	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	170.0	
101915	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	190.0	
101916	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
101917	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
101918	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
101919	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	1	
101920	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
101921	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	1	
101922	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
101923	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
101924	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
101925	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
101926	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
101927	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
101928	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	All Connections OK?	y	
101929	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Current Tap Position	6L	
101930	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
101931	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
101932	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
101933	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	40	
101934	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	40	
101935	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	3	
101936	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
101937	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Unknown Operations	3	
101938	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	573	
101939	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	573	
101940	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	4	
101941	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
101942	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Unknown Operations	2	
101943	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Max Tap Position	6R	
101944	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Min Tap Position	12L	
101945	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Operations Since Last Insp	1812	
101946	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
101947	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
101948	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
101949	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
101950	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
101951	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
101952	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
101953	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
101954	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
101955	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
101956	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	480.0	
101957	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0136	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
101958	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
101959	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
101960	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	3467.52	kw
101961	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
101962	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
101963	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
101964	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Time Delay	30	Seconds
101965	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
101966	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
101967	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
101968	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
101969	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
101970	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
101971	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
101972	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
101973	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
101974	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
101975	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
101976	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
101977	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
101978	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
101979	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
101980	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	10	
101981	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
101982	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	9.64	%
101983	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	12.05	%
101984	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	200.0	
101985	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	210.0	
101986	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	200.0	
101987	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
101988	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
101989	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
101990	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
101991	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
101992	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
101993	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
101994	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
101995	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
101996	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
101997	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
101998	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
101999	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
102000	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
102001	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102002	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
102003	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
102004	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
102005	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
102006	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	19	
102007	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	42.16	%
102008	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
102009	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
102010	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
102011	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
102012	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
102013	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
102014	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
102015	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
102016	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
102017	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
102018	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
102019	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
102020	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
102021	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
102022	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
102023	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
102024	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
102025	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
102026	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102027	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
102028	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
102029	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
102030	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
102031	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102032	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102033	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102034	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102035	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102036	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102037	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102038	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102039	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102040	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102041	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
102042	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
102043	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
102044	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations Ground	0	
102045	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations C Ø	0	
102046	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations B Ø	0	
102047	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations A Ø	0	
102048	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102049	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102050	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102051	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	All Connections OK?	y	
102052	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	Follow-up Action Required?	n	
102053	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	General Comments		
102054	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	LTC Operation Checked?	y	
102055	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
102056	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC0000662	LTCControl	549-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
102057	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	23.1	%
102058	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	23.1	%
102059	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
102060	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	General Comments		
102061	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
102062	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
102063	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1100	
102064	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	4	
102065	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	23.1	%
102066	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1100	
102067	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
102068	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
102069	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0126	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
102070	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102071	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AL	188	
102072	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AF	188	
102073	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Moisture and Leak Free?	y	
102074	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Maintenance Operations	0	
102075	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Grounds in Place?	y	
102076	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102077	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	General Comments		
102078	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Foundation Condition	Good	
102079	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Follow-up Action Required?	n	
102080	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Follow-up Action Required?	n	
102081	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
102082	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
102083	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
102084	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102085	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
102086	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
102087	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	165	
102088	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
102089	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
102090	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
102091	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
102092	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
102093	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
102094	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
102095	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102096	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
102097	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
102098	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
102099	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102100	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102101	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102102	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
102103	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	General Comments		
102104	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	General Comments		
102105	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
102106	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Follow-up Action Required?	n	
102107	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
102108	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
102109	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
102110	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		
102111	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
102112	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
102113	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
102114	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
102115	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
102116	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
102117	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
102118	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
102119	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
102120	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
102121	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
102122	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
102123	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
102124	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
102125	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
102126	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
102127	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
102128	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
102129	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
102130	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
102131	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
102132	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
102133	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
102134	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	2	
102135	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	2	
102136	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	
102137	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
102138	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Unknown Operations	0	
102139	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
102140	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
102141	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	1	
102142	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	207	
102143	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	207	
102144	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
102145	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
102146	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
102147	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
102148	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
102149	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	General Comments		
102150	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
102151	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102152	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
102153	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments	C Phase IOC	
102154	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
102155	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
102156	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
102157	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1100	
102158	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1100	
102159	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
102160	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
102161	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	General Comments		
102162	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0124	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
102163	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
102164	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
102165	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
102166	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102167	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102168	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102169	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
102170	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
102171	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
102172	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
102173	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
102174	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
102175	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
102176	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102177	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102178	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102179	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102180	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102181	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102182	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushing Condition	Good	
102183	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps C Ø	59.0	
102184	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps B Ø	66.0	
102185	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps A Ø	65.0	
102186	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102187	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102188	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102189	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations	1	
102190	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102191	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102192	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102193	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
102194	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	325	
102195	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	325	
102196	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
102197	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
102198	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
102199	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	113	
102200	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	113	
102201	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
102202	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
102203	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
102204	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	1	
102205	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
102206	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
102207	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
102208	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	100.0	
102209	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	100.0	
102210	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	100.0	
102211	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
102212	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
102213	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
102214	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
102215	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
102216	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
102217	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
102218	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
102219	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
102220	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
102221	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Months Operations	0	
102222	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
102223	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
102224	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
102225	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps A Ø	50.0	
102226	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps B Ø	30.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102227	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps C Ø	50.0	
102228	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
102229	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
102230	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
102231	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	178	
102232	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	178	
102233	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
102234	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
102235	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
102236	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
102237	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
102238	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
102239	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
102240	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations A Ø	0	
102241	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations B Ø	0	
102242	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations C Ø	0	
102243	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations Ground	0	
102244	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
102245	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Follow-up Action Required?	n	
102246	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	General Comments		
102247	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	General Comments		
102248	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
102249	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Maintenance Operations	0	
102250	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AF	99955	
102251	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AL	99955	
102252	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations This Read AM	0	
102253	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Switching Operations	0	
102254	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Unknown Operations	0	
102255	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	329.0	
102256	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	315.0	
102257	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102258	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102259	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102260	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
102261	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
102262	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
102263	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
102264	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	6	
102265	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
102266	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
102267	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
102268	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
102269	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	891	
102270	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
102271	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102272	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102273	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102274	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	1120.0	
102275	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
102276	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
102277	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102278	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102279	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102280	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102281	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102282	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102283	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102284	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102285	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102286	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102287	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
102288	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
102289	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
102290	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
102291	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102292	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
102293	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
102294	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
102295	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
102296	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
102297	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
102298	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
102299	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	305	
102300	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	305	
102301	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	9L	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102302	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	7R	
102303	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
102304	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	1	
102305	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	25.51	%
102306	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	31.09	%
102307	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	15.15	%
102308	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	322.0	
102309	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
102310	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102311	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	2	
102312	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
102313	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
102314	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
102315	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
102316	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	29.0	
102317	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	40.0	
102318	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	56.0	
102319	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102320	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102321	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102322	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
102323	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	972	
102324	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	972	
102325	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
102326	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
102327	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	General Comments		
102328	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
102329	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
102330	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
102331	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
102332	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
102333	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
102334	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	286	
102335	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
102336	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
102337	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	48.0	
102338	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	48.0	
102339	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0131	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	48.0	
102340	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
102341	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
102342	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
102343	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
102344	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	55.0	
102345	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
102346	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
102347	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
102348	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102349	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
102350	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	228	
102351	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	228	
102352	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
102353	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
102354	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
102355	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
102356	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
102357	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
102358	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
102359	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102360	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
102361	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
102362	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
102363	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
102364	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102365	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102366	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102367	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102368	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102369	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102370	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102371	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	286	
102372	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
102373	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
102374	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	
102375	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	43.0	
102376	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	44.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102377	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	42.0	
102378	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
102379	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
102380	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
102381	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
102382	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
102383	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
102384	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
102385	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
102386	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		
102387	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
102388	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	680	
102389	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	10	
102390	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102391	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102392	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102393	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	100.0	
102394	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
102395	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
102396	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102397	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102398	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102399	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102400	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102401	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102402	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102403	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102404	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102405	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102406	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
102407	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
102408	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
102409	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
102410	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102411	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
102412	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
102413	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
102414	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
102415	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
102416	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
102417	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
102418	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	662	
102419	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	662	
102420	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
102421	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102422	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	5	
102423	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
102424	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
102425	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	680	
102426	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
102427	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
102428	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
102429	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102430	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps C Ø	177.0	
102431	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps B Ø	157.0	
102432	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps A Ø	165.0	
102433	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty C Ph V	5	%
102434	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty B Ph V	6.67	%
102435	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty A Ph V	5	%
102436	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations	13	
102437	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Unknown Operations	0	
102438	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Switching Operations	0	
102439	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations This Read Vac	0	
102440	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
102441	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
102442	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
102443	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AL	166	
102444	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AF	166	
102445	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Maintenance Operations	0	
102446	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
102447	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
102448	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
102449	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
102450	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	LTC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
102451	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102452	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
102453	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	10	
102454	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102455	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	10	
102456	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	378	
102457	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	378	
102458	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
102459	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
102460	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
102461	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
102462	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
102463	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
102464	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
102465	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102466	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
102467	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	General Comments		
102468	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Follow-up Action Required?	n	
102469	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations Ground	0	
102470	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations C Ø	0	
102471	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations B Ø	0	
102472	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations A Ø	0	
102473	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102474	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102475	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102476	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps C Ø	75.0	
102477	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps B Ø	125.0	
102478	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps A Ø	111.0	
102479	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty C Ph V	3.33	%
102480	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty B Ph V	5	%
102481	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty A Ph V	5	%
102482	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102483	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102484	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102485	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	32.0	
102486	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	36.0	
102487	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	29.0	
102488	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	9.57	%
102489	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	16.74	%
102490	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
102491	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	6	
102492	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
102493	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
102494	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
102495	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
102496	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
102497	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
102498	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102499	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102500	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102501	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102502	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102503	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102504	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102505	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102506	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102507	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102508	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
102509	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
102510	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
102511	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102512	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102513	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102514	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
102515	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
102516	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
102517	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
102518	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
102519	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
102520	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
102521	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BCH000101	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
102522	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Unknown Operations	0	
102523	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Switching Operations	0	
102524	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations This Read Vac	0	
102525	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AL	158	
102526	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AF	158	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102527	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Maintenance Operations	0	
102528	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	General Comments		
102529	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Follow-up Action Required?	n	
102530	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations Ground	0	
102531	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations C Ø	0	
102532	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations B Ø	0	
102533	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations A Ø	0	
102534	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102535	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102536	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
102537	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
102538	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
102539	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
102540	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
102541	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102542	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102543	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102544	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
102545	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
102546	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102547	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102548	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102549	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102550	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102551	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
102552	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
102553	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
102554	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
102555	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
102556	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
102557	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	General Comments		
102558	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
102559	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
102560	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
102561	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
102562	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
102563	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
102564	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
102565	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	General Comments		
102566	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
102567	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
102568	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
102569	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
102570	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
102571	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Vegetation	None	
102572	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
102573	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
102574	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
102575	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
102576	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
102577	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	
102578	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
102579	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
102580	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
102581	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Unknown Operations	0	
102582	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
102583	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
102584	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102585	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102586	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102587	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
102588	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
102589	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations	3	
102590	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
102591	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
102592	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Reading	.5910	
102593	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
102594	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
102595	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
102596	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
102597	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
102598	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
102599	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
102600	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
102601	11/5/2019 13:29	Distribution	Middleboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Present	35	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102602	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Max	35	°C
102603	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
102604	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
102605	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	LTC Totalizer Reading	5673.60	kw
102606	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
102607	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	General Comments		
102608	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	General Comments		
102609	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
102610	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
102611	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Follow-up Action Required?	n	
102612	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
102613	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
102614	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
102615	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
102616	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
102617	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
102618	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
102619	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
102620	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
102621	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	920.0	
102622	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	890.0	
102623	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	863.0	
102624	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102625	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102626	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102627	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
102628	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
102629	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
102630	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
102631	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
102632	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
102633	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
102634	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
102635	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
102636	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
102637	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
102638	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
102639	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
102640	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
102641	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
102642	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
102643	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	0	
102644	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
102645	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
102646	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	138	
102647	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	138	
102648	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
102649	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
102650	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
102651	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
102652	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
102653	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
102654	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
102655	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102656	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102657	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
102658	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
102659	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
102660	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
102661	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
102662	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
102663	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
102664	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
102665	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
102666	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
102667	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
102668	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
102669	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
102670	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1442	
102671	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1442	
102672	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
102673	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
102674	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
102675	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
102676	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102677	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
102678	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
102679	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
102680	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
102681	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
102682	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
102683	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
102684	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	93.0	
102685	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	85.0	
102686	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
102687	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
102688	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
102689	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
102690	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
102691	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
102692	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
102693	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
102694	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
102695	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
102696	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
102697	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
102698	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
102699	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
102700	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
102701	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
102702	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
102703	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102704	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102705	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102706	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushing Condition	Good	
102707	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
102708	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
102709	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps C Ø	240.0	
102710	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps B Ø	240.0	
102711	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps A Ø	240.0	
102712	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102713	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102714	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102715	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations	14	
102716	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	2	
102717	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
102718	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
102719	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
102720	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	178.0	
102721	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	210.0	
102722	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	197.0	
102723	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102724	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102725	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102726	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
102727	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
102728	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
102729	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
102730	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
102731	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	0	
102732	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	962	
102733	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	962	
102734	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
102735	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		
102736	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
102737	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
102738	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
102739	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	0	
102740	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
102741	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
102742	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
102743	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
102744	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	132.0	
102745	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	118.0	
102746	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	128.0	
102747	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
102748	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
102749	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
102750	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
102751	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102752	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
102753	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
102754	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
102755	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
102756	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
102757	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
102758	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
102759	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
102760	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
102761	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
102762	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
102763	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	9	
102764	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	3	
102765	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
102766	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
102767	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
102768	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	63.0	
102769	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	86.0	
102770	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	72.0	
102771	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102772	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102773	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102774	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
102775	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
102776	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
102777	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
102778	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
102779	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
102780	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
102781	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	243	
102782	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	243	
102783	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	1	
102784	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	1	
102785	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
102786	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
102787	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
102788	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
102789	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	2	
102790	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	22.89	%
102791	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
102792	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	16.86	%
102793	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	150.0	
102794	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	110.0	
102795	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	120.0	
102796	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
102797	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
102798	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
102799	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
102800	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
102801	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
102802	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
102803	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
102804	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
102805	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
102806	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	General Comments		
102807	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
102808	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Found Counter	96087	
102809	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Left Counter	96087	
102810	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
102811	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
102812	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
102813	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
102814	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1456	
102815	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
102816	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
102817	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
102818	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	5	
102819	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	23.92	%
102820	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
102821	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	20.73	%
102822	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	75.0	
102823	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	68.0	
102824	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	69.0	
102825	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102826	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
102827	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102828	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
102829	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
102830	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
102831	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
102832	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
102833	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
102834	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
102835	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	406	
102836	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	406	
102837	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
102838	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
102839	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
102840	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	3963	
102841	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	3963	
102842	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
102843	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
102844	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
102845	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
102846	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	General Comments		
102847	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
102848	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
102849	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
102850	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
102851	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
102852	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
102853	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
102854	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
102855	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0133	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
102856	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Unknown Operations	0	
102857	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
102858	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	257.0	
102859	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	252.0	
102860	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	222.0	
102861	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102862	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102863	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102864	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
102865	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
102866	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
102867	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
102868	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Trash?	y	
102869	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
102870	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
102871	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
102872	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
102873	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
102874	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	General Comments		
102875	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
102876	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Vegetation	None	
102877	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
102878	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
102879	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
102880	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
102881	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
102882	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
102883	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	547	
102884	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	547	
102885	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
102886	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
102887	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Unknown Operations	0	
102888	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	227939	
102889	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
102890	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
102891	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
102892	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
102893	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
102894	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	267	
102895	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	267	
102896	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
102897	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments	Closed on #0028	
102898	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
102899	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
102900	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
102901	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102902	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
102903	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102904	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102905	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102906	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	260.0	
102907	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	260.0	
102908	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	260.0	
102909	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	61.61	%
102910	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
102911	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	4921	
102912	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
102913	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	57.0	
102914	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	55.0	
102915	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
102916	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
102917	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
102918	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
102919	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
102920	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
102921	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
102922	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
102923	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
102924	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
102925	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
102926	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
102927	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
102928	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
102929	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
102930	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
102931	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
102932	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
102933	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
102934	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
102935	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
102936	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
102937	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
102938	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Unknown Operations	0	
102939	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	4914	
102940	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
102941	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
102942	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
102943	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
102944	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
102945	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
102946	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
102947	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
102948	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
102949	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
102950	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
102951	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
102952	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
102953	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
102954	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
102955	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
102956	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
102957	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
102958	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
102959	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
102960	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
102961	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	1	
102962	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
102963	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
102964	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
102965	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
102966	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
102967	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
102968	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
102969	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3R	
102970	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Unknown Operations	0	
102971	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Tank Paint Condition	Good	
102972	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Switching Operations	11	
102973	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
102974	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations This Read Vac	11	
102975	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AL	51	
102976	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AF	51	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
102977	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Moisture and Leak Free?	y	
102978	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Maintenance Operations	0	
102979	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Grounds in Place?	y	
102980	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	General Comments		
102981	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	General Comments		
102982	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Foundation Condition	Good	
102983	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	4	
102984	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
102985	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	4	
102986	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	205	
102987	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	205	
102988	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
102989	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments		
102990	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
102991	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
102992	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	0	
102993	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	0	
102994	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
102995	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	44.72	
102996	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	44.72	
102997	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	44.72	
102998	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	83.0	
102999	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Follow-up Action Required?	n	
103000	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Follow-up Action Required?	n	
103001	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations Ground	0	
103002	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations C Ø	0	
103003	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations B Ø	0	
103004	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations A Ø	0	
103005	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103006	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103007	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103008	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103009	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103010	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103011	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
103012	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
103013	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
103014	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
103015	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
103016	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
103017	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	61.61	%
103018	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	61.61	%
103019	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	7	
103020	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
103021	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
103022	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Reading	.5688	
103023	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Multiplier	4600	
103024	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103025	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103026	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
103027	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
103028	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
103029	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
103030	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
103031	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Present	22	°C
103032	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Max	22	°C
103033	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
103034	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
103035	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	LTC Totalizer Reading	2616.48	kw
103036	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
103037	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	General Comments		
103038	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	General Comments		
103039	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
103040	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
103041	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Follow-up Action Required?	n	
103042	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
103043	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
103044	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
103045	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
103046	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
103047	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
103048	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
103049	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
103050	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
103051	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103052	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
103053	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
103054	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
103055	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
103056	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
103057	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
103058	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
103059	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
103060	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
103061	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
103062	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
103063	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
103064	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
103065	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
103066	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	BAT000094	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
103067	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
103068	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
103069	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
103070	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	194551	
103071	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations C Ø	0	
103072	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations Ground	0	
103073	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Follow-up Action Required?	n	
103074	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Follow-up Action Required?	n	
103075	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Foundation Condition	Good	
103076	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	General Comments		
103077	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	General Comments		
103078	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Grounds in Place?	y	
103079	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Maintenance Operations	0	
103080	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Moisture and Leak Free?	y	
103081	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AF	413	
103082	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AL	413	
103083	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
103084	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
103085	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
103086	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
103087	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
103088	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
103089	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103090	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103091	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103092	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	54.0	
103093	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	62.0	
103094	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	67.0	
103095	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
103096	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	27.9	%
103097	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	27.1	%
103098	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	2	
103099	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations This Read Vac	5	
103100	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103101	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Switching Operations	5	
103102	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Tank Paint Condition	Good	
103103	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Unknown Operations	0	
103104	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Unknown Operations	0	
103105	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	1	
103106	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	1	
103107	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	375	
103108	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	4	
103109	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
103110	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
103111	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
103112	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	38.0	
103113	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	40.0	
103114	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations	6	
103115	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
103116	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
103117	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
103118	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps A Ø	100.0	
103119	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps B Ø	80.0	
103120	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps C Ø	120.0	
103121	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushing Condition	Good	
103122	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
103123	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
103124	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
103125	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
103126	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103127	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
103128	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
103129	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
103130	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
103131	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
103132	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
103133	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
103134	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103135	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103136	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103137	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
103138	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
103139	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99970	
103140	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99970	
103141	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
103142	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103143	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
103144	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
103145	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
103146	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103147	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103148	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103149	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103150	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations A Ø	0	
103151	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Unknown Operations	0	
103152	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
103153	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
103154	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	355	
103155	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	355	
103156	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
103157	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations B Ø	0	
103158	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
103159	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	15.66	%
103160	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	7	
103161	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	14	
103162	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	13.55	%
103163	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	15.94	%
103164	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
103165	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	20.0	
103166	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	39.0	
103167	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	23.0	
103168	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
103169	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
103170	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
103171	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	3	
103172	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	3	
103173	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	3	
103174	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
103175	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
103176	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
103177	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
103178	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	372	
103179	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	372	
103180	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	9	
103181	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
103182	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
103183	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Broom on Site?	y	
103184	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
103185	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
103186	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
103187	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
103188	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
103189	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
103190	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Floor Swept?	y	
103191	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
103192	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
103193	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	General Comments		
103194	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
103195	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Trash Emptied?	n	
103196	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
103197	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	CH000242	ControlHouse	951-Offline-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
103198	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
103199	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
103200	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
103201	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103202	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	0.0	
103203	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103204	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103205	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103206	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
103207	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
103208	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
103209	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
103210	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
103211	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
103212	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
103213	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	160	
103214	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	160	
103215	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
103216	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
103217	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
103218	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
103219	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
103220	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
103221	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	685	
103222	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	685	
103223	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
103224	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
103225	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	General Comments		
103226	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
103227	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
103228	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
103229	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
103230	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0130	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
103231	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	375	
103232	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
103233	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
103234	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
103235	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
103236	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
103237	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
103238	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
103239	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
103240	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
103241	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
103242	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	210.0	
103243	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	210.0	
103244	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	210.0	
103245	7/30/2019 13:42	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
103246	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	472	
103247	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
103248	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
103249	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
103250	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
103251	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
103252	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
103253	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
103254	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	4	
103255	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	334	
103256	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	334	
103257	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
103258	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments	A, B and C phase IOC	
103259	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
103260	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
103261	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	2	
103262	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	1	
103263	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	1	
103264	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
103265	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
103266	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
103267	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	51.0	
103268	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	52.0	
103269	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	63.0	
103270	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	21.52	%
103271	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	21.52	%
103272	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	43.05	%
103273	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	20	
103274	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
103275	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
103276	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
103277	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
103278	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
103279	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
103280	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
103281	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	General Comments		
103282	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
103283	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
103284	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
103285	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
103286	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
103287	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
103288	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
103289	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Months Operations	0	
103290	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	3.2	%
103291	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	3.2	%
103292	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	3.2	%
103293	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps A Ø	50.0	
103294	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps B Ø	30.0	
103295	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps C Ø	50.0	
103296	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
103297	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
103298	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
103299	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
103300	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations A Ø	0	
103301	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations B Ø	0	
103302	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations C Ø	0	
103303	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations Ground	0	
103304	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
103305	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Follow-up Action Required?	n	
103306	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	General Comments		
103307	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	General Comments		
103308	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
103309	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Maintenance Operations	0	
103310	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AF	288	
103311	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AL	288	
103312	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations This Read AM	0	
103313	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
103314	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
103315	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
103316	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
103317	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
103318	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Switching Operations	0	
103319	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Unknown Operations	0	
103320	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103321	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103322	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103323	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	139.0	
103324	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	102.0	
103325	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	145.0	
103326	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
103327	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
103328	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	8.77	%
103329	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	4	
103330	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
103331	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
103332	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	472	
103333	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Foundation Condition	Good	
103334	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
103335	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
103336	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	General Comments		
103337	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
103338	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
103339	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
103340	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
103341	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
103342	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
103343	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
103344	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
103345	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
103346	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
103347	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
103348	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
103349	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1675	
103350	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
103351	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	6R	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
103352	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
103353	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
103354	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	18584	
103355	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	18576	
103356	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
103357	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	General Comments		
103358	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
103359	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
103360	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
103361	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
103362	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
103363	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
103364	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
103365	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
103366	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
103367	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
103368	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
103369	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
103370	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103371	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103372	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103373	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103374	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103375	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103376	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103377	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
103378	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
103379	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
103380	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
103381	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
103382	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
103383	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
103384	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
103385	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
103386	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
103387	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
103388	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	
103389	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5	
103390	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	
103391	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	
103392	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.800	
103393	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	0	
103394	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	16.74	
103395	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	18.33	
103396	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	7.97	
103397	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	170.0	
103398	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	181.0	
103399	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	173.0	
103400	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103401	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103402	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103403	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
103404	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
103405	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
103406	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
103407	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
103408	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
103409	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
103410	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	197	
103411	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	197	
103412	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	0	
103413	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
103414	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
103415	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
103416	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
103417	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
103418	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
103419	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
103420	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
103421	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
103422	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
103423	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
103424	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
103425	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103426	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103427	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
103428	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
103429	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations	7	
103430	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
103431	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
103432	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
103433	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments	Not in service	
103434	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
103435	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
103436	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
103437	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
103438	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
103439	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103440	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103441	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
103442	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
103443	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
103444	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	44	°C
103445	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	51	°C
103446	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
103447	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
103448	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	8075.52	kw
103449	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
103450	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	General Comments		
103451	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
103452	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
103453	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
103454	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
103455	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
103456	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
103457	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
103458	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps A Ø	114.0	
103459	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps B Ø	130.0	
103460	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
103461	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
103462	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
103463	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
103464	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
103465	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
103466	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
103467	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
103468	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
103469	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
103470	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
103471	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
103472	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
103473	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
103474	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
103475	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
103476	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
103477	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
103478	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	5868.00	kw
103479	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
103480	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
103481	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
103482	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
103483	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
103484	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
103485	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
103486	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
103487	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
103488	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
103489	11/6/2019 7:35	Distribution	Middleboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
103490	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
103491	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103492	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103493	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103494	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
103495	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
103496	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
103497	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
103498	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
103499	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
103500	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
103501	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103502	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
103503	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
103504	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
103505	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
103506	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
103507	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	68	°C
103508	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	42	°C
103509	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
103510	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
103511	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
103512	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
103513	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
103514	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103515	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103516	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
103517	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.8150	
103518	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
103519	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
103520	8/5/2019 13:18	Distribution	Canal Quarterly Inspection	LB0896	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
103521	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
103522	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
103523	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
103524	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
103525	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99990	
103526	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	MB0168	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99990	
103527	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
103528	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
103529	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8412	
103530	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
103531	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103532	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103533	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
103534	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Current Tap Position	7L	
103535	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
103536	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Left Counter	38167	
103537	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Found Counter	38160	
103538	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	General Comments		
103539	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	General Comments		
103540	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
103541	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
103542	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	265	
103543	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	265	
103544	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	0	
103545	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Follow-up Action Required?	n	
103546	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
103547	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Unknown Operations	0	
103548	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
103549	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Switching Operations	2	
103550	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103551	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations This Read Vac	2	
103552	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AL	191	
103553	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AF	191	
103554	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
103555	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Maintenance Operations	0	
103556	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
103557	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
103558	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	General Comments		
103559	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	General Comments		
103560	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
103561	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Follow-up Action Required?	n	
103562	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103563	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103564	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations A Ø	0	
103565	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
103566	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations B Ø	0	
103567	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations Ground	0	
103568	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTC0000821	LTCControl	780-3	LTC Control Insp	All Connections OK?	y	
103569	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTC0000821	LTCControl	780-3	LTC Control Insp	Follow-up Action Required?	n	
103570	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
103571	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
103572	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
103573	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
103574	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
103575	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
103576	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTC0000821	LTCControl	780-3	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
103577	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCCControl	780-3	LTC Control Insp	LTC Operation Checked?	y	
103578	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCCControl	780-3	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
103579	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCCControl	780-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
103580	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
103581	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
103582	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
103583	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
103584	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
103585	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations C Ø	0	
103586	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCCControl	780-3	LTC Control Insp	VRR Time Delay	30	Seconds
103587	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCCControl	780-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
103588	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
103589	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
103590	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103591	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103592	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	0	
103593	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103594	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103595	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103596	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
103597	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
103598	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
103599	11/6/2019 7:35	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps C Ø	129.0	
103600	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
103601	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	0	
103602	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	0	
103603	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	General Comments		
103604	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
103605	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
103606	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
103607	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
103608	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
103609	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
103610	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
103611	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
103612	11/5/2019 12:50	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
103613	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
103614	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Operations Since Last Insp	1280	
103615	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
103616	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Min Tap Position	14L	
103617	11/5/2019 13:29	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
103618	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Present	35	°C
103619	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Max	40	°C
103620	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Reading	.6700	
103621	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
103622	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
103623	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
103624	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
103625	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
103626	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
103627	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
103628	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103629	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103630	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
103631	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
103632	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
103633	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
103634	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
103635	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Present	35	°C
103636	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Max	35	°C
103637	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
103638	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
103639	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	LTC Totalizer Reading	12060.00	kw
103640	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
103641	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	General Comments		
103642	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AL	446	
103643	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations Ground	0	
103644	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
103645	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Follow-up Action Required?	n	
103646	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	General Comments		
103647	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	General Comments		
103648	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Maintenance Operations	0	
103649	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AF	446	
103650	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
103651	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A5 Found Float Voltage	53.3	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103652	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
103653	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
103654	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
103655	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
103656	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
103657	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
103658	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations A Ø	0	
103659	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
103660	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
103661	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
103662	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
103663	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps C Ø	50.0	
103664	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	General Comments		
103665	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
103666	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
103667	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Foundation Condition	Good	
103668	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
103669	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
103670	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
103671	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
103672	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
103673	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
103674	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps B Ø	30.0	
103675	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
103676	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
103677	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
103678	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
103679	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps A Ø	50.0	
103680	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
103681	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
103682	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
103683	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
103684	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
103685	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
103686	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
103687	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
103688	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
103689	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
103690	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	
103691	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
103692	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
103693	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
103694	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
103695	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Months Operations	35	
103696	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Switching Operations	1	
103697	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Tank Paint Condition	Good	
103698	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Unknown Operations	0	
103699	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	9 Month Operations	5	
103700	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
103701	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
103702	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
103703	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
103704	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
103705	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
103706	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
103707	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
103708	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
103709	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
103710	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	General Comments		
103711	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	General Comments		
103712	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
103713	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
103714	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Follow-up Action Required?	n	
103715	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
103716	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
103717	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations C Ø	0	
103718	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations B Ø	0	
103719	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
103720	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
103721	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
103722	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
103723	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
103724	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
103725	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
103726	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103727	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Operations Since Last Insp	1176	
103728	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
103729	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Min Tap Position	4L	
103730	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Max Tap Position	5R	
103731	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Current Tap Position	4R	
103732	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
103733	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Left Counter	40414	
103734	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Found Counter	40414	
103735	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	General Comments		
103736	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	General Comments		
103737	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
103738	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Follow-up Action Required?	n	
103739	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
103740	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
103741	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
103742	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
103743	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
103744	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
103745	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
103746	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
103747	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
103748	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
103749	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
103750	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
103751	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
103752	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
103753	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
103754	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
103755	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushings Connection/Risers	Good	
103756	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
103757	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
103758	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
103759	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
103760	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
103761	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	General Comments		
103762	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
103763	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
103764	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
103765	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
103766	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
103767	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
103768	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
103769	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
103770	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
103771	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
103772	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
103773	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Unknown Operations	0	
103774	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Tank Paint Condition	Good	
103775	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Switching Operations	0	
103776	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103777	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations This Read Vac	4	
103778	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AL	166	
103779	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AF	166	
103780	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Moisture and Leak Free?	y	
103781	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Maintenance Operations	4	
103782	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
103783	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
103784	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
103785	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
103786	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
103787	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000138	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
103788	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Grounds in Place?	y	
103789	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	General Comments		
103790	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	General Comments		
103791	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Foundation Condition	Good	
103792	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Follow-up Action Required?	n	
103793	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Follow-up Action Required?	n	
103794	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations Ground	0	
103795	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations C Ø	0	
103796	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
103797	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
103798	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
103799	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
103800	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	LTC Totalizer Reading	11070.00	kw
103801	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
103802	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
103803	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Max	45	°C
103804	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Present	35	°C
103805	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
103806	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
103807	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
103808	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
103809	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
103810	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Operations Since Last Insp	1894	
103811	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
103812	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
103813	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
103814	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
103815	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103816	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103817	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
103818	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Reading	.6150	
103819	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Max	45	°C
103820	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Present	45	°C
103821	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
103822	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
103823	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
103824	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Max Tap Position	7R	
103825	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Current Tap Position	5R	
103826	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
103827	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Left Counter	243855	
103828	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Found Counter	243845	
103829	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	General Comments		
103830	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations	36	
103831	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
103832	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
103833	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
103834	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps A Ø	195.0	
103835	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps B Ø	145.0	
103836	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps C Ø	155.0	
103837	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushing Condition	Good	
103838	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
103839	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Vegetation	None	
103840	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
103841	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
103842	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	General Comments		
103843	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
103844	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
103845	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
103846	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
103847	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
103848	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Trash?	y	
103849	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
103850	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
103851	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
103852	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	General Comments		
103853	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
103854	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
103855	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
103856	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
103857	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
103858	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
103859	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
103860	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
103861	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
103862	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
103863	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	General Comments		
103864	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
103865	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	General Comments		
103866	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
103867	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
103868	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
103869	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
103870	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
103871	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Follow-up Action Required?	n	
103872	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
103873	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
103874	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
103875	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	General Comments		
103876	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
103877	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
103878	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
103879	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
103880	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations B Ø	0	
103881	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations A Ø	0	
103882	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103883	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103884	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103885	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103886	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103887	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103888	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103889	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
103890	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
103891	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushing Condition	Good	
103892	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps C Ø	185.0	
103893	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
103894	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
103895	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps B Ø	200.0	
103896	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps A Ø	175.0	
103897	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Paint Condition	Good	
103898	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
103899	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
103900	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
103901	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
103902	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations A Ø	0	
103903	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations B Ø	0	
103904	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations C Ø	0	
103905	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations Ground	0	
103906	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Follow-up Action Required?	n	
103907	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Follow-up Action Required?	n	
103908	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Foundation Condition	Good	
103909	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	General Comments		
103910	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	General Comments		
103911	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Grounds in Place?	y	
103912	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Heaters (All) Functioning?	y	
103913	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Maintenance Operations	0	
103914	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Moisture and Leak Free?	y	
103915	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AF	275	
103916	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AL	275	
103917	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations This Read Vac	0	
103918	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
103919	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Switching Operations	0	
103920	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Tank Paint Condition	Good	
103921	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Unknown Operations	0	
103922	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
103923	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
103924	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
103925	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
103926	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
103927	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Present	45	°C
103928	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Max	60	°C
103929	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Reading	1.0400	
103930	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
103931	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	78	
103932	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
103933	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
103934	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
103935	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
103936	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Left Counter	337067	
103937	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Found Counter	337067	
103938	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
103939	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	General Comments		
103940	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
103941	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
103942	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	VRR Time Delay	30	Seconds
103943	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
103944	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
103945	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
103946	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
103947	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Trash?	y	
103948	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
103949	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
103950	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
103951	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
103952	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
103953	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	General Comments		
103954	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
103955	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
103956	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Vegetation	None	
103957	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
103958	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
103959	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
103960	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
103961	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	LTC Operation Checked?	y	
103962	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	General Comments		
103963	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	Follow-up Action Required?	n	
103964	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
103965	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
103966	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
103967	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	General Comments		
103968	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
103969	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
103970	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
103971	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
103972	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
103973	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
103974	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Trash?	y	
103975	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
103976	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
103977	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
103978	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
103979	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
103980	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
103981	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
103982	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
103983	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
103984	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
103985	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	General Comments		
103986	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
103987	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
103988	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Foundation Condition	Good	
103989	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
103990	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
103991	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
103992	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
103993	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
103994	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
103995	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
103996	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
103997	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
103998	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
103999	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
104000	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
104001	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
104002	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
104003	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
104004	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
104005	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
104006	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
104007	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
104008	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
104009	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BAT000408	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
104010	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
104011	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
104012	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
104013	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
104014	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
104015	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
104016	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
104017	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
104018	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
104019	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
104020	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
104021	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
104022	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
104023	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
104024	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
104025	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
104026	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104027	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
104028	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
104029	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
104030	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Foundation Condition	Good	
104031	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
104032	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
104033	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	General Comments		
104034	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
104035	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
104036	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
104037	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
104038	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
104039	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
104040	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
104041	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
104042	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
104043	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
104044	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
104045	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
104046	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
104047	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
104048	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
104049	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
104050	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
104051	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
104052	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
104053	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	BCH000520	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
104054	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
104055	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
104056	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	LTC000728	LTCControl	400-1	LTC Control Insp	All Connections OK?	y	
104057	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
104058	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
104059	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
104060	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Operations Since Last Insp	1105	
104061	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
104062	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Min Tap Position	9L	
104063	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Max Tap Position	3L	
104064	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Current Tap Position	3L	
104065	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
104066	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Left Counter	51121	
104067	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Found Counter	51121	
104068	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	General Comments		
104069	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	General Comments		
104070	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
104071	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Follow-up Action Required?	n	
104072	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
104073	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	General Comments		
104074	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
104075	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
104076	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
104077	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
104078	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
104079	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
104080	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Present	40	°C
104081	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Max	55	°C
104082	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
104083	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
104084	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	LTC Totalizer Reading	9984.00	kw
104085	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
104086	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	General Comments		
104087	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	General Comments		
104088	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
104089	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
104090	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Follow-up Action Required?	n	
104091	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
104092	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
104093	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
104094	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
104095	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
104096	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
104097	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
104098	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104099	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104100	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104101	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104102	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps C Ø	225.0	
104103	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps B Ø	175.0	
104104	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps A Ø	165.0	
104105	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104106	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104107	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104108	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	9 Month Operations	2	
104109	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Unknown Operations	0	
104110	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Tank Paint Condition	Good	
104111	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Switching Operations	0	
104112	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104113	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations This Read Vac	0	
104114	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AL	166	
104115	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AF	166	
104116	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Moisture and Leak Free?	y	
104117	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Maintenance Operations	0	
104118	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104119	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Grounds in Place?	y	
104120	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	General Comments		
104121	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	General Comments		
104122	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Foundation Condition	Good	
104123	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Follow-up Action Required?	n	
104124	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Follow-up Action Required?	n	
104125	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations Ground	0	
104126	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations C Ø	0	
104127	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations B Ø	0	
104128	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations A Ø	0	
104129	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104130	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104131	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104132	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Pre-test Volts	12.7	VDC
104133	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104134	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104135	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104136	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104137	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104138	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104139	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104140	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104141	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104142	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations This Read AM	0	
104143	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Switching Operations	0	
104144	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Unknown Operations	0	
104145	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104146	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations This Read Vac	1	
104147	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AL	176	
104148	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AF	176	
104149	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Moisture and Leak Free?	y	
104150	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Maintenance Operations	0	
104151	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Grounds in Place?	y	
104152	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	General Comments		
104153	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	General Comments		
104154	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Foundation Condition	Good	
104155	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Follow-up Action Required?	n	
104156	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Follow-up Action Required?	n	
104157	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations Ground	0	
104158	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations C Ø	0	
104159	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations B Ø	0	
104160	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations A Ø	0	
104161	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104162	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104163	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104164	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104165	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104166	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	150.0	
104167	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	150.0	
104168	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	170.0	
104169	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
104170	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104171	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104172	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
104173	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
104174	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
104175	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
104176	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104177	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
104178	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
104179	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
104180	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Pre-test Volts	12.6	VDC
104181	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Post-test Volts	13.0	VDC
104182	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 2 Load Test Volts	10.3	VDC
104183	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Post-test Volts	12.9	VDC
104184	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	Battery 1 Load Test Volts	10.2	VDC
104185	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104186	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
104187	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
104188	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
104189	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
104190	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Follow-up Action Required?	n	
104191	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
104192	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
104193	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	General Comments		
104194	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	General Comments		
104195	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
104196	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	LTC Totalizer Reading	6710.40	kw
104197	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
104198	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
104199	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Max	72	*C
104200	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Present	52	*C
104201	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
104202	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
104203	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
104204	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
104205	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
104206	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
104207	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
104208	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
104209	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Reading	.6990	
104210	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
104211	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
104212	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104213	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
104214	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
104215	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	230	
104216	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	230	
104217	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
104218	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
104219	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
104220	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
104221	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
104222	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
104223	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
104224	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
104225	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
104226	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
104227	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Vegetation	None	
104228	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
104229	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
104230	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104231	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104232	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104233	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104234	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushing Condition	Good	
104235	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps C Ø	70.0	
104236	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps B Ø	70.0	
104237	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps A Ø	60.0	
104238	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104239	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104240	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104241	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	9 Month Operations	1	
104242	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
104243	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
104244	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
104245	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
104246	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
104247	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
104248	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BAT000132	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
104249	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
104250	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
104251	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104252	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
104253	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
104254	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
104255	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
104256	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
104257	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
104258	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
104259	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
104260	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
104261	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
104262	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
104263	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
104264	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
104265	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
104266	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
104267	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
104268	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
104269	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
104270	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
104271	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
104272	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
104273	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
104274	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
104275	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
104276	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
104277	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
104278	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
104279	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
104280	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Max	26	°C
104281	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
104282	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Follow-up Action Required?	n	
104283	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
104284	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
104285	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
104286	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
104287	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.2	psi
104288	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
104289	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
104290	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	General Comments		
104291	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	General Comments		
104292	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
104293	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
104294	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
104295	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
104296	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
104297	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
104298	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
104299	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
104300	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
104301	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
104302	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
104303	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
104304	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
104305	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
104306	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
104307	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
104308	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
104309	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104310	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104311	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104312	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushing Condition	Good	
104313	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps C Ø	220.0	
104314	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps B Ø	215.0	
104315	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps A Ø	220.0	
104316	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104317	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Foundation Condition	Good	
104318	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
104319	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	General Comments		
104320	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
104321	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
104322	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
104323	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
104324	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
104325	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
104326	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104327	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
104328	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
104329	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
104330	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Leaks	None	
104331	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
104332	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
104333	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Regulator As Left Counter	7785	
104334	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
104335	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
104336	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
104337	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
104338	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
104339	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
104340	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
104341	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
104342	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	General Comments		
104343	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
104344	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
104345	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
104346	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
104347	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
104348	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
104349	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
104350	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
104351	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
104352	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Unknown Operations	0	
104353	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104354	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104355	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104356	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104357	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
104358	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
104359	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
104360	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
104361	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
104362	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	General Comments		
104363	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Follow-up Action Required?	n	
104364	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
104365	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations Ground	0	
104366	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations C Ø	0	
104367	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations B Ø	0	
104368	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations A Ø	0	
104369	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
104370	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
104371	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	VRR Time Delay	30	Seconds
104372	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
104373	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
104374	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
104375	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	LTC Operation Checked?	y	
104376	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	General Comments		
104377	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	Follow-up Action Required?	n	
104378	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	LTC000836	LTCControl	639-1	LTC Control Insp	All Connections OK?	y	
104379	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
104380	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Switching Operations	0	
104381	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations This Read Vac	0	
104382	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AL	163	
104383	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AF	163	
104384	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
104385	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Maintenance Operations	0	
104386	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
104387	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	General Comments		
104388	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	General Comments		
104389	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
104390	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Follow-up Action Required?	n	
104391	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
104392	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations Ground	0	
104393	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations C Ø	0	
104394	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations B Ø	0	
104395	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations A Ø	0	
104396	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104397	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104398	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104399	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104400	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104401	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104402	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104403	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104404	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104405	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
104406	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	General Comments		
104407	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	General Comments		
104408	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Grounds in Place?	y	
104409	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104410	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Maintenance Operations	0	
104411	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Moisture and Leak Free?	y	
104412	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AF	187	
104413	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
104414	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
104415	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
104416	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
104417	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
104418	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AL	187	
104419	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations This Read Vac	0	
104420	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104421	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Switching Operations	0	
104422	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Tank Paint Condition	Good	
104423	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
104424	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
104425	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
104426	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
104427	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
104428	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
104429	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
104430	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
104431	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
104432	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
104433	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
104434	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Unknown Operations	0	
104435	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
104436	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
104437	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
104438	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
104439	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
104440	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
104441	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	General Comments		
104442	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
104443	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
104444	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Unknown Operations	0	
104445	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Switching Operations	0	
104446	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations This Read AM	0	
104447	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AL	472	
104448	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AF	472	
104449	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Maintenance Operations	0	
104450	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	General Comments		
104451	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
104452	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104453	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations A Ø	0	
104454	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations B Ø	0	
104455	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations C Ø	0	
104456	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
104457	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
104458	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations Ground	0	
104459	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Leaks	None	
104460	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
104461	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
104462	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Regulator As Left Counter	8220	
104463	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
104464	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
104465	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
104466	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
104467	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
104468	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Follow-up Action Required?	n	
104469	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Follow-up Action Required?	n	
104470	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Foundation Condition	Good	
104471	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	General Comments		
104472	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	General Comments		
104473	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Grounds in Place?	y	
104474	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104475	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104476	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
104477	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Maintenance Operations	0	
104478	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Moisture and Leak Free?	y	
104479	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AF	186	
104480	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AL	186	
104481	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations This Read Vac	0	
104482	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104483	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Switching Operations	0	
104484	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Tank Paint Condition	Good	
104485	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Unknown Operations	0	
104486	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
104487	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
104488	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
104489	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
104490	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104491	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104492	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104493	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104494	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104495	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
104496	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	479	
104497	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations	3	
104498	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104499	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104500	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104501	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps A Ø	296.0	
104502	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps B Ø	311.0	
104503	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps C Ø	365.0	
104504	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushing Condition	Good	
104505	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104506	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
104507	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104508	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104509	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104510	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
104511	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104512	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
104513	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
104514	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
104515	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
104516	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
104517	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
104518	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
104519	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
104520	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
104521	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
104522	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104523	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104524	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104525	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104526	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	All Connections OK?	y	
104527	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	Follow-up Action Required?	n	
104528	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	General Comments		
104529	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	LTC Operation Checked?	y	
104530	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
104531	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
104532	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
104533	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
104534	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	VRR Time Delay	45	Seconds
104535	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104536	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	479	
104537	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
104538	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
104539	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104540	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations This Read Vac	0	
104541	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AL	168	
104542	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AF	168	
104543	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Moisture and Leak Free?	y	
104544	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Maintenance Operations	0	
104545	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
104546	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Max Tap Position	5R	
104547	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
104548	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	General Comments		
104549	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
104550	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
104551	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
104552	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
104553	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
104554	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
104555	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
104556	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
104557	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104558	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Grounds in Place?	y	
104559	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	General Comments		
104560	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	General Comments		
104561	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Foundation Condition	Good	
104562	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Follow-up Action Required?	n	
104563	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Follow-up Action Required?	n	
104564	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations Ground	0	
104565	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations C Ø	0	
104566	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations B Ø	0	
104567	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations A Ø	0	
104568	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104569	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104570	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
104571	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
104572	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Leaks	None	
104573	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
104574	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
104575	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Regulator As Left Counter	7183	
104576	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
104577	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
104578	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
104579	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
104580	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
104581	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
104582	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Max Tap Position	3R	
104583	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
104584	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	General Comments		
104585	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
104586	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations	2	
104587	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104588	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104589	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
104590	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	25.0	VDC
104591	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	25.0	VDC
104592	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
104593	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
104594	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104595	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps A Ø	0.0	
104596	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps B Ø	0.0	
104597	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps C Ø	0.0	
104598	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushing Condition	Good	
104599	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104600	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104601	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104602	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	General Comments		
104603	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104604	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104605	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104606	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104607	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104608	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104609	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations A Ø	0	
104610	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations B Ø	0	
104611	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104612	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
104613	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
104614	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Present	18	°C
104615	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Max	23	°C
104616	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
104617	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
104618	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
104619	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104620	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104621	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104622	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations C Ø	0	
104623	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations Ground	0	
104624	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Follow-up Action Required?	n	
104625	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Unknown Operations	0	
104626	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
104627	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Switching Operations	0	
104628	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
104629	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
104630	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
104631	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104632	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104633	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104634	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104635	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	9 Month Operations	4	
104636	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104637	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104638	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104639	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps A Ø	320.0	
104640	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps B Ø	300.0	
104641	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps C Ø	320.0	
104642	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushing Condition	Good	
104643	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104644	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104645	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104646	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104647	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104648	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104649	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104650	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104651	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104652	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations A Ø	0	
104653	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations B Ø	0	
104654	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations C Ø	0	
104655	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations Ground	0	
104656	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Follow-up Action Required?	n	
104657	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Follow-up Action Required?	n	
104658	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Foundation Condition	Good	
104659	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	General Comments		
104660	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	General Comments		
104661	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Grounds in Place?	y	
104662	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104663	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Maintenance Operations	0	
104664	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
104665	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AF	225	
104666	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AL	225	
104667	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations This Read Vac	0	
104668	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104669	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Switching Operations	0	
104670	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Tank Paint Condition	Good	
104671	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Unknown Operations	0	
104672	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
104673	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
104674	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
104675	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104676	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104677	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104678	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104679	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AL	384	
104680	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AF	384	
104681	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Maintenance Operations	0	
104682	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	General Comments		
104683	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	General Comments		
104684	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Follow-up Action Required?	n	
104685	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Tank Paint Condition	Good	
104686	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Switching Operations	0	
104687	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
104688	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 3	59	psi
104689	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 2	59	psi
104690	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 1	59	psi
104691	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
104692	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations This Read SF6	0	
104693	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AL	77	
104694	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AF	77	
104695	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Num Operations Last 9 Months	2	
104696	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
104697	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Maintenance Operations	0	
104698	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
104699	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Grounds in Place?	y	
104700	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	General Comments	y	
104701	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
104702	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
104703	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Foundation Condition	Good	
104704	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Follow-up Action Required?	n	
104705	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Follow-up Action Required?	n	
104706	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
104707	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations Ground	0	
104708	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations C Ø	0	
104709	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations B Ø	0	
104710	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations A Ø	0	
104711	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
104712	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
104713	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
104714	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
104715	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Fault Operations	0	
104716	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	701	
104717	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	701	
104718	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
104719	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
104720	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
104721	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
104722	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104723	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
104724	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
104725	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
104726	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
104727	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
104728	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
104729	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
104730	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
104731	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	General Comments		
104732	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
104733	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
104734	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
104735	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
104736	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
104737	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
104738	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
104739	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
104740	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
104741	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
104742	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
104743	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
104744	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
104745	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104746	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104747	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104748	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104749	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104750	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104751	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104752	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104753	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104754	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushing Condition	Good	
104755	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps C Ø	430.0	
104756	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps B Ø	425.0	
104757	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps A Ø	465.0	
104758	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104759	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104760	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104761	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations	5	
104762	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
104763	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
104764	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
104765	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
104766	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
104767	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
104768	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
104769	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
104770	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
104771	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
104772	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
104773	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
104774	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
104775	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Follow-up Action Required?	n	
104776	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104777	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
104778	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	General Comments		
104779	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	General Comments		
104780	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
104781	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104782	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
104783	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
104784	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
104785	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
104786	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104787	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104788	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
104789	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
104790	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Ambient Temperature	50	*F
104791	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104792	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
104793	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Vegetation	None	
104794	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
104795	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
104796	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	General Comments		
104797	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
104798	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
104799	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
104800	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
104801	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104802	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
104803	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
104804	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps C Ø	60.0	
104805	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps B Ø	70.0	
104806	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps A Ø	90.0	
104807	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
104808	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
104809	11/4/2019 10:34	Distribution	Florida Tile Quarterly Inspection	CB0250	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
104810	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Unknown Operations	0	
104811	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Tank Paint Condition	Good	
104812	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Switching Operations	0	
104813	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
104814	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations This Read Vac	0	
104815	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AL	187	
104816	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AF	187	
104817	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
104818	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Maintenance Operations	0	
104819	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104820	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Grounds in Place?	y	
104821	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	General Comments		
104822	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	General Comments		
104823	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Foundation Condition	Good	
104824	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Follow-up Action Required?	n	
104825	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Follow-up Action Required?	n	
104826	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations Ground	0	
104827	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations C Ø	0	
104828	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations B Ø	0	
104829	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations A Ø	0	
104830	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
104831	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
104832	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
104833	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations	1	
104834	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Unknown Operations	0	
104835	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Tank Paint Condition	Good	
104836	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Switching Operations	0	
104837	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations This Read Vac	0	
104838	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AL	189	
104839	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AF	189	
104840	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Moisture and Leak Free?	y	
104841	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Maintenance Operations	0	
104842	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Grounds in Place?	y	
104843	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	General Comments		
104844	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	General Comments		
104845	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Foundation Condition	Good	
104846	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps B Ø	0.0	
104847	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps A Ø	0.0	
104848	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
104849	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
104850	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
104851	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
104852	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
104853	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
104854	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
104855	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
104856	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
104857	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104858	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104859	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations	14	
104860	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
104861	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
104862	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
104863	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
104864	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
104865	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
104866	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
104867	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
104868	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
104869	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
104870	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
104871	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
104872	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
104873	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
104874	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
104875	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
104876	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Follow-up Action Required?	n	
104877	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps C Ø	0.0	
104878	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps B Ø	0.0	
104879	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps A Ø	0.0	
104880	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104881	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104882	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104883	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations	1	
104884	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Unknown Operations	0	
104885	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Tank Paint Condition	Good	
104886	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Switching Operations	0	
104887	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations This Read Vac	0	
104888	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AL	179	
104889	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AF	179	
104890	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Moisture and Leak Free?	y	
104891	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Maintenance Operations	0	
104892	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Grounds in Place?	y	
104893	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	General Comments		
104894	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	General Comments		
104895	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Foundation Condition	Good	
104896	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Follow-up Action Required?	n	
104897	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Follow-up Action Required?	n	
104898	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations Ground	0	
104899	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations C Ø	0	
104900	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations B Ø	0	
104901	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations A Ø	0	
104902	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104903	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104904	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104905	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
104906	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
104907	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
104908	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps C Ø	0.0	
104909	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104910	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104911	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104912	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104913	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104914	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushing Condition	Good	
104915	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps C Ø	0.0	
104916	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps B Ø	0.0	
104917	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps A Ø	0.0	
104918	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104919	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104920	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104921	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations B Ø	0	
104922	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations A Ø	0	
104923	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104924	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
104925	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
104926	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
104927	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
104928	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
104929	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
104930	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
104931	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
104932	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushing Condition	Good	
104933	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps C Ø	0.0	
104934	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps B Ø	0.0	
104935	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps A Ø	0.0	
104936	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104937	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104938	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104939	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations	1	
104940	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
104941	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
104942	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
104943	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
104944	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Months Operations	44	
104945	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
104946	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
104947	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
104948	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
104949	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Operations Since Last Insp	946	
104950	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
104951	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Min Tap Position	6L	
104952	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
104953	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
104954	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
104955	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Max Tap Position	1L	
104956	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Current Tap Position	1L	
104957	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
104958	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Left Counter	72038	
104959	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Found Counter	72038	
104960	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Months Operations	25	
104961	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
104962	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	General Comments		
104963	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	General Comments		
104964	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
104965	11/4/2019 12:06	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Follow-up Action Required?	n	
104966	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Unknown Operations	0	
104967	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Switching Operations	0	
104968	11/4/2019 11:36	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations This Read AM	0	
104969	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations C Ø	0	
104970	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations Ground	0	
104971	11/4/2019 11:17	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Follow-up Action Required?	n	
104972	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	5	
104973	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
104974	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	9	
104975	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
104976	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations This Read Vac	7	
104977	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	390	
104978	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	390	
104979	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	0	
104980	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		
104981	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
104982	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
104983	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
104984	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	1	
104985	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	1	
104986	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
104987	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
104988	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
104989	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
104990	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
104991	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	135.0	
104992	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	160.0	
104993	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	140.0	
104994	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
104995	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
104996	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		
104997	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
104998	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
104999	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
105000	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105001	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105077	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	179	
105078	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
105079	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
105080	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
105081	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
105082	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
105083	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
105084	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
105085	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105086	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
105087	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
105088	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
105089	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105090	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105091	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105092	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
105093	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
105094	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	General Comments		
105095	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
105096	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
105097	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Vegetation	None	
105098	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
105099	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
105100	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
105101	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105102	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105103	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105104	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
105105	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Foundation Condition	Good	
105106	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
105107	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105108	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	General Comments		
105109	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
105110	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
105111	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
105112	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
105113	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
105114	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
105115	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
105116	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
105117	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
105118	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
105119	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
105120	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
105121	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
105122	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
105123	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	54	*F
105124	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
105125	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
105126	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
105127	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
105128	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
105129	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
105130	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
105131	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
105132	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
105133	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
105134	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
105135	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
105136	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
105137	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
105138	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Trash?	y	
105139	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
105140	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
105141	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
105142	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
105143	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
105144	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
105145	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
105146	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
105147	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
105148	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	LTC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
105149	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
105150	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
105151	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105152	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
105153	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
105154	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
105155	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
105156	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
105157	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
105158	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
105159	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
105160	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
105161	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
105162	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
105163	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
105164	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
105165	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
105166	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
105167	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	General Comments		
105168	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	General Comments		
105169	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
105170	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
105171	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
105172	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
105173	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
105174	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	320.0	
105175	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	340.0	
105176	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	335.0	
105177	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
105178	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
105179	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
105180	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
105181	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
105182	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB00041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
105183	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
105184	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
105185	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	498.60	kw
105186	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
105187	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
105188	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
105189	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
105190	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
105191	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
105192	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
105193	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
105194	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
105195	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
105196	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8310	
105197	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
105198	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
105199	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
105200	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
105201	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
105202	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
105203	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
105204	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
105205	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
105206	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
105207	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105208	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105209	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
105210	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
105211	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
105212	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
105213	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
105214	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
105215	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
105216	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
105217	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
105218	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
105219	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	General Comments		
105220	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	General Comments		
105221	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
105222	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	LTC Totalizer Reading	5627.52	kw
105223	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
105224	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
105225	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
105226	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105227	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
105228	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
105229	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
105230	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
105231	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
105232	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Top Oil Temperature Max	55	°C
105233	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105234	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
105235	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Foundation Condition	Good	
105236	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
105237	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105238	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	General Comments		
105239	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
105240	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
105241	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
105242	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
105243	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
105244	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Top Oil Temperature Present	20	°C
105245	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
105246	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Reading	.5862	
105247	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
105248	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
105249	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
105250	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
105251	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
105252	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
105253	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
105254	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
105255	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
105256	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
105257	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58412	
105258	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105259	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
105260	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Leaks	None	
105261	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
105262	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
105263	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105264	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
105265	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105266	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105267	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105268	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105269	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
105270	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
105271	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Follow-up Action Required?	n	
105272	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
105273	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
105274	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
105275	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
105276	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	39527	
105277	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	39527	
105278	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
105279	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
105280	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
105281	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
105282	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
105283	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
105284	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1117	
105285	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
105286	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
105287	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
105288	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105289	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
105290	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	263	
105291	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	263	
105292	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
105293	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
105294	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
105295	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
105296	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
105297	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
105298	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
105299	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Leaks	None	
105300	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
105301	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
105302	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Regulator As Left Counter	68584	
105303	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
105304	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
105305	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
105306	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105307	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105308	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
105309	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
105310	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
105311	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
105312	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
105313	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
105314	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
105315	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
105316	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
105317	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
105318	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
105319	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
105320	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
105321	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105322	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105323	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105324	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105325	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
105326	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105327	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
105328	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
105329	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
105330	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
105331	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	General Comments		
105332	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105333	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
105334	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
105335	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
105336	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105337	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	General Comments		
105338	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
105339	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
105340	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
105341	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105342	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105343	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
105344	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
105345	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105346	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105347	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105348	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105349	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
105350	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
105351	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
105352	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
105353	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
105354	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
105355	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
105356	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
105357	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
105358	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
105359	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
105360	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
105361	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
105362	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
105363	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Operations Since Last Insp	468	
105364	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Min Tap Position	6L	
105365	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Max Tap Position	2R	
105366	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Current Tap Position	5L	
105367	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
105368	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Left Counter	34648	
105369	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Found Counter	34648	
105370	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	General Comments		
105371	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	General Comments		
105372	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
105373	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Follow-up Action Required?	n	
105374	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
105375	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
105376	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105377	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
105378	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
105379	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
105380	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
105381	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
105382	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
105383	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
105384	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
105385	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
105386	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
105387	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
105388	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
105389	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
105390	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
105391	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
105392	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
105393	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
105394	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
105395	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
105396	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
105397	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
105398	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
105399	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Leaks	None	
105400	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
105401	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
105402	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
105403	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
105404	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
105405	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
105406	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
105407	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
105408	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
105409	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
105410	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
105411	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	30.0	
105412	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	15.0	
105413	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	20.0	
105414	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
105415	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
105416	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
105417	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
105418	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105419	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Regulator As Left Counter	65018	
105420	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
105421	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
105422	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
105423	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105424	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105425	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
105426	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
105427	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
105428	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	General Comments		
105429	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105430	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
105431	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
105432	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105433	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
105434	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
105435	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	General Comments		
105436	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
105437	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
105438	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
105439	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
105440	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
105441	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
105442	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
105443	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
105444	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
105445	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
105446	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
105447	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
105448	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
105449	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
105450	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
105451	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
105452	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
105453	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
105454	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
105455	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	General Comments		
105456	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
105457	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
105458	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
105459	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
105460	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
105461	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
105462	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
105463	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
105464	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
105465	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Vegetation	None	
105466	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
105467	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
105468	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
105469	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
105470	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
105471	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
105472	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	161	
105473	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	161	
105474	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
105475	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105476	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
105477	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
105478	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
105479	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushings Connection/Risers	Good	
105480	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushing Condition	Good	
105481	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps C Ø	60.0	
105482	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps B Ø	65.0	
105483	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps A Ø	65.0	
105484	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
105485	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
105486	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
105487	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
105488	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
105489	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
105490	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
105491	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations	4	
105492	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
105493	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Trash?	y	
105494	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
105495	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
105496	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
105497	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
105498	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	11016.00	kw
105499	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
105500	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
105501	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
105502	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	*C
105503	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	25	*C
105504	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
105505	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
105506	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
105507	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
105508	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
105509	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
105510	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
105511	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
105512	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AF	315	
105513	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AL	315	
105514	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
105515	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
105516	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
105517	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
105518	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
105519	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	35	*C
105520	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
105521	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
105522	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
105523	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
105524	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
105525	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
105526	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
105527	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	General Comments		
105528	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105529	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18942	
105530	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
105531	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
105532	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
105533	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
105534	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
105535	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
105536	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
105537	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
105538	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
105539	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
105540	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
105541	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1312.00	kw
105542	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
105543	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
105544	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
105545	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
105546	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
105547	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
105548	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
105549	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
105550	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
105551	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
105552	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
105553	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	General Comments		
105554	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
105555	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105556	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105557	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
105558	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
105559	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
105560	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	General Comments		
105561	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
105562	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
105563	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
105564	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
105565	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
105566	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
105567	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
105568	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
105569	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
105570	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
105571	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	General Comments		
105572	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations This Read Vac	0	
105573	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105574	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Switching Operations	0	
105575	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Tank Paint Condition	Good	
105576	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
105577	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
105578	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
105579	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
105580	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
105581	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
105582	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
105583	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Unknown Operations	0	
105584	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
105585	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
105586	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
105587	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
105588	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
105589	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
105590	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
105591	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	General Comments		
105592	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
105593	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
105594	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
105595	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
105596	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
105597	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
105598	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
105599	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
105600	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
105601	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105602	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
105603	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6120	
105604	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	70	°C
105605	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105606	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105607	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105608	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105609	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
105610	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105611	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
105612	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
105613	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105614	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105615	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
105616	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	General Comments		
105617	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
105618	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Max Tap Position	15R	
105619	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
105620	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	9 Month Operations	20	
105621	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
105622	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
105623	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
105624	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps A Ø	100.0	
105625	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps B Ø	110.0	
105626	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps C Ø	100.0	
105627	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushing Condition	Good	
105628	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushings Connection/Risers	Good	
105629	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
105630	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
105631	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
105632	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Paint Condition	Good	
105633	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105634	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Equipment Properly Labeled?	y	
105635	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
105636	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
105637	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
105638	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations A Ø	0	
105639	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations B Ø	0	
105640	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations C Ø	0	
105641	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations Ground	0	
105642	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Follow-up Action Required?	n	
105643	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Follow-up Action Required?	n	
105644	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Foundation Condition	Good	
105645	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	General Comments		
105646	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	General Comments		
105647	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105648	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
105649	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
105650	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
105651	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105652	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105653	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
105654	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
105655	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
105656	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18545	
105657	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105658	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Leaks	None	
105659	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
105660	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
105661	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Unknown Operations	0	
105662	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Tank Paint Condition	Good	
105663	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
105664	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	General Comments		
105665	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
105666	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
105667	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
105668	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
105669	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
105670	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
105671	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
105672	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	LTC000397	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
105673	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Switching Operations	0	
105674	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105675	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations This Read Vac	0	
105676	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AL	328	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105677	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AF	328	
105678	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Moisture and Leak Free?	y	
105679	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105680	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
105681	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
105682	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105683	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
105684	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105685	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105686	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105687	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105688	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
105689	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
105690	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105691	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105692	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105693	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105694	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
105695	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
105696	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
105697	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
105698	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
105699	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
105700	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
105701	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8200	
105702	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
105703	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
105704	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
105705	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
105706	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
105707	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
105708	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
105709	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
105710	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
105711	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
105712	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
105713	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
105714	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
105715	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
105716	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
105717	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Follow-up Action Required?	n	
105718	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations Ground	0	
105719	11/3/2019 11:38	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
105720	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations C Ø	0	
105721	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
105722	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
105723	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
105724	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations B Ø	0	
105725	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations A Ø	0	
105726	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
105727	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
105728	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
105729	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
105730	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Leaks	None	
105731	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Moisture and Leak Free?	y	
105732	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Maintenance Operations	0	
105733	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Heaters (All) Functioning?	y	
105734	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Grounds in Place?	y	
105735	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
105736	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Regulator As Left Counter	14581	
105737	11/1/2019 8:24	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
105738	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Equipment Properly Labeled?	y	
105739	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Follow-up Action Required?	n	
105740	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Foundation Condition	Good	
105741	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	General Comments		
105742	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	General Comments		
105743	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Paint Condition	Good	
105744	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Grounds in Place?	y	
105745	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Heaters (All) Functioning?	y	
105746	11/1/2019 8:40	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Maintenance Operations	0	
105747	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
105748	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
105749	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
105750	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1976	
105751	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105752	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
105753	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
105754	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
105755	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
105756	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
105757	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
105758	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
105759	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
105760	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
105761	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
105762	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
105763	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
105764	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
105765	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
105766	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	CX0127	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
105767	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Follow-up Action Required?	n	
105768	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
105769	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
105770	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Foundation Condition	Good	
105771	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	General Comments		
105772	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	General Comments		
105773	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Grounds in Place?	y	
105774	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Maintenance Operations	0	
105775	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Moisture and Leak Free?	y	
105776	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AF	174	
105777	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.0	
105778	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AL	174	
105779	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations This Read Vac	0	
105780	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Switching Operations	0	
105781	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Tank Paint Condition	Good	
105782	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Unknown Operations	0	
105783	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
105784	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
105785	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
105786	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
105787	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
105788	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
105789	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
105790	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
105791	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
105792	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Follow-up Action Required?	n	
105793	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
105794	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	General Comments		
105795	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	General Comments		
105796	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Found Counter	103622	
105797	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Left Counter	103626	
105798	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
105799	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Current Tap Position	3L	
105800	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Max Tap Position	1R	
105801	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Min Tap Position	6L	
105802	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
105803	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Operations Since Last Insp	659	
105804	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
105805	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
105806	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
105807	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	2	
105808	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
105809	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
105810	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
105811	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	DX0024	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
105812	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
105813	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Equipment Properly Labeled?	y	
105814	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Paint Condition	Good	
105815	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
105816	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
105817	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
105818	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushings Connection/Risers	Good	
105819	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushing Condition	Good	
105820	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps C Ø	80.0	
105821	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Trash?	y	
105822	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
105823	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
105824	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
105825	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps B Ø	70.0	
105826	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps A Ø	65.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105827	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
105828	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
105829	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
105830	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	9 Month Operations	9	
105831	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105832	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
105833	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
105834	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
105835	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105836	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105837	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105838	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105839	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
105840	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105841	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
105842	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
105843	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
105844	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
105845	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105846	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	General Comments		
105847	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
105848	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
105849	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
105850	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
105851	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
105852	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
105853	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105854	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105855	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
105856	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
105857	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	510223	
105858	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
105859	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
105860	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0621	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
105861	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
105862	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
105863	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
105864	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Vegetation	None	
105865	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
105866	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
105867	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34891	
105868	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34891	
105869	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
105870	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
105871	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
105872	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
105873	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
105874	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
105875	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
105876	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
105877	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
105878	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
105879	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
105880	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
105881	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
105882	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
105883	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
105884	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
105885	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
105886	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
105887	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
105888	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
105889	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
105890	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	General Comments		
105891	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105892	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
105893	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
105894	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105895	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105896	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105897	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
105898	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
105899	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	General Comments		
105900	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
105901	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
105902	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
105903	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
105904	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
105905	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
105906	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
105907	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
105908	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
105909	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
105910	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
105911	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
105912	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
105913	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
105914	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
105915	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
105916	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
105917	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
105918	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
105919	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
105920	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
105921	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
105922	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
105923	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
105924	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
105925	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
105926	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
105927	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
105928	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
105929	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
105930	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
105931	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0620	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	54071	
105932	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Unknown Operations	0	
105933	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Tank Paint Condition	Good	
105934	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Switching Operations	0	
105935	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
105936	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations This Read Vac	0	
105937	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AL	217	
105938	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AF	217	
105939	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Moisture and Leak Free?	y	
105940	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Maintenance Operations	0	
105941	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Grounds in Place?	y	
105942	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	General Comments		
105943	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	General Comments		
105944	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Foundation Condition	Good	
105945	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Follow-up Action Required?	n	
105946	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Follow-up Action Required?	n	
105947	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations Ground	0	
105948	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations C Ø	0	
105949	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations B Ø	0	
105950	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations A Ø	0	
105951	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
105952	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
105953	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
105954	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
105955	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105956	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
105957	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Foundation Condition	Good	
105958	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
105959	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105960	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105961	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105962	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
105963	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
105964	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
105965	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
105966	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
105967	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
105968	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
105969	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
105970	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
105971	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
105972	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
105973	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
105974	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
105975	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
105976	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
105977	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
105978	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
105979	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Follow-up Action Required?	n	
105980	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
105981	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
105982	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
105983	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
105984	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
105985	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
105986	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	28	*C
105987	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	26	*C
105988	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
105989	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
105990	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
105991	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
105992	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
105993	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
105994	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
105995	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
105996	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	ST000122	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
105997	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
105998	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
105999	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
106000	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
106001	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
106002	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
106003	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
106004	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
106005	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
106006	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
106007	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
106008	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	YD000118	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	40	*F
106009	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	General Comments		
106010	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	General Comments		
106011	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Found Counter	219780	
106012	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Left Counter	219785	
106013	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
106014	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Current Tap Position	4L	
106015	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Max Tap Position	4L	
106016	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Min Tap Position	9L	
106017	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
106018	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	24	*C
106019	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Maintenance Operations	0	
106020	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Moisture and Leak Free?	y	
106021	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AF	164	
106022	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AL	164	
106023	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
106024	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
106025	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
106026	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
106027	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
106028	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
106029	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
106030	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
106031	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
106032	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106033	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106034	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
106035	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
106036	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106037	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
106038	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
106039	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106040	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
106041	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
106042	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
106043	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
106044	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0341	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
106045	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
106046	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
106047	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
106048	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
106049	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
106050	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	General Comments		
106051	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106052	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Switching Operations	0	
106053	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Tank Paint Condition	Good	
106054	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Unknown Operations	0	
106055	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	9 Month Operations	0	
106056	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106057	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106058	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106059	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	BreakerVacuum	Grounds in Place?	y
106060	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps A Ø	64.0	
106061	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps B Ø	60.0	
106062	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps C Ø	55.0	
106063	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushing Condition	Good	
106064	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	General Comments		
106065	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	General Comments		
106066	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Foundation Condition	Good	
106067	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Follow-up Action Required?	n	
106068	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Follow-up Action Required?	n	
106069	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations Ground	0	
106070	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations C Ø	0	
106071	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations B Ø	0	
106072	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations A Ø	0	
106073	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106074	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106075	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106076	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106077	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106078	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106079	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106080	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106081	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
106082	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
106083	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
106084	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106085	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushing Condition	Good	
106086	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps C Ø	211.0	
106087	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps B Ø	255.0	
106088	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps A Ø	205.0	
106089	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106090	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106091	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106092	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	9 Month Operations	0	
106093	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106094	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106095	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106096	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106097	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
106098	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
106099	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
106100	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
106101	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
106102	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
106103	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
106104	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
106105	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
106106	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
106107	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
106108	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
106109	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	403662	
106110	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	403662	
106111	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
106112	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
106113	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
106114	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
106115	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
106116	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	722	
106117	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
106118	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
106119	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
106120	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106121	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
106122	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
106123	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106124	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	General Comments		
106125	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	General Comments		
106126	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
106127	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
106128	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
106129	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	27.36	kw
106130	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
106131	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
106132	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
106133	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
106134	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
106135	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
106136	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
106137	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
106138	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
106139	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106140	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
106141	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0228	
106142	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106143	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106144	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106145	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106146	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations A Ø	0	
106147	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations B Ø	0	
106148	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations C Ø	0	
106149	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations Ground	0	
106150	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Follow-up Action Required?	n	
106151	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	24	°C
106152	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Operations Since Last Insp	695	
106153	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
106154	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
106155	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
106156	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
106157	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.2	
106158	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.6	
106159	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.3	
106160	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
106161	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
106162	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
106163	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
106164	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
106165	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	General Comments		
106166	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
106167	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Operations Counter	271	
106168	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
106169	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
106170	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
106171	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106172	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106173	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushing Condition	Good	
106174	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps C Ø	37.0	
106175	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps B Ø	32.0	
106176	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps A Ø	40.0	
106177	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106178	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106179	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106180	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	9 Month Operations	0	
106181	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Unknown Operations	0	
106182	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Tank Paint Condition	Good	
106183	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Switching Operations	0	
106184	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations This Read Vac	0	
106185	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AL	152	
106186	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AF	152	
106187	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Moisture and Leak Free?	y	
106188	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Maintenance Operations	0	
106189	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Grounds in Place?	y	
106190	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	General Comments		
106191	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	General Comments		
106192	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Foundation Condition	Good	
106193	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Follow-up Action Required?	n	
106194	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
106195	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	75699	
106196	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	75701	
106197	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
106198	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Follow-up Action Required?	n	
106199	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations Ground	0	
106200	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
106201	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106202	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8R	
106203	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
106204	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8R	
106205	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
106206	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations C Ø	0	
106207	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations B Ø	0	
106208	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations A Ø	0	
106209	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106210	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106211	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106212	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106213	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106214	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106215	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106216	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106217	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106218	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
106219	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
106220	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106221	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
106222	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106223	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106224	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106225	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106226	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
106227	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
106228	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
106229	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
106230	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
106231	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
106232	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
106233	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
106234	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
106235	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106236	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
106237	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
106238	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
106239	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
106240	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
106241	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	18	*C
106242	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	20	*C
106243	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
106244	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
106245	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
106246	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
106247	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
106248	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
106249	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106250	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
106251	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
106252	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106253	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
106254	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
106255	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106256	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106257	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
106258	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0340	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
106259	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
106260	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	General Comments		
106261	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
106262	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
106263	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
106264	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
106265	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
106266	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
106267	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Unknown Operations	0	
106268	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Tank Paint Condition	Good	
106269	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Switching Operations	0	
106270	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
106271	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations This Read Vac	0	
106272	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AL	203	
106273	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AF	203	
106274	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Moisture and Leak Free?	y	
106275	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Maintenance Operations	0	
106276	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106277	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	General Comments		
106278	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	General Comments		
106279	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Foundation Condition	Good	
106280	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Follow-up Action Required?	n	
106281	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Follow-up Action Required?	n	
106282	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.0450	
106283	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
106284	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106285	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Switching Operations	0	
106286	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Tank Paint Condition	Good	
106287	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Unknown Operations	0	
106288	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
106289	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
106290	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
106291	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
106292	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
106293	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
106294	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
106295	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
106296	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
106297	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
106298	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
106299	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
106300	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
106301	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
106302	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
106303	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
106304	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	103634	
106305	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
106306	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
106307	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
106308	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
106309	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
106310	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
106311	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
106312	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
106313	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
106314	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
106315	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
106316	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
106317	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
106318	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
106319	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
106320	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
106321	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
106322	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
106323	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
106324	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
106325	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
106326	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106327	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
106328	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106329	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
106330	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
106331	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
106332	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
106333	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
106334	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
106335	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
106336	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
106337	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106338	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106339	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106340	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
106341	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
106342	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
106343	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
106344	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
106345	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
106346	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
106347	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
106348	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
106349	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
106350	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
106351	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106352	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
106353	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
106354	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
106355	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps B Ø	33.0	
106356	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps A Ø	69.0	
106357	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106358	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106359	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106360	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	9 Month Operations	1	
106361	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
106362	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
106363	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
106364	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
106365	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
106366	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
106367	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	154020	
106368	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Operations Counter	117	
106369	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
106370	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	General Comments		
106371	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
106372	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
106373	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
106374	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
106375	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
106376	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
106377	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
106378	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
106379	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
106380	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
106381	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
106382	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
106383	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
106384	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
106385	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
106386	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
106387	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
106388	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps C Ø	98.0	
106389	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps B Ø	92.0	
106390	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps A Ø	88.0	
106391	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106392	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
106393	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106394	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106395	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106396	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106397	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
106398	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Unknown Operations	0	
106399	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	0	
106400	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	0	
106401	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	11	
106402	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	15.36	%
106403	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	17.2	%
106404	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	15.97	%
106405	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	45.0	
106406	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	45.0	
106407	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	44.0	
106408	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106409	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106410	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106411	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
106412	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	0	
106413	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
106414	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
106415	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
106416	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments		
106417	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
106418	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	85	
106419	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	85	
106420	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
106421	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
106422	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
106423	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
106424	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
106425	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
106426	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	45	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106427	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
106428	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
106429	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	27.00	kw
106430	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
106431	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
106432	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
106433	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
106434	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106435	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations Ground	0	
106436	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations C Ø	0	
106437	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations B Ø	0	
106438	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations A Ø	0	
106439	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106440	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106441	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106442	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106443	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106444	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106445	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106446	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106447	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106448	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushing Condition	Good	
106449	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps C Ø	35.0	
106450	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
106451	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
106452	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
106453	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1301	
106454	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1301	
106455	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
106456	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
106457	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
106458	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
106459	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
106460	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
106461	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
106462	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
106463	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106464	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
106465	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
106466	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
106467	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
106468	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
106469	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106470	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106471	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
106472	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	C0161	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
106473	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
106474	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	General Comments		
106475	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
106476	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
106477	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
106478	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
106479	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
106480	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
106481	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
106482	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
106483	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	180.0	
106484	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	100.0	
106485	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	100.0	
106486	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
106487	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
106488	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
106489	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
106490	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments		
106491	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Maintenance Operations	0	
106492	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
106493	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
106494	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
106495	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	401	
106496	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	401	
106497	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
106498	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
106499	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	9 Month Operations	12	
106500	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106501	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
106502	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106503	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps A Ø	170.0	
106504	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps B Ø	120.0	
106505	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps C Ø	120.0	
106506	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushing Condition	Good	
106507	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106508	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106509	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106510	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106511	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106512	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106513	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106514	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106515	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106516	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations A Ø	0	
106517	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations B Ø	0	
106518	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations C Ø	0	
106519	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations Ground	0	
106520	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Follow-up Action Required?	n	
106521	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Follow-up Action Required?	n	
106522	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Foundation Condition	Good	
106523	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	General Comments		
106524	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	General Comments		
106525	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Grounds in Place?	y	
106526	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Maintenance Operations	0	
106527	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Moisture and Leak Free?	y	
106528	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AF	42	
106529	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AL	42	
106530	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations This Read Vac	0	
106531	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
106532	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Switching Operations	0	
106533	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Tank Paint Condition	Good	
106534	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
106535	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AF	70	
106536	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AL	70	
106537	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations This Read Vac	0	
106538	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	0	
106539	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Unknown Operations	0	
106540	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
106541	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Vegetation	None	
106542	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
106543	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	General Comments		
106544	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
106545	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
106546	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
106547	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
106548	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
106549	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
106550	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	General Comments		
106551	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
106552	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
106553	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
106554	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
106555	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
106556	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	220.0	
106557	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	220.0	
106558	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	100.0	
106559	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
106560	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
106561	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
106562	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	3	
106563	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
106564	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Present	28	°C
106565	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Max	32	°C
106566	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Reading	.4362	
106567	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
106568	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106569	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
106570	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
106571	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
106572	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
106573	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
106574	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
106575	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
106576	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
106577	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Present	24	°C
106578	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Max	35	°C
106579	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
106580	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
106581	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	LTC Totalizer Reading	7851.60	kw
106582	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
106583	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	General Comments		
106584	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	General Comments		
106585	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106586	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
106587	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Leaks	None	
106588	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
106589	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
106590	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82879	
106591	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
106592	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
106593	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
106594	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
106595	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
106596	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
106597	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Follow-up Action Required?	n	
106598	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106599	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
106600	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
106601	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106602	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
106603	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
106604	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
106605	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
106606	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106607	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
106608	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
106609	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
106610	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	9 Month Operations	1	
106611	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty A Ph V	3.69	%
106612	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty B Ph V	5.53	%
106613	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty C Ph V	4.3	%
106614	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps A Ø	42.0	
106615	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps B Ø	43.0	
106616	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps C Ø	43.0	
106617	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106618	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106619	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106620	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
106621	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
106622	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
106623	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
106624	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	0	
106625	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations This Read Vac	0	
106626	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
106627	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Switching Operations	0	
106628	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Tank Paint Condition	Good	
106629	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Unknown Operations	0	
106630	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	9 Month Operations	0	
106631	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106632	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106633	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106634	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps A Ø	300.0	
106635	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps B Ø	350.0	
106636	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps C Ø	305.0	
106637	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushing Condition	Good	
106638	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106639	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106640	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106641	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106642	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106643	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106644	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
106645	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Fence is rusted.	
106646	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
106647	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
106648	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106649	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106650	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106651	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
106652	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations B Ø	0	
106653	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations C Ø	0	
106654	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations Ground	0	
106655	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Follow-up Action Required?	n	
106656	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
106657	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
106658	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
106659	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
106660	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
106661	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
106662	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
106663	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
106664	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
106665	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
106666	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
106667	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
106668	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
106669	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	FE000117	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
106670	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
106671	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Trash?	y	
106672	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
106673	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Follow-up Action Required?	n	
106674	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Foundation Condition	Good	
106675	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	General Comments		
106676	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	General Comments		
106677	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Grounds in Place?	y	
106678	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Maintenance Operations	0	
106679	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
106680	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AF	136	
106681	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AL	136	
106682	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
106683	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Leaks	None	
106684	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
106685	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
106686	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Regulator As Left Counter	164856	
106687	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
106688	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
106689	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations This Read Vac	0	
106690	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
106691	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
106692	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
106693	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	General Comments	vegetation needs cut back away from fence	
106694	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	9 Month Operations	13	
106695	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
106696	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
106697	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
106698	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
106699	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Unknown Operations	0	
106700	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
106701	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps A Ø	120.0	
106702	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps B Ø	120.0	
106703	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps C Ø	120.0	
106704	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushing Condition	Good	
106705	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushings Connection/Risers	Good	
106706	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
106707	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
106708	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
106709	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
106710	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
106711	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
106712	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
106713	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
106714	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
106715	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
106716	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
106717	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106718	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
106719	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106720	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106721	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106722	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106723	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
106724	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
106725	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
106726	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106727	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	FE000054	Fence	380-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
106728	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
106729	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
106730	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
106731	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
106732	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Paint Condition	Good	
106733	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Equipment Properly Labeled?	y	
106734	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
106735	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
106736	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
106737	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations A Ø	0	
106738	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations B Ø	0	
106739	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations C Ø	0	
106740	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations Ground	0	
106741	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Follow-up Action Required?	n	
106742	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Follow-up Action Required?	n	
106743	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Foundation Condition	Good	
106744	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	General Comments		
106745	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	General Comments		
106746	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Grounds in Place?	y	
106747	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Maintenance Operations	0	
106748	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Moisture and Leak Free?	y	
106749	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AF	973	
106750	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AL	973	
106751	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
106752	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
106753	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	100.0	
106754	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	100.0	
106755	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	70.0	
106756	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
106757	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
106758	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
106759	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
106760	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Reading	.6222	
106761	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
106762	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106763	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
106764	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
106765	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
106766	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
106767	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
106768	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Present	15	*C
106769	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Max	40	*C
106770	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
106771	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
106772	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	LTC Totalizer Reading	2239.92	kw
106773	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
106774	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	General Comments		
106775	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	General Comments		
106776	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106777	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
106778	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Follow-up Action Required?	n	
106779	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106780	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
106781	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
106782	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106783	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
106784	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
106785	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
106786	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
106787	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106788	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
106789	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
106790	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
106791	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
106792	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
106793	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
106794	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
106795	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
106796	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
106797	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
106798	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
106799	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
106800	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
106801	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106802	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
106803	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
106804	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
106805	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
106806	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
106807	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
106808	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
106809	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
106810	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
106811	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
106812	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
106813	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	General Comments		
106814	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
106815	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
106816	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
106817	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
106818	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
106819	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
106820	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
106821	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
106822	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
106823	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
106824	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Evidence of Insects	None	
106825	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
106826	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
106827	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Swept?	y	
106828	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
106829	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	All Connections OK?	y	
106830	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	Follow-up Action Required?	n	
106831	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	General Comments		
106832	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	LTC Operation Checked?	y	
106833	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
106834	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
106835	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
106836	11/1/2019 11:04	Distribution	Shelbyville Quarterly Inspection	LTC000133	LTCControl	198-5	LTC Control Insp	VRR Time Delay	30	Seconds
106837	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
106838	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
106839	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
106840	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
106841	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
106842	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
106843	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
106844	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
106845	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
106846	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	324	
106847	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	324	
106848	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
106849	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
106850	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
106851	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
106852	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
106853	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
106854	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	General Comments	2 insulators on high side fuses has a chipped skirt.	
106855	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
106856	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
106857	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
106858	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
106859	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
106860	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
106861	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
106862	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
106863	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
106864	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Vegetation	None	
106865	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
106866	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	General Comments		
106867	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
106868	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
106869	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
106870	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
106871	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
106872	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Trash?	y	
106873	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
106874	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
106875	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
106876	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
106877	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
106878	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
106879	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
106880	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	27376	
106881	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	1246.0	volts
106882	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
106883	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
106884	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
106885	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
106886	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
106887	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
106888	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
106889	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
106890	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
106891	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
106892	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
106893	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106894	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
106895	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106896	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106897	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106898	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106899	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
106900	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
106901	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
106902	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
106903	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.9078	
106904	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
106905	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
106906	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
106907	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
106908	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
106909	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
106910	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
106911	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
106912	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
106913	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
106914	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
106915	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
106916	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
106917	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
106918	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
106919	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	General Comments		
106920	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
106921	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
106922	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
106923	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
106924	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
106925	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
106926	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
106927	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
106928	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
106929	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
106930	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
106931	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
106932	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
106933	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
106934	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
106935	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
106936	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
106937	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
106938	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
106939	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
106940	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
106941	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
106942	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Follow-up Action Required?	n	
106943	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
106944	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	General Comments		
106945	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	General Comments		
106946	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
106947	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
106948	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
106949	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
106950	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
106951	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Found Counter	149856	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
106952	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Left Counter	149860	
106953	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
106954	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Current Tap Position	6L	
106955	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Max Tap Position	16R	
106956	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Min Tap Position	12L	
106957	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Operations Since Last Insp	1021	
106958	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
106959	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
106960	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
106961	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
106962	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
106963	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
106964	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
106965	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
106966	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
106967	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
106968	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
106969	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
106970	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
106971	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
106972	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	General Comments		
106973	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
106974	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Trash Emptied?	y	
106975	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
106976	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	434	
106977	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps A Ø	.7	
106978	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
106979	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps C Ø	.7	
106980	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	405	
106981	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
106982	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
106983	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
106984	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
106985	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
106986	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
106987	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
106988	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
106989	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
106990	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
106991	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
106992	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
106993	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
106994	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
106995	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
106996	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
106997	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
106998	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
106999	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
107000	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
107001	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
107002	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
107003	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
107004	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
107005	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
107006	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
107007	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
107008	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
107009	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	498493	
107010	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
107011	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
107012	11/1/2019 13:33	Distribution	Black Creek 2 Quarterly Inspection	R0622	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
107013	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
107014	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
107015	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
107016	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
107017	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
107018	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
107019	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
107020	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
107021	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
107022	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	185	
107023	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
107024	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
107025	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
107026	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107027	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
107028	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
107029	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
107030	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
107031	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
107032	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
107033	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2178.72	kw
107034	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
107035	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
107036	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	80	*C
107037	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	*C
107038	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107039	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107040	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107041	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
107042	11/1/2019 14:00	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107043	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
107044	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Regulator As Left Counter	368459	
107045	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
107046	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
107047	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
107048	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
107049	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
107050	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
107051	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
107052	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
107053	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	General Comments		
107054	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
107055	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
107056	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
107057	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushing Condition	Good	
107058	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps C Ø	320.0	
107059	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps B Ø	340.0	
107060	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps A Ø	320.0	
107061	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
107062	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
107063	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
107064	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	9 Month Operations	1	
107065	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
107066	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
107067	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
107068	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
107069	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
107070	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
107071	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
107072	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Reading	.9402	
107073	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
107074	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107075	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107076	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
107077	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	*C
107078	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	*C
107079	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107080	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
107081	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107082	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
107083	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
107084	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
107085	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
107086	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107087	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
107088	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
107089	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	*C
107090	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
107091	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Max	45	*C
107092	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Present	20	*C
107093	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
107094	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
107095	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
107096	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
107097	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
107098	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
107099	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
107100	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107101	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107102	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
107103	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Unknown Operations	0	
107104	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Tank Paint Condition	Good	
107105	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Switching Operations	0	
107106	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107107	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations This Read Vac	0	
107108	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AL	123	
107109	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AF	123	
107110	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
107111	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Maintenance Operations	0	
107112	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Grounds in Place?	y	
107113	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	General Comments		
107114	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	General Comments		
107115	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Foundation Condition	Good	
107116	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Follow-up Action Required?	n	
107117	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Follow-up Action Required?	n	
107118	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations Ground	0	
107119	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations C Ø	0	
107120	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations B Ø	0	
107121	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations A Ø	0	
107122	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107123	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
107124	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Leaks	None	
107125	11/1/2019 13:29	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
107126	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
107127	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	27.5	VDC
107128	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	27.5	VDC
107129	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
107130	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
107131	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
107132	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
107133	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107134	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107135	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107136	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107137	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107138	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107139	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107140	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
107141	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
107142	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
107143	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
107144	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
107145	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
107146	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107147	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
107148	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
107149	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107150	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
107151	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
107152	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
107153	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC000810	LTCControl	380-1	LTC Control Insp	VRR Time Delay	30	Seconds
107154	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
107155	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
107156	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107157	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
107158	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107159	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107160	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107161	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107162	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107163	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
107164	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
107165	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107166	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Follow-up Action Required?	n	
107167	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
107168	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107169	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	General Comments		
107170	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	General Comments		
107171	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
107172	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	LTC Totalizer Reading	9025.92	kw
107173	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107174	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
107175	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Max	31	°C
107176	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
107177	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107178	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
107179	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
107180	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
107181	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
107182	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
107183	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	All Connections OK?	y	
107184	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	Follow-up Action Required?	n	
107185	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	General Comments		
107186	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	LTC Operation Checked?	y	
107187	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
107188	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107189	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
107190	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107191	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
107192	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
107193	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107194	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
107195	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
107196	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
107197	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
107198	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107199	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
107200	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107201	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Present	31	*C
107202	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
107203	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
107204	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107205	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107206	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107207	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107208	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
107209	11/1/2019 13:08	Distribution	Bear Branch Quarterly Inspection	LTC0000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
107210	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
107211	11/1/2019 13:29	Distribution	Esserville Quarterly Inspection	LTC0000078	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
107212	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
107213	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107214	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107215	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107216	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107217	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107218	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
107219	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
107220	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107221	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
107222	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
107223	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107224	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	0	
107225	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
107226	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
107227	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
107228	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
107229	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
107230	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	50.0	
107231	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	100.0	
107232	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	50.0	
107233	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
107234	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107235	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107236	11/1/2019 12:39	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107237	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
107238	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good		
107239	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good		
107240	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
107241	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
107242	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
107243	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
107244	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
107245	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
107246	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00		
107247	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
107248	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y		
107249	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	General Comments			
107250	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
107251	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly 'B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
107327	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107328	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107329	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
107330	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107331	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107332	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107333	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107334	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107335	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107336	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107337	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107338	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107339	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107340	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107341	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107342	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107343	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1101	
107344	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107345	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	On TFR with 1457.	
107346	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107347	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107348	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107349	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107350	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	5	
107351	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	74	
107352	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
107353	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107354	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
107355	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107356	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107357	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107358	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
107359	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107360	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
107361	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107362	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107363	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107364	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107365	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107366	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	354	
107367	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	74	
107368	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
107369	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
107370	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
107371	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
107372	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
107373	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
107374	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	399	
107375	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	399	
107376	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	0	
107377	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
107378	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
107379	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
107380	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
107381	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	70.0	
107382	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	80.0	
107383	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	60.0	
107384	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	25.05	%
107385	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	27.69	%
107386	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	17.14	%
107387	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	69.0	
107388	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	68.0	
107389	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	69.0	
107390	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107391	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107392	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107393	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107394	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107395	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107396	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
107397	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.56	%
107398	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.12	%
107399	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.56	%
107400	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107401	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107402	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107403	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107404	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107405	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107406	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107407	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107408	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
107409	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107410	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99996	
107411	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99996	
107412	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
107413	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
107414	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
107415	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107416	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107417	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
107418	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
107419	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
107420	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
107421	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	517	
107422	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107423	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	517	
107424	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107425	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
107426	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107427	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107428	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107429	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107430	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107431	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107432	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107433	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107434	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107435	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107436	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107437	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
107438	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
107439	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
107440	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
107441	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	0	
107442	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	1	
107443	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	658	
107444	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	658	
107445	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	47	
107446	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	0	
107447	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments	B phase IOC	
107448	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Follow-up Action Required?	n	
107449	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Fault Operations	1	
107450	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	100.0	
107451	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	100.0	
107452	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	100.0	
107453	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	75.16	%
107454	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	80.43	%
107455	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	77.80	%
107456	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
107457	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	90.0	
107458	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	90.0	
107459	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	100.0	
107460	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
107461	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
107462	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
107463	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	
107464	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	12	
107465	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	676	
107466	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	676	
107467	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	0	
107468	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	0	
107469	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
107470	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	75.0	
107471	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	70.0	
107472	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	70.0	
107473	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107474	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	30.0	
107475	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	30.0	
107476	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	35.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
107477	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
107478	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
107479	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
107480	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
107481	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
107482	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
107483	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	2	
107484	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	776	
107485	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	776	
107486	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
107487	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
107488	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
107489	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107490	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107491	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107492	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107493	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107494	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
107495	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
107496	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
107497	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
107498	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
107499	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
107500	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
107501	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107502	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
107503	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107504	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107505	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107506	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107507	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107508	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
107509	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107510	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
107511	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107512	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107513	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
107514	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Pressure	6	psi
107515	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Tank Paint Condition	Good	
107516	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
107517	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	10.40	%
107518	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.40	%
107519	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	General Comments		
107520	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
107521	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
107522	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	410	
107523	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
107524	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13L	
107525	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
107526	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	245	
107527	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	100245	
107528	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments	This is correct VC. VC cycled through.	
107529	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
107530	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
107531	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
107532	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
107533	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
107534	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
107535	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	47.47	%
107536	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	48.79	%
107537	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	35.60	%
107538	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	160.0	
107539	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	166.0	
107540	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	156.0	
107541	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107542	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107543	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107544	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107545	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107546	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107547	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107548	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107549	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	on TFR with 1456	
107550	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107551	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	727	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107552	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	727	
107553	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
107554	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
107555	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
107556	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107557	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
107558	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
107559	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
107560	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1766	
107561	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1766	
107562	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107563	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107564	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107565	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107566	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107567	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107568	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
107569	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107570	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
107571	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107572	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107573	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
107574	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.67	%
107575	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107576	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107577	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107578	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107579	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107580	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107581	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107582	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107583	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
107584	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	12.0	
107585	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	11.0	
107586	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
107587	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
107588	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107589	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
107590	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
107591	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	104	
107592	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	104	
107593	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
107594	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
107595	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
107596	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	No amp meter	
107597	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
107598	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
107599	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107600	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107601	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107602	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107603	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107604	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
107605	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
107606	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	General Comments	y	
107607	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
107608	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Follow-up Action Required?	n	
107609	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
107610	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
107611	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107612	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
107613	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Ambient Temperature	43	*F
107614	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107615	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
107616	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107617	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107618	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107619	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	350.0	
107620	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	450.0	
107621	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	350.0	
107622	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
107623	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
107624	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107625	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107626	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
107627	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107628	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
107629	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
107630	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107631	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107632	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
107633	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107634	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107635	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107636	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107637	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107638	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
107639	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
107640	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107641	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107642	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107643	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107644	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
107645	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
107646	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
107647	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
107648	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107649	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107650	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107651	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107652	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107653	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107654	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
107655	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107656	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
107657	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107658	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107659	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107660	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
107661	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107662	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
107663	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
107664	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107665	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	36.00	
107666	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
107667	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
107668	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107669	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
107670	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
107671	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1416	
107672	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1416	
107673	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	1	
107674	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107675	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107676	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107677	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107678	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0291	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107679	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107680	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107681	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107682	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107683	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
107684	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
107685	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
107686	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107687	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107688	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
107689	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
107690	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
107691	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
107692	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
107693	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
107694	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107695	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
107696	3/11/2019 12:09	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
107697	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107698	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107699	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107700	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107701	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
107702	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107703	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0254	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
107704	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
107705	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
107706	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
107707	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
107708	10/31/2019 13:27	Distribution	Danville Substation Department Quarterly	B0290	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107709	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
107710	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107711	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107712	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
107713	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
107714	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
107715	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
107716	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
107717	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
107718	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
107719	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
107720	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
107721	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
107722	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	9 Month Operations	1	
107723	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
107724	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
107725	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
107726	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
107727	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	235	
107728	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	235	
107729	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
107730	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
107731	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		
107732	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
107733	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
107734	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
107735	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107736	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107737	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107738	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107739	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Unknown Operations	0	
107740	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Switching Operations	2	
107741	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A Ø	0	
107742	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B Ø	0	
107743	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C Ø	0	
107744	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
107745	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107746	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations A Ø	0	
107747	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations B Ø	0	
107748	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations C Ø	0	
107749	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations Ground	0	
107750	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Follow-up Action Required?	n	
107751	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Follow-up Action Required?	n	
107752	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	General Comments		
107753	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107754	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations This Read Vac	2	
107755	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AL	184	
107756	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AF	184	
107757	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
107758	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Moisture and Leak Free?	y	
107759	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Maintenance Operations	0	
107760	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Heaters (All) Functioning?	y	
107761	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Grounds in Place?	y	
107762	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	General Comments		
107763	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
107764	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations	2	
107765	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
107766	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
107767	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
107768	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107769	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107770	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
107771	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds
107772	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
107773	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107774	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107775	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107776	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107777	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
107778	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107779	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
107780	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107781	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107782	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations A Ø	0	
107783	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations B Ø	0	
107784	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations C Ø	0	
107785	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
107786	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
107787	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	
107788	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations Ground	0	
107789	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
107790	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Follow-up Action Required?	n	
107791	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	General Comments		
107792	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	General Comments		
107793	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
107794	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
107795	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107796	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107797	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
107798	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
107799	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	175.0	
107800	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	160.0	
107801	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
107802	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
107803	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Foundation Condition	Good	
107804	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
107805	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Unknown Operations	0	
107806	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Switching Operations	0	
107807	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107808	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations This Read Vac	0	
107809	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AL	134	
107810	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AF	134	
107811	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
107812	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Maintenance Operations	0	
107813	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	113	
107814	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
107815	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
107816	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
107817	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	1083	
107818	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	°C
107819	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
107820	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
107821	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
107822	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	14L	
107823	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	2L	
107824	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	8L	
107825	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
107826	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	5270	
107827	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	5270	
107828	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
107829	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
107830	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
107831	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107832	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107833	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107834	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107835	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107836	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107837	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107838	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Unknown Operations	0	
107839	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Switching Operations	2	
107840	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107841	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	113	
107842	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations This Read Vac	0	
107843	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations This Read Vac	2	
107844	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AL	247	
107845	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps C Ø	0.0	
107846	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps B Ø	0.0	
107847	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps A Ø	0.0	
107848	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107849	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	0	
107850	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
107851	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107852	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
107853	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AF	247	
107854	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Moisture and Leak Free?	y	
107855	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Maintenance Operations	0	
107856	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
107857	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	79	
107858	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	79	
107859	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
107860	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
107861	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
107862	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
107863	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
107864	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
107865	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
107866	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
107867	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Operations Since Last Insp	1090	
107868	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
107869	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
107870	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Min Tap Position	14L	
107871	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107872	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107873	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107874	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107875	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107876	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107877	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107878	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Max Tap Position	2L	
107879	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
107880	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
107881	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	7	
107882	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Current Tap Position	8L	
107883	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
107884	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Left Counter	19665	
107885	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Unknown Operations	0	
107886	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Switching Operations	3	
107887	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107888	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations This Read Vac	3	
107889	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AL	198	
107890	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AF	198	
107891	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Moisture and Leak Free?	y	
107892	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Found Counter	19665	
107893	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	General Comments		
107894	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	General Comments		
107895	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
107896	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Follow-up Action Required?	n	
107897	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
107898	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
107899	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Present	30	°C
107900	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Max	40	°C
107901	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Maintenance Operations	0	
107902	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Heaters (All) Functioning?	y	
107903	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Grounds in Place?	y	
107904	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	General Comments		
107905	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	General Comments		
107906	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Follow-up Action Required?	n	
107907	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Follow-up Action Required?	n	
107908	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations Ground	0	
107909	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations C Ø	0	
107910	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations B Ø	0	
107911	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations A Ø	0	
107912	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107913	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107914	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107915	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107916	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107917	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107918	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107919	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107920	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps C Ø	170.0	
107921	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	General Comments		
107922	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
107923	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
107924	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
107925	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
107926	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
107927	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
107928	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps A Ø	0.0	
107929	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps B Ø	0.0	
107930	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps C Ø	0.0	
107931	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
107932	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Unknown Operations	0	
107933	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
107934	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
107935	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
107936	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
107937	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
107938	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
107939	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107940	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
107941	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
107942	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
107943	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
107944	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
107945	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
107946	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
107947	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
107948	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
107949	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
107950	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
107951	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	General Comments		
107952	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Follow-up Action Required?	n	
107953	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Follow-up Action Required?	n	
107954	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations Ground	0	
107955	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations C Ø	0	
107956	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations B Ø	0	
107957	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations A Ø	0	
107958	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
107959	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
107960	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	0	
107961	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	0	
107962	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations This Read Vac	0	
107963	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107964	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
107965	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
107966	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
107967	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Switching Operations	0	
107968	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
107969	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations This Read Vac	0	
107970	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AL	216	
107971	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AF	216	
107972	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Moisture and Leak Free?	y	
107973	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Maintenance Operations	0	
107974	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Heaters (All) Functioning?	y	
107975	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Grounds in Place?	y	
107976	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
107977	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC0000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
107978	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
107979	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
107980	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
107981	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaWatt Demand Meter Max	8.67	MegaWatts
107982	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaVar Demand Meter Max	2.81	MegaVars
107983	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	LTC Totalizer Reading	.87	kw
107984	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Kwh Reading	0	KwH
107985	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
107986	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
107987	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
107988	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
107989	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
107990	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
107991	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
107992	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
107993	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
107994	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
107995	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
107996	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
107997	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
107998	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	90.0	
107999	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	90.0	
108000	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
108001	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108002	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
108003	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
108004	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
108005	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
108006	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
108007	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
108008	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
108009	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
108010	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
108011	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108012	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108013	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations	0	
108014	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
108015	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
108016	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
108017	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
108018	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
108019	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
108020	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
108021	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
108022	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
108023	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
108024	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
108025	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
108026	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	90.0	
108027	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108028	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108029	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108030	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps C Ø	0.0	
108031	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps B Ø	0.0	
108032	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps A Ø	0.0	
108033	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108034	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108035	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108036	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations This Read Vac	7	
108037	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps B Ø	180.0	
108038	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Reading	.8666	
108039	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Multiplier	1	
108040	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108041	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	General Comments		
108042	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	General Comments		
108043	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Follow-up Action Required?	n	
108044	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Follow-up Action Required?	n	
108045	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations Ground	0	
108046	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps A Ø	185.0	
108047	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108048	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108049	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108050	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations	3	
108051	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps C Ø	365.0	
108052	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps B Ø	415.0	
108053	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps A Ø	380.0	
108054	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108055	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations C Ø	0	
108056	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations B Ø	0	
108057	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations A Ø	0	
108058	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108059	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108060	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108061	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
108062	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108063	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108064	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
108065	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
108066	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
108067	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Present	30	*C
108068	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108069	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108070	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108071	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108072	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
108073	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
108074	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
108075	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
108076	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
108077	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
108078	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108079	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108080	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
108081	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
108082	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	1	
108083	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
108084	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
108085	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
108086	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
108087	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
108088	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	General Comments		
108089	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
108090	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
108091	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
108092	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
108093	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Max	40	°C
108094	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
108095	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Foundation Condition	Good	
108096	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
108097	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	General Comments		
108098	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
108099	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
108100	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
108101	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
108102	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
108103	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
108104	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
108105	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
108106	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
108107	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
108108	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
108109	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
108110	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
108111	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
108112	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
108113	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
108114	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
108115	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
108116	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
108117	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
108118	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
108119	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
108120	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
108121	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
108122	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
108123	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
108124	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
108125	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
108126	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
108127	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
108128	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
108129	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
108130	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
108131	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
108132	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
108133	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
108134	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
108135	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
108136	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
108137	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
108138	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
108139	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
108140	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
108141	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
108142	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
108143	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
108144	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
108145	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
108146	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108147	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
108148	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
108149	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108150	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108151	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
108152	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.7820	
108153	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
108154	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
108155	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
108156	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
108157	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
108158	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
108159	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
108160	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
108161	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
108162	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
108163	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
108164	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
108165	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
108166	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
108167	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
108168	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
108169	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
108170	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	General Comments		
108171	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
108172	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
108173	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
108174	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
108175	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
108176	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
108177	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
108178	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Trash?	y	
108179	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
108180	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
108181	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
108182	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
108183	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
108184	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
108185	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	General Comments		
108186	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
108187	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
108188	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
108189	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Vegetation	None	Need size info and qty
108190	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
108191	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
108192	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
108193	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
108194	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
108195	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
108196	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
108197	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108198	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	5	
108199	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
108200	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
108201	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
108202	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
108203	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
108204	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
108205	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
108206	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Unknown Operations	0	
108207	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Switching Operations	0	
108208	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108209	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations This Read Vac	0	
108210	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AL	209	
108211	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AF	209	
108212	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
108213	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Maintenance Operations	0	
108214	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108215	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Grounds in Place?	y	
108216	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	General Comments		
108217	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	General Comments		
108218	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Follow-up Action Required?	n	
108219	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Follow-up Action Required?	n	
108220	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations Ground	0	
108221	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations C Ø	0	
108222	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	All Connections OK?	y	
108223	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	Follow-up Action Required?	n	
108224	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	General Comments		
108225	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	LTC Operation Checked?	y	
108226	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108227	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
108228	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
108229	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
108230	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Time Delay	30	Seconds
108231	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations	0	
108232	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108233	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108234	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108235	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps A Ø	215.0	
108236	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps B Ø	240.0	
108237	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps C Ø	200.0	
108238	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108239	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108240	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108241	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108242	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108243	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108244	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108245	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108246	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations A Ø	0	
108247	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations B Ø	0	
108248	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
108249	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
108250	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
108251	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
108252	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
108253	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
108254	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
108255	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
108256	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
108257	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	3	
108258	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108259	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations This Read Vac	3	
108260	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	65	
108261	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	65	
108262	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
108263	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
108264	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108265	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
108266	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
108267	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
108268	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
108269	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
108270	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
108271	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
108272	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
108273	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
108274	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	
108275	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108276	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108277	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108278	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108279	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108280	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108281	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108282	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108283	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
108284	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
108285	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	120.0	
108286	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	120.0	
108287	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	120.0	
108288	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108289	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108290	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
108291	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
108292	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
108293	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
108294	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
108295	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
108296	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
108297	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
108298	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
108299	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
108300	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108301	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108302	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108303	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108304	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108305	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108306	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108307	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108308	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108309	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108310	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108311	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108312	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps C Ø	100.0	
108313	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps B Ø	135.0	
108314	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps A Ø	120.0	
108315	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108316	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108317	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108318	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations	5	
108319	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
108320	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
108321	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108322	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108323	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps C Ø	0.0	
108324	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps B Ø	0.0	
108325	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps A Ø	0.0	
108326	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108327	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108328	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108329	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations	0	
108330	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
108331	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
108332	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
108333	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
108334	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
108335	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
108336	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
108337	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
108338	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		
108339	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
108340	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
108341	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
108342	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
108343	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
108344	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
108345	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
108346	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
108347	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
108348	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
108349	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
108350	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
108351	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
108352	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
108353	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
108354	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	170.0	
108355	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108356	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108357	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108358	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	9	
108359	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
108360	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
108361	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
108362	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
108363	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
108364	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
108365	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
108366	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
108367	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108368	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108369	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108370	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108371	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108372	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108373	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108374	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108375	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
108376	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108377	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
108378	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108379	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108380	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108381	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	0	
108382	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Grounds in Place?	y	
108383	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
108384	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
108385	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	243	
108386	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	243	
108387	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations This Read Vac	2	
108388	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108389	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	2	
108390	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Tank Paint Condition	Good	
108391	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
108392	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108393	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Grounds in Place?	y	
108394	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	General Comments		
108395	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	General Comments		
108396	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Follow-up Action Required?	n	
108397	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Follow-up Action Required?	n	
108398	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations Ground	0	
108399	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations C Ø	0	
108400	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations B Ø	0	
108401	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations A Ø	0	
108402	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	4L	
108403	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
108404	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	12790	
108405	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	12790	
108406	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
108407	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
108408	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
108409	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
108410	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
108411	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
108412	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
108413	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
108414	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
108415	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
108416	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
108417	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
108418	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
108419	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
108420	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
108421	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
108422	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
108423	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
108424	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
108425	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
108426	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
108427	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
108428	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
108429	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
108430	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
108431	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
108432	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
108433	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
108434	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
108435	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
108436	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
108437	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
108438	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
108439	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
108440	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
108441	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
108442	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
108443	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
108444	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
108445	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
108446	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
108447	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	6256.00	kw
108448	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
108449	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
108450	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	50	°C
108451	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108452	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108453	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
108454	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
108455	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
108456	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
108457	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
108458	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
108459	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
108460	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
108461	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
108462	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
108463	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
108464	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
108465	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	1004	
108466	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	9L	
108467	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	2L	
108468	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
108469	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
108470	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
108471	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
108472	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
108473	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
108474	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
108475	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
108476	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
108477	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
108478	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
108479	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	General Comments		
108480	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
108481	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	LTC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
108482	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
108483	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
108484	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	30	*C
108485	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	47	*C
108486	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.2480	
108487	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
108488	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108489	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108490	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
108491	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
108492	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108493	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108494	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
108495	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	30	*C
108496	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	47	*C
108497	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
108498	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
108499	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
108500	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	5952.00	kw
108501	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	0	Kwh
108502	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
108503	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
108504	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
108505	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	825	
108506	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Moisture and Leak Free?	y	
108507	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AF	174	
108508	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AL	174	
108509	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations This Read Vac	2	
108510	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108511	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Switching Operations	2	
108512	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Tank Paint Condition	Good	
108513	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Unknown Operations	0	
108514	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	9 Month Operations	2	
108515	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108516	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108517	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108518	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps A Ø	0.0	
108519	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps B Ø	0.0	
108520	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps C Ø	0.0	
108521	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108522	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108523	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108524	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108525	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108526	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
108527	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108528	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108529	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations A Ø	0	
108530	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations B Ø	0	
108531	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations C Ø	0	
108532	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations Ground	0	
108533	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Follow-up Action Required?	n	
108534	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Follow-up Action Required?	n	
108535	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Foundation Condition	Good	
108536	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	General Comments		
108537	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	General Comments		
108538	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Grounds in Place?	y	
108539	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Maintenance Operations	0	
108540	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Moisture and Leak Free?	y	
108541	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AF	144	
108542	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AL	144	
108543	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations This Read Vac	2	
108544	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108545	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Switching Operations	2	
108546	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Tank Paint Condition	Good	
108547	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Unknown Operations	0	
108548	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	9 Month Operations	2	
108549	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108550	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108551	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108552	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps A Ø	60.0	
108553	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps B Ø	60.0	
108554	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108555	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108556	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
108557	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
108558	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	825	
108559	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
108560	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	All Connections OK?	y	
108561	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	Follow-up Action Required?	n	
108562	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	General Comments		
108563	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	LTC Operation Checked?	y	
108564	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
108565	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
108566	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
108567	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
108568	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTC0000726	LTCControl	428-2	LTC Control Insp	VRR Time Delay	30	Seconds
108569	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	0	
108570	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	BK0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations	2	
108571	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	General Comments		
108572	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Grounds in Place?	y	
108573	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Maintenance Operations	0	
108574	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Moisture and Leak Free?	y	
108575	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AF	173	
108576	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AL	173	
108577	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations This Read Vac	2	
108578	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108579	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Switching Operations	2	
108580	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Tank Paint Condition	Good	
108581	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Unknown Operations	0	
108582	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	9 Month Operations	2	
108583	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108584	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108585	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108586	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps A Ø	50.0	
108587	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps B Ø	65.0	
108588	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps C Ø	90.0	
108589	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108590	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108591	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108592	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108593	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108594	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108595	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108596	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108597	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations A Ø	0	
108598	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations B Ø	0	
108599	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations C Ø	0	
108600	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations Ground	0	
108601	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108602	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Follow-up Action Required?	n	
108603	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Foundation Condition	Good	
108604	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	General Comments		
108605	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	General Comments		
108606	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Grounds in Place?	y	
108607	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Maintenance Operations	0	
108608	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
108609	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
108610	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	1	
108611	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108612	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations This Read Vac	1	
108613	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Moisture and Leak Free?	y	
108614	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Maintenance Operations	0	
108615	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108616	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Grounds in Place?	y	
108617	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	General Comments		
108618	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	General Comments		
108619	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Foundation Condition	Good	
108620	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Follow-up Action Required?	n	
108621	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Follow-up Action Required?	n	
108622	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations Ground	0	
108623	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations C Ø	0	
108624	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
108625	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations B Ø	0	
108626	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations A Ø	0	
108627	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108628	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108629	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108630	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
108631	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
108632	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108633	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108634	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108635	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108636	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108637	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushings Connection/Risers	Good	
108638	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushing Condition	Good	
108639	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps C Ø	640.0	
108640	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps B Ø	630.0	
108641	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps A Ø	590.0	
108642	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108643	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108644	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108645	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations	3	
108646	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
108647	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	82	
108648	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	83	
108649	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
108650	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
108651	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
108652	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
108653	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
108654	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	General Comments		
108655	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
108656	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
108657	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
108658	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
108659	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
108660	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Tank Paint Condition	Good	
108661	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
108662	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
108663	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
108664	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
108665	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108666	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108667	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
108668	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
108669	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108670	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
108671	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
108672	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
108673	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
108674	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
108675	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
108676	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108677	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108678	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
108679	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
108680	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
108681	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	
108682	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108683	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108684	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108685	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108686	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108687	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108688	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108689	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108690	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
108691	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108692	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
108693	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	300.0	
108694	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	300.0	
108695	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	250.0	
108696	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108697	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108698	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108699	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108700	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108701	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108702	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108703	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108704	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108705	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
108706	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	
108707	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
108708	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
108709	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	5	
108710	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
108711	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
108712	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
108713	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
108714	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Unknown Operations	0	
108715	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Tank Paint Condition	Good	
108716	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Switching Operations	1	
108717	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108718	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations This Read Vac	1	
108719	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AL	328	
108720	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AF	328	
108721	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations A Ø	0	
108722	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108723	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108724	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108725	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108726	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108727	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108728	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
108729	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
108730	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108731	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108732	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
108733	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
108734	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
108735	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps C Ø	90.0	
108736	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps B Ø	120.0	
108737	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps A Ø	100.0	
108738	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108739	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108740	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108741	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations	2	
108742	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Grounds in Place?	y	
108743	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
108744	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
108745	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
108746	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
108747	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
108748	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
108749	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
108750	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Maintenance Operations	0	
108751	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108752	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AF	159	
108753	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	159	
108754	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations This Read Vac	0	
108755	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108756	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	0	
108757	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Tank Paint Condition	Good	
108758	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
108759	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
108760	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
108761	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	2	
108762	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108763	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
108764	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
108765	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
108766	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
108767	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
108768	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
108769	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
108770	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
108771	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
108772	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	60	°C
108773	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
108774	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108775	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations C Ø	0	
108776	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations B Ø	0	
108777	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
108778	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108779	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108780	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations Ground	0	
108781	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Follow-up Action Required?	n	
108782	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Follow-up Action Required?	n	
108783	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Foundation Condition	Good	
108784	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	General Comments		
108785	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	General Comments		
108786	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Unknown Operations	0	
108787	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Switching Operations	2	
108788	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108789	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations This Read Vac	2	
108790	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AL	210	
108791	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AF	210	
108792	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Moisture and Leak Free?	y	
108793	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Maintenance Operations	0	
108794	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108795	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Grounds in Place?	y	
108796	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	General Comments		
108797	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	General Comments		
108798	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Follow-up Action Required?	n	
108799	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108800	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108801	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108802	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108803	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108804	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108805	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	140.0	
108806	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	160.0	
108807	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	140.0	
108808	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108809	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108810	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108811	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Unknown Operations	0	
108812	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Switching Operations	2	
108813	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108814	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations This Read Vac	2	
108815	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AL	243	
108816	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AF	243	
108817	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
108818	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
108819	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
108820	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
108821	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
108822	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
108823	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
108824	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
108825	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Follow-up Action Required?	n	
108826	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
108827	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations C Ø	0	
108828	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations B Ø	0	
108829	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108830	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108831	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108832	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108833	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108834	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108835	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps C Ø	115.0	
108836	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108837	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108838	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108839	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108840	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps B Ø	120.0	
108841	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps A Ø	115.0	
108842	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108843	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108844	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108845	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations A Ø	0	
108846	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations B Ø	0	
108847	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations C Ø	0	
108848	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations Ground	0	
108849	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Follow-up Action Required?	n	
108850	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Follow-up Action Required?	n	
108851	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Foundation Condition	Good	
108852	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	General Comments		
108853	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Oil Temp Present	26	°C
108854	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
108855	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108856	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108857	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
108858	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
108859	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108860	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108861	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
108862	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Reading	2.9950	
108863	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Max	50	°C
108864	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Present	26	°C
108865	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
108866	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
108867	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Follow-up Action Required?	n	
108868	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
108869	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	General Comments		
108870	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	General Comments		
108871	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Found Counter	6417	
108872	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Left Counter	6417	
108873	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
108874	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Current Tap Position	2L	
108875	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Max Tap Position	1L	
108876	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Min Tap Position	7L	
108877	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
108878	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
108879	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Operations Since Last Insp	823	
108880	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
108881	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
108882	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
108883	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108884	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
108885	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
108886	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108887	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108888	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
108889	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
108890	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
108891	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
108892	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
108893	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
108894	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
108895	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
108896	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
108897	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations	2	
108898	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
108899	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
108900	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000739	LTCControl	028-6	LTC Control Insp	All Connections OK?	y	
108901	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000739	LTCControl	028-6	LTC Control Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
108902	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	General Comments		
108903	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Operation Checked?	y	
108904	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
108905	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
108906	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
108907	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Time Delay	30	Seconds
108908	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	General Comments		
108909	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
108910	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	LTC Totalizer Reading	2995.00	kw
108911	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
108912	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
108913	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
108914	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Oil Temp Max	49	°C
108915	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Moisture and Leak Free?	y	
108916	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Maintenance Operations	0	
108917	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108918	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
108919	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps A Ø	110.0	
108920	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps B Ø	125.0	
108921	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps C Ø	105.0	
108922	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108923	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108924	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108925	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108926	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Grounds in Place?	y	
108927	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	General Comments		
108928	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	General Comments		
108929	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Follow-up Action Required?	n	
108930	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Follow-up Action Required?	n	
108931	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations Ground	0	
108932	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations C Ø	0	
108933	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations B Ø	0	
108934	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations A Ø	0	
108935	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108936	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
108937	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
108938	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
108939	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Paint Condition	Good	
108940	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
108941	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
108942	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
108943	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
108944	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
108945	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
108946	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
108947	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
108948	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Grounds in Place?	y	
108949	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
108950	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
108951	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
108952	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	
108953	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Foundation Condition	Good	
108954	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
108955	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Kwh Reading	0	Kwh
108956	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	LTC Totalizer Reading	4338.00	kw
108957	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	MegaVar Demand Meter Max	3.69	MegaVars
108958	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
108959	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
108960	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
108961	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
108962	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
108963	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
108964	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
108965	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
108966	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Max	55	°C
108967	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
108968	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Reading	4.3380	
108969	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Max	57	°C
108970	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
108971	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Unknown Operations	0	
108972	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Switching Operations	2	
108973	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
108974	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations This Read Vac	2	
108975	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AL	229	
108976	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
108977	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Max	57	°C
108978	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Present	27	°C
108979	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Max	57	°C
108980	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Present	28	°C
108981	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Max	57	°C
108982	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Present	28	°C
108983	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AF	229	
108984	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Moisture and Leak Free?	y	
108985	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Maintenance Operations	0	
108986	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Heaters (All) Functioning?	y	
108987	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Grounds in Place?	y	
108988	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
108989	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Grounds in Place?	y	
108990	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
108991	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
108992	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	206	
108993	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	206	
108994	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
108995	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	General Comments		
108996	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	General Comments		
108997	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Follow-up Action Required?	n	
108998	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
108999	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	0	
109000	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109001	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109002	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109003	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	190.0	
109004	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	225.0	
109005	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	220.0	
109006	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109007	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109008	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
109009	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
109010	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109011	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
109012	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
109013	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109014	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109015	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109016	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109017	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109018	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109019	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109020	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
109021	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
109022	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
109023	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
109024	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	
109025	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
109026	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
109027	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
109028	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
109029	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109030	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
109031	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109032	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109033	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps C Ø	0.0	
109034	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps B Ø	0.0	
109035	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps A Ø	0.0	
109036	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109037	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109038	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109039	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	9 Month Operations	0	
109040	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109041	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109042	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109043	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109044	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109045	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109046	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109047	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
109048	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109049	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Follow-up Action Required?	n	
109050	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
109051	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
109052	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	General Comments		
109053	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	General Comments		
109054	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
109055	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Foundation Condition	Good	
109056	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
109057	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109058	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109059	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109060	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations This Read Vac	2	
109061	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations This Read Vac	2	
109062	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109063	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AL	213	
109064	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	2	
109065	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Tank Paint Condition	Good	
109066	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
109067	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	2	
109068	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109069	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AF	213	
109070	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Moisture and Leak Free?	y	
109071	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Maintenance Operations	0	
109072	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Heaters (All) Functioning?	y	
109073	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Grounds in Place?	y	
109074	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	General Comments		
109075	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	General Comments		
109076	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Follow-up Action Required?	n	
109077	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Follow-up Action Required?	n	
109078	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations Ground	0	
109079	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations C Ø	0	
109080	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations B Ø	0	
109081	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations A Ø	0	
109082	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109083	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109084	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109085	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109086	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109087	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109088	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109089	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109090	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps C Ø	0.0	
109091	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps B Ø	0.0	
109092	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps A Ø	0.0	
109093	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Maintenance Operations	0	
109094	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
109095	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AF	143	
109096	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AL	143	
109097	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations This Read Vac	1	
109098	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109099	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109100	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109101	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	9 Month Operations	2	
109102	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109103	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Switching Operations	1	
109104	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
109105	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Unknown Operations	0	
109106	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
109107	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109108	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109109	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Unknown Operations	0	
109110	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Switching Operations	0	
109111	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109112	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations This Read Vac	0	
109113	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AL	195	
109114	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AF	195	
109115	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
109116	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Maintenance Operations	0	
109117	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
109118	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Grounds in Place?	y	
109119	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	General Comments		
109120	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Follow-up Action Required?	n	
109121	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations Ground	0	
109122	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations C Ø	0	
109123	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations B Ø	0	
109124	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations A Ø	0	
109125	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109126	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109127	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109128	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109129	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109130	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109131	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109132	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109133	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps C Ø	70.0	
109134	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps B Ø	75.0	
109135	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps A Ø	75.0	
109136	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109137	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109138	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109139	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations	2	
109140	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
109141	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	176	
109142	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	176	
109143	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations This Read Vac	0	
109144	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109145	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	0	
109146	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Tank Paint Condition	Good	
109147	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	
109148	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	1	
109149	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109150	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109151	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109152	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
109153	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
109154	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
109155	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109156	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109157	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	
109158	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
109159	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
109160	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109161	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109162	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109163	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109164	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109165	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109166	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109167	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
109168	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	
109169	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
109170	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
109171	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
109172	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
109173	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
109174	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
109175	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	General Comments		
109176	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
109177	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109178	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109179	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations	2	
109180	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Unknown Operations	0	
109181	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Switching Operations	2	
109182	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	114	
109183	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	114	
109184	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	
109185	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	
109186	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Grounds in Place?	y	
109187	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
109188	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Grounds in Place?	y	
109189	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
109190	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
109191	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	175	
109192	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	175	
109193	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations This Read Vac	2	
109194	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109195	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	2	
109196	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Tank Paint Condition	Good	
109197	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
109198	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	2	
109199	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109200	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109201	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109202	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
109203	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Foundation Condition	Good	
109204	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
109205	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
109206	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	50.0	
109207	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Unknown Operations	0	
109208	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Tank Paint Condition	Good	
109209	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Switching Operations	0	
109210	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109211	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations This Read Vac	0	
109212	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AL	0	
109213	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AF	0	
109214	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Moisture and Leak Free?	y	
109215	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
109216	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	124.0	
109217	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
109218	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
109219	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
109220	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	General Comments	OFFLINE LTC MAINT.	
109221	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
109222	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	LTC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
109223	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Maintenance Operations	0	
109224	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Grounds in Place?	y	
109225	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	General Comments	0	
109226	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	General Comments		
109227	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
109228	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
109229	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
109230	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
109231	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
109232	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
109233	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
109234	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
109235	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
109236	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
109237	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
109238	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
109239	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
109240	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
109241	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
109242	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
109243	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
109244	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
109245	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
109246	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
109247	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
109248	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
109249	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
109250	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109251	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
109252	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
109253	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	26662	
109254	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	26662	
109255	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109256	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	4L	
109257	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	3L	
109258	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	8L	
109259	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	835	
109260	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109261	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
109262	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109263	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
109264	10/30/2019 9:31	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
109265	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
109266	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Foundation Condition	Good	
109267	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
109268	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
109269	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	2	
109270	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109271	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations This Read Vac	2	
109272	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Tank Paint Condition	Good	
109273	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	2	
109274	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A Ø	0	
109275	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	55.0	
109276	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	60.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109277	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B Ø	0	
109278	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C Ø	0	
109279	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
109280	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109281	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
109282	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109283	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
109284	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Operations Since Last Insp	845	
109285	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
109286	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
109287	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
109288	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Min Tap Position	6L	
109289	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
109290	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
109291	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109292	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Left Counter	24468	
109293	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Found Counter	24468	
109294	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109295	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations This Read Vac	2	
109296	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	149	
109297	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AF	149	
109298	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Moisture and Leak Free?	y	
109299	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Maintenance Operations	0	
109300	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Grounds in Place?	y	
109301	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	General Comments		
109302	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	General Comments		
109303	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Foundation Condition	Good	
109304	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Follow-up Action Required?	n	
109305	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Follow-up Action Required?	n	
109306	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	General Comments		
109307	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	General Comments		
109308	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109309	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109310	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109311	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109312	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109313	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109314	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps C Ø	65.0	
109315	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109316	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109317	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109318	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109319	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations A Ø	0	
109320	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations B Ø	0	
109321	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations C Ø	0	
109322	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations Ground	0	
109323	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Follow-up Action Required?	n	
109324	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109325	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109326	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109327	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Foundation Condition	Good	
109328	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Follow-up Action Required?	n	
109329	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations A Ø	0	
109330	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations B Ø	0	
109331	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations C Ø	0	
109332	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations Ground	0	
109333	10/30/2019 8:50	Distribution	Hume Road Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109334	10/30/2019 13:53	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Follow-up Action Required?	n	
109335	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
109336	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
109337	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
109338	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	91	
109339	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
109340	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	31.12	%
109341	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	31.12	%
109342	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	31.12	%
109343	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
109344	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
109345	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
109346	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
109347	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
109348	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
109349	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
109350	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
109351	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109577	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	196	
109578	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	196	
109579	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
109580	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
109581	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
109582	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
109583	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
109584	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
109585	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
109586	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
109587	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
109588	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
109589	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
109590	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
109591	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
109592	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	272.0	
109593	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	292.0	
109594	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	220	
109595	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	220	
109596	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
109597	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
109598	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
109599	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
109600	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
109601	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
109602	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
109603	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
109604	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
109605	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
109606	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	327.0	
109607	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
109608	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
109609	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
109610	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LTC0000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
109611	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LTC0000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
109612	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LTC0000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
109613	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LTC0000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
109614	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
109615	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
109616	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
109617	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
109618	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
109619	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
109620	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
109621	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
109622	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
109623	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
109624	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
109625	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
109626	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
109627	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
109628	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
109629	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations	2	
109630	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	853	
109631	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	853	
109632	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
109633	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
109634	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109635	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109636	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
109637	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
109638	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
109639	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
109640	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
109641	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
109642	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
109643	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
109644	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
109645	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
109646	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
109647	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109648	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109649	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps A Ø	70.0	
109650	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
109651	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109652	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
109653	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109654	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
109655	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109656	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109657	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109658	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109659	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushings Connection/Risers	Good	
109660	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushing Condition	Good	
109661	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps C Ø	85.0	
109662	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps B Ø	80.0	
109663	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
109664	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
109665	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
109666	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109667	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
109668	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109669	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Unknown Operations	0	
109670	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109671	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109672	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109673	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
109674	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109675	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations	2	
109676	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
109677	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
109678	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
109679	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109680	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
109681	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
109682	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109683	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
109684	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
109685	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
109686	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
109687	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
109688	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
109689	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
109690	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
109691	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
109692	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
109693	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
109694	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
109695	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
109696	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
109697	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
109698	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
109699	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
109700	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
109701	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
109702	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
109703	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
109704	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
109705	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
109706	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
109707	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
109708	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
109709	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
109710	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
109711	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
109712	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
109713	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109714	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109715	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Descant	Good	check oil cup
109716	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109717	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
109718	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000054	LTCMechanism	EOC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109719	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
109720	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
109721	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
109722	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
109723	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
109724	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
109725	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
109726	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
109727	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
109728	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109729	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109730	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109731	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	105.0	
109732	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	100.0	
109733	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps C Ø	85.0	
109734	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushing Condition	Good	
109735	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
109736	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109737	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109738	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109739	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109740	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109741	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109742	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109743	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109744	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations A Ø	0	
109745	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations B Ø	0	
109746	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations C Ø	0	
109747	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations Ground	0	
109748	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Follow-up Action Required?	n	
109749	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Follow-up Action Required?	n	
109750	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Foundation Condition	Good	
109751	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	General Comments		
109752	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
109753	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
109754	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	0	
109755	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
109756	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
109757	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
109758	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
109759	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
109760	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
109761	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109762	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
109763	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
109764	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
109765	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
109766	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
109767	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109768	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	0	
109769	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
109770	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
109771	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
109772	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
109773	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	General Comments		
109774	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
109775	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
109776	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
109777	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
109778	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	210	
109779	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	210	
109780	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	0	
109781	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
109782	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	232	
109783	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	232	
109784	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations This Read Vac	1	
109785	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
109786	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	0	
109787	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	
109788	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
109789	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
109790	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109791	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
109792	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
109793	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
109794	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109795	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
109796	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109797	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
109798	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
109799	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
109800	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
109801	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109802	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
109803	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109804	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
109805	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
109806	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
109807	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
109808	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
109809	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109810	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
109811	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109812	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109813	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
109814	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
109815	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109816	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
109817	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
109818	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	0	
109819	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
109820	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
109821	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
109822	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
109823	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-5TA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109824	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-5TA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
109825	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109826	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
109827	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-5TA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109828	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-5TA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
109829	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109830	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109831	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
109832	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
109833	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
109834	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109835	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
109836	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
109837	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
109838	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109839	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
109840	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109841	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
109842	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
109843	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
109844	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
109845	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
109846	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
109847	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109848	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109849	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
109850	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations	3	
109851	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109852	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109853	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109854	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	70.0	
109855	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
109856	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
109857	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
109858	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
109859	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109860	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-5TA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109861	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-5TA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
109862	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-5TA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
109863	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-5TA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
109864	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	75.0	
109865	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	60.0	
109866	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
109867	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
109868	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109869	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109870	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109871	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109872	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109873	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
109874	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109875	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109876	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
109877	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	0	
109878	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109879	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109880	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
109881	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
109882	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
109883	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
109884	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
109885	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
109886	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
109887	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
109888	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109889	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109890	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109891	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109892	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109893	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109894	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushings Connection/Risers	Good	
109895	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushing Condition	Good	
109896	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps C Ø	10.0	
109897	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps B Ø	15.0	
109898	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps A Ø	8.0	
109899	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109900	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109901	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109902	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations	3	
109903	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Unknown Operations	0	
109904	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Tank Paint Condition	Good	
109905	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Switching Operations	0	
109906	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations This Read Vac	0	
109907	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AL	209	
109908	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AF	209	
109909	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Moisture and Leak Free?	y	
109910	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
109911	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
109912	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
109913	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
109914	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Maintenance Operations	0	
109915	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Grounds in Place?	y	
109916	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	General Comments		
109917	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
109918	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
109919	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
109920	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
109921	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
109922	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	General Comments		
109923	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Foundation Condition	Good	
109924	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Follow-up Action Required?	n	
109925	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Follow-up Action Required?	n	
109926	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations Ground	0	
109927	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations C Ø	0	
109928	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations B Ø	0	
109929	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations A Ø	0	
109930	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109931	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109932	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109933	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
109934	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
109935	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations Ground	0	
109936	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
109937	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
109938	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
109939	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
109940	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
109941	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
109942	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109943	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
109944	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109945	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
109946	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
109947	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushings Connection/Risers	Good	
109948	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushing Condition	Good	
109949	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations This Read Vac	0	
109950	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
109951	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
109952	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
109953	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
109954	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
109955	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
109956	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
109957	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
109958	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
109959	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
109960	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
109961	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
109962	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	General Comments		
109963	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
109964	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps C Ø	7.0	
109965	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps B Ø	12.0	
109966	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps A Ø	5.0	
109967	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109968	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
109969	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
109970	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations	2	
109971	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Unknown Operations	0	
109972	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Tank Paint Condition	Good	
109973	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Switching Operations	1	
109974	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations This Read Vac	1	
109975	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AL	202	
109976	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AF	202	
109977	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Moisture and Leak Free?	y	
109978	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Maintenance Operations	0	
109979	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Grounds in Place?	y	
109980	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	General Comments		
109981	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	General Comments		
109982	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Foundation Condition	Good	
109983	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Follow-up Action Required?	n	
109984	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Follow-up Action Required?	n	
109985	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations Ground	0	
109986	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations C Ø	0	
109987	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations B Ø	0	
109988	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations A Ø	0	
109989	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109990	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	210.0	
109991	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	210.0	
109992	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	230.0	
109993	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
109994	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
109995	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
109996	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
109997	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	260.0	
109998	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	230.0	
109999	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	250.0	
110000	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110001	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110002	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110003	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110004	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
110005	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
110006	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
110007	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
110008	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
110009	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
110010	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
110011	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
110012	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
110013	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	72	
110014	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	72	
110015	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
110016	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
110017	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110018	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110019	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110020	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
110021	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
110022	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
110023	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
110024	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
110025	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
110026	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110027	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
110028	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110029	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
110030	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	319	
110031	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	319	
110032	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
110033	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
110034	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
110035	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
110036	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
110037	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110038	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110039	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110040	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
110041	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110042	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110043	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110044	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110045	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
110046	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110047	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110048	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
110049	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110050	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110051	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
110052	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	AB PHASE IOC	
110053	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
110054	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1083	
110055	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1083	
110056	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	10	
110057	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
110058	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	0	
110059	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110060	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110061	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110062	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	380.0	
110063	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	380.0	
110064	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	380.0	
110065	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110066	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110067	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110068	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110069	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110070	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
110071	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
110072	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
110073	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
110074	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
110075	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
110076	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
110077	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
110078	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110079	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
110080	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	197	
110081	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	197	
110082	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
110083	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
110084	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
110085	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	2	
110086	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110087	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110088	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110089	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	50.0	
110090	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	80.0	
110091	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	50.0	
110092	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110093	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110094	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110095	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110096	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110097	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
110098	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
110099	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
110100	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
110101	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110102	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
110103	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
110104	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
110105	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110106	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
110107	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	205	
110108	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	205	
110109	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
110110	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
110111	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
110112	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	0	
110113	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110114	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110115	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110116	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	6L	
110117	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	1L	
110118	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	11L	
110119	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	917	
110120	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110121	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110122	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110123	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110124	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	80.0	
110125	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	50.0	
110126	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110127	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	General Comments		
110128	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110129	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
110130	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110131	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110132	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110133	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110134	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110135	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110136	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
110137	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
110138	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
110139	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
110140	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
110141	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
110142	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
110143	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
110144	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110145	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
110146	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	189	
110147	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	189	
110148	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
110149	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
110150	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
110151	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
110152	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110153	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110154	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
110155	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
110156	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
110157	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
110158	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110159	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
110160	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
110161	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	0.0	
110162	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110163	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110164	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110165	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110166	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110167	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
110168	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
110169	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
110170	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	5	
110171	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110172	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110173	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110174	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	36.0	
110175	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	42.0	
110176	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	45.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110177	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110178	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110179	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110180	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110181	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
110182	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110183	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110184	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
110185	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
110186	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	28	°C
110187	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	57	°C
110188	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
110189	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
110190	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
110191	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
110192	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110193	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110194	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
110195	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110196	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110197	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110198	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110199	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
110200	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
110201	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110202	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110203	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110204	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Started T. C filter but it kicked off after about 5 min..	
110205	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
110206	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110207	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110208	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
110209	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
110210	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
110211	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
110212	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110213	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110214	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110215	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110216	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110217	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110218	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110219	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110220	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
110221	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110222	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110223	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110224	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
110225	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110226	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
110227	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	General Comments	DID NOT FIND	
110228	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110229	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110230	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110231	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
110232	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	3	
110233	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110234	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110235	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110236	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	100.0	
110237	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110238	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
110239	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
110240	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	39882	
110241	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	39882	
110242	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
110243	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110244	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
110245	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
110246	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
110247	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110248	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
110249	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110250	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110251	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110252	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110253	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
110254	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110255	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110256	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
110257	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110258	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110259	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
110260	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110261	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110262	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110263	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110264	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110265	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110266	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
110267	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110268	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110269	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110270	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
110271	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2744	
110272	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
110273	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
110274	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
110275	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110276	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	259289	
110277	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	259289	
110278	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
110279	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
110280	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110281	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
110282	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
110283	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
110284	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
110285	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
110286	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
110287	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110288	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110289	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110290	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110291	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110292	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110293	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110294	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110295	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
110296	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
110297	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110298	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
110299	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110300	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110301	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
110302	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments		
110303	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110304	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	4118.40	kw
110305	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
110306	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
110307	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
110308	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
110309	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
110310	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
110311	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
110312	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
110313	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
110314	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
110315	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
110316	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
110317	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
110318	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
110319	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
110320	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
110321	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
110322	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
110323	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
110324	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
110325	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
110326	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
110327	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
110328	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110329	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	General Comments		
110330	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
110331	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Found Counter	132806	
110332	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Left Counter	132806	
110333	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110334	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
110335	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
110336	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
110337	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	21	
110338	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
110339	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110340	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110341	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110342	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
110343	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110344	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
110345	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
110346	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	67928	
110347	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	67928	
110348	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110349	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
110350	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
110351	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
110352	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1770	
110353	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110354	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110355	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110356	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
110357	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCCControl	TA-TRANS 4	LTC Control Insp	General Comments		
110358	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
110359	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
110360	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCCControl	TA-TRANS 1	LTC Control Insp	General Comments		
110361	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
110362	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
110363	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCCControl	TA-TRANS 3	LTC Control Insp	General Comments		
110364	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
110365	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110366	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
110367	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
110368	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110369	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
110370	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110371	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110372	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110373	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110374	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2053	
110375	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
110376	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
110377	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	12R	
110378	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
110379	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110380	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	230286	
110381	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	230286	
110382	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
110383	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
110384	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110385	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
110386	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	5	
110387	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	27.9	%
110388	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	28.7	%
110389	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	27.1	%
110390	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	12.0	
110391	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	12.0	
110392	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	12.0	
110393	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110394	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110395	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
110396	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	31.32	%
110397	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	32.52	%
110398	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	42.16	%
110399	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110400	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110401	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110402	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
110403	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
110404	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
110405	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
110406	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
110407	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
110408	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
110409	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
110410	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	118	
110411	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	118	
110412	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	0	
110413	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
110414	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	0	
110415	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
110416	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	3	
110417	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110418	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	140.0	
110419	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	140.0	
110420	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	140.0	
110421	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
110422	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	55.90	
110423	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	55.90	
110424	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
110425	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	5	
110426	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	5	
110427	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
110428	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
110429	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
110430	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
110431	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
110432	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110433	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110434	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	60	*C
110435	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	35	*C
110436	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC0000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
110437	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC0000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
110438	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC0000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
110439	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LTC0000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
110440	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110441	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110442	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110443	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110444	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
110445	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110446	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110447	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
110448	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	.2860	
110449	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
110450	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
110451	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
110452	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
110453	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
110454	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
110455	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
110456	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
110457	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
110458	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
110459	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
110460	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
110461	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
110462	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
110463	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
110464	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
110465	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
110466	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110467	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110468	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
110469	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
110470	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
110471	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
110472	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
110473	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110474	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	General Comments		
110475	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
110476	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
110477	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
110478	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
110479	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
110480	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
110481	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
110482	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments	Does not have follow up action required Yes or No at bottom of list on this page	
110483	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
110484	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
110485	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
110486	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
110487	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
110488	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
110489	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
110490	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
110491	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
110492	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110493	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110494	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110495	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110496	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110497	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
110498	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
110499	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
110500	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110501	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110502	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110503	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110504	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110505	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
110506	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
110507	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
110508	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
110509	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
110510	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
110511	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
110512	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
110513	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110514	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
110515	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	220	
110516	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	220	
110517	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
110518	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
110519	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
110520	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
110521	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
110522	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
110523	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
110524	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
110525	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
110526	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
110527	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
110528	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
110529	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
110530	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
110531	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
110532	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
110533	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
110534	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
110535	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
110536	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
110537	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
110538	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
110539	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
110540	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110541	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
110542	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110543	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
110544	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
110545	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110546	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110547	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110548	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110549	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110550	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110551	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110552	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
110553	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110554	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110555	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
110556	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110557	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
110558	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
110559	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
110560	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110561	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
110562	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
110563	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
110564	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
110565	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
110566	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
110567	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
110568	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110569	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110570	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110571	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
110572	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	12.0	
110573	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	11.0	
110574	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110575	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110576	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
110577	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
110578	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
110579	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	148	
110580	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	148	
110581	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
110582	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
110583	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
110584	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
110585	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
110586	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
110587	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
110588	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
110589	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
110590	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
110591	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
110592	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
110593	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
110594	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
110595	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
110596	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
110597	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
110598	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
110599	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.23	%
110600	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
110601	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110602	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110603	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110604	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
110605	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
110606	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
110607	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
110608	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
110609	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
110610	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
110611	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
110612	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110613	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
110614	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	282	
110615	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	282	
110616	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
110617	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
110618	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
110619	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	2	
110620	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110621	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110622	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110623	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
110624	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110625	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110626	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
110627	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110628	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	13L	
110629	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	3R	
110630	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
110631	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110632	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	225623	
110633	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	225623	
110634	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
110635	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments		
110636	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110637	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
110638	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
110639	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
110640	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
110641	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
110642	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
110643	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110644	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110645	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110646	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
110647	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
110648	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110649	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110650	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
110651	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110652	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
110653	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110654	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110655	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110656	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110657	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110658	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110659	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110660	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110661	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
110662	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
110663	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110664	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
110665	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
110666	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110667	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
110668	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110669	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110670	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110671	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110672	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110673	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110674	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110675	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
110676	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110677	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110678	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
110679	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110680	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110681	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
110682	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
110683	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110684	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000121	WithLTC	EOC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110685	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110686	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
110687	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110688	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110689	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
110690	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
110691	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110692	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110693	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
110694	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
110695	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
110696	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
110697	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
110698	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110699	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110700	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
110701	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110702	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110703	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110704	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110705	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
110706	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110707	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110708	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
110709	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
110710	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
110711	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
110712	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
110713	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
110714	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	30	°C
110715	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
110716	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
110717	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
110718	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
110719	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110720	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
110721	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110722	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
110723	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
110724	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
110725	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
110726	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
110727	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110728	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110729	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-5TA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110730	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-5TA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
110731	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110732	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
110733	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
110734	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110735	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
110736	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110737	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
110738	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1929	
110739	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
110740	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
110741	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
110742	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
110743	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	30	°C
110744	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
110745	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	30	°C
110746	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
110747	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
110748	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110749	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110750	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110751	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
110752	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
110753	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
110754	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
110755	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
110756	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		
110757	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
110758	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110759	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
110760	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	171	
110761	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	171	
110762	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	0	
110763	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
110764	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
110765	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
110766	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110767	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110768	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110769	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110770	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
110771	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110772	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110773	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110774	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
110775	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
110776	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110777	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
110778	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110779	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110780	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
110781	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	8	
110782	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110783	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110784	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110785	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	71.0	
110786	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	60.0	
110787	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	80.0	
110788	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110789	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110790	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110791	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110792	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110793	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
110794	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
110795	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
110796	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
110797	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110798	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
110799	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
110800	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
110801	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments		
110802	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
110803	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110804	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
110805	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	166	
110806	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110807	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
110808	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
110809	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
110810	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
110811	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
110812	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110813	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110814	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110815	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
110816	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
110817	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
110818	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
110819	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
110820	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110821	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
110822	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	156	
110823	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	156	
110824	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations This Read Vac	0	
110825	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
110826	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
110827	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
110828	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
110829	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
110830	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
110831	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
110832	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
110833	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
110834	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
110835	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
110836	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
110837	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110838	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
110839	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
110840	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
110841	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
110842	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
110843	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
110844	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
110845	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
110846	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110847	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
110848	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	310	
110849	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	310	
110850	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	3	
110851	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	3	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110852	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
110853	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	0	
110854	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110855	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110856	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110857	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	230.0	
110858	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	240.0	
110859	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	230.0	
110860	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110861	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110862	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110863	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110864	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110865	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
110866	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110867	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110868	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
110869	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110870	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110871	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
110872	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110873	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110874	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
110875	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110876	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
110877	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
110878	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
110879	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
110880	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
110881	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
110882	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments		
110883	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
110884	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
110885	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	324	
110886	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	324	
110887	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	0	
110888	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
110889	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
110890	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110891	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110892	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
110893	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110894	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110895	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
110896	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
110897	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
110898	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
110899	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
110900	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
110901	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
110902	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110903	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110904	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110905	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
110906	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
110907	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
110908	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110909	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110910	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
110911	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
110912	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
110913	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
110914	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
110915	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
110916	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
110917	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
110918	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
110919	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
110920	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
110921	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
110922	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	General Comments		
110923	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110924	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110925	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
110926	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
110927	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110928	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110929	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110930	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
110931	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
110932	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110933	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments		
110934	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110935	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
110936	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
110937	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110938	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110939	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110940	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110941	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110942	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110943	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
110944	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110945	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110946	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
110947	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
110948	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	105	°C
110949	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	166	
110950	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	0	
110951	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
110952	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
110953	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
110954	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
110955	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
110956	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	100	°C
110957	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
110958	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
110959	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
110960	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
110961	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
110962	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
110963	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
110964	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
110965	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
110966	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
110967	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
110968	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
110969	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
110970	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
110971	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	32	
110972	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
110973	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
110974	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
110975	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
110976	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
110977	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
110978	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Heaters in CCC are not working	
110979	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
110980	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
110981	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
110982	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
110983	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
110984	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
110985	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
110986	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
110987	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
110988	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
110989	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
110990	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
110991	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
110992	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
110993	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
110994	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	114.0	
110995	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	107.0	
110996	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	98.0	
110997	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
110998	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
110999	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111000	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
111001	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111002	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
111003	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111004	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111005	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111006	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	0	
111007	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111008	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
111009	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111010	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111011	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111012	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
111013	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111014	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111015	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
111016	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
111017	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Present	35	°C
111018	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Max	60	°C
111019	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Reading	.4200	
111020	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
111021	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111022	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111023	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111024	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111025	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111026	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111027	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111028	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111029	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111030	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
111031	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111032	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111033	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111034	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111035	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111036	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
111037	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111038	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
111039	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
111040	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111041	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
111042	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
111043	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
111044	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111045	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
111046	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111047	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111048	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111049	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111050	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	General Comments		
111051	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
111052	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111053	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
111054	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111055	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
111056	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111057	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111058	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
111059	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
111060	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111061	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
111062	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
111063	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111064	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
111065	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111066	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111067	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
111068	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111069	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
111070	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111071	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
111072	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111073	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111074	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
111075	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111076	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111077	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111078	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111079	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
111080	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
111081	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations This Read AM	0	
111082	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	54	
111083	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	54	
111084	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	0	
111085	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		
111086	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
111087	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
111088	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
111089	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
111090	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
111091	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
111092	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
111093	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111094	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111095	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111096	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111097	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	150.0	
111098	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	150.0	
111099	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	150.0	
111100	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111101	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111102	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111103	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Present	30	°C
111104	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Max	50	°C
111105	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
111106	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
111107	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111108	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	LTC Totalizer Reading	6048.00	kw
111109	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111110	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	General Comments		
111111	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	10	
111112	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111113	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111114	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111115	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
111116	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
111117	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
111118	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
111119	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
111120	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
111121	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
111122	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111123	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111124	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111125	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111126	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
111127	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
111128	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
111129	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
111130	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
111131	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
111132	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
111133	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
111134	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
111135	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1279	
111136	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1279	
111137	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
111138	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
111139	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
111140	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111141	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111142	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
111143	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
111144	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
111145	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
111146	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
111147	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	General Comments		
111148	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
111149	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
111150	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111151	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111152	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111153	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111154	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111155	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
111156	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111157	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
111158	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	13.25	%
111159	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
111160	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
111161	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
111162	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
111163	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
111164	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111165	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
111166	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111167	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111168	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
111169	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
111170	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
111171	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
111172	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
111173	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
111174	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
111175	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A PHASE IOC	
111176	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
111177	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	100	
111178	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	100	
111179	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
111180	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
111181	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
111182	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111183	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111184	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
111185	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
111186	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111187	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111188	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111189	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111190	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111191	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111192	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
111193	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111194	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111195	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
111196	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
111197	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
111198	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111199	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111200	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111201	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
111202	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111203	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111204	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111205	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111206	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	47.50	
111207	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111208	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111209	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111210	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111211	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111212	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111213	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111214	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111215	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111216	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
111217	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111218	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111219	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111220	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
111221	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	15	
111222	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
111223	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
111224	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
111225	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
111226	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111227	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	89	
111228	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	89	
111229	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
111230	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
111231	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
111232	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
111233	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
111234	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
111235	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
111236	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
111237	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
111238	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
111239	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
111240	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
111241	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
111242	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
111243	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
111244	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111245	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
111246	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111247	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111248	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111249	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
111250	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
111251	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
111252	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111253	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111254	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111255	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111256	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
111257	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
111258	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
111259	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
111260	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
111261	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
111262	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
111263	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
111264	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
111265	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	725	
111266	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	725	
111267	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
111268	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
111269	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
111270	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
111271	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments		
111272	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
111273	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
111274	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
111275	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
111276	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
111277	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	
111278	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	0	
111279	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	0	
111280	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
111281	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
111282	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111283	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
111284	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
111285	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
111286	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
111287	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
111288	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
111289	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
111290	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	400.0	
111291	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	350.0	
111292	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	330.0	
111293	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
111294	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111295	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111296	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111297	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111298	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111299	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
111300	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111301	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111302	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111303	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111304	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111305	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111306	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111307	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111308	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
111309	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111310	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111311	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
111312	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
111313	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
111314	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	12L	
111315	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	2L	
111316	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	7L	
111317	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111318	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	7945	
111319	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111320	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111321	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111322	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111323	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
111324	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111325	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
111326	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111327	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111328	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	7945	
111329	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
111330	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		
111331	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111332	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
111333	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111334	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
111335	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
111336	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111337	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
111338	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111339	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111340	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
111341	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111342	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111343	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
111344	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
111345	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
111346	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
111347	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
111348	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
111349	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
111350	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	440.0	
111351	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	500.0	
111352	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	390.0	
111353	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
111354	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
111355	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
111356	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	2	
111357	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	VRR Time Delay	30	Seconds
111358	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
111359	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
111360	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
111361	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
111362	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	General Comments		
111363	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	
111364	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
111365	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111366	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111367	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111368	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
111369	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
111370	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
111371	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111372	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
111373	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
111374	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111375	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	876	
111376	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111377	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111378	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111379	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
111380	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
111381	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111382	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments	DID NOT FIND	
111383	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111384	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
111385	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
111386	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111387	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111388	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	NO OIL	
111389	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
111390	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111391	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
111392	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
111393	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111394	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111395	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111396	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
111397	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
111398	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111399	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111400	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111401	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111402	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111403	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111404	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111405	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111406	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
111407	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111408	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111409	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111410	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
111411	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
111412	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
111413	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
111414	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
111415	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
111416	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
111417	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
111418	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111419	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111420	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111421	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
111422	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
111423	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
111424	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111425	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111426	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111427	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111428	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
111429	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
111430	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
111431	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111432	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111433	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111434	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111435	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
111436	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
111437	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
111438	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
111439	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
111440	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111441	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	0	
111442	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111443	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111444	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111445	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	0.0	
111446	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	0.0	
111447	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	0.0	
111448	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111449	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111450	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111451	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111452	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
111453	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
111454	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
111455	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
111456	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
111457	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
111458	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
111459	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
111460	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
111461	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111462	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
111463	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111464	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	192	
111465	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	192	
111466	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
111467	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111468	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
111469	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111470	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111471	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
111472	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
111473	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111474	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
111475	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
111476	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111477	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
111478	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111479	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111480	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
111481	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111482	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111483	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
111484	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111485	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111486	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111487	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111488	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
111489	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
111490	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
111491	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
111492	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
111493	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
111494	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
111495	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	89	
111496	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	89	
111497	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
111498	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
111499	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
111500	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111501	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
111502	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111503	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111504	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
111505	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
111506	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111507	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
111508	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
111509	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111510	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
111511	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111512	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111513	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
111514	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111515	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111516	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111517	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
111518	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
111519	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111520	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
111521	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111522	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111523	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
111524	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111525	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111526	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111527	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111528	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
111529	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
111530	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111531	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
111532	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
111533	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111534	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111535	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
111536	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111537	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
111538	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
111539	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
111540	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
111541	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	976	
111542	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	976	
111543	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
111544	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
111545	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
111546	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
111547	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
111548	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
111549	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
111550	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
111551	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
111552	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
111553	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	13	
111554	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	13	
111555	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
111556	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
111557	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
111558	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111559	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111560	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
111561	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111562	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
111563	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111564	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
111565	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
111566	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
111567	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111568	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111569	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111570	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
111571	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
111572	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
111573	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111574	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111575	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111576	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
111577	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
111578	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
111579	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111580	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111581	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111582	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111583	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
111584	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
111585	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
111586	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	4	
111587	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	4	
111588	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
111589	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
111590	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111591	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
111592	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111593	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
111594	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
111595	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
111596	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
111597	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
111598	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
111599	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
111600	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
111601	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence 25' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111602	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
111603	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
111604	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
111605	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
111606	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
111607	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
111608	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
111609	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
111610	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
111611	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
111612	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
111613	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments	there is brush hanging on the corner of the fence behind the control house. Pic sent to Stinson	
111614	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
111615	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
111616	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
111617	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
111618	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
111619	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
111620	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
111621	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
111622	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
111623	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
111624	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
111625	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments	Yard lights by DA6660 and TR1 are out. Need small bucket truck	
111626	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
111627	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
111628	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
111629	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
111630	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111631	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111632	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111633	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111634	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111635	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
111636	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Follow-up Action Required?	n	
111637	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	80.0	
111638	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	80.0	
111639	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	80.0	
111640	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
111641	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
111642	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
111643	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
111644	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
111645	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
111646	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111647	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
111648	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
111649	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111650	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111651	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
111652	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111653	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
111654	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
111655	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
111656	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111657	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
111658	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111659	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111660	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
111661	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
111662	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111663	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
111664	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
111665	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	37725	
111666	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	37725	
111667	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111668	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
111669	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
111670	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
111671	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	*C
111672	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	*C
111673	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2150	
111674	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
111675	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
111676	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111677	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
111678	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
111679	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
111680	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
111681	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	271	
111682	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	271	
111683	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111684	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111685	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
111686	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111687	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111688	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111689	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111690	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111691	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111692	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
111693	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111694	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111695	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111696	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
111697	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
111698	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111699	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111700	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111701	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111702	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
111703	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111704	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
111705	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2274	
111706	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
111707	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
111708	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
111709	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111710	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	19504	
111711	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	19504	
111712	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
111713	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
111714	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111715	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
111716	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111717	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
111718	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111719	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2379	
111720	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
111721	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	12L	
111722	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8R	
111723	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
111724	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
111725	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	63791	
111726	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	63791	
111727	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
111728	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
111729	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111730	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
111731	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111732	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
111733	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
111734	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
111735	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
111736	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
111737	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
111738	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
111739	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
111740	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
111741	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	General Comments		
111742	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111743	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111744	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
111745	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111746	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	General Comments		
111747	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111748	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111749	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
111750	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
111751	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111752	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
111753	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	397	
111754	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	397	
111755	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
111756	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
111757	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
111758	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
111759	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
111760	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
111761	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
111762	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
111763	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
111764	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
111765	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
111766	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Main heater Fan in Switch gear is not working	
111767	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
111768	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
111769	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
111770	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
111771	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
111772	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
111773	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
111774	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
111775	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
111776	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111777	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111778	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
111779	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111780	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111781	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111782	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
111783	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111784	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111785	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111786	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
111787	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
111788	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111789	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111790	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
111791	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
111792	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
111793	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
111794	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
111795	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
111796	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
111797	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	54	
111798	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	54	
111799	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations This Read Vac	0	
111800	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
111801	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	0	
111802	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
111803	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
111804	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	0	
111805	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
111806	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111807	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
111808	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
111809	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111810	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
111811	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111812	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
111813	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
111814	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
111815	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111816	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
111817	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111818	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
111819	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
111820	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
111821	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
111822	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	0	
111823	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	79	
111824	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	79	
111825	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
111826	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
111827	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
111828	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
111829	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
111830	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
111831	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
111832	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
111833	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
111834	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
111835	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
111836	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
111837	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
111838	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	General Comments		
111839	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
111840	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
111841	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		
111842	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
111843	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
111844	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
111845	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
111846	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
111847	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
111848	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
111849	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111850	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
111851	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
111852	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
111853	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
111854	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
111855	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	
111856	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	190	
111857	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111858	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111859	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111860	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
111861	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
111862	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Present	60	°C
111863	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Max	100	°C
111864	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111865	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	190	
111866	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111867	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111868	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	General Comments		
111869	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
111870	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111871	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
111872	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
111873	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111874	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
111875	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
111876	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111877	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
111878	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
111879	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
111880	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111881	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
111882	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111883	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111884	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
111885	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111886	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
111887	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111888	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations This Read Vac	0	
111889	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
111890	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
111891	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	0	
111892	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	22	
111893	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
111894	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
111895	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
111896	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	130.0	
111897	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	135.0	
111898	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	155.0	
111899	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
111900	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
111901	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111902	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
111903	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
111904	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
111905	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
111906	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111907	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
111908	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
111909	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
111910	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	1	
111911	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	0	
111912	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	General Comments		
111913	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	General Comments		
111914	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Foundation Condition	Good	
111915	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
111916	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
111917	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
111918	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	General Comments	NO OIL (EMPTY)	
111919	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111920	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
111921	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
111922	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
111923	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
111924	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
111925	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations	1	
111926	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
111927	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
111928	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111929	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
111930	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
111931	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
111932	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111933	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
111934	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	0	
111935	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
111936	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	203	
111937	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	203	
111938	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations This Read Vac	1	
111939	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	0	
111940	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
111941	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
111942	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	0	
111943	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
111944	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
111945	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
111946	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	145.0	
111947	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	175.0	
111948	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	155.0	
111949	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
111950	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
111951	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
111952	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
111953	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
111954	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
111955	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
111956	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111957	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
111958	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments		
111959	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
111960	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
111961	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
111962	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
111963	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	149	
111964	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	149	
111965	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111966	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
111967	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
111968	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
111969	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
111970	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
111971	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
111972	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
111973	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
111974	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
111975	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
111976	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
111977	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
111978	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
111979	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
111980	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
111981	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
111982	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
111983	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111984	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
111985	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
111986	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
111987	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	250.0	
111988	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	250.0	
111989	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	250.0	
111990	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111991	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	T0498	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
111992	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
111993	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
111994	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
111995	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
111996	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
111997	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
111998	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
111999	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112000	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112001	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112002	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112003	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112004	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112005	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
112006	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112007	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112008	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112009	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
112010	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112011	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
112012	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
112013	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112014	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
112015	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112016	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112017	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
112018	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
112019	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112020	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112021	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
112022	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112023	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112024	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112025	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112026	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112027	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112028	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112029	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
112030	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
112031	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112032	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
112033	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
112034	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	27	°C
112035	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112036	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112037	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
112038	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112039	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
112040	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112041	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112042	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
112043	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
112044	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
112045	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	21	°C
112046	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
112047	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	27	°C
112048	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
112049	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	27	°C
112050	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
112051	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112052	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
112053	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
112054	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112055	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112056	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
112057	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112058	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	General Comments	DID FIND	
112059	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112060	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
112061	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations Ground	0	
112062	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations C Ø	0	
112063	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations B Ø	0	
112064	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
112065	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
112066	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
112067	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	100.0	
112068	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	100.0	
112069	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	100.0	
112070	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
112071	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
112072	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
112073	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
112074	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
112075	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
112076	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
112077	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
112078	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
112079	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
112080	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112081	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations A Ø	0	
112082	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
112083	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
112084	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
112085	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
112086	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
112087	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
112088	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
112089	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
112090	10/29/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
112091	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112092	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112093	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	VRR Time Delay	30	Seconds
112094	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
112095	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
112096	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
112097	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
112098	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
112099	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	General Comments		
112100	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
112101	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	LTC0000736	LTCControl	196-5	LTC Control Insp	All Connections OK?	y	
112102	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
112103	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112104	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
112105	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
112106	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
112107	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
112108	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
112109	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
112110	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
112111	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112112	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112113	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112114	10/29/2019 12:37	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.800	millivolts
112115	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112116	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112117	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112118	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112119	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112120	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112121	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
112122	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112123	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AF	164	
112124	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
112125	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Maintenance Operations	0	
112126	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112127	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
112128	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
112129	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
112130	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
112131	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
112132	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
112133	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
112134	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
112135	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
112136	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
112137	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AL	164	
112138	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations This Read Vac	0	
112139	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
112140	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Switching Operations	0	
112141	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
112142	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Unknown Operations	0	
112143	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations	1	
112144	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112145	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
112146	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	226.00	
112147	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
112148	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
112149	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
112150	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112151	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
112152	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
112153	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112154	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
112155	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112156	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
112157	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112158	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112159	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112160	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112161	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps A Ø	250.0	
112162	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps B Ø	250.0	
112163	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
112164	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
112165	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps C Ø	240.0	
112166	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushing Condition	Good	
112167	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112168	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112169	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112170	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112171	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112172	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112173	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112174	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112175	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
112176	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
112177	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
112178	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
112179	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
112180	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99965	
112181	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99965	
112182	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
112183	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	General Comments		
112184	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	General Comments		
112185	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
112186	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Follow-up Action Required?	n	
112187	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112188	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112189	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
112190	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112191	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Foundation Condition	Good	
112192	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	General Comments		
112193	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	General Comments		
112194	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Grounds in Place?	y	
112195	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Maintenance Operations	0	
112196	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
112197	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AF	163	
112198	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AL	163	
112199	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations This Read Vac	0	
112200	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Switching Operations	0	
112201	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112202	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Unknown Operations	0	
112203	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112204	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations A Ø	0	
112205	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112206	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112207	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112208	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112209	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112210	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112211	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112212	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112213	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
112214	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
112215	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112216	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112217	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
112218	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps C Ø	0.0	
112219	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps B Ø	0.0	
112220	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps A Ø	0.0	
112221	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112222	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112223	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112224	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations	3	
112225	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Unknown Operations	0	
112226	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Tank Paint Condition	Good	
112227	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Switching Operations	0	
112228	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
112229	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
112230	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112231	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112232	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112233	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
112234	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
112235	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
112236	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	0	
112237	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
112238	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
112239	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	38	
112240	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	38	
112241	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
112242	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
112243	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
112244	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
112245	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112246	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112247	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
112248	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
112249	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
112250	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations This Read Vac	0	
112251	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AL	157	
112252	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AF	157	
112253	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
112254	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Maintenance Operations	0	
112255	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Grounds in Place?	y	
112256	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
112257	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
112258	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112259	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112260	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
112261	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112262	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112263	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
112264	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
112265	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
112266	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	110	°C
112267	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
112268	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	120	°C
112269	10/29/2019 10:49	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	70	°C
112270	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
112271	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112272	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112273	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112274	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112275	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112276	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
112277	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations B Ø	0	
112278	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations C Ø	0	
112279	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations Ground	0	
112280	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Follow-up Action Required?	n	
112281	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112282	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112283	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112284	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112285	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
112286	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
112287	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112288	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112289	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
112290	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112291	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112292	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
112293	10/29/2019 14:59	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112294	10/29/2019 14:20	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Follow-up Action Required?	n	
112295	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	94.0	
112296	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
112297	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
112298	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	0	
112299	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	161	
112300	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	162	
112301	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations This Read Vac	1	
112302	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	1	
112303	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
112304	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	87.0	
112305	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
112306	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
112307	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
112308	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	2	
112309	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
112310	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	144.0	
112311	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	99.0	
112312	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	145.0	
112313	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112314	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112315	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112316	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	1.17	%
112317	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	1.52	%
112318	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	5	
112319	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	1.17	%
112320	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	134.0	
112321	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	151.0	
112322	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	132.0	
112323	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112324	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112325	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	172	
112326	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	173	
112327	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations This Read Vac	1	
112328	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	1	
112329	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
112330	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112331	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	0	
112332	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
112333	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	
112334	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
112335	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
112336	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	
112337	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
112338	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112339	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112340	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
112341	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
112342	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
112343	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112344	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
112345	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
112346	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	
112347	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
112348	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
112349	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
112350	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	0	
112351	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	145.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
112352	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	184	
112353	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	185	
112354	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations This Read Vac	1	
112355	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	1	
112356	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
112357	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	2	
112358	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
112359	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
112360	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
112361	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112362	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	1619	
112363	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	9L	
112364	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	4R	
112365	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	3L	
112366	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	32747	
112367	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	32737	
112368	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
112369	8/19/2019 11:58	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
112370	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
112371	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
112372	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	146182	
112373	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	146182	
112374	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112375	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1169	
112376	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
112377	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
112378	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
112379	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112380	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112381	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
112382	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112383	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
112384	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
112385	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
112386	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
112387	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
112388	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
112389	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
112390	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
112391	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
112392	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
112393	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
112394	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments		
112395	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
112396	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
112397	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
112398	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
112399	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
112400	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
112401	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
112402	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
112403	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
112404	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Bushing Condition	Good	
112405	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	123	
112406	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	123	
112407	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read Vac	0	
112408	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
112409	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
112410	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
112411	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	General Comments		
112412	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
112413	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000665	LTCCControl	662-1	LTC Control Insp	All Connections OK?	y	
112414	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
112415	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
112416	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
112417	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
112418	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
112419	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112420	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112421	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
112422	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Unknown Operations	0	
112423	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	
112424	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
112425	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	General Comments		
112426	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112427	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	2718	
112428	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	2718	
112429	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112430	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
112431	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	
112432	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	1	
112433	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations This Read Vac	1	
112434	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	140	
112435	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	140	
112436	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
112437	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	6L	
112438	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	1L	
112439	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	8L	
112440	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	935	
112441	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112442	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Unknown Operations	0	
112443	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations	2	
112444	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
112445	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
112446	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
112447	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
112448	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
112449	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
112450	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
112451	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
112452	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
112453	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112454	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112455	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
112456	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
112457	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
112458	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	476	
112459	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	476	
112460	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
112461	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
112462	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
112463	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112464	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112465	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112466	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112467	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
112468	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
112469	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps C Ø	0.0	
112470	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Fault Operations	0	
112471	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Follow-up Action Required?	n	
112472	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	General Comments		
112473	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Maintenance Operations	0	
112474	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Number of Ops last 9 Months	0	
112475	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AF	1695	
112476	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AL	1695	
112477	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations This Read Oil	0	
112478	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Switching Operations	0	
112479	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Unknown Operations	0	
112480	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
112481	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
112482	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112483	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112484	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112485	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112486	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
112487	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
112488	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
112489	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	354	
112490	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	354	
112491	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
112492	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
112493	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
112494	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
112495	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
112496	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
112497	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
112498	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
112499	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
112500	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
112501	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112502	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
112503	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
112504	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	52.0	
112505	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	66.0	
112506	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	65.0	
112507	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
112508	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
112509	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
112510	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
112511	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
112512	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
112513	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
112514	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
112515	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
112516	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
112517	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
112518	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations This Read Vac	0	
112519	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Switching Operations	0	
112520	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Tank Paint Condition	Good	
112521	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Unknown Operations	0	
112522	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations	2	
112523	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112524	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112525	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112526	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps A Ø	360.0	
112527	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps B Ø	370.0	
112528	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps C Ø	370.0	
112529	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushing Condition	Good	
112530	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
112531	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
112532	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112533	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112534	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112535	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112536	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112537	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112538	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112539	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112540	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112541	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112542	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112543	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112544	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations A Ø	0	
112545	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations B Ø	0	
112546	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations C Ø	0	
112547	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations Ground	0	
112548	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1200	
112549	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
112550	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
112551	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	10L	
112552	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
112553	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
112554	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
112555	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
112556	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
112557	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
112558	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	0	
112559	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
112560	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
112561	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	45	°C
112562	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.8320	
112563	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
112564	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112565	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
112566	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
112567	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112568	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Readings	Follow-up Action Required?	n	
112569	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112570	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112571	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112572	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112573	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
112574	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112575	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	General Comments		
112576	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112577	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112578	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112579	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
112580	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
112581	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	50	°C
112582	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
112583	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	General Comments		
112584	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112585	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	11980.80	kw
112586	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112587	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112588	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112589	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112590	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112591	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps A Ø	0.0	
112592	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112593	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112594	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps B Ø	0.0	
112595	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps C Ø	0.0	
112596	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushing Condition	Good	
112597	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112598	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112599	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112600	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112601	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112602	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112603	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112604	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112605	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112606	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
112607	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
112608	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
112609	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
112610	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
112611	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
112612	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
112613	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
112614	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
112615	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
112616	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
112617	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
112618	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations A Ø	0	
112619	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations B Ø	0	
112620	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations C Ø	0	
112621	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations Ground	0	
112622	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Follow-up Action Required?	n	
112623	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Follow-up Action Required?	n	
112624	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Foundation Condition	Good	
112625	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	General Comments		
112626	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	General Comments		
112627	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Grounds in Place?	y	
112628	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Maintenance Operations	0	
112629	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Moisture and Leak Free?	y	
112630	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AF	195	
112631	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AL	190	
112632	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	6649	
112633	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	6649	
112634	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112635	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC0000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
112636	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC0000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
112637	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC0000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
112638	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
112639	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
112640	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
112641	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
112642	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
112643	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
112644	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
112645	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
112646	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
112647	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
112648	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112649	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112650	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
112651	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112652	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112653	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112654	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112655	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
112656	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
112657	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
112658	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
112659	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
112660	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112661	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
112662	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
112663	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
112664	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
112665	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
112666	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
112667	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
112668	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
112669	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
112670	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
112671	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
112672	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	
112673	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
112674	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	164	
112675	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	164	
112676	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations This Read Vac	0	
112677	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
112678	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	0	
112679	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
112680	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
112681	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Unknown Operations	0	
112682	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Switching Operations	4	
112683	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations This Read Vac	4	
112684	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AL	154	
112685	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AF	154	
112686	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Maintenance Operations	0	
112687	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	General Comments		
112688	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Follow-up Action Required?	n	
112689	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations Ground	0	
112690	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations C Ø	0	
112691	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations B Ø	0	
112692	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations A Ø	0	
112693	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112694	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112695	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112696	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps C Ø	75.0	
112697	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps B Ø	77.0	
112698	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps A Ø	75.0	
112699	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty C Ph V	7.12	%
112700	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty B Ph V	7.12	%
112701	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty A Ph V	7.12	%
112702	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations	8	
112703	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
112704	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
112705	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
112706	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
112707	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
112708	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
112709	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
112710	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
112711	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
112712	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
112713	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
112714	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
112715	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
112716	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
112717	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
112718	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
112719	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112720	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112721	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112722	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112723	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
112724	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112725	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
112726	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112727	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
112728	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112729	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	6583.68	kw
112730	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspei	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
112731	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspei	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
112732	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspei	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		
112733	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspei	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
112734	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112735	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
112736	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
112737	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	50	*C
112738	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	20	*C
112739	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112740	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
112741	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
112742	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112743	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112744	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
112745	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.4572	
112746	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	50	*C
112747	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	25	*C
112748	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
112749	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
112750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps A Ø	0.0	
112751	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps B Ø	0.0	
112752	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps C Ø	0.0	
112753	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Fault Operations	0	
112754	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Follow-up Action Required?	n	
112755	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	General Comments		
112756	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Maintenance Operations	0	
112757	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Number of Ops last 9 Months	1	
112758	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AF	3245	
112759	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AL	3245	
112760	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations This Read Oil	0	
112761	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Switching Operations	0	
112762	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Unknown Operations	0	
112763	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations	4	
112764	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112765	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112766	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112767	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0.0	
112768	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0.0	
112769	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0.0	
112770	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
112771	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112772	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112773	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112774	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112775	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112776	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112777	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112778	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112779	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
112780	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112781	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
112782	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
112783	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112784	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
112785	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112786	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112787	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
112788	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
112789	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112790	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	7981.92	kw
112791	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112792	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
112793	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	65	*C
112794	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	35	*C
112795	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
112796	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
112797	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112798	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112799	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
112800	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
112801	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112802	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112803	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
112804	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112805	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112806	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
112807	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Maintenance Operations	0	
112808	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	General Comments		
112809	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Follow-up Action Required?	n	
112810	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Fault Operations	0	
112811	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps C Ø	10.0	
112812	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps B Ø	10.0	
112813	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps A Ø	10.0	
112814	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.5543	
112815	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
112816	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
112817	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
112818	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
112819	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
112820	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
112821	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112822	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	9676.80	kw
112823	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112824	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	80	°C
112825	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	40	°C
112826	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
112827	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
112828	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.0080	
112829	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
112830	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112831	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112832	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
112833	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112834	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
112835	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
112836	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112837	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	75	°C
112838	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
112839	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
112840	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
112841	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
112842	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Unknown Operations	0	
112843	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Switching Operations	0	
112844	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations This Read Oil	0	
112845	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AL	126	
112846	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AF	126	
112847	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Number of Ops last 9 Months	0	
112848	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
112849	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
112850	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		
112851	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
112852	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Unknown Operations	0	
112853	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Switching Operations	1	
112854	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations This Read Oil	1	
112855	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AL	1478	
112856	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	36555	
112857	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	36555	
112858	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112859	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	7L	
112860	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	3L	
112861	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	8L	
112862	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	870	
112863	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112864	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112865	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112866	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AF	1478	
112867	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Number of Ops last 9 Months	9	
112868	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Maintenance Operations	0	
112869	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	General Comments		
112870	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Follow-up Action Required?	n	
112871	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
112872	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112873	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112874	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
112875	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112876	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
112877	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112878	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112879	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112880	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
112881	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
112882	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
112883	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
112884	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112885	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112886	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Fault Operations	0	
112887	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps C Ø	0.0	
112888	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps B Ø	0.0	
112889	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps A Ø	0.0	
112890	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
112891	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
112892	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
112893	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112894	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
112895	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112896	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112897	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112898	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112899	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
112900	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
112901	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
112902	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
112903	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
112904	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
112905	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1233	
112906	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1233	
112907	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
112908	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
112909	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
112910	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
112911	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112912	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112913	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112914	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
112915	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
112916	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
112917	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
112918	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
112919	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
112920	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
112921	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
112922	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
112923	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
112924	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
112925	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
112926	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
112927	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
112928	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
112929	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
112930	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
112931	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	131.0	
112932	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	117.0	
112933	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	106.0	
112934	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
112935	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
112936	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
112937	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
112938	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	0	
112939	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
112940	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	
112941	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
112942	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
112943	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
112944	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
112945	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
112946	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
112947	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
112948	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
112949	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
112950	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
112951	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
112952	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112953	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112954	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112955	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	1800	
112956	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	10L	
112957	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	100.0	
112958	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	100.0	
112959	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps B Ø	0.0	
112960	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps A Ø	0.0	
112961	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
112962	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
112963	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
112964	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
112965	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
112966	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
112967	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
112968	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
112969	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
112970	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
112971	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
112972	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
112973	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen, oil is seeping from radiator mount on side of the transformer. Pic sent to Stinson	
112974	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
112975	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
112976	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
112977	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
112978	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
112979	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
112980	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
112981	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
112982	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
112983	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
112984	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
112985	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
112986	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
112987	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
112988	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
112989	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	289	
112990	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
112991	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	12L	
112992	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	3L	
112993	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	8L	
112994	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
112995	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	98609	
112996	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	98609	
112997	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
112998	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
112999	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
113000	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
113001	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
113002	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
113003	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
113004	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
113005	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
113006	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
113007	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
113008	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	LTCC000251	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
113009	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
113010	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
113011	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	0	
113012	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
113013	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations This Read Vac	0	
113014	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	403	
113015	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	403	
113016	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
113017	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
113018	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113019	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
113020	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
113021	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
113022	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
113023	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
113024	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
113025	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
113026	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113027	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
113028	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
113029	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
113030	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
113031	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
113032	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
113033	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
113034	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen Bottle refilled, Oil Pump is leaking oil pic sent to Stinson	
113035	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
113036	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
113037	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
113038	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
113039	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	62	°C
113040	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	41	°C
113041	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
113042	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
113043	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
113044	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
113045	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
113046	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
113047	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
113048	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
113049	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
113050	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
113051	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
113052	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
113053	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	42	°C
113054	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	70	°C
113055	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	42	°C
113056	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	67	°C
113057	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	42	°C
113058	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
113059	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
113060	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
113061	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
113062	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
113063	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
113064	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
113065	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
113066	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
113067	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
113068	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
113069	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
113070	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
113071	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
113072	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
113073	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
113074	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
113075	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
113076	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113077	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113078	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113079	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	100.0	
113080	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113081	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113082	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113083	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	8	
113084	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	4R	
113085	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	7L	
113086	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
113087	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	140420	
113088	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	140420	
113089	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
113090	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
113091	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
113092	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
113093	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113094	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113095	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
113096	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
113097	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113098	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	27.9	%
113099	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	27.1	%
113100	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	0	
113101	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113102	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113103	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113104	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	85.0	
113105	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	85.0	
113106	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	85.0	
113107	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113108	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
113109	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
113110	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
113111	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113112	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
113113	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113114	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113115	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
113116	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
113117	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
113118	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
113119	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
113120	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	142	
113121	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
113122	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
113123	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
113124	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
113125	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	142	
113126	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
113127	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
113128	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
113129	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
113130	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113131	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113132	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113133	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113134	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113135	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113136	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113137	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
113138	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113139	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
113140	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	0	
113141	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
113142	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
113143	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
113144	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
113145	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
113146	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
113147	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
113148	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
113149	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations B Ø	0	
113150	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations A Ø	0	
113151	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113152	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113153	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113154	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113155	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113156	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113157	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113158	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113159	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113160	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
113161	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps C Ø	0.0	
113162	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps B Ø	0.0	
113163	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps A Ø	0.0	
113164	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113165	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113166	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113167	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations	3	
113168	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Unknown Operations	0	
113169	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Tank Paint Condition	Good	
113170	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Switching Operations	2	
113171	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations This Read Vac	2	
113172	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AL	195	
113173	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AF	195	
113174	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Moisture and Leak Free?	y	
113175	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Maintenance Operations	0	
113176	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113177	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	General Comments		
113178	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	General Comments		
113179	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
113180	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
113181	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
113182	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
113183	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
113184	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
113185	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113186	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113187	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113188	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
113189	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
113190	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113191	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps A Ø	257.0	
113192	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps B Ø	275.0	
113193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps C Ø	282.0	
113194	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Fault Operations	0	
113195	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Follow-up Action Required?	n	
113196	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	General Comments		
113197	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Maintenance Operations	0	
113198	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Number of Ops last 9 Months	6	
113199	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AF	1081	
113200	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AL	1081	
113201	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations This Read Oil	0	
113202	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Switching Operations	0	
113203	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Unknown Operations	0	
113204	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
113205	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113206	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
113207	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
113208	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
113209	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113210	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	230.0	
113211	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	227.0	
113212	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	196.0	
113213	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113214	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113215	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113216	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
113217	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	285.0	
113218	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	280.0	
113219	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	275.0	
113220	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113221	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113222	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113223	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	2	
113224	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
113225	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
113226	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	2	
113227	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations This Read Vac	2	
113228	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	174	
113229	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	174	
113230	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
113231	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113232	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113233	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113234	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113235	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113236	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113237	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushing Condition	Good	
113238	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps C Ø	155.0	
113239	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps B Ø	150.0	
113240	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps A Ø	155.0	
113241	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113242	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
113243	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
113244	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations	4	
113245	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Unknown Operations	0	
113246	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
113247	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113248	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	15.0	
113249	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	9.0	
113250	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	14.0	
113251	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113252	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113253	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113254	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
113255	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
113256	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
113257	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
113258	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
113259	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	186	
113260	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
113261	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	7L	
113262	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	2R	
113263	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	6L	
113264	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
113265	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	16842	
113266	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	16842	
113267	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
113268	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
113269	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
113270	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
113271	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Tank Paint Condition	Good	
113272	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Switching Operations	2	
113273	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations This Read Vac	2	
113274	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AL	175	
113275	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
113276	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
113277	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
113278	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
113279	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
113280	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113281	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Foundation Condition	Good	
113282	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Follow-up Action Required?	n	
113283	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Follow-up Action Required?	n	
113284	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations Ground	0	
113285	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations C Ø	0	
113286	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations B Ø	0	
113287	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations A Ø	0	
113288	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113289	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113290	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113291	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113292	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
113293	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
113294	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
113295	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
113296	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
113297	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
113298	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
113299	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
113300	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
113301	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
113302	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
113303	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
113304	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
113305	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
113306	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
113307	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
113308	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
113309	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	814	
113310	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	814	
113311	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
113312	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
113313	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
113314	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
113315	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
113316	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113317	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113318	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
113319	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113320	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0091	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
113321	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Fault Operations	0	
113322	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Follow-up Action Required?	n	
113323	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	General Comments		
113324	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Maintenance Operations	0	
113325	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Number of Ops last 9 Months	3	
113326	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AF	1157	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113327	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AL	1157	
113328	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations This Read Oil	2	
113329	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Switching Operations	0	
113330	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Unknown Operations	2	
113331	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
113332	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
113333	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
113334	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
113335	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
113336	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
113337	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
113338	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
113339	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
113340	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
113341	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
113342	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
113343	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
113344	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
113345	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113346	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113347	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113348	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113349	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113350	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113351	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113352	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113353	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
113354	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
113355	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.5840	
113356	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
113357	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
113358	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
113359	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
113360	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
113361	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
113362	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
113363	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
113364	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Max	50	°C
113365	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
113366	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
113367	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
113368	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
113369	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
113370	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
113371	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
113372	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
113373	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
113374	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
113375	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
113376	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
113377	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
113378	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
113379	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
113380	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
113381	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
113382	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
113383	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
113384	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
113385	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113386	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen	
113387	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
113388	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
113389	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
113390	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
113391	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
113392	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113393	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
113394	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113395	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113396	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113397	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113398	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113399	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113400	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113401	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113402	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
113403	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
113404	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
113405	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
113406	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
113407	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
113408	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
113409	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps A Ø	0.0	
113410	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps B Ø	0.0	
113411	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps C Ø	0.0	
113412	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
113413	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
113414	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
113415	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113416	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
113417	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113418	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113419	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113420	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113421	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113422	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113423	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113424	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
113425	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
113426	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
113427	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
113428	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
113429	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
113430	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	135	
113431	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	135	
113432	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
113433	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
113434	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113435	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
113436	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
113437	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
113438	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
113439	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
113440	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
113441	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
113442	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
113443	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
113444	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
113445	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113446	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113447	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113448	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113449	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113450	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113451	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113452	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113453	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113454	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
113455	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
113456	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
113457	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
113458	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	LTC Totalizer Reading	2803.20	kw
113459	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
113460	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	General Comments		
113461	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	General Comments		
113462	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
113463	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
113464	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	Follow-up Action Required?	n	
113465	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
113466	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
113467	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
113468	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113469	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113470	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113471	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113472	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113473	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113474	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113475	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113476	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	B0281	WithLTC	662-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113477	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
113478	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
113479	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	35	°C
113480	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	70	°C
113481	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.3840	
113482	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
113483	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
113484	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
113485	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
113486	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
113487	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
113488	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
113489	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
113490	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
113491	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
113492	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	30	°C
113493	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	60	°C
113494	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
113495	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
113496	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	9216.00	kw
113497	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
113498	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
113499	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
113500	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
113501	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
113502	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
113503	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
113504	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	General Comments		
113505	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
113506	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
113507	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113508	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
113509	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
113510	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99778	
113511	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99778	
113512	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Operations This Read Vac	0	
113513	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
113514	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	0	
113515	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
113516	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	0	
113517	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations B Ø	0	
113518	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations A Ø	0	
113519	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	2	
113520	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
113521	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
113522	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	896	
113523	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	896	
113524	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
113525	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
113526	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
113527	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
113528	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113529	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113530	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113531	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113532	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113533	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113534	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113535	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113536	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113537	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushing Condition	Good	
113538	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps C Ø	40.0	
113539	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps B Ø	55.0	
113540	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps A Ø	30.0	
113541	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113542	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113543	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113544	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	9 Month Operations	3	
113545	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Unknown Operations	0	
113546	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Tank Paint Condition	Good	
113547	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
113548	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	1	
113549	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	551	
113550	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	551	
113551	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113552	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
113553	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
113554	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
113555	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
113556	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
113557	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
113558	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
113559	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
113560	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
113561	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
113562	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
113563	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113564	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	510.0	
113565	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	492.0	
113566	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	486.0	
113567	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113568	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113569	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113570	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	2	
113571	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	10	
113572	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113573	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113574	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113575	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps Ø	80.0	
113576	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	90.0	
113577	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	90.0	
113578	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
113579	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113580	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113581	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113582	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113583	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113584	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113585	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113586	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113587	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113588	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	0	
113589	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	0	
113590	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
113591	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
113592	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
113593	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
113594	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations Ground	0	
113595	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations C Ø	0	
113596	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations B Ø	0	
113597	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations A Ø	0	
113598	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113599	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113600	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113601	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113602	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113603	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113604	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113605	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113606	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113607	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps C Ø	295.0	
113608	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps B Ø	310.0	
113609	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps A Ø	280.0	
113610	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113611	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113612	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113613	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations	4	
113614	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
113615	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
113616	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
113617	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	645	
113618	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	645	
113619	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
113620	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
113621	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
113622	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
113623	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
113624	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113625	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113626	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113627	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113628	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
113629	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
113630	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
113631	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113632	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	367.0	
113633	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	320.0	
113634	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	386.0	
113635	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113636	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113637	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113638	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
113639	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113640	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113641	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
113642	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113643	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
113644	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
113645	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
113646	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113647	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	115.0	
113648	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	102.0	
113649	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
113650	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
113651	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
113652	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
113653	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
113654	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
113655	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
113656	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
113657	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
113658	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
113659	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
113660	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
113661	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
113662	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
113663	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
113664	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
113665	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
113666	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
113667	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
113668	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	126.0	
113669	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113670	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113671	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113672	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
113673	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Switching Operations	2	
113674	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations This Read Vac	2	
113675	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AL	179	
113676	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AF	179	
113677	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Moisture and Leak Free?	y	
113678	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Maintenance Operations	0	
113679	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Grounds in Place?	y	
113680	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	General Comments		
113681	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
113682	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
113683	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
113684	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
113685	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps B Ø	0.0	
113686	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps A Ø	0.0	
113687	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	6.45	%
113688	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	6.45	%
113689	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	6.45	%
113690	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations	1	
113691	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113692	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113693	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
113694	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
113695	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	0	
113696	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
113697	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations This Read Vac	0	
113698	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	156	
113699	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	156	
113700	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
113701	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113702	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113703	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
113704	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
113705	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
113706	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
113707	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
113708	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
113709	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
113710	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
113711	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
113712	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
113713	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113714	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113715	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113716	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113717	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113718	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113719	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113720	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113721	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113722	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
113723	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	275.0	
113724	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	245.0	
113725	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113726	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113727	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113728	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushing Condition	Good	
113729	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps C Ø	100.0	
113730	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AF	175	
113731	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Moisture and Leak Free?	y	
113732	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Maintenance Operations	0	
113733	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Grounds in Place?	y	
113734	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	General Comments		
113735	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	General Comments		
113736	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Foundation Condition	Good	
113737	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Follow-up Action Required?	n	
113738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps A Ø	0.0	
113739	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps B Ø	0.0	
113740	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps C Ø	0.0	
113741	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Fault Operations	0	
113742	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Follow-up Action Required?	n	
113743	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	General Comments		
113744	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Maintenance Operations	0	
113745	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Number of Ops last 9 Months	0	
113746	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AF	1163	
113747	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AL	1163	
113748	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations This Read Oil	0	
113749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Switching Operations	0	
113750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Unknown Operations	0	
113751	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Follow-up Action Required?	n	
113752	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations Ground	0	
113753	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations C Ø	0	
113754	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations B Ø	0	
113755	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations A Ø	0	
113756	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Unknown Operations	0	
113757	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Switching Operations	0	
113758	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations This Read Vac	0	
113759	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AL	746	
113760	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AF	746	
113761	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Maintenance Operations	0	
113762	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	General Comments		
113763	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Follow-up Action Required?	n	
113764	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations Ground	0	
113765	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations C Ø	0	
113766	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations B Ø	0	
113767	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations A Ø	0	
113768	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113769	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113770	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113771	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113772	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113773	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113774	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113775	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps C Ø	0.0	
113776	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	460.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113777	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	500.0	
113778	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	480.0	
113779	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
113780	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
113781	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
113782	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
113783	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Operations This Read Vac	0	
113784	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	120	
113785	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	120	
113786	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
113787	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
113788	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113789	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
113790	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
113791	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
113792	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
113793	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
113794	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
113795	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
113796	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
113797	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
113798	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
113799	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113800	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113801	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113802	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113803	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113804	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113805	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113806	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113807	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113808	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
113809	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps C Ø	320.0	
113810	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps B Ø	320.0	
113811	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Amps A Ø	320.0	
113812	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113813	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113814	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113815	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
113816	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
113817	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
113818	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
113819	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
113820	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Unknown Operations	1	
113821	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
113822	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps B Ø	90.0	
113823	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps A Ø	95.0	
113824	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113825	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113826	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113827	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations	2	
113828	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Unknown Operations	0	
113829	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Tank Paint Condition	Good	
113830	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Switching Operations	3	
113831	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations This Read Vac	3	
113832	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	265.0	
113833	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113834	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113835	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
113836	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	2	
113837	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AL	199	
113838	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AF	199	
113839	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Moisture and Leak Free?	y	
113840	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Maintenance Operations	0	
113841	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113842	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Grounds in Place?	y	
113843	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	General Comments		
113844	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	General Comments		
113845	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Foundation Condition	Good	
113846	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Follow-up Action Required?	n	
113847	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Follow-up Action Required?	n	
113848	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations Ground	0	
113849	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations C Ø	0	
113850	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
113851	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113852	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
113853	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	417	
113854	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	417	
113855	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
113856	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
113857	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
113858	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
113859	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
113860	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
113861	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
113862	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
113863	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
113864	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
113865	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
113866	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
113867	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113868	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
113869	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113870	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	264.0	
113871	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	261.0	
113872	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	242.0	
113873	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113874	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113875	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113876	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113877	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
113878	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
113879	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
113880	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
113881	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
113882	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
113883	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
113884	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
113885	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
113886	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
113887	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
113888	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
113889	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
113890	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Unknown Operations	0	
113891	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	13	
113892	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
113893	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	14.45	%
113894	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	16.86	%
113895	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	440.0	
113896	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	520.0	
113897	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	450.0	
113898	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
113899	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
113900	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
113901	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
113902	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
113903	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
113904	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
113905	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
113906	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
113907	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
113908	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
113909	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
113910	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
113911	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	44	
113912	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	44	
113913	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
113914	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
113915	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
113916	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
113917	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
113918	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
113919	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
113920	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
113921	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
113922	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
113923	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
113924	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
113925	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
113926	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	10.3	amps

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
113927	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
113928	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
113929	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.500	millivolts
113930	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	0	
113931	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
113932	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
113933	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
113934	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	174.0	
113935	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	164.0	
113936	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	160.0	
113937	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113938	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113939	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113940	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113941	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
113942	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
113943	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
113944	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
113945	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
113946	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
113947	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
113948	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
113949	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
113950	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	547	
113951	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	547	
113952	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
113953	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
113954	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Unknown Operations	0	
113955	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
113956	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
113957	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
113958	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
113959	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	210	
113960	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
113961	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
113962	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
113963	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
113964	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
113965	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
113966	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
113967	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
113968	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
113969	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
113970	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
113971	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
113972	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
113973	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
113974	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
113975	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
113976	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
113977	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
113978	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
113979	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
113980	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
113981	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
113982	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
113983	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
113984	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
113985	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
113986	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Unknown Operations	0	
113987	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
113988	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
113989	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	576	
113990	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	576	
113991	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
113992	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
113993	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
113994	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
113995	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
113996	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
113997	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
113998	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
113999	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114000	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114001	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
114002	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
114003	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
114004	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	0	
114005	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
114006	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Unknown Operations	0	
114007	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
114008	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
114009	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
114010	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
114011	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Follow-up Action Required?	n	
114012	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
114013	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	General Comments		
114014	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
114015	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Found Counter	7549	
114016	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Left Counter	7549	
114017	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
114018	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Current Tap Position	5L	
114019	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Max Tap Position	5L	
114020	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Min Tap Position	8L	
114021	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Operations Since Last Insp	1219	
114022	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
114023	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
114024	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
114025	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
114026	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
114027	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
114028	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
114029	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
114030	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
114031	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
114032	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
114033	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
114034	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
114035	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
114036	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
114037	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
114038	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
114039	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
114040	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
114041	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	798	
114042	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	798	
114043	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
114044	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
114045	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
114046	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
114047	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114048	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
114049	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0341	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	210	
114050	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
114051	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	5380	
114052	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	5380	
114053	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
114054	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
114055	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
114056	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
114057	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
114058	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
114059	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
114060	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
114061	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
114062	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
114063	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
114064	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
114065	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
114066	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	General Comments		
114067	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
114068	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
114069	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
114070	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	1211	
114071	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
114072	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	16L	
114073	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	4R	
114074	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	10L	
114075	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
114076	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	16101	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114077	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	16101	
114078	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
114079	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
114080	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
114081	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
114082	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
114083	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
114084	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Leaks	None	
114085	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
114086	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
114087	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114088	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
114089	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
114090	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
114091	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
114092	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
114093	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
114094	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
114095	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Tank Paint Condition	Good	
114096	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Switching Operations	2	
114097	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations This Read Vac	2	
114098	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AL	176	
114099	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AF	176	
114100	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Moisture and Leak Free?	y	
114101	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Maintenance Operations	0	
114102	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Grounds in Place?	y	
114103	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	General Comments		
114104	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	General Comments		
114105	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Foundation Condition	Good	
114106	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Follow-up Action Required?	n	
114107	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Follow-up Action Required?	n	
114108	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations Ground	0	
114109	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations C Ø	0	
114110	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations B Ø	0	
114111	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations A Ø	0	
114112	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114113	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114114	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114115	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114116	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114117	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114118	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114119	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114120	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114121	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushing Condition	Good	
114122	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps C Ø	65.0	
114123	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps B Ø	50.0	
114124	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps A Ø	70.0	
114125	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114126	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114127	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114128	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	2	
114129	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
114130	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
114131	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
114132	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
114133	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	1086	
114134	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	21	°C
114135	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
114136	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
114137	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
114138	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	12L	
114139	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	3L	
114140	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	10L	
114141	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
114142	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None		
114143	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
114144	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	35		°C
114145	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0		psi
114146	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
114147	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	13708.80		kw
114148	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y		
114149	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Readings	General Comments			
114150	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Insp: S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments			
114151	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Unknown Operations	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114152	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Switching Operations	0	
114153	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations This Read Oil	4	
114154	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AL	702	
114155	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AF	702	
114156	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Number of Ops last 9 Months	5	
114157	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Maintenance Operations	0	
114158	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	General Comments		
114159	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Follow-up Action Required?	n	
114160	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Fault Operations	0	
114161	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps C Ø	0.0	
114162	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps B Ø	0.0	
114163	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps A Ø	0.0	
114164	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
114165	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
114166	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
114167	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
114168	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
114169	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
114170	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
114171	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
114172	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
114173	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
114174	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
114175	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
114176	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
114177	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
114178	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
114179	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
114180	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
114181	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
114182	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
114183	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
114184	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
114185	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
114186	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
114187	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
114188	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
114189	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	26	°C
114190	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Unknown Operations	0	
114191	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Switching Operations	0	
114192	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations This Read Oil	0	
114193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AL	1465	
114194	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AF	1465	
114195	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Number of Ops last 9 Months	2	
114196	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Maintenance Operations	0	
114197	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	General Comments		
114198	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Follow-up Action Required?	n	
114199	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Fault Operations	0	
114200	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps C Ø	303.0	
114201	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps B Ø	291.0	
114202	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps A Ø	278.0	
114203	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	49	°C
114204	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.3640	
114205	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
114206	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
114207	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
114208	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
114209	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
114210	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
114211	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
114212	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114213	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
114214	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
114215	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	26	°C
114216	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	49	°C
114217	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
114218	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
114219	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
114220	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	8736.00	kw
114221	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
114222	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
114223	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
114224	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
114225	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	55	°C
114226	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.9520	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
114227	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
114228	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
114229	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
114230	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
114231	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
114232	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
114233	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
114234	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
114235	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
114236	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
114237	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
114238	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
114239	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
114240	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
114241	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	223	
114242	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	223	
114243	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
114244	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
114245	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
114246	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
114247	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
114248	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	General Comments		
114249	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
114250	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
114251	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
114252	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
114253	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
114254	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
114255	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
114256	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
114257	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114258	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114259	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
114260	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
114261	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
114262	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
114263	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
114264	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
114265	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0388	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
114266	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
114267	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
114268	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Reading	.8300	
114269	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
114270	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
114271	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
114272	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
114273	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
114274	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
114275	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
114276	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114277	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Follow-up Action Required?	n	
114278	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	General Comments		
114279	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Maintenance Operations	0	
114280	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Number of Ops last 9 Months	0	
114281	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AF	1831	
114282	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AL	1831	
114283	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations This Read Oil	0	
114284	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Switching Operations	0	
114285	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
114286	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
114287	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC000774	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
114288	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
114289	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Unknown Operations	0	
114290	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114291	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114292	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114293	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
114294	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
114295	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
114296	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
114297	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114298	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114299	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114300	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114301	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114302	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114303	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114304	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114305	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114306	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
114307	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
114308	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
114309	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
114310	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
114311	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
114312	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
114313	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
114314	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
114315	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
114316	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
114317	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
114318	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
114319	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	955	
114320	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	955	
114321	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
114322	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
114323	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AL	177	
114324	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AF	177	
114325	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
114326	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Maintenance Operations	0	
114327	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Grounds in Place?	y	
114328	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	General Comments		
114329	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	General Comments		
114330	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Foundation Condition	Good	
114331	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Follow-up Action Required?	n	
114332	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Follow-up Action Required?	n	
114333	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations Ground	0	
114334	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations C Ø	0	
114335	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations B Ø	0	
114336	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations A Ø	0	
114337	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114338	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114339	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114340	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114341	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114342	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114343	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114344	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114345	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114346	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
114347	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
114348	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
114349	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
114350	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	467	
114351	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	467	
114352	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
114353	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
114354	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
114355	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
114356	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
114357	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
114358	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
114359	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
114360	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
114361	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
114362	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
114363	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
114364	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
114365	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
114366	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
114367	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
114368	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Oil Temp Max	55	*C
114369	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
114370	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
114371	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	LTC Totalizer Reading	7968.00	kw
114372	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
114373	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	General Comments		
114374	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	General Comments		
114375	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
114376	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114377	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Follow-up Action Required?	n	
114378	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
114379	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
114380	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
114381	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
114382	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
114383	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
114384	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
114385	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
114386	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
114387	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
114388	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
114389	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
114390	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
114391	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
114392	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
114393	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
114394	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
114395	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
114396	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114397	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
114398	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
114399	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
114400	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
114401	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
114402	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Unknown Operations	0	
114403	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Tank Paint Condition	Good	
114404	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
114405	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
114406	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
114407	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
114408	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
114409	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
114410	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
114411	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
114412	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Switching Operations	1	
114413	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations This Read Vac	1	
114414	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114415	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
114416	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
114417	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
114418	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
114419	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
114420	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
114421	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
114422	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
114423	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	General Comments		
114424	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
114425	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
114426	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
114427	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
114428	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
114429	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	229	
114430	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	229	
114431	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
114432	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
114433	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
114434	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
114435	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
114436	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
114437	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	B80213	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
114438	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
114439	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
114440	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
114441	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
114442	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
114443	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
114444	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114445	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
114446	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114447	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114448	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114449	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114450	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114451	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	B80282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114452	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	9 Month Operations	8	
114453	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114454	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114455	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114456	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps A Ø	85.0	
114457	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps B Ø	75.0	
114458	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps C Ø	85.0	
114459	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
114460	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114461	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
114462	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	48	
114463	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	48	
114464	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
114465	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
114466	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
114467	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
114468	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
114469	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
114470	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
114471	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
114472	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
114473	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114474	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114475	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114476	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114477	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	113.0	
114478	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	112.0	
114479	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	116.0	
114480	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	74.94	%
114481	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	74.94	%
114482	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	69.36	%
114483	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	11	
114484	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Unknown Operations	0	
114485	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Switching Operations	0	
114486	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations This Read Oil	0	
114487	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AL	1161	
114488	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AF	1161	
114489	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Number of Ops last 9 Months	3	
114490	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Maintenance Operations	0	
114491	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	General Comments		
114492	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Follow-up Action Required?	n	
114493	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Fault Operations	0	
114494	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps C Ø	270.0	
114495	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps B Ø	267.0	
114496	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps A Ø	245.0	
114497	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	200.0	
114498	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	200.0	
114499	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	200.0	
114500	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
114501	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
114502	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
114503	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
114504	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0213	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114505	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114506	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114507	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114508	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114509	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114510	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114511	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114512	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114513	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114514	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
114515	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
114516	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
114517	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
114518	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
114519	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
114520	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
114521	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
114522	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
114523	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
114524	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
114525	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
114526	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114527	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	125	
114528	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	125	
114529	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
114530	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114531	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
114532	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
114533	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
114534	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	All Connections OK?	y	
114535	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	Follow-up Action Required?	n	
114536	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	General Comments		
114537	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	LTC Operation Checked?	y	
114538	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
114539	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
114540	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
114541	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000772	LTCControl	314-2	LTC Control Insp	VRR Time Delay	30	Seconds
114542	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000774	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
114543	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000774	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
114544	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000774	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
114545	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
114546	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	LTC0000774	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
114547	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps A Ø	0.0	
114548	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps B Ø	0.0	
114549	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps C Ø	0.0	
114550	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Fault Operations	0	
114551	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushing Condition	Good	
114552	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114553	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114554	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114555	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114556	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114557	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114558	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114559	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114560	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114561	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations A Ø	0	
114562	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations B Ø	0	
114563	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations C Ø	0	
114564	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations Ground	0	
114565	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Follow-up Action Required?	n	
114566	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Follow-up Action Required?	n	
114567	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Foundation Condition	Good	
114568	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	General Comments		
114569	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	General Comments		
114570	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Grounds in Place?	y	
114571	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Maintenance Operations	0	
114572	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Moisture and Leak Free?	y	
114573	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AF	329	
114574	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AL	329	
114575	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations This Read Vac	0	
114576	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114577	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Switching Operations	0	
114578	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Tank Paint Condition	Good	
114579	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Unknown Operations	0	
114580	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114581	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
114582	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
114583	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
114584	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
114585	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114586	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114587	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114588	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
114589	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
114590	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114591	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114592	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114593	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	340.0	
114594	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	340.0	
114595	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	340.0	
114596	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
114597	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	General Comments		
114598	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
114599	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Foundation Condition	Good	
114600	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Follow-up Action Required?	n	
114601	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114602	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations Ground	0	
114603	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations C Ø	0	
114604	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations B Ø	0	
114605	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations A Ø	0	
114606	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114607	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114608	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114609	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114610	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114611	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
114612	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
114613	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
114614	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
114615	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
114616	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
114617	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
114618	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
114619	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
114620	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
114621	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
114622	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
114623	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
114624	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
114625	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
114626	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114627	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114628	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114629	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114630	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
114631	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
114632	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
114633	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
114634	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114635	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114636	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114637	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	8	
114638	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
114639	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
114640	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
114641	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
114642	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
114643	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
114644	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
114645	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
114646	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
114647	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
114648	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
114649	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
114650	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
114651	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
114652	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
114653	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
114654	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
114655	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
114656	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
114657	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
114658	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
114659	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
114660	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
114661	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
114662	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
114663	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	0.0	
114664	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	0.0	
114665	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	0.0	
114666	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114667	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114668	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114669	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	8	
114670	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
114671	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114672	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114673	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114674	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114675	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
114676	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	130.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
114677	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	133.0	
114678	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	137.0	
114679	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114680	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114681	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114682	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	*F
114683	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
114684	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	12	
114685	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
114686	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
114687	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
114688	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
114689	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	777	
114690	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	777	
114691	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
114692	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
114693	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
114694	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
114695	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
114696	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
114697	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
114698	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
114699	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
114700	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
114701	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
114702	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
114703	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
114704	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
114705	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
114706	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Unknown Operations	0	
114707	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
114708	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
114709	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
114710	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
114711	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
114712	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BCH000519	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
114713	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
114714	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
114715	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
114716	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
114717	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	95.0	
114718	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Tank Paint Condition	Good	
114719	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Switching Operations	0	
114720	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114721	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations This Read Vac	0	
114722	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AL	226	
114723	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AF	226	
114724	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Moisture and Leak Free?	y	
114725	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Readings	Maintenance Operations	0	
114726	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
114727	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Grounds in Place?	y	
114728	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
114729	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
114730	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
114731	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
114732	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
114733	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
114734	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
114735	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
114736	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
114737	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
114738	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
114739	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
114740	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
114741	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
114742	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitrogen, Radiators are leaking oil. Pic sent to Stinson	
114743	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
114744	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
114745	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
114746	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114747	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
114748	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
114749	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
114750	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
114751	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114752	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
114753	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps A Ø	50.0	
114754	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps B Ø	50.0	
114755	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps C Ø	50.0	
114756	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Fault Operations	0	
114757	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Follow-up Action Required?	n	
114758	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	General Comments		
114759	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Maintenance Operations	0	
114760	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Number of Ops last 9 Months	2	
114761	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AF	1047	
114762	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AL	1047	
114763	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations This Read Oil	2	
114764	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Switching Operations	0	
114765	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Unknown Operations	2	
114766	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
114767	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
114768	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
114769	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114770	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114771	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
114772	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
114773	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
114774	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
114775	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
114776	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
114777	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
114778	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
114779	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
114780	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
114781	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
114782	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
114783	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
114784	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
114785	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
114786	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
114787	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
114788	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
114789	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
114790	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
114791	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
114792	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
114793	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
114794	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
114795	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
114796	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
114797	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		If no, which cells in comments
114798	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
114799	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
114800	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
114801	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
114802	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
114803	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
114804	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
114805	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
114806	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
114807	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BAT000025	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
114808	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
114809	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
114810	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
114811	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
114812	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	General Comments		
114813	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
114814	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
114815	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
114816	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
114817	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
114818	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
114819	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
114820	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
114821	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
114822	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
114823	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
114824	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
114825	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
114826	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
114827	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
114828	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
114829	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
114830	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
114831	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
114832	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
114833	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
114834	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
114835	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
114836	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
114837	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
114838	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
114839	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
114840	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
114841	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
114842	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
114843	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
114844	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
114845	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
114846	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
114847	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
114848	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
114849	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
114850	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
114851	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
114852	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	
114853	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
114854	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
114855	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
114856	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
114857	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
114858	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
114859	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
114860	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
114861	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
114862	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
114863	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	844	
114864	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	844	
114865	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
114866	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
114867	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
114868	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
114869	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
114870	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
114871	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
114872	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
114873	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
114874	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
114875	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
114876	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
114877	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
114878	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
114879	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
114880	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
114881	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
114882	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
114883	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
114884	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
114885	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
114886	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
114887	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
114888	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	847	
114889	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	847	
114890	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
114891	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
114892	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
114893	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114894	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114895	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
114896	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
114897	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
114898	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
114899	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
114900	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114901	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
114902	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
114903	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
114904	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
114905	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
114906	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
114907	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
114908	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	General Comments	Actual counter	
114909	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps A Ø	0.0	
114910	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps B Ø	0.0	
114911	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps C Ø	0.0	
114912	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Fault Operations	0	
114913	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Follow-up Action Required?	n	
114914	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	General Comments		
114915	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Maintenance Operations	0	
114916	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Number of Ops last 9 Months	0	
114917	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AF	5489	
114918	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AL	5489	
114919	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations This Read Oil	0	
114920	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Switching Operations	0	
114921	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	44	
114922	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	44	
114923	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
114924	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
114925	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	63.84	%
114926	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	VRR Time Delay	30	Seconds
114927	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
114928	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
114929	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
114930	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	LTC Operation Checked?	y	
114931	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	General Comments		
114932	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	Follow-up Action Required?	n	
114933	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	LTC0000690	LTCControl	621-1	LTC Control Insp	All Connections OK?	y	
114934	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	49.38	%
114935	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	260.0	
114936	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	280.0	
114937	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	260.0	
114938	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
114939	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
114940	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
114941	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
114942	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
114943	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
114944	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
114945	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
114946	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
114947	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
114948	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
114949	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments	260	
114950	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
114951	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	88.0	
114952	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
114953	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	579	
114954	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	579	
114955	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	0	
114956	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
114957	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Unknown Operations	0	
114958	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	97.0	
114959	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	81.0	
114960	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
114961	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
114962	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
114963	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
114964	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
114965	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
114966	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
114967	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
114968	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
114969	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
114970	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
114971	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
114972	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
114973	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
114974	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
114975	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
114976	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
114977	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
114978	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
114979	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
114980	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
114981	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
114982	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
114983	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
114984	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
114985	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
114986	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
114987	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
114988	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
114989	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
114990	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
114991	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	24	
114992	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	1	
114993	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
114994	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	0	
114995	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
114996	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations This Read Vac	1	
114997	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	210	
114998	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	210	
114999	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
115000	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
115001	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115002	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
115003	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
115004	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
115005	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
115006	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
115007	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
115008	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
115009	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
115010	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
115011	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
115012	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	8.00	
115013	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
115014	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
115015	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115016	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
115017	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
115018	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
115019	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
115020	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
115021	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
115022	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
115023	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
115024	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
115025	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
115026	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
115027	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
115028	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	0	
115029	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
115030	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	0	
115031	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115032	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations This Read Vac	0	
115033	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	30	
115034	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	30	
115035	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
115036	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
115037	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115038	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	
115039	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
115040	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
115041	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
115042	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
115043	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	
115044	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
115045	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	0	
115046	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
115047	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	0	
115048	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115049	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115050	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115051	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115052	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115053	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115054	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115055	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115056	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115057	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115058	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
115059	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Unknown Operations	0	
115060	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	2	
115061	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
115062	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
115063	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	0	
115064	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115065	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	2	
115066	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	211	
115067	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	211	
115068	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
115069	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
115070	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115071	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
115072	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
115073	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
115074	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
115075	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
115076	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
115077	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
115078	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
115079	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
115080	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
115081	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
115082	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
115083	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
115084	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
115085	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
115086	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
115087	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
115088	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115089	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115090	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115091	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115092	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115093	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115094	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115095	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115096	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115097	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
115098	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
115099	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
115100	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
115101	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
115102	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
115103	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115104	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0233	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
115105	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
115106	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
115107	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
115108	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
115109	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115110	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115111	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115112	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115113	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115114	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115115	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
115116	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
115117	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	46.0	
115118	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	42.0	
115119	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	45.0	
115120	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
115121	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
115122	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty B Ph V	27.36	%
115124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty C Ph V	4.21	%
115125	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps A Ø	10.0	
115126	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115127	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
115128	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
115129	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
115130	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1880	
115131	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	12L	
115132	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	2R	
115133	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	10L	
115134	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
115135	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	174097	
115136	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	174097	
115137	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
115138	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
115139	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
115140	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
115141	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
115142	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
115143	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
115144	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2070	
115145	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
115146	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14R	
115147	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
115148	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	13R	
115149	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
115150	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	165716	
115151	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	165716	
115152	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
115153	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps B Ø	10.0	
115154	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps C Ø	10.0	
115155	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115156	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
115157	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
115158	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
115159	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
115160	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
115161	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
115162	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
115163	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
115164	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
115165	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
115166	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
115167	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
115168	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
115169	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
115170	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations	5	
115171	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty A Ph V	3.17	%
115172	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty B Ph V	3.17	%
115173	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty C Ph V	3.17	%
115174	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps A Ø	0.0	
115175	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps B Ø	0.0	
115176	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps C Ø	0.0	
115177	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115178	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
115179	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
115180	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
115181	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
115182	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
115183	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
115184	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	5129	
115185	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
115186	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
115187	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
115188	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
115189	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
115190	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
115191	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
115192	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
115193	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
115194	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
115195	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
115196	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
115197	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
115198	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
115199	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
115200	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
115201	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115202	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
115203	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
115204	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
115205	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
115206	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
115207	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
115208	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
115209	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
115210	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	243.0	
115211	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	246.0	
115212	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	246.0	
115213	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
115214	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
115215	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
115216	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
115217	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
115218	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
115219	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
115220	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
115221	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
115222	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
115223	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
115224	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
115225	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
115226	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
115227	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
115228	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
115229	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
115230	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
115231	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BCH000373	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
115232	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
115233	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
115234	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
115235	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
115236	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
115237	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
115238	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
115239	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
115240	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
115241	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
115242	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
115243	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
115244	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
115245	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
115246	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
115247	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
115248	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
115249	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
115250	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
115251	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115252	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations	1	
115253	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty A Ph V	27.36	%
115254	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	315	
115255	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	315	
115256	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Operations This Read Vac	3	
115257	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115258	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115259	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
115260	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
115261	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
115262	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	0	
115263	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
115264	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
115265	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
115266	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
115267	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
115268	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
115269	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
115270	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
115271	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
115272	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
115273	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
115274	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115275	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115276	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115277	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
115278	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
115279	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
115280	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
115281	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
115282	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
115283	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
115284	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
115285	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
115286	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
115287	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
115288	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
115289	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
115290	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
115291	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
115292	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
115293	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
115294	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	174	
115295	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	174	
115296	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
115297	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
115298	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115299	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
115300	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
115301	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
115302	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
115303	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
115304	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
115305	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
115306	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Unknown Operations	0	
115307	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
115308	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps A Ø	0.0	
115309	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps B Ø	0.0	
115310	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps C Ø	0.0	
115311	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Switching Operations	0	
115312	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations This Read Oil	0	
115313	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AL	3841	
115314	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AF	3841	
115315	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Number of Ops last 9 Months	0	
115316	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Maintenance Operations	0	
115317	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	General Comments		
115318	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Follow-up Action Required?	n	
115319	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Fault Operations	0	
115320	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
115321	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Unknown Operations	0	
115322	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Switching Operations	1	
115323	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations This Read Oil	1	
115324	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AL	1957	
115325	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AF	1957	
115326	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Number of Ops last 9 Months	2	
115327	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Maintenance Operations	0	
115328	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	General Comments		
115329	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Follow-up Action Required?	n	
115330	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Fault Operations	0	
115331	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps C Ø	0.0	
115332	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps B Ø	0.0	
115333	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps A Ø	0.0	
115334	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	96057	
115335	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	96057	
115336	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
115337	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
115338	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
115339	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
115340	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115341	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115342	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations A Ø	0	
115343	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations B Ø	0	
115344	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations C Ø	0	
115345	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations Ground	0	
115346	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Follow-up Action Required?	n	
115347	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	General Comments		
115348	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Maintenance Operations	0	
115349	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AF	1140	
115350	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AL	1140	
115351	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations This Read Vac	3	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115352	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Switching Operations	3	
115353	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Unknown Operations	0	
115354	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115355	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115356	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations A Ø	0	
115357	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations B Ø	0	
115358	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations C Ø	0	
115359	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations Ground	0	
115360	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Follow-up Action Required?	n	
115361	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	General Comments		
115362	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Maintenance Operations	0	
115363	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AF	670	
115364	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
115365	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115366	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
115367	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
115368	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
115369	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
115370	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
115371	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
115372	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115373	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115374	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115375	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115376	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115377	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115378	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115379	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115380	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AL	670	
115381	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations This Read Vac	1	
115382	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Switching Operations	1	
115383	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Unknown Operations	0	
115384	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
115385	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
115386	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	550.0	
115387	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	16.86	%
115388	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
115389	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	22.89	%
115390	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	2	
115391	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
115392	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Unknown Operations	0	
115393	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Switching Operations	0	
115394	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations This Read Oil	0	
115395	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AL	845	
115396	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AF	845	
115397	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Number of Ops last 9 Months	0	
115398	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Maintenance Operations	0	
115399	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	General Comments		
115400	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Follow-up Action Required?	n	
115401	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Fault Operations	0	
115402	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps C Ø	0.0	
115403	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps B Ø	0.0	
115404	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
115405	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
115406	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
115407	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
115408	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	11	
115409	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115410	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Unknown Operations	0	
115411	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
115412	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	
115413	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	3	
115414	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	3	
115415	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
115416	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
115417	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
115418	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
115419	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
115420	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
115421	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
115422	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
115423	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
115424	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
115425	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
115426	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115427	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
115428	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	260.0	
115429	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	250.0	
115430	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	250.0	
115431	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	
115432	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	
115433	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	
115434	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
115435	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
115436	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
115437	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	240.0	
115438	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	230.0	
115439	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	190.0	
115440	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
115441	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps A Ø	0.0	
115442	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115443	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115444	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115445	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115446	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115447	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
115448	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
115449	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
115450	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115451	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
115452	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
115453	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
115454	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
115455	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
115456	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
115457	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments		
115458	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
115459	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
115460	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
115461	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
115462	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
115463	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
115464	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
115465	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
115466	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Unknown Operations	0	
115467	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
115468	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps A Ø	50.0	
115469	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps B Ø	50.0	
115470	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps C Ø	50.0	
115471	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Fault Operations	0	
115472	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Follow-up Action Required?	n	
115473	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	General Comments		
115474	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Maintenance Operations	0	
115475	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Number of Ops last 9 Months	2	
115476	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AF	1309	
115477	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AL	1309	
115478	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations This Read Oil	1	
115479	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Switching Operations	1	
115480	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Unknown Operations	0	
115481	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
115482	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
115483	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
115484	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
115485	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
115486	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
115487	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
115488	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
115489	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
115490	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
115491	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
115492	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
115493	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
115494	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
115495	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
115496	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
115497	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
115498	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
115499	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
115500	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
115501	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115502	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
115503	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
115504	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
115505	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
115506	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
115507	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
115508	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
115509	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
115510	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
115511	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
115512	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
115513	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
115514	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
115515	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	550.0	
115516	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	550.0	
115517	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115518	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115519	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
115520	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	0	
115521	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
115522	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
115523	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
115524	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
115525	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
115526	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
115527	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
115528	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
115529	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
115530	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
115531	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
115532	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
115533	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
115534	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
115535	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
115536	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	FE000384	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
115537	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
115538	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
115539	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
115540	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
115541	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
115542	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
115543	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
115544	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
115545	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
115546	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
115547	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115548	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
115549	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
115550	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
115551	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
115552	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	356	
115553	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	356	
115554	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
115555	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
115556	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
115557	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
115558	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
115559	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
115560	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
115561	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments		
115562	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
115563	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
115564	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
115565	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
115566	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
115567	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
115568	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
115569	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
115570	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
115571	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
115572	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
115573	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
115574	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
115575	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
115576	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115577	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
115578	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
115579	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
115580	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
115581	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
115582	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
115583	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
115584	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
115585	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
115586	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
115587	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
115588	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115589	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
115590	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115591	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	12.82	
115592	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
115593	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115594	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	2	
115595	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	1	
115596	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	0	
115597	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
115598	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	0	
115599	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115600	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations This Read Vac	2	
115601	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	225	
115602	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	225	
115603	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
115604	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
115605	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115606	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
115607	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
115608	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
115609	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
115610	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
115611	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
115612	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	
115613	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
115614	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	1	
115615	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	1	
115616	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115617	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
115618	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
115619	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115620	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115621	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115622	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115623	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
115624	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
115625	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
115626	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	190.0	
115627	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	195.0	
115628	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	190.0	
115629	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
115630	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
115631	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
115632	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	6	
115633	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
115634	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
115635	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
115636	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
115637	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
115638	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
115639	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
115640	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
115641	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
115642	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115643	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115644	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115645	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115646	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115647	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115648	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0338	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115649	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
115650	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
115651	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
115652	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
115653	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
115654	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
115655	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
115656	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
115657	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
115658	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
115659	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
115660	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
115661	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
115662	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115663	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
115664	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
115665	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
115666	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
115667	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
115668	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
115669	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
115670	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115671	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
115672	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115673	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
115674	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
115675	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
115676	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
115677	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
115678	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
115679	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
115680	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
115681	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	General Comments		
115682	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
115683	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
115684	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
115685	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
115686	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
115687	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	179	
115688	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	179	
115689	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
115690	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
115691	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
115692	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
115693	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
115694	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
115695	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	BB0129	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
115696	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Unknown Operations	0	
115697	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
115698	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
115699	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
115700	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
115701	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1030	
115702	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
115703	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Switching Operations	1	
115704	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations This Read Vac	1	
115705	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AL	672	
115706	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AF	672	
115707	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Maintenance Operations	0	
115708	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	General Comments		
115709	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Follow-up Action Required?	n	
115710	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
115711	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
115712	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	Seeping	
115713	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
115714	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments	oil level is low pic sent to stinson	
115715	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
115716	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
115717	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations Ground	0	
115718	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations C Ø	0	
115719	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations B Ø	0	
115720	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations A Ø	0	
115721	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	General Comments		
115722	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
115723	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	2	
115724	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	General Comments		
115725	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Follow-up Action Required?	n	
115726	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Fault Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115727	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps C Ø	0.0	
115728	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps B Ø	0.0	
115729	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps A Ø	0.0	
115730	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations	4	
115731	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty A Ph V	4.21	%
115732	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty B Ph V	4.21	%
115733	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty C Ph V	4.21	%
115734	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps A Ø	49.2	
115735	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps B Ø	50.8	
115736	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps C Ø	51.6	
115737	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115739	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
115740	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Switching Operations	0	
115741	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations This Read Vac	2	
115742	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	9 Month Operations	14	
115743	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps A Ø	212.0	
115744	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps B Ø	218.0	
115745	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps C Ø	215.0	
115746	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	398.56	
115747	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	398.56	
115748	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	398.56	
115749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations A Ø	0	
115750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations B Ø	0	
115751	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations C Ø	0	
115752	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations Ground	0	
115753	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Follow-up Action Required?	n	
115754	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	General Comments		
115755	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Maintenance Operations	0	
115756	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AF	102	
115757	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AL	102	
115758	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AL	134	
115759	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AF	134	
115760	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
115761	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Maintenance Operations	0	
115762	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115763	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations This Read Vac	14	
115764	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Switching Operations	7	
115765	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115766	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Unknown Operations	7	
115767	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
115768	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
115769	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	General Comments		
115770	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
115771	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations A Ø	0	
115772	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations B Ø	0	
115773	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations C Ø	0	
115774	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
115775	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
115776	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
115777	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	LTC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
115778	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
115779	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
115780	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	General Comments		
115781	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
115782	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
115783	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
115784	10/24/2019 13:56	Distribution	Lexington Water Company Quarterly Inspe	LTC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
115785	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations Ground	0	
115786	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Follow-up Action Required?	n	
115787	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	General Comments		
115788	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Maintenance Operations	0	
115789	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AF	840	
115790	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AL	840	
115791	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations This Read Vac	3	
115792	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
115793	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	General Comments		
115794	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Switching Operations	3	
115795	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Unknown Operations	0	
115796	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
115797	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps B Ø	50.0	
115798	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps A Ø	50.0	
115799	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
115800	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
115801	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115802	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
115803	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Unknown Operations	0	
115804	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
115805	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115806	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
115807	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115808	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
115809	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115810	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
115811	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115812	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
115813	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115814	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
115815	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115816	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	25	°C
115817	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	25	°C
115818	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	20	°C
115819	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	20	°C
115820	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	15	°C
115821	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	15	°C
115822	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
115823	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
115824	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
115825	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
115826	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
115827	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
115828	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
115829	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
115830	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
115831	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
115832	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
115833	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	15	°C
115834	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	50	°C
115835	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
115836	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
115837	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
115838	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	10	°C
115839	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	45	°C
115840	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
115841	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
115842	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
115843	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
115844	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
115845	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
115846	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
115847	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
115848	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
115849	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
115850	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
115851	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
115852	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
115853	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
115854	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
115855	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
115856	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
115857	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
115858	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
115859	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
115860	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
115861	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
115862	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
115863	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
115864	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
115865	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
115866	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
115867	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	30	°C
115868	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	100	°C
115869	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115870	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
115871	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
115872	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
115873	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
115874	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
115875	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
115876	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115877	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
115878	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
115879	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115880	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115881	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115882	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps C Ø	0.0	
115883	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps B Ø	0.0	
115884	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps A Ø	0.0	
115885	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty C Ph V	25.26	%
115886	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty B Ph V	25.26	%
115887	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty A Ph V	25.26	%
115888	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations	4	
115889	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
115890	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
115891	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
115892	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	54.0	
115893	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	55.0	
115894	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	54.0	
115895	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115896	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115897	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115898	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115899	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
115900	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
115901	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
115902	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
115903	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
115904	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
115905	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
115906	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
115907	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
115908	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Unknown Operations	0	
115909	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Switching Operations	1	
115910	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations This Read Oil	1	
115911	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AL	119	
115912	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AF	119	
115913	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
115914	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Number of Ops last 9 Months	2	
115915	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Maintenance Operations	0	
115916	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	General Comments		
115917	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
115918	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
115919	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
115920	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
115921	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
115922	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
115923	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
115924	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
115925	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	77095	
115926	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	77095	
115927	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
115928	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
115929	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
115930	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
115931	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
115932	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
115933	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
115934	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
115935	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
115936	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
115937	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
115938	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
115939	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Follow-up Action Required?	n	
115940	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Fault Operations	0	
115941	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
115942	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
115943	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
115944	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps C Ø	50.0	
115945	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
115946	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
115947	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
115948	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
115949	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
115950	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
115951	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
115952	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
115953	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
115954	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
115955	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
115956	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
115957	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
115958	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
115959	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	630.0	
115960	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	10	
115961	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	10	
115962	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
115963	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	2	
115964	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115965	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	2	
115966	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
115967	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	
115968	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations This Read Vac	2	
115969	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	172	
115970	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	172	
115971	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
115972	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	616.0	
115973	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	574.0	
115974	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
115975	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
115976	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
115977	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
115978	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
115979	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
115980	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
115981	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
115982	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
115983	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
115984	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
115985	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
115986	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
115987	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	
115988	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
115989	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
115990	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
115991	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
115992	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
115993	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
115994	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
115995	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Unknown Operations	0	
115996	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
115997	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
115998	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
115999	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
116000	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
116001	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
116002	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1235	
116003	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1235	
116004	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
116005	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
116006	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments		
116007	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
116008	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
116009	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
116010	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
116011	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
116012	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
116013	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
116014	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
116015	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
116016	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
116017	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116018	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116019	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
116020	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
116021	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
116022	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	148	
116023	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	148	
116024	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
116025	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
116026	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
116027	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
116028	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
116029	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
116030	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
116031	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
116032	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
116033	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
116034	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
116035	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
116036	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
116037	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
116038	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
116039	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
116040	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
116041	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
116042	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
116043	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
116044	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116045	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
116046	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
116047	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	98	
116048	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	98	
116049	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
116050	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116051	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
116052	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
116053	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
116054	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116055	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
116056	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116057	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
116058	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116059	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
116060	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0283	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
116061	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
116062	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	53.0	
116063	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	49.0	
116064	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	29.0	
116065	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116066	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116067	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116068	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116069	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
116070	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
116071	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
116072	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116073	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
116074	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116075	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
116076	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
116077	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
116078	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
116079	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
116080	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
116081	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
116082	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	355	
116083	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	355	
116084	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
116085	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
116086	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Unknown Operations	0	
116087	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
116088	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116089	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
116090	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116091	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
116092	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116093	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116094	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
116095	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
116096	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
116097	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
116098	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
116099	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
116100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
116101	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116102	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
116103	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116104	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116105	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116106	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116107	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116108	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116109	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
116110	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
116111	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
116112	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
116113	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116114	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
116115	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116116	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
116117	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	3	
116118	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116119	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116120	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116121	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	150.0	
116122	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	148.0	
116123	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	151.0	
116124	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
116125	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116126	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116127	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116128	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116129	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116130	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116131	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116132	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116133	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116134	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
116135	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
116136	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
116137	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
116138	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
116139	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
116140	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
116141	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
116142	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments	Actual counter	
116143	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
116144	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116145	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
116146	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
116147	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	224	
116148	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	224	
116149	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	0	
116150	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116151	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
116152	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
116153	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
116154	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Unknown Operations	0	
116155	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Switching Operations	0	
116156	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations This Read Oil	0	
116157	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AL	826	
116158	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AF	826	
116159	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Number of Ops last 9 Months	0	
116160	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Maintenance Operations	0	
116161	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116162	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
116163	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116164	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116165	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116166	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	6	
116167	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116168	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116169	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
116170	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
116171	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	General Comments		
116172	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
116173	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
116174	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
116175	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
116176	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116177	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
116178	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
116179	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
116180	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116181	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116182	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
116183	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
116184	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
116185	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
116186	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
116187	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
116188	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
116189	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
116190	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
116191	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
116192	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116193	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116194	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
116195	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
116196	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
116197	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
116198	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	253.0	
116199	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	247.0	
116200	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116201	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
116202	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116203	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps A Ø	116.0	
116204	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps B Ø	119.0	
116205	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps C Ø	114.0	
116206	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Fault Operations	0	
116207	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Follow-up Action Required?	n	
116208	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	General Comments		
116209	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Maintenance Operations	0	
116210	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Number of Ops last 9 Months	6	
116211	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AF	973	
116212	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AL	973	
116213	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations This Read Oil	0	
116214	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Switching Operations	0	
116215	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
116216	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	259.0	
116217	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
116218	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
116219	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
116220	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
116221	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
116222	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
116223	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
116224	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
116225	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
116226	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
116227	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116228	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116229	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116230	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116231	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116232	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116233	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116234	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116235	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116236	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
116237	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
116238	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
116239	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
116240	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BB0346	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116241	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116242	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116243	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
116244	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	100.0	
116245	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	100.0	
116246	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	100.0	
116247	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116248	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116249	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116250	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	376	
116251	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	376	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
116252	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
116253	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
116254	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
116255	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
116256	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
116257	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
116258	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
116259	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
116260	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
116261	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
116262	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
116263	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
116264	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
116265	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	400.0	
116266	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
116267	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
116268	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
116269	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
116270	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	87.0	
116271	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	92.0	
116272	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	105.0	
116273	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
116274	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
116275	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
116276	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
116277	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
116278	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
116279	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
116280	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
116281	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
116282	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
116283	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
116284	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
116285	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
116286	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	541	
116287	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	541	
116288	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
116289	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
116290	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
116291	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	8	
116292	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
116293	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments		
116294	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
116295	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
116296	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
116297	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
116298	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
116299	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
116300	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
116301	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	0	
116302	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116303	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations This Read Vac	0	
116304	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	449	
116305	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	449	
116306	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
116307	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
116308	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116309	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
116310	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
116311	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
116312	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
116313	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
116314	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
116315	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
116316	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
116317	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	854	
116318	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	854	
116319	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
116320	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
116321	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
116322	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
116323	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
116324	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
116325	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
116326	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
116327	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
116328	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
116329	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
116330	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
116331	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
116332	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	158.0	
116333	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	156.0	
116334	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	171.0	
116335	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
116336	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
116337	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
116338	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
116339	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	0	
116340	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
116341	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	0	
116342	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116343	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116344	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116345	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116346	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116347	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116348	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116349	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
116350	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
116351	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Unknown Operations	0	
116352	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
116353	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	0	
116354	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
116355	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
116356	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
116357	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
116358	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
116359	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
116360	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
116361	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
116362	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
116363	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
116364	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
116365	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	326	
116366	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	326	
116367	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
116368	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
116369	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
116370	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
116371	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
116372	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	57827	
116373	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	57827	
116374	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
116375	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
116376	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
116377	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116378	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	
116379	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
116380	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	219	
116381	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	219	
116382	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations This Read Vac	0	
116383	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116384	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	0	
116385	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
116386	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
116387	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
116388	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
116389	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
116390	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	5013	
116391	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
116392	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
116393	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
116394	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
116395	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
116396	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
116397	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
116398	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
116399	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
116400	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	177592	
116401	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	177592	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
116402	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
116403	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	13L	
116404	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
116405	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	14L	
116406	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1732	
116407	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
116408	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
116409	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
116410	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	400.0	
116411	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	400.0	
116412	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
116413	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
116414	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
116415	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
116416	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
116417	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
116418	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
116419	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
116420	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
116421	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
116422	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
116423	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
116424	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
116425	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
116426	10/24/2019 8:41	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
116427	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
116428	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	23.1	%
116429	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	23.1	%
116430	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	23.1	%
116431	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
116432	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
116433	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
116434	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116435	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116436	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
116437	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
116438	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
116439	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	8	
116440	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116441	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
116442	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	4	
116443	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116444	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116445	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116446	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	60.0	
116447	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	45.0	
116448	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	60.0	
116449	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
116450	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116451	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116452	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116453	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
116454	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
116455	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116456	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116457	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116458	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116459	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116460	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116461	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116462	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	0	
116463	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
116464	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	0	
116465	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
116466	10/24/2019 11:46	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
116467	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
116468	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
116469	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
116470	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1229	
116471	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
116472	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1229	
116473	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
116474	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
116475	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
116476	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116477	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
116478	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
116479	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
116480	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
116481	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
116482	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
116483	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
116484	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
116485	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
116486	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
116487	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	90	*C
116488	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
116489	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
116490	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
116491	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
116492	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
116493	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	4	
116494	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116495	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116496	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116497	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	258.0	
116498	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	247.0	
116499	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	256.0	
116500	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
116501	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116502	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116503	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116504	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
116505	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
116506	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
116507	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
116508	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Unknown Operations	0	
116509	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Switching Operations	0	
116510	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations This Read Oil	0	
116511	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AL	1158	
116512	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AF	1158	
116513	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Number of Ops last 9 Months	1	
116514	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Maintenance Operations	0	
116515	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	General Comments		
116516	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Follow-up Action Required?	n	
116517	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Fault Operations	0	
116518	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps C Ø	0	
116519	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps B Ø	0	
116520	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps A Ø	0	
116521	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	30	*C
116522	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	90	*C
116523	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	30	*C
116524	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
116525	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
116526	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
116527	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
116528	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
116529	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
116530	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
116531	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
116532	10/29/2019 12:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116533	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	17	
116534	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	48.18	%
116535	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
116536	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	30	*C
116537	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	80	*C
116538	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
116539	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
116540	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
116541	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
116542	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments	X2 will not reset	
116543	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments	fans to auto	
116544	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
116545	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
116546	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	y	
116547	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
116548	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
116549	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
116550	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
116551	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116552	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
116553	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
116554	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
116555	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
116556	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
116557	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
116558	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	*F
116559	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
116560	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
116561	10/24/2019 11:19	Distribution	West High Street Quarterly Inspection	BAT000382	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
116562	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
116563	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
116564	10/24/2019 13:46	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
116565	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
116566	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
116567	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116568	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	General Comments		
116569	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
116570	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
116571	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
116572	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Grounds in Place?	y	
116573	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Maintenance Operations	0	
116574	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Moisture and Leak Free?	y	
116575	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AF	175	
116576	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AL	175	
116577	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations This Read Vac	0	
116578	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116579	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
116580	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
116581	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
116582	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
116583	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
116584	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
116585	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
116586	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Max	50	*C
116587	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
116588	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
116589	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
116590	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
116591	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
116592	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116593	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116594	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116595	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116596	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Switching Operations	0	
116597	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Tank Paint Condition	Good	
116598	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Unknown Operations	0	
116599	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushing Condition	Good	
116600	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116601	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116602	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC000835	LTCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds
116603	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	240.0	
116604	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	240.0	
116605	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	240.0	
116606	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	
116607	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
116608	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
116609	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
116610	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
116611	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
116612	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
116613	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
116614	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
116615	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
116616	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	674	
116617	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
116618	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
116619	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	674	
116620	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
116621	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
116622	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations A Ø	0	
116623	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
116624	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations B Ø	0	
116625	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
116626	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116627	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
116628	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
116629	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
116630	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
116631	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
116632	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
116633	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
116634	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
116635	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
116636	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
116637	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	General Comments		
116638	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
116639	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
116640	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
116641	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations C Ø	0	
116642	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations Ground	0	
116643	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Follow-up Action Required?	n	
116644	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Follow-up Action Required?	n	
116645	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Foundation Condition	Good	
116646	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	General Comments		
116647	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
116648	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
116649	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Reading	1.1530	
116650	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
116651	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
116652	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
116653	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
116654	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
116655	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
116656	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
116657	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
116658	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Present	35	°C
116659	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
116660	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
116661	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
116662	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
116663	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
116664	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
116665	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116666	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	0	
116667	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
116668	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
116669	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
116670	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
116671	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
116672	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
116673	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
116674	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
116675	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
116676	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
116677	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
116678	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
116679	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116680	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116681	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116682	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
116683	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
116684	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
116685	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
116686	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
116687	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
116688	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Follow-up Action Required?	n	
116689	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
116690	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
116691	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	General Comments		
116692	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	General Comments		
116693	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116694	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116695	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116696	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
116697	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
116698	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	13.61	
116699	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
116700	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
116701	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116702	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
116703	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
116704	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
116705	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
116706	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	277	
116707	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	277	
116708	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations This Read Vac	5	
116709	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
116710	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	4	
116711	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
116712	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
116713	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0215	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
116714	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
116715	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Follow-up Action Required?	n	
116716	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Foundation Condition	Good	
116717	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	General Comments		
116718	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
116719	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Grounds in Place?	y	
116720	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Moisture and Leak Free?	y	
116721	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Tank Paint Condition	Good	
116722	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	LTC Totalizer Reading	3689.60	kw
116723	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
116724	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
116725	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	0	
116726	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
116727	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	1	
116728	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116729	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116730	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
116731	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
116732	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
116733	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
116734	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
116735	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
116736	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
116737	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
116738	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
116739	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
116740	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
116741	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
116742	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
116743	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
116744	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
116745	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
116746	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
116747	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
116748	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
116749	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
116750	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
116751	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
116752	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
116753	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
116754	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
116755	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
116756	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
116757	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
116758	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
116759	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
116760	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	General Comments		
116761	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
116762	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116763	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116764	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	16.0	
116765	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	18.0	
116766	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	16.0	
116767	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
116768	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116769	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116770	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116771	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116772	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116773	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116774	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
116775	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116776	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116777	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	1	
116778	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
116779	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
116780	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
116781	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
116782	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
116783	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
116784	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
116785	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
116786	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
116787	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
116788	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
116789	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
116790	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
116791	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
116792	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	166	
116793	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	166	
116794	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	1	
116795	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	0	
116796	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
116797	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116798	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	220.0	
116799	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	230.0	
116800	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
116801	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	All Connections OK?	y	
116802	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	210.0	
116803	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
116804	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116805	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116806	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116807	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116808	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116809	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
116810	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
116811	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
116812	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
116813	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
116814	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
116815	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
116816	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
116817	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
116818	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
116819	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
116820	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
116821	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
116822	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
116823	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
116824	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
116825	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
116826	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
116827	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
116828	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
116829	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
116830	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116831	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116832	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116833	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116834	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116835	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116836	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116837	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116838	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116839	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
116840	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	80.0	
116841	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	80.0	
116842	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	95.0	
116843	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116844	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116845	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116846	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	4	
116847	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
116848	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
116849	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
116850	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCCControl	660-1	LTC Control Insp	All Connections OK?	y	
116851	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116852	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
116853	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
116854	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
116855	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
116856	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
116857	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
116858	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	3	
116859	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116860	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116861	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
116862	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
116863	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
116864	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
116865	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
116866	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
116867	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
116868	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
116869	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
116870	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
116871	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	175	
116872	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	175	
116873	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	0	
116874	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	0	
116875	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
116876	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	0	
116877	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	5	
116878	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116879	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
116880	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
116881	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
116882	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
116883	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
116884	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
116885	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
116886	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
116887	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
116888	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
116889	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
116890	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8813	
116891	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
116892	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
116893	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
116894	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Tank Paint Condition	Good	
116895	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Moisture and Leak Free?	y	
116896	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Grounds in Place?	y	
116897	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	General Comments		
116898	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Foundation Condition	Good	
116899	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Follow-up Action Required?	n	
116900	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116901	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116902	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116903	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116904	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116905	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116906	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushing Condition	Good	
116907	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
116908	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
116909	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
116910	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
116911	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
116912	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
116913	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
116914	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
116915	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
116916	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	
116917	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
116918	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
116919	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
116920	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
116921	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
116922	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
116923	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
116924	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
116925	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
116926	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	7	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
116927	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
116928	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
116929	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
116930	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
116931	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
116932	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
116933	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	General Comments		
116934	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
116935	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
116936	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
116937	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000835	LTCCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
116938	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
116939	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116940	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
116941	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
116942	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
116943	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	0	
116944	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
116945	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
116946	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
116947	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
116948	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
116949	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
116950	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
116951	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
116952	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
116953	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
116954	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	0	
116955	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
116956	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
116957	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
116958	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
116959	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	
116960	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
116961	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
116962	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
116963	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
116964	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	0	
116965	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
116966	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	233	
116967	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	233	
116968	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations This Read Vac	2	
116969	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	2	
116970	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	
116971	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
116972	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	General Comments		
116973	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
116974	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
116975	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
116976	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
116977	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	LTC0000646	LTCCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
116978	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
116979	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
116980	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	VRR Time Delay	30	Seconds
116981	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
116982	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
116983	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
116984	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	LTC Operation Checked?	y	
116985	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	General Comments		
116986	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	Follow-up Action Required?	n	
116987	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000775	LTCCControl	617-2	LTC Control Insp	All Connections OK?	y	
116988	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
116989	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
116990	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
116991	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
116992	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
116993	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
116994	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
116995	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
116996	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
116997	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	1253	
116998	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
116999	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
117000	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
117001	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
117002	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
117003	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117004	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments		
117005	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
117006	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	810	
117007	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	810	
117008	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117009	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	8L	
117010	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
117011	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	12L	
117012	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	789	
117013	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
117014	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
117015	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
117016	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
117017	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117018	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
117019	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117020	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
117021	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
117022	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
117023	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
117024	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
117025	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
117026	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
117027	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
117028	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
117029	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
117030	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
117031	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
117032	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
117033	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
117034	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
117035	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
117036	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
117037	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
117038	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
117039	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
117040	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
117041	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
117042	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
117043	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
117044	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
117045	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
117046	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
117047	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
117048	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	740	
117049	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	740	
117050	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
117051	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
117052	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
117053	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
117054	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
117055	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
117056	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
117057	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
117058	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
117059	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
117060	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
117061	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
117062	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
117063	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
117064	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
117065	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
117066	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117067	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117068	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117069	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
117070	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
117071	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
117072	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
117073	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
117074	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
117075	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
117076	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117077	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117078	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117079	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117080	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117081	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117082	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117083	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117084	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117085	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
117086	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	80.0	
117087	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	40.0	
117088	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	100.0	
117089	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117090	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117091	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117092	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	2	
117093	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
117094	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
117095	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
117096	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
117097	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
117098	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
117099	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
117100	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
117101	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
117102	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117103	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushing Condition	Good	
117104	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps C Ø	280.0	
117105	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps B Ø	255.0	
117106	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps A Ø	305.0	
117107	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117108	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117109	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117110	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	2	
117111	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
117112	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
117113	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
117114	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
117115	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
117116	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
117117	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
117118	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
117119	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
117120	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	0	
117121	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
117122	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations This Read Vac	0	
117123	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	266	
117124	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	266	
117125	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
117126	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
117127	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117128	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
117129	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
117130	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	110293	
117131	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	110293	
117132	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117133	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	4L	
117134	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	3L	
117135	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	8L	
117136	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
117137	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
117138	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
117139	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
117140	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
117141	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
117142	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
117143	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
117144	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
117145	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
117146	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	
117147	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
117148	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
117149	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
117150	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
117151	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117152	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
117153	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
117154	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
117155	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
117156	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
117157	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
117158	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
117159	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
117160	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
117161	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
117162	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
117163	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
117164	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
117165	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
117166	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
117167	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
117168	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
117169	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
117170	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
117171	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
117172	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
117173	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
117174	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
117175	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
117176	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
117177	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
117178	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
117179	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
117180	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
117181	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
117182	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
117183	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
117184	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
117185	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
117186	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
117187	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
117188	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
117189	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
117190	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		
117191	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	
117192	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
117193	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
117194	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
117195	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
117196	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
117197	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
117198	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
117199	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
117200	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
117201	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
117202	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
117203	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
117204	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
117205	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
117206	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
117207	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
117208	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
117209	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
117210	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
117211	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
117212	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
117213	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
117214	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
117215	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
117216	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
117217	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
117218	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
117219	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
117220	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	2	
117221	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
117222	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations This Read Vac	2	
117223	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	301	
117224	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	301	
117225	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
117226	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117227	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
117228	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
117229	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
117230	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
117231	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
117232	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
117233	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
117234	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
117235	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C Ø	0	
117236	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B Ø	0	
117237	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A Ø	0	
117238	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117239	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117240	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117241	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117242	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117243	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117244	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117245	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117246	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117247	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
117248	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	60.0	
117249	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	50.0	
117250	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	55.0	
117251	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117252	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117253	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117254	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	3	
117255	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
117256	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
117257	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117258	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117259	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117260	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117261	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117262	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117263	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117264	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117265	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117266	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
117267	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0.0	
117268	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0.0	
117269	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0.0	
117270	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117271	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117272	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117273	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	12	
117274	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
117275	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	0	
117276	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Unknown Operations	Good	
117277	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
117278	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
117279	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
117280	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
117281	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	4	
117282	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117283	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117284	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117285	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	515.0	
117286	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	480.0	
117287	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	510.0	
117288	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	VCB Patrol Inspection	Bushing Condition	Good	
117289	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8857	
117290	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
117291	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
117292	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
117293	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
117294	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
117295	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
117296	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
117297	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
117298	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	Regulator Patrol Inspection	General Comments		
117299	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117300	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117301	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117301	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	VCB Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
117302	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
117303	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
117304	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117305	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117306	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117307	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117308	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117309	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117310	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117311	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117312	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117313	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
117314	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
117315	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
117316	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
117317	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
117318	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
117319	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
117320	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
117321	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
117322	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
117323	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	0	
117324	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
117325	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
117326	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
117327	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
117328	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
117329	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
117330	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
117331	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	187	
117332	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	187	
117333	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations This Read Vac	0	
117334	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	0	
117335	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
117336	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
117337	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
117338	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
117339	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
117340	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
117341	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
117342	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117343	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
117344	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
117345	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
117346	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
117347	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
117348	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
117349	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-01-22 00:00:00.000000	
117350	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
117351	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	412	
117352	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	412	
117353	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
117354	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
117355	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
117356	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	30	°C
117357	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	80	°C
117358	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.5510	
117359	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
117360	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117361	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
117362	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
117363	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117364	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117365	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
117366	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117367	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
117368	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
117369	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	30	°C
117370	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	70	°C
117371	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
117372	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
117373	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	7934.40	kw
117374	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
117375	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments	DOES NOT HAVE GROUP SWITCH	
117376	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117377	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117378	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
117379	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
117380	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
117381	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
117382	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
117383	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117384	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
117385	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
117386	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
117387	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
117388	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	General Comments		
117389	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
117390	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
117391	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
117392	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
117393	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
117394	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
117395	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
117396	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
117397	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117398	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117399	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117400	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117401	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117402	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117403	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
117404	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
117405	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
117406	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117407	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
117408	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
117409	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
117410	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
117411	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	7409	
117412	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
117413	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117414	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	1029	
117415	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
117416	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
117417	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
117418	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
117419	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
117420	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
117421	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
117422	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
117423	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
117424	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
117425	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Unknown Operations	0	
117426	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Tank Paint Condition	Good	
117427	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Switching Operations	0	
117428	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
117429	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations This Read Vac	0	
117430	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AL	232	
117431	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AF	232	
117432	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Moisture and Leak Free?	y	
117433	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Maintenance Operations	0	
117434	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Heaters (All) Functioning?	y	
117435	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Grounds in Place?	y	
117436	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	General Comments		
117437	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	General Comments		
117438	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Foundation Condition	Good	
117439	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Follow-up Action Required?	n	
117440	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Follow-up Action Required?	n	
117441	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations Ground	0	
117442	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations C Ø	0	
117443	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations B Ø	0	
117444	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
117445	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117446	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117447	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117448	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
117449	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
117450	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
117451	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117452	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117453	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117454	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117455	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117456	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117457	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117458	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117459	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117460	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117461	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations A Ø	0	
117462	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117463	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117464	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117465	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117466	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
117467	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
117468	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	0	
117469	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations This Read Vac	0	
117470	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	181	
117471	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	181	
117472	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
117473	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
117474	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
117475	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
117476	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
117477	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
117478	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
117479	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
117480	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
117481	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
117482	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
117483	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117484	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
117485	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	120810	
117486	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	120810	
117487	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117488	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	8L	
117489	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	2L	
117490	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	16L	
117491	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	4534	
117492	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
117493	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
117494	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
117495	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
117496	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
117497	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
117498	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
117499	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
117500	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9555	
117501	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
117502	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
117503	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
117504	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
117505	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
117506	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
117507	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
117508	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
117509	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
117510	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
117511	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
117512	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
117513	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
117514	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
117515	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
117516	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
117517	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
117518	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
117519	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
117520	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
117521	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
117522	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
117523	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117524	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117525	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
117526	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117527	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
117528	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
117529	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
117530	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
117531	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
117532	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
117533	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	General Comments		
117534	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
117535	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
117536	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
117537	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
117538	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
117539	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
117540	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
117541	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	
117542	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	87	
117543	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	87	
117544	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
117545	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
117546	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
117547	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
117548	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
117549	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	7409	
117550	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117551	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	8L	
117552	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	1L	
117553	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	12L	
117554	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	60	°C
117555	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	45	°C
117556	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117557	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
117558	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117559	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117560	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
117561	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
117562	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
117563	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
117564	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	If no, which cells in comments
117565	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
117566	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
117567	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
117568	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
117569	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
117570	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
117571	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
117572	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
117573	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117574	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117575	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117576	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117577	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117578	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117579	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117580	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
117581	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
117582	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
117583	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	n	
117584	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
117585	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117586	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
117587	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments		
117588	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
117589	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	10465.20	kw
117590	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
117591	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
117592	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	55	°C
117593	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
117594	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
117595	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
117596	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
117597	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
117598	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
117599	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
117600	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
117601	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117602	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
117603	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
117604	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
117605	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
117606	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
117607	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
117608	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Unknown Operations	0	
117609	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Tank Paint Condition	Good	
117610	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Switching Operations	0	
117611	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations This Read Vac	0	
117612	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AL	159	
117613	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AF	159	
117614	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
117615	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Maintenance Operations	0	
117616	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Grounds in Place?	y	
117617	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	General Comments		
117618	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	General Comments		
117619	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Foundation Condition	Good	
117620	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Follow-up Action Required?	n	
117621	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117622	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
117623	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	.7010	
117624	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
117625	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
117626	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
117627	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
117628	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
117629	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
117630	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
117631	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
117632	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
117633	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
117634	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
117635	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
117636	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
117637	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
117638	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
117639	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
117640	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
117641	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
117642	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
117643	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
117644	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
117645	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117646	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117647	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117648	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117649	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117650	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117651	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117652	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
117653	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
117654	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
117655	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
117656	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
117657	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117658	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments		
117659	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations Ground	0	
117660	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations C Ø	0	
117661	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations B Ø	0	
117662	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations A Ø	0	
117663	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117664	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117665	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117666	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117667	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117668	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117669	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117670	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117671	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117672	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushing Condition	Good	
117673	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps C Ø	460.0	
117674	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps B Ø	480.0	
117675	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps A Ø	475.0	
117676	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117677	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
117678	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
117679	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
117680	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
117681	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
117682	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
117683	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	LTC0000420	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
117684	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117685	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117686	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117687	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	2	
117688	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
117689	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
117690	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
117691	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
117692	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	5047.20	kw
117693	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
117694	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
117695	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.3380	
117696	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117697	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
117698	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
117699	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117700	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
117701	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	.6300	
117702	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	70	°C
117703	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	40	°C
117704	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
117705	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
117706	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
117707	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117708	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
117709	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
117710	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117711	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117712	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
117713	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
117714	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
117715	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117716	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117717	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117718	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117719	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117720	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
117721	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
117722	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
117723	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
117724	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
117725	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
117726	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
117727	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	LTC0000505	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
117728	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117729	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117730	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
117731	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
117732	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
117733	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
117734	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
117735	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117736	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
117737	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
117738	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117739	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	55	°C
117740	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
117741	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
117742	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	3244.80	kw
117743	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
117744	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
117745	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
117746	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
117747	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
117748	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	9 Month Operations	11	
117749	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117750	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117751	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117752	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps A Ø	90.0	
117753	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps B Ø	100.0	
117754	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps C Ø	85.0	
117755	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushing Condition	Good	
117756	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117757	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117758	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117759	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117760	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117761	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117762	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117763	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117764	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117765	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
117766	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Follow-up Action Required?	n	
117767	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations Ground	0	
117768	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations C Ø	0	
117769	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations B Ø	0	
117770	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations A Ø	0	
117771	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117772	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117773	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117774	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117775	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117776	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117777	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117778	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117779	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117780	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushing Condition	Good	
117781	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps C Ø	230.0	
117782	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps B Ø	250.0	
117783	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps A Ø	220.0	
117784	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117785	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117786	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117787	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	9 Month Operations	8	
117788	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
117789	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
117790	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
117791	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
117792	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117793	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117794	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117795	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117796	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117797	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117798	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
117799	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117800	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
117801	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
117802	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
117803	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	45	*C
117804	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
117805	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
117806	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117807	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
117808	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117809	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117810	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
117811	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
117812	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117813	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
117814	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	.5814	
117815	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	70	*C
117816	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	40	*C
117817	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
117818	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
117819	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
117820	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
117821	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117822	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
117823	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
117824	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
117825	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	11340.00	kw
117826	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
117827	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
117828	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	70	°C
117829	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	40	°C
117830	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
117831	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
117832	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117833	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
117834	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117835	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
117836	10/23/2019 13:49	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
117837	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
117838	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
117839	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3200	
117840	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
117841	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Grounds in Place?	y	
117842	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	General Comments		
117843	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	General Comments		
117844	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
117845	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
117846	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
117847	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
117848	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
117849	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
117850	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
117851	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
117852	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
117853	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
117854	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
117855	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
117856	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
117857	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
117858	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
117859	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
117860	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
117861	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
117862	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
117863	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
117864	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
117865	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
117866	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
117867	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
117868	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
117869	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	27479	
117870	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	27479	
117871	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
117872	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	10L	
117873	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	2L	
117874	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	12L	
117875	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
117876	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	1036	
117877	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
117878	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
117879	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
117880	10/24/2019 7:53	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
117881	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
117882	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
117883	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
117884	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1024.00	kw
117885	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
117886	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
117887	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
117888	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
117889	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
117890	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
117891	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
117892	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
117893	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
117894	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	None	
117895	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
117896	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
117897	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
117898	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
117899	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
117900	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
117901	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
117902	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
117903	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
117904	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AF	208	
117905	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
117906	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
117907	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
117908	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Switching Operations	1	
117909	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
117910	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
117911	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
117912	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
117913	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
117914	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
117915	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Follow-up Action Required?	n	
117916	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Follow-up Action Required?	n	
117917	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Foundation Condition	Good	
117918	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
117919	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Maintenance Operations	0	
117920	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
117921	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
117922	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
117923	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
117924	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	General Comments		
117925	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
117926	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
117927	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
117928	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	LTC0000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
117929	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AL	208	
117930	10/23/2019 9:22	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations This Read Vac	1	
117931	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
117932	10/23/2019 8:29	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
117933	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117934	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117935	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
117936	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
117937	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
117938	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117939	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations Ground	0	
117940	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
117941	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
117942	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
117943	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117944	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117945	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117946	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117947	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117948	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
117949	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments		
117950	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	
117951	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
117952	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
117953	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
117954	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
117955	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
117956	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
117957	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
117958	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
117959	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
117960	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
117961	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
117962	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
117963	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
117964	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
117965	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
117966	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
117967	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
117968	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
117969	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
117970	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117971	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
117972	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
117973	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
117974	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
117975	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	5.2	%
117976	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	5.2	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
117977	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	5.2	%
117978	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	4	
117979	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
117980	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
117981	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Amps C Ø	360.0	
117982	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Amps B Ø	360.0	
117983	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Amps A Ø	360.0	
117984	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
117985	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117986	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117987	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017		BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	1	
117988	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
117989	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
117990	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Switching Operations	0	
117991	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
117992	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	0	
117993	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	194	
117994	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	194	
117995	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
117996	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	0	
117997	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
117998	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
117999	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
118000	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
118001	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
118002	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
118003	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Readings	Follow-up Action Required?	n	
118004	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
118005	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
118006	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments		
118007	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Readings	General Comments		
118008	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
118009	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
118010	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	40	°C
118011	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
118012	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
118013	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	50	°C
118014	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.8650	
118015	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
118016	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
118017	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
118018	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
118019	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
118020	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
118021	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
118022	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
118023	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5	psi
118024	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Readings	Oil Temp Max	40	°C
118025	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Readings	Oil Temp Present	20	°C
118026	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
118027	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
118028	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
118029	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
118030	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
118031	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
118032	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
118033	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
118034	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433		WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
118035	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
118036	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC000013	LTCControl	412-2	LTC Control Insp	General Comments		
118037	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
118038	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
118039	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
118040	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
118041	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	40	°C
118042	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	70	°C
118043	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
118044	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
118045	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	12456.00	kw
118046	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
118047	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
118048	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
118049	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
118050	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments		
118051	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0335		BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118052	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None		
118053	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
118054	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
118055	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
118056	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
118057	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
118058	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000		
118059	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.9804		
118060	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushing Condition	Good		
118061	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Amps C Ø	50.0		
118062	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Amps B Ø	50.0		
118063	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Amps A Ø	50.0		
118064	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y		
118065	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y		
118066	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0		
118067	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y		
118068	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	52		
118069	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	52		
118070	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	0		
118071	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged		
118072	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	0		
118073	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
118074	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
118075	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
118076	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	2		
118077	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good		
118078	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Unknown Operations	0		
118079	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000		
118080	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Multiplier	14000		
118081	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y		
118082	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Max	45	°C	
118083	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Present	45	°C	
118084	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds	
118085	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC	
118086	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC	
118087	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position	
118088	10/22/2019 8:22	Distribution	UK West Quarterly Inspection LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	122.0	VAC	
118089	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00		
118090	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00		
118091	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y		
118092	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good		
118093	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
118094	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good		
118095	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
118096	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		
118097	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
118098	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
118099	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
118100	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0		
118101	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
118102	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0		
118103	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0		
118104	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n		
118105	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n		
118106	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good		
118107	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments			
118108	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments			
118109	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y		
118110	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y		
118111	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	0		
118112	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y		
118113	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	168		
118114	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	168		
118115	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Operations This Read Vac	0		
118116	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged		
118117	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	0		
118118	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good		
118119	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0		
118120	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC	
118121	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments	
118122	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y		
118123	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	General Comments			
118124	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y		
118125	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	23529.60	kw	
118126	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118127	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi	
118128	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	60	°C	
118129	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	30	°C	
118130	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
118131	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
118132	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	90.0	
118133	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
118134	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
118135	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
118136	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	0	
118137	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118138	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118139	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118140	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118141	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118142	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
118143	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Max	40	°C	
118144	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Present	20	°C	
118145	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	WithLTC	716-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00		
118146	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	WithLTC	716-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00		
118147	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
118148	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
118149	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
118150	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
118151	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Unknown Operations	0	
118152	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Switching Operations	0	
118153	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations This Read AM	0	
118154	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AL	810	
118155	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AF	810	
118156	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Maintenance Operations	0	
118157	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	General Comments		
118158	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Follow-up Action Required?	n	
118159	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	90.0	
118160	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	90.0	
118161	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations	2		
118162	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
118163	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
118164	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
118165	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
118166	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
118167	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
118168	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Amps A Ø	50.0		
118169	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Amps B Ø	50.0		
118170	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Readings	Amps C Ø	50.0		
118171	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushing Condition	Good		
118172	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushings Connection/Risers	Good		
118173	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
118174	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good		
118175	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y		
118176	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118177	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
118178	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118179	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
118180	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good		
118181	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
118182	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		
118183	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
118184	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
118185	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter	
118186	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
118187	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good		
118188	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y		
118189	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
118190	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n		
118191	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
118192	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
118193	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
118194	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
118195	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118196	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118197	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118198	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118199	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good		
118200	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
118201	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments			

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118202	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118203	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
118204	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118205	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118206	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118207	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118208	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118209	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118210	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118211	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118212	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118213	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118214	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	
118215	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
118216	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
118217	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
118218	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
118219	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	16R	
118220	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	16L	
118221	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
118222	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
118223	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
118224	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118225	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
118226	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	404	
118227	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	404	
118228	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
118229	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	1445	
118230	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
118231	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
118232	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
118233	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
118234	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
118235	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118236	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118237	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118238	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118239	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118240	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118241	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
118242	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118243	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
118244	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
118245	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
118246	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
118247	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
118248	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118249	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
118250	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
118251	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
118252	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
118253	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
118254	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
118255	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
118256	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
118257	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
118258	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
118259	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
118260	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
118261	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118262	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations A Ø	0	
118263	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations B Ø	0	
118264	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations C Ø	0	
118265	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations Ground	0	
118266	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
118267	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Follow-up Action Required?	n	
118268	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
118269	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	General Comments		
118270	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Readings	General Comments		
118271	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
118272	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	LTC0000571	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
118273	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations Ground	0	
118274	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations C Ø	0	
118275	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations B Ø	0	
118276	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118277	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
118278	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
118279	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
118280	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps C Ø	0.0	
118281	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps B Ø	0.0	
118282	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps A Ø	0.0	
118283	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
118284	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
118285	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
118286	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Months Operations	0	
118287	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
118288	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
118289	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
118290	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
118291	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
118292	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
118293	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
118294	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments		
118295	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
118296	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
118297	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
118298	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
118299	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
118300	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
118301	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
118302	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
118303	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
118304	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
118305	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
118306	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
118307	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
118308	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
118309	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
118310	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
118311	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
118312	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
118313	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments		
118314	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	47472	
118315	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	47472	
118316	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
118317	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	9L	
118318	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
118319	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
118320	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
118321	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
118322	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
118323	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
118324	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
118325	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	786	
118326	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	786	
118327	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
118328	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
118329	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
118330	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
118331	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
118332	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
118333	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
118334	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
118335	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
118336	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
118337	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
118338	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
118339	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
118340	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
118341	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
118342	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
118343	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
118344	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
118345	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
118346	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	7	
118347	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	37.47	%
118348	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	58.19	%
118349	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	16.74	%
118350	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	79.0	
118351	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	81.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118352	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations	6		
118353	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
118354	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
118355	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
118356	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Amps A Ø	0.0		
118357	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Amps B Ø	0.0		
118358	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Amps C Ø	0.0		
118359	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushing Condition	Good		
118360	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushings Connection/Risers	Good		
118361	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
118362	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Heaters Functioning?	y		
118363	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Internal Condition?	Clean		
118364	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Paint Condition	Good		
118365	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Equipment Properly Labeled?	y		
118366	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
118367	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
118368	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
118369	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations A Ø	0		
118370	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n		
118371	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
118372	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y		
118373	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good		
118374	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
118375	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter	
118376	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
118377	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
118378	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		
118379	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
118380	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good		
118381	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
118382	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good		
118383	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y		
118384	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0		
118385	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0		
118386	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	0		
118387	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	307		
118388	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	307		
118389	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0		
118390	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments			
118391	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n		
118392	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0		
118393	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0		
118394	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0		
118395	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0		
118396	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
118397	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
118398	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
118399	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	80.0		
118400	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Grounds in Place?	y		
118401	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	General Comments			
118402	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	General Comments			
118403	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Foundation Condition	Good		
118404	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Follow-up Action Required?	n		
118405	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Follow-up Action Required?	n		
118406	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations Ground	0		
118407	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0		
118408	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0		
118409	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations C Ø	0		
118410	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations B Ø	0		
118411	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	49527		
118412	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
118413	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y		
118414	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	49527		
118415	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good		
118416	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	2L		
118417	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
118418	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y		
118419	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n		
118420	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y		
118421	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y		
118422	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y		
118423	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y		
118424	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0		
118425	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n		
118426	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments			

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118427	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
118428	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	4R	
118429	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	3L	
118430	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	528	
118431	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
118432	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
118433	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
118434	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
118435	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
118436	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
118437	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
118438	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	317	
118439	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	317	
118440	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	0	
118441	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
118442	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
118443	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
118444	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
118445	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
118446	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
118447	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
118448	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
118449	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
118450	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
118451	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
118452	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
118453	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
118454	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
118455	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
118456	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
118457	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
118458	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
118459	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
118460	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
118461	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
118462	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
118463	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
118464	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
118465	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
118466	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
118467	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
118468	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
118469	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
118470	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
118471	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
118472	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
118473	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
118474	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
118475	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
118476	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
118477	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
118478	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
118479	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
118480	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
118481	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
118482	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
118483	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
118484	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
118485	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
118486	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
118487	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
118488	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
118489	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
118490	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
118491	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Counter Readings	General Comments		
118492	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0471		LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
118493	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
118494	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
118495	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
118496	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
118497	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118498	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118499	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118500	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	462.0	
118501	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	403.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
118502	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	432.0	
118503	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
118504	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
118505	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
118506	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	0	
118507	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
118508	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
118509	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
118510	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
118511	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
118512	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Foundation Condition	Good	
118513	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
118514	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
118515	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	General Comments		
118516	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
118517	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
118518	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
118519	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
118520	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
118521	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
118522	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
118523	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
118524	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
118525	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
118526	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
118527	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
118528	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	0	
118529	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
118530	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
118531	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
118532	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
118533	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	166	
118534	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	120.0	
118535	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
118536	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
118537	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
118538	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	8	
118539	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	1	
118540	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
118541	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
118542	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
118543	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	0.0	
118544	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	0.0	
118545	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	94.0	
118546	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	157.0	
118547	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118548	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118549	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118550	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
118551	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
118552	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
118553	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
118554	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
118555	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
118556	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	0	
118557	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	0.0	
118558	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
118559	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
118560	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
118561	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
118562	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
118563	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
118564	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	171	
118565	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	171	
118566	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
118567	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
118568	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
118569	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
118570	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
118571	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
118572	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
118573	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
118574	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
118575	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	75	°C
118576	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector	BB0394	BreakerVacuum	716-0107	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118577	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Tank Paint Condition	Good		
118578	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Switching Operations	3		
118579	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Spring Compression Ind.	springcharged		
118580	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	28		
118581	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	75.73	%	
118582	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	54.21	%	
118583	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	61.38	%	
118584	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	223.0		
118585	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	229.0		
118586	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	225.0		
118587	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
118588	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
118589	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
118590	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0		
118591	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Operations This Read Vac	3		
118592	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AL	826		
118593	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AF	826		
118594	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Moisture and Leak Free?	y		
118595	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Readings	Maintenance Operations	0		
118596	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Heaters (All) Functioning?	y		
118597	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	1.0060		
118598	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600		
118599	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
118600	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
118601	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
118602	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
118603	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
118604	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None		
118605	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
118606	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	25	°C	
118607	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	65	°C	
118608	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi	
118609	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
118610	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	9657.60	kw	
118611	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y		
118612	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Readings	General Comments			
118613	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments			
118614	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
118615	10/22/2019 8:22	Distribution	UK West Quarterly Inspection S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good		
118616	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	166		
118617	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	0		
118618	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0		
118619	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0		
118620	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52		
118621	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	0		
118622	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y		
118623	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0		
118624	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y		
118625	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y		
118626	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	General Comments			
118627	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments			
118628	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good		
118629	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good		
118630	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0		
118631	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n		
118632	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments			
118633	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0		
118634	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	192		
118635	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	192		
118636	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0		
118637	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0		
118638	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0		
118639	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n		
118640	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n		
118641	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0		
118642	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts	
118643	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC	
118644	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC	
118645	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps	
118646	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n		
118647	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments			
118648	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y		
118649	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good		
118650	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean		
118651	10/22/2019 8:22	Distribution	UK West Quarterly Inspection BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118652	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
118653	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	68	*F
118654	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
118655	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
118656	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	25	*C
118657	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
118658	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
118659	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
118660	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
118661	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
118662	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
118663	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
118664	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
118665	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
118666	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
118667	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118668	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
118669	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118670	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118671	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118672	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118673	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118674	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118675	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118676	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
118677	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
118678	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
118679	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
118680	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
118681	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
118682	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
118683	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
118684	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
118685	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
118686	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118687	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
118688	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
118689	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	61	
118690	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	61	
118691	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
118692	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118693	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
118694	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	12L	
118695	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
118696	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	9L	
118697	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
118698	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
118699	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
118700	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
118701	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
118702	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
118703	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
118704	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
118705	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	275.00	
118706	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
118707	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	*C
118708	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	*C
118709	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	*C
118710	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	*C
118711	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	*C
118712	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	*C
118713	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
118714	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
118715	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
118716	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
118717	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
118718	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
118719	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
118720	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
118721	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
118722	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
118723	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
118724	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
118725	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
118726	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118727	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
118728	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
118729	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
118730	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
118731	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
118732	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
118733	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
118734	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
118735	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	16715	
118736	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	16715	
118737	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
118738	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
118739	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
118740	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
118741	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
118742	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
118743	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
118744	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
118745	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
118746	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
118747	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
118748	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	30.8	%
118749	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	30.8	%
118750	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	30.8	%
118751	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
118752	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Unknown Operations	0	
118753	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
118754	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
118755	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
118756	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
118757	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
118758	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
118759	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
118760	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
118761	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
118762	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
118763	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
118764	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
118765	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
118766	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	219	
118767	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	219	
118768	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
118769	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
118770	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	1	
118771	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Switching Operations	0	
118772	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118773	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations This Read Vac	0	
118774	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AL	169	
118775	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AF	169	
118776	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
118777	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Maintenance Operations	0	
118778	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector K0017	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118779	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	12.76	%
118780	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	12.76	%
118781	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	12.76	%
118782	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
118783	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	1090	
118784	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
118785	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
118786	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
118787	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
118788	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
118789	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
118790	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
118791	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
118792	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
118793	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	32725	
118794	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	32725	
118795	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
118796	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	9L	
118797	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
118798	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	11L	
118799	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	13.0	
118800	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	11.0	
118801	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118802	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118803	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118804	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
118805	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
118806	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
118807	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
118808	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
118809	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
118810	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
118811	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	282	
118812	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	282	
118813	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
118814	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
118815	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
118816	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
118817	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
118818	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	1215	
118819	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
118820	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	725	
118821	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	725	
118822	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations This Read Vac	2	
118823	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118824	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	0	
118825	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
118826	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
118827	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	30.24	%
118828	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	31.68	%
118829	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	27.36	%
118830	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	23.0	
118831	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	21.0	
118832	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	42.0	
118833	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
118834	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
118835	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118836	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118837	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118838	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118839	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
118840	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
118841	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118842	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118843	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	1	
118844	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
118845	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
118846	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
118847	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
118848	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
118849	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
118850	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
118851	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
118852	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
118853	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118854	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
118855	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
118856	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	97	
118857	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	97	
118858	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	1	
118859	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
118860	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
118861	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
118862	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
118863	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	2	
118864	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
118865	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
118866	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
118867	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0.0	
118868	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0.0	
118869	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0.0	
118870	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
118871	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
118872	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
118873	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118874	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
118875	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
118876	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118877	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118878	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118879	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	3	
118880	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
118881	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
118882	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
118883	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
118884	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
118885	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
118886	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
118887	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
118888	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118889	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
118890	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
118891	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
118892	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
118893	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
118894	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
118895	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
118896	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
118897	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
118898	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
118899	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
118900	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	2	
118901	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
118902	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC0000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
118903	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC0000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
118904	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC0000800	LTCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds
118905	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
118906	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
118907	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
118908	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
118909	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
118910	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
118911	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
118912	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
118913	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
118914	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
118915	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
118916	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
118917	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Follow-up Action Required?	n	
118918	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
118919	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	General Comments		
118920	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	General Comments		
118921	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	66162	
118922	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	66162	
118923	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
118924	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	8L	
118925	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	2L	
118926	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	8L	
118927	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
118928	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	372	
118929	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
118930	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
118931	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
118932	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
118933	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
118934	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
118935	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
118936	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
118937	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
118938	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
118939	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
118940	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.9	psi
118941	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
118942	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	*C
118943	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
118944	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
118945	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
118946	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
118947	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
118948	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
118949	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
118950	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
118951	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
118952	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
118953	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
118954	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
118955	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
118956	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
118957	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
118958	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
118959	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
118960	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
118961	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
118962	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
118963	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
118964	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
118965	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
118966	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Unknown Operations	0	
118967	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
118968	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
118969	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
118970	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
118971	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
118972	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
118973	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
118974	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
118975	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
118976	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	*F
118977	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
118978	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
118979	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC000800	LTCControl	526-1	LTC Control Insp	All Connections OK?	y	
118980	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC000800	LTCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
118981	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC000800	LTCControl	526-1	LTC Control Insp	General Comments		
118982	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC000800	LTCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
118983	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	LTC000800	LTCControl	526-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
118984	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
118985	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
118986	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
118987	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
118988	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
118989	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
118990	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
118991	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
118992	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
118993	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	
118994	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	1	
118995	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
118996	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
118997	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
118998	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
118999	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119000	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119001	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushing Condition	Good	
119002	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps C Ø	0.0	
119003	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps B Ø	5.0	
119004	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps A Ø	20.0	
119005	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119006	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119007	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119008	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations	5	
119009	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
119010	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
119011	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	0	
119012	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations This Read Vac	0	
119013	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	174	
119014	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	174	
119015	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
119016	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
119017	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
119018	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
119019	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
119020	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
119021	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
119022	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119023	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
119024	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119025	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119026	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	100.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119027	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	115.0	
119028	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	150.0	
119029	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
119030	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119031	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119032	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
119033	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	0	
119034	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	0	
119035	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119036	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119037	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119038	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations Ground	0	
119039	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations C Ø	0	
119040	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations B Ø	0	
119041	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations A Ø	0	
119042	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119043	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119044	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119045	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119046	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119047	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119048	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Months Operations	3	
119049	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.8	%
119050	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.8	%
119051	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	5.2	%
119052	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps A Ø	210.0	
119053	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
119054	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps C Ø	150.0	
119055	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
119056	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
119057	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
119058	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
119059	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
119060	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
119061	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
119062	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
119063	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	General Comments		
119064	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Maintenance Operations	0	
119065	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AF	532	
119066	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AL	532	
119067	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations This Read AM	0	
119068	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Switching Operations	0	
119069	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Unknown Operations	0	
119070	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	0	
119071	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119072	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119073	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
119074	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
119075	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
119076	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
119077	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
119078	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
119079	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
119080	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
119081	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
119082	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
119083	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119084	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
119085	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
119086	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	167	
119087	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	167	
119088	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations This Read Vac	0	
119089	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119090	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	0	
119091	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	LTC000552	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
119092	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119093	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
119094	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
119095	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
119096	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
119097	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
119098	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
119099	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
119100	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
119101	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119102	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y		
119103	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y		
119104	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y		
119105	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n		
119106	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good		
119107	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y		
119108	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y		
119109	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments			
119110	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y		
119111	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y		
119112	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y		
119113	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	2		
119114	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
119115	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
119116	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y		
119117	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y		
119118	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean		
119119	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y		
119120	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
119121	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good		
119122	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good		
119123	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	320.0		
119124	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	320.0		
119125	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	315.0		
119126	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
119127	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
119128	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
119129	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	8		
119130	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	87.84	%	
119131	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	87.84	%	
119132	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	87.84	%	
119133	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0		
119134	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0		
119135	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0		
119136	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good		
119137	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good		
119138	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
119139	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y		
119140	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean		
119141	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good		
119142	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y		
119143	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
119144	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
119145	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
119146	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y		
119147	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
119148	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
119149	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good		
119150	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset		
119151	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
119152	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good		
119153	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup	
119154	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	294		
119155	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good		
119156	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L		
119157	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L		
119158	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L		
119159	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good		
119160	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	53292		
119161	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	53292		
119162	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments			
119163	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments			
119164	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
119165	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n		
119166	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter	
119167	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
119168	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
119169	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		
119170	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
119171	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good		
119172	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
119173	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good		
119174	10/22/2019 8:22	Distribution	UK West Quarterly Inspection B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y		
119175	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Unknown Operations	0		
119176	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119177	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Switching Operations	0	
119178	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119179	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations This Read Vac	0	
119180	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AL	49	
119181	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AF	49	
119182	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
119183	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Maintenance Operations	0	
119184	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
119185	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	
119186	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
119187	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
119188	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
119189	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
119190	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
119191	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
119192	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
119193	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
119194	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
119195	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
119196	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	0	
119197	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119198	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119199	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119200	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119201	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
119202	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	
119203	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119204	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119205	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119206	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119207	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119208	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119209	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119210	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119211	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119212	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
119213	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	115.0	
119214	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	100.0	
119215	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	130.0	
119216	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119217	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119218	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119219	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	3	
119220	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Unknown Operations	0	
119221	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Tank Paint Condition	Good	
119222	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	0	
119223	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations This Read Vac	0	
119224	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	186	
119225	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	186	
119226	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
119227	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	0	
119228	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119229	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
119230	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
119231	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
119232	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
119233	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
119234	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Follow-up Action Required?	n	
119235	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations Ground	0	
119236	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations C Ø	0	
119237	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations B Ø	0	
119238	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations A Ø	0	
119239	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119240	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119241	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119242	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119243	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119244	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119245	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119246	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119247	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119248	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushing Condition	Good	
119249	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps C Ø	465.0	
119250	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps B Ø	565.0	
119251	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps A Ø	505.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119252	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119253	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119254	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119255	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
119256	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
119257	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
119258	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	22.32	%
119259	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	32.68	%
119260	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	0	
119261	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
119262	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119263	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119264	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119265	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119266	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119267	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119268	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
119269	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
119270	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
119271	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
119272	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119273	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
119274	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119275	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
119276	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
119277	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
119278	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
119279	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	205	
119280	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	205	
119281	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
119282	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
119283	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
119284	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
119285	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
119286	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
119287	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
119288	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119289	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119290	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119291	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	130.0	
119292	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	160.0	
119293	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	140.0	
119294	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	0	
119295	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
119296	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	0	
119297	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations This Read Vac	0	
119298	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	188	
119299	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	188	
119300	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
119301	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
119302	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
119303	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		
119304	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments		
119305	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
119306	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
119307	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
119308	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
119309	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
119310	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119311	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119312	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119313	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119314	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	General Comments		
119315	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Foundation Condition	Good	
119316	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
119317	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
119318	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
119319	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
119320	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
119321	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
119322	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
119323	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
119324	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
119325	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
119326	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119327	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	12208.32	kw
119328	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
119329	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
119330	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
119331	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
119332	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
119333	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
119334	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
119335	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
119336	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
119337	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
119338	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
119339	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
119340	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
119341	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
119342	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
119343	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
119344	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	197	
119345	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	197	
119346	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
119347	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
119348	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
119349	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
119350	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
119351	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
119352	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
119353	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119354	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119355	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119356	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	480.0	
119357	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	500.0	
119358	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	520.0	
119359	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
119360	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
119361	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
119362	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Follow-up Action Required?	n	
119363	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Follow-up Action Required?	n	
119364	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BK00049	BreakerVacuum	716-1	VCB Readings	9 Month Operations	0	
119365	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
119366	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
119367	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
119368	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
119369	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
119370	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
119371	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
119372	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
119373	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
119374	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
119375	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
119376	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
119377	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
119378	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
119379	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
119380	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
119381	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
119382	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
119383	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
119384	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
119385	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
119386	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
119387	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
119388	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
119389	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	4.78	%
119390	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	2	
119391	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
119392	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
119393	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
119394	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
119395	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
119396	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
119397	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
119398	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	9	
119399	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119400	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119401	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
119402	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
119403	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
119404	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
119405	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
119406	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119407	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119408	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Switching Operations	0	
119409	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119410	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations This Read Vac	0	
119411	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AL	179	
119412	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AF	179	
119413	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Moisture and Leak Free?	y	
119414	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Maintenance Operations	0	
119415	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119416	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Grounds in Place?	y	
119417	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	General Comments		
119418	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119419	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
119420	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
119421	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
119422	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
119423	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	6392	
119424	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	6392	
119425	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
119426	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	2.88	%
119427	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	2.88	%
119428	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	0	
119429	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	6L	
119430	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Maintenance Operations	0	
119431	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119432	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	General Comments	IOC A,B, and C phase	
119433	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
119434	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Follow-up Action Required?	n	
119435	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
119436	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations Ground	0	
119437	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations C Ø	0	
119438	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations B Ø	0	
119439	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations A Ø	0	
119440	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119441	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119442	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119443	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119444	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps C Ø	120.0	
119445	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps B Ø	110.0	
119446	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps A Ø	110.0	
119447	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty C Ph V	4.02	%
119448	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty B Ph V	12.85	%
119449	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty A Ph V	6.42	%
119450	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations	0	
119451	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Unknown Operations	1	
119452	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Switching Operations	0	
119453	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	3R	
119454	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	8L	
119455	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119456	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119457	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119458	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119459	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119460	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
119461	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	0.0	
119462	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	0.0	
119463	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	4.0	
119464	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119465	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119466	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119467	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	4	
119468	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
119469	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
119470	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
119471	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	897	
119472	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
119473	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
119474	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	3844.80	kw
119475	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
119476	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119477	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
119478	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	40	°C
119479	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	20	°C
119480	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
119481	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
119482	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
119483	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
119484	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
119485	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
119486	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
119487	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
119488	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
119489	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
119490	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
119491	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
119492	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119493	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119494	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119495	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119496	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119497	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119498	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
119499	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.2670	
119500	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
119501	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
119502	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
119503	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
119504	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	General Comments		
119505	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Foundation Condition	Good	
119506	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Follow-up Action Required?	n	
119507	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Follow-up Action Required?	n	
119508	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations Ground	0	
119509	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations C Ø	0	
119510	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations B Ø	0	
119511	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations A Ø	0	
119512	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119513	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119514	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119515	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119516	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	40	°C
119517	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	25	°C
119518	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
119519	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
119520	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119521	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119522	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119523	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
119524	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	102.0	
119525	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	107.0	
119526	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	101.0	
119527	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	2.88	%
119528	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Maintenance Operations	0	
119529	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
119530	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Grounds in Place?	y	
119531	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	General Comments	y	
119532	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	General Comments		
119533	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
119534	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Foundation Condition	Good	
119535	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Follow-up Action Required?	n	
119536	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations B Ø	0	
119537	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations C Ø	0	
119538	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations Ground	0	
119539	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
119540	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Follow-up Action Required?	n	
119541	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
119542	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Follow-up Action Required?	n	
119543	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Fault Operations	0	
119544	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
119545	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
119546	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119547	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
119548	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
119549	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	59	°F
119550	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
119551	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
119552	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
119553	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
119554	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
119555	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations This Read SF6	0	
119556	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	64	
119557	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	64	
119558	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	1	
119559	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
119560	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
119561	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
119562	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
119563	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
119564	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
119565	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
119566	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	
119567	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	
119568	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
119569	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
119570	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
119571	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
119572	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119573	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
119574	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Unknown Operations	0	
119575	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Switching Operations	0	
119576	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations This Read Vac	0	
119577	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AL	251	
119578	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AF	251	
119579	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Maintenance Operations	0	
119580	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119581	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	General Comments		
119582	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
119583	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
119584	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
119585	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
119586	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
119587	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	General Comments		
119588	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
119589	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
119590	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
119591	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
119592	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	LTC0000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
119593	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	59	*F
119594	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
119595	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations	3	
119596	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty A Ph V	4.82	%
119597	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty B Ph V	3.21	%
119598	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty C Ph V	3.21	%
119599	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Months Operations	17	
119600	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps A Ø	300.0	
119601	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps B Ø	320.0	
119602	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps C Ø	280.0	
119603	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119604	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119605	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119606	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119607	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations A Ø	0	
119608	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty A Ph AM	25.29	%
119609	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty B Ph AM	22.89	%
119610	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
119611	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps A Ø	50.0	
119612	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps B Ø	30.0	
119613	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps C Ø	80.0	
119614	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
119615	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
119616	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
119617	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations A Ø	0	
119618	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations B Ø	0	
119619	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations C Ø	0	
119620	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations Ground	0	
119621	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Follow-up Action Required?	n	
119622	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	General Comments		
119623	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Maintenance Operations	0	
119624	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AF	1384	
119625	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AL	1384	
119626	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations This Read AM	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119627	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Tank Paint Condition	Good	
119628	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Switching Operations	0	
119629	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
119630	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
119631	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
119632	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations This Read SF6	0	
119633	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AL	69	
119634	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AF	69	
119635	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Num Operations Last 9 Months	1	
119636	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
119637	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
119638	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
119639	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
119640	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations This Read Vac	0	
119641	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119642	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	0	
119643	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	
119644	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
119645	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
119646	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
119647	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
119648	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119649	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
119650	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	148	
119651	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	87.0	
119652	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
119653	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119654	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119655	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119656	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119657	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119658	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119659	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119660	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119661	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119662	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	50.0	
119663	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	50.0	
119664	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	50.0	
119665	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
119666	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119667	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119668	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119669	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119670	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119671	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119672	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119673	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119674	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119675	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	
119676	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
119677	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
119678	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	
119679	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
119680	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
119681	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	
119682	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
119683	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
119684	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
119685	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119686	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	0	
119687	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
119688	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	348	
119689	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	348	
119690	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations This Read Vac	0	
119691	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
119692	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
119693	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
119694	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations Ground	0	
119695	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
119696	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
119697	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
119698	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
119699	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments		
119700	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
119701	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119702	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
119703	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
119704	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	287	
119705	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	287	
119706	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	5	
119707	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Unknown Operations	0	
119708	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Tank Paint Condition	Good	
119709	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	0	
119710	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119711	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations This Read Vac	0	
119712	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AL	192	
119713	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AF	192	
119714	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
119715	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
119716	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
119717	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
119718	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
119719	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
119720	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
119721	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	4	
119722	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119723	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	4	
119724	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
119725	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Unknown Operations	0	
119726	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
119727	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
119728	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
119729	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	4	
119730	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	23.04	%
119731	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	34.56	%
119732	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	10.08	%
119733	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	85.0	
119734	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	87.0	
119735	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	General Comments		
119736	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
119737	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
119738	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119739	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
119740	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
119741	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	155	
119742	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	155	
119743	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119744	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
119745	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
119746	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations Ground	0	
119747	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations C Ø	0	
119748	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations B Ø	0	
119749	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations A Ø	0	
119750	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119751	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119752	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119753	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119754	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119755	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119756	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119757	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119758	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119759	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119760	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
119761	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
119762	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
119763	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
119764	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119765	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119766	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushing Condition	Good	
119767	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps C Ø	5.0	
119768	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps B Ø	5.0	
119769	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps A Ø	5.0	
119770	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119771	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119772	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119773	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations	5	
119774	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
119775	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
119776	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119777	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations This Read Vac	0	
119778	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	168	
119779	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	168	
119780	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119781	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119782	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
119783	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
119784	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
119785	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
119786	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
119787	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
119788	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
119789	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
119790	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
119791	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
119792	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
119793	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
119794	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
119795	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
119796	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
119797	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
119798	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
119799	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
119800	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119801	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	0	
119802	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
119803	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	0	
119804	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119805	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	0	
119806	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	148	
119807	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
119808	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
119809	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119810	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
119811	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
119812	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
119813	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
119814	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
119815	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	0	
119816	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
119817	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	
119818	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
119819	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
119820	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
119821	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
119822	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments		
119823	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
119824	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119825	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
119826	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
119827	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	75	
119828	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	75	
119829	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	0	
119830	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119831	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	0	
119832	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
119833	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Unknown Operations	0	
119834	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
119835	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
119836	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
119837	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
119838	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
119839	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119840	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119841	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119842	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119843	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119844	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119845	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B80289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119846	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Moisture and Leak Free?	y	
119847	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Maintenance Operations	0	
119848	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119849	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Grounds in Place?	y	
119850	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	General Comments		
119851	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119852	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Foundation Condition	Good	
119853	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Follow-up Action Required?	n	
119854	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Follow-up Action Required?	n	
119855	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
119856	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
119857	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
119858	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
119859	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
119860	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
119861	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
119862	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
119863	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations This Read Vac	2	
119864	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	2	
119865	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
119866	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
119867	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	5	
119868	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119869	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119870	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119871	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	100.0	
119872	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	95.0	
119873	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	100.0	
119874	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
119875	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119876	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119877	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119878	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119879	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119880	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119881	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119882	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119883	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119884	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
119885	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
119886	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
119887	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
119888	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
119889	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
119890	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
119891	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
119892	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
119893	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
119894	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
119895	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
119896	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
119897	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
119898	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
119899	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
119900	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
119901	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
119902	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
119903	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
119904	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
119905	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119906	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	60.0	
119907	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	60.0	
119908	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	65.0	
119909	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
119910	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119911	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119912	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119913	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119914	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119915	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119916	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119917	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119918	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	1050	
119919	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	8L	
119920	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	5R	
119921	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	5L	
119922	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
119923	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	55823	
119924	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	55823	
119925	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
119926	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
119927	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
119928	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
119929	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
119930	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
119931	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
119932	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
119933	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
119934	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
119935	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
119936	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
119937	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
119938	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
119939	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
119940	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
119941	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
119942	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	180	
119943	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	180	
119944	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
119945	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
119946	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
119947	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
119948	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
119949	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
119950	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	89	
119951	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	89	
119952	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
119953	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
119954	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
119955	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations	3	
119956	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty A Ph V	1.18	%
119957	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%
119958	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119959	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps A Ø	50.0	
119960	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps B Ø	70.0	
119961	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps C Ø	100.0	
119962	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
119963	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
119964	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
119965	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations A Ø	0	
119966	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations B Ø	0	
119967	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations C Ø	0	
119968	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations Ground	0	
119969	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Follow-up Action Required?	n	
119970	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	General Comments	IOC A,B and C phase	
119971	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Maintenance Operations	0	
119972	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AF	140	
119973	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AL	140	
119974	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations This Read Vac	3	
119975	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Switching Operations	0	
119976	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Unknown Operations	3	
119977	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
119978	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	50.0	
119979	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	70.0	
119980	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	95.0	
119981	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
119982	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
119983	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
119984	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
119985	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
119986	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
119987	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
119988	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
119989	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
119990	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
119991	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	186	
119992	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	186	
119993	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations This Read Vac	0	
119994	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
119995	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	0	
119996	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
119997	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
119998	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	5	
119999	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120000	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120001	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Months Operations	3	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120002	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty A Ph AM	24.09	%
120003	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
120004	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty C Ph AM	20.48	%
120005	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps A Ø	190.0	
120006	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps B Ø	180.0	
120007	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps C Ø	200.0	
120008	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
120009	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
120010	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
120011	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations A Ø	0	
120012	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations B Ø	0	
120013	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations C Ø	0	
120014	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations Ground	0	
120015	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Follow-up Action Required?	n	
120016	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	General Comments	IOC B phase	
120017	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Maintenance Operations	0	
120018	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AF	768	
120019	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AL	768	
120020	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations This Read AM	0	
120021	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Switching Operations	0	
120022	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Unknown Operations	0	
120023	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
120024	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	15.59	%
120025	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	15.59	%
120026	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	15.59	%
120027	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
120028	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
120029	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
120030	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
120031	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
120032	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
120033	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
120034	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
120035	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
120036	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
120037	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.7650	
120038	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Unknown Operations	0	
120039	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Switching Operations	0	
120040	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations This Read Vac	0	
120041	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AL	448	
120042	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AF	448	
120043	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
120044	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
120045	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	35	°C
120046	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
120047	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
120048	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
120049	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
120050	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
120051	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
120052	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
120053	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
120054	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	35	°C
120055	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	35	°C
120056	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
120057	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
120058	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	10710.00	kw
120059	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
120060	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
120061	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
120062	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
120063	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
120064	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
120065	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
120066	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
120067	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
120068	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
120069	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
120070	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
120071	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
120072	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
120073	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
120074	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
120075	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
120076	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120077	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	51	
120078	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	50.59	%
120079	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	49.38	%
120080	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
120081	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
120082	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
120083	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
120084	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
120085	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
120086	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
120087	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
120088	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
120089	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
120090	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
120091	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
120092	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
120093	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
120094	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
120095	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
120096	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
120097	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
120098	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
120099	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
120100	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
120101	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
120102	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
120103	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
120104	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	General Comments		
120105	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
120106	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
120107	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
120108	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
120109	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	LTC0000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
120110	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
120111	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
120112	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
120113	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
120114	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
120115	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
120116	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
120117	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
120118	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
120119	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
120120	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
120121	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
120122	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
120123	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
120124	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
120125	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120126	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120127	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120128	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	VCB Patrol Inspection	Bushing Condition	Good	
120129	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Amps C Ø	360.0	
120130	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Amps B Ø	360.0	
120131	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Amps A Ø	360.0	
120132	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120133	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120134	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120135	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector BB0441	BreakerVacuum	716-0023	VCB Readings	VCB Readings	9 Month Operations	3	
120136	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	35	*C
120137	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	.3010	
120138	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
120139	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
120140	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
120141	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
120142	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
120143	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
120144	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
120145	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
120146	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	25	*C
120147	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	25	*C
120148	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
120149	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
120150	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	4334.40	kw
120151	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
120152	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	General Comments		
120153	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
120154	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
120155	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
120156	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
120157	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
120158	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
120159	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
120160	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
120161	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
120162	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
120163	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
120164	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
120165	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
120166	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
120167	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
120168	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
120169	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	7	
120170	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	42.16	%
120171	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	220.0	
120172	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	180.0	
120173	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	200.0	
120174	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
120175	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
120176	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
120177	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
120178	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
120179	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
120180	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
120181	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
120182	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments	C Phase Inst	
120183	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
120184	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	267	
120185	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	267	
120186	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
120187	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
120188	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
120189	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Unknown Operations	0	
120190	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Tank Paint Condition	Good	
120191	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Switching Operations	0	
120192	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
120193	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations This Read Vac	0	
120194	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AL	623	
120195	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AF	623	
120196	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Moisture and Leak Free?	y	
120197	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Maintenance Operations	0	
120198	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120199	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Grounds in Place?	y	
120200	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	General Comments		
120201	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	General Comments		
120202	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Foundation Condition	Good	
120203	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Follow-up Action Required?	n	
120204	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Follow-up Action Required?	n	
120205	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations Ground	0	
120206	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations C Ø	0	
120207	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations B Ø	0	
120208	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations A Ø	0	
120209	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120210	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120211	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120212	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120213	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120214	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120215	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120216	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120217	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps A Ø	100.0	
120218	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps B Ø	95.0	
120219	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Unknown Operations	0	
120220	10/22/2019 13:44	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Tank Paint Condition	Good	
120221	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps C Ø	100.0	
120222	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushing Condition	Good	
120223	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120224	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120225	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120226	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120227	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120228	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120229	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120230	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120231	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120232	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations A Ø	0	
120233	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC000159	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
120234	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
120235	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
120236	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
120237	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
120238	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
120239	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations B Ø	0	
120240	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations C Ø	0	
120241	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations Ground	0	
120242	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
120243	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
120244	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
120245	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
120246	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	
120247	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
120248	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
120249	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		
120250	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
120251	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
120252	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
120253	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
120254	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
120255	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
120256	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Unknown Operations	0	
120257	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
120258	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	0	
120259	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
120260	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	0	
120261	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	123	
120262	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	123	
120263	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
120264	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
120265	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120266	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
120267	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
120268	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
120269	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
120270	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	
120271	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
120272	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
120273	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
120274	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	186	
120275	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
120276	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	186	
120277	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
120278	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments	Actual Counter	
120279	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
120280	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
120281	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
120282	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
120283	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
120284	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120285	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120286	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120287	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	
120288	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
120289	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
120290	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	0	
120291	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120292	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120293	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120294	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120295	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120296	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120297	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120298	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120299	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	
120300	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
120301	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120302	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
120303	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
120304	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
120305	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
120306	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120307	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120308	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120309	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	5	
120310	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Unknown Operations	0	
120311	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Tank Paint Condition	Good	
120312	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Switching Operations	0	
120313	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	55	°C
120314	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
120315	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations This Read Vac	0	
120316	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AL	142	
120317	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	142	
120318	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
120319	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
120320	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	30	°C
120321	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
120322	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
120323	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120324	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
120325	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
120326	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
120327	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
120328	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
120329	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
120330	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
120331	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
120332	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
120333	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
120334	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
120335	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
120336	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
120337	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
120338	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
120339	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
120340	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
120341	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC0000159	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
120342	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC0000159	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
120343	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC0000159	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
120344	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC0000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
120345	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTC0000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
120346	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
120347	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
120348	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
120349	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
120350	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
120351	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	188	
120352	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	188	
120353	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations This Read Vac	0	
120354	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	0	
120355	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Tank Paint Condition	Good	
120356	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Unknown Operations	0	
120357	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations	1	
120358	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120359	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations This Read Vac	0	
120360	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	138	
120361	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120362	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
120363	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Counter Readings	Reset Tap Drag Hands	Reset	
120364	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
120365	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Counter Readings	LTC Operations Since Last Insp	0	
120366	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
120367	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120368	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120369	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120370	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120371	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
120372	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
120373	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
120374	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Counter Readings	LTC Min Tap Position	Neutral	
120375	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Counter Readings	LTC Max Tap Position	Neutral	
120376	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspector B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Counter Readings	LTC Current Tap Position	Neutral	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120377	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good		
120378	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	13897		
120379	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
120380	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	7.2	
120381	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	7.2	
120382	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	7.2	
120383	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments			
120384	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y		
120385	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None		
120386	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y		
120387	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	
120388	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	
120389	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	0	
120390	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
120391	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	
120392	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	138	
120393	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	13897		
120394	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.8478	
120395	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	55	
120396	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
120397	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
120398	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	40	
120399	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
120400	10/22/2019 8:22	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
120401	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments			
120402	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments			
120403	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
120404	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n		
120405	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	130.0	
120406	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	130.0	
120407	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y		
120408	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y		
120409	10/22/2019 13:32	Distribution	Higby Mill Distribution Quarterly Inspection YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n		
120410	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	160.0	
120411	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
120412	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
120413	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120414	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
120415	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
120416	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
120417	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120418	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120419	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120420	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120421	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
120422	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	
120423	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
120424	10/22/2019 14:02	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	70	
120425	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
120426	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
120427	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
120428	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
120429	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
120430	10/22/2019 11:09	Distribution	Tip Top Quarterly Inspection	CAPO00133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
120431	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	0	
120432	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	
120433	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
120434	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
120435	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
120436	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
120437	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
120438	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	
120439	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	
120440	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	
120441	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	
120442	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	
120443	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
120444	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
120445	10/22/2019 11:18	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
120446	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	
120447	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	
120448	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	
120449	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	
120450	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
120451	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120602	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
120603	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
120604	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
120605	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
120606	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
120607	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
120608	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
120609	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
120610	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	260	
120611	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	260	
120612	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
120613	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
120614	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
120615	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120616	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120617	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120618	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	400.0	
120619	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
120620	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400.0	
120621	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120622	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120623	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120624	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120625	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
120626	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
120627	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
120628	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
120629	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120630	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
120631	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
120632	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
120633	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
120634	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120635	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120636	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120637	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120638	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120639	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
120640	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
120641	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
120642	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
120643	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
120644	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
120645	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
120646	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
120647	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
120648	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
120649	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
120650	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
120651	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	33	°C
120652	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
120653	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
120654	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
120655	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
120656	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
120657	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
120658	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
120659	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
120660	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
120661	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
120662	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
120663	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
120664	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
120665	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
120666	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
120667	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
120668	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
120669	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
120670	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
120671	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
120672	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
120673	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	General Comments		
120674	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
120675	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000218	LTCControl	896-2	LTC Control Insp	All Connections OK?	y	
120676	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTO173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
120677	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments		
120678	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
120679	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
120680	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
120681	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	912.00	kw
120682	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
120683	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
120684	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
120685	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
120686	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
120687	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
120688	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
120689	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
120690	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
120691	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	44	°C
120692	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
120693	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
120694	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
120695	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
120696	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
120697	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
120698	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
120699	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
120700	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
120701	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	General Comments	OFFLINE	
120702	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
120703	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
120704	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
120705	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
120706	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
120707	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
120708	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
120709	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
120710	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
120711	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
120712	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
120713	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
120714	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
120715	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
120716	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
120717	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
120718	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
120719	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
120720	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
120721	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
120722	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
120723	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
120724	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
120725	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	LTC000507	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
120726	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
120727	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
120728	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
120729	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
120730	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
120731	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
120732	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
120733	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
120734	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
120735	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
120736	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
120737	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
120738	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
120739	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
120740	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
120741	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
120742	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
120743	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
120744	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
120745	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
120746	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
120747	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120748	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	0	
120749	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	
120750	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	230	
120751	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	230	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
120752	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations This Read Vac	0	
120753	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
120754	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
120755	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
120756	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
120757	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
120758	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
120759	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
120760	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments		
120761	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
120762	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
120763	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
120764	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
120765	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LTC0000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
120766	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
120767	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
120768	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
120769	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
120770	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
120771	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
120772	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
120773	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	0	
120774	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
120775	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
120776	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
120777	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
120778	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
120779	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
120780	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
120781	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	55	°C
120782	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
120783	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
120784	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations	1	
120785	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120786	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
120787	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
120788	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
120789	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
120790	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
120791	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
120792	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
120793	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
120794	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
120795	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
120796	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120797	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	14583.60	kw
120798	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
120799	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120800	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120801	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120802	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120803	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushing Condition	Good	
120804	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps C Ø	0.0	
120805	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps B Ø	0.0	
120806	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps A Ø	0.0	
120807	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120808	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
120809	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
120810	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
120811	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
120812	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
120813	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
120814	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
120815	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	57	
120816	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	57	
120817	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
120818	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
120819	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
120820	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
120821	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
120822	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
120823	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
120824	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
120825	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.1900	
120826	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
120827	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
120828	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
120829	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	
120830	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	0	
120831	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations This Read Vac	0	
120832	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	211	
120833	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	211	
120834	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
120835	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	0	
120836	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
120837	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
120838	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
120839	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
120840	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
120841	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	
120842	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
120843	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C Ø	0	
120844	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B Ø	0	
120845	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A Ø	0	
120846	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120847	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120848	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120849	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120850	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120851	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
120852	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
120853	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	55	°C
120854	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	.8102	
120855	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
120856	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
120857	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
120858	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	1	
120859	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120860	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120861	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120862	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	105.0	
120863	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	105.0	
120864	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	105.0	
120865	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
120866	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120867	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120868	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120869	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120870	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120871	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120872	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120873	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120874	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120875	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
120876	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
120877	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
120878	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
120879	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
120880	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
120881	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
120882	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
120883	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
120884	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
120885	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
120886	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
120887	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
120888	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
120889	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
120890	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
120891	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
120892	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
120893	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
120894	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
120895	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
120896	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
120897	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
120898	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
120899	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Heaters (All) Functioning?	y	
120900	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
120901	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
120902	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	214	
120903	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	214	
120904	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations This Read Vac	0	
120905	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	0	
120906	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
120907	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
120908	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120909	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
120910	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
120911	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
120912	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
120913	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
120914	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	80202	
120915	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
120916	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
120917	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
120918	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
120919	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
120920	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
120921	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	9L	
120922	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
120923	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
120924	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
120925	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
120926	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
120927	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
120928	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	9L	
120929	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
120930	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
120931	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
120932	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
120933	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120934	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120935	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120936	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120937	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120938	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120939	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
120940	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
120941	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
120942	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
120943	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
120944	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
120945	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
120946	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
120947	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
120948	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
120949	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
120950	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
120951	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
120952	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	250.0	
120953	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	250.0	
120954	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	
120955	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
120956	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
120957	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	200.0	
120958	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
120959	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
120960	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
120961	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	1	
120962	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
120963	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
120964	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments	2 4ft bulbs changed on the light that is on all the time and the lights still didn't work. High sewage level alarm on the annunciator	
120965	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
120966	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
120967	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
120968	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
120969	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
120970	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
120971	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
120972	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
120973	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
120974	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
120975	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
120976	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
120977	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
120978	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
120979	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
120980	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
120981	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
120982	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
120983	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
120984	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
120985	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
120986	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
120987	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
120988	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
120989	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
120990	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
120991	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
120992	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
120993	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
120994	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
120995	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
120996	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
120997	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
120998	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
120999	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
121000	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
121001	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
121002	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
121003	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
121004	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
121005	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
121006	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
121007	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121008	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	300.0	
121009	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	280.0	
121010	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	300.0	
121011	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
121012	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121013	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121014	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121015	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121016	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
121017	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
121018	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
121019	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
121020	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
121021	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
121022	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
121023	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
121024	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121025	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
121026	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	150	
121027	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	150	
121028	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
121029	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	0	
121030	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Unknown Operations	0	
121031	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	1	
121032	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121033	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	7	
121034	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121035	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121036	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121037	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	60.0	
121038	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
121039	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
121040	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
121041	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
121042	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
121043	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
121044	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
121045	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
121046	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
121047	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0982	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
121048	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
121049	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	62	*F
121050	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	62	*F
121051	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121052	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
121053	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121054	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
121055	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
121056	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
121057	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
121058	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
121059	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
121060	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
121061	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
121062	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	
121063	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
121064	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
121065	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
121066	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
121067	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	0	
121068	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	66	
121069	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	66	
121070	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations This Read SF6	0	
121071	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
121072	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	2	
121073	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
121074	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
121075	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
121076	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	20.0	
121077	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	20.0	
121078	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	20.0	
121079	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
121080	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
121081	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
121082	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
121083	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
121084	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
121085	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
121086	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
121087	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
121088	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
121089	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
121090	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments	IOC B phase	
121091	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
121092	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	95	
121093	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
121094	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
121095	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	0	
121096	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	95	
121097	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	1	
121098	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
121099	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Unknown Operations	1	
121100	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
121101	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	1	
121102	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121103	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121104	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121105	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121106	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121107	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121108	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121109	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121110	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121111	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
121112	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
121113	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
121114	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
121115	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
121116	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
121117	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
121118	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
121119	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
121120	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
121121	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121122	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
121123	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
121124	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	189	
121125	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	189	
121126	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations This Read Vac	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
121127	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	1	
121128	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
121129	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
121130	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	1	
121131	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121132	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121133	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121134	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	300.0	
121135	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	340.0	
121136	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	300.0	
121137	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
121138	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121139	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121140	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121141	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121142	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121143	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121144	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121145	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121146	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121147	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	
121148	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
121149	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
121150	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
121151	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	
121152	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
121153	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
121154	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
121155	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
121156	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
121157	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121158	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
121159	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
121160	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
121161	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
121162	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
121163	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
121164	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
121165	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
121166	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Num Operations Last 9 Months	1	
121167	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	47	
121168	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	47	
121169	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations This Read SF6	1	
121170	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
121171	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
121172	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
121173	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	1	
121174	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
121175	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
121176	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
121177	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
121178	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
121179	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
121180	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
121181	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
121182	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
121183	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
121184	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
121185	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
121186	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
121187	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
121188	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
121189	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	0	
121190	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121191	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	0	
121192	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	246	
121193	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	246	
121194	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
121195	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
121196	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121197	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
121198	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
121199	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
121200	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
121201	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
121202	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
121203	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
121204	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
121205	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
121206	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
121207	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	5	
121208	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121209	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121210	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121211	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
121212	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
121213	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
121214	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
121215	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121216	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121217	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	303	
121218	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	303	
121219	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
121220	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
121221	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
121222	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
121223	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
121224	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
121225	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
121226	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	0	
121227	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
121228	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
121229	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
121230	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
121231	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
121232	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	100.0	
121233	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	100.0	
121234	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	100.0	
121235	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
121236	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
121237	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
121238	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	7	
121239	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121240	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121241	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121242	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121243	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121244	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121245	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
121246	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
121247	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
121248	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
121249	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
121250	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
121251	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	
121252	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
121253	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
121254	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
121255	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121256	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
121257	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
121258	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	214	
121259	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	214	
121260	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations This Read Vac	0	
121261	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	0	
121262	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
121263	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
121264	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	4	
121265	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121266	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121267	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121268	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	90.0	
121269	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	90.0	
121270	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	80.0	
121271	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
121272	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121273	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121274	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	164	
121275	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	164	
121276	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121277	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	0	
121278	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
121279	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
121280	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations	2	
121281	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121282	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121283	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121284	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	145.0	
121285	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	160.0	
121286	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	140.0	
121287	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
121288	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121289	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121290	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121291	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121292	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121293	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121294	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121295	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121296	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121297	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	0	
121298	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	0	
121299	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
121300	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
121301	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
121302	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
121303	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
121304	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
121305	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
121306	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
121307	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121308	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
121309	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
121310	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	186	
121311	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	186	
121312	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations This Read Vac	0	
121313	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	0	
121314	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
121315	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	0	
121316	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	4	
121317	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121318	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121319	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121320	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	85.0	
121321	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	85.0	
121322	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	95.0	
121323	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
121324	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121325	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121326	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121327	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121328	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Unknown Operations	0	
121329	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
121330	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	0	
121331	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	
121332	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	General Comments		
121333	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments		
121334	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
121335	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121336	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
121337	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
121338	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	230	
121339	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	230	
121340	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations This Read Vac	1	
121341	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121342	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	1	
121343	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
121344	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
121345	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
121346	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
121347	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
121348	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
121349	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
121350	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
121351	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121352	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
121353	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
121354	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
121355	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
121356	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	n	
121357	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
121358	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
121359	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
121360	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
121361	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
121362	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Needs Nitro. Top left fan on group one not working	
121363	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
121364	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
121365	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5.0	psi
121366	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
121367	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
121368	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
121369	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
121370	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
121371	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
121372	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
121373	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
121374	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
121375	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
121376	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
121377	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
121378	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
121379	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	75	°C
121380	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
121381	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
121382	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
121383	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
121384	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
121385	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
121386	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
121387	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	63	°C
121388	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	22	°C
121389	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
121390	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
121391	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
121392	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
121393	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
121394	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
121395	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
121396	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
121397	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	1.1960	
121398	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	74	°C
121399	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	22	°C
121400	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
121401	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
121402	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
121403	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
121404	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
121405	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
121406	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	17738	
121407	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	17738	
121408	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
121409	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	6L	
121410	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	4R	
121411	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	9L	
121412	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
121413	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
121414	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
121415	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	1481	
121416	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
121417	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
121418	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
121419	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
121420	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
121421	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations	1	
121422	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121423	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121424	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121425	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	0.0	
121426	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121427	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	0.0	
121428	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
121429	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121430	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121431	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121432	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121433	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121434	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121435	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121436	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121437	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121438	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
121439	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
121440	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	
121441	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
121442	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
121443	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
121444	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
121445	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
121446	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
121447	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
121448	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
121449	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
121450	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
121451	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
121452	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
121453	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
121454	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	114	
121455	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	114	
121456	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	
121457	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
121458	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Unknown Operations	0	
121459	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
121460	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
121461	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
121462	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
121463	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	53.5	amps
121464	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
121465	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
121466	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BCH001236	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
121467	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
121468	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
121469	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
121470	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
121471	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
121472	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
121473	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
121474	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
121475	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
121476	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
121477	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
121478	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
121479	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
121480	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
121481	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
121482	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	1	
121483	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
121484	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
121485	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
121486	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
121487	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
121488	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
121489	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
121490	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
121491	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
121492	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
121493	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
121494	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
121495	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
121496	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
121497	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
121498	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
121499	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
121500	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
121501	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121502	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
121503	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
121504	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
121505	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
121506	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
121507	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
121508	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
121509	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
121510	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
121511	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
121512	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
121513	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
121514	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
121515	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
121516	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Pumps are leaking oil pics sent to Stinson	
121517	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
121518	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
121519	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
121520	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
121521	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	*C
121522	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	*C
121523	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
121524	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
121525	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
121526	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
121527	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
121528	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
121529	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	General Comments		
121530	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	LTC0000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
121531	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
121532	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
121533	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
121534	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
121535	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
121536	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
121537	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
121538	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
121539	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
121540	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
121541	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
121542	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	*C
121543	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	*C
121544	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	76	*C
121545	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	*C
121546	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	*C
121547	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	*C
121548	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
121549	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
121550	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
121551	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
121552	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
121553	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
121554	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
121555	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
121556	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
121557	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
121558	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121559	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121560	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	50.0	
121561	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	20.0	
121562	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	80.0	
121563	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121564	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121565	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121566	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
121567	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
121568	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
121569	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
121570	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
121571	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
121572	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
121573	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
121574	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
121575	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
121576	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
121577	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
121578	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
121579	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
121580	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
121581	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
121582	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
121583	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121584	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
121585	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
121586	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
121587	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
121588	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
121589	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
121590	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
121591	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
121592	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121593	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
121594	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	162	
121595	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	162	
121596	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
121597	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
121598	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Unknown Operations	0	
121599	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	6	
121600	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121601	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121602	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121603	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	80.0	
121604	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	120.0	
121605	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	40.0	
121606	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121607	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
121608	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
121609	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
121610	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
121611	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
121612	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
121613	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
121614	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
121615	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
121616	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
121617	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
121618	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
121619	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
121620	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
121621	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
121622	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
121623	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
121624	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
121625	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
121626	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
121627	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
121628	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments	yard light by tr1 is not working need small bucket truck	
121629	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
121630	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
121631	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	60.0	
121632	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	40.0	
121633	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
121634	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121635	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121636	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121637	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121638	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121639	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121640	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121641	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121642	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121643	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
121644	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
121645	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
121646	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
121647	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
121648	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
121649	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
121650	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
121651	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121652	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	
121653	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121654	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
121655	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	
121656	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	257	
121657	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	257	
121658	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
121659	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
121660	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
121661	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
121662	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
121663	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
121664	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
121665	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
121666	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations This Read Vac	1	
121667	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121668	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	1	
121669	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
121670	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
121671	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121672	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
121673	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	0	
121674	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
121675	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
121676	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
121677	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
121678	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
121679	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments	Actual Counter. IOC A phase	
121680	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121681	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
121682	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	197	
121683	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	197	
121684	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	0	
121685	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
121686	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Unknown Operations	0	
121687	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
121688	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
121689	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
121690	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
121691	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
121692	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
121693	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
121694	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
121695	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
121696	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
121697	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
121698	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
121699	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
121700	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
121701	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
121702	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
121703	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
121704	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
121705	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
121706	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
121707	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
121708	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
121709	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
121710	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
121711	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Heater fan not working on main heater in Switch gear	
121712	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
121713	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
121714	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
121715	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
121716	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
121717	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
121718	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
121719	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
121720	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
121721	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
121722	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
121723	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
121724	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	28704.00	kw
121725	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
121726	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121727	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
121728	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
121729	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
121730	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
121731	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
121732	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
121733	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
121734	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	152	
121735	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
121736	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121737	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121738	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121739	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
121740	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
121741	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
121742	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
121743	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121744	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121745	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121746	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121747	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121748	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121749	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121750	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121751	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121752	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
121753	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
121754	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
121755	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
121756	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
121757	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
121758	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
121759	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
121760	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
121761	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
121762	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
121763	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
121764	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	493	
121765	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	493	
121766	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
121767	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121768	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
121769	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
121770	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CB0216	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
121771	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	152	
121772	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	1	
121773	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
121774	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Unknown Operations	1	
121775	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	20	
121776	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121777	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121778	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121779	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	100.0	
121780	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	80.0	
121781	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	100.0	
121782	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121783	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121784	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121785	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121786	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
121787	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
121788	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
121789	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
121790	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121791	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121792	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121793	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121794	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121795	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121796	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	101.34	
121797	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	101.34	
121798	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	101.34	
121799	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
121800	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
121801	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
121802	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
121803	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
121804	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
121805	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
121806	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
121807	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
121808	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
121809	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	14	
121810	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
121811	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	821	
121812	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	821	
121813	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	38	
121814	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121815	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
121816	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
121817	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	20	
121818	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X3 Winding Temp Max	67	*C
121819	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X2 Winding Temp Max	67	*C
121820	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	X1 Winding Temp Max	67	*C
121821	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
121822	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
121823	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	67	*C
121824	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.6610	
121825	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
121826	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
121827	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
121828	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
121829	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
121830	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
121831	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
121832	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
121833	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	47	*C
121834	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
121835	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
121836	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
121837	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	15864.00	kw
121838	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
121839	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
121840	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
121841	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
121842	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
121843	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
121844	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
121845	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
121846	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
121847	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
121848	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
121849	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
121850	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
121851	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
121852	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
121853	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
121854	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
121855	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	790	
121856	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
121857	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
121858	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
121859	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
121860	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
121861	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
121862	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
121863	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
121864	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
121865	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99998	
121866	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99998	
121867	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
121868	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
121869	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
121870	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
121871	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
121872	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
121873	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
121874	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
121875	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
121876	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
121877	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
121878	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
121879	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
121880	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
121881	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
121882	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121883	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121884	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121885	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121886	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121887	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121888	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
121889	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
121890	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	129.0	
121891	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	129.0	
121892	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121893	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121894	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121895	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0139	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
121896	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
121897	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
121898	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
121899	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
121900	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	75726	
121901	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	75726	
121902	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
121903	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
121904	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
121905	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
121906	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
121907	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1917	
121908	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
121909	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
121910	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
121911	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
121912	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
121913	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
121914	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
121915	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
121916	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
121917	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
121918	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
121919	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
121920	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		
121921	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
121922	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	38	
121923	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121924	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	MB0140	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121925	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
121926	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
121927	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
121928	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
121929	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
121930	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
121931	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
121932	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
121933	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
121934	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
121935	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
121936	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
121937	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
121938	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
121939	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
121940	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	0	
121941	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	0	
121942	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	189	
121943	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	189	
121944	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
121945	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
121946	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
121947	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
121948	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
121949	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
121950	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
121951	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
121952	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
121953	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
121954	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
121955	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
121956	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
121957	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
121958	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
121959	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
121960	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
121961	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
121962	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
121963	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
121964	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
121965	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
121966	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
121967	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
121968	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
121969	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
121970	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
121971	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
121972	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
121973	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	83.0	
121974	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	133.0	
121975	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	91.0	
121976	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
121977	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
121978	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
121979	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	0	
121980	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
121981	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
121982	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
121983	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
121984	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
121985	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
121986	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
121987	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
121988	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
121989	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
121990	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
121991	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
121992	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
121993	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
121994	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
121995	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
121996	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
121997	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
121998	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
121999	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
122000	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
122001	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
122002	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
122003	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
122004	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
122005	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
122006	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
122007	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
122008	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
122009	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
122010	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
122011	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
122012	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
122013	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
122014	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
122015	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
122016	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
122017	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
122018	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
122019	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
122020	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
122021	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
122022	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
122023	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
122024	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
122025	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
122026	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122027	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
122028	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
122029	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
122030	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
122031	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
122032	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
122033	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
122034	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
122035	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
122036	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
122037	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
122038	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
122039	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
122040	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
122041	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
122042	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
122043	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
122044	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
122045	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
122046	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
122047	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
122048	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
122049	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
122050	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
122051	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
122052	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
122053	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
122054	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
122055	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
122056	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
122057	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
122058	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
122059	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
122060	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
122061	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
122062	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
122063	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
122064	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
122065	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	19	
122066	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	19	
122067	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
122068	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
122069	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	600.0	
122070	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122071	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122072	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122073	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	1	
122074	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
122075	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
122076	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
122077	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
122078	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
122079	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
122080	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
122081	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
122082	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
122083	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
122084	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
122085	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
122086	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
122087	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	528	
122088	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	528	
122089	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
122090	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
122091	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
122092	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
122093	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
122094	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
122095	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
122096	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
122097	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
122098	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
122099	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
122100	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
122101	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122102	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
122103	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122104	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
122105	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	4	
122106	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
122107	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
122108	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
122109	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	50.0	
122110	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	50.0	
122111	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	50.0	
122112	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
122113	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
122114	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
122115	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
122116	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122117	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
122118	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122119	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
122120	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
122121	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
122122	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
122123	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	0	
122124	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
122125	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
122126	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
122127	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
122128	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
122129	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
122130	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
122131	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
122132	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
122133	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
122134	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
122135	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
122136	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Unknown Operations	0	
122137	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
122138	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
122139	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
122140	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
122141	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
122142	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
122143	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
122144	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
122145	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
122146	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122147	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
122148	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
122149	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122150	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
122151	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
122152	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
122153	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
122154	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	General Comments		
122155	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
122156	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	1756.80	kw
122157	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
122158	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
122159	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	50	°C
122160	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
122161	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
122162	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122163	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
122164	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
122165	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
122166	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122167	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
122168	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.1220	
122169	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	50	°C
122170	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
122171	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	80361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
122172	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
122173	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
122174	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	0	
122175	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
122176	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
122177	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	532	
122178	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	532	
122179	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
122180	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
122181	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
122182	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
122183	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
122184	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
122185	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
122186	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
122187	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
122188	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
122189	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
122190	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
122191	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
122192	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122193	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
122194	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
122195	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122196	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
122197	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122198	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
122199	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
122200	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
122201	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
122202	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	600.0	
122203	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	600.0	
122204	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	S1-12KV TR 2	AMCB Readings	Operations This Read AM	0	
122205	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
122206	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	3883.68	kw
122207	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
122208	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
122209	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
122210	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
122211	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
122212	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
122213	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
122214	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
122215	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122216	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
122217	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
122218	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122219	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
122220	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
122221	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
122222	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
122223	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
122224	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
122225	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
122226	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
122227	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
122228	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
122229	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
122230	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
122231	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
122232	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
122233	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
122234	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
122235	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
122236	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
122237	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
122238	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
122239	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
122240	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
122241	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
122242	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
122243	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
122244	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
122245	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
122246	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
122247	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
122248	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
122249	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
122250	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
122251	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	LTC0000352	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122252	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
122253	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
122254	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
122255	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
122256	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	137353	
122257	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
122258	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
122259	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
122260	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
122261	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
122262	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
122263	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
122264	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
122265	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	
122266	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122267	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
122268	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
122269	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	45714	
122270	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	45714	
122271	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122272	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	8L	
122273	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	3R	
122274	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	10L	
122275	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	173	
122276	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
122277	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
122278	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
122279	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
122280	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	154948	
122281	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
122282	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
122283	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
122284	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
122285	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
122286	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
122287	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
122288	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
122289	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
122290	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
122291	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
122292	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
122293	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
122294	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
122295	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
122296	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
122297	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
122298	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
122299	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
122300	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	173	
122301	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	2	
122302	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
122303	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Unknown Operations	2	
122304	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
122305	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
122306	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
122307	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
122308	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
122309	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
122310	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	326.0	
122311	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	338.0	
122312	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	322.0	
122313	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
122314	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
122315	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
122316	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	1	
122317	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	VRR Time Delay	30	Seconds
122318	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
122319	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
122320	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
122321	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	LTC Operation Checked?	y	
122322	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	General Comments		
122323	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	Follow-up Action Required?	n	
122324	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	LTC000856	LTCControl	823-1	LTC Control Insp	All Connections OK?	y	
122325	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5394	
122326	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122327	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
122328	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
122329	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
122330	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
122331	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122332	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122333	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122334	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
122335	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
122336	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122337	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
122338	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
122339	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
122340	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122341	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
122342	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
122343	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	38	°C
122344	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
122345	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
122346	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	1076	
122347	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
122348	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	8L	
122349	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	2R	
122350	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	6L	
122351	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122352	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	51002	
122353	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	51002	
122354	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
122355	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
122356	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
122357	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
122358	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122359	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
122360	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
122361	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
122362	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
122363	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
122364	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
122365	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
122366	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
122367	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
122368	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
122369	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
122370	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
122371	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
122372	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
122373	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
122374	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
122375	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
122376	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
122377	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122378	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
122379	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	4R	
122380	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	6L	
122381	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122382	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
122383	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	17954	
122384	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	17954	
122385	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
122386	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
122387	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122388	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
122389	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
122390	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
122391	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
122392	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252193	
122393	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122394	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252193	
122395	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
122396	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
122397	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122398	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
122399	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
122400	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122401	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122402	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
122403	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	367124	
122404	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	367135	
122405	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
122406	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	1245	
122407	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	36	°C
122408	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
122409	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
122410	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122411	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	3L	
122412	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
122413	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	10L	
122414	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
122415	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	10R	
122416	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
122417	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
122418	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122419	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
122420	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
122421	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	36557	
122422	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	36557	
122423	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
122424	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	7L	
122425	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	1L	
122426	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	8L	
122427	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	545	
122428	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122429	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
122430	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
122431	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
122432	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	3	
122433	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
122434	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122435	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
122436	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
122437	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
122438	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122439	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
122440	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
122441	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
122442	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
122443	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
122444	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
122445	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
122446	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
122447	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
122448	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
122449	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
122450	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
122451	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
122452	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
122453	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
122454	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122455	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
122456	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
122457	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	30	°C
122458	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
122459	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	11592.00	kw
122460	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	55	°C
122461	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.4830	
122462	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
122463	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Present	30	°C
122464	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Top Oil Temperature Max	30	°C
122465	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122466	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
122467	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
122468	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
122469	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
122470	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
122471	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122472	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
122473	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
122474	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
122475	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
122476	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122477	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
122478	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
122479	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
122480	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
122481	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
122482	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
122483	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
122484	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122485	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
122486	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
122487	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
122488	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
122489	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
122490	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
122491	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
122492	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
122493	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments		
122494	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
122495	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
122496	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
122497	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
122498	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
122499	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	3L	
122500	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	8L	
122501	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	899	
122502	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
122503	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
122504	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
122505	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
122506	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
122507	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
122508	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
122509	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
122510	10/21/2019 9:04	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
122511	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122512	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
122513	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
122514	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
122515	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
122516	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
122517	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
122518	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
122519	10/22/2019 11:44	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
122520	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
122521	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
122522	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
122523	10/21/2019 15:43	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
122524	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
122525	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
122526	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
122527	10/21/2019 15:05	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
122528	10/21/2019 15:54	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
122529	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
122530	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
122531	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
122532	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations This Read Vac	4	
122533	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	377	
122534	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	377	
122535	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
122536	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments	A,B PHASE IOC	
122537	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122538	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
122539	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
122540	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	8	
122541	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	8	
122542	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	8	
122543	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	89.44	
122544	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	89.44	
122545	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	4	
122546	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	99994	
122547	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	99990	
122548	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
122549	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
122550	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	89.44	
122551	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122552	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments	1 blown arrestor	
122553	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments		
122554	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122555	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	130.0	
122556	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	110.0	
122557	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	115.0	
122558	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122559	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
122560	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
122561	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
122562	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
122563	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
122564	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good		
122565	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00		
122566	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0		psi
122567	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
122568	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
122569	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
122570	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
122571	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
122572	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	10	
122573	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122574	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122575	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122576	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	20.0	
122577	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good		
122578	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
122579	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good		
122580	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
122581	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
122582	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good		
122583	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good		
122584	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
122585	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
122586	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	24	
122587	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	799	
122588	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	20.0	
122589	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	20.0	
122590	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
122591	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
122592	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
122593	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
122594	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
122595	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
122596	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
122597	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122598	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
122599	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122600	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	799	
122601	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
122602	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
122603	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
122604	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
122605	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	2	
122606	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	2	
122607	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
122608	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
122609	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
122610	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	56	
122611	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	56	
122612	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	4	
122613	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	0	
122614	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
122615	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
122616	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
122617	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122618	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
122619	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
122620	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	
122621	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
122622	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
122623	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
122624	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
122625	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
122626	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122627	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
122628	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
122629	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
122630	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
122631	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	12.0	
122632	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	12.0	
122633	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	12.0	
122634	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122635	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122636	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
122637	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
122638	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122639	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
122640	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
122641	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122642	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
122643	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
122644	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
122645	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
122646	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
122647	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
122648	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122649	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122650	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
122651	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
122652	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122653	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	17	
122654	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
122655	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	free breather	
122656	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
122657	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
122658	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122659	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Equipment Properly Labeled?	y	
122660	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Follow-up Action Required?	n	
122661	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Foundation Condition	Good	
122662	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	General Comments	OUT OF SERVICE (JUNK)	
122663	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Grounds in Place?	y	
122664	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 1 Oil Level	Good	
122665	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 2 Oil level	Good	
122666	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 3 Oil Level	Good	
122667	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank Leaks	None	
122668	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122669	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122670	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
122671	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
122672	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
122673	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
122674	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank Leaks	None	
122675	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 3 Oil Level	Good	
122676	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 2 Oil level	Good	
122677	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 1 Oil Level	Good	
122678	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Grounds in Place?	y	
122679	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	General Comments	OUT OF SERVICE (JUNK)	
122680	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Foundation Condition	Good	
122681	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Follow-up Action Required?	n	
122682	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Equipment Properly Labeled?	y	
122683	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
122684	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122685	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
122686	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122687	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
122688	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
122689	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122690	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122691	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
122692	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	4	
122693	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
122694	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
122695	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122696	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122697	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	24	
122698	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	0	
122699	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
122700	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	5	
122701	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
122702	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	5	
122703	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1282	
122704	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1277	
122705	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
122706	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
122707	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
122708	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
122709	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
122710	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments	2 blown arrestors	
122711	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments		
122712	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
122713	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
122714	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
122715	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
122716	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
122717	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
122718	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
122719	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
122720	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
122721	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
122722	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
122723	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments	RACKED OUT.....DANGER CARD	
122724	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
122725	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
122726	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122727	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
122728	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
122729	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
122730	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
122731	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
122732	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
122733	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
122734	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
122735	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
122736	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
122737	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
122738	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
122739	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
122740	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
122741	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
122742	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
122743	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
122744	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
122745	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
122746	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
122747	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122748	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
122749	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
122750	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122751	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
122752	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
122753	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122754	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
122755	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122756	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
122757	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
122758	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
122759	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
122760	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
122761	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
122762	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
122763	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	n	
122764	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
122765	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
122766	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments	yellow rope needs replaced	
122767	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
122768	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
122769	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
122770	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
122771	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
122772	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
122773	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
122774	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
122775	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
122776	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	50	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
122777	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
122778	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments	NEEDS YELLOW ROPE REPLACED	
122779	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
122780	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
122781	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
122782	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
122783	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
122784	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
122785	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
122786	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
122787	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
122788	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
122789	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
122790	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
122791	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	10	
122792	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122793	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122794	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
122795	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	80.0	
122796	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	80.0	
122797	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
122798	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
122799	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
122800	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
122801	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
122802	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
122803	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
122804	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
122805	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
122806	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
122807	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
122808	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
122809	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
122810	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00		
122811	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
122812	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
122813	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
122814	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
122815	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
122816	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
122817	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
122818	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
122819	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
122820	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
122821	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
122822	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
122823	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
122824	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
122825	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments	A,B PHASE IOC	
122826	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
122827	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
122828	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
122829	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
122830	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
122831	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	2	
122832	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	2	
122833	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
122834	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
122835	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
122836	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
122837	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	80.0	
122838	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
122839	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
122840	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
122841	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
122842	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
122843	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	*F
122844	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
122845	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
122846	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
122847	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
122848	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
122849	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
122850	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		If no, which cells in comments
122851	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122852	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
122853	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
122854	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
122855	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
122856	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
122857	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
122858	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
122859	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
122860	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
122861	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
122862	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
122863	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
122864	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
122865	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
122866	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
122867	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
122868	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
122869	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
122870	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
122871	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
122872	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
122873	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank Leaks	None	
122874	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
122875	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
122876	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
122877	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
122878	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
122879	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
122880	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
122881	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
122882	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
122883	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
122884	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122885	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
122886	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
122887	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Equipment Properly Labeled?	y	
122888	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Follow-up Action Required?	n	
122889	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Foundation Condition	Good	
122890	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	General Comments	OUT OF SERVICE (JUNK)	
122891	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Grounds in Place?	y	
122892	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 1 Oil Level	Good	
122893	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
122894	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
122895	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
122896	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
122897	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
122898	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
122899	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 2 Oil level	Good	
122900	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 3 Oil Level	Good	
122901	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
122902	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	4	
122903	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
122904	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
122905	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
122906	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122907	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
122908	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
122909	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
122910	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
122911	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
122912	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
122913	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
122914	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
122915	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
122916	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
122917	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
122918	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
122919	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
122920	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
122921	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
122922	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
122923	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
122924	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
122925	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	*C
122926	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
122927	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
122928	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
122929	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
122930	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
122931	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
122932	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
122933	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
122934	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
122935	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00		
122936	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
122937	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
122938	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
122939	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good		
122940	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
122941	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
122942	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
122943	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
122944	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
122945	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
122946	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
122947	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
122948	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
122949	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
122950	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
122951	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
122952	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean		
122953	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
122954	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good		
122955	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good		
122956	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
122957	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
122958	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
122959	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
122960	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
122961	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
122962	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments	Heater not working. Work order made to replace the heater.	
122963	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
122964	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
122965	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
122966	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
122967	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
122968	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
122969	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
122970	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
122971	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	
122972	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
122973	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
122974	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
122975	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
122976	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
122977	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
122978	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
122979	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
122980	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
122981	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
122982	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
122983	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.4	VDC
122984	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.4	VDC
122985	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	8.600	millivolts
122986	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
122987	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
122988	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
122989	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
122990	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
122991	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
122992	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
122993	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
122994	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
122995	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
122996	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
122997	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
122998	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
122999	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
123000	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
123001	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123002	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
123003	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
123004	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
123005	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
123006	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
123007	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
123008	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
123009	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
123010	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
123011	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
123012	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
123013	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
123014	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
123015	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
123016	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
123017	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123018	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123019	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123020	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123021	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123022	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123023	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
123024	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123025	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123026	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123027	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123028	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
123029	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123030	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123031	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123032	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123033	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123034	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123035	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123036	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
123037	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123038	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123039	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123040	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
123041	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
123042	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
123043	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
123044	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123045	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
123046	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123047	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123048	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
123049	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
123050	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
123051	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
123052	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arresters blown on cir,414.and one arrester blown on cir.415	
123053	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
123054	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123055	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123056	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
123057	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
123058	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
123059	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
123060	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
123061	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
123062	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
123063	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
123064	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
123065	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123066	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123067	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123068	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123069	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123070	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123071	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123072	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
123073	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
123074	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123075	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	100.0	
123076	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	100.0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123077	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	100.0	
123078	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123079	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123080	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000063		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123081	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
123082	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123083	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123084	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123085	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
123086	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123087	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
123088	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
123089	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
123090	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
123091	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
123092	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123093	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123094	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0013		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123095	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123096	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Equipment Properly Labeled?	y	
123097	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Follow-up Action Required?	n	
123098	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Foundation Condition	Good	
123099	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	General Comments	OUT OF SERVICE (JUNK)	
123100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Grounds in Place?	y	
123101	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 1 Oil Level	Good	
123102	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 2 Oil level	Good	
123103	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
123104	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
123105	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
123106	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	15	
123107	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
123108	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
123109	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
123110	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
123111	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
123112	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
123113	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
123114	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
123115	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
123116	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
123117	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
123118	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
123119	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
123120	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
123121	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
123122	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	8.0	
123123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 3 Oil Level	Good	
123124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank Leaks	None	
123125	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123126	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
123127	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
123128	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
123129	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
123130	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
123131	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123132	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123133	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
123134	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
123135	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
123136	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
123137	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
123138	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
123139	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
123140	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
123141	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments	Fence on back right corner has big gap but has barbed wire running between fence bottom and the ground.	
123142	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
123143	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	12	
123144	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
123145	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123146	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123147	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123148	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
123149	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123150	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123151	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123152	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123153	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
123154	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
123155	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123156	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123157	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123158	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
123159	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
123160	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
123161	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
123162	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
123163	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
123164	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
123165	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
123166	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123167	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	General Comments		
123168	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
123169	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
123170	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	3398.40	kw
123171	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123172	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
123173	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	55	°C
123174	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	31	°C
123175	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123176	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
123177	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123178	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
123179	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
123180	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
123181	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123182	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
123183	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	.7080	
123184	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
123185	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
123186	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
123187	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
123188	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
123189	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	18054	
123190	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	18054	
123191	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
123192	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
123193	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
123194	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
123195	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
123196	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1390	
123197	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
123198	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
123199	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
123200	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123201	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123202	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123203	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
123204	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
123205	10/18/2019 13:16	Distribution	Kentonia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTG Bushing Dynamic Health	0.00	
123206	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
123207	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
123208	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123209	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
123210	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123211	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123212	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0931		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123213	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123214	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123215	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123216	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123217	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
123218	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123219	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123220	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0930		NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123221	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
123222	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
123223	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
123224	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0426		LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
123225	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123226	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123227	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
123228	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123229	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123230	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123231	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
123232	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123233	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123234	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123235	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
123236	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank Leaks	None	
123237	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 3 Oil Level	Good	
123238	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 2 Oil Level	Good	
123239	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 1 Oil Level	Good	
123240	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
123241	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
123242	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123243	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123244	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123245	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123246	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123247	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123248	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123249	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123250	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123251	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123252	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
123253	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123254	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123255	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123256	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123257	10/18/2019 9:26	Distribution	Pineville Substation Department Transform	O947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123258	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
123259	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
123260	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	1	
123261	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	641	
123262	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	641	
123263	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
123264	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments	C PHASE IOC	
123265	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
123266	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
123267	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
123268	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
123269	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	1	
123270	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
123271	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	0	
123272	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
123273	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123274	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123275	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Grounds in Place?	y	
123276	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
123277	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
123278	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
123279	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
123280	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
123281	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
123282	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
123283	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
123284	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
123285	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
123286	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
123287	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
123288	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
123289	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
123290	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
123291	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
123292	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
123293	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
123294	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
123295	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
123296	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	General Comments	OUT OF SERVICE	
123297	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Foundation Condition	Good	
123298	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Follow-up Action Required?	n	
123299	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Equipment Properly Labeled?	y	
123300	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123301	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123302	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
123303	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
123304	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments		
123305	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
123306	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
123307	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
123308	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
123309	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
123310	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
123311	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
123312	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
123313	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
123314	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
123315	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
123316	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
123317	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123318	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00		
123319	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
123320	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
123321	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
123322	10/18/2019 9:26	Distribution	Pineville Substation Department Transform C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123323	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
123324	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
123325	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123326	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
123327	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
123328	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
123329	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00		
123330	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
123331	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
123332	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
123333	10/18/2019 9:26	Distribution	Pineville Substation Department Transform W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123334	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good		
123335	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123336	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	100.0	
123337	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	100.0	
123338	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	100.0	
123339	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123340	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good		check oil cup
123341	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments			
123342	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
123343	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
123344	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
123345	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
123346	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123347	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
123348	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
123349	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
123350	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
123351	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
123352	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
123353	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
123354	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
123355	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
123356	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
123357	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
123358	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
123359	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
123360	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good		
123361	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good		
123362	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
123363	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n		
123364	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
123365	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments			
123366	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
123367	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
123368	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
123369	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
123370	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
123371	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
123372	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
123373	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
123374	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
123375	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
123376	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123377	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
123378	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
123379	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
123380	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
123381	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
123382	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
123383	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
123384	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
123385	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
123386	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123387	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123388	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123389	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123390	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123391	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123392	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123393	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
123394	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123395	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	31	°C
123396	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	53	°C
123397	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
123398	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123399	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	2681.28	kw
123400	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
123401	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
123402	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		
123403	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123404	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
123405	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
123406	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
123407	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123408	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123409	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123410	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
123411	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123412	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123413	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123414	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
123415	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
123416	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123417	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123418	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123419	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123420	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123421	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123422	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	General Comments		
123423	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123424	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123425	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
123426	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
123427	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	General Comments		
123428	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
123429	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	LTC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
123430	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
123431	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
123432	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123433	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123434	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123435	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank Leaks	None	
123436	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
123437	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
123438	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
123439	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Grounds in Place?	y	
123440	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
123441	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123442	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123443	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123444	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
123445	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
123446	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123447	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
123448	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
123449	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
123450	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	9	
123451	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123452	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
123453	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	General Comments	OUT OF SERVICE	
123454	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Foundation Condition	Good	
123455	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Follow-up Action Required?	n	
123456	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
123457	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123458	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
123459	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	14L	
123460	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	6L	
123461	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	11L	
123462	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
123463	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	276087	
123464	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123465	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123466	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123467	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	276074	
123468	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
123469	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
123470	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
123471	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
123472	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123473	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
123474	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
123475	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
123476	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
123477	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
123478	10/18/2019 9:26	Distribution	Pineville Substation Department Transform 0980	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
123479	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
123480	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
123481	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
123482	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	847	
123483	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	14L	
123484	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	5L	
123485	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	10L	
123486	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
123487	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	23150	
123488	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	23143	
123489	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
123490	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
123491	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
123492	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
123493	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123494	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123495	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123496	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123497	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
123498	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
123499	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123500	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123501	10/18/2019 9:26	Distribution	Pineville Substation Department Transform M0038	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123502	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123503	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123504	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123505	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
123506	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123507	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123508	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123509	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123510	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123511	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
123512	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123513	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
123514	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
123515	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123516	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123517	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
123518	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000212	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123519	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
123520	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
123521	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.5586	
123522	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
123523	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123524	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
123525	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
123526	10/18/2019 12:08	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123527	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123528	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123529	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123530	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
123531	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123532	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
123533	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
123534	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
123535	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None		
123536	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
123537	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
123538	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
123539	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None		
123540	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
123541	10/18/2019 9:26	Distribution	Pineville Substation Department Transform B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123542	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123543	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
123544	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Equipment Properly Labeled?	y	
123545	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Follow-up Action Required?	n	
123546	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Foundation Condition	Good	
123547	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
123548	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
123549	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	General Comments	OUT OF SERVICE (JUNK)	
123550	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Grounds in Place?	y	
123551	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 1 Oil Level	Good	
123552	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 2 Oil level	Good	
123553	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 3 Oil Level	Good	
123554	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank Leaks	None	
123555	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
123556	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
123557	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
123558	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	922	
123559	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	380.0	
123560	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	380.0	
123561	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	380.0	
123562	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123563	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
123564	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
123565	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	0	
123566	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good		
123567	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
123568	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
123569	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
123570	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
123571	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
123572	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
123573	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
123574	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
123575	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
123576	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
123577	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
123578	10/18/2019 13:16	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
123579	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
123580	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
123581	10/18/2019 9:26	Distribution	Pineville Substation Department Transform LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
123582	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
123583	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
123584	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	205	
123585	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	205	
123586	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
123587	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None		
123588	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
123589	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None		
123590	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2050	psi	
123591	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi	
123592	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
123593	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
123594	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
123595	10/18/2019 12:24	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
123596	10/18/2019 9:26	Distribution	Pineville Substation Department Transform O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
123597	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments			
123598	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
123599	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good		
123600	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y		
123601	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123602	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y		
123603	10/18/2019 9:26	Distribution	Pineville Substation Department Transform TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good		
123604	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
123605	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
123606	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
123607	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	30	
123608	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124.0	
123609	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124.0	
123610	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	124.0	
123611	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
123612	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
123613	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
123614	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
123615	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
123616	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	OFFLINE	
123617	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
123618	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	139	
123619	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
123620	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
123621	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
123622	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123623	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
123624	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
123625	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
123626	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	139	
123627	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
123628	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
123629	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
123630	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
123631	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123632	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123633	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
123634	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
123635	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
123636	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
123637	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
123638	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
123639	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
123640	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
123641	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
123642	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
123643	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
123644	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123645	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
123646	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123647	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123648	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
123649	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123650	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123651	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123652	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
123653	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
123654	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
123655	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
123656	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
123657	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
123658	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
123659	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
123660	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
123661	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
123662	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	488	
123663	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	488	
123664	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
123665	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	OFFLINE	
123666	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
123667	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
123668	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
123669	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
123670	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
123671	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123672	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
123673	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
123674	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
123675	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
123676	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123677	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123678	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
123679	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123680	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
123681	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
123682	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
123683	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
123684	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
123685	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
123686	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123687	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
123688	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
123689	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
123690	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123691	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123692	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123693	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
123694	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
123695	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
123696	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
123697	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
123698	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	OFFLINE	
123699	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
123700	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	248	
123701	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	248	
123702	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
123703	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
123704	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
123705	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
123706	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
123707	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
123708	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
123709	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
123710	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
123711	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123712	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123713	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
123714	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123715	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
123716	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
123717	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
123718	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
123719	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
123720	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
123721	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
123722	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
123723	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
123724	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
123725	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
123726	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
123727	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
123728	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
123729	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
123730	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
123731	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
123732	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
123733	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
123734	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
123735	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
123736	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
123737	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
123738	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
123739	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
123740	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
123741	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Moisture and Leak Free?	y	
123742	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
123743	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
123744	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
123745	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
123746	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
123747	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
123748	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
123749	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
123750	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	UG Pothead Condition Good?	y	
123751	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
123752	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
123753	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
123754	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
123755	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
123756	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
123757	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
123758	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
123759	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
123760	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
123761	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123762	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
123763	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
123764	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	
123765	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
123766	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123767	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
123768	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
123769	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
123770	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
123771	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
123772	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123773	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
123774	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
123775	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
123776	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
123777	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
123778	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
123779	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123780	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123781	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
123782	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
123783	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
123784	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
123785	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
123786	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
123787	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
123788	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
123789	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
123790	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123791	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
123792	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
123793	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123794	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
123795	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
123796	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
123797	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
123798	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
123799	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
123800	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
123801	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
123802	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6220.80	kw
123803	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123804	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123805	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
123806	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123807	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123808	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
123809	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
123810	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
123811	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
123812	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
123813	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123814	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
123815	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
123816	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
123817	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
123818	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
123819	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
123820	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
123821	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6480	
123822	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
123823	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
123824	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
123825	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123826	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123827	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
123828	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
123829	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
123830	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123831	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
123832	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
123833	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	237	
123834	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	237	
123835	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
123836	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
123837	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
123838	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
123839	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
123840	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
123841	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
123842	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	General Comments		
123843	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
123844	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
123845	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
123846	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
123847	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
123848	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123849	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
123850	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
123851	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
123852	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123853	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
123854	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
123855	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
123856	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0068	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
123857	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	14	
123858	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
123859	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
123860	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123861	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	200.0	
123862	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	210.0	
123863	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	230.0	
123864	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
123865	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
123866	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
123867	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123868	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123869	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
123870	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123871	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123872	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	60	°C
123873	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.6970	
123874	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
123875	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123876	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
123877	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
123878	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
123879	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123880	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
123881	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123882	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
123883	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
123884	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	30	°C
123885	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	60	°C
123886	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
123887	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123888	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	16728.00	kw
123889	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
123890	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
123891	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
123892	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
123893	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
123894	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
123895	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
123896	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
123897	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
123898	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
123899	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
123900	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	65	°C
123901	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	85	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123902	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
123903	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
123904	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
123905	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
123906	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
123907	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
123908	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
123909	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
123910	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
123911	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
123912	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
123913	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
123914	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
123915	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
123916	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
123917	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	10	°C
123918	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	50	°C
123919	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.5	psi
123920	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
123921	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
123922	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
123923	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
123924	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
123925	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
123926	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
123927	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
123928	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
123929	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
123930	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
123931	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
123932	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
123933	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	General Comments		
123934	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
123935	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
123936	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
123937	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
123938	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
123939	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
123940	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
123941	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
123942	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BCH000389	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
123943	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
123944	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
123945	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
123946	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
123947	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
123948	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
123949	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
123950	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
123951	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	837	
123952	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	837	
123953	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
123954	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
123955	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
123956	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
123957	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
123958	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
123959	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
123960	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
123961	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
123962	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
123963	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
123964	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
123965	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
123966	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
123967	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
123968	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
123969	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
123970	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
123971	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
123972	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
123973	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
123974	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
123975	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
123976	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
123977	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
123978	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
123979	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
123980	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
123981	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
123982	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
123983	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
123984	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
123985	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
123986	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
123987	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
123988	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
123989	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
123990	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
123991	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
123992	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
123993	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
123994	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
123995	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	115.0	
123996	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
123997	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
123998	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
123999	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124000	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	32	
124001	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
124002	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
124003	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
124004	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
124005	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
124006	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
124007	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
124008	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
124009	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
124010	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
124011	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
124012	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
124013	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
124014	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
124015	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
124016	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
124017	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
124018	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
124019	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
124020	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
124021	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
124022	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	144	
124023	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	144	
124024	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
124025	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
124026	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124027	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
124028	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
124029	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
124030	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
124031	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
124032	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
124033	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
124034	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
124035	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
124036	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
124037	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124038	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124039	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124040	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124041	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124042	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124043	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124044	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124045	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124046	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
124047	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
124048	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
124049	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
124050	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
124051	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124052	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
124053	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124054	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124055	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124056	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80299	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	20	
124057	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
124058	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
124059	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	3	
124060	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
124061	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Operations This Read Vac	3	
124062	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	767	
124063	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	767	
124064	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
124065	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
124066	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124067	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B80398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
124068	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
124069	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
124070	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
124071	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
124072	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments	OFFLINE	
124073	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
124074	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
124075	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
124076	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
124077	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
124078	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
124079	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
124080	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
124081	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
124082	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
124083	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	General Comments		
124084	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
124085	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
124086	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
124087	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
124088	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
124089	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
124090	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
124091	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
124092	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
124093	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTG Bushing Dynamic Health	0.00	
124094	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
124095	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	50	°C
124096	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	75	°C
124097	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Reading	1.1270	
124098	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
124099	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
124100	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
124101	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
124102	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
124103	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
124104	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
124105	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
124106	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
124107	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
124108	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	55	°C
124109	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	75	°C
124110	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
124111	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
124112	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	LTC Totalizer Reading	27048.00	kw
124113	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
124114	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments		
124115	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
124116	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
124117	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
124118	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	n	
124119	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
124120	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
124121	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
124122	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
124123	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
124124	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000859	LTCControl	463-1	LTC Control Insp	All Connections OK?	y	
124125	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000859	LTCControl	463-1	LTC Control Insp	Follow-up Action Required?	n	
124126	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000859	LTCControl	463-1	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124127	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC000859	LTCControl	463-1	LTC Control Insp	LTC Operation Checked?	y	
124128	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC000859	LTCControl	463-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
124129	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
124130	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
124131	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC000859	LTCControl	463-1	LTC Control Insp	VRR Time Delay	30	Seconds
124132	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
124133	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
124134	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	General Comments		
124135	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	General Comments		
124136	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Foundation Condition	Good	
124137	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Follow-up Action Required?	n	
124138	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Follow-up Action Required?	n	
124139	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations Ground	0	
124140	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
124141	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations B Ø	0	
124142	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations A Ø	0	
124143	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124144	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124145	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124146	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124147	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124148	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124149	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124150	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124151	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124152	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushing Condition	Good	
124153	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps C Ø	85.0	
124154	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps B Ø	85.0	
124155	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps A Ø	80.0	
124156	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124157	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124158	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124159	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations	3	
124160	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Unknown Operations	0	
124161	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Tank Paint Condition	Good	
124162	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Switching Operations	0	
124163	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations This Read Vac	1	
124164	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AL	190	
124165	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AF	190	
124166	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Moisture and Leak Free?	y	
124167	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	0	
124168	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
124169	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
124170	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	General Comments		
124171	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Foundation Condition	Good	
124172	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
124173	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
124174	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
124175	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	1	
124176	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
124177	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
124178	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	12.90	
124179	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124180	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124181	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124182	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124183	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124184	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124185	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124186	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124187	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
124188	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	245.0	
124189	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	240.0	
124190	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	260.0	
124191	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124192	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124193	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124194	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	3	
124195	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	0	
124196	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124197	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124198	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124199	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124200	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124201	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124202	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124203	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124204	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124205	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
124206	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	65.0	
124207	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	60.0	
124208	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	60.0	
124209	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124210	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124211	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124212	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	6	
124213	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
124214	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
124215	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	0	
124216	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations This Read Vac	0	
124217	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	173	
124218	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	173	
124219	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
124220	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
124221	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
124222	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
124223	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
124224	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
124225	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
124226	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
124227	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
124228	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations C Ø	0	
124229	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations B Ø	0	
124230	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations A Ø	0	
124231	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124232	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124233	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124234	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124235	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124236	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124237	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124238	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124239	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124240	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushing Condition	Good	
124241	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps C Ø	30.0	
124242	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps B Ø	40.0	
124243	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps A Ø	30.0	
124244	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124245	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124246	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124247	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations	3	
124248	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Unknown Operations	0	
124249	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Tank Paint Condition	Good	
124250	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Switching Operations	0	
124251	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations This Read Vac	0	
124252	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AL	180	
124253	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AF	180	
124254	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Moisture and Leak Free?	y	
124255	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Maintenance Operations	0	
124256	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Grounds in Place?	y	
124257	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
124258	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
124259	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
124260	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
124261	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
124262	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
124263	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
124264	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
124265	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
124266	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
124267	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
124268	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
124269	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
124270	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
124271	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
124272	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
124273	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
124274	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
124275	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
124276	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	5451	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124277	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	5451	
124278	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
124279	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	6L	
124280	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
124281	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	9L	
124282	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
124283	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
124284	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	44	°C
124285	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	992	
124286	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
124287	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
124288	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
124289	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
124290	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6490	
124291	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
124292	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
124293	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
124294	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
124295	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
124296	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
124297	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
124298	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
124299	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
124300	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	22	°C
124301	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
124302	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
124303	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1557.60	kw
124304	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
124305	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
124306	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
124307	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
124308	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
124309	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
124310	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
124311	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
124312	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
124313	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
124314	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
124315	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
124316	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
124317	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
124318	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
124319	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	4	
124320	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124321	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124322	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124323	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	70.0	
124324	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	60.0	
124325	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	70.0	
124326	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
124327	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124328	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124329	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124330	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124331	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124332	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124333	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124334	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124335	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124336	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
124337	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
124338	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
124339	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
124340	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
124341	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
124342	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
124343	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
124344	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
124345	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
124346	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124347	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
124348	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
124349	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	244	
124350	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	244	
124351	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124352	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
124353	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	4	
124354	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
124355	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
124356	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
124357	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments		
124358	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
124359	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
124360	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
124361	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
124362	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
124363	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
124364	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
124365	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
124366	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
124367	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
124368	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
124369	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
124370	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
124371	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
124372	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
124373	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
124374	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
124375	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
124376	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
124377	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
124378	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
124379	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
124380	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
124381	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
124382	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	235.0	
124383	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	200.0	
124384	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	210.0	
124385	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
124386	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
124387	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
124388	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations	2	
124389	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Unknown Operations	0	
124390	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
124391	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	0	
124392	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations This Read Vac	0	
124393	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	153	
124394	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	153	
124395	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
124396	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	0	
124397	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
124398	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
124399	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
124400	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
124401	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
124402	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
124403	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
124404	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
124405	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
124406	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
124407	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124408	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124409	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124410	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124411	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124412	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124413	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124414	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124415	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124416	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
124417	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	335.0	
124418	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	355.0	
124419	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	350.0	
124420	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
124421	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
124422	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
124423	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	1	
124424	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
124425	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
124426	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124427	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations This Read Vac	0	
124428	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	178	
124429	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	178	
124430	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
124431	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	0	
124432	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
124433	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
124434	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
124435	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
124436	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
124437	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
124438	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
124439	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
124440	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
124441	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
124442	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124443	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124444	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0.0	
124445	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0.0	
124446	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0.0	
124447	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
124448	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124449	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124450	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124451	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124452	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124453	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	4	
124454	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
124455	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
124456	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	0	
124457	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	0	
124458	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	156	
124459	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	156	
124460	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
124461	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	0	
124462	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Grounds in Place?	y	
124463	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	General Comments		
124464	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	General Comments		
124465	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Foundation Condition	Good	
124466	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Follow-up Action Required?	n	
124467	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Follow-up Action Required?	n	
124468	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations Ground	0	
124469	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations C Ø	0	
124470	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations B Ø	0	
124471	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations A Ø	0	
124472	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124473	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124474	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124475	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124476	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124477	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124478	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124479	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124480	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	
124481	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
124482	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
124483	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
124484	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
124485	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
124486	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
124487	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
124488	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
124489	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
124490	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124491	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	0	
124492	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
124493	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	190	
124494	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	190	
124495	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations This Read Vac	0	
124496	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	0	
124497	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
124498	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
124499	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124500	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124501	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124502	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124503	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124504	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
124505	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
124506	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
124507	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
124508	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
124509	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
124510	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
124511	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
124512	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
124513	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
124514	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
124515	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
124516	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
124517	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
124518	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
124519	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
124520	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
124521	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
124522	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BCH000906	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
124523	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
124524	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
124525	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
124526	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
124527	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
124528	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
124529	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
124530	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
124531	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
124532	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124533	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124534	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124535	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124536	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124537	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124538	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124539	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124540	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124541	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
124542	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	75.0	
124543	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	65.0	
124544	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	70.0	
124545	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124546	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124547	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124548	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	4	
124549	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
124550	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
124551	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	0	
124552	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations This Read Vac	0	
124553	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	178	
124554	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	178	
124555	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Moisture and Leak Free?	y	
124556	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Maintenance Operations	0	
124557	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Grounds in Place?	y	
124558	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	General Comments		
124559	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
124560	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
124561	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
124562	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
124563	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
124564	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
124565	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	0	
124566	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124567	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124568	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124569	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124570	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124571	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124572	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124573	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124574	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124575	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
124576	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	110.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
124577	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	95.0	
124578	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	90.0	
124579	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124580	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124581	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124582	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	3	
124583	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
124584	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
124585	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
124586	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
124587	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
124588	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
124589	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
124590	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
124591	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
124592	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
124593	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
124594	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
124595	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
124596	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124597	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
124598	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
124599	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	60	*F
124600	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
124601	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
124602	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
124603	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
124604	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
124605	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
124606	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
124607	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
124608	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
124609	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
124610	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
124611	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
124612	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
124613	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124614	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
124615	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
124616	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	60	*F
124617	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
124618	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
124619	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	0	
124620	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations This Read Vac	0	
124621	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	177	
124622	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	177	
124623	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
124624	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	0	
124625	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
124626	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
124627	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
124628	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124629	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124630	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124631	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
124632	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
124633	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
124634	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
124635	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124636	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124637	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124638	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
124639	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
124640	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
124641	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
124642	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
124643	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
124644	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
124645	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
124646	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
124647	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
124648	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
124649	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
124650	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
124651	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124652	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
124653	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
124654	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
124655	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
124656	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
124657	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
124658	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
124659	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
124660	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
124661	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
124662	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
124663	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
124664	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
124665	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
124666	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
124667	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
124668	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
124669	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
124670	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
124671	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
124672	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
124673	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
124674	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
124675	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
124676	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	9 Month Operations	4	
124677	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124678	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124679	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124680	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Amps A Ø	39.0	
124681	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Amps B Ø	34.0	
124682	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	VCB Readings	Amps C Ø	37.0	
124683	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Bushing Condition	Good	
124684	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124685	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124686	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124687	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124688	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124689	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	General Comments		
124690	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Found Counter	71893	
124691	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Left Counter	71893	
124692	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
124693	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
124694	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
124695	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Min Tap Position	10L	
124696	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
124697	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Operations Since Last Insp	947	
124698	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
124699	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
124700	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
124701	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
124702	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
124703	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	General Comments	OFFLINNE	
124704	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	
124705	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
124706	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
124707	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
124708	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	LTC0000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
124709	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	
124710	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
124711	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	General Comments		
124712	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	y	
124713	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
124714	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
124715	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
124716	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	LTC0000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
124717	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	All Connections OK?	y	
124718	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	Follow-up Action Required?	n	
124719	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	General Comments		
124720	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	LTC Operation Checked?	y	
124721	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
124722	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
124723	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
124724	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Control Insp	VRR Time Delay	30	Seconds
124725	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
124726	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124727	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
124728	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
124729	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
124730	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	263	
124731	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	263	
124732	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
124733	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
124734	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124735	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
124736	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	OFFLINE	
124737	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
124738	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
124739	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
124740	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
124741	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
124742	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
124743	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
124744	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
124745	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124746	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124747	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124748	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124749	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124750	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0473	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124751	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Amps B Ø	0.0	
124752	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Amps C Ø	0.0	
124753	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Bushing Condition	Good	
124754	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Bushings Connection/Risers	Good	
124755	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124756	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124757	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124758	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Cabinet Paint Condition	Good	
124759	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Equipment Properly Labeled?	y	
124760	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124761	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124762	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124763	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Operations A Ø	0	
124764	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Operations B Ø	0	
124765	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Operations C Ø	0	
124766	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Fault Operations Ground	0	
124767	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Follow-up Action Required?	n	
124768	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Follow-up Action Required?	n	
124769	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Foundation Condition	Good	
124770	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	General Comments		
124771	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	General Comments		
124772	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Grounds in Place?	y	
124773	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Maintenance Operations	0	
124774	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Moisture and Leak Free?	y	
124775	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Operations Counter AF	170	
124776	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Operations Counter AL	170	
124777	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Operations This Read Vac	1	
124778	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Switching Operations	1	
124779	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Patrol Inspection	Tank Paint Condition	Good	
124780	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135		VCB Readings	Unknown Operations	0	
124781	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
124782	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124.0	
124783	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
124784	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
124785	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
124786	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	General Comments		
124787	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
124788	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	LTC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
124789	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
124790	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
124791	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
124792	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
124793	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
124794	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
124795	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
124796	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
124797	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
124798	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
124799	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
124800	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	25	°C
124801	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124802	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
124803	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
124804	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
124805	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
124806	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
124807	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
124808	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
124809	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
124810	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
124811	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
124812	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
124813	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Equipment Properly Labeled?	y		
124814	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps A Phase V	0.00		
124815	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
124816	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
124817	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations A Ø	0		
124818	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations B Ø	0		
124819	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations C Ø	0		
124820	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
124821	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
124822	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	1	
124823	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations This Read Vac	1	
124824	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	190	
124825	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	190	
124826	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
124827	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
124828	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
124829	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
124830	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
124831	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
124832	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
124833	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
124834	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
124835	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
124836	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
124837	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
124838	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124839	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124840	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124841	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124842	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations Ground	0		
124843	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Follow-up Action Required?	n		
124844	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Follow-up Action Required?	n		
124845	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Foundation Condition	Good		
124846	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	General Comments			
124847	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	General Comments			
124848	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Grounds in Place?	y		
124849	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Maintenance Operations	0		
124850	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Moisture and Leak Free?	y		
124851	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AF	191		
124852	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AL	191		
124853	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Operations This Read Vac	1		
124854	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Switching Operations	1		
124855	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Tank Paint Condition	Good		
124856	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124857	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124858	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124859	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124860	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124861	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
124862	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	125.0	
124863	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	125.0	
124864	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	119.0	
124865	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124866	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124867	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124868	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	12	
124869	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000533	BreakerVacuum	417-2133	VCB Readings	Unknown Operations	0		
124870	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations	2		
124871	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%	
124872	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%	
124873	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%	
124874	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector BK000534	BreakerVacuum	417-2135	VCB Readings	Amps A Ø	0.0		
124875	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
124876	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124877	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
124878	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124879	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
124880	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
124881	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	164	
124882	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	164	
124883	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations This Read Vac	1	
124884	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	1	
124885	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
124886	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
124887	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
124888	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
124889	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	1	
124890	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	5	
124891	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	145	
124892	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	145	
124893	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
124894	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
124895	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
124896	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
124897	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
124898	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
124899	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
124900	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
124901	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
124902	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	2	
124903	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	2	
124904	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	
124905	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	9.37	
124906	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	9.37	
124907	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124908	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124909	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	Follow-up Action Required?	n	
124910	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
124911	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	General Comments		
124912	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	General Comments		
124913	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC As Found Counter	8155	
124914	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC As Left Counter	8155	
124915	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
124916	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC Current Tap Position	3L	
124917	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC Max Tap Position	Neutral	
124918	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC Min Tap Position	8L	
124919	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
124920	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	LTC Operations Since Last Insp	828	
124921	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
124922	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Counter Readings	Reset Tap Drag Hands	Reset	
124923	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
124924	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
124925	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124926	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
124927	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124928	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124929	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushing Condition	Good	
124930	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps C Ø	69.0	
124931	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps B Ø	76.0	
124932	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps A Ø	75.0	
124933	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124934	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124935	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124936	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
124937	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
124938	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
124939	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
124940	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
124941	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
124942	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	16	
124943	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124944	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124945	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124946	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	130.0	
124947	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	120.0	
124948	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	142.0	
124949	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
124950	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124951	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
124952	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124953	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124954	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124955	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124956	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124957	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	
124958	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
124959	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
124960	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
124961	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
124962	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
124963	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
124964	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
124965	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
124966	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
124967	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
124968	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
124969	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
124970	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	167	
124971	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	167	
124972	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations This Read Vac	1	
124973	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	1	
124974	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
124975	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
124976	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations	4	
124977	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
124978	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
124979	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
124980	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps A Ø	69.0	
124981	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	70.0	
124982	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	90.0	
124983	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
124984	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
124985	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
124986	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
124987	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
124988	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
124989	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
124990	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
124991	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A Ø	0	
124992	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B Ø	0	
124993	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C Ø	0	
124994	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
124995	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
124996	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	
124997	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
124998	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
124999	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
125000	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
125001	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
125002	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
125003	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Bushing Condition	Good	
125004	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
125005	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
125006	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
125007	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
125008	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
125009	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
125010	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
125011	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
125012	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Fans Condition	Good	
125013	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
125014	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
125015	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
125016	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
125017	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
125018	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
125019	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
125020	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	If no, which cells in comments
125021	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
125022	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Fans Operational?	y	
125023	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
125024	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Readings	Follow-up Action Required?	n	
125025	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Foundation Condition	Good	
125026	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125027	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments			
125028	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	General Comments			
125029	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y		
125030	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	8760.96	kw	
125031	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
125032	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi	
125033	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	70	*C	
125034	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	30	*C	
125035	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
125036	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None		
125037	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
125038	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
125039	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
125040	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
125041	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
125042	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600		
125043	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.9126		
125044	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00		
125045	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00		
125046	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	General Comments			
125047	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n		
125048	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good		
125049	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments	
125050	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s	
125051	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments	
125052	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments	
125053	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments	
125054	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good		
125055	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	46	*F	
125056	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection BAT000543	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y		
125057	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection B0400	LTCMechanism	463-2	LTC Counter Readings	Follow-up Action Required?	n		
125058	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
125059	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection B0400	LTCMechanism	463-2	LTC Counter Readings	General Comments			
125060	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations	7		
125061	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y		
125062	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y		
125063	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	n		
125064	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y		
125065	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y		
125066	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y		
125067	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y		
125068	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y		
125069	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments			
125070	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n		
125071	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n		
125072	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y		
125073	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y		
125074	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y		
125075	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None		
125076	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y		
125077	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y		
125078	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y		
125079	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y		
125080	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed	
125081	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y		
125082	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y		
125083	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y		
125084	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0		
125085	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good		
125086	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	1		
125087	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	1		
125088	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	155		
125089	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	155		
125090	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y		
125091	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0		
125092	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y		
125093	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments			
125094	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments			
125095	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good		
125096	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n		
125097	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n		
125098	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0		
125099	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0		
125100	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0		
125101	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125102	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125103	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125104	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125105	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125106	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125107	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125108	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125109	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125110	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125111	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
125112	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	6.0	
125113	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	4.0	
125114	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	13.0	
125115	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125116	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125117	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125118	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	4	
125119	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	OFFLINE	
125120	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
125121	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	BCH000514	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
125122	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125123	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125124	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	14	
125125	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125126	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125127	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125128	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	100.0	
125129	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	120.0	
125130	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	70.0	
125131	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
125132	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125133	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125134	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125135	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125136	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125137	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125138	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125139	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125140	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125141	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
125142	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
125143	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
125144	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	
125145	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
125146	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
125147	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
125148	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
125149	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
125150	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
125151	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125152	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
125153	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
125154	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	393	
125155	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	393	
125156	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Operations This Read Vac	4	
125157	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
125158	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	4	
125159	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
125160	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector K0025	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
125161	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125162	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
125163	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
125164	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
125165	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	511	
125166	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	8L	
125167	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	5L	
125168	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	6L	
125169	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
125170	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	237432	
125171	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Found Counter	237432	
125172	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
125173	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
125174	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
125175	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	
125176	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	185.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125177	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	180.0	
125178	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
125179	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125180	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125181	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
125182	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
125183	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
125184	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
125185	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125186	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125187	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125188	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125189	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125190	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125191	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125192	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
125193	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
125194	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	
125195	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
125196	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
125197	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
125198	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
125199	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
125200	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125201	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
125202	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
125203	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
125204	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
125205	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
125206	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
125207	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
125208	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
125209	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
125210	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
125211	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
125212	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
125213	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
125214	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	15	
125215	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
125216	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
125217	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
125218	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
125219	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
125220	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125221	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
125222	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
125223	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	95287	
125224	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	95287	
125225	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
125226	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
125227	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
125228	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
125229	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
125230	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
125231	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
125232	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125233	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125234	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	185.0	
125235	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
125236	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
125237	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	0	
125238	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
125239	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
125240	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
125241	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	n	
125242	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
125243	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
125244	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
125245	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
125246	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
125247	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
125248	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
125249	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	y	
125250	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
125251	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments	Relaced 2 8ft bulbs and still didnt work. The lights are still out over the bathroom. High sewage alarm is on on the annunciator panel	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125252	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
125253	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
125254	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
125255	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
125256	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
125257	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
125258	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
125259	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
125260	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
125261	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations This Read Vac	0	
125262	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	610	
125263	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	610	
125264	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
125265	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
125266	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125267	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Grounds in Place?	y	
125268	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	General Comments		
125269	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	General Comments		
125270	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Foundation Condition	Good	
125271	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Follow-up Action Required?	n	
125272	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Follow-up Action Required?	n	
125273	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations Ground	0	
125274	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations C Ø	0	
125275	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations B Ø	0	
125276	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations A Ø	0	
125277	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125278	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125279	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125280	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125281	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125282	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125283	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125284	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125285	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125286	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125287	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
125288	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
125289	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
125290	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
125291	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
125292	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
125293	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125294	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
125295	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125296	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125297	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125298	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125299	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Unknown Operations	0	
125300	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
125301	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
125302	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
125303	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
125304	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
125305	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
125306	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
125307	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
125308	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
125309	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	64522	
125310	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	64522	
125311	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
125312	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	6L	
125313	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
125314	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
125315	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
125316	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
125317	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
125318	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
125319	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
125320	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
125321	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
125322	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
125323	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125324	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
125325	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
125326	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125327	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
125328	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125329	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125330	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
125331	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
125332	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
125333	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	36582	
125334	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125335	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
125336	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
125337	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
125338	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
125339	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
125340	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
125341	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
125342	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
125343	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
125344	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
125345	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125346	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125347	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125348	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
125349	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
125350	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
125351	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
125352	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125353	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125354	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125355	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
125356	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
125357	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
125358	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
125359	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	1553	
125360	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125361	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
125362	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	100.0	
125363	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	110.0	
125364	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	100.0	
125365	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125366	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125367	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125368	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	General Comments		
125369	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Grounds in Place?	y	
125370	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125371	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Maintenance Operations	0	
125372	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
125373	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AF	313	
125374	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AL	313	
125375	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations This Read Vac	4	
125376	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	12	
125377	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125378	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Vegetation	None	
125379	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125380	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
125381	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
125382	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
125383	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
125384	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	General Comments		
125385	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125386	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125387	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector YD000454	Yard	417-Yard	Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125388	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Switching Operations	4	
125389	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
125390	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125391	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125392	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
125393	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125394	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
125395	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
125396	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
125397	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
125398	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125399	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125400	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125401	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector ST000456	Structure	417-Structure	Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125402	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125403	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments		
125404	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
125405	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
125406	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
125407	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
125408	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
125409	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
125410	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
125411	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
125412	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
125413	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
125414	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
125415	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
125416	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125417	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
125418	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
125419	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
125420	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
125421	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125422	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125423	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
125424	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
125425	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
125426	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
125427	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
125428	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
125429	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
125430	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
125431	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
125432	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
125433	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	202009	
125434	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125435	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
125436	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
125437	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125438	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
125439	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
125440	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
125441	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125442	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125443	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125444	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
125445	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125446	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125447	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125448	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
125449	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125450	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
125451	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125452	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125453	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125454	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125455	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125456	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125457	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125458	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
125459	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125460	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
125461	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
125462	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125463	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125464	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
125465	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125466	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125467	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125468	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125469	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125470	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
125471	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
125472	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
125473	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
125474	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125475	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
125476	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125477	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
125478	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
125479	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125480	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125481	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
125482	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
125483	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
125484	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125485	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125486	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125487	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125488	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125489	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125490	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125491	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125492	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125493	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	0	
125494	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	0	
125495	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
125496	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
125497	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
125498	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
125499	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
125500	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
125501	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
125502	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
125503	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125504	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
125505	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
125506	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	642	
125507	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	642	
125508	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations This Read Vac	8	
125509	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
125510	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	8	
125511	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
125512	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	
125513	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
125514	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
125515	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125516	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125517	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
125518	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
125519	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125520	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
125521	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125522	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
125523	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	General Comments		
125524	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125525	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125526	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125527	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125528	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125529	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125530	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125531	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125532	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125533	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
125534	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
125535	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
125536	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
125537	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
125538	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
125539	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
125540	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
125541	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
125542	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
125543	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
125544	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC0000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
125545	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
125546	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
125547	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
125548	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
125549	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
125550	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
125551	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125552	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
125553	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
125554	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125555	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	181612	
125556	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
125557	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125558	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125559	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
125560	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125561	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
125562	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
125563	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
125564	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125565	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125566	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125567	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
125568	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125569	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
125570	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
125571	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
125572	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125573	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125574	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
125575	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125576	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125577	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125578	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125579	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
125580	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	23	
125581	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125582	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125583	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125584	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	120.0	
125585	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	115.0	
125586	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	120.0	
125587	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125588	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
125589	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
125590	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		
125591	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125592	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125593	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125594	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125595	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125596	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125597	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125598	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125599	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
125600	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125601	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125602	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125603	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
125604	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125605	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
125606	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
125607	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
125608	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
125609	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
125610	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
125611	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
125612	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
125613	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
125614	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
125615	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
125616	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
125617	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
125618	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
125619	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
125620	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
125621	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
125622	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125623	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125624	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
125625	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125626	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125627	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
125628	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
125629	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
125630	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
125631	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
125632	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
125633	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
125634	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125635	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125636	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125637	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
125638	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125639	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
125640	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
125641	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
125642	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125643	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125644	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
125645	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125646	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125647	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
125648	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
125649	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125650	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125651	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
125652	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
125653	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
125654	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125655	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125656	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125657	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
125658	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125659	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
125660	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
125661	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125662	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125663	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125664	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125665	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125666	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125667	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125668	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125669	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125670	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
125671	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
125672	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
125673	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
125674	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
125675	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
125676	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
125677	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
125678	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector FE000450		Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
125679	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
125680	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
125681	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
125682	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
125683	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
125684	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
125685	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
125686	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
125687	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
125688	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
125689	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125690	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125691	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125692	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125693	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125694	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125695	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
125696	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32648	
125697	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
125698	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
125699	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
125700	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
125701	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125702	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125703	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
125704	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125705	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125706	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		
125707	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125708	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
125709	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
125710	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
125711	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
125712	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
125713	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
125714	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
125715	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
125716	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
125717	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
125718	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125719	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125720	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125721	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125722	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125723	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125724	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125725	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125726	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125727	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments		
125728	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
125729	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
125730	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
125731	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
125732	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125733	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
125734	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125735	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125736	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
125737	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
125738	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
125739	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125740	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
125741	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
125742	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125743	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125744	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125745	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125746	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
125747	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	LTC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
125748	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125749	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125750	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125751	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125752	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
125753	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
125754	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
125755	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
125756	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
125757	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
125758	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
125759	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
125760	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79234	
125761	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125762	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
125763	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
125764	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
125765	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
125766	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
125767	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
125768	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
125769	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
125770	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
125771	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
125772	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
125773	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
125774	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
125775	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
125776	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125777	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125778	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
125779	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
125780	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
125781	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
125782	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
125783	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Foundation Condition	Good	
125784	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Follow-up Action Required?	n	
125785	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Follow-up Action Required?	n	
125786	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
125787	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
125788	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
125789	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
125790	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
125791	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
125792	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
125793	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
125794	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.7008	
125795	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
125796	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
125797	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
125798	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
125799	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
125800	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
125801	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
125802	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
125803	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	35	°C
125804	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
125805	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125806	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
125807	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
125808	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
125809	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
125810	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
125811	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	4	
125812	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
125813	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations This Read Vac	4	
125814	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	45	°C
125815	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
125816	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
125817	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	2242.56	kw
125818	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
125819	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	234	
125820	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	234	
125821	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
125822	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
125823	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
125824	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
125825	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125826	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125827	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
125828	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
125829	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
125830	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	191176	
125831	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125832	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
125833	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
125834	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations Ground	0	
125835	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations C Ø	8	
125836	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations B Ø	0	
125837	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations A Ø	8	
125838	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
125839	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
125840	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
125841	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
125842	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
125843	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
125844	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
125845	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
125846	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
125847	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
125848	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
125849	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	45.0	
125850	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
125851	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
125852	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
125853	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
125854	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
125855	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
125856	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
125857	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
125858	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
125859	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
125860	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
125861	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments	new control was installed. counter is in the control	
125862	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
125863	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
125864	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	2	
125865	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
125866	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
125867	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
125868	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	
125869	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	4	
125870	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations This Read Vac	20	
125871	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	251	
125872	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	251	
125873	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
125874	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125875	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125876	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125877	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations	6	
125878	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
125879	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
125880	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
125881	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
125882	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
125883	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
125884	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
125885	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
125886	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
125887	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
125888	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
125889	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
125890	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125891	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125892	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
125893	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
125894	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
125895	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
125896	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
125897	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
125898	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
125899	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	General Comments		
125900	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
125901	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
125902	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
125903	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
125904	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
125905	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	682	
125906	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	682	
125907	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
125908	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
125909	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
125910	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
125911	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
125912	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
125913	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0110	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
125914	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
125915	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125916	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125917	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
125918	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
125919	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
125920	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
125921	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
125922	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
125923	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
125924	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations E Ø	0	
125925	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
125926	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
125927	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
125928	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	
125929	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
125930	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125931	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125932	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125933	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125934	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125935	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
125936	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
125937	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
125938	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
125939	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	25571	
125940	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
125941	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
125942	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
125943	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C Ø	0	
125944	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B Ø	0	
125945	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A Ø	0	
125946	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
125947	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125948	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125949	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125950	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125951	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125952	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125953	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125954	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
125955	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
125956	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
125957	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
125958	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125959	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125960	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125961	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125962	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
125963	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	1100.0	
125964	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	1100.0	
125965	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	1000.0	
125966	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125967	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125968	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125969	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
125970	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125971	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
125972	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C Ø	110.0	
125973	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	110.0	
125974	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	100.0	
125975	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125976	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125977	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125978	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	15	
125979	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
125980	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
125981	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
125982	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
125983	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
125984	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	100.0	
125985	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
125986	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
125987	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
125988	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	110.0	
125989	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	100.0	
125990	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125991	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125992	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125993	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	11	
125994	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
125995	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
125996	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
125997	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
125998	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	28	
125999	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		
126000	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
126001	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126002	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
126003	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
126004	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
126005	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
126006	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
126007	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
126008	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
126009	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
126010	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
126011	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
126012	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
126013	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
126014	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
126015	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps C Phase V	100.39	
126016	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126017	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps A Phase V	100.39	
126018	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126019	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126020	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126021	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126022	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126023	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126024	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
126025	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C Ø	170.0	
126026	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B Ø	175.0	
126027	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A Ø	140.0	
126028	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
126029	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
126030	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	3	
126031	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations This Read Vac	3	
126032	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	211	
126033	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	211	
126034	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
126035	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
126036	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126037	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
126038	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
126039	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
126040	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
126041	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
126042	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
126043	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
126044	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
126045	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
126046	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	General Comments		
126047	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	
126048	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
126049	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
126050	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
126051	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
126052	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126053	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126054	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126055	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126056	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
126057	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
126058	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
126059	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
126060	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126061	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
126062	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	232	
126063	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126064	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
126065	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
126066	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	232	
126067	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
126068	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
126069	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126070	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
126071	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
126072	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
126073	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
126074	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126075	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
126076	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
126077	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
126078	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
126079	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
126080	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
126081	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
126082	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
126083	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
126084	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
126085	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
126086	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
126087	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
126088	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
126089	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
126090	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
126091	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
126092	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
126093	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
126094	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6935.04	kw
126095	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
126096	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
126097	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
126098	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
126099	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
126100	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
126101	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
126102	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126103	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
126104	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
126105	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
126106	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126107	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126108	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126109	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126110	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
126111	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126112	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
126113	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
126114	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
126115	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
126116	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
126117	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
126118	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7224	
126119	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
126120	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
126121	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
126122	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
126123	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	203455	
126124	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	408	
126125	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	203455	
126126	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
126127	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	10L	
126128	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	1L	
126129	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	14L	
126130	10/17/2019 16:55	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
126131	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
126132	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
126133	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
126134	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
126135	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
126136	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
126137	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
126138	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
126139	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	9L	
126140	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
126141	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
126142	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
126143	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
126144	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126145	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
126146	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126147	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
126148	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
126149	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
126150	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
126151	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126152	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
126153	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
126154	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126155	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126156	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
126157	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126158	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126159	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126160	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126161	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
126162	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
126163	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
126164	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
126165	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
126166	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63951	
126167	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126168	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
126169	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
126170	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
126171	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
126172	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126173	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126174	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
126175	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
126176	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126177	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126178	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
126179	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
126180	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
126181	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
126182	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
126183	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
126184	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126185	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126186	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
126187	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
126188	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
126189	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
126190	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	498	
126191	10/17/2019 11:15	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	498	
126192	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
126193	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
126194	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
126195	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
126196	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126197	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
126198	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
126199	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
126200	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
126201	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Operations This Read Vac	4	
126202	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126203	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126204	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
126205	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
126206	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
126207	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
126208	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
126209	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
126210	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
126211	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	4	
126212	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
126213	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
126214	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
126215	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Foundation Condition	Good	
126216	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Follow-up Action Required?	n	
126217	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Follow-up Action Required?	n	
126218	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations Ground	0	
126219	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations C Ø	0	
126220	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations B Ø	0	
126221	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations A Ø	0	
126222	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126223	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126224	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126225	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126226	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126227	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		
126228	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
126229	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
126230	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
126231	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
126232	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
126233	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
126234	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
126235	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126236	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126237	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126238	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
126239	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
126240	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
126241	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
126242	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
126243	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
126244	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
126245	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
126246	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
126247	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
126248	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
126249	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
126250	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
126251	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
126252	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
126253	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
126254	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
126255	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
126256	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
126257	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
126258	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
126259	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
126260	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
126261	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
126262	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
126263	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126264	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126265	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126266	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126267	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
126268	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
126269	10/17/2019 13:55	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
126270	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Amps A Ø	50.0	
126271	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Amps B Ø	60.0	
126272	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Amps C Ø	45.0	
126273	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushing Condition	Good	
126274	10/17/2019 10:19	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
126275	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
126276	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
126277	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
126278	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126279	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126280	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
126281	10/17/2019 8:12	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
126282	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	1641	
126283	10/17/2019 12:37	Distribution	Harrodsburg Industrial Quarterly Inspector	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	1641	
126284	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
126285	10/17/2019 13:40	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
126286	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
126287	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126288	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126289	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37553	
126290	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4 volts	
126291	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
126292	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
126293	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126294	10/17/2019 9:10	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126295	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
126296	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
126297	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	69	
126298	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
126299	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
126300	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
126301	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126302	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
126303	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
126304	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
126305	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
126306	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
126307	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
126308	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
126309	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	2	
126310	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
126311	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
126312	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
126313	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	35	
126314	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
126315	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
126316	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
126317	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Could not get amps on this trip	
126318	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
126319	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
126320	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	12	
126321	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
126322	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
126323	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
126324	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations	4	
126325	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126326	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126327	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126328	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps A Ø	15.0	
126329	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps B Ø	7.0	
126330	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps C Ø	14.0	
126331	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushing Condition	Good	
126332	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations A Ø	0	
126333	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Foundation Condition	Good	
126334	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Follow-up Action Required?	n	
126335	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Follow-up Action Required?	n	
126336	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126337	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
126338	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
126339	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
126340	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
126341	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
126342	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
126343	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
126344	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	115705	
126345	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	115705	
126346	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
126347	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
126348	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	1R	
126349	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
126350	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	523	
126351	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
126352	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
126353	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
126354	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
126355	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
126356	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
126357	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
126358	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126359	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126360	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126361	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126362	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126363	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126364	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126365	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
126366	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
126367	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126368	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126369	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53444	
126370	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
126371	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
126372	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
126373	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
126374	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	0	
126375	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations This Read Vac	2	
126376	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	27	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
126377	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	27	
126378	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
126379	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	0	
126380	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126381	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126382	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126383	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126384	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
126385	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations This Read Vac	2	
126386	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126387	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Switching Operations	2	
126388	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Tank Paint Condition	Good	
126389	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Unknown Operations	0	
126390	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
126391	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
126392	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
126393	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
126394	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
126395	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
126396	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
126397	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
126398	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126399	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
126400	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
126401	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
126402	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
126403	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	4444	
126404	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	4444	
126405	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
126406	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126407	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126408	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126409	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126410	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
126411	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushing Condition	Good	
126412	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps C Ø	53.0	
126413	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps B Ø	53.0	
126414	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps A Ø	53.0	
126415	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126416	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126417	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126418	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations	3	
126419	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
126420	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126421	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
126422	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
126423	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
126424	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126425	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126426	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126427	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	250.0	
126428	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	200.0	
126429	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AL	102	
126430	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AF	102	
126431	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
126432	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Maintenance Operations	0	
126433	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126434	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Grounds in Place?	y	
126435	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	General Comments		
126436	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	General Comments		
126437	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Foundation Condition	Good	
126438	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Follow-up Action Required?	n	
126439	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Follow-up Action Required?	n	
126440	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations Ground	0	
126441	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations C Ø	0	
126442	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations B Ø	0	
126443	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations A Ø	0	
126444	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
126445	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	1R	
126446	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	1R	
126447	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126448	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
126449	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
126450	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126451	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126452	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
126453	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
126454	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
126455	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
126456	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	200.0	
126457	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
126458	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126459	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126460	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126461	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126462	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
126463	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126464	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126465	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
126466	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126467	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
126468	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
126469	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
126470	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Unknown Operations	0	
126471	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Tank Paint Condition	Good	
126472	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Switching Operations	0	
126473	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations This Read Vac	0	
126474	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AL	206	
126475	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126476	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126477	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126478	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments		
126479	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126480	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	
126481	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
126482	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126483	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Current Tap Position	1R	
126484	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126485	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126486	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126487	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126488	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushing Condition	Good	
126489	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
126490	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
126491	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	227454	
126492	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126493	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126494	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
126495	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
126496	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
126497	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Leaks	None	
126498	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126499	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126500	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Regulator As Left Counter	46186	
126501	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Output Voltage Level	120.6	volts
126502	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
126503	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
126504	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126505	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126506	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Min Tap Position	1L	
126507	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Max Tap Position	1L	
126508	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Grounds in Place?	y	
126509	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	General Comments		
126510	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126511	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
126512	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
126513	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
126514	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
126515	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
126516	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Unknown Operations	0	
126517	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Tank Paint Condition	Good	
126518	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Switching Operations	1	
126519	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126520	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations This Read Vac	1	
126521	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
126522	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
126523	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
126524	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
126525	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB00086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
126526	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB00086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126527	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	0	
126528	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126529	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	0	
126530	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	234	
126531	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	8	
126532	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
126533	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
126534	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
126535	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
126536	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
126537	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
126538	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
126539	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
126540	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AF	123	
126541	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LTC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
126542	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LTC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
126543	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
126544	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
126545	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126546	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126547	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126548	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126549	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126550	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126551	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126552	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126553	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126554	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
126555	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	195.0	
126556	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	165.0	
126557	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	215.0	
126558	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126559	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126560	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126561	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	5	
126562	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Foundation Condition	Good	
126563	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
126564	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126565	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LTC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
126566	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Current Tap Position	1L	
126567	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126568	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126569	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126570	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126571	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushing Condition	Good	
126572	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Follow-up Action Required?	n	
126573	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations Ground	0	
126574	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations C Ø	0	
126575	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations B Ø	0	
126576	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AL	123	
126577	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126578	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126579	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126580	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126581	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Grounds in Place?	y	
126582	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	General Comments		
126583	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	General Comments		
126584	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126585	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126586	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126587	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
126588	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AF	206	
126589	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Moisture and Leak Free?	y	
126590	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Maintenance Operations	0	
126591	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126592	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126593	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126594	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
126595	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126596	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126597	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126598	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126599	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
126600	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
126601	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126602	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
126603	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
126604	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
126605	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
126606	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
126607	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
126608	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126609	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
126610	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126611	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126612	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	0	
126613	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
126614	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	390	
126615	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	390	
126616	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	3	
126617	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
126618	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
126619	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.8	volts
126620	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	48325	
126621	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126622	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126623	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
126624	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
126625	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Follow-up Action Required?	n	
126626	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Foundation Condition	Good	
126627	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	General Comments		
126628	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	General Comments		
126629	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Grounds in Place?	y	
126630	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126631	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126632	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	3	
126633	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
126634	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
126635	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	234	
126636	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
126637	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
126638	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126639	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
126640	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Maintenance Operations	0	
126641	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
126642	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
126643	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126644	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
126645	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126646	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126647	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126648	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126649	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
126650	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
126651	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
126652	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
126653	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
126654	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
126655	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	8438.40	kw
126656	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
126657	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
126658	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
126659	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
126660	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
126661	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
126662	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
126663	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
126664	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
126665	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
126666	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
126667	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
126668	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
126669	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
126670	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.5860	
126671	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	85	°C
126672	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	35	°C
126673	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
126674	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
126675	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
126676	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126677	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
126678	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
126679	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
126680	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
126681	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
126682	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
126683	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
126684	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
126685	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
126686	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
126687	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
126688	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
126689	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
126690	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
126691	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126692	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
126693	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
126694	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
126695	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
126696	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
126697	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
126698	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
126699	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
126700	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
126701	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
126702	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
126703	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
126704	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
126705	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
126706	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
126707	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
126708	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
126709	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
126710	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
126711	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
126712	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
126713	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
126714	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
126715	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
126716	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
126717	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
126718	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
126719	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
126720	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
126721	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
126722	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126723	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
126724	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
126725	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
126726	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126727	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126728	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
126729	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
126730	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
126731	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
126732	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126733	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
126734	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
126735	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
126736	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
126737	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
126738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
126739	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
126740	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
126741	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
126742	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
126743	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
126744	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
126745	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
126746	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
126747	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
126748	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
126749	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
126750	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126751	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
126752	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126753	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126754	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126755	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126756	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126757	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126758	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126759	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
126760	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	220.0	
126761	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	210.0	
126762	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
126763	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126764	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126765	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126766	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
126767	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
126768	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
126769	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
126770	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
126771	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
126772	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
126773	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
126774	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
126775	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
126776	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
126777	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
126778	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
126779	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
126780	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
126781	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments	Limbs from trees growing over fence into station.	
126782	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
126783	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
126784	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
126785	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
126786	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
126787	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
126788	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
126789	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126790	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
126791	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	272	
126792	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	272	
126793	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
126794	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
126795	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126796	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Present	60	*C
126797	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Max	100	*C
126798	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
126799	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
126800	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
126801	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
126802	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Leaks	None	
126803	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
126804	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
126805	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
126806	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
126807	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Operational?	y	
126808	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Condition	Good	
126809	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Present	60	*C
126810	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Max	90	*C
126811	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
126812	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
126813	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
126814	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
126815	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	General Comments	NEED NITROGEN BOTTLE FILLED	
126816	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	General Comments		
126817	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
126818	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
126819	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
126820	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Follow-up Action Required?	n	
126821	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Operational?	y	
126822	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Condition	Good	
126823	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
126824	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
126825	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
126826	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	8L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126827	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	1R	
126828	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	4L	
126829	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
126830	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	111572	
126831	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	111572	
126832	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
126833	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
126834	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
126835	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
126836	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	10L	
126837	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	3L	
126838	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	5L	
126839	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
126840	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	141515	
126841	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	141515	
126842	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
126843	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC000006	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
126844	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC000006	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	y	
126845	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC000006	LTCControl	Retired Distribution	LTC Control Insp	General Comments	OUT OF SERVICE	
126846	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC000006	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
126847	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
126848	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
126849	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
126850	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
126851	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	General Comments	OK	
126852	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
126853	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	General Comments	OK	
126854	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
126855	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
126856	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	2	
126857	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126858	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	2	
126859	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	492	
126860	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	492	
126861	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
126862	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
126863	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126864	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
126865	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
126866	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
126867	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
126868	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
126869	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
126870	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
126871	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
126872	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
126873	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
126874	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	0	
126875	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
126876	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	0	
126877	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	0	
126878	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	443	
126879	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
126880	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
126881	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
126882	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
126883	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
126884	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
126885	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
126886	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
126887	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
126888	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
126889	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
126890	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
126891	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
126892	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126893	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126894	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126895	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126896	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126897	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126898	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126899	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126900	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126901	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126902	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	180.0	
126903	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	200.0	
126904	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
126905	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
126906	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	200.0	
126907	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126908	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126909	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126910	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	9	
126911	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
126912	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	561	
126913	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
126914	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
126915	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
126916	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
126917	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	931	
126918	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
126919	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
126920	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
126921	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
126922	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
126923	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
126924	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
126925	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
126926	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
126927	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
126928	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
126929	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
126930	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
126931	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
126932	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
126933	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
126934	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
126935	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
126936	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
126937	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
126938	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
126939	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
126940	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
126941	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
126942	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
126943	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
126944	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
126945	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
126946	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
126947	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
126948	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
126949	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
126950	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
126951	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
126952	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
126953	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
126954	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
126955	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
126956	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
126957	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
126958	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
126959	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
126960	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
126961	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
126962	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
126963	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
126964	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
126965	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
126966	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
126967	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
126968	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
126969	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
126970	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
126971	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
126972	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
126973	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
126974	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
126975	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
126976	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
126977	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	140.0	
126978	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	140.0	
126979	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	140.0	
126980	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
126981	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
126982	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
126983	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
126984	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28931	
126985	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
126986	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
126987	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
126988	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
126989	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	10	
126990	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
126991	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
126992	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
126993	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
126994	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
126995	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
126996	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
126997	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
126998	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
126999	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
127000	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
127001	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
127002	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
127003	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
127004	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
127005	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
127006	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
127007	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
127008	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
127009	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
127010	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
127011	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
127012	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
127013	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
127014	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
127015	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
127016	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
127017	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127018	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
127019	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
127020	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	53	*F
127021	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	186366	
127022	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	186362	
127023	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
127024	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
127025	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127026	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
127027	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
127028	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127029	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
127030	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
127031	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	*C
127032	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Present	52	*C
127033	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
127034	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
127035	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127036	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
127037	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127038	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127039	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
127040	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
127041	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127042	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
127043	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
127044	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
127045	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	120.8	VAC
127046	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
127047	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	General Comments		
127048	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
127049	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
127050	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
127051	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127052	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
127053	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
127054	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
127055	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		
127056	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
127057	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
127058	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
127059	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Grounds in Place?	y	
127060	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	General Comments		
127061	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	General Comments		
127062	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
127063	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Foundation Condition	Good	
127064	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
127065	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
127066	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
127067	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
127068	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
127069	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127070	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
127071	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
127072	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Ambient Temperature	53	*F
127073	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127074	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
127075	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
127076	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127077	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
127078	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	General Comments		
127079	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127080	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127081	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127082	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	678	
127083	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	9L	
127084	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	4L	
127085	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	6L	
127086	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127087	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Tank Paint Condition	Good	
127088	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Switching Operations	0	
127089	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
127090	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	68	psi
127091	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
127092	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations This Read SF6	0	
127093	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	81	
127094	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	81	
127095	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	0	
127096	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
127097	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
127098	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
127099	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
127100	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
127101	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
127102	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
127103	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
127104	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
127105	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
127106	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
127107	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
127108	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
127109	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
127110	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
127111	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
127112	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
127113	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
127114	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
127115	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
127116	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
127117	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
127118	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	7	
127119	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127120	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127121	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127122	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	150.0	
127123	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	145.0	
127124	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	145.0	
127125	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
127126	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127127	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
127128	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
127129	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
127130	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
127131	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
127132	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
127133	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127134	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
127135	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127136	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
127137	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127138	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
127139	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	1	
127140	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
127141	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	1	
127142	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
127143	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
127144	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
127145	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
127146	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
127147	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments		
127148	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	
127149	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
127150	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
127151	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
127152	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
127153	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
127154	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
127155	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
127156	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
127157	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
127158	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
127159	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
127160	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
127161	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
127162	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
127163	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
127164	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
127165	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
127166	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
127167	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
127168	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
127169	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
127170	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
127171	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
127172	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
127173	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
127174	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
127175	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
127176	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
127177	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
127178	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
127179	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
127180	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
127181	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
127182	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
127183	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
127184	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
127185	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
127186	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
127187	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
127188	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	159659	
127189	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
127190	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
127191	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
127192	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
127193	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
127194	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
127195	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
127196	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
127197	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127198	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127199	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127200	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations A Ø	0	
127201	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127202	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations C Ø	0	
127203	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations Ground	0	
127204	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Follow-up Action Required?	n	
127205	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Follow-up Action Required?	n	
127206	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	General Comments		
127207	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	General Comments		
127208	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Maintenance Operations	0	
127209	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AF	1002	
127210	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AL	1002	
127211	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations This Read Vac	0	
127212	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Switching Operations	0	
127213	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Unknown Operations	0	
127214	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
127215	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
127216	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
127217	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
127218	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
127219	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
127220	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
127221	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
127222	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
127223	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
127224	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
127225	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
127226	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
127227	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
127228	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
127229	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
127230	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments		
127231	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
127232	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
127233	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127234	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127235	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
127236	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
127237	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
127238	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
127239	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
127240	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127241	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
127242	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
127243	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127244	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2198	
127245	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127246	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments		
127247	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
127248	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	328329	
127249	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	328329	
127250	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127251	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	4L	
127252	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	3L	
127253	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	8L	
127254	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	653	
127255	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127256	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127257	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
127258	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
127259	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	10L	
127260	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127261	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	125294	
127262	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127263	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	125294	
127264	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
127265	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
127266	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127267	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
127268	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations	0	
127269	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127270	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127271	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127272	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps A Ø	0.0	
127273	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127274	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127275	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127276	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	979	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127277	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	7L	
127278	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	4R	
127279	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	3L	
127280	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127281	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	272335	
127282	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	272335	
127283	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
127284	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
127285	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127286	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
127287	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps B Ø	0.0	
127288	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps C Ø	0.0	
127289	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127290	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
127291	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
127292	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
127293	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
127294	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
127295	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
127296	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
127297	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
127298	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
127299	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
127300	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
127301	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
127302	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
127303	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
127304	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
127305	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
127306	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
127307	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
127308	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
127309	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
127310	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Grounds in Place?	y	
127311	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Heaters (All) Functioning?	y	
127312	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Maintenance Operations	0	
127313	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Moisture and Leak Free?	y	
127314	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AF	313	
127315	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AL	313	
127316	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations This Read Vac	0	
127317	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
127318	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Switching Operations	0	
127319	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Tank Paint Condition	Good	
127320	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Unknown Operations	0	
127321	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
127322	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
127323	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
127324	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Tank Paint Condition	Good	
127325	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Switching Operations	0	
127326	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
127327	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Pressure	65	psi
127328	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
127329	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
127330	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations This Read SF6	0	
127331	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AL	80	
127332	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AF	80	
127333	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Num Operations Last 9 Months	0	
127334	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
127335	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Maintenance Operations	0	
127336	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	9	
127337	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127338	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127339	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127340	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	120.0	
127341	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	130.0	
127342	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	130.0	
127343	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
127344	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
127345	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
127346	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
127347	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
127348	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
127349	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
127350	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
127351	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
127352	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
127353	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
127354	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
127355	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
127356	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
127357	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		
127358	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
127359	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
127360	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
127361	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
127362	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
127363	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
127364	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
127365	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127366	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
127367	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127368	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127369	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127370	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127371	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
127372	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
127373	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
127374	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
127375	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
127376	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations Ground	0	
127377	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Follow-up Action Required?	n	
127378	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Follow-up Action Required?	n	
127379	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Foundation Condition	Good	
127380	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	General Comments		
127381	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	General Comments		
127382	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
127383	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	9152.00	kw
127384	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127385	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
127386	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	50	°C
127387	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	25	°C
127388	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127389	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
127390	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127391	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127392	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
127393	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
127394	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127395	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
127396	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	1.1440	
127397	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
127398	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
127399	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
127400	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
127401	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
127402	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
127403	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
127404	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
127405	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
127406	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
127407	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
127408	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Unknown Operations	0	
127409	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Switching Operations	4	
127410	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations This Read Vac	4	
127411	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AL	12	
127412	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AF	12	
127413	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Maintenance Operations	0	
127414	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	General Comments		
127415	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	General Comments		
127416	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Follow-up Action Required?	n	
127417	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Follow-up Action Required?	n	
127418	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations Ground	0	
127419	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations C Ø	0	
127420	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations B Ø	0	
127421	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations A Ø	0	
127422	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127423	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127424	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127425	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127426	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127427	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps B Ø	0.0	
127428	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps A Ø	0.0	
127429	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127430	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127431	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127432	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	9 Month Operations	7	
127433	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
127434	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
127435	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
127436	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
127437	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
127438	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	General Comments		
127439	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
127440	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
127441	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
127442	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
127443	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
127444	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
127445	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
127446	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
127447	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Bank Amps	2.5	AMPS
127448	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
127449	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BAT001042	Battery	930-Offline-Distribution	Battery Patrol Inspection	All Connections OK?	y	
127450	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
127451	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
127452	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
127453	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
127454	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
127455	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
127456	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
127457	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
127458	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
127459	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
127460	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
127461	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
127462	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
127463	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
127464	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
127465	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
127466	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
127467	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
127468	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127469	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127470	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
127471	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
127472	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
127473	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
127474	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127475	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
127476	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
127477	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127478	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
127479	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
127480	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127481	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
127482	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
127483	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
127484	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
127485	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
127486	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
127487	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
127488	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
127489	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		
127490	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
127491	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
127492	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	
127493	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
127494	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
127495	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
127496	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
127497	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127498	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127499	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127500	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127501	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127502	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127503	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
127504	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
127505	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
127506	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushing Condition	Good	
127507	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps C Ø	0.0	
127508	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps B Ø	0.0	
127509	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127510	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
127511	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	General Comments		
127512	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps A Ø	0.0	
127513	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127514	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127515	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127516	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations	12	
127517	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
127518	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
127519	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
127520	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
127521	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
127522	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
127523	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
127524	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
127525	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
127526	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
127527	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
127528	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000143	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
127529	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000145	LTCControl	P-TRANS 2	LTC Control Insp	All Connections OK?	y	
127530	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000145	LTCControl	P-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
127531	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000145	LTCControl	P-TRANS 2	LTC Control Insp	General Comments		
127532	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000145	LTCControl	P-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
127533	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
127534	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTO159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127535	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
127536	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
127537	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
127538	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
127539	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	4	
127540	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127541	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127542	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127543	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	914	
127544	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	8L	
127545	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	4R	
127546	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	4L	
127547	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127548	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	6363	
127549	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	6363	
127550	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
127551	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
127552	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127553	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
127554	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
127555	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127556	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127557	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127558	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127559	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
127560	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
127561	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127562	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
127563	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments		
127564	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
127565	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
127566	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
127567	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
127568	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	53	°C
127569	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
127570	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
127571	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
127572	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127573	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC0000345	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
127574	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC0000345	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
127575	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC0000345	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
127576	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC0000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
127577	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC000345	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
127578	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
127579	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
127580	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	LTC000345	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
127581	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
127582	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
127583	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations This Read Vac	4	
127584	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	720	
127585	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	720	
127586	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127587	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
127588	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127589	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127590	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
127591	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
127592	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127593	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
127594	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127595	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127596	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
127597	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127598	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
127599	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127600	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
127601	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
127602	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
127603	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
127604	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127605	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
127606	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127607	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127608	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
127609	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
127610	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127611	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
127612	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
127613	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	
127614	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
127615	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
127616	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
127617	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
127618	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
127619	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
127620	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
127621	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
127622	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
127623	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
127624	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
127625	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
127626	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
127627	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	6	
127628	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
127629	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
127630	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
127631	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127632	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Follow-up Action Required?	n	
127633	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	General Comments		
127634	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank Leaks	None	
127635	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 3 Oil Level	Good	
127636	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations C Ø	0	
127637	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations B Ø	0	
127638	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
127639	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
127640	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
127641	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
127642	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
127643	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
127644	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
127645	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
127646	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
127647	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments		
127648	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
127649	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
127650	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
127651	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127652	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
127653	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations A Ø	0	
127654	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127655	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127656	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127657	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127658	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
127659	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127660	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
127661	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
127662	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushing Condition	Good	
127663	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps C Ø	105.0	
127664	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps B Ø	110.0	
127665	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps A Ø	100.0	
127666	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty C Ph V	.98	%
127667	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty B Ph V	.98	%
127668	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty A Ph V	4.88	%
127669	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations	4	
127670	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
127671	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127672	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127673	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
127674	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
127675	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
127676	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
127677	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127678	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
127679	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127680	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
127681	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127682	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
127683	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
127684	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127685	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
127686	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
127687	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127688	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
127689	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
127690	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
127691	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127692	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
127693	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
127694	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127695	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
127696	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127697	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
127698	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
127699	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127700	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
127701	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
127702	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127703	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
127704	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
127705	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
127706	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127707	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
127708	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
127709	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	542.40	kw
127710	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
127711	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
127712	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
127713	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
127714	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127715	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
127716	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127717	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127718	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
127719	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
127720	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127721	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
127722	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0904	
127723	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
127724	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
127725	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
127726	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127727	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
127728	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
127729	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
127730	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127731	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127732	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
127733	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
127734	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
127735	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
127736	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
127737	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
127738	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
127739	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
127740	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
127741	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
127742	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
127743	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
127744	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
127745	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
127746	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 2 Oil level	Good	
127747	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 1 Oil Level	Good	
127748	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Grounds in Place?	y	
127749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	General Comments		
127750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Foundation Condition	Good	
127751	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Follow-up Action Required?	n	
127752	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Equipment Properly Labeled?	y	
127753	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127754	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
127755	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127756	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127757	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127758	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	1038	
127759	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
127760	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	8L	
127761	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
127762	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	5L	
127763	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127764	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	25295	
127765	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	25295	
127766	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
127767	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
127768	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127769	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
127770	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	25	°C
127771	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	4390	
127772	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
127773	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127774	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
127775	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
127776	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127777	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127778	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
127779	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127780	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
127781	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
127782	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
127783	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
127784	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
127785	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
127786	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2107.20	kw
127787	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
127788	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
127789	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations A Ø	0	
127790	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127791	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127792	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127793	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127794	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
127795	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
127796	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
127797	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
127798	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
127799	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Bushing Condition	Good	
127800	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps C Ø	215.0	
127801	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps B Ø	218.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
127802	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps A Ø	212.0	
127803	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	9 Month Operations	3	
127804	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	13L	
127805	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
127806	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
127807	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
127808	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
127809	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
127810	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
127811	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
127812	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
127813	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
127814	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
127815	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
127816	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
127817	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
127818	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
127819	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	"F
127820	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
127821	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
127822	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
127823	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
127824	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
127825	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
127826	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
127827	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
127828	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
127829	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
127830	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
127831	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
127832	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
127833	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
127834	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	n	
127835	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
127836	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
127837	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
127838	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
127839	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
127840	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
127841	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
127842	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
127843	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
127844	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
127845	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
127846	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127847	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
127848	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
127849	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
127850	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
127851	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
127852	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
127853	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
127854	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
127855	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
127856	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
127857	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
127858	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
127859	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
127860	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
127861	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	LTC0000816	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
127862	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
127863	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
127864	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
127865	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
127866	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000147	LTCControl	P-TRANS 1	LTC Control Insp	All Connections OK?	y	
127867	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000147	LTCControl	P-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
127868	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Unknown Operations	0	
127869	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Tank Paint Condition	Good	
127870	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Switching Operations	2	
127871	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
127872	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations This Read Vac	2	
127873	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AL	34	
127874	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AF	34	
127875	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
127876	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127877	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
127878	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Grounds in Place?	y	
127879	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	General Comments		
127880	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	General Comments		
127881	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Foundation Condition	Good	
127882	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Follow-up Action Required?	n	
127883	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Follow-up Action Required?	n	
127884	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000147	LTCControl	P-TRANS 1	LTC Control Insp	General Comments		
127885	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000147	LTCControl	P-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
127886	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
127887	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations Ground	0	
127888	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations C Ø	0	
127889	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations B Ø	0	
127890	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
127891	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
127892	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
127893	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
127894	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
127895	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
127896	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
127897	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
127898	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
127899	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
127900	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
127901	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
127902	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
127903	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
127904	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
127905	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
127906	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
127907	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
127908	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
127909	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
127910	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
127911	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
127912	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
127913	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
127914	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
127915	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
127916	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
127917	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	All Connections OK?	y	
127918	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	Follow-up Action Required?	n	
127919	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	General Comments		
127920	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	LTC Operation Checked?	y	
127921	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	LTC Output Voltage Level	121.5	VAC
127922	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
127923	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
127924	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	LTC0000589	LTCControl	825-3	LTC Control Insp	VRR Time Delay	30	Seconds
127925	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
127926	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
127927	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
127928	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
127929	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1381	
127930	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
127931	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
127932	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
127933	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
127934	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
127935	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Left Counter	117524	
127936	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
127937	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
127938	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	General Comments		
127939	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
127940	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Found Counter	117524	
127941	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
127942	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
127943	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
127944	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
127945	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
127946	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
127947	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
127948	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty, and trees are overhanging the fence	
127949	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
127950	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	57460	
127951	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
127952	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
127953	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
127954	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
127955	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
127956	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
127957	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
127958	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
127959	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
127960	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
127961	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
127962	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
127963	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
127964	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
127965	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
127966	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
127967	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
127968	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
127969	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
127970	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
127971	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
127972	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
127973	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments		
127974	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
127975	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
127976	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
127977	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
127978	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
127979	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
127980	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
127981	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
127982	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
127983	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
127984	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
127985	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
127986	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
127987	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
127988	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
127989	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
127990	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
127991	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
127992	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
127993	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Present	0	°C
127994	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LV Winding Temp Max	0	°C
127995	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	8280.96	kw
127996	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Present	0	°C
127997	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	HV Winding Temp Max	0	°C
127998	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
127999	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
128000	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
128001	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
128002	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
128003	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
128004	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
128005	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
128006	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
128007	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128008	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
128009	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
128010	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
128011	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
128012	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128013	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
128014	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	2	
128015	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128016	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128017	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128018	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	60.0	
128019	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	70.0	
128020	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	55.0	
128021	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
128022	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128023	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128024	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128025	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128026	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
128027	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128028	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128029	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128030	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128031	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	
128032	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
128033	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	
128034	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
128035	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
128036	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
128037	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
128038	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
128039	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
128040	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
128041	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128042	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
128043	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
128044	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	General Comments	NEEDS NITROGEN	
128045	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
128046	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
128047	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128048	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128049	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
128050	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
128051	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
128052	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
128053	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
128054	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
128055	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
128056	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
128057	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Eyewash Solution	Good	
128058	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
128059	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
128060	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
128061	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
128062	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
128063	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
128064	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
128065	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
128066	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
128067	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
128068	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
128069	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
128070	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
128071	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
128072	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
128073	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
128074	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128075	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128076	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
128077	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
128078	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
128079	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Present	0	°C
128080	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	TV Winding Temp Max	0	°C
128081	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	.8626	
128082	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
128083	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
128084	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
128085	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
128086	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
128087	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
128088	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
128089	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
128090	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	34	°C
128091	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	70	°C
128092	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
128093	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Oil Level	Good	
128094	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Condition	Good	
128095	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
128096	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
128097	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
128098	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
128099	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	n	
128100	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
128101	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128102	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
128103	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
128104	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
128105	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
128106	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
128107	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
128108	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
128109	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
128110	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
128111	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
128112	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
128113	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
128114	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
128115	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
128116	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
128117	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
128118	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
128119	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
128120	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
128121	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
128122	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
128123	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
128124	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
128125	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
128126	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
128127	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
128128	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
128129	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
128130	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
128131	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
128132	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
128133	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
128134	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
128135	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
128136	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
128137	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
128138	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128139	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
128140	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
128141	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
128142	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
128143	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128144	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	
128145	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
128146	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	170	
128147	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	170	
128148	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations This Read Vac	1	
128149	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
128150	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	1	
128151	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
128152	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	
128153	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
128154	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
128155	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushing Condition	Good	
128156	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128157	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128158	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128159	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128160	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Current Tap Position	5L	
128161	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128162	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
128163	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Foundation Condition	Good	
128164	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128165	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	General Comments		
128166	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Grounds in Place?	y	
128167	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Max Tap Position	3L	
128168	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Min Tap Position	10L	
128169	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128170	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128171	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
128172	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
128173	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.9	volts
128174	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	15949	
128175	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
128176	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128177	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
128178	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
128179	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Paint Condition	Good	
128180	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Leaks	None	
128181	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
128182	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 2 Oil Level	Good	
128183	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
128184	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
128185	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Grounds in Place?	y	
128186	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	General Comments		
128187	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Foundation Condition	Good	
128188	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Follow-up Action Required?	n	
128189	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
128190	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
128191	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128192	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
128194	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
128195	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
128196	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
128197	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
128198	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
128199	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
128200	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
128201	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
128202	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
128203	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
128204	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
128205	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
128206	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
128207	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
128208	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
128209	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
128210	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
128211	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
128212	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
128213	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
128214	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
128215	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
128216	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
128217	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
128218	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
128219	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
128220	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
128221	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
128222	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
128223	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
128224	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
128225	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
128226	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
128227	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
128228	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
128229	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
128230	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
128231	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
128232	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
128233	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	792	
128234	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
128235	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
128236	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
128237	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
128238	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	56793	
128239	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	56793	
128240	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	TODAY THE LTC WAS JUST A LIL BELOW 25C LOOKS GOOD TO ME	
128241	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
128242	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
128243	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
128244	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
128245	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
128246	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
128247	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
128248	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
128249	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128250	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
128251	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128252	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
128253	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
128254	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
128255	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
128256	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
128257	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	General Comments		
128258	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
128259	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
128260	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Foundation Condition	Good	
128261	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
128262	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
128263	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
128264	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
128265	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
128266	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
128267	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
128268	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
128269	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
128270	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
128271	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
128272	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
128273	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	4616.00	kw
128274	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
128275	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
128276	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	50	°C
128277	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	30	°C
128278	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
128279	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
128280	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
128281	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
128282	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
128283	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
128284	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
128285	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
128286	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.5770	
128287	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
128288	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
128289	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
128290	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
128291	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
128292	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
128293	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
128294	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
128295	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
128296	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
128297	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
128298	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments		
128299	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
128300	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
128301	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
128302	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
128303	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
128304	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
128305	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
128306	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128307	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128308	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128309	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128310	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128311	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128312	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128313	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128314	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128315	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
128316	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	80.0	
128317	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	65.0	
128318	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	90.0	
128319	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128320	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128321	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128322	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	4	
128323	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
128324	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
128325	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
128326	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
128327	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
128328	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
128329	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
128330	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
128331	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
128332	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
128333	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
128334	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
128335	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
128336	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
128337	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
128338	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
128339	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
128340	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
128341	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	0	
128342	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128343	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128344	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128345	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	120.0	
128346	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	200.0	
128347	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
128348	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	2	
128349	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	2	
128350	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	201	
128351	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	201	
128352	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
128353	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	
128354	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128355	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
128356	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
128357	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
128358	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
128359	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
128360	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
128361	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
128362	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
128363	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
128364	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
128365	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128366	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128367	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128368	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128369	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128370	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128371	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128372	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128373	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128374	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
128375	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
128376	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
128377	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
128378	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128379	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128380	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128381	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	4	
128382	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
128383	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
128384	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
128385	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	1	
128386	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	1	
128387	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	201	
128388	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	201	
128389	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
128390	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
128391	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128392	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
128393	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
128394	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
128395	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
128396	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
128397	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
128398	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
128399	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128400	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
128401	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128402	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128403	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
128404	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128405	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128406	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128407	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128408	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
128409	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	n	
128410	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	y	
128411	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCCControl	Retired Distribution	LTC Control Insp	General Comments	JUNK	
128412	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
128413	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
128414	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
128415	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
128416	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
128417	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
128418	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
128419	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
128420	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
128421	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
128422	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
128423	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
128424	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
128425	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
128426	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
128427	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
128428	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
128429	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
128430	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
128431	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
128432	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
128433	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		
128434	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
128435	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
128436	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
128437	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
128438	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
128439	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
128440	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
128441	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
128442	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
128443	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
128444	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
128445	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
128446	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
128447	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
128448	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128449	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128450	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
128451	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	270.0	
128452	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	290.0	
128453	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
128454	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128455	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128456	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128457	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BB0250	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
128458	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
128459	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
128460	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
128461	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
128462	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
128463	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations Ground	0	
128464	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations C Ø	0	
128465	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations B Ø	0	
128466	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations A Ø	0	
128467	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128468	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128469	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128470	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128471	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128472	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128473	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128474	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128475	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushing Condition	Good	
128476	10/16/2019 10:40	Distribution	Wilson Downning Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps C Ø	110.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
128477	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
128478	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
128479	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
128480	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps B Ø	100.0	
128481	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps A Ø	105.0	
128482	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128483	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
128484	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty A Ph V	1.34	%
128485	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	9 Month Operations	4	
128486	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
128487	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
128488	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
128489	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
128490	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61033	
128491	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
128492	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
128493	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
128494	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128495	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128496	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
128497	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
128498	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
128499	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
128500	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
128501	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128502	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128503	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128504	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128505	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128506	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
128507	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
128508	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128509	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
128510	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
128511	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128512	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128513	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
128514	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
128515	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
128516	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
128517	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
128518	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
128519	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
128520	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
128521	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
128522	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
128523	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
128524	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
128525	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
128526	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
128527	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
128528	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
128529	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	General Comments		
128530	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
128531	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	LTC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
128532	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
128533	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
128534	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
128535	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
128536	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
128537	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
128538	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
128539	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
128540	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
128541	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
128542	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
128543	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
128544	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
128545	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
128546	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
128547	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
128548	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
128549	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128550	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
128551	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128552	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
128553	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
128554	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
128555	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
128556	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
128557	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
128558	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
128559	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128560	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128561	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128562	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128563	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
128564	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
128565	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
128566	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128567	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128568	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128569	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
128570	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
128571	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128572	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128573	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128574	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128575	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128576	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
128577	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
128578	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128579	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
128580	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
128581	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128582	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128583	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
128584	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
128585	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1272	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
128586	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
128587	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128588	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128589	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128590	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128591	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128592	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
128593	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
128594	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128595	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
128596	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
128597	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128598	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128599	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
128600	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	R1273	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
128601	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
128602	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
128603	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128604	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
128605	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
128606	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128607	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
128608	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128609	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128610	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128611	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128612	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
128613	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
128614	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
128615	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
128616	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
128617	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6704	
128618	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
128619	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
128620	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
128621	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128622	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128623	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
128624	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
128625	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
128626	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
128627	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128628	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
128629	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
128630	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128631	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
128632	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128633	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128634	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128635	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128636	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
128637	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
128638	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Leaks	None	
128639	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
128640	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
128641	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5438	
128642	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
128643	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
128644	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
128645	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128646	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128647	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
128648	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
128649	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
128650	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
128651	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
128652	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
128653	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
128654	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
128655	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
128656	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
128657	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
128658	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	858	
128659	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	*C
128660	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	*C
128661	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	11L	
128662	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	3L	
128663	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	4L	
128664	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
128665	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	17698	
128666	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128667	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128668	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128669	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations	10	
128670	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	17698	
128671	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
128672	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
128673	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
128674	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
128675	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	General Comments		
128676	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
128677	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
128678	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
128679	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
128680	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
128681	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1611	
128682	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1611	
128683	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
128684	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
128685	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
128686	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
128687	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
128688	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
128689	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
128690	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
128691	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
128692	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
128693	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
128694	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6408	
128695	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
128696	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
128697	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
128698	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
128699	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
128700	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
128701	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	2L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128702	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	General Comments		
128703	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Foundation Condition	Good	
128704	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Follow-up Action Required?	n	
128705	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
128706	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
128707	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
128708	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
128709	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
128710	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
128711	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1952	
128712	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1952	
128713	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
128714	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
128715	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
128716	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
128717	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
128718	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	General Comments		
128719	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
128720	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
128721	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
128722	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
128723	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
128724	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
128725	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
128726	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
128727	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128728	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128729	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
128730	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
128731	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
128732	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
128733	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
128734	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
128735	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
128736	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
128737	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
128738	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
128739	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
128740	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
128741	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
128742	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
128743	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
128744	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
128745	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
128746	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
128747	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
128748	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
128749	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
128750	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	FE000371	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
128751	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Follow-up Action Required?	n	
128752	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations Ground	0	
128753	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
128754	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
128755	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
128756	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
128757	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
128758	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
128759	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
128760	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
128761	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
128762	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
128763	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
128764	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
128765	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
128766	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
128767	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
128768	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
128769	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
128770	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
128771	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
128772	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
128773	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
128774	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
128775	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
128776	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128777	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
128778	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
128779	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
128780	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
128781	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
128782	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		
128783	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
128784	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Eyewash Solution	Good	
128785	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
128786	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
128787	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
128788	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
128789	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
128790	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
128791	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
128792	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
128793	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Unknown Operations	0	
128794	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Tank Paint Condition	Good	
128795	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Switching Operations	0	
128796	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations This Read Vac	0	
128797	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AL	231	
128798	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AF	231	
128799	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Moisture and Leak Free?	y	
128800	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Maintenance Operations	0	
128801	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128802	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Grounds in Place?	y	
128803	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	General Comments		
128804	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
128805	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	*C
128806	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	*C
128807	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	*C
128808	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	*C
128809	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	*C
128810	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	*C
128811	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
128812	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
128813	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
128814	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128815	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
128816	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
128817	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
128818	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
128819	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128820	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128821	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
128822	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
128823	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
128824	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
128825	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
128826	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
128827	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
128828	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
128829	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	465.60	kw
128830	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
128831	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
128832	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	51	*C
128833	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	38	*C
128834	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
128835	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
128836	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
128837	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
128838	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3880	
128839	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
128840	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	384	
128841	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	384	
128842	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	0	
128843	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
128844	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	0	
128845	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
128846	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
128847	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
128848	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
128849	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	2	
128850	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
128851	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	2	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128852	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	73	
128853	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	73	
128854	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	120.0	
128855	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
128856	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128857	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128858	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128859	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128860	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128861	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128862	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128863	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128864	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128865	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
128866	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
128867	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
128868	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
128869	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
128870	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
128871	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
128872	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
128873	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
128874	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
128875	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
128876	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
128877	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
128878	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
128879	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
128880	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
128881	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
128882	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
128883	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
128884	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
128885	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
128886	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
128887	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
128888	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
128889	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
128890	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
128891	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
128892	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
128893	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
128894	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
128895	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
128896	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
128897	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
128898	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
128899	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
128900	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
128901	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
128902	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
128903	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
128904	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
128905	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
128906	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTC000319	LTCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
128907	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Follow-up Action Required?	n	
128908	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations Ground	0	
128909	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations C Ø	0	
128910	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations B Ø	0	
128911	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations A Ø	0	
128912	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128913	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128914	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128915	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128916	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128917	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128918	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128919	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128920	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128921	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushing Condition	Good	
128922	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps C Ø	50.0	
128923	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps B Ø	120.0	
128924	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps A Ø	105.0	
128925	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
128926	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
128927	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
128928	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
128929	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
128930	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
128931	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
128932	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
128933	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
128934	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
128935	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
128936	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128937	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128938	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
128939	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
128940	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
128941	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
128942	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
128943	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
128944	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
128945	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
128946	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	812	
128947	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	°C
128948	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	24	°C
128949	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	10L	
128950	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	4L	
128951	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	5L	
128952	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
128953	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	18573	
128954	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	18573	
128955	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	General Comments		
128956	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
128957	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
128958	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128959	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
128960	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
128961	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
128962	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
128963	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
128964	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
128965	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
128966	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
128967	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
128968	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
128969	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
128970	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
128971	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
128972	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
128973	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
128974	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
128975	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
128976	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
128977	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
128978	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
128979	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	180.0	
128980	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	150.0	
128981	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	200.0	
128982	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
128983	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
128984	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
128985	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	8	
128986	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Unknown Operations	0	
128987	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Tank Paint Condition	Good	
128988	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Switching Operations	0	
128989	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
128990	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations This Read Vac	0	
128991	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AL	177	
128992	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AF	177	
128993	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Moisture and Leak Free?	y	
128994	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Maintenance Operations	0	
128995	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Heaters (All) Functioning?	y	
128996	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Grounds in Place?	y	
128997	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	General Comments		
128998	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	General Comments		
128999	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Foundation Condition	Good	
129000	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Follow-up Action Required?	n	
129001	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129002	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
129003	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	General Comments		
129004	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
129005	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
129006	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
129007	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
129008	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129009	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129010	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129011	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129012	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129013	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129014	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129015	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129016	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129017	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations A Ø	0	
129018	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations B Ø	0	
129019	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations C Ø	0	
129020	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations Ground	0	
129021	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Follow-up Action Required?	n	
129022	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Follow-up Action Required?	n	
129023	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Foundation Condition	Good	
129024	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	General Comments		
129025	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	General Comments		
129026	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Grounds in Place?	y	
129027	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129028	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
129029	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
129030	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	113	
129031	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	113	
129032	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations This Read Vac	0	
129033	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
129034	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	0	
129035	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
129036	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
129037	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Paint Condition	Good	
129038	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Leaks	None	
129039	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 3 Oil Level	Good	
129040	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 2 Oil level	Good	
129041	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 1 Oil Level	Good	
129042	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations This Read Oil	0	
129043	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AL	1262	
129044	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AF	1262	
129045	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Number of Ops last 9 Months	0	
129046	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Moisture and Leak Free?	y	
129047	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Grounds in Place?	y	
129048	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	General Comments	OUT OF SERVICE	
129049	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Foundation Condition	Good	
129050	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Follow-up Action Required?	n	
129051	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Tank Paint Condition	Good	
129052	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	9 Month Operations	2	
129053	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129054	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129055	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129056	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps A Ø	350.0	
129057	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps B Ø	360.0	
129058	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps C Ø	420.0	
129059	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushing Condition	Good	
129060	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129061	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129062	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	2	
129063	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129064	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129065	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129066	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129067	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129068	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129069	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129070	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129071	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129072	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations A Ø	0	
129073	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations B Ø	0	
129074	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations C Ø	0	
129075	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations Ground	0	
129076	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129077	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Follow-up Action Required?	n	
129078	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Foundation Condition	Good	
129079	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	General Comments		
129080	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	General Comments		
129081	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Grounds in Place?	y	
129082	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129083	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Maintenance Operations	0	
129084	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Moisture and Leak Free?	y	
129085	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AF	226	
129086	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AL	226	
129087	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations This Read Vac	0	
129088	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
129089	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Switching Operations	0	
129090	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129091	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Tank Paint Condition	Good	
129092	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Unknown Operations	0	
129093	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	200.0	
129094	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	214.0	
129095	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	205.0	
129096	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Left Counter	301032	
129097	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
129098	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10R	
129099	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Condition	Good	
129100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Oil Level	Good	
129101	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushings Connection/Risers	Good	
129102	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
129103	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129104	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129105	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Paint Condition	Good	
129106	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Equipment Properly Labeled?	y	
129107	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Fault Operations	0	
129108	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Follow-up Action Required?	n	
129109	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Follow-up Action Required?	n	
129110	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Foundation Condition	Good	
129111	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	General Comments		
129112	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Grounds in Place?	y	
129113	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Maintenance Operations	0	
129114	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Moisture and Leak Free?	y	
129115	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Number of Ops last 9 Months	0	
129116	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AF	645	
129117	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AL	645	
129118	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations This Read Oil	0	
129119	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Max Tap Position	12R	
129120	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9R	
129121	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	238	
129122	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
129123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
129124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
129125	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Switching Operations	0	
129126	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 1 Oil Level	Good	
129127	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 2 Oil Level	Good	
129128	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 3 Oil Level	Good	
129129	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Leaks	None	
129130	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Paint Condition	Good	
129131	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
129132	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
129133	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
129134	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
129135	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
129136	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
129137	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments	station supply transformer fuse looking somewhat frayed	
129138	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
129139	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
129140	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Equipment Properly Labeled?	y	
129141	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129142	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129143	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Bushing Condition	Good	
129144	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
129145	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
129146	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.81	%
129147	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
129148	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.81	%
129149	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	145.0	
129150	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	140.0	
129151	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
129152	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
129153	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129154	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129155	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129156	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129157	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129158	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129159	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129160	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129161	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129162	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
129163	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
129164	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
129165	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
129166	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
129167	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
129168	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
129169	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
129170	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
129171	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
129172	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129173	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
129174	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
129175	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	271	
129176	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	271	
129177	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
129178	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
129179	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
129180	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	KB0022	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
129181	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
129182	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	General Comments		
129183	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
129184	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Found Counter	301032	
129185	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
129186	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
129187	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
129188	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
129189	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
129190	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
129191	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
129192	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
129193	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
129194	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	65.8	VDC
129195	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.1	VDC
129196	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
129197	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
129198	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
129199	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
129200	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129201	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
129202	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129203	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129204	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129205	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
129206	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129207	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
129208	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
129209	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129210	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129211	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
129212	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
129213	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
129214	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129215	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
129216	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129217	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
129218	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
129219	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129220	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
129221	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
129222	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129223	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	General Comments		
129224	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	General Comments		
129225	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
129226	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
129227	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
129228	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129229	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129230	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129231	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
129232	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129233	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	29	*C
129234	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	49	*C
129235	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
129236	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
129237	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	38.88	kw
129238	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129239	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
129240	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
129241	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
129242	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
129243	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129244	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
129245	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
129246	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129247	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
129248	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
129249	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129250	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129251	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129252	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
129253	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
129254	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
129255	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129256	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
129257	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129258	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
129259	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
129260	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129261	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
129262	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
129263	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129264	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	General Comments		
129265	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	General Comments		
129266	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
129267	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
129268	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
129269	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129270	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
129271	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
129272	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
129273	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
129274	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	General Comments		
129275	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Follow-up Action Required?	n	
129276	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129277	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129278	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129279	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129280	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129281	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Unknown Operations	0	
129282	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Switching Operations	0	
129283	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations This Read Vac	0	
129284	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AL	141	
129285	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AF	141	
129286	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Maintenance Operations	0	
129287	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	General Comments		
129288	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	General Comments		
129289	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
129290	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
129291	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations Ground	0	
129292	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations C ∅	0	
129293	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations B ∅	0	
129294	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations A ∅	0	
129295	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129296	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129297	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129298	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129299	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps C ∅	190.0	
129300	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps B ∅	193.0	
129301	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps A ∅	190.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129302	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129303	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129304	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129305	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations	1	
129306	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129307	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129308	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129309	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129310	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129311	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129312	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Follow-up Action Required?	n	
129313	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Foundation Condition	Good	
129314	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	General Comments		
129315	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Grounds in Place?	y	
129316	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129317	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
129318	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
129319	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	106.00	
129320	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
129321	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Max	75	°C
129322	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Present	45	°C
129323	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129324	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
129325	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129326	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129327	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129328	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
129329	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129330	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
129331	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
129332	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129333	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129334	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
129335	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
129336	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
129337	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129338	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
129339	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129340	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
129341	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
129342	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129343	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
129344	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
129345	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129346	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
129347	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	General Comments		
129348	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
129349	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
129350	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
129351	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129352	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
129353	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
129354	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
129355	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
129356	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129357	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
129358	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129359	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129360	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129361	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
129362	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129363	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Grounds in Place?	y	
129364	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
129365	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129366	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
129367	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
129368	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129369	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
129370	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
129371	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129372	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
129373	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
129374	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
129375	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	3913.92	kw
129376	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129377	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
129378	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	40	*C
129379	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	24	*C
129380	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129381	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
129382	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129383	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129384	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
129385	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
129386	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129387	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
129388	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.2718	
129389	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	50	*C
129390	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	25	*C
129391	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
129392	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
129393	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
129394	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
129395	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129396	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
129397	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
129398	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
129399	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129400	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129401	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129402	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
129403	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
129404	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
129405	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2334	
129406	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
129407	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
129408	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
129409	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
129410	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
129411	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Unknown Operations	0	
129412	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
129413	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
129414	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Leaks	None	
129415	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
129416	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
129417	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
129418	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Switching Operations	0	
129419	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations This Read Oil	0	
129420	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AL	2037	
129421	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AF	2037	
129422	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Number of Ops last 9 Months	15	
129423	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
129424	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Maintenance Operations	0	
129425	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
129426	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Grounds in Place?	y	
129427	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	General Comments		
129428	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	General Comments		
129429	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
129430	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Foundation Condition	Good	
129431	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Follow-up Action Required?	n	
129432	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
129433	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Fault Operations	0	
129434	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
129435	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
129436	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129437	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Heaters Distriobution?	y	
129438	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
129439	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
129440	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
129441	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Condition	Good	
129442	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps C Ø	60.0	
129443	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps B Ø	70.0	
129444	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps A Ø	60.0	
129445	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
129446	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
129447	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129448	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129449	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
129450	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
129451	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129452	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129453	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
129454	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
129455	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
129456	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
129457	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
129458	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
129459	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	87069	
129460	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
129461	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
129462	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
129463	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
129464	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
129465	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
129466	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
129467	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
129468	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
129469	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
129470	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
129471	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
129472	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
129473	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
129474	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
129475	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
129476	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
129477	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.4	VDC
129478	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.4	VDC
129479	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
129480	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
129481	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
129482	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
129483	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129484	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
129485	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129486	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129487	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129488	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
129489	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129490	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	38	*C
129491	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	52	*C
129492	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
129493	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
129494	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129495	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
129496	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
129497	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
129498	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
129499	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
129500	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
129501	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
129502	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2R	
129503	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
129504	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	2R	
129505	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
129506	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	59102	
129507	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	59102	
129508	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	OUT OF SERVICE	
129509	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	JUNK	
129510	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
129511	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	y	
129512	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
129513	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
129514	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
129515	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
129516	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	5R	
129517	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
129518	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5R	
129519	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
129520	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	35242	
129521	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	35242	
129522	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	OUT OF SERVICE	
129523	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	OUT OF SERVICE	
129524	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
129525	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	y	
129526	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129527	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
129528	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
129529	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
129530	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
129531	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
129532	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
129533	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
129534	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
129535	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
129536	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
129537	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
129538	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
129539	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
129540	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
129541	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
129542	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Unknown Operations	0	
129543	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Switching Operations	3	
129544	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations This Read Vac	3	
129545	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AL	1171	
129546	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AF	1171	
129547	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Maintenance Operations	0	
129548	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	General Comments		
129549	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	General Comments		
129550	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Follow-up Action Required?	n	
129551	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Follow-up Action Required?	n	
129552	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129553	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129554	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129555	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129556	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129557	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129558	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations Ground	0	
129559	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations C Ø	0	
129560	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations B Ø	0	
129561	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations A Ø	0	
129562	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129563	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129564	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129565	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129566	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps C Ø	0.0	
129567	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps B Ø	0.0	
129568	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps A Ø	0.0	
129569	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129570	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129571	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129572	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations	4	
129573	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	All Connections OK?	y	
129574	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
129575	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Overall Condition	Good	
129576	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
129577	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
129578	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
129579	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
129580	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
129581	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Eyewash Solution	Good	
129582	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Follow-up Action Required?	n	
129583	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	General Comments		
129584	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
129585	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
129586	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
129587	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
129588	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
129589	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
129590	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
129591	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
129592	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments		
129593	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
129594	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
129595	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
129596	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
129597	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
129598	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
129599	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
129600	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
129601	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	54	*F

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
129602	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
129603	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
129604	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	0	
129605	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
129606	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations This Read Vac	0	
129607	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	125	
129608	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	125	
129609	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
129610	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
129611	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129612	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
129613	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
129614	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
129615	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
129616	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
129617	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
129618	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
129619	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
129620	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	
129621	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
129622	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129623	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	General Comments		
129624	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Follow-up Action Required?	n	
129625	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129626	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
129627	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
129628	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
129629	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
129630	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
129631	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
129632	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
129633	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
129634	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
129635	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
129636	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
129637	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
129638	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
129639	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
129640	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
129641	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
129642	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
129643	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
129644	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129645	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
129646	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
129647	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
129648	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	54	°C
129649	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
129650	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
129651	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
129652	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
129653	10/16/2019 10:01	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
129654	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
129655	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
129656	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
129657	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
129658	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
129659	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
129660	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.4	volts
129661	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	86515	
129662	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
129663	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
129664	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
129665	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
129666	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
129667	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
129668	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
129669	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
129670	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
129671	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
129672	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
129673	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
129674	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
129675	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
129676	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129677	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
129678	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129679	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129680	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	
129681	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	101.0	
129682	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	230.0	
129683	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	243.0	
129684	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129685	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129686	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129687	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	2	
129688	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
129689	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
129690	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
129691	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
129692	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
129693	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
129694	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
129695	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
129696	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
129697	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
129698	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
129699	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
129700	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Max	43	°C
129701	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.5	psi
129702	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
129703	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
129704	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	General Comments	CAN,T BLEED OFF NITROGEN PRESSURE	
129705	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	General Comments		
129706	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129707	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
129708	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
129709	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
129710	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
129711	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
129712	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129713	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
129714	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129715	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
129716	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
129717	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
129718	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129719	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129720	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
129721	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
129722	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
129723	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
129724	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
129725	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
129726	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
129727	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
129728	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
129729	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
129730	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
129731	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
129732	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
129733	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	2	
129734	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129735	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129736	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129737	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	126.0	
129738	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	128.0	
129739	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	136.0	
129740	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129741	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129742	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129743	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129744	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
129745	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
129746	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
129747	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
129748	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
129749	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
129750	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
129751	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129752	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
129753	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	314	
129754	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	314	
129755	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	0	
129756	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	
129757	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
129758	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
129759	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
129760	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
129761	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
129762	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
129763	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
129764	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
129765	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
129766	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
129767	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
129768	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
129769	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
129770	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
129771	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
129772	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
129773	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
129774	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
129775	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
129776	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
129777	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
129778	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
129779	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
129780	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	85	
129781	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
129782	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
129783	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments		
129784	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
129785	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
129786	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
129787	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
129788	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
129789	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
129790	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
129791	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
129792	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
129793	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
129794	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments		
129795	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
129796	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
129797	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
129798	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
129799	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
129800	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
129801	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
129802	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
129803	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
129804	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments	Could not get amps on this trip	
129805	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
129806	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	182	
129807	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
129808	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
129809	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
129810	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
129811	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
129812	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	General Comments		
129813	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	General Comments	NEEDS NITROGEN	
129814	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
129815	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
129816	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
129817	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Max	43	*C
129818	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Present	40	*C
129819	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
129820	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
129821	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
129822	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
129823	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
129824	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
129825	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	118904	
129826	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129827	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
129828	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
129829	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
129830	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
129831	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
129832	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
129833	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
129834	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
129835	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
129836	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
129837	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
129838	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
129839	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
129840	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
129841	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
129842	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
129843	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
129844	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
129845	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
129846	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
129847	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
129848	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
129849	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
129850	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
129851	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
129852	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
129853	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53726	
129854	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
129855	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
129856	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
129857	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
129858	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
129859	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4	amps
129860	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
129861	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
129862	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
129863	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
129864	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
129865	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
129866	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
129867	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
129868	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
129869	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
129870	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
129871	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
129872	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
129873	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
129874	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129875	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
129876	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129877	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
129878	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129879	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
129880	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129881	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
129882	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
129883	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
129884	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
129885	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
129886	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
129887	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
129888	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
129889	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129890	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129891	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129892	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
129893	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
129894	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
129895	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
129896	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
129897	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
129898	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
129899	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129900	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129901	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	General Comments	OK	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
129902	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129903	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129904	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129905	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
129906	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
129907	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
129908	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
129909	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
129910	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
129911	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
129912	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	General Comments	OUT OF SERVICE	
129913	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129914	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
129915	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129916	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129917	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129918	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129919	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129920	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129921	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129922	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	General Comments	OK	
129923	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129924	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	General Comments	OK	
129925	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129926	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
129927	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
129928	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
129929	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
129930	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
129931	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
129932	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
129933	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
129934	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
129935	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
129936	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
129937	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129938	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
129939	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
129940	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	167	
129941	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	167	
129942	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations This Read Vac	0	
129943	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
129944	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
129945	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	127	
129946	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
129947	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
129948	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
129949	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
129950	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
129951	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
129952	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
129953	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	0	
129954	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
129955	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
129956	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
129957	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	243.0	
129958	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	233.0	
129959	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	101.0	
129960	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
129961	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
129962	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
129963	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
129964	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
129965	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
129966	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
129967	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
129968	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	General Comments	OK	
129969	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129970	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
129971	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
129972	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129973	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129974	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
129975	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
129976	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
129977	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
129978	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
129979	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
129980	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
129981	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
129982	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
129983	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
129984	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
129985	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
129986	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
129987	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
129988	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
129989	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
129990	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
129991	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	8012	
129992	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	8012	
129993	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
129994	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
129995	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
129996	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
129997	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
129998	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.700	millivolts
129999	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
130000	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
130001	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
130002	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
130003	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Follow-up Action Required?	n	
130004	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	General Comments		
130005	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Ground Lights	None	
130006	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
130007	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
130008	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
130009	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
130010	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
130011	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
130012	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
130013	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
130014	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
130015	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
130016	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
130017	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BCH000551	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
130018	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
130019	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
130020	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
130021	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Operations Since Last Insp	0	
130022	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Min Tap Position	3R	
130023	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Max Tap Position	8R	
130024	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Current Tap Position	5R	
130025	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
130026	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Left Counter	90954	
130027	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Found Counter	90954	
130028	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	General Comments	COUNTER NOT WORKING	
130029	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	General Comments		
130030	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Follow-up Action Required?	y	
130031	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
130032	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
130033	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
130034	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130035	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	0	
130036	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
130037	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
130038	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130039	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130040	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	260.0	
130041	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0288	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	230.0	
130042	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
130043	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
130044	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
130045	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
130046	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
130047	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
130048	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	OK	
130049	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
130050	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130051	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130052	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	General Comments		
130053	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	General Comments	OK	
130054	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
130055	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
130056	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
130057	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130058	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130059	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
130060	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
130061	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130062	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130063	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130064	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130065	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130066	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130067	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130068	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
130069	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
130070	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
130071	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
130072	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
130073	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
130074	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
130075	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
130076	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
130077	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B80288	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
130078	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
130079	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
130080	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130081	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
130082	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130083	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
130084	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
130085	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
130086	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
130087	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
130088	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
130089	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
130090	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
130091	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
130092	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
130093	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130094	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
130095	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
130096	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130097	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
130098	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
130099	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
130100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Bushing Condition	Good	
130101	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Unknown Operations	0	
130102	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
130103	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Switching Operations	0	
130104	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
130105	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AL	171	
130106	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AF	171	
130107	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
130108	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Maintenance Operations	0	
130109	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130110	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
130111	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	General Comments		
130112	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
130113	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
130114	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
130115	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
130116	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
130117	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
130118	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
130119	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
130120	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130121	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130122	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Unknown Operations	0	
130123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Switching Operations	0	
130124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations This Read Oil	0	
130125	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AL	1338	
130126	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AF	1338	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130127	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Number of Ops last 9 Months	15	
130128	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Maintenance Operations	0	
130129	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	General Comments		
130130	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Follow-up Action Required?	n	
130131	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Fault Operations	0	
130132	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps C Ø	0.0	
130133	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps B Ø	0.0	
130134	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps A Ø	0.0	
130135	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130136	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
130137	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130138	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130139	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
130140	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
130141	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
130142	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
130143	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
130144	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130145	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	7603.20	kw
130146	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130147	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
130148	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
130149	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
130150	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
130151	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130152	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130153	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130154	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130155	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
130156	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130157	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130158	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
130159	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.5280	
130160	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	75	°C
130161	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	30	°C
130162	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
130163	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	41	°C
130164	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
130165	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
130166	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130167	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
130168	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
130169	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
130170	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
130171	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
130172	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
130173	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
130174	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
130175	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
130176	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
130177	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
130178	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
130179	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
130180	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
130181	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
130182	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
130183	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
130184	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
130185	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	General Comments		
130186	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
130187	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130188	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
130189	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
130190	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
130191	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
130192	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Max	54	°C
130193	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
130194	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130195	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
130196	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130197	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130198	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
130199	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
130200	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130201	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130202	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
130203	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130204	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130205	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130206	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130207	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0054	
130208	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
130209	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130210	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
130211	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
130212	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130213	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130214	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130215	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
130216	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
130217	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130218	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130219	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130220	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
130221	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
130222	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
130223	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
130224	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
130225	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
130226	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130227	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130228	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130229	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130230	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130231	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130232	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130233	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
130234	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps C Ø	455.0	
130235	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps B Ø	476.0	
130236	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps A Ø	448.0	
130237	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130238	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130239	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130240	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations	1	
130241	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Tank Paint Condition	Good	
130242	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Moisture and Leak Free?	y	
130243	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130244	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130245	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130246	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130247	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
130248	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130249	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
130250	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
130251	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130252	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
130253	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
130254	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130255	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	General Comments		
130256	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
130257	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130258	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130259	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
130260	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
130261	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130262	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	441.60	kw
130263	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130264	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
130265	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
130266	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	30	°C
130267	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130268	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	30	°C
130269	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	60	°C
130270	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
130271	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130272	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	7476.00	kw
130273	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130274	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
130275	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
130276	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130277	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
130278	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
130279	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
130280	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
130281	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
130282	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
130283	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
130284	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
130285	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
130286	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
130287	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
130288	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130289	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
130290	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130291	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
130292	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
130293	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130294	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
130295	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130296	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130297	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130298	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130299	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130300	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
130301	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
130302	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
130303	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
130304	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
130305	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130306	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130307	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130308	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130309	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
130310	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130311	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130312	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
130313	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
130314	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
130315	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
130316	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	1.2460	
130317	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
130318	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130319	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130320	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
130321	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130322	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
130323	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
130324	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	374323	
130325	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	374323	
130326	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
130327	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
130328	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
130329	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1189	
130330	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
130331	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130332	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130333	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
130334	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130335	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130336	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130337	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130338	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130339	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130340	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130341	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130342	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
130343	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
130344	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130345	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130346	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130347	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130348	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130349	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
130350	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
130351	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	2	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
130352	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130353	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130354	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130355	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
130356	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130357	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Follow-up Action Required?	n	
130358	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	General Comments		
130359	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
130360	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
130361	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
130362	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130363	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130364	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130365	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130366	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130367	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130368	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130369	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130370	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130371	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
130372	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
130373	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
130374	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
130375	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
130376	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
130377	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
130378	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
130379	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments		
130380	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
130381	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130382	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
130383	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
130384	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	180	
130385	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	180	
130386	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations This Read Vac	0	
130387	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	0	
130388	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
130389	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	
130390	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130391	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130392	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
130393	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
130394	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
130395	10/16/2019 14:01	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
130396	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130397	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130398	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130399	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130400	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
130401	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130402	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130403	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
130404	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.1380	
130405	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
130406	10/16/2019 14:16	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
130407	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
130408	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
130409	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
130410	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
130411	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
130412	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
130413	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
130414	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130415	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130416	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130417	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130418	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
130419	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
130420	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	General Comments		
130421	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
130422	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
130423	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
130424	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
130425	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC0000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
130426	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
130427	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
130428	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
130429	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
130430	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
130431	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
130432	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	68	
130433	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
130434	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
130435	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130436	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130437	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
130438	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	75.0	
130439	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130440	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	1010.40	kw
130441	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130442	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
130443	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	55	°C
130444	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	30	°C
130445	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130446	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130447	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130448	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130449	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130450	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
130451	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130452	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130453	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
130454	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
130455	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
130456	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
130457	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
130458	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
130459	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Oil Level	Good	
130460	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Condition	Good	
130461	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130462	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
130463	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
130464	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130465	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130466	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
130467	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
130468	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
130469	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
130470	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
130471	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
130472	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
130473	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
130474	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	General Comments		
130475	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
130476	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
130477	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
130478	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
130479	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
130480	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1832	
130481	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1832	
130482	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
130483	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130484	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130485	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130486	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130487	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
130488	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
130489	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	30	
130490	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6R	
130491	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Max Tap Position	6R	
130492	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	0	
130493	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130494	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
130495	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
130496	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
130497	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
130498	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
130499	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
130500	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
130501	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130502	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
130503	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
130504	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130505	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130506	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130507	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
130508	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
130509	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
130510	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
130511	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Grounds in Place?	y	
130512	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	General Comments		
130513	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
130514	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
130515	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
130516	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
130517	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
130518	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
130519	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
130520	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
130521	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
130522	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
130523	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
130524	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
130525	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
130526	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments		
130527	10/16/2019 13:41	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
130528	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000091	LTCControl	P-TRANS 4A	LTC Control Insp	Follow-up Action Required?	n	
130529	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000091	LTCControl	P-TRANS 4A	LTC Control Insp	General Comments		
130530	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LTC0000091	LTCControl	P-TRANS 4A	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
130531	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Foundation Condition	Good	
130532	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Follow-up Action Required?	n	
130533	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
130534	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
130535	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130536	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130537	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130538	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130539	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130540	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
130541	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
130542	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
130543	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	
130544	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
130545	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
130546	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
130547	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
130548	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
130549	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
130550	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
130551	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
130552	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130553	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
130554	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130555	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
130556	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
130557	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
130558	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
130559	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
130560	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
130561	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
130562	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
130563	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
130564	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
130565	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
130566	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
130567	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
130568	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
130569	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130570	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
130571	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
130572	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
130573	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
130574	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
130575	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
130576	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130577	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	237	
130578	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5R	
130579	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
130580	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
130581	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
130582	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Unknown Operations	0	
130583	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Switching Operations	1	
130584	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations This Read Vac	1	
130585	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AL	576	
130586	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AF	576	
130587	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Maintenance Operations	0	
130588	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	General Comments		
130589	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5R	
130590	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
130591	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
130592	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
130593	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130594	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130595	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130596	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
130597	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130598	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
130599	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130600	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130601	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130602	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
130603	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130604	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Blades	
130605	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
130606	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
130607	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
130608	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130609	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130610	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	General Comments		
130611	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen and the bottle is empty. Bottom left fan from CCC of fan group 1 is not working	
130612	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130613	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130614	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
130615	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
130616	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
130617	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
130618	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6R	
130619	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
130620	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Left Counter	56559	
130621	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Found Counter	56559	
130622	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
130623	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
130624	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130625	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130626	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
130627	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	General Comments		
130628	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
130629	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
130630	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130631	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130632	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
130633	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130634	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130635	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
130636	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
130637	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
130638	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
130639	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
130640	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
130641	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
130642	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
130643	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
130644	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
130645	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
130646	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Paint Condition	Good	
130647	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	0	
130648	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130649	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130650	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130651	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps A Ø	200.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130652	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps B Ø	214.0	
130653	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps C Ø	205.0	
130654	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushing Condition	Good	
130655	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
130656	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
130657	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
130658	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
130659	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
130660	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	General Comments		
130661	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
130662	10/16/2019 14:28	Distribution	Buchanan Quarterly Inspection	LTC0000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
130663	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130664	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130665	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130666	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130667	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130668	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Unknown Operations	0	
130669	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Tank Paint Condition	Good	
130670	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	5	
130671	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
130672	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations This Read Vac	5	
130673	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	208	
130674	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130675	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130676	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130677	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130678	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AF	208	
130679	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations A Ø	0	
130680	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations B Ø	0	
130681	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Moisture and Leak Free?	y	
130682	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Maintenance Operations	0	
130683	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130684	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Grounds in Place?	y	
130685	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	General Comments		
130686	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	General Comments		
130687	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Foundation Condition	Good	
130688	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Follow-up Action Required?	n	
130689	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Follow-up Action Required?	n	
130690	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations Ground	0	
130691	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations C Ø	0	
130692	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations B Ø	0	
130693	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations A Ø	0	
130694	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130695	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130696	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130697	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130698	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	y	
130699	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
130700	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
130701	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
130702	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130703	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130704	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130705	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	OUT OF SERVICE	
130706	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	OUT OF SERVICE	
130707	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130708	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130709	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
130710	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
130711	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130712	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	0	°C
130713	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	0	°C
130714	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
130715	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
130716	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130717	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130718	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130719	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130720	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
130721	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130722	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130723	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130724	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130725	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130726	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130727	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130728	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
130729	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	General Comments		
130730	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Foundation Condition	Good	
130731	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130732	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
130733	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
130734	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Follow-up Action Required?	n	
130735	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
130736	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
130737	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130739	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
130740	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
130741	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Oil Level	Good	
130742	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	0	°C
130743	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	0	°C
130744	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Grounds in Place?	y	
130745	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
130746	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
130747	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
130748	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Condition	Good	
130749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
130750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Leaks	None	
130751	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
130752	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
130753	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
130754	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
130755	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
130756	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
130757	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
130758	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
130759	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
130760	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
130761	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	
130762	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
130763	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130764	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130765	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130766	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130767	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130768	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130769	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130770	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
130771	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130772	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
130773	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
130774	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
130775	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
130776	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	0	
130777	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations This Read Vac	0	
130778	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	275	
130779	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	275	
130780	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
130781	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	80.0	
130782	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	90.0	
130783	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130784	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130785	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
130786	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130787	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130788	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
130789	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
130790	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
130791	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	161	
130792	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	161	
130793	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations This Read Vac	0	
130794	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130795	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130796	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130797	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
130798	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	0	
130799	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	
130800	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
130801	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
130802	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Leaks	None	
130803	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
130804	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Paint Condition	Good	
130805	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
130806	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
130807	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
130808	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushings Connection/Risers	Good	
130809	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushing Condition	Good	
130810	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps C Ø	5.0	
130811	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments		
130812	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
130813	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
130814	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	All Connections OK?	y	
130815	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
130816	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	General Comments		
130817	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
130818	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps B Ø	10.0	
130819	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps A Ø	10.0	
130820	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
130821	10/16/2019 14:08	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
130822	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations C Ø	0	
130823	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations Ground	0	
130824	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Follow-up Action Required?	n	
130825	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
130826	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130827	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130828	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130829	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	10	
130830	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
130831	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130832	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130833	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	17	
130834	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130835	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130836	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130837	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	90.0	
130838	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
130839	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
130840	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
130841	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
130842	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29617	
130843	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
130844	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
130845	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
130846	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
130847	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
130848	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
130849	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
130850	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
130851	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
130852	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
130853	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
130854	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
130855	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
130856	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
130857	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130858	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
130859	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	300.0	
130860	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130861	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130862	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
130863	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
130864	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130865	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
130866	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
130867	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130868	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130869	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
130870	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
130871	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130872	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
130873	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9040	
130874	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
130875	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
130876	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
130877	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
130878	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
130879	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
130880	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
130881	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
130882	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
130883	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
130884	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
130885	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130886	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
130887	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130888	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
130889	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
130890	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130891	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
130892	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
130893	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
130894	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
130895	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130896	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
130897	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
130898	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
130899	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
130900	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
130901	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
130902	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
130903	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130904	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130905	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130906	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130907	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130908	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130909	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
130910	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
130911	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
130912	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130913	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
130914	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
130915	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
130916	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130917	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
130918	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
130919	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
130920	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
130921	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
130922	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130923	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
130924	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
130925	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130926	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	General Comments		
130927	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
130928	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
130929	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	4838.40	kw
130930	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
130931	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
130932	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
130933	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
130934	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
130935	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	370.0	
130936	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
130937	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
130938	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
130939	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
130940	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	290.0	
130941	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
130942	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
130943	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
130944	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
130945	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
130946	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	47	°C
130947	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	24	°C
130948	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
130949	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
130950	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
130951	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
130952	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
130953	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
130954	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
130955	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
130956	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
130957	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
130958	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
130959	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
130960	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments		
130961	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
130962	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
130963	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	24	°C
130964	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	48	°C
130965	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
130966	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
130967	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	.3360	
130968	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
130969	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	3L	
130970	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
130971	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
130972	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
130973	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	76463	
130974	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.2	volts
130975	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
130976	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
130977	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
130978	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
130979	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
130980	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
130981	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
130982	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	3L	
130983	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	3L	
130984	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
130985	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
130986	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
130987	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
130988	10/16/2019 14:25	Distribution	Danville North Quarterly Inspection	LTC000112	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
130989	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
130990	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
130991	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
130992	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
130993	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
130994	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
130995	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	61	°C
130996	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
130997	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	61	°C
130998	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
130999	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
131000	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
131001	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
131002	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
131003	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	20088	
131004	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	20088	
131005	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
131006	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
131007	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
131008	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
131009	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
131010	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
131011	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
131012	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1373	
131013	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
131014	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
131015	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
131016	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
131017	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
131018	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
131019	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
131020	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
131021	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
131022	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
131023	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
131024	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
131025	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
131026	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
131027	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
131028	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131029	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
131030	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
131031	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	62	°C
131032	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
131033	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
131034	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	492	
131035	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	492	
131036	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
131037	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
131038	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
131039	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
131040	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Left Counter	49879	
131041	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
131042	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
131043	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
131044	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
131045	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
131046	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
131047	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
131048	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
131049	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
131050	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Found Counter	49879	
131051	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
131052	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
131053	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
131054	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
131055	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131056	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
131057	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
131058	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	General Comments		
131059	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	General Comments		
131060	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131061	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
131062	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
131063	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
131064	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations Ground	0	
131065	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
131066	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131067	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
131068	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131069	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
131070	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
131071	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
131072	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
131073	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1684	
131074	10/16/2019 13:40	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
131075	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
131076	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131077	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
131078	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
131079	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131080	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	79.0	
131081	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	60.0	
131082	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131083	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131084	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131085	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
131086	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
131087	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
131088	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131089	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
131090	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
131091	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	58	°C
131092	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
131093	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
131094	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
131095	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131096	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
131097	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131098	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131099	10/17/2019 13:13	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
131100	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	6	
131101	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	7	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131102	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131103	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131104	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131105	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	87.0	
131106	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	88.0	
131107	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	90.0	
131108	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131109	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131110	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131111	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131112	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
131113	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	0	
131114	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
131115	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
131116	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
131117	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	n	
131118	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
131119	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131120	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps C Ø	226.0	
131121	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps B Ø	226.0	
131122	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps A Ø	226.0	
131123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131125	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131126	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations	3	
131127	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
131128	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
131129	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
131130	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
131131	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
131132	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
131133	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
131134	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
131135	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
131136	10/16/2019 10:40	Distribution	Wilson Downing Quarterly Inspection	BB0143	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
131137	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
131138	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	0	
131139	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131140	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131141	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
131142	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131143	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations This Read Vac	0	
131144	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131145	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131146	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
131147	10/16/2019 12:08	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
131148	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131149	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
131150	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131151	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	635	
131152	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
131153	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131154	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
131155	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131156	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
131157	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
131158	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131159	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
131160	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments		
131161	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
131162	10/16/2019 14:48	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	635	
131163	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131164	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131165	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
131166	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
131167	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131168	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
131169	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131170	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
131171	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2892.80	kw
131172	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
131173	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
131174	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
131175	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
131176	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131177	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
131178	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131179	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131180	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
131181	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
131182	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131183	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
131184	10/16/2019 14:28	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
131185	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131186	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131187	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
131188	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131189	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
131190	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131191	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
131192	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131194	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
131195	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
131196	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131197	10/16/2019 12:03	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
131198	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
131199	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131200	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131201	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
131202	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
131203	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131204	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
131205	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.4680	
131206	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131207	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	35	°C
131208	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	40	°C
131209	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	20	°C
131210	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	50	°C
131211	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131212	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
131213	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131214	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
131215	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
131216	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
131217	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	LTC Operation Checked?	y	
131218	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	General Comments		
131219	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	Follow-up Action Required?	n	
131220	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	All Connections OK?	y	
131221	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	6739.20	kw
131222	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
131223	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
131224	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
131225	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131226	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
131227	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
131228	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
131229	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
131230	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
131231	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
131232	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	LTC Operation Checked?	y	
131233	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	General Comments		
131234	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
131235	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCCControl	451-1	LTC Control Insp	All Connections OK?	y	
131236	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131237	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
131238	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
131239	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131240	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
131241	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
131242	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
131243	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
131244	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
131245	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
131246	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		
131247	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
131248	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
131249	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
131250	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
131251	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131252	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
131253	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
131254	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
131255	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
131256	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
131257	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
131258	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
131259	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
131260	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131261	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131262	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131263	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131264	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131265	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131266	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131267	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131268	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131269	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
131270	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
131271	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
131272	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
131273	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
131274	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	LTC000121	LTCControl	451-2	LTC Control Insp	VRR Time Delay	30	Seconds
131275	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
131276	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
131277	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
131278	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A Ø	2	
131279	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
131280	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
131281	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131282	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
131283	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
131284	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131285	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
131286	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
131287	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131288	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
131289	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131290	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	3	
131291	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	6	
131292	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B Ø	0	
131293	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C Ø	0	
131294	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	
131295	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
131296	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
131297	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
131298	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
131299	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
131300	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
131301	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131302	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131303	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131304	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	5.0	
131305	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	5.0	
131306	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	5.0	
131307	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
131308	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
131309	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
131310	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
131311	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
131312	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
131313	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
131314	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
131315	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	2	
131316	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131317	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131318	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131319	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	120.0	
131320	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	130.0	
131321	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	135.0	
131322	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
131323	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131324	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131325	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131326	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131327	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131328	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131329	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
131330	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
131331	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
131332	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	2	
131333	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations This Read Vac	4	
131334	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	217	
131335	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	217	
131336	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
131337	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
131338	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
131339	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
131340	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
131341	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131342	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131343	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131344	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131345	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
131346	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
131347	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
131348	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
131349	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
131350	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
131351	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
131352	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
131353	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
131354	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
131355	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
131356	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
131357	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
131358	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
131359	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
131360	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131361	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131362	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131363	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131364	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131365	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations A Ø	0	
131366	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations B Ø	0	
131367	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations C Ø	0	
131368	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations Ground	0	
131369	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Follow-up Action Required?	n	
131370	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Follow-up Action Required?	n	
131371	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Foundation Condition	Good	
131372	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	General Comments		
131373	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	General Comments		
131374	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
131375	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131376	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
131377	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
131378	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	305	
131379	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	305	
131380	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations This Read Vac	2	
131381	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	2	
131382	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
131383	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
131384	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
131385	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
131386	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
131387	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
131388	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
131389	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
131390	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
131391	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
131392	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
131393	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
131394	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
131395	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
131396	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
131397	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
131398	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
131399	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
131400	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
131401	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
131402	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
131403	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments	BKR OPEB	
131404	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
131405	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
131406	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1690	
131407	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
131408	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131409	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	35	°C
131410	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	54	°C
131411	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
131412	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131413	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	3081.60	kw
131414	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
131415	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
131416	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
131417	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131418	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
131419	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	
131420	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131421	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
131422	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
131423	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131424	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131425	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
131426	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
131427	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
131428	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
131429	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131430	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131431	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
131432	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131433	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131434	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
131435	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
131436	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
131437	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments	mmotor fuse blown. replaced fuse and reg was able to function.	
131438	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
131439	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
131440	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131441	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131442	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
131443	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131444	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131445	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
131446	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
131447	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
131448	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
131449	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
131450	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
131451	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131452	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
131453	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
131454	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
131455	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131456	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	
131457	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
131458	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	234	
131459	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	234	
131460	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	0	
131461	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131462	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	0	
131463	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
131464	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
131465	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
131466	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
131467	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131468	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131469	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131470	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
131471	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
131472	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71735	
131473	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
131474	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
131475	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
131476	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
131477	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.3210	
131478	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
131479	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
131480	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
131481	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
131482	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
131483	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
131484	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
131485	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
131486	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
131487	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
131488	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131489	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
131490	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
131491	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
131492	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
131493	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
131494	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
131495	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131496	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
131497	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
131498	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131499	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131500	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
131501	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131502	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
131503	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
131504	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
131505	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
131506	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
131507	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
131508	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
131509	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
131510	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
131511	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
131512	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131513	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131514	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131515	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131516	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131517	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131518	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131519	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131520	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131521	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
131522	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	190.0	
131523	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	200.0	
131524	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	200.0	
131525	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131526	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131527	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131528	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	5	
131529	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
131530	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
131531	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
131532	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
131533	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
131534	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
131535	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments	dessicant carterage changed. LTC filter changed	
131536	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	103163	
131537	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	103163	
131538	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
131539	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	5L	
131540	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	3L	
131541	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
131542	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	10L	
131543	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	488	
131544	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
131545	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
131546	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
131547	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
131548	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
131549	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	4	
131550	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131551	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131552	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131553	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	150.0	
131554	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	150.0	
131555	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	150.0	
131556	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
131557	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
131558	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	3	
131559	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
131560	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
131561	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131562	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131563	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131564	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131565	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131566	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131567	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131568	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131569	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131570	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
131571	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
131572	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
131573	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
131574	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
131575	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131576	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131577	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131578	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131579	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131580	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131581	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131582	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131583	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131584	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
131585	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
131586	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
131587	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
131588	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
131589	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
131590	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
131591	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131592	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131593	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
131594	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
131595	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
131596	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
131597	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
131598	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
131599	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
131600	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
131601	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
131602	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
131603	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131604	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
131605	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
131606	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	43	
131607	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	43	
131608	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations This Read Vac	0	
131609	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131610	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	243	
131611	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	243	
131612	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	0	
131613	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131614	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	0	
131615	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
131616	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
131617	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
131618	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131619	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
131620	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131621	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
131622	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
131623	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
131624	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
131625	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
131626	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
131627	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
131628	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
131629	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	
131630	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
131631	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
131632	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
131633	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131634	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
131635	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
131636	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	38	
131637	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	38	
131638	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
131639	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131640	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
131641	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
131642	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	5	
131643	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131644	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations This Read Vac	5	
131645	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	197	
131646	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	197	
131647	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
131648	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131649	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
131650	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131651	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
131652	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
131653	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	50	°C
131654	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
131655	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131656	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	139680.00	kw
131657	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
131658	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
131659	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
131660	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131661	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
131662	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
131663	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131664	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	37	
131665	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	57.78	%
131666	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	54.09	%
131667	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	46.71	%
131668	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	85.0	
131669	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	90.0	
131670	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	85.0	
131671	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131672	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
131673	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
131674	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131675	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131676	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
131677	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
131678	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
131679	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
131680	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
131681	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
131682	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
131683	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	338	
131684	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	338	
131685	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
131686	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
131687	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
131688	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
131689	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
131690	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131691	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131692	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
131693	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
131694	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Fault Operations	0	
131695	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
131696	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
131697	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131698	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131699	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131700	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131701	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
131702	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131703	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Follow-up Action Required?	n	
131704	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
131705	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments		
131706	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	General Comments		
131707	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131708	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
131709	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
131710	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
131711	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Maintenance Operations	0	
131712	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
131713	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Number of Ops last 9 Months	1	
131714	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AF	2769	
131715	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AL	2769	
131716	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations This Read Oil	0	
131717	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Switching Operations	0	
131718	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
131719	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
131720	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
131721	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Unknown Operations	0	
131722	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
131723	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
131724	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
131725	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
131726	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
131727	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
131728	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131729	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
131730	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
131731	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
131732	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
131733	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
131734	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
131735	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
131736	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	441	
131737	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	441	
131738	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	0	
131739	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
131740	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	0	
131741	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
131742	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
131743	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
131744	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
131745	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131746	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131747	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
131748	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
131749	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
131750	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
131751	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131752	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
131753	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
131754	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131755	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
131756	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
131757	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131758	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
131759	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
131760	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
131761	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	12589.20	kw
131762	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
131763	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
131764	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	110	°C
131765	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	50	°C
131766	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131767	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
131768	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131769	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131770	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
131771	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
131772	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131773	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
131774	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
131775	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	201	
131776	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131777	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
131778	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.6994	
131779	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
131780	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
131781	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
131782	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
131783	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	93991	
131784	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
131785	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
131786	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
131787	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
131788	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
131789	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
131790	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	50	°C
131791	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.5820	
131792	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	240000	
131793	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131794	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
131795	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
131796	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131797	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
131798	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
131799	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
131800	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	0	
131801	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	358	
131802	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	358	
131803	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations This Read AM	0	
131804	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
131805	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	
131806	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4254	
131807	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	2	
131808	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131809	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131810	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131811	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
131812	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
131813	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
131814	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
131815	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
131816	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
131817	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
131818	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
131819	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
131820	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
131821	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
131822	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
131823	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
131824	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
131825	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
131826	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
131827	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
131828	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
131829	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
131830	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
131831	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
131832	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
131833	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
131834	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
131835	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	211	
131836	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	211	
131837	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
131838	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
131839	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131840	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
131841	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
131842	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
131843	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
131844	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
131845	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
131846	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
131847	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
131848	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
131849	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
131850	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131851	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131852	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
131853	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	General Comments		
131854	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	General Comments		
131855	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Found Counter	257546	
131856	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Left Counter	257546	
131857	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
131858	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Current Tap Position	6L	
131859	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
131860	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Min Tap Position	11L	
131861	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
131862	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Operations Since Last Insp	221	
131863	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
131864	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
131865	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
131866	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
131867	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
131868	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
131869	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
131870	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
131871	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
131872	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
131873	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
131874	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
131875	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
131876	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
131877	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
131878	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	0	
131879	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
131880	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	13.52	%
131881	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	11.06	%
131882	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	85.0	
131883	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	80.0	
131884	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	75.0	
131885	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131886	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131887	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131888	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
131889	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
131890	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
131891	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
131892	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
131893	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
131894	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
131895	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	157	
131896	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	157	
131897	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
131898	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
131899	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
131900	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
131901	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
131902	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
131903	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
131904	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	0	
131905	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	
131906	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
131907	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
131908	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
131909	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
131910	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
131911	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	7	
131912	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
131913	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
131914	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
131915	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	150.0	
131916	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	300.0	
131917	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	270.0	
131918	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
131919	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
131920	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
131921	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
131922	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
131923	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
131924	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds In Place?	y	
131925	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
131926	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
131927	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	510.48	kw
131928	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
131929	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
131930	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
131931	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
131932	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
131933	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
131934	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
131935	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
131936	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
131937	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
131938	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
131939	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
131940	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
131941	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
131942	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
131943	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	
131944	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
131945	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
131946	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
131947	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3722	
131948	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131949	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131950	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131951	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131952	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131953	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131954	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131955	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131956	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
131957	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
131958	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
131959	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
131960	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	158	
131961	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	158	
131962	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	0	
131963	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	0	
131964	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
131965	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
131966	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
131967	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
131968	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
131969	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
131970	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
131971	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
131972	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
131973	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
131974	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
131975	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
131976	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
131977	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
131978	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
131979	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
131980	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
131981	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
131982	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
131983	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
131984	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
131985	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
131986	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
131987	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
131988	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
131989	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
131990	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
131991	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
131992	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
131993	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	General Comments		
131994	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
131995	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
131996	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
131997	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK00031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
131998	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
131999	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	0	
132000	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132001	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132002	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132003	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	180.0	
132004	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	170.0	
132005	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	170.0	
132006	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
132007	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132008	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132009	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132010	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132011	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132012	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132013	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132014	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132015	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132016	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132017	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
132018	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
132019	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
132020	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
132021	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
132022	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
132023	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
132024	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
132025	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
132026	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
132027	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
132028	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
132029	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
132030	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
132031	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
132032	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
132033	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	1	
132034	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132035	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
132036	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
132037	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132038	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
132039	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
132040	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132041	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132042	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	185.0	
132043	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	185.0	
132044	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	160.0	
132045	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
132046	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132047	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
132048	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
132049	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	LTC0000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
132050	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132051	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132052	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132053	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132054	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132055	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
132056	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
132057	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132058	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
132059	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
132060	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132061	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
132062	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments		
132063	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
132064	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132065	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
132066	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
132067	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1646.64	kw
132068	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
132069	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
132070	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
132071	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
132072	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132073	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
132074	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132075	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
132076	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
132077	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132078	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132079	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132080	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132081	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
132082	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
132083	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
132084	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
132085	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
132086	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
132087	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
132088	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
132089	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
132090	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
132091	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
132092	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
132093	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
132094	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132095	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
132096	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	24	
132097	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	24	
132098	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Readings	Operations This Read Vac	14	
132099	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132100	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	4	
132101	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
132102	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	M80175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	
132103	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
132104	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
132105	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	0	
132106	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132107	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	0	
132108	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	371	
132109	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	371	
132110	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
132111	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
132112	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132113	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
132114	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
132115	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
132116	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
132117	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	0	
132118	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
132119	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
132120	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
132121	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
132122	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
132123	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
132124	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
132125	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132126	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
132127	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
132128	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
132129	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	
132130	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
132131	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
132132	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
132133	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
132134	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
132135	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
132136	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132137	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132138	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132139	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132140	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132141	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132142	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132143	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132144	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132145	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
132146	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
132147	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
132148	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132149	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
132150	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
132151	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
132152	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
132153	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132154	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132155	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
132156	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
132157	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132158	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
132159	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
132160	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132161	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
132162	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	5.0	
132163	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
132164	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
132165	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	7027.20	kw
132166	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132167	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
132168	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132169	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
132170	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
132171	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
132172	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
132173	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
132174	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
132175	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
132176	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132177	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
132178	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
132179	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	2	
132180	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations This Read Vac	2	
132181	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	170	
132182	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
132183	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
132184	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132185	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
132186	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
132187	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132188	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
132189	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132190	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
132191	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
132192	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
132193	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132194	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	-60	°C
132195	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	-60	°C
132196	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
132197	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
132198	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
132199	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132200	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
132201	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
132202	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132203	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
132204	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
132205	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132206	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132207	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
132208	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
132209	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
132210	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
132211	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	170	
132212	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
132213	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
132214	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	16	
132215	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132216	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132217	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132218	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	100.0	
132219	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	80.0	
132220	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	80.0	
132221	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
132222	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132223	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132224	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132225	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132226	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132227	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132228	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132229	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132230	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132231	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
132232	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
132233	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
132234	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
132235	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	
132236	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
132237	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
132238	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
132239	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	counter has been changed out		
132240	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
132241	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132242	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	10	
132243	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	6	
132244	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	0	
132245	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	7.99	%
132246	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	7.99	%
132247	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	7.38	%
132248	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	120.0	
132249	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	120.0	
132250	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	120.0	
132251	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132252	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
132253	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132254	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132255	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
132256	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
132257	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
132258	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
132259	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Found Counter	24362	
132260	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
132261	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	General Comments		
132262	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
132263	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
132264	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
132265	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
132266	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
132267	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	166	
132268	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	166	
132269	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
132270	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
132271	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
132272	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
132273	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	0	
132274	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132275	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	0	
132276	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	173	
132277	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	176	
132278	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
132279	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	0	
132280	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132281	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
132282	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
132283	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
132284	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.4810	
132285	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
132286	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132287	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
132288	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
132289	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
132290	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132291	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
132292	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132293	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	50	°C
132294	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	50	°C
132295	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
132296	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132297	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	8658.00	kw
132298	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
132299	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
132300	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		
132301	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132302	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
132303	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
132304	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132305	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
132306	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
132307	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
132308	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
132309	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
132310	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
132311	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
132312	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
132313	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
132314	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
132315	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132316	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132317	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
132318	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132319	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
132320	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
132321	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
132322	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	5.0	
132323	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	5.0	
132324	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132325	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132326	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132327	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	7	
132328	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132329	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Max	39	°C
132330	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Top Oil Temperature Present	39	°C
132331	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
132332	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.7320	
132333	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
132334	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
132335	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
132336	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
132337	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	66	
132338	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
132339	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments		
132340	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
132341	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
132342	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
132343	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
132344	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
132345	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
132346	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
132347	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
132348	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
132349	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
132350	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
132351	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
132352	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments		
132353	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
132354	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
132355	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
132356	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	7	
132357	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
132358	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
132359	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
132360	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
132361	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	600	
132362	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
132363	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
132364	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
132365	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
132366	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
132367	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16L	
132368	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
132369	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
132370	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Left Counter	24362	
132371	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.0	
132372	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
132373	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
132374	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	205	
132375	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
132376	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132377	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132378	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132379	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132380	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132381	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132382	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132383	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132384	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132385	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
132386	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	150.0	
132387	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	150.0	
132388	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	120.0	
132389	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132390	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132391	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132392	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
132393	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
132394	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132395	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
132396	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
132397	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132398	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
132399	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
132400	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132401	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132402	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
132403	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
132404	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
132405	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
132406	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132407	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
132408	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
132409	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
132410	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
132411	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
132412	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
132413	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132414	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
132415	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
132416	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	696	
132417	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	696	
132418	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
132419	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132420	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
132421	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
132422	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
132423	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
132424	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
132425	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
132426	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
132427	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
132428	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
132429	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
132430	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
132431	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	2	
132432	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132433	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132434	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
132435	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132436	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132437	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132438	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
132439	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
132440	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
132441	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
132442	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132443	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132444	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132445	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132446	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132447	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132448	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132449	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132450	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132451	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
132452	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
132453	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132454	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
132455	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
132456	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
132457	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132458	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
132459	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132460	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
132461	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
132462	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Present	48	°C
132463	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
132464	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
132465	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
132466	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
132467	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
132468	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3830	
132469	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
132470	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132471	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
132472	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
132473	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
132474	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132475	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
132476	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
132477	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments		
132478	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
132479	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
132480	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
132481	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
132482	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
132483	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
132484	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	101157	
132485	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	101157	
132486	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
132487	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
132488	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	599	
132489	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
132490	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
132491	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
132492	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
132493	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
132494	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
132495	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
132496	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
132497	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
132498	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
132499	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
132500	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
132501	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
132502	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
132503	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
132504	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
132505	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
132506	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
132507	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
132508	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
132509	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132510	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132511	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132512	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
132513	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
132514	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
132515	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
132516	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132517	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132518	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132519	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132520	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132521	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132522	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132523	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132524	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132525	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
132526	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
132527	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
132528	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
132529	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
132530	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
132531	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
132532	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	17	°C
132533	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	37	°C
132534	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
132535	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
132536	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3676.80	kw
132537	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
132538	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
132539	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132540	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
132541	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	420	
132542	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	420	
132543	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
132544	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
132545	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
132546	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
132547	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132548	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	70.0	
132549	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	80.0	
132550	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	60.0	
132551	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
132552	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132553	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132554	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132555	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132556	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132557	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132558	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132559	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132560	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132561	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
132562	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
132563	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
132564	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
132565	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
132566	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
132567	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
132568	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
132569	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
132570	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
132571	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
132572	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
132573	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
132574	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
132575	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
132576	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
132577	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
132578	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
132579	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
132580	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6842	
132581	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
132582	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
132583	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
132584	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
132585	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
132586	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
132587	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
132588	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
132589	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
132590	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
132591	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
132592	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
132593	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
132594	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
132595	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
132596	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
132597	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
132598	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
132599	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
132600	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
132601	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132602	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
132603	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
132604	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	243	
132605	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	243	
132606	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	0	
132607	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
132608	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
132609	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
132610	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
132611	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
132612	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
132613	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
132614	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
132615	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
132616	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
132617	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
132618	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
132619	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
132620	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
132621	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
132622	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
132623	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132624	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
132625	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
132626	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
132627	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132628	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	48	°C
132629	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	62	°C
132630	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
132631	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NIT	
132632	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	General Comments		
132633	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132634	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
132635	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
132636	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
132637	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
132638	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
132639	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132640	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132641	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
132642	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
132643	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
132644	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
132645	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6553	
132646	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
132647	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
132648	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
132649	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
132650	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
132651	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
132652	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
132653	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
132654	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
132655	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
132656	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
132657	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
132658	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
132659	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
132660	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
132661	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
132662	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
132663	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
132664	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
132665	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
132666	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
132667	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
132668	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
132669	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5218	
132670	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
132671	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
132672	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
132673	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
132674	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
132675	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
132676	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	4L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132677	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
132678	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		
132679	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
132680	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
132681	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
132682	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
132683	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
132684	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
132685	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
132686	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
132687	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132688	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
132689	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
132690	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
132691	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132692	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
132693	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
132694	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	268	
132695	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	268	
132696	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	0	
132697	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132698	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	0	
132699	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
132700	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
132701	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
132702	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
132703	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
132704	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
132705	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
132706	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
132707	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
132708	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
132709	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
132710	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
132711	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
132712	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	7957.44	kw
132713	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
132714	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
132715	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	650	psi
132716	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	30	°C
132717	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	30	°C
132718	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
132719	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
132720	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
132721	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
132722	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
132723	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
132724	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
132725	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
132726	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	.5526	
132727	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	40	°C
132728	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	35	°C
132729	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
132730	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
132731	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
132732	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
132733	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
132734	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132735	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
132736	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
132737	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
132738	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
132739	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
132740	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
132741	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
132742	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
132743	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
132744	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments		
132745	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
132746	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
132747	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
132748	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
132749	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
132750	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
132751	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132752	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
132753	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
132754	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	4	
132755	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132756	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations This Read Vac	9	
132757	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	230	
132758	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	230	
132759	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
132760	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	0	
132761	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132762	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	
132763	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments		
132764	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132765	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132766	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132767	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132768	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132769	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132770	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132771	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132772	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132773	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
132774	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	60.0	
132775	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	70.0	
132776	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	80.0	
132777	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	2	
132778	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132779	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132780	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132781	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
132782	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
132783	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
132784	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
132785	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132786	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132787	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132788	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132789	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132790	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132791	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132792	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132793	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132794	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132795	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132796	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	9	
132797	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
132798	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
132799	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
132800	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
132801	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
132802	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
132803	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	2	
132804	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	33.8	%
132805	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	34.42	%
132806	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	31.96	%
132807	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	150.0	
132808	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132809	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
132810	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
132811	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	140.0	
132812	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	145.0	
132813	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
132814	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
132815	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
132816	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
132817	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
132818	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
132819	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132820	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
132821	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
132822	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
132823	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
132824	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
132825	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
132826	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132827	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
132828	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
132829	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48931	
132830	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
132831	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
132832	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
132833	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
132834	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
132835	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
132836	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
132837	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
132838	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		
132839	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
132840	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
132841	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
132842	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
132843	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
132844	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
132845	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
132846	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
132847	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
132848	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
132849	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
132850	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
132851	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	2	
132852	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
132853	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	31985	
132854	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	31985	
132855	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
132856	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
132857	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
132858	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
132859	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	1	
132860	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
132861	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations This Read Vac	1	
132862	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	219	
132863	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	219	
132864	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
132865	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	0	
132866	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
132867	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
132868	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
132869	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
132870	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
132871	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
132872	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
132873	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
132874	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
132875	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
132876	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	618	
132877	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	10L	
132878	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	2L	
132879	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	2L	
132880	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
132881	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	67763	
132882	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	67763	
132883	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
132884	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments		
132885	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
132886	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
132887	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
132888	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
132889	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
132890	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
132891	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
132892	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
132893	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
132894	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
132895	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
132896	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
132897	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations	10	
132898	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132899	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132900	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132901	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps A Ø	310.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
132902	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps B Ø	330.0	
132903	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	320.0	
132904	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
132905	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132906	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132907	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132908	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132909	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132910	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132911	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
132912	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
132913	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
132914	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
132915	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	252	
132916	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	9L	
132917	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	3L	
132918	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	5L	
132919	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
132920	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
132921	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	3	
132922	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	1	
132923	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	1	
132924	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	14.43	
132925	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
132926	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
132927	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132928	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
132929	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
132930	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
132931	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
132932	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
132933	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
132934	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	100.0	
132935	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	140.0	
132936	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	140.0	
132937	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
132938	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
132939	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
132940	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
132941	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	55000	
132942	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
132943	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
132944	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
132945	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
132946	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
132947	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	16	
132948	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
132949	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
132950	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
132951	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
132952	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
132953	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
132954	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
132955	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
132956	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments		
132957	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
132958	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	247	
132959	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	247	
132960	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	2	
132961	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
132962	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
132963	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
132964	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
132965	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
132966	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
132967	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
132968	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
132969	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC000454	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
132970	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
132971	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
132972	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
132973	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
132974	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
132975	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
132976	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
132977	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
132978	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
132979	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
132980	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
132981	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
132982	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
132983	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
132984	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
132985	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
132986	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
132987	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
132988	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
132989	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
132990	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
132991	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
132992	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
132993	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
132994	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
132995	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
132996	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
132997	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
132998	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
132999	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
133000	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
133001	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
133002	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
133003	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
133004	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
133005	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
133006	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
133007	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
133008	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
133009	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
133010	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
133011	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
133012	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
133013	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
133014	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
133015	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
133016	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
133017	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
133018	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
133019	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
133020	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
133021	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
133022	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
133023	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	9360.00	kw
133024	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
133025	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
133026	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	0	
133027	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	0	
133028	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
133029	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
133030	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
133031	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
133032	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
133033	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
133034	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
133035	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133036	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
133037	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
133038	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	333	
133039	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	333	
133040	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations This Read Vac	4	
133041	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133042	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	4	
133043	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
133044	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
133045	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
133046	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
133047	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
133048	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
133049	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
133050	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
133051	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133052	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
133053	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
133054	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
133055	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
133056	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
133057	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
133058	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
133059	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
133060	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
133061	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133062	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133063	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133064	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133065	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133066	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
133067	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
133068	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
133069	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
133070	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
133071	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
133072	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
133073	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
133074	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
133075	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
133076	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
133077	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
133078	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
133079	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
133080	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
133081	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1265	
133082	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1265	
133083	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
133084	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
133085	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
133086	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
133087	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
133088	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	General Comments		
133089	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
133090	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
133091	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
133092	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
133093	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
133094	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
133095	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
133096	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
133097	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133098	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133099	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
133100	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
133101	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
133102	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
133103	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
133104	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
133105	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BB0064	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
133106	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
133107	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133108	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133109	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
133110	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	190.0	
133111	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	200.0	
133112	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	200.0	
133113	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133114	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133115	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133116	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	0	
133117	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
133118	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
133119	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
133120	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
133121	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
133122	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
133123	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	8	
133124	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133125	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133126	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133127	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	20.0	
133128	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	20.0	
133129	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	20.0	
133130	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
133131	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133132	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133133	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133134	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133135	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133136	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
133137	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
133138	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
133139	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
133140	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	0	
133141	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133142	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	0	
133143	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	450	
133144	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
133145	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	422	
133146	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	422	
133147	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
133148	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	450	
133149	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
133150	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
133151	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133152	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
133153	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
133154	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
133155	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
133156	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
133157	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
133158	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
133159	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
133160	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133161	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133162	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133163	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133164	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133165	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133166	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133167	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133168	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133169	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
133170	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	50.0	
133171	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	60.0	
133172	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	50.0	
133173	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133174	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133175	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133176	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	4	
133177	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
133178	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
133179	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133180	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133181	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133182	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133183	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133184	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133185	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
133186	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
133187	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
133188	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
133189	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
133190	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133191	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133192	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133193	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
133194	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	310.0	
133195	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	310.0	
133196	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	320.0	
133197	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133198	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133199	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133200	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
133201	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133202	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
133203	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
133204	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
133205	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
133206	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
133207	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
133208	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
133209	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	0	
133210	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133211	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133212	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	50	°C
133213	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	20	°C
133214	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
133215	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
133216	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
133217	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
133218	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
133219	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
133220	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
133221	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
133222	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.9750	
133223	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
133224	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
133225	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
133226	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.85	%
133227	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.85	%
133228	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.85	%
133229	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
133230	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
133231	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
133232	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
133233	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
133234	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
133235	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
133236	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
133237	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
133238	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	4	
133239	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133240	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations This Read Vac	4	
133241	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
133242	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
133243	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
133244	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
133245	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	545	
133246	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	545	
133247	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
133248	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
133249	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
133250	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
133251	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
133252	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
133253	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
133254	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
133255	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	General Comments		
133256	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
133257	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
133258	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
133259	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
133260	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
133261	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
133262	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	0	
133263	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133264	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
133265	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	0	
133266	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	385	
133267	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	385	
133268	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
133269	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
133270	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133271	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
133272	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
133273	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
133274	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
133275	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
133276	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133277	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
133278	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
133279	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
133280	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
133281	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	150	
133282	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	150	
133283	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
133284	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
133285	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
133286	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
133287	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
133288	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
133289	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
133290	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	97871	
133291	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	97871	
133292	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
133293	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	2L	
133294	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	1R	
133295	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	8L	
133296	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	3489	
133297	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
133298	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
133299	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
133300	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
133301	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
133302	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
133303	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
133304	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
133305	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
133306	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
133307	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
133308	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
133309	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
133310	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
133311	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
133312	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133313	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations This Read AM	0	
133314	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	544	
133315	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	544	
133316	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
133317	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
133318	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
133319	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
133320	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
133321	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
133322	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
133323	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
133324	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
133325	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
133326	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
133327	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
133328	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
133329	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
133330	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	230.0	
133331	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	325.0	
133332	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	130.0	
133333	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
133334	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133335	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133336	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133337	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133338	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133339	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
133340	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
133341	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
133342	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133343	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
133344	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	5.0	
133345	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	5.0	
133346	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	5.0	
133347	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133348	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
133349	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
133350	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
133351	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133352	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
133353	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
133354	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
133355	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
133356	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
133357	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	4806.00	kw
133358	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
133359	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
133360	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	53	°C
133361	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	35	°C
133362	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
133363	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
133364	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
133365	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133366	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133367	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
133368	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
133369	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	0	
133370	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
133371	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
133372	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
133373	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
133374	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
133375	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
133376	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	
133377	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
133378	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
133379	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
133380	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	
133381	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
133382	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	184	
133383	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	184	
133384	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations This Read Vac	2	
133385	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	2	
133386	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
133387	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
133388	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	
133389	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
133390	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	4	
133391	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133392	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Operations This Read Vac	4	
133393	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	148	
133394	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	148	
133395	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
133396	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
133397	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133398	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
133399	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
133400	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.2670	
133401	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	47	°C
133402	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	25	°C
133403	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
133404	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
133405	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps A Ø	252.0	
133406	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133407	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133408	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133409	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	9 Month Operations	11	
133410	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
133411	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
133412	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
133413	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
133414	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
133415	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
133416	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
133417	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
133418	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
133419	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
133420	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
133421	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
133422	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
133423	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133424	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133425	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
133426	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
133427	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
133428	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
133429	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
133430	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
133431	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
133432	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
133433	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
133434	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
133435	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
133436	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
133437	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
133438	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
133439	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
133440	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
133441	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
133442	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
133443	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
133444	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
133445	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
133446	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
133447	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
133448	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
133449	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
133450	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
133451	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
133452	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
133453	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
133454	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
133455	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
133456	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
133457	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
133458	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
133459	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
133460	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
133461	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
133462	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
133463	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
133464	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
133465	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
133466	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
133467	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
133468	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
133469	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
133470	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
133471	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
133472	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
133473	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
133474	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
133475	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
133476	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
133477	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
133478	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
133479	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
133480	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
133481	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
133482	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
133483	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
133484	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
133485	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
133486	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
133487	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
133488	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
133489	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
133490	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
133491	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
133492	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
133493	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	82373	
133494	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
133495	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
133496	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
133497	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
133498	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
133499	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
133500	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
133501	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
133502	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
133503	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
133504	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
133505	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
133506	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
133507	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133508	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	8	
133509	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Tank Paint Condition	Good	
133510	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	4	
133511	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133512	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations This Read Vac	4	
133513	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	160	
133514	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	160	
133515	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
133516	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
133517	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133518	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
133519	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
133520	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
133521	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
133522	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
133523	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
133524	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
133525	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
133526	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
133527	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
133528	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
133529	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
133530	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
133531	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
133532	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	
133533	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
133534	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
133535	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
133536	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
133537	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
133538	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133539	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133540	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133541	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133542	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133543	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133544	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133545	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133546	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133547	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
133548	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
133549	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	6	
133550	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
133551	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	90.0	
133552	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	80.0	
133553	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	80.0	
133554	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133555	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133556	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133557	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	8	
133558	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
133559	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
133560	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
133561	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
133562	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
133563	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
133564	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
133565	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
133566	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
133567	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
133568	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CV-1486	VCB Readings	Amps C Ø	190.0	
133569	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Tank Paint Condition	Good	
133570	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Switching Operations	0	
133571	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133572	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations This Read Vac	0	
133573	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AL	322	
133574	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AF	322	
133575	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Moisture and Leak Free?	y	
133576	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133577	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133578	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Grounds in Place?	y	
133579	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	General Comments		
133580	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	General Comments		
133581	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Foundation Condition	Good	
133582	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Follow-up Action Required?	n	
133583	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Follow-up Action Required?	n	
133584	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations Ground	0	
133585	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	190.0	
133586	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	190.0	
133587	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	29.5	%
133588	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	35.03	%
133589	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	35.65	%
133590	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations C Ø	0	
133591	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations B Ø	0	
133592	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations A Ø	0	
133593	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133594	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133595	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	3	
133596	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
133597	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
133598	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
133599	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	27.0	VDC
133600	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
133601	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
133602	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
133603	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
133604	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
133605	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
133606	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
133607	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
133608	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
133609	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
133610	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
133611	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
133612	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
133613	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133614	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133615	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133616	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133617	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133618	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133619	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133620	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133621	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133622	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
133623	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133624	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133625	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133626	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133627	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133628	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133629	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133630	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushing Condition	Good	
133631	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps C Ø	241.0	
133632	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps B Ø	256.0	
133633	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
133634	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
133635	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
133636	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	20.0	
133637	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	35.0	
133638	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	35.0	
133639	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
133640	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
133641	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
133642	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
133643	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
133644	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
133645	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
133646	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
133647	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
133648	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
133649	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
133650	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
133651	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133652	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	0	
133653	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	172	
133654	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	172	
133655	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
133656	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
133657	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	
133658	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
133659	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
133660	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
133661	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
133662	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133663	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133664	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133665	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	75.0	
133666	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	70.0	
133667	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
133668	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
133669	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	80.0	
133670	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	14.75	%
133671	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	15.37	%
133672	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	17.21	%
133673	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	6	
133674	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
133675	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
133676	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	0	
133677	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
133678	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	0	
133679	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	348	
133680	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	348	
133681	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
133682	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
133683	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	
133684	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
133685	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
133686	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	3	
133687	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	357	
133688	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	357	
133689	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
133690	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
133691	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
133692	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
133693	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
133694	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
133695	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133696	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133697	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133698	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations	43	
133699	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Unknown Operations	0	
133700	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
133701	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BCH000603	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
133702	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
133703	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	3	
133704	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
133705	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
133706	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
133707	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	24.00	
133708	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	24.00	
133709	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	24.00	
133710	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	
133711	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133712	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133713	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133714	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133715	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133716	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133717	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
133718	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133719	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
133720	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
133721	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
133722	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
133723	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
133724	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
133725	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
133726	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133727	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
133728	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
133729	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
133730	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
133731	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
133732	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	*C
133733	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
133734	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
133735	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	*C
133736	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	*C
133737	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
133738	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
133739	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
133740	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
133741	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
133742	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
133743	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
133744	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	13132.80	kw
133745	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
133746	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
133747	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	40	*C
133748	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	20	*C
133749	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
133750	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
133751	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
133752	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
133753	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
133754	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
133755	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
133756	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
133757	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
133758	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.9120	
133759	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	70	*C
133760	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	70	*C
133761	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
133762	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
133763	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
133764	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
133765	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
133766	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
133767	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
133768	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
133769	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
133770	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
133771	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
133772	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
133773	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
133774	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
133775	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
133776	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
133777	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
133778	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
133779	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
133780	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
133781	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133782	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133783	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133784	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	4	
133785	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
133786	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
133787	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	n	
133788	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
133789	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
133790	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
133791	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
133792	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
133793	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
133794	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
133795	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
133796	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
133797	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
133798	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
133799	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
133800	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
133801	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133802	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
133803	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
133804	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
133805	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
133806	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
133807	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
133808	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
133809	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
133810	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	3	
133811	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133812	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133813	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133814	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	100.0	
133815	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	90.0	
133816	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	90.0	
133817	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
133818	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133819	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133820	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133821	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133822	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133823	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133824	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
133825	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133826	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133827	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	0	
133828	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
133829	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
133830	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
133831	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
133832	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
133833	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
133834	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
133835	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
133836	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
133837	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
133838	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
133839	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	188	
133840	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	188	
133841	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations This Read Vac	1	
133842	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	1	
133843	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
133844	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
133845	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	10	
133846	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133847	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133848	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133849	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	20.0	
133850	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	15.0	
133851	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	15.0	
133852	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
133853	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
133854	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
133855	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
133856	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
133857	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
133858	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
133859	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
133860	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
133861	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-5	psi
133862	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	610	
133863	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
133864	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
133865	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
133866	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
133867	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
133868	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
133869	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
133870	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	74	*F
133871	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
133872	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
133873	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
133874	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AL	170	
133875	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AF	170	
133876	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
133877	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Maintenance Operations	0	
133878	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Grounds in Place?	y	
133879	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	General Comments		
133880	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	General Comments		
133881	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Foundation Condition	Good	
133882	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Follow-up Action Required?	n	
133883	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Follow-up Action Required?	n	
133884	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations Ground	0	
133885	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations C Ø	0	
133886	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
133887	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
133888	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
133889	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
133890	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
133891	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
133892	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
133893	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
133894	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
133895	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
133896	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
133897	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations B Ø	0	
133898	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations A Ø	3	
133899	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
133900	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BAT000600	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
133901	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
133902	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
133903	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps A Phase V	15.20	
133904	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
133905	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
133906	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
133907	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
133908	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
133909	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
133910	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushing Condition	Good	
133911	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps C Ø	16.0	
133912	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps B Ø	14.0	
133913	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps A Ø	14.0	
133914	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
133915	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
133916	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
133917	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	9 Month Operations	4	
133918	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	5.0	
133919	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	5.0	
133920	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	5.0	
133921	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
133922	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
133923	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	28	*C
133924	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
133925	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
133926	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
133927	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
133928	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
133929	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
133930	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
133931	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
133932	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
133933	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
133934	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
133935	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
133936	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
133937	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
133938	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
133939	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
133940	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
133941	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
133942	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
133943	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
133944	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
133945	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
133946	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
133947	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
133948	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
133949	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	General Comments		
133950	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
133951	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	70	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
133952	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	43	°C
133953	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
133954	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
133955	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
133956	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
133957	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
133958	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
133959	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
133960	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
133961	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
133962	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
133963	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	260.00	
133964	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WLTG Bushing Dynamic Health	0.00	
133965	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Unknown Operations	0	
133966	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Tank Paint Condition	Good	
133967	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Switching Operations	0	
133968	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations This Read Vac	3	
133969	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
133970	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
133971	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
133972	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
133973	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	12528	
133974	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	12528	
133975	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
133976	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	6L	
133977	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	5L	
133978	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	15L	
133979	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
133980	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	844	
133981	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
133982	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
133983	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
133984	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
133985	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
133986	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
133987	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
133988	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	151256	
133989	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	151256	
133990	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
133991	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	4L	
133992	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
133993	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	8L	
133994	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
133995	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
133996	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
133997	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
133998	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
133999	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
134000	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
134001	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
134002	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
134003	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
134004	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
134005	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
134006	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
134007	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
134008	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
134009	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
134010	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
134011	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
134012	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
134013	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
134014	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
134015	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
134016	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	9	
134017	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	All Connections OK?	y	
134018	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	Follow-up Action Required?	n	
134019	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	General Comments		
134020	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	LTC Operation Checked?	y	
134021	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
134022	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
134023	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
134024	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	LTC000857	LTCControl	176-5	LTC Control Insp	VRR Time Delay	30	Seconds
134025	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
134026	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
134027	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	0	
134028	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134029	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	3	
134030	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	90470	
134031	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	90470	
134032	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
134033	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
134034	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134035	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
134036	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
134037	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
134038	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
134039	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
134040	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
134041	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
134042	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	1	
134043	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	1	
134044	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	1	
134045	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
134046	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
134047	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
134048	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134049	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134050	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134051	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134052	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134053	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134054	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
134055	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
134056	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
134057	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
134058	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
134059	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	100.0	
134060	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	100.0	
134061	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134062	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134063	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134064	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	100.0	
134065	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
134066	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
134067	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134068	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134069	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
134070	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
134071	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
134072	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
134073	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
134074	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
134075	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
134076	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
134077	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	General Comments		
134078	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
134079	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
134080	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
134081	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
134082	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	24	
134083	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2230	
134084	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2230	
134085	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
134086	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
134087	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
134088	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
134089	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
134090	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	CB0004	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
134091	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
134092	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	9 Months Operations	8	
134093	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
134094	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
134095	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
134096	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps A Ø	150.0	
134097	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps B Ø	100.0	
134098	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps C Ø	100.0	
134099	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
134100	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
134101	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134102	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
134103	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations A Ø	0	
134104	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations B Ø	0	
134105	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations C Ø	0	
134106	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations Ground	0	
134107	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
134108	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Follow-up Action Required?	n	
134109	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	General Comments		
134110	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	General Comments		
134111	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
134112	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Maintenance Operations	0	
134113	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AF	453	
134114	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AL	453	
134115	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations This Read AM	0	
134116	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Switching Operations	0	
134117	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Unknown Operations	0	
134118	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
134119	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
134120	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
134121	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
134122	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
134123	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
134124	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
134125	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
134126	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	LTC000298	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
134127	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
134128	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
134129	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
134130	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
134131	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
134132	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
134133	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
134134	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
134135	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	LTC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
134136	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134137	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
134138	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
134139	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
134140	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
134141	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
134142	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
134143	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
134144	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
134145	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
134146	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
134147	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134148	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134149	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134150	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134151	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134152	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134153	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134154	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134155	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134156	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
134157	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
134158	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
134159	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
134160	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134161	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134162	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134163	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
134164	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
134165	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	818	
134166	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	818	
134167	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
134168	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134169	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
134170	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
134171	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
134172	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
134173	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
134174	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134175	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
134176	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134177	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	501	
134178	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	501	
134179	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	9	
134180	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
134181	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
134182	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
134183	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
134184	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
134185	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
134186	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
134187	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
134188	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
134189	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
134190	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
134191	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	LTC0000074	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
134192	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
134193	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
134194	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
134195	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
134196	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
134197	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
134198	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
134199	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
134200	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
134201	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
134202	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	4	
134203	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134204	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134205	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134206	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps A Ø	300.0	
134207	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
134208	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
134209	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	General Comments		
134210	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
134211	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
134212	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134213	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134214	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134215	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
134216	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
134217	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
134218	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
134219	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134220	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134221	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134222	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134223	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134224	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134225	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134226	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134227	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134228	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
134229	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
134230	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
134231	10/15/2019 9:38	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
134232	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
134233	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
134234	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
134235	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134236	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
134237	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	279	
134238	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	279	
134239	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
134240	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
134241	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
134242	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
134243	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134244	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134245	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134246	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	310.0	
134247	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
134248	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	310.0	
134249	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
134250	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134251	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134252	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134253	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134254	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134255	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134256	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134257	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	23.98	
134258	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	23.98	
134259	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
134260	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	4	
134261	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	4	
134262	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
134263	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
134264	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
134265	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
134266	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
134267	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
134268	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
134269	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
134270	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
134271	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
134272	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
134273	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
134274	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134275	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
134276	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
134277	10/15/2019 7:59	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
134278	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
134279	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
134280	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
134281	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
134282	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
134283	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
134284	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
134285	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
134286	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
134287	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
134288	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
134289	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
134290	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
134291	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
134292	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
134293	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
134294	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
134295	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
134296	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments		
134297	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
134298	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
134299	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	*F
134300	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
134301	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
134302	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
134303	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
134304	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
134305	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
134306	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
134307	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
134308	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
134309	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
134310	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
134311	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
134312	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
134313	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
134314	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
134315	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
134316	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
134317	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
134318	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
134319	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
134320	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
134321	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
134322	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
134323	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
134324	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		
134325	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
134326	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
134327	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
134328	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
134329	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
134330	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
134331	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
134332	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
134333	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
134334	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
134335	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
134336	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
134337	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
134338	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
134339	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
134340	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
134341	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
134342	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
134343	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
134344	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments		
134345	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
134346	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
134347	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
134348	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	45	"C
134349	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	310.0	
134350	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps C Ø	300.0	
134351	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushing Condition	Good	
134352	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134353	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134354	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134355	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134356	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134357	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134358	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134359	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134360	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134361	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
134362	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
134363	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
134364	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	
134365	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
134366	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	1	
134367	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134368	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations This Read Vac	1	
134369	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	155	
134370	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	155	
134371	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
134372	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
134373	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134374	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
134375	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
134376	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
134377	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
134378	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
134379	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
134380	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
134381	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
134382	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
134383	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	
134384	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134385	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134386	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134387	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134388	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134389	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134390	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134391	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134392	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134393	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
134394	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	7.0	
134395	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	5.0	
134396	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	10.0	
134397	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134398	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134399	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134400	10/15/2019 11:15	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	1	
134401	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
134402	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
134403	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
134404	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
134405	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
134406	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
134407	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
134408	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134409	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
134410	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
134411	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	394	
134412	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	394	
134413	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations This Read Vac	1	
134414	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134415	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	1	
134416	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
134417	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
134418	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
134419	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
134420	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
134421	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
134422	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
134423	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
134424	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
134425	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
134426	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
134427	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps C Phase V	25.80	
134428	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps B Phase V	25.80	
134429	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps A Phase V	25.80	
134430	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134431	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
134432	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
134433	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134434	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134435	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134436	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134437	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134438	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushing Condition	Good	
134439	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps C Ø	191.0	
134440	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps B Ø	189.0	
134441	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps A Ø	184.0	
134442	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134443	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134444	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
134445	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
134446	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
134447	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
134448	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
134449	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
134450	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
134451	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
134452	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
134453	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
134454	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
134455	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134456	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	9 Month Operations	27	
134457	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Unknown Operations	0	
134458	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Tank Paint Condition	Good	
134459	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Switching Operations	0	
134460	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134461	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations This Read Vac	0	
134462	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AL	348	
134463	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AF	348	
134464	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Moisture and Leak Free?	y	
134465	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
134466	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
134467	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
134468	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134469	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134470	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134471	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
134472	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
134473	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	470.0	
134474	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
134475	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134476	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134477	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
134478	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
134479	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
134480	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134481	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134482	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134483	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	9 Month Operations	39	
134484	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
134485	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
134486	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134487	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	0	
134488	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
134489	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	129	
134490	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	129	
134491	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations This Read Vac	4	
134492	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134493	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	4	
134494	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
134495	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
134496	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
134497	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
134498	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
134499	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
134500	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
134501	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
134502	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
134503	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
134504	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
134505	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
134506	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
134507	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Unknown Operations	2	
134508	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Tank Paint Condition	Good	
134509	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Switching Operations	0	
134510	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134511	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations This Read Vac	2	
134512	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AL	347	
134513	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AF	347	
134514	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Moisture and Leak Free?	y	
134515	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Maintenance Operations	0	
134516	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134517	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Grounds in Place?	y	
134518	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	General Comments		
134519	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	General Comments		
134520	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Foundation Condition	Good	
134521	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Follow-up Action Required?	n	
134522	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Follow-up Action Required?	n	
134523	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations Ground	0	
134524	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations C Ø	0	
134525	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations B Ø	0	
134526	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations A Ø	0	
134527	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
134528	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
134529	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
134530	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
134531	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
134532	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Foundation Condition	Good	
134533	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Follow-up Action Required?	n	
134534	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Follow-up Action Required?	n	
134535	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations Ground	0	
134536	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations C Ø	0	
134537	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations B Ø	0	
134538	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations A Ø	0	
134539	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134540	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134541	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134542	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134543	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134544	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134545	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134546	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134547	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134548	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushing Condition	Good	
134549	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps C Ø	65.0	
134550	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps B Ø	74.0	
134551	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps A Ø	83.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134552	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
134553	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
134554	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
134555	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
134556	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A \emptyset	0.0	
134557	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B \emptyset	0.0	
134558	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C \emptyset	0.0	
134559	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
134560	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
134561	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
134562	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A \emptyset	0	
134563	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B \emptyset	0	
134564	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C \emptyset	0	
134565	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
134566	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
134567	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
134568	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
134569	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	726	
134570	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	726	
134571	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
134572	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
134573	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
134574	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
134575	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
134576	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
134577	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
134578	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
134579	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
134580	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
134581	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
134582	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
134583	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
134584	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
134585	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
134586	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
134587	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
134588	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134589	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134590	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134591	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134592	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134593	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134594	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134595	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134596	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A \emptyset	0	
134597	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B \emptyset	0	
134598	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C \emptyset	0	
134599	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
134600	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
134601	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
134602	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
134603	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
134604	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
134605	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
134606	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
134607	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134608	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
134609	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
134610	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	124	
134611	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
134612	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
134613	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
134614	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	33635	
134615	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	33635	
134616	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
134617	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	6L	
134618	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	124	
134619	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
134620	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
134621	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
134622	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
134623	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	2L	
134624	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	7L	
134625	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
134626	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	1224	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
134627	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
134628	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
134629	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
134630	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
134631	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
134632	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
134633	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
134634	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
134635	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
134636	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Maintenance Operations	0	
134637	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134638	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Grounds in Place?	y	
134639	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	General Comments		
134640	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	General Comments		
134641	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
134642	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
134643	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
134644	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
134645	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	5L	
134646	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	11L	
134647	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	1098	
134648	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
134649	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
134650	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
134651	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134652	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
134653	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
134654	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
134655	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
134656	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
134657	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
134658	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
134659	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
134660	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps C Ø	387.0	
134661	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps B Ø	396.0	
134662	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps A Ø	397.0	
134663	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134664	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134665	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134666	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations	60	
134667	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
134668	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
134669	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
134670	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
134671	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
134672	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	General Comments		
134673	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
134674	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	LTC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
134675	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
134676	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
134677	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
134678	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
134679	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
134680	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
134681	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
134682	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	General Comments		
134683	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	General Comments		
134684	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
134685	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134686	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Maintenance Operations	0	
134687	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
134688	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AF	378	
134689	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AL	378	
134690	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
134691	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
134692	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
134693	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
134694	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
134695	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
134696	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
134697	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
134698	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
134699	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
134700	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
134701	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	58281	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134702	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
134703	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
134704	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
134705	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
134706	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
134707	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
134708	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
134709	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	740	
134710	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
134711	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	12L	
134712	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	2L	
134713	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	5L	
134714	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
134715	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	151482	
134716	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	151482	
134717	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		
134718	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
134719	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
134720	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
134721	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
134722	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
134723	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
134724	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134725	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134726	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134727	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134728	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134729	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134730	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134731	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134732	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134733	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134734	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134735	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134736	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134737	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
134738	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
134739	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
134740	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
134741	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	55298	
134742	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
134743	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
134744	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
134745	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	58281	
134746	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
134747	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
134748	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
134749	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
134750	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
134751	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
134752	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
134753	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
134754	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
134755	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
134756	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	7L	
134757	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
134758	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
134759	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
134760	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
134761	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
134762	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
134763	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
134764	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
134765	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Maintenance Operations	0	
134766	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
134767	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AF	371	
134768	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AL	371	
134769	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
134770	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
134771	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134772	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Switching Operations	0	
134773	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
134774	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Unknown Operations	0	
134775	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
134776	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
134777	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
134778	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
134779	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
134780	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	9	
134781	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134782	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134783	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134784	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	5.0	
134785	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	5.0	
134786	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	5.0	
134787	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
134788	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134789	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134790	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134791	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134792	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134793	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134794	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134795	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134796	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134797	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
134798	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
134799	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
134800	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
134801	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
134802	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
134803	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
134804	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
134805	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
134806	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
134807	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
134808	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
134809	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
134810	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
134811	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
134812	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
134813	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
134814	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
134815	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
134816	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
134817	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
134818	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
134819	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps C Ø	291.0	
134820	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps B Ø	298.0	
134821	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps A Ø	291.0	
134822	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134823	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134824	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134825	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134826	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
134827	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
134828	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
134829	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
134830	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
134831	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
134832	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
134833	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	General Comments		
134834	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	General Comments		
134835	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1 POT	VCB Patrol Inspection	Grounds in Place?	y	
134836	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134837	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
134838	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134839	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
134840	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134841	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
134842	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134843	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
134844	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134845	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
134846	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134847	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
134848	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134849	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
134850	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
134851	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134852	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
134853	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
134854	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
134855	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
134856	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
134857	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
134858	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
134859	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
134860	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
134861	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
134862	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
134863	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
134864	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	
134865	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
134866	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
134867	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
134868	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
134869	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
134870	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134871	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
134872	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Switching Operations	0	
134873	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134874	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
134875	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
134876	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
134877	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
134878	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
134879	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
134880	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134881	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushing Condition	Good	
134882	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps C Ø	114.0	
134883	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps B Ø	117.0	
134884	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps A Ø	114.0	
134885	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
134886	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
134887	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
134888	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134889	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134890	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134891	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
134892	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
134893	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
134894	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134895	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134896	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134897	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134898	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134899	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134900	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
134901	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
134902	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
134903	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
134904	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
134905	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
134906	10/15/2019 14:38	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
134907	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations	26	
134908	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Unknown Operations	1	
134909	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Tank Paint Condition	Good	
134910	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Switching Operations	0	
134911	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
134912	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
134913	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
134914	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
134915	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134916	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
134917	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
134918	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
134919	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
134920	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
134921	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
134922	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
134923	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
134924	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
134925	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
134926	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence 25' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
134927	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
134928	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
134929	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
134930	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments		
134931	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
134932	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
134933	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Unknown Operations	0	
134934	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
134935	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Grounds in Place?	y	
134936	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	General Comments		
134937	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	General Comments		
134938	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Foundation Condition	Good	
134939	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Follow-up Action Required?	n	
134940	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Follow-up Action Required?	n	
134941	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations Ground	0	
134942	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations C Ø	0	
134943	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations B Ø	0	
134944	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations A Ø	0	
134945	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
134946	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
134947	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
134948	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
134949	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
134950	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
134951	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
134952	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
134953	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
134954	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
134955	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
134956	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
134957	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
134958	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
134959	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
134960	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
134961	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
134962	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
134963	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
134964	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
134965	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
134966	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
134967	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
134968	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.4	VDC
134969	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.4	VDC
134970	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
134971	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	9 Month Operations	44	
134972	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
134973	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
134974	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
134975	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	General Comments		
134976	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Switching Operations	0	
134977	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134978	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
134979	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AL	346	
134980	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AF	346	
134981	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
134982	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
134983	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
134984	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
134985	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
134986	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
134987	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
134988	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
134989	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
134990	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
134991	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
134992	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
134993	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
134994	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations This Read Vac	1	
134995	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AL	351	
134996	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AF	351	
134997	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Moisture and Leak Free?	y	
134998	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
134999	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Maintenance Operations	0	
135000	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
135001	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
135002	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	General Comments		
135003	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	General Comments		
135004	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Foundation Condition	Good	
135005	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Follow-up Action Required?	n	
135006	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Follow-up Action Required?	n	
135007	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations Ground	0	
135008	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations C Ø	0	
135009	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations B Ø	0	
135010	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
135011	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
135012	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
135013	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
135014	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
135015	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
135016	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
135017	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations A Ø	0	
135018	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
135019	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
135020	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
135021	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135022	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
135023	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135024	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135025	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
135026	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
135027	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushing Condition	Good	
135028	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps C Ø	79.0	
135029	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
135030	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
135031	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BCH000105	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
135032	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps B Ø	79.0	
135033	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps A Ø	79.0	
135034	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
135035	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
135036	10/15/2019 10:16	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
135037	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
135038	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
135039	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
135040	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
135041	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	292508	
135042	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	292508	
135043	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
135044	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
135045	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
135046	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
135047	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
135048	10/15/2019 15:29	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
135049	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
135050	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
135051	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
135052	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
135053	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	9 Month Operations	37	
135054	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Unknown Operations	0	
135055	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Tank Paint Condition	Good	
135056	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Switching Operations	0	
135057	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
135058	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations This Read Vac	0	
135059	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
135060	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AL	337	
135061	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
135062	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AF	337	
135063	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
135064	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
135065	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
135066	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
135067	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
135068	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
135069	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
135070	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
135071	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
135072	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	654	
135073	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
135074	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
135075	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	General Comments		
135076	10/16/2019 9:46	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135077	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
135078	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
135079	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
135080	10/15/2019 10:36	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
135081	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Moisture and Leak Free?	y	
135082	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
135083	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
135084	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
135085	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
135086	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
135087	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
135088	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
135089	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
135090	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Maintenance Operations	0	
135091	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
135092	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
135093	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
135094	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
135095	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	General Comments		
135096	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
135097	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
135098	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
135099	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
135100	10/16/2019 7:03	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
135101	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
135102	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
135103	10/15/2019 13:37	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
135104	10/15/2019 12:40	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
135105	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135106	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
135107	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
135108	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135109	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
135110	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
135111	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
135112	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
135113	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135114	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135115	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
135116	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135117	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Unknown Operations	0	
135118	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135119	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
135120	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135121	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135122	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135123	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Oil Level	Good	
135124	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Condition	Good	
135125	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135126	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Pressure OK?	y	
135127	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Leaks	None	
135128	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135129	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135130	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135131	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135132	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
135133	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135134	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Leaks	None	
135135	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Paint Condition	Good	
135136	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
135137	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
135138	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
135139	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
135140	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
135141	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
135142	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
135143	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #-'s
135144	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
135145	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
135146	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
135147	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
135148	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
135149	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
135150	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	If no, which cells in comments
135151	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135152	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
135153	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Switching Operations	0	
135154	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations This Read Oil	0	
135155	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AL	1927	
135156	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AF	1927	
135157	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
135158	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments	NOT IN SERVICE	
135159	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
135160	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
135161	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1389	
135162	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135163	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C Ø	0.0	
135164	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B Ø	0.0	
135165	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A Ø	0.0	
135166	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135167	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135168	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135169	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135170	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135171	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135172	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135173	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	402940	
135174	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135175	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135176	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135177	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135178	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A Ø	0	
135179	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Condition	Good	
135180	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Oil Level	Good	
135181	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Grounds in Place?	y	
135182	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
135183	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135184	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135185	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
135186	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B Ø	0	
135187	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135188	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135189	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135190	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135191	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135192	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135194	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135195	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Follow-up Action Required?	n	
135196	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C Ø	0	
135197	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
135198	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
135199	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135200	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135201	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Leaks	None	
135202	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135203	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135204	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135205	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135206	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
135207	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
135208	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
135209	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	402940	
135210	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135211	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
135212	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
135213	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
135214	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
135215	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
135216	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Foundation Condition	Good	
135217	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	General Comments		
135218	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Grounds in Place?	y	
135219	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135220	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
135221	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
135222	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
135223	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
135224	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135225	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135226	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135227	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135228	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135229	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135230	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135231	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
135232	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
135233	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
135234	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
135235	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
135236	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
135237	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135238	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
135239	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
135240	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135241	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135242	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135243	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
135244	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
135245	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
135246	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
135247	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
135248	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Grounds in Place?	y	
135249	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	General Comments		
135250	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
135251	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Foundation Condition	Good	
135252	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Follow-up Action Required?	n	
135253	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135254	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135255	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135256	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135257	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135258	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135259	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Oil Level	Good	
135260	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Condition	Good	
135261	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135262	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Pressure OK?	y	
135263	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
135264	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
135265	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
135266	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
135267	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
135268	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
135269	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
135270	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
135271	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
135272	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
135273	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
135274	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135275	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135276	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135277	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
135278	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	264	
135279	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135280	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135281	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135282	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135283	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135284	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135285	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135286	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135287	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135288	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135289	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135290	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135291	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135292	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135293	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
135294	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1389	
135295	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135296	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135297	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135298	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135299	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Leaks	None	
135300	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
135301	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
135302	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	*C
135303	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	*C
135304	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
135305	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
135306	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
135307	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135308	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Maintenance Operations	0	
135309	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
135310	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
135311	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
135312	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
135313	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
135314	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
135315	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
135316	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
135317	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	306	
135318	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
135319	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
135320	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations This Read AM	0	
135321	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
135322	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
135323	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
135324	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	41	
135325	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	41	
135326	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135327	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
135328	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
135329	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
135330	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
135331	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
135332	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
135333	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
135334	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
135335	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
135336	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
135337	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135338	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
135339	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
135340	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
135341	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
135342	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
135343	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
135344	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
135345	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
135346	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
135347	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
135348	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
135349	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
135350	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135351	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
135352	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135353	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135354	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
135355	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
135356	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	General Comments		
135357	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	General Comments		
135358	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
135359	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Follow-up Action Required?	n	
135360	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
135361	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Fault Operations	0	
135362	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Leaks	None	
135363	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135364	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135365	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	147	
135366	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	147	
135367	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135368	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135369	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135370	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135371	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135372	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135373	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135374	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135375	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135376	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
135377	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135378	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135379	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Leaks	None	
135380	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Pressure OK?	y	
135381	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135382	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Condition	Good	
135383	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Oil Level	Good	
135384	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135385	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135386	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
135387	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135388	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135389	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135390	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Follow-up Action Required?	y	
135391	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Foundation Condition	Good	
135392	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
135393	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	General Comments	HEATER BAD	
135394	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135395	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135396	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
135397	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
135398	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
135399	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
135400	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
135401	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
135402	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135403	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Oil Level	Good	
135404	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Condition	Good	
135405	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
135406	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
135407	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
135408	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
135409	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
135410	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
135411	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
135412	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	108.0	
135413	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
135414	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
135415	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
135416	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135417	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135418	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
135419	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135420	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
135421	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135422	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135423	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135424	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
135425	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135426	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135427	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135428	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
135429	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
135430	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
135431	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135432	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135433	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135434	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135435	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135436	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135437	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135438	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135439	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135440	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135441	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135442	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135443	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135444	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99871	
135445	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99871	
135446	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135447	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135448	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps B Ø	0.0	
135449	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps C Ø	0.0	
135450	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
135451	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135452	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
135453	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
135454	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
135455	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
135456	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
135457	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
135458	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
135459	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
135460	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
135461	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
135462	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
135463	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
135464	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
135465	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0129	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
135466	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	3	
135467	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135468	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135469	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135470	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	100.0	
135471	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	220.0	
135472	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	240.0	
135473	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34891	
135474	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34891	
135475	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
135476	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
135477	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
135478	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
135479	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
135480	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
135481	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
135482	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
135483	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
135484	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
135485	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135486	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135487	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135488	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135489	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
135490	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
135491	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
135492	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
135493	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	15	
135494	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
135495	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
135496	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
135497	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
135498	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
135499	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	75699	
135500	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	75699	
135501	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
135502	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
135503	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
135504	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
135505	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135506	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135507	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Grounds in Place?	y	
135508	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
135509	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135510	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135511	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135512	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Pressure OK?	y	
135513	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Leaks	None	
135514	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135515	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
135516	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135517	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Leaks	None	
135518	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135519	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135520	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
135521	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps A Ø	0.0	
135522	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank Leaks	None	
135523	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135524	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
135525	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
135526	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135527	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Grounds in Place?	y	
135528	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	General Comments	OUT OF SERVICE MISSING PARTS	
135529	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Foundation Condition	Good	
135530	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Follow-up Action Required?	n	
135531	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135532	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135533	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135534	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135535	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135536	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Oil Level	Good	
135537	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Condition	Good	
135538	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
135539	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
135540	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
135541	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
135542	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
135543	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
135544	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
135545	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
135546	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135547	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135548	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135549	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	440.0	
135550	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	430.0	
135551	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	440.0	
135552	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135553	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135554	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
135555	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
135556	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
135557	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
135558	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
135559	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
135560	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
135561	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
135562	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
135563	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
135564	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	
135565	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
135566	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135567	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135568	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135569	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135570	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
135571	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
135572	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.2436	
135573	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
135574	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Leaks	None	
135575	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135576	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Follow-up Action Required?	n	
135577	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Foundation Condition	Good	
135578	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
135579	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	General Comments		
135580	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Grounds in Place?	y	
135581	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135582	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135583	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135584	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Follow-up Action Required?	n	
135585	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
135586	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
135587	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135588	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135589	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135590	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135591	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135592	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Leaks	None	
135593	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135594	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135595	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Leaks	None	
135596	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135597	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135598	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Foundation Condition	Good	
135599	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	General Comments	OUT OF SERVICE MISSING PARTS	
135600	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Grounds in Place?	y	
135601	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 1 Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135602	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 2 Oil Level	Good	
135603	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135604	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank Leaks	None	
135605	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135606	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135607	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Grounds in Place?	y	
135608	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	General Comments		
135609	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Foundation Condition	Good	
135610	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Follow-up Action Required?	n	
135611	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135612	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135613	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135614	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135615	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
135616	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135617	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	General Comments		
135618	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
135619	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Foundation Condition	Good	
135620	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Follow-up Action Required?	n	
135621	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135622	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135623	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135624	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135625	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135626	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
135627	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
135628	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
135629	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	1952.64	kw
135630	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
135631	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135632	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
135633	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
135634	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99965	
135635	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135636	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135637	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135638	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
135639	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
135640	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135641	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
135642	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
135643	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
135644	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Max	70	°C
135645	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
135646	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
135647	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	.8136	
135648	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
135649	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
135650	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
135651	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
135652	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
135653	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
135654	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
135655	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
135656	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
135657	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
135658	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
135659	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
135660	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
135661	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
135662	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
135663	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Present	37	°C
135664	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Top Oil Temperature Max	55	°C
135665	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
135666	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
135667	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
135668	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
135669	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
135670	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
135671	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135672	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
135673	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
135674	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	1948.80	kw
135675	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
135676	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135677	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
135678	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
135679	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
135680	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
135681	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
135682	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
135683	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
135684	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135685	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
135686	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
135687	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
135688	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
135689	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135690	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
135691	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
135692	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
135693	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135694	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135695	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135696	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135697	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135698	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135699	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135700	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135701	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9965	
135702	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135703	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Leaks	None	
135704	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135705	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135706	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Follow-up Action Required?	n	
135707	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Foundation Condition	Good	
135708	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	General Comments		
135709	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
135710	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135711	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135712	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135713	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Fault Operations	0	
135714	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Follow-up Action Required?	n	
135715	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Follow-up Action Required?	y	
135716	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Foundation Condition	Good	
135717	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
135718	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	General Comments		
135719	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	General Comments	HEATER BAD	
135720	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Grounds in Place?	y	
135721	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Maintenance Operations	0	
135722	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
135723	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Number of Ops last 9 Months	43	
135724	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AF	1192	
135725	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AL	1192	
135726	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations This Read Oil	1	
135727	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135728	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Switching Operations	1	
135729	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135730	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
135731	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135732	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Leaks	None	
135733	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135734	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Unknown Operations	0	
135735	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Grounds in Place?	y	
135736	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135737	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 2 Oil level	Good	
135738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135739	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank Leaks	None	
135740	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135741	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
135742	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
135743	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
135744	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135745	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
135746	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
135747	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
135748	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
135749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Grounds in Place?	y	
135750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135751	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135752	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135753	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135754	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Leaks	None	
135755	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135756	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
135757	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135758	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135759	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135760	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
135761	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
135762	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
135763	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135764	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135765	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135766	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135767	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
135768	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
135769	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
135770	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
135771	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
135772	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
135773	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
135774	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
135775	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
135776	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
135777	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
135778	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations This Read AM	0	
135779	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
135780	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
135781	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135782	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Leaks	None	
135783	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Pressure OK?	y	
135784	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135785	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps A Ø	100.0	
135786	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps B Ø	100.0	
135787	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps C Ø	100.0	
135788	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Condition	Good	
135789	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Oil Level	Good	
135790	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135791	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135792	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135793	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
135794	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135795	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135796	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
135797	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
135798	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135799	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135800	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135801	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135802	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135803	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	72	
135804	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	72	
135805	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135806	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135807	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135808	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135809	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135810	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135811	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135812	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
135813	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
135814	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
135815	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	70	
135816	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	70	
135817	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
135818	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
135819	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
135820	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
135821	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
135822	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
135823	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
135824	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
135825	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
135826	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135827	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
135828	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
135829	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
135830	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
135831	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
135832	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135833	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135834	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135835	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135836	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135837	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135838	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135839	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
135840	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
135841	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
135842	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
135843	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135844	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
135845	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
135846	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
135847	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
135848	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
135849	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
135850	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
135851	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
135852	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
135853	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
135854	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
135855	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
135856	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
135857	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
135858	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
135859	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
135860	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135861	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
135862	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
135863	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Leaks	None	
135864	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
135865	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
135866	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135867	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
135868	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
135869	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	General Comments		
135870	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
135871	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
135872	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135873	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135874	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
135875	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
135876	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
135877	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
135878	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
135879	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
135880	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
135881	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
135882	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
135883	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
135884	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
135885	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
135886	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
135887	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
135888	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
135889	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135890	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	General Comments		
135891	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Foundation Condition	Good	
135892	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Follow-up Action Required?	n	
135893	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Follow-up Action Required?	n	
135894	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Fault Operations	0	
135895	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135896	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135897	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135898	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135899	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
135900	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
135901	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
135902	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Condition	Good	
135903	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps C Ø	100.0	
135904	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
135905	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
135906	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135907	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
135908	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
135909	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Leaks	None	
135910	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
135911	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
135912	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
135913	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135914	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135915	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
135916	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
135917	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps B Ø	100.0	
135918	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps A Ø	100.0	
135919	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
135920	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
135921	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
135922	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
135923	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
135924	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
135925	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
135926	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		
135927	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
135928	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LTC0000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
135929	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
135930	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
135931	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
135932	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
135933	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
135934	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Paint Condition	Good	
135935	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Leaks	None	
135936	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135937	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
135938	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
135939	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
135940	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
135941	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
135942	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
135943	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
135944	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
135945	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
135946	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
135947	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
135948	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
135949	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
135950	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
135951	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
135952	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
135953	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	497	
135954	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	497	
135955	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
135956	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
135957	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
135958	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
135959	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Switching Operations	0	
135960	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations This Read Oil	0	
135961	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AL	1243	
135962	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AF	1243	
135963	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Number of Ops last 9 Months	16	
135964	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
135965	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
135966	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
135967	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
135968	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
135969	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
135970	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
135971	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Leaks	None	
135972	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Paint Condition	Good	
135973	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Unknown Operations	0	
135974	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
135975	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Maintenance Operations	0	
135976	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
135977	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
135978	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
135979	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
135980	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
135981	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
135982	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	General Comments		
135983	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	General Comments		
135984	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Oil Level	Good	
135985	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Condition	Good	
135986	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
135987	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Pressure OK?	y	
135988	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Leaks	None	
135989	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
135990	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
135991	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
135992	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
135993	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
135994	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
135995	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
135996	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
135997	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Fault Operations	0	
135998	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Follow-up Action Required?	n	
135999	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Follow-up Action Required?	n	
136000	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Foundation Condition	Good	
136001	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136002	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	General Comments		
136003	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	General Comments		
136004	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Grounds in Place?	y	
136005	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Maintenance Operations	0	
136006	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136007	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Number of Ops last 9 Months	1	
136008	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AF	1268	
136009	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AL	1268	
136010	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations This Read Oil	0	
136011	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136012	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Switching Operations	0	
136013	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136014	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 2 Oil Level	Good	
136015	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136016	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Leaks	None	
136017	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Paint Condition	Good	
136018	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Unknown Operations	0	
136019	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Grounds in Place?	y	
136020	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Condition	Good	
136021	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Oil Level	Good	
136022	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136023	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136024	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136025	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136026	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136027	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136028	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Follow-up Action Required?	n	
136029	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Foundation Condition	Good	
136030	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	General Comments		
136031	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
136032	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136033	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136034	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136035	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Grounds in Place?	y	
136036	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136037	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Leaks	None	
136038	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Pressure OK?	y	
136039	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136040	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps A Ø	0.0	
136041	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps B Ø	0.0	
136042	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps C Ø	0.0	
136043	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Condition	Good	
136044	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136045	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136046	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136047	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136048	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136049	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
136050	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
136051	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
136052	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136053	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Leaks	None	
136054	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Pressure OK?	y	
136055	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136056	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Condition	Good	
136057	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Oil Level	Good	
136058	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136059	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136060	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136061	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136062	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136063	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136064	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Follow-up Action Required?	n	
136065	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Foundation Condition	Good	
136066	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
136067	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	General Comments		
136068	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	General Comments		
136069	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136070	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Foundation Condition	Good	
136071	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136072	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136073	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136074	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136075	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136076	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136077	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136078	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
136079	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
136080	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
136081	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
136082	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136083	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136084	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136085	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136086	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	380.0	
136087	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	380.0	
136088	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	380.0	
136089	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136090	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136091	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136092	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	3	
136093	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	203463	
136094	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	203463	
136095	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136096	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
136097	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments		
136098	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
136099	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
136100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Leaks	None	
136101	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Pressure OK?	y	
136102	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136103	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Condition	Good	
136104	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136105	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136106	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136107	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
136108	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136109	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136110	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136111	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Follow-up Action Required?	y	
136112	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Foundation Condition	Good	
136113	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136114	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	General Comments	HEATER BAD	
136115	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Grounds in Place?	y	
136116	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136117	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136118	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136119	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
136120	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136121	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Leaks	None	
136122	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Paint Condition	Good	
136123	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
136124	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
136125	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136126	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136127	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136128	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	1	
136129	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	0	
136130	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
136131	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations This Read Vac	0	
136132	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	225	
136133	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	225	
136134	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
136135	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments	B Phase IOC	
136136	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		
136137	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
136138	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
136139	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
136140	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
136141	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
136142	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
136143	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136144	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136145	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136146	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136147	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	150.0	
136148	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	130.0	
136149	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	130.0	
136150	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136151	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136152	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136153	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	12	
136154	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	0	
136155	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	0	
136156	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations This Read Vac	0	
136157	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	255	
136158	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	255	
136159	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
136160	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
136161	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
136162	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1726	
136163	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
136164	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
136165	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
136166	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
136167	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
136168	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments		
136169	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
136170	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
136171	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
136172	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	220.0	
136173	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	190.0	
136174	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	170.0	
136175	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136176	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136177	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136178	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	0	
136179	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
136180	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
136181	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
136182	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
136183	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136184	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	273.0	
136185	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	270.0	
136186	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	284.0	
136187	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136188	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136189	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136190	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
136191	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Condition	Good	
136192	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136193	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136194	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136195	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136196	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136197	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136198	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136199	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136200	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Foundation Condition	Good	
136201	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136202	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Grounds in Place?	y	
136203	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136204	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
136205	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
136206	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
136207	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
136208	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
136209	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
136210	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
136211	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
136212	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
136213	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
136214	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
136215	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
136216	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
136217	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
136218	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
136219	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
136220	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	401	
136221	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	401	
136222	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
136223	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
136224	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
136225	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
136226	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
136227	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
136228	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
136229	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
136230	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
136231	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
136232	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
136233	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
136234	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
136235	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136236	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136237	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
136238	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
136239	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
136240	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
136241	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
136242	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	284	
136243	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	284	
136244	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
136245	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
136246	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
136247	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
136248	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
136249	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
136250	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
136251	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
136252	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
136253	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
136254	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
136255	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
136256	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
136257	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
136258	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1399	
136259	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
136260	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
136261	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
136262	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
136263	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	96691	
136264	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	96691	
136265	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
136266	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136267	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
136268	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
136269	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
136270	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136271	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136272	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136273	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
136274	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
136275	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
136276	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136277	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	324	
136278	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	324	
136279	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
136280	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
136281	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
136282	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
136283	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
136284	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
136285	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
136286	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
136287	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
136288	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
136289	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
136290	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
136291	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
136292	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
136293	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
136294	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
136295	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
136296	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
136297	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
136298	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
136299	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
136300	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
136301	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
136302	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
136303	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
136304	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136305	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	100.0	
136306	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	125.0	
136307	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	130.0	
136308	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136309	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136310	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136311	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	0	
136312	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
136313	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136314	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136315	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136316	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
136317	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
136318	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136319	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136320	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
136321	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
136322	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
136323	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7475	
136324	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7475	
136325	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
136326	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
136327	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
136328	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
136329	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
136330	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
136331	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
136332	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
136333	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
136334	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
136335	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
136336	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
136337	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	863	
136338	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5R	
136339	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
136340	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
136341	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
136342	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	255573	
136343	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	255573	
136344	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
136345	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
136346	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
136347	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
136348	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
136349	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
136350	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	138.0	
136351	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	90.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
136352	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	108.0	
136353	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136354	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136355	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136356	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	MB0125	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
136357	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
136358	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
136359	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
136360	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
136361	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	n	
136362	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
136363	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
136364	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	
136365	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
136366	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
136367	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136368	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136369	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136370	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136371	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	0.0	
136372	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	0.0	
136373	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	0.0	
136374	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136375	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136376	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136377	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	0	
136378	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	0	
136379	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	
136380	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations This Read Vac	0	
136381	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	119	
136382	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	119	
136383	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
136384	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments		
136385	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
136386	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
136387	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
136388	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
136389	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
136390	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	
136391	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
136392	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136393	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136394	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136395	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136396	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	50.0	
136397	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
136398	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
136399	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
136400	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
136401	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
136402	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
136403	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
136404	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
136405	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	50.0	
136406	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	50.0	
136407	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
136408	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
136409	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
136410	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
136411	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
136412	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
136413	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	764	
136414	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	9L	
136415	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	1L	
136416	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136417	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Leaks	None	
136418	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Pressure OK?	y	
136419	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136420	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Condition	Good	
136421	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Oil Level	Good	
136422	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136423	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136424	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136425	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136426	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136427	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136428	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Follow-up Action Required?	n	
136429	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Foundation Condition	Good	
136430	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
136431	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	General Comments		
136432	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Grounds in Place?	y	
136433	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
136434	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136435	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136436	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
136437	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136438	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Leaks	None	
136439	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Paint Condition	Good	
136440	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	5L	
136441	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
136442	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	251617	
136443	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	251610	
136444	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
136445	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
136446	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
136447	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
136448	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	0	
136449	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
136450	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations This Read Vac	0	
136451	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	123	
136452	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	123	
136453	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
136454	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments		
136455	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
136456	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
136457	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
136458	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
136459	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
136460	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136461	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
136462	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
136463	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
136464	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
136465	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
136466	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
136467	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
136468	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
136469	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136470	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
136471	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	75.0	
136472	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	70.0	
136473	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	70.0	
136474	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136475	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136476	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136477	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
136478	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
136479	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
136480	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
136481	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
136482	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
136483	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
136484	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
136485	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
136486	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Unknown Operations	0	
136487	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
136488	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		
136489	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
136490	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
136491	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
136492	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	12	psi
136493	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	46	°C
136494	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
136495	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
136496	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
136497	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
136498	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Grounds in Place?	y	
136499	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	General Comments		
136500	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Foundation Condition	Good	
136501	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136502	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136503	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136504	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136505	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136506	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
136507	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
136508	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
136509	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
136510	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
136511	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
136512	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
136513	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
136514	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
136515	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
136516	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
136517	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
136518	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
136519	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
136520	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
136521	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
136522	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
136523	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments		
136524	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
136525	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
136526	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	y	
136527	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
136528	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
136529	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
136530	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
136531	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
136532	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
136533	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
136534	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
136535	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
136536	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
136537	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
136538	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
136539	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
136540	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
136541	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	y	
136542	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
136543	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
136544	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AF	6231	
136545	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AL	6231	
136546	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Paint Condition	Good	
136547	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136548	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
136549	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
136550	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations This Read Oil	0	
136551	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136552	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Switching Operations	0	
136553	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136554	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
136555	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
136556	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136557	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136558	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136559	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136560	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
136561	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	0	
136562	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
136563	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments		
136564	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
136565	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
136566	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
136567	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
136568	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
136569	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
136570	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	0	
136571	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
136572	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
136573	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
136574	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
136575	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
136576	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
136577	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
136578	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
136579	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
136580	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136581	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136582	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136583	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136584	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
136585	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136586	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136587	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
136588	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
136589	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Leaks	None	
136590	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136591	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
136592	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
136593	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
136594	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
136595	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
136596	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
136597	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
136598	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
136599	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
136600	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136601	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	190.0	
136602	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	190.0	
136603	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	190.0	
136604	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
136605	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
136606	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
136607	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
136608	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
136609	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
136610	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
136611	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
136612	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
136613	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
136614	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
136615	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136616	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	32	
136617	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
136618	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136619	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
136620	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
136621	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
136622	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136623	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	General Comments		
136624	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
136625	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
136626	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
136627	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
136628	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136629	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136630	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
136631	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
136632	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
136633	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
136634	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136635	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
136636	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136637	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136638	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136639	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	150.0	
136640	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps A Ø	0.0	
136641	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps B Ø	0.0	
136642	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps C Ø	0.0	
136643	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
136644	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136645	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136646	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136647	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136648	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136649	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136650	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136651	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Fault Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136652	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136653	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
136654	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	150.0	
136655	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
136656	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
136657	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
136658	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	kudzu growing under the fence	
136659	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
136660	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
136661	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
136662	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
136663	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
136664	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136665	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136666	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
136667	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136668	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136669	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136670	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136671	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136672	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	*C
136673	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
136674	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
136675	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Unknown Operations	0	
136676	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Switching Operations	0	
136677	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
136678	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
136679	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations This Read Vac	0	
136680	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	531	
136681	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	531	
136682	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
136683	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments		
136684	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Oil Level	Good	
136685	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Condition	Good	
136686	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136687	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136688	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136689	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136690	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
136691	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136692	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
136693	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
136694	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
136695	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000538	LTCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
136696	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000538	LTCControl	CY-TRANS 1	LTC Control Insp	General Comments		
136697	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
136698	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	*C
136699	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	*C
136700	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1308	
136701	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
136702	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
136703	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
136704	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
136705	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
136706	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
136707	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
136708	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
136709	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
136710	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
136711	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
136712	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
136713	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
136714	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
136715	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
136716	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
136717	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
136718	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
136719	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
136720	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	0	
136721	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	0	
136722	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTC0000538	LTCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
136723	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
136724	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
136725	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
136726	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	46	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136727	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	35	°C
136728	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
136729	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	8	
136730	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
136731	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations This Read Vac	8	
136732	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
136733	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
136734	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	326	
136735	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	318	
136736	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136737	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Leaks	None	
136738	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Pressure OK?	y	
136739	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136740	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Condition	Good	
136741	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
136742	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136743	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Leaks	None	
136744	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Pressure OK?	y	
136745	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136746	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps A Ø	0.0	
136747	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps B Ø	0.0	
136748	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps C Ø	0.0	
136749	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Condition	Good	
136750	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136751	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
136752	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
136753	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
136754	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
136755	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
136756	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
136757	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136758	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
136759	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
136760	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
136761	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
136762	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
136763	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
136764	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
136765	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
136766	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
136767	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
136768	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
136769	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
136770	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
136771	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
136772	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
136773	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
136774	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
136775	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
136776	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
136777	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	General Comments		
136778	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
136779	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
136780	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
136781	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
136782	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
136783	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	LTC0000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
136784	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136785	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136786	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136787	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136788	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136789	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136790	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Fault Operations	0	
136791	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136792	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Follow-up Action Required?	n	
136793	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
136794	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
136795	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
136796	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136797	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136798	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136799	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136800	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136801	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136802	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
136803	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
136804	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Fault Operations	0	
136805	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136806	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Follow-up Action Required?	n	
136807	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Foundation Condition	Good	
136808	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136809	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	General Comments		
136810	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	General Comments		
136811	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Grounds in Place?	y	
136812	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Maintenance Operations	0	
136813	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136814	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Number of Ops last 9 Months	5	
136815	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AF	905	
136816	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
136817	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
136818	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
136819	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	11	
136820	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	11	
136821	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
136822	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
136823	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
136824	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136825	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Condition	Good	
136826	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps C Ø	0.0	
136827	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps B Ø	0.0	
136828	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
136829	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
136830	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
136831	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
136832	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
136833	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
136834	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
136835	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
136836	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps A Ø	0.0	
136837	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136838	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
136839	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
136840	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
136841	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Pressure OK?	y	
136842	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Leaks	None	
136843	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136844	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
136845	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
136846	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AL	905	
136847	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations This Read Oil	0	
136848	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136849	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Switching Operations	0	
136850	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
136851	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136852	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
136853	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136854	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Leaks	None	
136855	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
136856	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Paint Condition	Good	
136857	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
136858	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
136859	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
136860	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
136861	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
136862	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
136863	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
136864	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136865	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Follow-up Action Required?	n	
136866	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Foundation Condition	Good	
136867	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136868	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	General Comments		
136869	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Grounds in Place?	y	
136870	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
136871	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
136872	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
136873	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
136874	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
136875	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
136876	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136877	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
136878	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
136879	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
136880	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
136881	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
136882	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
136883	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
136884	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
136885	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
136886	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
136887	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
136888	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
136889	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	General Comments		
136890	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	General Comments		
136891	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Grounds in Place?	y	
136892	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Maintenance Operations	0	
136893	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
136894	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
136895	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
136896	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
136897	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	13027	
136898	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	13027	
136899	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
136900	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
136901	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
136902	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
136903	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
136904	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
136905	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
136906	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
136907	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
136908	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Leaks	None	
136909	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Paint Condition	Good	
136910	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
136911	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
136912	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
136913	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
136914	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
136915	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
136916	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
136917	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
136918	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
136919	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
136920	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
136921	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
136922	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
136923	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
136924	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
136925	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
136926	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
136927	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	y	
136928	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
136929	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
136930	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	y	
136931	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
136932	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
136933	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
136934	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
136935	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
136936	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
136937	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Unknown Operations	0	
136938	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
136939	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
136940	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
136941	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
136942	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Leaks	None	
136943	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
136944	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136945	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
136946	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps A Ø	0.0	
136947	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps B Ø	0.0	
136948	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps C Ø	0.0	
136949	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
136950	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Oil Level?	Good	
136951	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
136952	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136953	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136954	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136955	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
136956	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
136957	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
136958	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
136959	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
136960	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
136961	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
136962	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	None	
136963	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
136964	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
136965	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Foundation Condition	Good	
136966	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
136967	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	y	
136968	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136969	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136970	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136971	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
136972	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
136973	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments		
136974	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
136975	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
136976	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
136977	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
136978	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
136979	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Fault Operations	0	
136980	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
136981	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Follow-up Action Required?	n	
136982	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
136983	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
136984	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	General Comments		
136985	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	General Comments		
136986	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
136987	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Maintenance Operations	0	
136988	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
136989	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
136990	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Leaks	None	
136991	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Pressure OK?	y	
136992	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
136993	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Condition	Good	
136994	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Oil Level	Good	
136995	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
136996	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
136997	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
136998	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
136999	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
137000	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137001	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
137002	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
137003	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
137004	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137005	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
137006	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
137007	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
137008	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Leaks	None	
137009	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Pressure OK?	y	
137010	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
137011	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Condition	Good	
137012	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Oil Level	Good	
137013	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
137014	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
137015	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137016	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137017	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
137018	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
137019	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
137020	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
137021	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
137022	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
137023	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	751	
137024	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	751	
137025	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
137026	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137027	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
137028	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
137029	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
137030	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
137031	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
137032	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
137033	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
137034	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
137035	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
137036	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
137037	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
137038	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
137039	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
137040	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
137041	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
137042	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
137043	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
137044	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
137045	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
137046	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
137047	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
137048	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
137049	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
137050	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
137051	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
137052	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
137053	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
137054	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
137055	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
137056	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137057	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
137058	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
137059	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Follow-up Action Required?	n	
137060	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Foundation Condition	Good	
137061	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
137062	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	General Comments		
137063	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Grounds in Place?	y	
137064	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
137065	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137066	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
137067	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Number of Ops last 9 Months	2	
137068	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AF	1067	
137069	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AL	1067	
137070	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations This Read Oil	1	
137071	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137072	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Switching Operations	1	
137073	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137074	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
137075	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137076	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Leaks	None	
137077	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Paint Condition	Good	
137078	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Unknown Operations	0	
137079	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
137080	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
137081	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
137082	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
137083	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
137084	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
137085	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
137086	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
137087	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	General Comments	OK	
137088	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
137089	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
137090	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
137091	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
137092	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137093	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137094	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
137095	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137096	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Leaks	None	
137097	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Paint Condition	Good	
137098	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Condition	Good	
137099	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
137100	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Pressure OK?	y	
137101	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137102	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
137103	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
137104	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
137105	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Foundation Condition	Good	
137106	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Follow-up Action Required?	n	
137107	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
137108	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137109	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137110	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137111	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
137112	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
137113	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Oil Level	Good	
137114	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Condition	Good	
137115	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
137116	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Pressure OK?	y	
137117	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Leaks	None	
137118	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
137119	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
137120	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
137121	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
137122	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
137123	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
137124	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
137125	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
137126	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
137127	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
137128	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
137129	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
137130	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
137131	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
137132	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
137133	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
137134	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
137135	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
137136	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
137137	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	125.0	
137138	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	130.0	
137139	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
137140	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
137141	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
137142	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	9	
137143	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137144	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
137145	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137146	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Leaks	None	
137147	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Paint Condition	Good	
137148	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
137149	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
137150	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
137151	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
137152	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
137153	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
137154	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
137155	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
137156	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Oil is seeping out of the C phase Thermal well for the winding temp guage. Pic sent to Stinson	
137157	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
137158	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
137159	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
137160	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
137161	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
137162	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
137163	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
137164	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
137165	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
137166	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
137167	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
137168	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
137169	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
137170	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
137171	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
137172	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
137173	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
137174	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
137175	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
137176	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137177	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	General Comments		
137178	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
137179	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
137180	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
137181	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
137182	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
137183	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137184	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Paint Condition	Good	
137185	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Leaks	None	
137186	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137187	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
137188	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137189	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
137190	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
137191	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1301	
137192	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1301	
137193	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
137194	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
137195	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
137196	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137197	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
137198	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Grounds in Place?	y	
137199	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
137200	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
137201	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
137202	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
137203	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
137204	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
137205	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
137206	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
137207	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
137208	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
137209	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
137210	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137211	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
137212	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
137213	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
137214	10/15/2019 14:25	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
137215	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
137216	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
137217	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
137218	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
137219	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
137220	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
137221	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
137222	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
137223	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
137224	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137225	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
137226	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
137227	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
137228	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
137229	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
137230	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
137231	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
137232	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
137233	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
137234	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	9	
137235	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
137236	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations This Read Vac	9	
137237	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	192	
137238	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	184	
137239	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
137240	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	0	
137241	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
137242	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
137243	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
137244	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
137245	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
137246	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
137247	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
137248	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
137249	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations E Ø	0	
137250	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
137251	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137252	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
137253	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137254	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137255	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137256	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137257	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137258	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137259	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137260	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
137261	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	125.0	
137262	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
137263	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
137264	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
137265	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
137266	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Maintenance Operations	0	
137267	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
137268	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
137269	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	4530	
137270	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	4525	
137271	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
137272	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AF	1634	
137273	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments	Drag hands will not reset	
137274	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
137275	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
137276	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
137277	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AL	1634	
137278	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations This Read Oil	0	
137279	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Grounds in Place?	y	
137280	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
137281	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137282	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137283	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
137284	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137285	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Leaks	None	
137286	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Paint Condition	Good	
137287	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Switching Operations	0	
137288	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137289	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
137290	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137291	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
137292	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Oil Level	Good	
137293	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
137294	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Unknown Operations	0	
137295	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137296	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
137297	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
137298	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
137299	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments	Fence has been repaired since vehicle ran through it but need to be fixed permanatly	
137300	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
137301	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
137302	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
137303	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	793	
137304	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	12L	
137305	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	3L	
137306	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	7L	
137307	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	66464	
137308	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	66464	
137309	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments	corrected the as found counter reading. An extra digit had been added.	
137310	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
137311	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
137312	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
137313	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	8	
137314	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
137315	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
137316	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
137317	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
137318	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
137319	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
137320	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
137321	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
137322	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
137323	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
137324	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
137325	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
137326	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137327	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
137328	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
137329	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
137330	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
137331	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
137332	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	FE000101	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
137333	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
137334	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Follow-up Action Required?	n	
137335	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
137336	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	General Comments		
137337	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	General Comments		
137338	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
137339	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Maintenance Operations	0	
137340	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
137341	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
137342	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AF	2073	
137343	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AL	2073	
137344	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
137345	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations This Read Oil	0	
137346	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Switching Operations	0	
137347	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137348	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Leaks	None	
137349	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Pressure OK?	y	
137350	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
137351	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Condition	Good	
137352	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Oil Level	Good	
137353	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
137354	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
137355	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137356	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137357	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137358	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
137359	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Follow-up Action Required?	n	
137360	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Foundation Condition	Good	
137361	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
137362	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	General Comments		
137363	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
137364	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
137365	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
137366	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
137367	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	780	
137368	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
137369	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Leaks	None	
137370	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
137371	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
137372	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps A Ø	0.0	
137373	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps B Ø	0.0	
137374	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps C Ø	0.0	
137375	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
137376	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
137377	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
137378	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
137379	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137380	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137381	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137382	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
137383	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137384	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
137385	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
137386	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	General Comments		
137387	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
137388	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
137389	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Fault Operations	0	
137390	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
137391	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Follow-up Action Required?	n	
137392	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
137393	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	10L	
137394	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	1L	
137395	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	5L	
137396	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	General Comments		
137397	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	General Comments		
137398	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
137399	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
137400	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
137401	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137402	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
137403	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
137404	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137405	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137406	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
137407	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
137408	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137409	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Follow-up Action Required?	n	
137410	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Foundation Condition	Good	
137411	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
137412	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
137413	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
137414	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
137415	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
137416	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
137417	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
137418	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Paint Condition	Good	
137419	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Leaks	None	
137420	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137421	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
137422	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
137423	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
137424	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
137425	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Grounds in Place?	y	
137426	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	General Comments		
137427	10/14/2019 14:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
137428	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
137429	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
137430	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
137431	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
137432	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
137433	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
137434	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
137435	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	120.0	
137436	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
137437	10/14/2019 15:21	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137438	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
137439	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
137440	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
137441	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
137442	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
137443	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
137444	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
137445	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
137446	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
137447	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
137448	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
137449	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
137450	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
137451	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
137452	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
137453	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
137454	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
137455	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BCH001021	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
137456	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
137457	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
137458	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
137459	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
137460	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
137461	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
137462	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
137463	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Foundation Condition	Good	
137464	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
137465	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	General Comments		
137466	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Grounds in Place?	y	
137467	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
137468	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
137469	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
137470	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
137471	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
137472	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
137473	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
137474	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
137475	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
137476	10/15/2019 7:27	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137477	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
137478	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
137479	10/18/2019 14:38	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Oil Level	Good	
137480	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
137481	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
137482	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
137483	10/14/2019 14:56	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
137484	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
137485	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
137486	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
137487	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
137488	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137489	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
137490	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
137491	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
137492	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
137493	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
137494	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
137495	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
137496	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
137497	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
137498	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
137499	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	6	
137500	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	6	
137501	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
137502	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
137503	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
137504	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
137505	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	15575	
137506	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	15575	
137507	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
137508	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.05	%
137509	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
137510	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
137511	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	4R	
137512	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	12R	
137513	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	8L	
137514	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
137515	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	43	
137516	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	4	
137517	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
137518	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	4	
137519	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
137520	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	44.72	
137521	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	44.72	
137522	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137523	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
137524	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
137525	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
137526	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	32.52	%
137527	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	27.7	%
137528	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	21.68	%
137529	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	45	
137530	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	67.08	
137531	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	723	
137532	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
137533	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
137534	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
137535	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
137536	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
137537	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
137538	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
137539	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	6	
137540	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	559	
137541	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	559	
137542	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
137543	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
137544	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
137545	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
137546	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
137547	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
137548	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
137549	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	24.09	%
137550	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	30.11	%
137551	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.05	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137552	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	110.0	
137553	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
137554	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	110.0	
137555	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137556	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	67.08	
137557	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
137558	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
137559	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
137560	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
137561	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	1L	
137562	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
137563	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
137564	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
137565	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
137566	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
137567	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
137568	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	723	
137569	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	12	
137570	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
137571	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
137572	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
137573	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
137574	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	8	
137575	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	500	
137576	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
137577	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	500	
137578	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
137579	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
137580	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
137581	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations C Ø	0	
137582	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations B Ø	0	
137583	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations A Ø	0	
137584	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
137585	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
137586	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137587	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137588	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137589	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137590	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137591	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137592	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137593	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushing Condition	Good	
137594	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps C Ø	205.0	
137595	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps B Ø	205.0	
137596	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps A Ø	195.0	
137597	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
137598	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
137599	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
137600	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations	17	
137601	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
137602	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
137603	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
137604	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
137605	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
137606	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137607	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
137608	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
137609	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
137610	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
137611	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
137612	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
137613	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
137614	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
137615	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
137616	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
137617	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137618	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
137619	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
137620	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
137621	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
137622	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
137623	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
137624	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
137625	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
137626	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137627	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137628	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
137629	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
137630	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
137631	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
137632	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
137633	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
137634	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
137635	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
137636	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
137637	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
137638	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
137639	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
137640	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
137641	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
137642	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
137643	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	27018.00	kw
137644	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
137645	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		
137646	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
137647	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
137648	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
137649	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	161	
137650	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	161	
137651	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
137652	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
137653	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
137654	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
137655	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
137656	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
137657	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	2L	
137658	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
137659	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
137660	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
137661	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
137662	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
137663	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
137664	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
137665	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	0	
137666	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
137667	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
137668	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
137669	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
137670	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
137671	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137672	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137673	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137674	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137675	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137676	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137677	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
137678	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
137679	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
137680	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
137681	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	58.24	%
137682	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	60.48	%
137683	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	58.24	%
137684	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0247	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
137685	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
137686	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
137687	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
137688	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
137689	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
137690	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
137691	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
137692	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
137693	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
137694	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
137695	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137696	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137697	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137698	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
137699	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
137700	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
137701	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
137702	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Unknown Operations	0	
137703	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Tank Paint Condition	Good	
137704	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Switching Operations	0	
137705	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations This Read Vac	0	
137706	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AL	179	
137707	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AF	179	
137708	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Moisture and Leak Free?	y	
137709	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Maintenance Operations	0	
137710	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Grounds in Place?	y	
137711	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	General Comments		
137712	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	General Comments		
137713	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Foundation Condition	Good	
137714	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Follow-up Action Required?	n	
137715	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Follow-up Action Required?	n	
137716	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations Ground	0	
137717	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	13.53	%
137718	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	11.45	%
137719	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	250.0	
137720	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	250.0	
137721	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	250.0	
137722	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
137723	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137724	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137725	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137726	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137727	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137728	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137729	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137730	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
137731	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
137732	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
137733	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
137734	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
137735	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
137736	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
137737	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
137738	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
137739	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
137740	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
137741	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
137742	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
137743	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
137744	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
137745	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	437	
137746	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	437	
137747	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	0	
137748	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
137749	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	0	
137750	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
137751	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
137752	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
137753	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
137754	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
137755	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
137756	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
137757	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137758	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
137759	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
137760	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
137761	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
137762	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments	Oil level guage not working	
137763	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
137764	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Inaccurate	
137765	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
137766	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
137767	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	67.68	kw
137768	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
137769	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
137770	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137771	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
137772	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
137773	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
137774	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
137775	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
137776	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137777	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
137778	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
137779	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1128	
137780	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
137781	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
137782	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
137783	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137784	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
137785	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
137786	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
137787	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	70	°C
137788	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	40	°C
137789	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
137790	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
137791	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
137792	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	LTC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
137793	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
137794	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
137795	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	460.0	
137796	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	450.0	
137797	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	500.0	
137798	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137799	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
137800	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
137801	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
137802	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
137803	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
137804	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
137805	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
137806	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
137807	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
137808	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
137809	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
137810	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
137811	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
137812	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
137813	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
137814	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
137815	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
137816	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
137817	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
137818	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
137819	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
137820	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
137821	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
137822	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.5010	
137823	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	75	°C
137824	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	40	°C
137825	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
137826	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
137827	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
137828	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137829	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137830	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137831	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137832	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
137833	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	880.0	
137834	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	845.0	
137835	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
137836	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
137837	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
137838	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	815.0	
137839	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	2.51	%
137840	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	2.51	%
137841	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	5.03	%
137842	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	3	
137843	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
137844	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
137845	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
137846	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
137847	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
137848	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
137849	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
137850	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
137851	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
137852	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	12.49	%
137853	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
137854	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
137855	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
137856	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137857	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
137858	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
137859	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
137860	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	74	
137861	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
137862	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
137863	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.0	
137864	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	447	
137865	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
137866	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
137867	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
137868	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
137869	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
137870	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
137871	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
137872	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
137873	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
137874	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
137875	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
137876	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
137877	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments		
137878	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
137879	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
137880	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
137881	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
137882	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
137883	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
137884	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
137885	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
137886	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
137887	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
137888	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	69	
137889	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
137890	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
137891	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
137892	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
137893	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
137894	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
137895	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
137896	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
137897	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
137898	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
137899	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
137900	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
137901	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
137902	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
137903	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
137904	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
137905	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	HEATER KEEPS TRIPING OUT needs new breaker style no. 4990D03G39 WESTINGHOUSE	
137906	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
137907	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
137908	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
137909	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
137910	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
137911	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
137912	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
137913	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
137914	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
137915	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
137916	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
137917	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
137918	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
137919	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
137920	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
137921	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
137922	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
137923	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
137924	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
137925	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	13.97	
137926	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
137927	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
137928	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments		
137929	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
137930	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
137931	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
137932	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
137933	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	223	
137934	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	223	
137935	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
137936	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
137937	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
137938	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0247	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
137939	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
137940	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
137941	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
137942	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
137943	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
137944	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
137945	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
137946	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
137947	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
137948	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
137949	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
137950	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
137951	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
137952	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
137953	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
137954	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
137955	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
137956	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
137957	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
137958	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
137959	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
137960	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
137961	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
137962	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
137963	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	18.74	%
137964	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	21.86	%
137965	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	10.41	%
137966	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
137967	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
137968	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
137969	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
137970	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.7	
137971	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
137972	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	260.0	
137973	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	280.0	
137974	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
137975	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
137976	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
137977	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
137978	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
137979	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
137980	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	15.66	%
137981	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	21.68	%
137982	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
137983	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
137984	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	15L	
137985	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
137986	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
137987	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
137988	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
137989	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
137990	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
137991	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
137992	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
137993	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
137994	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
137995	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
137996	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
137997	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
137998	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
137999	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
138000	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
138001	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
138002	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
138003	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
138004	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
138005	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
138006	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
138007	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
138008	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
138009	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
138010	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
138011	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
138012	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	89	
138013	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	89	
138014	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
138015	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
138016	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
138017	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138018	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	517	
138019	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
138020	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BB0273	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
138021	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
138022	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
138023	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
138024	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
138025	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
138026	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
138027	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
138028	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
138029	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
138030	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	426	
138031	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	426	
138032	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
138033	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
138034	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
138035	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	0	
138036	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
138037	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	0	
138038	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
138039	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
138040	10/11/2019 15:06	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
138041	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
138042	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
138043	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
138044	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
138045	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	15	
138046	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	656	
138047	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
138048	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	656	
138049	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
138050	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
138051	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
138052	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
138053	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
138054	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
138055	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
138056	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	
138057	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	note in comments if present
138058	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
138059	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
138060	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
138061	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
138062	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
138063	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
138064	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
138065	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
138066	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
138067	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
138068	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
138069	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
138070	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	656	*F
138071	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
138072	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
138073	10/11/2019 7:56	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
138074	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LTC0000117	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
138075	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LTC0000117	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
138076	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LTC0000117	LTCControl	Retired Distribution	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138077	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
138078	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
138079	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
138080	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
138081	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
138082	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	0	
138083	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	195888	
138084	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
138085	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
138086	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
138087	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
138088	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
138089	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
138090	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
138091	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
138092	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	179	
138093	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
138094	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	179	
138095	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
138096	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations This Read Vac	1	
138097	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138098	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138099	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138100	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
138101	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
138102	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
138103	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
138104	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
138105	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
138106	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
138107	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
138108	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
138109	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	0	
138110	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
138111	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
138112	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
138113	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
138114	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
138115	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
138116	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
138117	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
138118	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
138119	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
138120	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1317	
138121	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	1	
138122	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138123	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138124	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138125	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
138126	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
138127	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
138128	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
138129	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
138130	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
138131	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
138132	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
138133	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
138134	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
138135	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
138136	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	1	
138137	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
138138	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
138139	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
138140	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
138141	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
138142	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
138143	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
138144	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
138145	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
138146	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments		
138147	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
138148	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
138149	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
138150	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138151	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1228	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138152	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
138153	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
138154	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
138155	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	1	
138156	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
138157	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
138158	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
138159	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
138160	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
138161	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	195888	
138162	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138163	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
138164	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
138165	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	10.0	
138166	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	10.0	
138167	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	10.0	
138168	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
138169	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
138170	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
138171	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	3	
138172	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
138173	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
138174	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
138175	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
138176	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	94	
138177	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138178	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	8	
138179	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	96	
138180	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	2	
138181	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
138182	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
138183	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
138184	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
138185	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	200	
138186	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	200	
138187	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations This Read Vac	1	
138188	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	1	
138189	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
138190	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
138191	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138192	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138193	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
138194	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
138195	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	866	
138196	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	866	
138197	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
138198	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	2	
138199	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
138200	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
138201	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
138202	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
138203	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
138204	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
138205	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
138206	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
138207	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
138208	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	2	
138209	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
138210	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
138211	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
138212	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
138213	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	0	
138214	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138215	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138216	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138217	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138218	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
138219	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
138220	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.9	amps
138221	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
138222	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
138223	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
138224	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
138225	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
138226	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138227	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
138228	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
138229	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
138230	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
138231	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
138232	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
138233	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
138234	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
138235	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
138236	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
138237	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
138238	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
138239	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
138240	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
138241	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
138242	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
138243	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
138244	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
138245	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
138246	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	10	
138247	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138248	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138249	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138250	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	0.0	
138251	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	0.0	
138252	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	0.0	
138253	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
138254	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138255	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138256	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138257	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138258	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138259	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138260	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138261	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138262	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138263	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
138264	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
138265	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
138266	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
138267	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
138268	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
138269	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
138270	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
138271	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
138272	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
138273	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
138274	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
138275	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
138276	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
138277	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	
138278	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
138279	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
138280	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138281	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
138282	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	880	
138283	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	880	
138284	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	0	
138285	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
138286	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
138287	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
138288	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
138289	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments		
138290	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
138291	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
138292	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
138293	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
138294	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
138295	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
138296	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
138297	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
138298	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
138299	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
138300	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
138301	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138302	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
138303	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
138304	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
138305	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
138306	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
138307	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
138308	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
138309	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
138310	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
138311	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
138312	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
138313	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138314	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
138315	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
138316	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
138317	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
138318	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	0	
138319	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
138320	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
138321	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
138322	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
138323	10/10/2019 10:42	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138324	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
138325	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
138326	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
138327	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
138328	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
138329	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
138330	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
138331	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
138332	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
138333	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
138334	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
138335	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
138336	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
138337	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
138338	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
138339	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
138340	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
138341	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
138342	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
138343	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	59.0	VDC
138344	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	59.0	VDC
138345	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
138346	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
138347	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
138348	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	50.0	
138349	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	50.0	
138350	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	50.0	
138351	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
138352	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
138353	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	71369	
138354	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	71381	
138355	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
138356	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	1L	
138357	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	9L	
138358	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	9L	
138359	10/10/2019 10:42	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	9.64	%
138360	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Needs Replaced	
138361	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	372	
138362	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
138363	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138364	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
138365	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
138366	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
138367	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
138368	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
138369	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
138370	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
138371	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
138372	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
138373	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
138374	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	105986	
138375	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	105986	
138376	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138377	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments	sub is out of service.	
138378	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
138379	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
138380	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
138381	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
138382	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	468	
138383	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	468	
138384	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	1	
138385	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	1	
138386	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
138387	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
138388	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
138389	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
138390	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
138391	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
138392	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
138393	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
138394	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	y	
138395	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
138396	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
138397	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
138398	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
138399	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
138400	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
138401	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
138402	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of insects	None	
138403	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
138404	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
138405	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
138406	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
138407	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
138408	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
138409	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments		
138410	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
138411	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
138412	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
138413	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	0	
138414	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
138415	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
138416	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
138417	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
138418	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138419	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
138420	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
138421	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
138422	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138423	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
138424	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
138425	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
138426	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
138427	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
138428	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
138429	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
138430	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
138431	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
138432	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
138433	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
138434	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138435	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
138436	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
138437	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	0	
138438	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations This Read Vac	0	
138439	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	217	
138440	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	217	
138441	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
138442	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	0	
138443	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	
138444	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments		
138445	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
138446	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
138447	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Follow-up Action Required?	n	
138448	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Follow-up Action Required?	n	
138449	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations Ground	0	
138450	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations C Ø	0	
138451	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138452	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations A Ø	0	
138453	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138454	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138455	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138456	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138457	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138458	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138459	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138460	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138461	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138462	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushing Condition	Good	
138463	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps C Ø	76.0	
138464	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	1	
138465	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	1	
138466	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	558	
138467	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	558	
138468	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
138469	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments	Racked out and carded #0028	
138470	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
138471	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
138472	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
138473	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
138474	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
138475	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
138476	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
138477	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
138478	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
138479	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
138480	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138481	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	0.0	
138482	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	0.0	
138483	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	0.0	
138484	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
138485	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
138486	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
138487	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	2	
138488	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	70.0	
138489	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	80.0	
138490	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
138491	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138492	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138493	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138494	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
138495	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
138496	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
138497	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
138498	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
138499	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
138500	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
138501	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
138502	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
138503	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
138504	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
138505	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
138506	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
138507	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
138508	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
138509	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	81	*F
138510	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
138511	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
138512	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
138513	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
138514	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
138515	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments		
138516	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
138517	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
138518	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	34	
138519	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
138520	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
138521	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
138522	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
138523	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel/loff	Position
138524	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
138525	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
138526	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
138527	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
138528	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
138529	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
138530	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
138531	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
138532	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
138533	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
138534	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
138535	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
138536	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
138537	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
138538	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
138539	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
138540	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
138541	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
138542	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
138543	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
138544	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
138545	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
138546	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
138547	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
138548	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
138549	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments		
138550	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
138551	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
138552	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
138553	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
138554	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
138555	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
138556	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
138557	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
138558	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
138559	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
138560	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
138561	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
138562	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
138563	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
138564	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps B Ø	79.0	
138565	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps A Ø	89.0	
138566	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138567	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138568	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138569	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	4	
138570	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
138571	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
138572	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
138573	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
138574	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
138575	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
138576	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
138577	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
138578	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
138579	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
138580	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000068	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
138581	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
138582	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	60	*C
138583	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	*C
138584	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	60	*C
138585	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	*C
138586	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	*C
138587	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
138588	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
138589	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138590	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138591	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138592	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138593	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138594	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138595	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
138596	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
138597	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
138598	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
138599	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
138600	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
138601	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
138602	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
138603	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
138604	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
138605	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
138606	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
138607	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
138608	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
138609	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
138610	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
138611	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
138612	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
138613	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
138614	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	831	
138615	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	831	
138616	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	3	
138617	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	0	
138618	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
138619	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
138620	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
138621	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
138622	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
138623	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
138624	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	1	
138625	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	1	
138626	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	559	
138627	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	21	
138628	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	12.05	%
138629	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
138630	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
138631	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	140.0	
138632	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	140.0	
138633	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
138634	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	100.0	
138635	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138636	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	44.72	
138637	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
138638	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	44.72	
138639	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	4	
138640	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
138641	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	4	
138642	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
138643	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
138644	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
138645	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
138646	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
138647	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
138648	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
138649	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
138650	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	LTC0000369	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
138651	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	559	
138652	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
138653	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
138654	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
138655	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
138656	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments	sub is out of service.	
138657	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
138658	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
138659	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
138660	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
138661	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
138662	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
138663	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
138664	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
138665	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
138666	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
138667	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BCH000215	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
138668	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
138669	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
138670	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
138671	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
138672	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
138673	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
138674	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
138675	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
138676	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138677	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
138678	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
138679	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
138680	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
138681	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
138682	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
138683	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
138684	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
138685	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
138686	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
138687	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
138688	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
138689	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
138690	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
138691	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
138692	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138693	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
138694	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	18	
138695	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
138696	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
138697	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
138698	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	10.0	
138699	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	10.0	
138700	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	10.0	
138701	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138702	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
138703	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
138704	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
138705	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	1	
138706	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	1	
138707	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	1	
138708	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
138709	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
138710	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
138711	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
138712	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments		
138713	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
138714	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
138715	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138716	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
138717	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
138718	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
138719	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	10	°C
138720	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	67	°C
138721	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	65	°C
138722	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
138723	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	15	°C
138724	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138725	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
138726	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
138727	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
138728	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
138729	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
138730	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	69	°C
138731	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	59	°C
138732	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138733	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
138734	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138735	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
138736	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	8	
138737	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138738	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138739	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138740	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	60.0	
138741	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
138742	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
138743	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
138744	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
138745	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138746	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	961	
138747	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
138748	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
138749	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
138750	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
138751	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138752	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	102089	
138753	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	102089	
138754	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments	VC SHOWS 2089, HAS ROOLED OVER	
138755	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
138756	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
138757	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
138758	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
138759	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
138760	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
138761	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
138762	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
138763	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
138764	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
138765	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
138766	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
138767	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
138768	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
138769	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
138770	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
138771	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
138772	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
138773	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
138774	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
138775	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
138776	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
138777	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
138778	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1291	
138779	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1291	
138780	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	8	
138781	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
138782	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
138783	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
138784	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro. Needs Dessicant	
138785	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
138786	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
138787	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
138788	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
138789	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
138790	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
138791	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
138792	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
138793	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
138794	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
138795	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
138796	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
138797	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
138798	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
138799	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
138800	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
138801	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
138802	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
138803	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
138804	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
138805	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
138806	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
138807	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
138808	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
138809	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
138810	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138811	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
138812	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138813	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
138814	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
138815	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.3210	
138816	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
138817	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138818	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
138819	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138820	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
138821	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138822	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	40	°C
138823	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	55	°C
138824	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
138825	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
138826	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	3686.40	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138827	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
138828	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
138829	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
138830	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138831	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
138832	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
138833	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
138834	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
138835	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
138836	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
138837	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
138838	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
138839	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
138840	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
138841	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
138842	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
138843	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
138844	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
138845	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
138846	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138847	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
138848	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
138849	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	BCH00023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
138850	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	2	
138851	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138852	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138853	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138854	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	27.0	
138855	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	16.0	
138856	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	49.0	
138857	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
138858	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138859	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
138860	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138861	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	40	°C
138862	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	49	°C
138863	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
138864	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
138865	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138866	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138867	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138868	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138869	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138870	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138871	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138872	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138873	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
138874	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
138875	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
138876	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
138877	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
138878	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
138879	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
138880	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
138881	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138882	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
138883	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
138884	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	5120	
138885	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
138886	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138887	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
138888	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138889	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
138890	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
138891	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138892	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
138893	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
138894	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
138895	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138896	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
138897	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138898	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
138899	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
138900	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
138901	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
138902	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138903	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
138904	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
138905	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
138906	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
138907	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
138908	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
138909	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
138910	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
138911	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
138912	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
138913	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
138914	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
138915	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138916	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138917	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138918	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138919	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138920	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138921	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138922	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138923	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
138924	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	0	
138925	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
138926	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	0	
138927	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	0	
138928	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
138929	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
138930	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
138931	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
138932	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
138933	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
138934	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
138935	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
138936	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	150	
138937	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	150	
138938	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations This Read Vac	1	
138939	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	1	
138940	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
138941	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
138942	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	3	
138943	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
138944	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
138945	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
138946	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	36.0	
138947	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	32.0	
138948	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	37.0	
138949	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
138950	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	
138951	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
138952	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
138953	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
138954	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
138955	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
138956	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
138957	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
138958	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
138959	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	0	
138960	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	0	
138961	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
138962	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	0	
138963	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
138964	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
138965	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	2311.20	kw
138966	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
138967	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
138968	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
138969	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138970	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
138971	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
138972	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
138973	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7812	
138974	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
138975	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
138976	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
138977	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
138978	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
138979	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
138980	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
138981	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
138982	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
138983	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
138984	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
138985	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1874.88	kw
138986	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
138987	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
138988	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
138989	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
138990	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
138991	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
138992	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
138993	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
138994	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
138995	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
138996	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
138997	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
138998	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
138999	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
139000	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139001	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139002	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
139003	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
139004	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
139005	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
139006	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139007	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
139008	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
139009	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
139010	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
139011	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
139012	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
139013	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139014	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139015	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
139016	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
139017	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
139018	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
139019	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
139020	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
139021	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
139022	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
139023	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments		
139024	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
139025	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	
139026	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
139027	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	641	
139028	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	641	
139029	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations This Read Vac	0	
139030	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
139031	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	0	
139032	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
139033	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
139034	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
139035	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments		
139036	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
139037	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
139038	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
139039	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
139040	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
139041	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
139042	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
139043	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
139044	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
139045	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
139046	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
139047	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
139048	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
139049	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
139050	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
139051	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139052	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
139053	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
139054	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
139055	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
139056	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
139057	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
139058	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
139059	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
139060	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
139061	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
139062	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
139063	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
139064	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
139065	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
139066	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139067	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139068	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139069	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139070	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
139071	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139072	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
139073	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
139074	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139075	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
139076	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
139077	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
139078	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
139079	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139080	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
139081	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
139082	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
139083	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139084	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
139085	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
139086	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
139087	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46174	
139088	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139089	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
139090	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
139091	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
139092	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
139093	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
139094	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Follow-up Action Required?	n	
139095	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
139096	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
139097	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
139098	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
139099	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
139100	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
139101	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
139102	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
139103	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
139104	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
139105	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
139106	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
139107	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
139108	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
139109	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
139110	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
139111	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
139112	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
139113	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
139114	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
139115	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
139116	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
139117	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
139118	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
139119	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
139120	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
139121	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
139122	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
139123	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
139124	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
139125	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
139126	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139127	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
139128	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
139129	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
139130	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
139131	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
139132	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
139133	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
139134	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
139135	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
139136	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
139137	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
139138	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
139139	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	39.0	
139140	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
139141	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
139142	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
139143	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
139144	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
139145	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
139146	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
139147	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
139148	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
139149	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
139150	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments		
139151	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
139152	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
139153	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	9	
139154	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
139155	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
139156	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
139157	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
139158	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	2	
139159	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
139160	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
139161	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
139162	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	185.0	
139163	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	179.0	
139164	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	175.0	
139165	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
139166	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
139167	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
139168	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		
139169	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
139170	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
139171	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
139172	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
139173	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
139174	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
139175	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
139176	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	
139177	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
139178	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
139179	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
139180	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
139181	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
139182	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
139183	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
139184	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
139185	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
139186	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
139187	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
139188	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
139189	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
139190	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
139191	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
139192	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139193	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
139194	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
139195	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
139196	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
139197	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
139198	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
139199	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
139200	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
139201	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139202	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	0.0	
139203	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	0.0	
139204	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	0.0	
139205	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
139206	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
139207	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
139208	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	14	
139209	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
139210	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
139211	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
139212	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
139213	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
139214	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
139215	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
139216	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
139217	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
139218	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
139219	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
139220	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
139221	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139222	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139223	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139224	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139225	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
139226	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139227	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
139228	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
139229	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.0714	
139230	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
139231	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139232	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
139233	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
139234	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
139235	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
139236	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
139237	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	40	°C
139238	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Max	48	°C
139239	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
139240	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
139241	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	LTC Totalizer Reading	171.36	kw
139242	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
139243	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
139244	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	General Comments		
139245	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
139246	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
139247	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
139248	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
139249	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
139250	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
139251	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139252	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
139253	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
139254	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
139255	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
139256	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139257	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139258	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
139259	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
139260	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
139261	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
139262	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139263	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	42829	
139264	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
139265	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
139266	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
139267	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139268	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139269	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139270	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
139271	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139272	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
139273	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
139274	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139275	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
139276	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139277	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	13R	
139278	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
139279	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139280	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139281	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
139282	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
139283	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
139284	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139285	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
139286	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
139287	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
139288	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
139289	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
139290	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
139291	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
139292	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
139293	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
139294	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
139295	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	109704	
139296	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
139297	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
139298	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
139299	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
139300	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139301	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139302	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139303	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139304	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
139305	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139306	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
139307	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
139308	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139309	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
139310	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
139311	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
139312	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
139313	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139314	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139315	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
139316	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
139317	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
139318	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	99224	
139319	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
139320	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
139321	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
139322	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139323	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139324	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
139325	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	1L	
139326	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
139327	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
139328	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139329	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
139330	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
139331	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139332	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
139333	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139334	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139335	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139336	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139337	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
139338	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
139339	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
139340	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
139341	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	1900.80	kw
139342	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
139343	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
139344	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
139345	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
139346	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
139347	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139348	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
139349	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
139350	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
139351	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139352	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
139353	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139354	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
139355	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
139356	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
139357	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
139358	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139359	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139360	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
139361	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
139362	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		
139363	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
139364	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
139365	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	2	
139366	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
139367	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	2	
139368	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	355	
139369	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	355	
139370	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139371	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
139372	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
139373	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
139374	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
139375	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
139376	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
139377	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139378	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
139379	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
139380	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139381	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
139382	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139383	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139384	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139385	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139386	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
139387	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
139388	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
139389	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
139390	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.1980	
139391	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
139392	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139393	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
139394	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
139395	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
139396	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
139397	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
139398	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	34	°C
139399	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	50	°C
139400	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
139401	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
139402	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
139403	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
139404	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139405	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
139406	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
139407	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
139408	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
139409	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139410	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139411	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
139412	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
139413	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
139414	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	95358	
139415	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139416	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
139417	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
139418	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
139419	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139420	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	43178	
139421	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	2727	
139422	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		
139423	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
139424	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
139425	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
139426	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139427	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	General Comments		
139428	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
139429	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
139430	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
139431	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
139432	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
139433	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
139434	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
139435	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
139436	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
139437	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	n	
139438	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
139439	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
139440	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
139441	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
139442	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
139443	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
139444	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
139445	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
139446	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
139447	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
139448	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
139449	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
139450	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
139451	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139452	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
139453	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
139454	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139455	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139456	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
139457	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
139458	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
139459	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
139460	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139461	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
139462	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
139463	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
139464	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
139465	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
139466	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
139467	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
139468	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		sub is out of service.
139469	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
139470	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
139471	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
139472	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
139473	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
139474	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
139475	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
139476	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
139477	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
139478	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
139479	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
139480	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
139481	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
139482	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
139483	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
139484	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
139485	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
139486	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
139487	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
139488	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
139489	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
139490	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
139491	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
139492	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
139493	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
139494	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
139495	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
139496	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
139497	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
139498	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
139499	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
139500	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	510	
139501	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	510	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139502	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	0	
139503	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
139504	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
139505	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139506	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
139507	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments	Contractors in control house doing work.	
139508	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
139509	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
139510	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
139511	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
139512	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
139513	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
139514	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
139515	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
139516	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
139517	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	941	
139518	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	9L	
139519	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
139520	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	4L	
139521	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
139522	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	2729	
139523	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
139524	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
139525	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
139526	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	540	
139527	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
139528	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	5L	
139529	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	1R	
139530	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
139531	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
139532	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	70379	
139533	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
139534	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
139535	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
139536	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
139537	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
139538	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
139539	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
139540	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments		
139541	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
139542	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
139543	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
139544	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
139545	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	None	
139546	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
139547	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
139548	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	70379	
139549	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
139550	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
139551	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
139552	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
139553	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
139554	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
139555	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
139556	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
139557	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	68520	
139558	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	68520	
139559	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
139560	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
139561	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
139562	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
139563	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
139564	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	*C
139565	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	*C
139566	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3926	
139567	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
139568	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
139569	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
139570	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
139571	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
139572	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139573	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139574	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
139575	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	45	*C
139576	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	25	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139577	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
139578	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
139579	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
139580	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
139581	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
139582	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
139583	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
139584	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
139585	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139586	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	0	
139587	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
139588	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
139589	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
139590	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
139591	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
139592	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
139593	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
139594	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
139595	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments		
139596	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
139597	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
139598	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
139599	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
139600	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
139601	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
139602	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
139603	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
139604	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
139605	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
139606	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
139607	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
139608	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
139609	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
139610	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	50	*C
139611	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	30	*C
139612	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
139613	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	200.00	
139614	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
139615	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
139616	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
139617	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
139618	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
139619	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
139620	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
139621	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
139622	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
139623	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
139624	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
139625	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
139626	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
139627	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
139628	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
139629	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
139630	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
139631	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
139632	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
139633	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
139634	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
139635	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
139636	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
139637	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139638	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
139639	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
139640	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139641	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
139642	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
139643	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.0	
139644	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
139645	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.0	
139646	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
139647	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
139648	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
139649	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
139650	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
139651	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139652	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
139653	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
139654	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Operations Counter	31	
139655	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
139656	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
139657	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
139658	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
139659	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
139660	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
139661	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
139662	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
139663	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
139664	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
139665	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
139666	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
139667	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
139668	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
139669	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
139670	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
139671	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
139672	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments	Some of fence fabric and post is rusty.	
139673	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
139674	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
139675	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
139676	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
139677	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
139678	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
139679	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
139680	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
139681	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
139682	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
139683	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
139684	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
139685	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139686	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	45545	
139687	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
139688	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
139689	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
139690	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
139691	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139692	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
139693	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
139694	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
139695	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
139696	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139697	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
139698	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
139699	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139700	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
139701	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
139702	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139703	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139704	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139705	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139706	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
139707	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
139708	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
139709	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	1	
139710	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
139711	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
139712	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
139713	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
139714	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
139715	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
139716	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
139717	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
139718	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
139719	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
139720	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
139721	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
139722	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
139723	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
139724	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
139725	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
139726	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139727	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
139728	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
139729	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
139730	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
139731	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
139732	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
139733	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
139734	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
139735	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139736	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139737	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139738	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
139739	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3230	
139740	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
139741	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Present	36	°C
139742	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Top Oil Temperature Max	49	°C
139743	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
139744	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
139745	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
139746	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
139747	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
139748	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
139749	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
139750	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
139751	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
139752	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2325.60	kw
139753	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
139754	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
139755	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
139756	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
139757	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
139758	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
139759	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
139760	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
139761	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
139762	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
139763	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
139764	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
139765	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
139766	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
139767	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
139768	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
139769	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
139770	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139771	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139772	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
139773	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
139774	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
139775	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
139776	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
139777	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
139778	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
139779	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
139780	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
139781	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
139782	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
139783	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
139784	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
139785	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
139786	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
139787	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
139788	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
139789	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
139790	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
139791	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
139792	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
139793	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
139794	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
139795	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
139796	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
139797	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
139798	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
139799	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
139800	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
139801	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139802	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
139803	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
139804	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	All Connections OK?	y	
139805	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	Follow-up Action Required?	n	
139806	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	General Comments	sub is out of service	
139807	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	LTC Operation Checked?	n	
139808	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
139809	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
139810	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
139811	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	LTC000854	LTCControl	532-1	LTC Control Insp	VRR Time Delay	30	Seconds
139812	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
139813	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	96307	
139814	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
139815	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
139816	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
139817	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
139818	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
139819	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	50	°C
139820	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139821	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
139822	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
139823	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
139824	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
139825	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
139826	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
139827	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
139828	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
139829	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
139830	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
139831	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
139832	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
139833	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
139834	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
139835	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
139836	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
139837	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
139838	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
139839	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
139840	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
139841	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
139842	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
139843	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
139844	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
139845	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
139846	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
139847	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
139848	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
139849	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
139850	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
139851	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
139852	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
139853	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
139854	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
139855	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
139856	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
139857	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
139858	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
139859	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
139860	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
139861	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
139862	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
139863	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
139864	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
139865	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
139866	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
139867	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
139868	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
139869	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	
139870	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	0.0	
139871	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	0.0	
139872	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	0.0	
139873	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
139874	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
139875	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
139876	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	3	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
139877	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
139878	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
139879	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
139880	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
139881	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
139882	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
139883	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
139884	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
139885	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
139886	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
139887	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
139888	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
139889	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
139890	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
139891	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
139892	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
139893	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
139894	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
139895	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
139896	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
139897	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
139898	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
139899	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments	sub is out of service.	
139900	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
139901	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
139902	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
139903	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
139904	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
139905	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
139906	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
139907	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
139908	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
139909	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
139910	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
139911	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
139912	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
139913	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
139914	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
139915	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
139916	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
139917	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
139918	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
139919	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
139920	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.0	
139921	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
139922	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
139923	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
139924	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
139925	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
139926	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
139927	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
139928	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	164	
139929	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
139930	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
139931	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
139932	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
139933	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
139934	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
139935	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
139936	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
139937	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
139938	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
139939	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
139940	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
139941	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
139942	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
139943	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
139944	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
139945	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
139946	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
139947	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
139948	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
139949	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
139950	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
139951	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
139952	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
139953	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
139954	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
139955	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
139956	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
139957	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
139958	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
139959	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
139960	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
139961	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
139962	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
139963	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
139964	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments	sub is out of service	
139965	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
139966	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
139967	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
139968	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
139969	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	467	
139970	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	467	
139971	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	2	
139972	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	2	
139973	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
139974	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
139975	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
139976	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
139977	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
139978	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments		
139979	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
139980	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
139981	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
139982	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
139983	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
139984	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
139985	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
139986	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
139987	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
139988	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
139989	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments	Contractors on site	
139990	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
139991	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
139992	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
139993	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
139994	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
139995	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
139996	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
139997	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
139998	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
139999	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
140000	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
140001	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140002	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
140003	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140004	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
140005	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
140006	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
140007	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
140008	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	11	
140009	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140010	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140011	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140012	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	0.0	
140013	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	0.0	
140014	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	0.0	
140015	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
140016	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140017	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140018	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140019	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140020	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140021	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140022	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
140023	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140024	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
140025	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
140026	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140027	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
140028	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
140029	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
140030	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
140031	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140032	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140033	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
140034	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
140035	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
140036	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
140037	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
140038	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
140039	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Operations Counter	299	
140040	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
140041	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	14	
140042	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140043	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140044	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
140045	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140046	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	80.0	
140047	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
140048	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
140049	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
140050	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
140051	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	52663	
140052	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	96.0	
140053	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	84.0	
140054	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
140055	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140056	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140057	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140058	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140059	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140060	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
140061	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
140062	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	52652	
140063	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
140064	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
140065	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
140066	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
140067	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	1	
140068	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140069	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations This Read Vac	1	
140070	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140071	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	10	
140072	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	219	
140073	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	219	
140074	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	10	
140075	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	1	
140076	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	12.17	
140077	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	6.09	
140078	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	6.09	
140079	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A Ø	2	
140080	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B Ø	0	
140081	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C Ø	0	
140082	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
140083	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	2	
140084	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
140085	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
140086	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
140087	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	0	
140088	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
140089	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
140090	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
140091	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
140092	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
140093	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments		
140094	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
140095	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
140096	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
140097	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140098	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	1	
140099	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
140100	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
140101	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140102	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
140103	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
140104	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
140105	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
140106	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
140107	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
140108	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
140109	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
140110	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140111	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
140112	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
140113	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140114	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	270.0	
140115	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	270.0	
140116	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	273.0	
140117	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
140118	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
140119	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
140120	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	0	
140121	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
140122	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
140123	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
140124	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
140125	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
140126	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
140127	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
140128	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
140129	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
140130	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
140131	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
140132	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
140133	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
140134	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
140135	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	General Comments		
140136	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
140137	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	697	
140138	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
140139	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	15L	
140140	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	8L	
140141	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
140142	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	11L	
140143	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments		
140144	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	9	
140145	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140146	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140147	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140148	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	17.4	
140149	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	0.0	
140150	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	25.0	
140151	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
140152	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140153	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140154	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140155	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140156	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140157	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140158	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140159	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140160	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140161	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	
140162	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
140163	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
140164	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
140165	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
140166	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
140167	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
140168	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
140169	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
140170	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments		
140171	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
140172	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
140173	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
140174	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
140175	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
140176	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140177	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
140178	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
140179	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
140180	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
140181	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
140182	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
140183	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
140184	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
140185	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
140186	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
140187	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
140188	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
140189	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
140190	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
140191	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
140192	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
140193	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
140194	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
140195	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
140196	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
140197	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
140198	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140199	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140200	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140201	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140202	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140203	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140204	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140205	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140206	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140207	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
140208	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	16.0	
140209	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	21.0	
140210	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	27.0	
140211	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
140212	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
140213	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		
140214	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
140215	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
140216	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
140217	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
140218	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
140219	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
140220	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
140221	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
140222	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
140223	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
140224	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
140225	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
140226	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
140227	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
140228	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
140229	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	
140230	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
140231	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
140232	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
140233	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
140234	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
140235	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
140236	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
140237	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
140238	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
140239	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
140240	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments		
140241	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
140242	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	688	
140243	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	688	
140244	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations This Read Vac	4	
140245	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140246	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	0	
140247	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
140248	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
140249	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
140250	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
140251	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140252	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	2	
140253	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140254	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140255	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140256	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTC000396	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
140257	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
140258	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
140259	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
140260	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
140261	10/14/2019 10:13	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
140262	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
140263	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
140264	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
140265	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
140266	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
140267	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
140268	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
140269	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
140270	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
140271	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
140272	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
140273	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
140274	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
140275	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
140276	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
140277	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
140278	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTC000396	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
140279	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments		
140280	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	LTC000396	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
140281	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
140282	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
140283	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	1	
140284	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
140285	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
140286	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
140287	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
140288	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
140289	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
140290	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
140291	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTC000654	LTCControl	444-3	LTC Control Insp	General Comments		
140292	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
140293	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	LTC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
140294	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
140295	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
140296	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
140297	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
140298	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
140299	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
140300	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
140301	10/11/2019 14:56	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
140302	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
140303	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
140304	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
140305	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
140306	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
140307	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
140308	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
140309	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
140310	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
140311	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
140312	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140313	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
140314	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
140315	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
140316	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
140317	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
140318	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140319	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
140320	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140321	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
140322	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
140323	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
140324	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
140325	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
140326	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140327	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
140328	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
140329	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140330	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
140331	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
140332	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140333	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
140334	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140335	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140336	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
140337	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
140338	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
140339	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
140340	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
140341	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
140342	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
140343	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
140344	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
140345	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
140346	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140347	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140348	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
140349	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
140350	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
140351	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
140352	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
140353	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140354	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
140355	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140356	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
140357	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
140358	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
140359	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
140360	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
140361	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
140362	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
140363	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments	gauge broke	
140364	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
140365	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140366	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140367	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140368	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
140369	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
140370	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
140371	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
140372	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
140373	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140374	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
140375	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
140376	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
140377	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
140378	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments	sub is out of service.	
140379	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
140380	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
140381	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
140382	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
140383	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
140384	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
140385	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
140386	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
140387	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
140388	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
140389	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
140390	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
140391	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
140392	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
140393	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
140394	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
140395	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
140396	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
140397	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
140398	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
140399	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
140400	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
140401	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140402	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
140403	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
140404	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
140405	10/10/2019 10:42	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
140406	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
140407	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
140408	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
140409	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
140410	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
140411	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
140412	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
140413	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
140414	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
140415	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
140416	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	.0440	
140417	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
140418	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
140419	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
140420	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
140421	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
140422	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140423	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
140424	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140425	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
140426	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
140427	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
140428	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
140429	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	12	
140430	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140431	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140432	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140433	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	0.0	
140434	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	0.0	
140435	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	0.0	
140436	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
140437	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140438	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140439	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140440	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140441	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140442	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140443	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	20	*C
140444	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	33	*C
140445	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
140446	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
140447	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	422.40	kw
140448	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
140449	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments		
140450	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments		
140451	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140452	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
140453	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
140454	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	81	*F
140455	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
140456	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
140457	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
140458	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
140459	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
140460	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
140461	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
140462	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
140463	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
140464	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
140465	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
140466	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
140467	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
140468	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
140469	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	257939	
140470	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
140471	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
140472	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
140473	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
140474	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
140475	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
140476	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140477	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
140478	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
140479	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
140480	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
140481	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	General Comments		
140482	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	y	
140483	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
140484	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
140485	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	LTC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
140486	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
140487	10/10/2019 12:02	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
140488	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
140489	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140490	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
140491	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
140492	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
140493	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140494	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
140495	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140496	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140497	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
140498	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
140499	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
140500	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
140501	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
140502	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
140503	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
140504	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
140505	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
140506	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	425328	
140507	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	425332	
140508	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
140509	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	7L	
140510	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	4R	
140511	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	14L	
140512	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	1707	
140513	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
140514	10/11/2019 7:20	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
140515	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
140516	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
140517	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	468	
140518	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140519	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
140520	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
140521	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
140522	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
140523	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
140524	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
140525	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
140526	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
140527	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	LTC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
140528	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
140529	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140530	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
140531	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140532	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140533	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
140534	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
140535	10/10/2019 10:04	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
140536	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
140537	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
140538	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
140539	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
140540	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
140541	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
140542	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
140543	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	468	
140544	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	2	
140545	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	2	
140546	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
140547	10/10/2019 16:41	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
140548	10/10/2019 11:15	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
140549	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
140550	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
140551	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140552	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
140553	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
140554	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
140555	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
140556	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
140557	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140558	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
140559	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140560	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
140561	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
140562	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
140563	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
140564	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
140565	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
140566	10/10/2019 10:50	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
140567	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
140568	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
140569	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
140570	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
140571	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
140572	10/10/2019 15:27	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
140573	10/10/2019 15:26	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
140574	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
140575	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
140576	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
140577	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
140578	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
140579	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
140580	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
140581	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
140582	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
140583	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
140584	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Vegetation	None	
140585	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
140586	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
140587	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140588	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
140589	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	383	
140590	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	383	
140591	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
140592	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
140593	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
140594	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
140595	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
140596	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
140597	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
140598	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
140599	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
140600	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
140601	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
140602	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
140603	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
140604	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
140605	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
140606	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
140607	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
140608	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
140609	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
140610	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140611	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140612	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140613	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140614	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140615	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140616	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140617	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140618	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140619	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
140620	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
140621	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
140622	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
140623	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
140624	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140625	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140626	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140627	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
140628	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
140629	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
140630	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
140631	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
140632	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
140633	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	General Comments		
140634	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
140635	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
140636	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
140637	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
140638	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
140639	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
140640	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
140641	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations Ground	0	
140642	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Follow-up Action Required?	n	
140643	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Follow-up Action Required?	n	
140644	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Foundation Condition	Good	
140645	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	General Comments		
140646	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	General Comments		
140647	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
140648	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
140649	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
140650	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
140651	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
140652	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
140653	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
140654	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
140655	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
140656	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
140657	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
140658	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
140659	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
140660	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.000	millivolts
140661	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
140662	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
140663	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
140664	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Grounds in Place?	y	
140665	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Heaters (All) Functioning?	y	
140666	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Maintenance Operations	0	
140667	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Moisture and Leak Free?	y	
140668	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AF	193	
140669	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AL	193	
140670	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations This Read Vac	0	
140671	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140672	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Switching Operations	0	
140673	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Tank Paint Condition	Good	
140674	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Unknown Operations	0	
140675	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
140676	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
140677	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
140678	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
140679	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
140680	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
140681	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
140682	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
140683	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
140684	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
140685	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	LTC0000357	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
140686	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
140687	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
140688	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140689	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
140690	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
140691	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
140692	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
140693	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
140694	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
140695	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
140696	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
140697	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
140698	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	431	
140699	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	431	
140700	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
140701	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
140702	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
140703	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
140704	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
140705	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
140706	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
140707	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140708	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140709	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
140710	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	9 Month Operations	36	
140711	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
140712	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
140713	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
140714	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
140715	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
140716	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Trash?	y	
140717	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
140718	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
140719	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
140720	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
140721	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
140722	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
140723	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
140724	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
140725	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
140726	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
140727	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	500.0	
140728	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	500.0	
140729	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	520.0	
140730	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140731	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
140732	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
140733	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
140734	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140735	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
140736	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
140737	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
140738	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
140739	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
140740	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
140741	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	*C
140742	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	100	*C
140743	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	*C
140744	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
140745	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
140746	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
140747	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	24	
140748	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	24	
140749	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
140750	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps A Ø	50.0	
140751	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps B Ø	20.0	
140752	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps C Ø	50.0	
140753	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushing Condition	Good	
140754	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140755	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140756	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140757	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140758	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140759	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140760	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140761	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140762	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140763	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations A Ø	0	
140764	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations B Ø	0	
140765	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations C Ø	0	
140766	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
140767	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
140768	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
140769	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
140770	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
140771	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments		
140772	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
140773	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
140774	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
140775	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	*C
140776	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140777	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
140778	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
140779	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
140780	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
140781	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
140782	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
140783	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
140784	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
140785	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
140786	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
140787	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
140788	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
140789	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
140790	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
140791	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
140792	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Unknown Operations	0	
140793	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
140794	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
140795	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
140796	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
140797	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
140798	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
140799	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
140800	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
140801	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
140802	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
140803	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
140804	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
140805	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
140806	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
140807	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
140808	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
140809	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
140810	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
140811	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
140812	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	311	
140813	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	311	
140814	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
140815	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
140816	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
140817	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	0	
140818	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
140819	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	32	
140820	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	32	
140821	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations This Read Vac	0	
140822	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
140823	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
140824	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
140825	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
140826	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
140827	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
140828	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	161506	
140829	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
140830	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
140831	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
140832	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
140833	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
140834	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
140835	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	746	
140836	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	746	
140837	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
140838	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	0	
140839	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
140840	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
140841	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
140842	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
140843	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	10L	
140844	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
140845	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
140846	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
140847	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
140848	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
140849	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
140850	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
140851	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140852	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
140853	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
140854	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
140855	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
140856	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
140857	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
140858	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
140859	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
140860	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
140861	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
140862	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
140863	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
140864	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140865	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140866	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
140867	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
140868	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
140869	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
140870	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
140871	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
140872	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
140873	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
140874	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
140875	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
140876	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"-s
140877	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
140878	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
140879	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	62346	
140880	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	62340	
140881	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
140882	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		
140883	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
140884	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
140885	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
140886	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
140887	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
140888	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
140889	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
140890	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
140891	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	BAT000113	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
140892	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
140893	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
140894	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
140895	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
140896	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
140897	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
140898	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"-s
140899	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
140900	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
140901	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
140902	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
140903	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
140904	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
140905	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
140906	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BAT000114	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
140907	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
140908	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
140909	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
140910	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
140911	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
140912	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	AB Phase IOC	
140913	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
140914	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
140915	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
140916	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
140917	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
140918	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
140919	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
140920	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140921	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
140922	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
140923	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140924	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
140925	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
140926	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
140927	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
140928	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
140929	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
140930	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	%
140931	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
140932	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
140933	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
140934	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
140935	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
140936	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
140937	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
140938	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
140939	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
140940	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
140941	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140942	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
140943	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
140944	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140945	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	404.0	
140946	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	412.0	
140947	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	401.0	
140948	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
140949	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
140950	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
140951	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
140952	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
140953	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
140954	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
140955	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	298	
140956	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	6L	
140957	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
140958	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	2L	
140959	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
140960	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
140961	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
140962	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
140963	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
140964	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
140965	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
140966	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
140967	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
140968	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
140969	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
140970	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
140971	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
140972	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
140973	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
140974	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
140975	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
140976	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
140977	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
140978	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
140979	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
140980	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
140981	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
140982	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
140983	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
140984	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
140985	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
140986	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
140987	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
140988	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
140989	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
140990	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
140991	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
140992	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
140993	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
140994	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
140995	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
140996	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
140997	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
140998	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
140999	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
141000	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	General Comments		
141001	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
141002	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	100	°C
141003	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
141004	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	90	°C
141005	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
141006	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
141007	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141008	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
141009	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
141010	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
141011	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
141012	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
141013	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
141014	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
141015	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
141016	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
141017	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
141018	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
141019	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
141020	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
141021	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
141022	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
141023	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
141024	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
141025	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
141026	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
141027	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
141028	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
141029	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
141030	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
141031	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
141032	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
141033	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
141034	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
141035	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
141036	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
141037	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
141038	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
141039	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
141040	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
141041	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
141042	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
141043	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
141044	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations	11	
141045	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141046	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141047	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141048	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps A Ø	0.0	
141049	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps B Ø	0.0	
141050	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
141051	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141052	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141053	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141054	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
141055	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
141056	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
141057	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141058	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
141059	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
141060	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141061	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
141062	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments	WindingTemp gauge max temp, will not reset. Gauge needs to be fixed	
141063	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
141064	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	55	°C
141065	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
141066	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
141067	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
141068	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
141069	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
141070	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
141071	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141072	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
141073	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
141074	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
141075	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
141076	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141077	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
141078	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
141079	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
141080	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
141081	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
141082	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
141083	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
141084	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	General Comments		
141085	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
141086	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141087	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
141088	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
141089	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
141090	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141091	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
141092	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
141093	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
141094	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
141095	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
141096	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
141097	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
141098	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
141099	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141100	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
141101	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
141102	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
141103	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
141104	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
141105	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
141106	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
141107	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
141108	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
141109	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
141110	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
141111	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
141112	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
141113	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
141114	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
141115	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
141116	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
141117	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	General Comments		
141118	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
141119	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
141120	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
141121	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
141122	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3075	
141123	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3075	
141124	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
141125	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
141126	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
141127	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
141128	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
141129	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141130	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
141131	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141132	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
141133	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
141134	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1375	psi
141135	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
141136	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
141137	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
141138	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments		
141139	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
141140	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141141	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
141142	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
141143	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141144	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
141145	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
141146	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141147	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
141148	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
141149	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
141150	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
141151	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141152	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
141153	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments		
141154	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
141155	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
141156	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
141157	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
141158	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
141159	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
141160	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
141161	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
141162	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments		
141163	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
141164	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
141165	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
141166	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
141167	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
141168	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
141169	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
141170	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
141171	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
141172	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
141173	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
141174	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
141175	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
141176	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
141177	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
141178	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
141179	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
141180	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
141181	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141182	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141183	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141184	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
141185	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
141186	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
141187	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
141188	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
141189	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
141190	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
141191	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
141192	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
141193	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
141194	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
141195	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
141196	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
141197	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
141198	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
141199	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
141200	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
141201	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	32	*C
141202	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	42	*C
141203	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	.7230	
141204	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
141205	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141206	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
141207	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
141208	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
141209	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141210	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
141211	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141212	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	35	*C
141213	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	46	*C
141214	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
141215	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
141216	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	6940.80	kw
141217	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
141218	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		
141219	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
141220	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141221	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
141222	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
141223	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141224	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
141225	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
141226	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141227	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
141228	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
141229	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
141230	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
141231	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141232	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141233	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141234	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141235	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141236	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141237	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141238	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141239	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141240	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
141241	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	15.0	
141242	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	18.0	
141243	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	16.0	
141244	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141245	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141246	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141247	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	2	
141248	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
141249	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
141250	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	0	
141251	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141252	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations This Read Vac	0	
141253	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	123	
141254	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	123	
141255	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
141256	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
141257	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
141258	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
141259	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
141260	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
141261	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
141262	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
141263	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
141264	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
141265	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	0	
141266	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
141267	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	0	
141268	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141269	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141270	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141271	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141272	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141273	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141274	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141275	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141276	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141277	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
141278	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	27.0	
141279	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	24.0	
141280	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	24.0	
141281	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141282	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141283	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141284	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	1	
141285	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
141286	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
141287	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
141288	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
141289	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
141290	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
141291	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
141292	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
141293	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
141294	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
141295	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
141296	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
141297	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
141298	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
141299	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
141300	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
141301	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141302	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
141303	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
141304	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
141305	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
141306	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141307	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141308	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	9.37	
141309	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141310	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.37	
141311	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	2	
141312	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
141313	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
141314	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
141315	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
141316	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
141317	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
141318	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
141319	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
141320	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
141321	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
141322	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
141323	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	113	
141324	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	113	
141325	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
141326	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141327	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
141328	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
141329	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
141330	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
141331	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
141332	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
141333	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
141334	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1794	
141335	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
141336	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
141337	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9R	
141338	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
141339	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
141340	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	92249	
141341	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	92249	
141342	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
141343	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments		
141344	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
141345	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
141346	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
141347	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141348	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141349	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141350	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	72.0	
141351	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	72.0	
141352	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
141353	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
141354	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141355	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141356	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141357	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141358	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141359	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141360	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141361	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141362	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141363	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
141364	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
141365	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
141366	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
141367	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
141368	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
141369	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
141370	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
141371	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
141372	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
141373	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
141374	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
141375	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	942	
141376	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	942	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141377	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
141378	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141379	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
141380	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
141381	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
141382	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
141383	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141384	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
141385	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
141386	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
141387	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
141388	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	258	
141389	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	258	
141390	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
141391	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
141392	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
141393	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
141394	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
141395	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
141396	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
141397	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
141398	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
141399	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
141400	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
141401	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
141402	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
141403	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
141404	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
141405	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
141406	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
141407	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
141408	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
141409	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
141410	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
141411	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
141412	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
141413	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
141414	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
141415	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
141416	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
141417	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
141418	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
141419	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
141420	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
141421	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
141422	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
141423	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
141424	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
141425	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
141426	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
141427	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
141428	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
141429	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
141430	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
141431	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
141432	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	24	
141433	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141434	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141435	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141436	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
141437	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	84.0	
141438	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	108.0	
141439	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
141440	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141441	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141442	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
141443	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141444	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141445	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
141446	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
141447	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
141448	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
141449	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
141450	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141451	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141452	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
141453	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
141454	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
141455	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
141456	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141457	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141458	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141459	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	34	°C
141460	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	52	°C
141461	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
141462	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
141463	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
141464	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Unknown Operations	0	
141465	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Switching Operations	0	
141466	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations This Read AM	0	
141467	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AL	542	
141468	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AF	542	
141469	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Maintenance Operations	0	
141470	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
141471	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	General Comments		
141472	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	General Comments		
141473	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Follow-up Action Required?	n	
141474	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
141475	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations Ground	0	
141476	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations C Ø	0	
141477	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	38	°C
141478	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	48	°C
141479	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	38	°C
141480	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	48	°C
141481	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
141482	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
141483	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
141484	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141485	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
141486	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
141487	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141488	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
141489	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
141490	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141491	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
141492	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
141493	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
141494	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
141495	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141496	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
141497	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
141498	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
141499	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations B Ø	0	
141500	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations A Ø	0	
141501	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
141502	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
141503	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
141504	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
141505	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	200.0	
141506	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	120.0	
141507	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	100.0	
141508	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141509	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141510	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141511	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	8	
141512	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
141513	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
141514	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
141515	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141516	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141517	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
141518	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
141519	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141520	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
141521	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
141522	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141523	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
141524	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments		
141525	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
141526	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
141527	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	18	
141528	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141529	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141530	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141531	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
141532	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
141533	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
141534	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141535	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
141536	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
141537	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141538	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
141539	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141540	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	36	°C
141541	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	49	°C
141542	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
141543	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
141544	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
141545	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
141546	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
141547	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
141548	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments		
141549	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
141550	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
141551	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
141552	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141553	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141554	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141555	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
141556	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
141557	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
141558	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	9 Months Operations	19	
141559	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141560	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141561	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141562	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps A Ø	165.0	
141563	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps B Ø	200.0	
141564	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
141565	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
141566	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
141567	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
141568	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
141569	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
141570	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	General Comments		
141571	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
141572	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCCControl	832-1	LTC Control Insp	All Connections OK?	y	
141573	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps C Ø	180.0	
141574	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
141575	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
141576	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
141577	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
141578	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations A Ø	0	
141579	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations B Ø	0	
141580	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations C Ø	0	
141581	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations Ground	0	
141582	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
141583	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Follow-up Action Required?	n	
141584	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	General Comments		
141585	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	General Comments	vc change with no targets	
141586	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
141587	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Maintenance Operations	0	
141588	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AF	502	
141589	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	502	
141590	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations This Read AM	0	
141591	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
141592	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
141593	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
141594	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
141595	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
141596	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
141597	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
141598	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
141599	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
141600	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
141601	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
141602	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	35	°C
141603	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	48	°C
141604	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141605	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
141606	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
141607	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
141608	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141609	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
141610	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
141611	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
141612	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	545.40	kw
141613	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Months Operations	19	
141614	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141615	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141616	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141617	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps A Ø	160.0	
141618	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps B Ø	180.0	
141619	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps C Ø	150.0	
141620	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
141621	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
141622	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
141623	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
141624	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations A Ø	0	
141625	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations B Ø	0	
141626	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations C Ø	0	
141627	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
141628	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
141629	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
141630	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
141631	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141632	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
141633	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141634	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
141635	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
141636	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141637	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
141638	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3030	
141639	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations Ground	0	
141640	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
141641	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Follow-up Action Required?	n	
141642	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	General Comments		
141643	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	General Comments	vc change no targets	
141644	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
141645	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Maintenance Operations	0	
141646	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AF	534	
141647	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AL	534	
141648	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations This Read AM	0	
141649	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Switching Operations	0	
141650	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Unknown Operations	0	
141651	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
141652	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
141653	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
141654	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
141655	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	930	
141656	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
141657	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	7L	
141658	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	2R	
141659	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	1L	
141660	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
141661	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	71610	
141662	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	71610	
141663	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
141664	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
141665	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
141666	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
141667	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
141668	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
141669	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	1	
141670	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141671	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations This Read Vac	1	
141672	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	55	
141673	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	55	
141674	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
141675	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
141676	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141677	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
141678	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
141679	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
141680	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
141681	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
141682	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
141683	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
141684	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	0	
141685	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	0	
141686	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
141687	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141688	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141689	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141690	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141691	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141692	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141693	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141694	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141695	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141696	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
141697	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
141698	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
141699	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	
141700	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
141701	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
141702	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
141703	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
141704	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments		
141705	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	
141706	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	9	
141707	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
141708	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	290	
141709	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	290	
141710	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations This Read Vac	9	
141711	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141712	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	0	
141713	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
141714	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
141715	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
141716	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
141717	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
141718	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
141719	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
141720	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
141721	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
141722	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
141723	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
141724	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
141725	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments		
141726	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
141727	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
141728	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
141729	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
141730	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
141731	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
141732	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
141733	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
141734	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
141735	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
141736	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
141737	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141738	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
141739	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
141740	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141741	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
141742	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	00170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
141743	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
141744	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
141745	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
141746	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
141747	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
141748	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	851	
141749	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
141750	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
141751	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141752	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
141753	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
141754	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	68166	
141755	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	68166	
141756	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
141757	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments		
141758	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
141759	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
141760	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
141761	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
141762	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
141763	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
141764	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
141765	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
141766	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
141767	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
141768	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
141769	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
141770	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
141771	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
141772	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
141773	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
141774	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43885	
141775	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
141776	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
141777	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
141778	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
141779	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
141780	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
141781	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
141782	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
141783	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
141784	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
141785	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
141786	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
141787	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
141788	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
141789	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
141790	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
141791	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
141792	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
141793	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	
141794	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	0	
141795	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
141796	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
141797	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
141798	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
141799	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
141800	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
141801	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
141802	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
141803	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
141804	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
141805	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	216	
141806	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	216	
141807	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations This Read Vac	0	
141808	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
141809	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	0	
141810	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
141811	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
141812	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
141813	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
141814	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
141815	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
141816	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
141817	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
141818	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42201	
141819	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
141820	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
141821	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
141822	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
141823	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	160.0	
141824	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	216.0	
141825	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	170.0	
141826	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141827	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141828	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
141829	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141830	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141831	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141832	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141833	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141834	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141835	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141836	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
141837	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
141838	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
141839	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
141840	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
141841	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
141842	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
141843	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0060	
141844	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
141845	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
141846	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
141847	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
141848	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
141849	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
141850	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
141851	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
141852	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
141853	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
141854	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
141855	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
141856	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
141857	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
141858	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
141859	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
141860	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
141861	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
141862	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
141863	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
141864	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
141865	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
141866	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
141867	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	2	
141868	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141869	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141870	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141871	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
141872	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
141873	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
141874	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
141875	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
141876	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
141877	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
141878	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
141879	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
141880	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
141881	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
141882	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
141883	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42229	
141884	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
141885	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
141886	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
141887	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
141888	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
141889	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
141890	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
141891	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
141892	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	2	
141893	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
141894	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
141895	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
141896	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	40.0	
141897	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	40.0	
141898	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	40.0	
141899	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
141900	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
141901	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141902	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
141903	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
141904	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
141905	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
141906	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
141907	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
141908	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
141909	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	0	
141910	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
141911	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
141912	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
141913	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
141914	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
141915	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments	Distribution pads crumbling on 660	
141916	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
141917	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
141918	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
141919	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
141920	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
141921	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
141922	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
141923	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments		
141924	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments		
141925	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
141926	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	237	
141927	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	237	
141928	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	0	
141929	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
141930	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Unknown Operations	0	
141931	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
141932	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
141933	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
141934	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
141935	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
141936	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
141937	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
141938	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	General Comments		
141939	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
141940	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
141941	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
141942	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
141943	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
141944	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
141945	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
141946	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
141947	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	General Comments		
141948	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
141949	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
141950	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
141951	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
141952	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
141953	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
141954	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
141955	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
141956	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
141957	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
141958	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
141959	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
141960	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
141961	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
141962	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
141963	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
141964	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
141965	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
141966	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
141967	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	*F
141968	10/9/2019 12:35	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
141969	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.9	VDC
141970	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.9	VDC
141971	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
141972	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
141973	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
141974	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
141975	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	85	
141976	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.4	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
141977	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.7	
141978	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.0	
141979	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	76	
141980	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
141981	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
141982	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	87	
141983	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
141984	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
141985	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
141986	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
141987	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
141988	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
141989	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
141990	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
141991	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
141992	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	
141993	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
141994	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
141995	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
141996	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
141997	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
141998	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
141999	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	708	
142000	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	708	
142001	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
142002	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142003	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142004	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
142005	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
142006	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
142007	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	173	
142008	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	173	
142009	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations This Read Vac	1	
142010	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
142011	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	1	
142012	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
142013	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
142014	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
142015	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
142016	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
142017	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
142018	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
142019	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
142020	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
142021	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
142022	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments		
142023	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
142024	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
142025	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
142026	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
142027	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
142028	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
142029	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
142030	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
142031	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
142032	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
142033	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
142034	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
142035	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	2	
142036	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
142037	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
142038	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
142039	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	40.0	
142040	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	40.0	
142041	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	40.0	
142042	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
142043	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
142044	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
142045	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
142046	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
142047	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
142048	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
142049	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
142050	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
142051	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142052	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
142053	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
142054	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
142055	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
142056	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
142057	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
142058	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
142059	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
142060	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
142061	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
142062	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
142063	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
142064	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
142065	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
142066	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
142067	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
142068	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
142069	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
142070	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
142071	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
142072	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
142073	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
142074	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142075	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142076	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142077	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142078	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
142079	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
142080	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
142081	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142082	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142083	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142084	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
142085	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
142086	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
142087	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
142088	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
142089	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
142090	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
142091	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
142092	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
142093	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC0000453	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
142094	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000433	LTCCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
142095	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000433	LTCCControl	HC-TRANS 2	LTC Control Insp	General Comments		
142096	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000433	LTCCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
142097	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LTC0000433	LTCCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
142098	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
142099	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
142100	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
142101	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
142102	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
142103	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
142104	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
142105	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
142106	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
142107	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
142108	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments		
142109	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
142110	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
142111	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
142112	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
142113	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142114	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142115	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
142116	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	143	
142117	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	143	
142118	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
142119	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
142120	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
142121	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
142122	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
142123	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
142124	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
142125	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
142126	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142127	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142128	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142129	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142130	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142131	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	140.0	
142132	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	140.0	
142133	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	140.0	
142134	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142135	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142136	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142137	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	63	
142138	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Unknown Operations	0	
142139	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Tank Paint Condition	Good	
142140	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Switching Operations	3	
142141	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
142142	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
142143	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
142144	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
142145	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
142146	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
142147	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
142148	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
142149	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
142150	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
142151	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
142152	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments		
142153	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
142154	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
142155	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
142156	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
142157	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
142158	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
142159	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
142160	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	9	
142161	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142162	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142163	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142164	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	200.0	
142165	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	170.0	
142166	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	190.0	
142167	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142168	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142169	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142170	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142171	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
142172	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
142173	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
142174	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
142175	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
142176	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
142177	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
142178	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
142179	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
142180	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
142181	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	6	
142182	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	6	
142183	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
142184	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
142185	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
142186	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142187	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142188	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	0	
142189	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142190	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142191	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142192	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	60.0	
142193	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	100.0	
142194	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	90.0	
142195	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142196	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142197	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142198	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142199	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
142200	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
142201	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142202	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
142203	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
142204	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
142205	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
142206	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
142207	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
142208	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
142209	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	584	
142210	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	584	
142211	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
142212	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
142213	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
142214	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
142215	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	105	
142216	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	105	
142217	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
142218	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
142219	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
142220	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
142221	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
142222	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
142223	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
142224	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
142225	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
142226	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
142227	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.9	amps
142228	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
142229	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
142230	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments		
142231	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AF	117	
142232	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Moisture and Leak Free?	y	
142233	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Maintenance Operations	0	
142234	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
142235	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Grounds in Place?	y	
142236	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	General Comments		
142237	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
142238	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
142239	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	60	°C
142240	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
142241	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
142242	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
142243	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
142244	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
142245	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
142246	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
142247	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
142248	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
142249	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	General Comments		
142250	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Foundation Condition	Good	
142251	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Follow-up Action Required?	n	
142252	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Follow-up Action Required?	n	
142253	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations Ground	0	
142254	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations C Ø	0	
142255	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations B Ø	0	
142256	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations A Ø	0	
142257	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
142258	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
142259	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
142260	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
142261	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
142262	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
142263	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
142264	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
142265	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
142266	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushing Condition	Good	
142267	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps C Ø	50.0	
142268	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps B Ø	30.0	
142269	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps A Ø	25.0	
142270	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
142271	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
142272	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
142273	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	9 Month Operations	0	
142274	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
142275	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
142276	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142277	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
142278	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
142279	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
142280	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
142281	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
142282	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments		
142283	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
142284	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
142285	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
142286	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
142287	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9.60	kw
142288	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
142289	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
142290	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
142291	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
142292	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
142293	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
142294	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations This Read Vac	3	
142295	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AL	178	
142296	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AF	178	
142297	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Moisture and Leak Free?	y	
142298	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Maintenance Operations	0	
142299	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Heaters (All) Functioning?	y	
142300	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Grounds in Place?	y	
142301	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	General Comments		
142302	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	General Comments		
142303	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Foundation Condition	Good	
142304	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Follow-up Action Required?	n	
142305	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Follow-up Action Required?	n	
142306	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations Ground	0	
142307	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations C Ø	0	
142308	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations B Ø	0	
142309	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations A Ø	0	
142310	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
142311	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
142312	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
142313	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	33	°C
142314	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	45	°C
142315	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.2900	
142316	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
142317	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
142318	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
142319	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
142320	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
142321	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
142322	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
142323	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
142324	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	35	°C
142325	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	45	°C
142326	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
142327	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
142328	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	2784.00	kw
142329	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
142330	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
142331	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
142332	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
142333	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
142334	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	
142335	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
142336	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
142337	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
142338	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
142339	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
142340	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
142341	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
142342	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
142343	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
142344	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
142345	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
142346	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
142347	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
142348	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
142349	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
142350	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
142351	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142352	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
142353	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
142354	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushing Condition	Good	
142355	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps C Ø	115.0	
142356	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps B Ø	115.0	
142357	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps A Ø	120.0	
142358	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
142359	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
142360	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
142361	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	9 Month Operations	56	
142362	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Unknown Operations	0	
142363	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Tank Paint Condition	Good	
142364	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Switching Operations	0	
142365	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
142366	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
142367	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations This Read Vac	0	
142368	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AL	117	
142369	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	LTC000155	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
142370	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
142371	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142372	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
142373	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
142374	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	201	
142375	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	201	
142376	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
142377	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
142378	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
142379	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
142380	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
142381	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
142382	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
142383	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
142384	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
142385	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
142386	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
142387	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
142388	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
142389	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
142390	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	10L	
142391	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
142392	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
142393	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
142394	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
142395	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
142396	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
142397	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	202885	
142398	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
142399	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
142400	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
142401	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
142402	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
142403	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
142404	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
142405	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
142406	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142407	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142408	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	90.0	
142409	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
142410	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
142411	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142412	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142413	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142414	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142415	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
142416	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
142417	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142418	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142419	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142420	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142421	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments		
142422	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142423	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
142424	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
142425	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
142426	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142427	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
142428	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
142429	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
142430	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
142431	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
142432	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
142433	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
142434	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	35.0	
142435	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	39.0	
142436	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	38.0	
142437	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
142438	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
142439	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
142440	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	0	
142441	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
142442	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
142443	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
142444	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
142445	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
142446	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
142447	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
142448	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
142449	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
142450	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
142451	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
142452	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142453	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142454	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
142455	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
142456	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142457	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
142458	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
142459	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142460	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142461	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142462	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	FE000347	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142463	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142464	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142465	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142466	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
142467	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142468	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
142469	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
142470	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
142471	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
142472	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	411420	
142473	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	411420	
142474	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
142475	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5R	
142476	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10R	
142477	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6R	
142478	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	149	
142479	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
142480	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
142481	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
142482	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
142483	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
142484	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
142485	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
142486	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
142487	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
142488	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
142489	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
142490	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
142491	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
142492	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
142493	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
142494	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
142495	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
142496	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
142497	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
142498	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments	#6 AND 4/0 WIRE CUT IN SHORT LENGHTS ALL AROUND STATION. ALL STATION GROUNDS IN PLACE.	
142499	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
142500	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
142501	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142502	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
142503	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
142504	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
142505	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
142506	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
142507	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
142508	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
142509	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
142510	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
142511	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
142512	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
142513	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
142514	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
142515	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
142516	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
142517	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	122	
142518	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	122	
142519	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
142520	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142521	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142522	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
142523	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
142524	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	1	
142525	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
142526	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations This Read Vac	1	
142527	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
142528	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
142529	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	1	
142530	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
142531	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
142532	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
142533	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	198	
142534	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	198	
142535	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
142536	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
142537	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
142538	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
142539	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
142540	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
142541	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
142542	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
142543	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142544	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142545	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
142546	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
142547	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142548	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments		
142549	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
142550	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
142551	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
142552	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
142553	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
142554	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
142555	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142556	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142557	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142558	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
142559	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
142560	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
142561	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
142562	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	y	
142563	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	5R	
142564	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
142565	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
142566	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
142567	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
142568	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	4L	
142569	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
142570	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	1588	
142571	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
142572	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
142573	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
142574	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
142575	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
142576	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142577	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
142578	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	95	
142579	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	95	
142580	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments	3 8ft bulbs need replaced.	
142581	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
142582	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations This Read Vac	0	
142583	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	0	
142584	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
142585	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
142586	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
142587	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
142588	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
142589	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
142590	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
142591	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
142592	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
142593	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
142594	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
142595	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142596	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
142597	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	
142598	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
142599	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
142600	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
142601	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
142602	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
142603	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142604	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142605	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
142606	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
142607	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142608	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
142609	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
142610	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142611	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142612	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142613	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142614	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments	vegetation growing on and through the fence in the upper substation.	
142615	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142616	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	70	*F
142617	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
142618	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
142619	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
142620	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
142621	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
142622	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
142623	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
142624	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
142625	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
142626	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
142627	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
142628	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
142629	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
142630	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
142631	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
142632	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
142633	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
142634	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
142635	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
142636	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
142637	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
142638	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
142639	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
142640	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
142641	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	32183	
142642	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	32183	
142643	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
142644	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1R	
142645	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
142646	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142647	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
142648	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
142649	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	4L	
142650	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	1L	
142651	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142652	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
142653	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
142654	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
142655	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
142656	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
142657	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
142658	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
142659	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	10L	
142660	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
142661	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	568	
142662	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
142663	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
142664	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
142665	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
142666	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
142667	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
142668	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142669	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
142670	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
142671	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
142672	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000814	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
142673	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
142674	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
142675	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
142676	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
142677	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
142678	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
142679	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
142680	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
142681	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
142682	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
142683	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
142684	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
142685	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
142686	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
142687	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
142688	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
142689	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
142690	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
142691	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142692	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
142693	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
142694	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142695	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
142696	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
142697	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
142698	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
142699	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
142700	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
142701	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
142702	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
142703	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
142704	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
142705	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
142706	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	87413	
142707	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	87424	
142708	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
142709	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	8L	
142710	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	3L	
142711	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	12L	
142712	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	841	
142713	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
142714	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
142715	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
142716	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
142717	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
142718	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
142719	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
142720	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
142721	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
142722	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
142723	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
142724	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
142725	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
142726	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142727	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
142728	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
142729	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
142730	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
142731	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
142732	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
142733	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
142734	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
142735	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
142736	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
142737	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
142738	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
142739	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	BAT000813	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
142740	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	75419	
142741	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	75424	
142742	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
142743	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
142744	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
142745	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
142746	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
142747	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
142748	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
142749	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
142750	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
142751	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
142752	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
142753	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
142754	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	.7880	
142755	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
142756	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
142757	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
142758	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
142759	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
142760	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
142761	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
142762	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
142763	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
142764	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
142765	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
142766	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	35	°C
142767	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	55	°C
142768	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
142769	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
142770	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	7564.80	kw
142771	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
142772	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
142773	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
142774	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
142775	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
142776	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
142777	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
142778	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
142779	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
142780	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
142781	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
142782	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
142783	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
142784	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
142785	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments	25 foot wood arm, that is the backside of the double arm of the line is rotten and needs replaced.	
142786	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
142787	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
142788	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
142789	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
142790	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
142791	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
142792	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
142793	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
142794	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
142795	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
142796	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
142797	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
142798	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
142799	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
142800	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
142801	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142802	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
142803	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
142804	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
142805	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
142806	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
142807	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
142808	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.3600	
142809	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
142810	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
142811	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
142812	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
142813	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
142814	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
142815	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
142816	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
142817	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	40	*C
142818	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
142819	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
142820	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	1728.00	kw
142821	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
142822	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
142823	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		
142824	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
142825	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
142826	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
142827	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
142828	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
142829	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
142830	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
142831	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	3	
142832	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
142833	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
142834	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
142835	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
142836	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
142837	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
142838	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
142839	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
142840	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
142841	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
142842	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
142843	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
142844	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
142845	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
142846	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
142847	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
142848	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
142849	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
142850	10/9/2019 13:49	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
142851	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142852	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142853	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
142854	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
142855	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
142856	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
142857	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
142858	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
142859	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142860	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142861	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142862	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142863	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142864	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
142865	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	124	
142866	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	124	
142867	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
142868	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A Phase IOC	
142869	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
142870	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
142871	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
142872	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
142873	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
142874	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
142875	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
142876	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
142877	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142878	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
142879	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142880	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations Ground	0	
142881	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations C Ø	0	
142882	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations B Ø	0	
142883	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations A Ø	0	
142884	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142885	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
142886	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
142887	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
142888	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142889	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142890	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142891	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
142892	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
142893	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142894	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142895	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142896	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
142897	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
142898	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps C Ø	100.0	
142899	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps B Ø	50.0	
142900	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps A Ø	50.0	
142901	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
142902	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
142903	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
142904	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	9 Months Operations	22	
142905	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
142906	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
142907	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
142908	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
142909	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
142910	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142911	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
142912	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142913	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142914	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
142915	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
142916	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
142917	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
142918	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
142919	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
142920	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
142921	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
142922	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
142923	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
142924	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
142925	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
142926	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
142927	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
142928	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
142929	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
142930	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
142931	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	123	
142932	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	123	
142933	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
142934	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
142935	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
142936	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
142937	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
142938	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
142939	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
142940	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
142941	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
142942	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
142943	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
142944	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
142945	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
142946	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
142947	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
142948	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
142949	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
142950	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
142951	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
142952	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
142953	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
142954	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
142955	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
142956	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
142957	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
142958	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
142959	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
142960	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
142961	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
142962	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
142963	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
142964	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
142965	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
142966	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
142967	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9R	
142968	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
142969	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15R	
142970	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
142971	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	448	
142972	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
142973	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
142974	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
142975	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
142976	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
142977	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
142978	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
142979	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
142980	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
142981	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
142982	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
142983	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
142984	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
142985	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
142986	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
142987	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
142988	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
142989	10/10/2019 7:18	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
142990	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
142991	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
142992	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
142993	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
142994	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
142995	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
142996	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
142997	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
142998	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
142999	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
143000	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143001	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143002	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
143003	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
143004	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	108.0	
143005	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	72.0	
143006	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
143007	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	0	
143008	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
143009	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	0	
143010	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	232	
143011	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	232	
143012	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
143013	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
143014	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
143015	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
143016	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
143017	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
143018	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
143019	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
143020	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
143021	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
143022	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
143023	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
143024	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
143025	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143026	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143027	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143028	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143029	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143030	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143031	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143032	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143033	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
143034	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
143035	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
143036	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
143037	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143038	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143039	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143040	10/9/2019 14:53	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	9	
143041	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143042	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
143043	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143044	10/9/2019 6:41	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
143045	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
143046	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
143047	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
143048	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
143049	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	12851	
143050	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	12851	
143051	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143052	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143053	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143054	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
143055	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
143056	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
143057	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
143058	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
143059	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
143060	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
143061	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
143062	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
143063	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
143064	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
143065	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
143066	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Follow-up Action Required?	n	
143067	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	General Comments		
143068	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	General Comments	no targets but had a vc change	
143069	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
143070	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Maintenance Operations	0	
143071	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143072	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AF	292	
143073	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AL	292	
143074	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations This Read AM	0	
143075	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Switching Operations	0	
143076	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Unknown Operations	0	
143077	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
143078	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143079	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143080	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	DB0059	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143081	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143082	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143083	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	84.0	
143084	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	84.0	
143085	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	108.0	
143086	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
143087	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143088	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143089	10/9/2019 12:11	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143090	10/9/2019 12:35	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
143091	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
143092	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
143093	10/9/2019 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
143094	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
143095	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
143096	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
143097	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
143098	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
143099	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
143100	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
143101	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143102	10/9/2019 12:35	Distribution	Donerall Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
143103	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
143104	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
143105	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
143106	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
143107	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
143108	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
143109	10/9/2019 11:27	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
143110	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
143111	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
143112	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
143113	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	6297.60	kw
143114	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
143115	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
143116	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
143117	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6560	
143118	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
143119	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
143120	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
143121	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
143122	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
143123	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
143124	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
143125	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
143126	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
143127	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
143128	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
143129	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
143130	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
143131	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
143132	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
143133	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
143134	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
143135	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
143136	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
143137	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
143138	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
143139	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
143140	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
143141	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
143142	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
143143	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
143144	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
143145	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
143146	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143147	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143148	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
143149	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
143150	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
143151	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
143152	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	100.0	
143153	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	100.0	
143154	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	100.0	
143155	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
143156	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143157	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
143158	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
143159	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
143160	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	General Comments		
143161	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
143162	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
143163	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
143164	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
143165	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
143166	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
143167	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
143168	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143169	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
143170	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
143171	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143172	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
143173	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments		
143174	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
143175	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
143176	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143177	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	9	
143178	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
143179	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
143180	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143181	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	194	
143182	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	194	
143183	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	0	
143184	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	0	
143185	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
143186	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
143187	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
143188	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
143189	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
143190	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
143191	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
143192	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
143193	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
143194	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments		
143195	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments		
143196	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
143197	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
143198	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	0	
143199	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	260	
143200	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
143201	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	1470	
143202	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
143203	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	260	
143204	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
143205	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
143206	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
143207	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
143208	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
143209	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
143210	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
143211	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
143212	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
143213	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
143214	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
143215	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
143216	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
143217	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
143218	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
143219	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
143220	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	0	
143221	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
143222	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
143223	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
143224	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
143225	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	269	
143226	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	269	
143227	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
143228	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
143229	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
143230	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
143231	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
143232	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
143233	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
143234	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
143235	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
143236	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
143237	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
143238	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
143239	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
143240	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
143241	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments		
143242	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143243	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143244	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143245	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	0	
143246	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	0	
143247	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	0	
143248	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
143249	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143250	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
143251	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143252	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143253	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
143254	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143255	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143256	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143257	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143258	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
143259	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
143260	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
143261	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143262	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
143263	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
143264	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
143265	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
143266	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	General Comments		
143267	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
143268	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
143269	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
143270	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
143271	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments		
143272	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
143273	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
143274	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
143275	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143276	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	ok	
143277	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143278	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
143279	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143280	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
143281	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143282	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143283	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143284	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143285	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143286	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143287	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143288	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143289	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
143290	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
143291	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments		
143292	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
143293	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
143294	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
143295	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
143296	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
143297	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
143298	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
143299	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
143300	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
143301	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
143302	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	General Comments	Not in service yet	
143303	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
143304	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
143305	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
143306	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
143307	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
143308	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
143309	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
143310	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
143311	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143312	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143313	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143314	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143315	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
143316	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	47	*C
143317	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	*C
143318	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
143319	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
143320	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
143321	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
143322	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
143323	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
143324	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
143325	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
143326	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143327	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
143328	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
143329	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
143330	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
143331	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
143332	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143333	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
143334	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments		
143335	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
143336	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
143337	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
143338	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
143339	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
143340	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
143341	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
143342	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
143343	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
143344	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
143345	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
143346	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
143347	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
143348	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
143349	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments	ok	
143350	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
143351	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
143352	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
143353	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
143354	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143355	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143356	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
143357	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
143358	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
143359	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
143360	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
143361	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
143362	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
143363	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
143364	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
143365	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
143366	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
143367	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
143368	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
143369	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143370	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
143371	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
143372	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments		
143373	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143374	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143375	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143376	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143377	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143378	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143379	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143380	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143381	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
143382	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143383	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
143384	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
143385	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
143386	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
143387	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
143388	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
143389	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
143390	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
143391	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
143392	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
143393	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments		
143394	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
143395	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
143396	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
143397	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143398	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143399	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
143400	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143401	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143402	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
143403	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
143404	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
143405	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments	ok	
143406	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143407	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143408	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143409	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143410	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143411	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143412	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143413	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143414	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143415	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
143416	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
143417	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments	ok	
143418	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
143419	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
143420	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
143421	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
143422	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
143423	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
143424	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
143425	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
143426	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
143427	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
143428	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
143429	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
143430	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
143431	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
143432	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
143433	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
143434	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
143435	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
143436	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
143437	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments	ok	
143438	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
143439	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
143440	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
143441	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
143442	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
143443	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
143444	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
143445	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
143446	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
143447	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
143448	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
143449	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
143450	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
143451	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
143452	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
143453	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
143454	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
143455	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
143456	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
143457	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
143458	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
143459	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
143460	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
143461	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
143462	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
143463	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
143464	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
143465	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
143466	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143467	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
143468	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
143469	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143470	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143471	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143472	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143473	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143474	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143475	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143476	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143477	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
143478	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143479	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143480	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
143481	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	30.0	
143482	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	30.0	
143483	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	20.0	
143484	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143485	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143486	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143487	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	50.0	
143488	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	120.0	
143489	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	75.0	
143490	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
143491	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
143492	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
143493	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
143494	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
143495	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
143496	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
143497	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
143498	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
143499	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
143500	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	4	
143501	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
143502	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
143503	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
143504	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
143505	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
143506	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
143507	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
143508	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
143509	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
143510	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
143511	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
143512	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
143513	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
143514	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
143515	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
143516	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	61	*F
143517	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143518	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
143519	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
143520	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
143521	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
143522	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
143523	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
143524	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
143525	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
143526	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
143527	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
143528	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
143529	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments	ok	
143530	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
143531	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
143532	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
143533	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
143534	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
143535	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
143536	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
143537	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
143538	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
143539	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
143540	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
143541	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
143542	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
143543	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
143544	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
143545	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
143546	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
143547	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
143548	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	General Comments		
143549	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
143550	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
143551	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143552	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
143553	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	LTC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
143554	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
143555	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
143556	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
143557	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
143558	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
143559	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
143560	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
143561	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
143562	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
143563	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments		
143564	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
143565	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
143566	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	233	
143567	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
143568	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
143569	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
143570	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
143571	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
143572	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
143573	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
143574	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
143575	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
143576	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
143577	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	ok	
143578	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
143579	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
143580	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
143581	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
143582	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
143583	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
143584	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
143585	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
143586	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
143587	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
143588	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
143589	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
143590	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
143591	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
143592	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
143593	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
143594	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
143595	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments		
143596	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
143597	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
143598	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
143599	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
143600	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
143601	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
143602	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	8L	
143603	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	1R	
143604	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	10L	
143605	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
143606	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	1040	
143607	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
143608	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
143609	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
143610	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
143611	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
143612	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
143613	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143614	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143615	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143616	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143617	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
143618	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	19.0	
143619	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	17.0	
143620	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	21.0	
143621	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143622	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143623	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143624	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	1	
143625	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
143626	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
143627	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
143628	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
143629	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	0	
143630	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	162	
143631	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	162	
143632	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
143633	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	0	
143634	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
143635	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
143636	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments		
143637	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments		
143638	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
143639	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
143640	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
143641	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
143642	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
143643	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
143644	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
143645	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
143646	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
143647	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
143648	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
143649	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
143650	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments		
143651	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
143652	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
143653	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143654	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143655	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143656	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143657	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143658	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143659	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
143660	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
143661	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
143662	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
143663	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
143664	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	0	
143665	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	207	
143666	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	207	
143667	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
143668	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	0	
143669	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
143670	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
143671	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments		
143672	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments		
143673	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
143674	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
143675	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
143676	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
143677	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
143678	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
143679	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
143680	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
143681	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143682	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
143683	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143684	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143685	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
143686	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
143687	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments	ok	
143688	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments	ok	
143689	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	272134	
143690	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	272143	
143691	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	448	
143692	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	316	
143693	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	316	
143694	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
143695	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
143696	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
143697	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
143698	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
143699	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
143700	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
143701	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143702	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
143703	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
143704	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
143705	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
143706	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
143707	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
143708	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	210.0	
143709	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	200.0	
143710	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	210.0	
143711	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
143712	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
143713	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
143714	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
143715	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	448	
143716	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	3	
143717	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
143718	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
143719	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
143720	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	1	
143721	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
143722	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
143723	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	2	
143724	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	55	
143725	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	55	
143726	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
143727	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments	A&C Phase IOC no change in veeder	
143728	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
143729	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	y	
143730	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
143731	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
143732	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	1	
143733	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
143734	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	1	
143735	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
143736	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143737	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
143738	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143739	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143740	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143741	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143742	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143743	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143744	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
143745	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	31.0	
143746	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	39.0	
143747	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	24.0	
143748	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143749	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143750	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143751	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	3	
143752	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	9	
143753	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143754	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143755	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143756	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	50.0	
143757	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	75.0	
143758	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	90.0	
143759	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
143760	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143761	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143762	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143763	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143764	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143765	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143766	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
143767	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
143768	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	13.31	
143769	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
143770	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
143771	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	2	
143772	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
143773	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
143774	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
143775	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
143776	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143777	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments		
143778	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
143779	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
143780	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
143781	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
143782	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
143783	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
143784	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
143785	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143786	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
143787	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
143788	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
143789	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
143790	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
143791	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
143792	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
143793	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
143794	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments		
143795	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments		
143796	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143797	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
143798	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments	ok	
143799	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
143800	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
143801	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
143802	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
143803	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
143804	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
143805	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
143806	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
143807	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
143808	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
143809	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
143810	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
143811	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
143812	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	
143813	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
143814	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
143815	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143816	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143817	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
143818	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
143819	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	General Comments		
143820	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
143821	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	124.5	
143822	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	
143823	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	
143824	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	LTC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	
143825	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143826	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143827	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
143828	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
143829	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
143830	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
143831	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
143832	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
143833	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
143834	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
143835	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
143836	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
143837	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
143838	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
143839	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
143840	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
143841	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
143842	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
143843	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
143844	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
143845	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments		
143846	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
143847	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
143848	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
143849	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
143850	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
143851	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143852	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
143853	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143854	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments		
143855	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143856	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143857	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143858	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143859	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143860	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143861	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143862	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143863	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143864	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	61	*F
143865	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
143866	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
143867	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
143868	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
143869	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
143870	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
143871	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
143872	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
143873	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
143874	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
143875	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
143876	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	0	
143877	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	0	
143878	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	324	
143879	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	324	
143880	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
143881	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments		
143882	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
143883	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
143884	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
143885	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
143886	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
143887	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
143888	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
143889	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
143890	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
143891	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
143892	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
143893	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
143894	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
143895	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
143896	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
143897	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
143898	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
143899	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
143900	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
143901	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
143902	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	280.0	
143903	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	280.0	
143904	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	200.0	
143905	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
143906	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
143907	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
143908	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	3	
143909	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
143910	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
143911	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	231	
143912	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	231	
143913	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	0	
143914	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	0	
143915	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
143916	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
143917	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
143918	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
143919	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143920	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143921	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	61	*F
143922	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
143923	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	0	
143924	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	0	
143925	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99768	
143926	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99768	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
143927	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
143928	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
143929	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
143930	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
143931	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
143932	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
143933	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
143934	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
143935	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
143936	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
143937	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
143938	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
143939	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
143940	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	500.0	
143941	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	500.0	
143942	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	500.0	
143943	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
143944	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
143945	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
143946	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	0	
143947	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	3	
143948	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
143949	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
143950	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
143951	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	85.0	
143952	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	85.0	
143953	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	80.0	
143954	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
143955	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
143956	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
143957	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
143958	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
143959	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
143960	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
143961	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
143962	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
143963	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
143964	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
143965	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
143966	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
143967	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
143968	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
143969	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
143970	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
143971	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
143972	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
143973	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
143974	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
143975	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
143976	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
143977	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
143978	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
143979	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
143980	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
143981	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
143982	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
143983	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
143984	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
143985	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
143986	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
143987	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
143988	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
143989	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
143990	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
143991	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
143992	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
143993	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
143994	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
143995	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
143996	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
143997	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
143998	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
143999	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
144000	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
144001	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144002	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
144003	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
144004	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
144005	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
144006	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
144007	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
144008	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
144009	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
144010	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
144011	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
144012	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	1	
144013	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
144014	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
144015	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	y	
144016	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		
144017	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
144018	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144019	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments	ok	
144020	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments	C Phase TOC veeder didnt change again might need to be replaced.	
144021	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
144022	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	65700	
144023	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	65700	
144024	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	1	
144025	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	
144026	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
144027	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments	ok	
144028	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	126065	
144029	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	126071	
144030	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144031	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	7L	
144032	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	16R	
144033	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	10L	
144034	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	1033	
144035	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144036	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
144037	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144038	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
144039	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
144040	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
144041	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
144042	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
144043	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
144044	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
144045	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
144046	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
144047	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
144048	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
144049	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
144050	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
144051	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
144052	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
144053	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
144054	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
144055	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
144056	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
144057	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144058	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
144059	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144060	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
144061	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
144062	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
144063	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
144064	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
144065	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144066	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
144067	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
144068	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144069	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
144070	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
144071	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	40	°C
144072	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	80	°C
144073	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
144074	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
144075	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
144076	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144077	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments	ok	
144078	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144079	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
144080	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
144081	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
144082	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
144083	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
144084	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
144085	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
144086	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
144087	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
144088	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
144089	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
144090	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
144091	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
144092	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
144093	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144094	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	365	
144095	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	16L	
144096	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	6L	
144097	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	10L	
144098	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144099	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	1471	
144100	10/7/2019 14:35	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
144101	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
144102	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
144103	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	50	°C
144104	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	85	°C
144105	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
144106	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
144107	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
144108	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144109	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
144110	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
144111	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144112	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	65	°C
144113	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	80	°C
144114	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
144115	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
144116	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
144117	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments	two fans working one not working	
144118	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments	ok	
144119	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144120	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
144121	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
144122	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
144123	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
144124	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
144125	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
144126	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
144127	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
144128	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
144129	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
144130	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
144131	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
144132	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
144133	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
144134	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144135	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
144136	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144137	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
144138	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	378	
144139	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
144140	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
144141	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	12L	
144142	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
144143	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144144	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	420531	
144145	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	420531	
144146	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
144147	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
144148	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
144149	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
144150	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Unknown Operations	0	
144151	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144152	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
144153	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	80.0	
144154	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	80.0	
144155	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	80.0	
144156	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
144157	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144158	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144159	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Switching Operations	0	
144160	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
144161	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	65	psi
144162	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
144163	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
144164	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations This Read SF6	0	
144165	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AL	72	
144166	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AF	72	
144167	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Num Operations Last 9 Months	31	
144168	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
144169	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Maintenance Operations	0	
144170	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
144171	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Grounds in Place?	y	
144172	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
144173	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	General Comments		
144174	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
144175	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Foundation Condition	Good	
144176	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Follow-up Action Required?	n	
144177	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	
144178	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Fault Operations	0	
144179	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
144180	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
144181	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144182	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
144183	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
144184	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Ambient Temperature	66	*F
144185	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
144186	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
144187	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
144188	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
144189	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
144190	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
144191	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
144192	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
144193	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
144194	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	100.0	
144195	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	100.0	
144196	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	200.0	
144197	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
144198	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
144199	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
144200	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	11	
144201	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
144202	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
144203	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
144204	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
144205	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
144206	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
144207	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
144208	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments	ok	
144209	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
144210	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
144211	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
144212	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144213	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144214	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144215	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144216	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144217	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
144218	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
144219	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
144220	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
144221	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
144222	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
144223	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
144224	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
144225	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments		
144226	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144227	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
144228	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
144229	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
144230	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
144231	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
144232	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	16	
144233	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
144234	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
144235	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
144236	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
144237	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	0	
144238	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
144239	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
144240	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
144241	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
144242	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
144243	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
144244	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
144245	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
144246	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
144247	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
144248	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
144249	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	72	
144250	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	72	
144251	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	0	
144252	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
144253	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
144254	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
144255	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
144256	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
144257	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
144258	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
144259	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
144260	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
144261	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
144262	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments		
144263	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
144264	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
144265	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
144266	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
144267	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
144268	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
144269	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
144270	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
144271	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
144272	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	4	
144273	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
144274	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
144275	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
144276	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	220.0	
144277	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	100.0	
144278	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	220.0	
144279	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
144280	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
144281	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
144282	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
144283	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
144284	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
144285	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
144286	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144287	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144288	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
144289	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
144290	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
144291	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
144292	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
144293	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
144294	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
144295	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments		
144296	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments		
144297	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
144298	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
144299	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
144300	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
144301	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144302	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99989	
144303	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99989	
144304	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
144305	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-10-08 00:00:00.000000	
144306	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
144307	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
144308	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
144309	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
144310	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144311	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144312	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144313	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
144314	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
144315	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
144316	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
144317	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
144318	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
144319	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
144320	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
144321	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
144322	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
144323	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	
144324	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
144325	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments	ok	
144326	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
144327	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
144328	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
144329	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
144330	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
144331	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
144332	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
144333	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
144334	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
144335	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
144336	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
144337	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
144338	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
144339	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
144340	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
144341	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
144342	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
144343	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
144344	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
144345	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
144346	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
144347	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
144348	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
144349	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
144350	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
144351	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	150154	
144352	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	150154	
144353	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144354	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	4L	
144355	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	3R	
144356	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	6L	
144357	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments		
144358	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
144359	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
144360	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
144361	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
144362	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
144363	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
144364	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
144365	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	1193	
144366	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144367	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
144368	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144369	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
144370	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	LTC0000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
144371	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
144372	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
144373	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
144374	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
144375	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144376	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144377	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
144378	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
144379	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
144380	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
144381	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
144382	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
144383	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
144384	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
144385	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
144386	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
144387	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
144388	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
144389	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
144390	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
144391	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144392	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	30	°C
144393	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	55	°C
144394	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
144395	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
144396	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	2223.36	kw
144397	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
144398	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments		
144399	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments		
144400	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144401	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
144402	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
144403	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
144404	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
144405	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
144406	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
144407	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
144408	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
144409	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
144410	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
144411	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
144412	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
144413	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
144414	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments		
144415	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
144416	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
144417	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
144418	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
144419	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
144420	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
144421	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
144422	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
144423	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
144424	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
144425	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
144426	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
144427	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
144428	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
144429	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144430	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments		
144431	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments		
144432	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	17816	
144433	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	17825	
144434	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144435	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	10L	
144436	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	3L	
144437	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	14L	
144438	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	753	
144439	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
144440	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144441	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
144442	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144443	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Unknown Operations	0	
144444	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
144445	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
144446	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144447	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144448	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144449	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144450	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144451	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144452	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
144453	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
144454	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments		
144455	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
144456	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
144457	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
144458	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
144459	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
144460	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
144461	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
144462	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	70	psi
144463	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
144464	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	0	
144465	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	45	
144466	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
144467	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
144468	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	31428	
144469	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
144470	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
144471	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
144472	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
144473	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments		
144474	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
144475	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
144476	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
144477	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
144478	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
144479	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
144480	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
144481	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
144482	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
144483	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
144484	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
144485	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
144486	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
144487	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
144488	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
144489	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
144490	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
144491	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments		
144492	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
144493	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
144494	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
144495	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
144496	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
144497	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
144498	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
144499	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
144500	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
144501	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
144502	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
144503	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
144504	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
144505	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
144506	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
144507	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
144508	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
144509	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments		
144510	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
144511	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
144512	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	152	
144513	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
144514	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
144515	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
144516	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
144517	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
144518	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
144519	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
144520	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
144521	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
144522	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
144523	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
144524	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
144525	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
144526	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
144527	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments	ok	
144528	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments	ok	
144529	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
144530	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
144531	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	0	
144532	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
144533	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	87	
144534	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	87	
144535	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	0	
144536	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
144537	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
144538	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
144539	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
144540	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
144541	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
144542	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
144543	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
144544	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
144545	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
144546	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
144547	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
144548	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
144549	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
144550	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
144551	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
144552	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
144553	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
144554	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
144555	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
144556	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
144557	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
144558	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
144559	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments		
144560	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
144561	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
144562	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
144563	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
144564	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
144565	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
144566	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
144567	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
144568	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
144569	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
144570	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
144571	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144572	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144573	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144574	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144575	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144576	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
144577	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	100.0	
144578	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	100.0	
144579	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	120.0	
144580	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
144581	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
144582	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
144583	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
144584	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
144585	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
144586	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments	barb wire is broken on NE fence	
144587	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
144588	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
144589	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
144590	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	1	If no, which cells in comments
144591	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	14	
144592	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
144593	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
144594	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
144595	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	80.0	
144596	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	80.0	
144597	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	80.0	
144598	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
144599	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144600	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144601	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
144602	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144603	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144604	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
144605	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	General Comments	ok	
144606	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
144607	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
144608	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
144609	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144610	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
144611	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
144612	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	9498	
144613	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	9498	
144614	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144615	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	5L	
144616	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	1R	
144617	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	5L	
144618	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
144619	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	1014	
144620	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
144621	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
144622	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
144623	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
144624	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
144625	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
144626	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	General Comments	ok	
144627	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
144628	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
144629	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
144630	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
144631	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	LTC0000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
144632	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
144633	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
144634	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
144635	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
144636	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.4632	
144637	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
144638	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
144639	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
144640	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
144641	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
144642	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
144643	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
144644	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
144645	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144646	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
144647	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
144648	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
144649	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
144650	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
144651	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
144652	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
144653	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
144654	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
144655	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
144656	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
144657	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
144658	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	113.4	VAC
144659	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
144660	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	General Comments		
144661	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
144662	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
144663	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
144664	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
144665	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
144666	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
144667	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	113.5	VAC
144668	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
144669	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
144670	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
144671	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
144672	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
144673	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
144674	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	General Comments	ok	
144675	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
144676	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
144677	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
144678	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
144679	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
144680	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
144681	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
144682	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
144683	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
144684	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
144685	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
144686	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
144687	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
144688	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
144689	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
144690	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments	ok	
144691	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
144692	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
144693	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	112.0	VAC
144694	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	112.0	VAC
144695	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
144696	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	112.9	VAC
144697	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	LTC0000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
144698	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
144699	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
144700	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
144701	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	0	
144702	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	167	
144703	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	167	
144704	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
144705	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	0	
144706	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
144707	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
144708	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments		
144709	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments		
144710	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
144711	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
144712	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
144713	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
144714	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
144715	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
144716	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
144717	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
144718	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
144719	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
144720	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
144721	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
144722	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144723	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
144724	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
144725	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
144726	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
144727	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	174.0	
144728	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	182.0	
144729	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	174.0	
144730	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
144731	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
144732	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
144733	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	1	
144734	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
144735	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
144736	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
144737	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
144738	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
144739	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
144740	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
144741	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
144742	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
144743	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
144744	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTC0000513	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
144745	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
144746	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
144747	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	24.7	VDC
144748	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
144749	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
144750	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
144751	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144752	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
144753	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
144754	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
144755	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
144756	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
144757	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
144758	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
144759	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
144760	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
144761	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
144762	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
144763	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
144764	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
144765	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
144766	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
144767	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
144768	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
144769	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
144770	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
144771	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
144772	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BAT000003	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
144773	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
144774	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
144775	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
144776	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
144777	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
144778	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
144779	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
144780	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
144781	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
144782	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
144783	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
144784	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
144785	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
144786	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
144787	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
144788	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
144789	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
144790	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
144791	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144792	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments		
144793	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments		
144794	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
144795	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	3502.08	kw
144796	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
144797	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
144798	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	*C
144799	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	45	*C
144800	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144801	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
144802	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
144803	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144804	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
144805	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
144806	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
144807	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
144808	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	1.0944	
144809	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
144810	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
144811	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	66	*F
144812	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30738	
144813	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
144814	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
144815	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
144816	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
144817	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	75.0	
144818	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
144819	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	76.0	
144820	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
144821	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
144822	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
144823	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
144824	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
144825	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
144826	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
144827	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
144828	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
144829	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
144830	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments		
144831	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
144832	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
144833	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	219	
144834	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
144835	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
144836	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
144837	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
144838	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	65	psi
144839	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
144840	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	0	
144841	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	62	
144842	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	62	
144843	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	2	
144844	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
144845	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
144846	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
144847	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
144848	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments	ok	
144849	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		
144850	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
144851	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
144852	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
144853	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
144854	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
144855	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
144856	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
144857	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
144858	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
144859	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
144860	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
144861	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
144862	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
144863	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments		
144864	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
144865	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
144866	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
144867	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
144868	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
144869	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
144870	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
144871	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
144872	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
144873	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
144874	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
144875	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
144876	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144877	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
144878	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
144879	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
144880	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
144881	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
144882	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
144883	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144884	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
144885	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
144886	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
144887	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
144888	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
144889	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
144890	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
144891	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments		
144892	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments		
144893	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144894	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
144895	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	1	
144896	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	1	
144897	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
144898	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
144899	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
144900	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
144901	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments	A,B&C Phase IOC	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
144902	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
144903	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	231	
144904	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	231	
144905	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	3	
144906	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	0	
144907	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
144908	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
144909	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
144910	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments		
144911	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
144912	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
144913	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
144914	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
144915	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
144916	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
144917	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
144918	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
144919	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
144920	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
144921	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
144922	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
144923	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144924	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
144925	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments		
144926	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	5426	
144927	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	5437	
144928	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
144929	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	45	
144930	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	3	
144931	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
144932	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
144933	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
144934	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
144935	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
144936	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
144937	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
144938	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
144939	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
144940	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
144941	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
144942	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments	ok	
144943	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
144944	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
144945	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
144946	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
144947	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
144948	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
144949	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
144950	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
144951	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
144952	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
144953	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
144954	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	66	°F
144955	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	24	
144956	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
144957	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
144958	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
144959	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	540.0	
144960	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	620.0	
144961	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	520.0	
144962	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
144963	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
144964	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
144965	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
144966	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	1	
144967	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
144968	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	25	°C
144969	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
144970	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
144971	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
144972	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
144973	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
144974	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
144975	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
144976	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
144977	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
144978	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
144979	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
144980	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	25	°C
144981	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	55	°C
144982	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
144983	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
144984	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
144985	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
144986	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
144987	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
144988	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
144989	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
144990	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
144991	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments	ok	
144992	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments	ok	
144993	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
144994	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
144995	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
144996	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
144997	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
144998	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
144999	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145000	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145001	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145002	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145003	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145004	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145005	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145006	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145007	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
145008	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments		
145009	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145010	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
145011	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
145012	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
145013	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
145014	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
145015	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
145016	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
145017	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
145018	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
145019	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
145020	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	LTCC000513	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
145021	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	4L	
145022	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	1L	
145023	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	9L	
145024	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	606	
145025	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
145026	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
145027	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
145028	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
145029	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145030	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
145031	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145032	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
145033	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
145034	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145035	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145036	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145037	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
145038	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
145039	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	58	°C
145040	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
145041	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
145042	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
145043	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
145044	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments		
145045	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
145046	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145047	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
145048	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
145049	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145050	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
145051	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145052	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145053	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
145054	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145055	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145056	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145057	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145058	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145059	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145060	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145061	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
145062	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
145063	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
145064	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	30	°C
145065	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	70	°C
145066	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145067	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
145068	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.7008	
145069	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
145070	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145071	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
145072	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
145073	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
145074	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145075	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
145076	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145077	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	50	°C
145078	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
145079	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
145080	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
145081	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	5045.76	kw
145082	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
145083	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments	ok	
145084	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments	ok	
145085	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145086	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
145087	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
145088	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145089	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
145090	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
145091	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145092	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145093	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145094	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145095	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145096	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145097	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145098	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145099	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
145100	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
145101	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145102	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
145103	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
145104	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
145105	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145106	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
145107	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
145108	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
145109	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
145110	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
145111	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
145112	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	0	
145113	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	6	
145114	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	231	
145115	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	231	
145116	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
145117	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
145118	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
145119	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
145120	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
145121	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
145122	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.8040	
145123	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
145124	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
145125	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
145126	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	100.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145127	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	100.0	
145128	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	50.0	
145129	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
145130	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
145131	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
145132	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
145133	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
145134	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
145135	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
145136	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
145137	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
145138	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
145139	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
145140	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
145141	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
145142	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
145143	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
145144	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145145	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments		
145146	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LTC0000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
145147	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LTC0000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
145148	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LTC0000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
145149	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
145150	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145151	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145152	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145153	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145154	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145155	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145156	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
145157	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
145158	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	General Comments		
145159	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
145160	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
145161	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
145162	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
145163	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	LTC0000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
145164	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145165	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145166	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
145167	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
145168	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145169	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
145170	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
145171	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145172	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments		
145173	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments		
145174	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
145175	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	7718.40	kw
145176	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
145177	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
145178	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	65	°C
145179	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	40	°C
145180	10/8/2019 12:07	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145181	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
145182	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
145183	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments	ok	
145184	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments	ok	
145185	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	35484	
145186	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	35499	
145187	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
145188	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	6L	
145189	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
145190	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	15L	
145191	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	169	
145192	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
145193	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
145194	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
145195	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
145196	10/8/2019 14:20	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
145197	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
145198	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	410.0	
145199	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	420.0	
145200	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	390.0	
145201	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145202	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
145203	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
145204	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	11	
145205	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
145206	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
145207	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
145208	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
145209	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	20579	
145210	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	20579	
145211	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
145212	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
145213	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
145214	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
145215	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1147	
145216	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
145217	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
145218	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
145219	10/8/2019 11:31	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
145220	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
145221	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
145222	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
145223	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
145224	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
145225	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
145226	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
145227	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
145228	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
145229	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
145230	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
145231	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
145232	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
145233	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
145234	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
145235	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	275	
145236	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	275	
145237	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	0	
145238	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	0	
145239	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
145240	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
145241	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
145242	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
145243	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
145244	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
145245	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
145246	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
145247	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
145248	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
145249	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
145250	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
145251	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
145252	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments	ok	
145253	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
145254	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
145255	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
145256	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
145257	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
145258	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
145259	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
145260	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
145261	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
145262	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145263	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145264	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145265	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145266	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145267	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145268	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145269	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145270	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
145271	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
145272	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145273	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
145274	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
145275	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145276	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145277	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
145278	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
145279	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	4838.40	kw
145280	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
145281	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
145282	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	55	°C
145283	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	30	°C
145284	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145285	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
145286	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145287	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
145288	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
145289	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
145290	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145291	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
145292	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
145293	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	1.0080	
145294	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
145295	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
145296	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	3	
145297	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
145298	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
145299	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
145300	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	75.0	
145301	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	80.0	
145302	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	70.0	
145303	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
145304	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
145305	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
145306	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
145307	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
145308	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
145309	10/8/2019 15:49	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
145310	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	0	
145311	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
145312	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
145313	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
145314	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	2	
145315	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	2	
145316	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	2	
145317	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	30.50	
145318	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	30.50	
145319	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	30.50	
145320	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
145321	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
145322	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
145323	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
145324	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
145325	10/8/2019 15:13	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
145326	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
145327	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
145328	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
145329	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
145330	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
145331	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
145332	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145333	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
145334	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
145335	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
145336	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
145337	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
145338	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
145339	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
145340	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
145341	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
145342	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.6	VDC
145343	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.6	VDC
145344	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments	ok	
145345	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
145346	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
145347	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
145348	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
145349	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	323	
145350	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145351	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145352	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
145353	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
145354	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
145355	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145356	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145357	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
145358	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
145359	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
145360	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
145361	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
145362	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
145363	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
145364	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
145365	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
145366	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
145367	10/8/2019 11:47	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
145368	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
145369	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
145370	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
145371	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
145372	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
145373	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
145374	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
145375	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
145376	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
145377	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
145378	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
145379	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
145380	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
145381	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
145382	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
145383	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
145384	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
145385	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
145386	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
145387	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
145388	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
145389	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
145390	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
145391	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
145392	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
145393	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
145394	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
145395	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
145396	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
145397	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
145398	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
145399	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
145400	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
145401	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
145402	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
145403	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
145404	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
145405	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
145406	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
145407	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
145408	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
145409	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments		
145410	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
145411	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
145412	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	0	
145413	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
145414	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	183	
145415	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	183	
145416	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	0	
145417	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
145418	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
145419	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
145420	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
145421	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
145422	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
145423	10/8/2019 10:42	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
145424	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
145425	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
145426	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145427	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
145428	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
145429	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145430	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145431	10/8/2019 9:50	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33889	
145432	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
145433	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
145434	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
145435	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
145436	10/8/2019 10:09	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
145437	10/8/2019 9:16	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	323	
145438	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
145439	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
145440	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
145441	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
145442	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
145443	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
145444	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
145445	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
145446	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
145447	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
145448	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.3	VDC
145449	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	68.8	VDC
145450	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
145451	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
145452	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145453	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145454	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
145455	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
145456	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
145457	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145458	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145459	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
145460	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
145461	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145462	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	110263	
145463	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
145464	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
145465	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
145466	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145467	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145468	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
145469	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
145470	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	11R	
145471	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
145472	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145473	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145474	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
145475	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
145476	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145477	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145478	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
145479	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145480	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	14R	
145481	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
145482	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
145483	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
145484	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
145485	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
145486	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145487	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145488	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145489	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145490	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
145491	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145492	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	17067	
145493	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145494	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
145495	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0769	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
145496	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
145497	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
145498	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145499	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145500	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	86220	
145501	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145502	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145503	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145504	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145505	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145506	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
145507	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145508	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
145509	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
145510	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
145511	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145512	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145513	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
145514	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	14R	
145515	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
145516	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
145517	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
145518	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	R0767	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145519	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	38.6	
145520	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	42.0	
145521	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	59.1	
145522	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
145523	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
145524	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
145525	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
145526	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
145527	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
145528	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
145529	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	518	
145530	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
145531	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
145532	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
145533	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145534	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
145535	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
145536	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145537	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
145538	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
145539	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145540	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
145541	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
145542	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145543	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145544	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
145545	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145546	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145547	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
145548	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
145549	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
145550	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments	ok	
145551	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145552	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145553	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
145554	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
145555	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
145556	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
145557	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145558	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
145559	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
145560	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
145561	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
145562	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
145563	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	General Comments		
145564	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145565	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
145566	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
145567	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
145568	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
145569	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
145570	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
145571	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
145572	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
145573	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
145574	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	All Connections OK?	y	
145575	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
145576	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145577	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
145578	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
145579	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
145580	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
145581	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
145582	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
145583	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
145584	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
145585	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
145586	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
145587	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
145588	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
145589	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
145590	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
145591	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
145592	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
145593	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
145594	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
145595	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
145596	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
145597	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
145598	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
145599	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
145600	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
145601	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
145602	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
145603	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
145604	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
145605	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
145606	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
145607	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
145608	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
145609	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations	8	
145610	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
145611	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
145612	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
145613	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
145614	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
145615	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
145616	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments	Barb wire rusted. In the process of being replaced . There is some vegetation growing through fence in two spots.	
145617	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
145618	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
145619	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
145620	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
145621	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
145622	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
145623	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
145624	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
145625	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
145626	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
145627	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
145628	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
145629	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
145630	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
145631	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
145632	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
145633	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
145634	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
145635	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
145636	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
145637	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
145638	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
145639	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
145640	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
145641	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
145642	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	240	
145643	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	240	
145644	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations This Read Vac	0	
145645	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
145646	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
145647	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145648	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145649	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	488485	
145650	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
145651	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145652	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
145653	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145654	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145655	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
145656	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
145657	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
145658	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
145659	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145660	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
145661	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
145662	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145663	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
145664	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145665	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145666	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145667	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145668	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
145669	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
145670	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
145671	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	5	
145672	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
145673	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations This Read Vac	5	
145674	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	346	
145675	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	346	
145676	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
145677	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
145678	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
145679	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
145680	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
145681	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
145682	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
145683	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
145684	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	
145685	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
145686	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
145687	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
145688	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145689	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145690	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
145691	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145692	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments		
145693	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments		
145694	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
145695	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
145696	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
145697	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
145698	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
145699	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
145700	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145701	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
145702	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145703	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
145704	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
145705	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
145706	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145707	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
145708	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
145709	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
145710	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	35	°C
145711	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
145712	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
145713	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
145714	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
145715	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
145716	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7057	
145717	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
145718	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
145719	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145720	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145721	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145722	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
145723	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps A Ø	80.0	
145724	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1056	
145725	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
145726	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145727	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
145728	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
145729	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145730	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
145731	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145732	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
145733	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
145734	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
145735	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
145736	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	253.44	kw
145737	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
145738	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
145739	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
145740	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
145741	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
145742	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments		
145743	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145744	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
145745	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
145746	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145747	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145748	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
145749	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
145750	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
145751	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145752	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
145753	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
145754	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
145755	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps B Ø	78.0	
145756	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps C Ø	70.0	
145757	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushing Condition	Good	
145758	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
145759	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
145760	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
145761	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
145762	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
145763	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
145764	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
145765	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
145766	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
145767	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
145768	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
145769	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
145770	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations This Read Vac	1	
145771	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	215	
145772	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	215	
145773	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
145774	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	1	
145775	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
145776	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
145777	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments	ok	
145778	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments	ok	
145779	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
145780	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
145781	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
145782	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
145783	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	0	
145784	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	0	
145785	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	0	
145786	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
145787	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
145788	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
145789	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
145790	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
145791	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
145792	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
145793	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
145794	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
145795	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
145796	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
145797	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
145798	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
145799	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
145800	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
145801	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145802	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
145803	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
145804	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
145805	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.6	VDC
145806	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
145807	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
145808	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	0	
145809	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
145810	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
145811	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
145812	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	29.0	
145813	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	32.0	
145814	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	41.0	
145815	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
145816	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
145817	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
145818	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	3	
145819	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
145820	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
145821	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
145822	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
145823	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
145824	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
145825	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
145826	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
145827	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
145828	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
145829	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
145830	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
145831	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
145832	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
145833	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
145834	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
145835	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
145836	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145837	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145838	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145839	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145840	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
145841	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
145842	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
145843	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
145844	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
145845	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
145846	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
145847	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
145848	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
145849	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
145850	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
145851	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
145852	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
145853	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
145854	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments	ok	
145855	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
145856	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
145857	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	91	
145858	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
145859	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
145860	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
145861	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
145862	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
145863	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
145864	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
145865	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
145866	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
145867	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
145868	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
145869	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Light	None	
145870	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
145871	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
145872	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
145873	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
145874	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
145875	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
145876	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
145877	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
145878	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
145879	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
145880	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
145881	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
145882	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
145883	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
145884	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145885	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145886	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145887	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145888	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
145889	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145890	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
145891	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
145892	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145893	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
145894	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
145895	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145896	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145897	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
145898	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
145899	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
145900	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	23626	
145901	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145902	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145903	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
145904	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
145905	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
145906	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
145907	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
145908	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145909	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145910	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145911	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145912	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
145913	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
145914	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
145915	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
145916	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
145917	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
145918	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
145919	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
145920	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
145921	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
145922	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
145923	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
145924	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
145925	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
145926	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72627	
145927	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145928	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
145929	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
145930	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments	ok	
145931	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145932	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
145933	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
145934	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
145935	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
145936	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
145937	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
145938	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
145939	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
145940	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
145941	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
145942	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
145943	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments		
145944	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
145945	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
145946	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	325.68	kw
145947	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
145948	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
145949	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	0	*C
145950	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	40	*C
145951	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
145952	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
145953	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
145954	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
145955	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
145956	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
145957	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Re-Paint	
145958	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
145959	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1357	
145960	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
145961	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
145962	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
145963	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
145964	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
145965	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
145966	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
145967	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
145968	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
145969	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
145970	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
145971	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
145972	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
145973	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000300	LTCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
145974	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
145975	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
145976	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
145977	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
145978	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
145979	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
145980	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
145981	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
145982	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
145983	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments	ok	
145984	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
145985	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
145986	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
145987	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
145988	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
145989	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
145990	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
145991	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
145992	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
145993	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
145994	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
145995	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
145996	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments	ok	
145997	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments	ok	
145998	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
145999	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146000	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
146001	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments		
146002	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146003	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	74426	
146004	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	74438	
146005	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146006	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	5R	
146007	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	7R	
146008	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	4R	
146009	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
146010	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	602	
146011	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146012	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146013	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
146014	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
146015	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
146016	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146017	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146018	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146019	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146020	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
146021	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146022	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments		
146023	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146024	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146025	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146026	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146027	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
146028	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146029	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146030	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146031	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
146032	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
146033	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146034	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146035	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1655	
146036	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	13L	
146037	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	3L	
146038	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	7L	
146039	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146040	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	35319	
146041	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	35316	
146042	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
146043	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
146044	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
146045	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
146046	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
146047	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
146048	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146049	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146050	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146051	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments		
146052	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
146053	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146054	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146055	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146056	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146057	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146058	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146059	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
146060	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146061	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
146062	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
146063	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146064	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
146065	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
146066	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments	ok	
146067	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
146068	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146069	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	158366	
146070	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
146071	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
146072	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
146073	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
146074	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
146075	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
146076	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146077	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146078	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
146079	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
146080	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
146081	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8896	
146082	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
146083	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
146084	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.9	VDC
146085	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.6	VDC
146086	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
146087	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
146088	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
146089	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
146090	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
146091	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
146092	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
146093	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	671	*F
146094	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
146095	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
146096	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.9	VDC
146097	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146098	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146099	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
146100	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
146101	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
146102	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
146103	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.2	VDC
146104	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146105	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
146106	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
146107	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146108	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146109	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146110	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146111	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146112	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146113	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146114	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146115	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
146116	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146117	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
146118	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146119	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146120	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146121	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	7L	
146122	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	1171	
146123	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
146124	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
146125	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
146126	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
146127	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
146128	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	12637	
146129	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	12637	
146130	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146131	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	1L	
146132	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	1R	
146133	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
146134	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146135	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
146136	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
146137	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
146138	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146139	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146140	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146141	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146142	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146143	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146144	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
146145	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
146146	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146147	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	General Comments		
146148	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	General Comments		
146149	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
146150	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
146151	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	99.72	kw
146152	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
146153	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
146154	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Max	42	*C
146155	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Present	32	*C
146156	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146157	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
146158	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146159	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146160	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
146161	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146162	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
146163	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
146164	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146165	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments	ok	
146166	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
146167	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
146168	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
146169	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146170	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146171	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
146172	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
146173	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
146174	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
146175	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
146176	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9260	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146177	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146178	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
146179	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.1662	
146180	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146181	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
146182	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146183	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146184	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146185	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146186	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
146187	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
146188	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146189	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
146190	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146191	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
146192	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
146193	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
146194	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
146195	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
146196	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
146197	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
146198	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
146199	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
146200	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
146201	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
146202	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
146203	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
146204	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
146205	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
146206	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
146207	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	484	
146208	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	484	
146209	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
146210	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
146211	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
146212	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146213	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146214	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
146215	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
146216	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146217	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	81666	
146218	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
146219	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
146220	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
146221	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146222	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
146223	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146224	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146225	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146226	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146227	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146228	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146229	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
146230	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146231	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
146232	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146233	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146234	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146235	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments		
146236	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146237	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146238	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146239	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
146240	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
146241	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146242	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
146243	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
146244	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
146245	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146246	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments	ok	
146247	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146248	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	14L	
146249	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
146250	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
146251	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
146252	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146253	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
146254	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
146255	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146256	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146257	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146258	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146259	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146260	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
146261	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146262	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146263	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146264	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146265	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146266	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146267	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
146268	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146269	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
146270	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146271	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146272	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
146273	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
146274	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
146275	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
146276	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146277	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146278	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146279	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146280	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	9L	
146281	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146282	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146283	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146284	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
146285	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
146286	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
146287	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	0	
146288	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	
146289	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	
146290	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	
146291	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	230.0	
146292	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	220.0	
146293	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
146294	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
146295	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146296	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146297	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146298	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146299	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
146300	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
146301	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
146302	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
146303	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146304	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
146305	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146306	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
146307	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
146308	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146309	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
146310	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments	ok	
146311	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
146312	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	
146313	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
146314	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3024.00	
146315	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
146316	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
146317	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	55	
146318	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	35	
146319	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146320	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
146321	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146322	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
146323	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
146324	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
146325	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146326	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146327	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6300	
146328	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	250.0	
146329	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
146330	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
146331	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
146332	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
146333	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
146334	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
146335	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
146336	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
146337	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
146338	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
146339	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
146340	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
146341	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
146342	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
146343	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
146344	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
146345	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
146346	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
146347	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
146348	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
146349	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
146350	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
146351	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
146352	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146353	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
146354	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
146355	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
146356	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
146357	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
146358	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
146359	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
146360	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
146361	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
146362	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146363	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146364	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
146365	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146366	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments	ok	
146367	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
146368	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
146369	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
146370	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146371	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146372	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
146373	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
146374	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146375	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146376	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146377	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
146378	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
146379	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
146380	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
146381	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	9	
146382	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
146383	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
146384	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
146385	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146386	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146387	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
146388	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146389	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146390	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
146391	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
146392	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146393	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146394	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146395	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
146396	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
146397	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146398	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146399	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146400	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
146401	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
146402	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146403	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
146404	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146405	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146406	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146407	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146408	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146409	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146410	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146411	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146412	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146413	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146414	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
146415	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146416	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146417	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
146418	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146419	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146420	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
146421	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
146422	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146423	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146424	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
146425	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
146426	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
146427	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
146428	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
146429	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87937	
146430	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146431	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Leaks	None	
146432	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
146433	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
146434	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
146435	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
146436	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
146437	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
146438	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
146439	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
146440	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments	ok	
146441	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146442	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
146443	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
146444	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146445	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
146446	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
146447	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146448	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments	ok	
146449	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146450	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
146451	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
146452	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
146453	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
146454	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146455	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146456	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146457	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146458	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146459	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146460	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
146461	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146462	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146463	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146464	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146465	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146466	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
146467	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
146468	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
146469	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
146470	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
146471	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
146472	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
146473	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	0	
146474	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
146475	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
146476	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146477	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
146478	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
146479	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
146480	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146481	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
146482	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146483	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146484	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146485	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146486	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
146487	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
146488	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146489	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
146490	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
146491	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
146492	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
146493	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
146494	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
146495	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	185.0	
146496	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	180.0	
146497	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	190.0	
146498	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
146499	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146500	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146501	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146502	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146503	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146504	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146505	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
146506	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146507	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
146508	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146509	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146510	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146511	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146512	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146513	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
146514	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
146515	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
146516	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
146517	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
146518	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146519	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146520	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146521	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	General Comments		
146522	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	General Comments		
146523	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
146524	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
146525	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
146526	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146527	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146528	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
146529	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146530	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
146531	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146532	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146533	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146534	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
146535	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
146536	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	4	
146537	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
146538	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations This Read Vac	6	
146539	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	211	
146540	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	211	
146541	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
146542	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
146543	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
146544	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Grounds in Place?	y	
146545	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	General Comments		
146546	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	General Comments		
146547	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Foundation Condition	Good	
146548	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Follow-up Action Required?	n	
146549	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
146550	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
146551	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146552	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	0	
146553	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	1	
146554	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
146555	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
146556	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
146557	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
146558	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
146559	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
146560	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
146561	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
146562	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
146563	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
146564	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
146565	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Present	33	°C
146566	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
146567	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	10.0	
146568	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	10.0	
146569	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	10.0	
146570	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
146571	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
146572	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
146573	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	10	
146574	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146575	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
146576	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146577	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
146578	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
146579	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146580	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
146581	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
146582	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
146583	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
146584	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
146585	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146586	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146587	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146588	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146589	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
146590	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146591	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
146592	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
146593	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
146594	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146595	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	25409	
146596	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
146597	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
146598	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
146599	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
146600	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
146601	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
146602	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	1797.12	kw
146603	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
146604	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
146605	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146606	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146607	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
146608	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
146609	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	55	°C
146610	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	40	°C
146611	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146612	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
146613	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146614	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
146615	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146616	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146617	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
146618	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146619	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
146620	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
146621	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146622	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
146623	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.5616	
146624	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
146625	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
146626	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
146627	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
146628	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
146629	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146630	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
146631	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
146632	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146633	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
146634	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
146635	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
146636	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
146637	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146638	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146639	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	80	
146640	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
146641	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	4L	
146642	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	2R	
146643	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	2L	
146644	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146645	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	458	
146646	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	458	
146647	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
146648	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
146649	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
146650	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146651	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
146652	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
146653	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
146654	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
146655	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
146656	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
146657	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
146658	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
146659	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
146660	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
146661	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
146662	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments	ok	
146663	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments	ok	
146664	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
146665	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	2449.44	kw
146666	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
146667	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
146668	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	40	°C
146669	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	40	°C
146670	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146671	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
146672	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146673	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
146674	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
146675	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
146676	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146677	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
146678	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	1.0206	
146679	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
146680	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
146681	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
146682	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
146683	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	7977.60	kw
146684	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
146685	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
146686	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		
146687	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146688	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
146689	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
146690	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146691	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
146692	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
146693	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146694	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
146695	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
146696	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
146697	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
146698	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146699	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146700	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
146701	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146702	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
146703	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
146704	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
146705	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
146706	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
146707	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
146708	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments	ok	
146709	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
146710	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
146711	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3470	
146712	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
146713	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146714	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
146715	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
146716	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
146717	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146718	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
146719	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146720	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	28	*C
146721	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	50	*C
146722	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
146723	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
146724	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2498.40	kw
146725	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
146726	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
146727	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
146728	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146729	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
146730	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
146731	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
146732	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
146733	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
146734	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
146735	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
146736	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
146737	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
146738	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
146739	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
146740	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
146741	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
146742	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
146743	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
146744	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
146745	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
146746	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
146747	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
146748	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
146749	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
146750	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
146751	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
146752	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
146753	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
146754	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
146755	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
146756	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
146757	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
146758	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
146759	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
146760	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
146761	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
146762	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
146763	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
146764	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
146765	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
146766	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.8310	
146767	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
146768	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
146769	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
146770	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
146771	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
146772	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
146773	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
146774	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
146775	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	45	*C
146776	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	45	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146777	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
146778	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146779	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
146780	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146781	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments	ok	
146782	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146783	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146784	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146785	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146786	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146787	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
146788	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146789	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146790	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146791	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
146792	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
146793	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
146794	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
146795	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
146796	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
146797	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
146798	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
146799	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
146800	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
146801	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
146802	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
146803	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
146804	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
146805	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
146806	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
146807	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
146808	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
146809	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
146810	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
146811	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
146812	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
146813	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
146814	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
146815	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
146816	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
146817	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
146818	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	1	
146819	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
146820	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
146821	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
146822	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	2	
146823	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	221	
146824	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	221	
146825	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
146826	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
146827	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146828	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
146829	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
146830	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146831	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
146832	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
146833	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
146834	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
146835	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146836	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146837	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
146838	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
146839	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146840	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
146841	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146842	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
146843	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146844	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146845	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146846	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146847	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146848	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
146849	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146850	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146851	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146852	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
146853	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
146854	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
146855	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
146856	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
146857	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
146858	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
146859	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
146860	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
146861	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
146862	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
146863	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments	ok	
146864	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
146865	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
146866	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
146867	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
146868	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
146869	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
146870	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
146871	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
146872	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146873	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
146874	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	1770	
146875	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
146876	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	8L	
146877	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	6R	
146878	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	1L	
146879	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146880	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	30875	
146881	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	30875	
146882	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	431622	
146883	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	431622	
146884	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
146885	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
146886	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
146887	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
146888	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
146889	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
146890	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
146891	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
146892	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
146893	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
146894	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
146895	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
146896	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146897	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146898	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
146899	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146900	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
146901	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
146902	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146903	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments	ok	
146904	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
146905	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
146906	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
146907	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
146908	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
146909	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
146910	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
146911	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
146912	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	68615	
146913	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
146914	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
146915	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
146916	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
146917	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
146918	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
146919	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
146920	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
146921	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146922	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146923	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146924	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146925	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146926	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
146927	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146928	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
146929	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146930	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
146931	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
146932	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
146933	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
146934	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
146935	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
146936	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
146937	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
146938	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
146939	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
146940	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
146941	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
146942	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
146943	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
146944	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
146945	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
146946	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146947	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146948	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	969	
146949	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	10L	
146950	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
146951	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	4L	
146952	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
146953	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
146954	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
146955	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
146956	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
146957	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
146958	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
146959	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
146960	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
146961	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
146962	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
146963	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
146964	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
146965	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
146966	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
146967	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
146968	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
146969	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
146970	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
146971	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
146972	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments	lower hand wont reset	
146973	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
146974	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
146975	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
146976	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
146977	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
146978	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
146979	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
146980	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
146981	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	8513.28	kw
146982	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
146983	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
146984	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
146985	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
146986	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
146987	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
146988	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
146989	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
146990	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
146991	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
146992	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
146993	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
146994	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
146995	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
146996	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
146997	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
146998	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
146999	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
147000	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147001	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147002	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
147003	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147004	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
147005	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147006	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
147007	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147008	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147009	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147010	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147011	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147012	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147013	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147014	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147015	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147016	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147017	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
147018	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
147019	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
147020	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
147021	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
147022	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
147023	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
147024	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374709	
147025	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
147026	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
147027	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147028	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147029	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
147030	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments		
147031	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147032	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
147033	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
147034	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147035	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
147036	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
147037	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
147038	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.8868	
147039	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
147040	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
147041	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
147042	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
147043	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
147044	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
147045	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
147046	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
147047	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	28	°C
147048	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	58	°C
147049	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
147050	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147051	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147052	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147053	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147054	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
147055	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
147056	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
147057	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
147058	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
147059	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49096	
147060	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
147061	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
147062	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
147063	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147064	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147065	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
147066	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
147067	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
147068	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
147069	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
147070	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
147071	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	595	
147072	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
147073	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
147074	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
147075	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
147076	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147077	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
147078	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
147079	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
147080	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments		
147081	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
147082	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
147083	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
147084	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
147085	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
147086	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
147087	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
147088	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
147089	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
147090	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
147091	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
147092	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
147093	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	5L	
147094	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	1L	
147095	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	3L	
147096	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
147097	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	525759	
147098	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	525748	
147099	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments	ok	
147100	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments	ok	
147101	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
147102	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
147103	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
147104	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
147105	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
147106	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
147107	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
147108	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
147109	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
147110	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
147111	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147112	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
147113	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
147114	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
147115	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
147116	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
147117	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
147118	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
147119	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
147120	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
147121	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
147122	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
147123	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	267.12	kw
147124	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
147125	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
147126	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp IMax	40	°C
147127	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
147128	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
147129	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
147130	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
147131	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
147132	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
147133	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
147134	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
147135	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
147136	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4452	
147137	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
147138	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
147139	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
147140	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
147141	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
147142	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
147143	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
147144	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
147145	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
147146	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
147147	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
147148	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
147149	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
147150	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
147151	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147152	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
147153	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
147154	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments	ok	
147155	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
147156	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
147157	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
147158	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
147159	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
147160	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
147161	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
147162	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	8L	
147163	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	2L	
147164	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	5L	
147165	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
147166	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	0	
147167	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
147168	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
147169	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
147170	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations This Read Vac	11	
147171	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	185	
147172	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	185	
147173	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
147174	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	11	
147175	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
147176	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
147177	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	General Comments	ok	
147178	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments		
147179	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
147180	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
147181	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
147182	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	
147183	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
147184	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
147185	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	0	
147186	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
147187	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
147188	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
147189	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
147190	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
147191	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
147192	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147193	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
147194	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
147195	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
147196	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	37.0	
147197	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	70.0	
147198	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	36.0	
147199	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
147200	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
147201	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
147202	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	17	
147203	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	19670	
147204	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	19670	
147205	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
147206	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
147207	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
147208	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
147209	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147210	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
147211	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147212	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147213	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147214	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147215	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147216	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147217	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147218	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147219	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147220	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
147221	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147222	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147223	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments		
147224	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147225	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
147226	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147227	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147228	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147229	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147230	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147231	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147232	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147233	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147234	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147235	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147236	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147237	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
147238	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
147239	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
147240	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
147241	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	61	*F
147242	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
147243	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147244	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147245	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
147246	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
147247	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
147248	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
147249	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
147250	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
147251	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments	ok	
147252	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
147253	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
147254	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
147255	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	1102	
147256	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	*C
147257	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147258	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments	Counter is operating twice per step.	
147259	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
147260	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
147261	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
147262	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147263	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147264	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
147265	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
147266	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	97870	
147267	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147268	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
147269	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
147270	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
147271	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
147272	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
147273	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
147274	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
147275	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
147276	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
147277	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
147278	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
147279	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
147280	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
147281	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
147282	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
147283	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
147284	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
147285	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
147286	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	3	
147287	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	3	
147288	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
147289	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
147290	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
147291	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
147292	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
147293	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
147294	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
147295	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
147296	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
147297	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
147298	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
147299	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
147300	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
147301	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147302	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
147303	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
147304	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
147305	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
147306	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	1	
147307	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147308	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
147309	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
147310	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments	ok	
147311	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments	ok	
147312	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
147313	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
147314	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
147315	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
147316	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
147317	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
147318	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
147319	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
147320	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	2.94	
147321	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	2.94	
147322	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
147323	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
147324	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
147325	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147326	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
147327	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
147328	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
147329	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	25.0	
147330	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	25.0	
147331	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	25.0	
147332	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
147333	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
147334	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
147335	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	5	
147336	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
147337	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
147338	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
147339	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
147340	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
147341	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
147342	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
147343	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC0000651	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
147344	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
147345	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147346	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147347	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147348	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147349	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
147350	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147351	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
147352	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
147353	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
147354	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
147355	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
147356	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
147357	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
147358	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
147359	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
147360	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
147361	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
147362	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
147363	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
147364	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
147365	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
147366	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
147367	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
147368	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
147369	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
147370	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
147371	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
147372	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
147373	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
147374	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
147375	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
147376	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
147377	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
147378	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
147379	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
147380	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
147381	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
147382	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments	ok	
147383	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
147384	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
147385	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
147386	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
147387	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
147388	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
147389	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
147390	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
147391	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
147392	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
147393	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
147394	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
147395	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
147396	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
147397	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
147398	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
147399	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
147400	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
147401	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
147402	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
147403	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
147404	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
147405	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
147406	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
147407	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
147408	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
147409	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
147410	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
147411	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
147412	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
147413	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
147414	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
147415	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
147416	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
147417	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
147418	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147419	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
147420	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
147421	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
147422	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
147423	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
147424	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
147425	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
147426	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
147427	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
147428	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0312	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
147429	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
147430	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
147431	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	1.0848	
147432	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
147433	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
147434	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
147435	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
147436	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
147437	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
147438	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
147439	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
147440	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
147441	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
147442	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	6508.80	kw
147443	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
147444	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
147445	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
147446	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
147447	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
147448	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
147449	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
147450	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147451	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147452	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147453	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147454	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147455	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147456	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147457	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147458	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147459	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147460	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147461	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
147462	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
147463	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
147464	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
147465	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
147466	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
147467	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
147468	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
147469	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
147470	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
147471	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
147472	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
147473	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments	ok	
147474	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
147475	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
147476	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
147477	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
147478	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
147479	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
147480	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
147481	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
147482	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
147483	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
147484	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
147485	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
147486	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments	ok	
147487	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
147488	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
147489	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
147490	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
147491	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
147492	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
147493	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147494	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147495	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
147496	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
147497	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTLC Bushing Dynamic Health	0.00	
147498	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
147499	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
147500	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
147501	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
147502	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
147503	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
147504	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
147505	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
147506	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
147507	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
147508	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
147509	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
147510	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
147511	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
147512	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
147513	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
147514	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
147515	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
147516	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
147517	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
147518	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.6180	
147519	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
147520	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
147521	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	1	
147522	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	1	
147523	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	285	
147524	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
147525	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
147526	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
147527	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
147528	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
147529	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
147530	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
147531	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
147532	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
147533	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
147534	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
147535	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
147536	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	40	*C
147537	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	65	*C
147538	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
147539	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
147540	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	7766.40	kw
147541	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
147542	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147543	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments		
147544	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147545	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147546	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147547	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147548	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
147549	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
147550	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
147551	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
147552	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147553	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147554	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147555	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147556	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
147557	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147558	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
147559	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
147560	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147561	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	indicator head broke	
147562	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
147563	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
147564	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1R	
147565	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147566	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147567	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
147568	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
147569	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
147570	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	30126	
147571	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
147572	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
147573	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
147574	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
147575	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
147576	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
147577	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
147578	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
147579	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
147580	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
147581	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
147582	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
147583	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
147584	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147585	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147586	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147587	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147588	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
147589	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
147590	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
147591	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
147592	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
147593	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
147594	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
147595	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
147596	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
147597	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
147598	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
147599	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
147600	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
147601	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147602	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
147603	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
147604	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
147605	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
147606	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
147607	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments	ok	
147608	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
147609	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
147610	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
147611	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
147612	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
147613	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
147614	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
147615	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
147616	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
147617	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
147618	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
147619	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
147620	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
147621	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments		
147622	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
147623	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
147624	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
147625	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
147626	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
147627	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
147628	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147629	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147630	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
147631	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
147632	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147633	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
147634	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147635	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
147636	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147637	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147638	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147639	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147640	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147641	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
147642	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
147643	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147644	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
147645	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
147646	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
147647	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	14L	
147648	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147649	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147650	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
147651	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
147652	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
147653	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	21301	
147654	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147655	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
147656	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
147657	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
147658	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
147659	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147660	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147661	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147662	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147663	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
147664	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147665	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
147666	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
147667	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147668	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
147669	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
147670	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
147671	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	12L	
147672	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147673	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147674	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
147675	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
147676	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147677	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	27750	
147678	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147679	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments		
147680	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147681	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
147682	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147683	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147684	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147685	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
147686	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147687	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147688	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147689	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147690	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
147691	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
147692	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147693	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments		
147694	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
147695	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
147696	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
147697	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147698	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147699	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
147700	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
147701	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
147702	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58509	
147703	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147704	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
147705	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
147706	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
147707	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
147708	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147709	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147710	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147711	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147712	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
147713	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147714	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
147715	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
147716	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147717	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
147718	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
147719	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
147720	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
147721	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147722	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147723	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
147724	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
147725	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
147726	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	367768	
147727	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147728	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
147729	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
147730	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
147731	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147732	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147733	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147734	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147735	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	11L	
147736	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147737	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
147738	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
147739	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
147740	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
147741	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
147742	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
147743	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
147744	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
147745	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
147746	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
147747	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
147748	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
147749	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147750	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
147751	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147752	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
147753	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	110.0	
147754	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	110.0	
147755	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	90.0	
147756	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
147757	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
147758	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
147759	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	3	
147760	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
147761	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
147762	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147763	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34428	
147764	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
147765	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
147766	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
147767	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147768	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147769	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
147770	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
147771	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
147772	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments		
147773	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
147774	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147775	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
147776	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147777	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147778	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147779	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147780	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
147781	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
147782	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	None	
147783	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147784	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	118041	
147785	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147786	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147787	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147788	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
147789	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147790	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
147791	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
147792	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
147793	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
147794	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147795	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147796	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147797	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147798	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
147799	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147800	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
147801	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
147802	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147803	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
147804	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
147805	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147806	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147807	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
147808	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
147809	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
147810	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
147811	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
147812	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
147813	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
147814	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
147815	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
147816	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
147817	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
147818	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	LTC000321	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
147819	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
147820	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
147821	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
147822	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
147823	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	1	
147824	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99938	
147825	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99938	
147826	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
147827	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	1	
147828	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
147829	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
147830	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments	ok	
147831	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments	ok	
147832	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
147833	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
147834	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
147835	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
147836	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147837	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
147838	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147839	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147840	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147841	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147842	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
147843	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147844	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
147845	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
147846	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147847	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
147848	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
147849	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
147850	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
147851	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
147852	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
147853	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
147854	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
147855	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
147856	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
147857	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
147858	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
147859	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
147860	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
147861	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	
147862	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
147863	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1421	
147864	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
147865	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
147866	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
147867	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
147868	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
147869	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
147870	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
147871	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
147872	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
147873	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
147874	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
147875	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
147876	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
147877	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
147878	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
147879	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
147880	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
147881	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
147882	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
147883	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
147884	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
147885	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
147886	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
147887	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
147888	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
147889	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
147890	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147891	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147892	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
147893	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
147894	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
147895	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
147896	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
147897	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
147898	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
147899	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
147900	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
147901	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
147902	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
147903	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
147904	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
147905	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
147906	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
147907	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
147908	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	495	
147909	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	5L	
147910	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	1L	
147911	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	4L	
147912	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
147913	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	120261	
147914	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	120251	
147915	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments	ok	
147916	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments	ok	
147917	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
147918	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
147919	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
147920	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
147921	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
147922	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
147923	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
147924	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
147925	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
147926	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147927	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147928	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
147929	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
147930	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
147931	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
147932	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
147933	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
147934	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
147935	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
147936	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
147937	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
147938	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
147939	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
147940	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
147941	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21590	
147942	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
147943	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
147944	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
147945	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
147946	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
147947	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147948	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147949	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
147950	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
147951	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
147952	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
147953	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
147954	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
147955	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments		
147956	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
147957	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
147958	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
147959	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
147960	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
147961	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
147962	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
147963	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
147964	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
147965	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	1113	
147966	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	9L	
147967	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	1R	
147968	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	1L	
147969	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
147970	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	13983	
147971	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	13983	
147972	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
147973	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments		
147974	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
147975	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
147976	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
147977	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
147978	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
147979	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
147980	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
147981	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
147982	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
147983	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
147984	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
147985	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
147986	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
147987	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
147988	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
147989	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	230.0	
147990	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	215.0	
147991	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	210.0	
147992	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
147993	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	General Comments		
147994	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
147995	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
147996	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
147997	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
147998	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
147999	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	184	
148000	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	184	
148001	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
148002	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
148003	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
148004	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
148005	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
148006	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
148007	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
148008	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
148009	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
148010	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
148011	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
148012	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
148013	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	78828	
148014	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
148015	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
148016	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
148017	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
148018	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
148019	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
148020	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
148021	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
148022	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
148023	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
148024	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
148025	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148026	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148027	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148028	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148029	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
148030	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
148031	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
148032	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
148033	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
148034	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
148035	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
148036	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
148037	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
148038	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
148039	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
148040	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
148041	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148042	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
148043	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
148044	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	367	
148045	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	0	
148046	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
148047	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148048	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
148049	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
148050	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0310	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
148051	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148052	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
148053	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148054	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148055	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148056	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
148057	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148058	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
148059	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
148060	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148061	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
148062	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments	ok	
148063	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
148064	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
148065	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
148066	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2599.68	kw
148067	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
148068	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
148069	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
148070	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
148071	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148072	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
148073	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
148074	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
148075	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments	ok	
148076	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
148077	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
148078	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
148079	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
148080	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
148081	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	
148082	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
148083	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
148084	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
148085	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
148086	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
148087	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
148088	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
148089	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
148090	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148091	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
148092	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
148093	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	285	
148094	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
148095	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
148096	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148097	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
148098	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
148099	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
148100	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
148101	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
148102	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
148103	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
148104	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
148105	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
148106	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
148107	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148108	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148109	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148110	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148111	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148112	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148113	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148114	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148115	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148116	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
148117	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
148118	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
148119	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
148120	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148121	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
148122	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
148123	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
148124	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
148125	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
148126	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
148127	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
148128	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
148129	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
148130	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148131	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
148132	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
148133	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	66	
148134	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	66	
148135	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	4	
148136	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148137	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	4	
148138	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
148139	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	6	
148140	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
148141	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
148142	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
148143	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	15.0	
148144	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	20.0	
148145	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	10.0	
148146	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
148147	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
148148	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
148149	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
148150	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
148151	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
148152	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
148153	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
148154	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
148155	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
148156	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
148157	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
148158	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
148159	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
148160	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	408	
148161	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	408	
148162	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
148163	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
148164	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
148165	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
148166	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
148167	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
148168	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
148169	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148170	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148171	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
148172	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
148173	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148174	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
148175	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8124	
148176	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148177	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148178	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	2	
148179	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
148180	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
148181	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148182	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148183	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
148184	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
148185	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
148186	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
148187	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
148188	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
148189	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
148190	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
148191	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
148192	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
148193	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
148194	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
148195	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
148196	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
148197	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
148198	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments	ok	
148199	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
148200	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	11	
148201	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148202	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148203	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148204	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	60.0	
148205	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	45.0	
148206	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	50.0	
148207	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
148208	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148209	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148210	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148211	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148212	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148213	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148214	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148215	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148216	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148217	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
148218	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
148219	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148220	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
148221	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
148222	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148223	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
148224	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
148225	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments	ok	
148226	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
148227	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
148228	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
148229	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
148230	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
148231	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
148232	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
148233	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148234	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
148235	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
148236	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148237	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148238	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
148239	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
148240	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
148241	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
148242	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148243	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
148244	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
148245	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148246	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
148247	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
148248	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148249	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
148250	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
148251	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
148252	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	18060.00	kw
148253	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
148254	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
148255	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
148256	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	811.20	kw
148257	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
148258	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
148259	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	40	°C
148260	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	30	°C
148261	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148262	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
148263	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148264	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148265	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
148266	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
148267	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148268	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
148269	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	.1014	
148270	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	40	°C
148271	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	30	°C
148272	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
148273	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.8	
148274	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
148275	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
148276	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
148277	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
148278	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments		
148279	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
148280	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	95	
148281	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
148282	10/7/2019 13:50	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
148283	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
148284	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148285	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148286	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
148287	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	75	°C
148288	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	35	°C
148289	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
148290	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
148291	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148292	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
148293	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148294	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148295	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
148296	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
148297	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
148298	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.538	
148299	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
148300	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
148301	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148302	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148303	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
148304	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
148305	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
148306	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
148307	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148308	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148309	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
148310	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
148311	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148312	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments	ok	
148313	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments	ok	
148314	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
148315	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	5042.88	kw
148316	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
148317	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
148318	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	55	°C
148319	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
148320	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
148321	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
148322	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
148323	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
148324	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
148325	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
148326	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
148327	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
148328	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
148329	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	30	°C
148330	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148331	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
148332	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
148333	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	General Comments		
148334	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
148335	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148336	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148337	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
148338	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
148339	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148340	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
148341	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	1.0506	
148342	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
148343	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
148344	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
148345	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
148346	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
148347	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
148348	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
148349	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.045	millivolts
148350	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	4	
148351	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148352	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148353	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148354	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	45.0	
148355	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	45.0	
148356	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	45.0	
148357	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
148358	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148359	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148360	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148361	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148362	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148363	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148364	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148365	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
148366	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
148367	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
148368	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148369	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148370	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148371	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
148372	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
148373	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148374	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
148375	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
148376	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148377	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
148378	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	
148379	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
148380	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
148381	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
148382	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
148383	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
148384	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
148385	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148386	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148387	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
148388	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
148389	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
148390	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
148391	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148392	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148393	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
148394	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	64.0	
148395	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	69.0	
148396	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	73.0	
148397	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
148398	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
148399	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
148400	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
148401	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
148402	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
148403	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
148404	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
148405	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
148406	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
148407	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
148408	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
148409	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
148410	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	1	
148411	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
148412	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
148413	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
148414	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.8	
148415	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.4	
148416	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
148417	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148418	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
148419	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
148420	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
148421	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2153.60	kw
148422	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
148423	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
148424	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	45	°C
148425	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	32	°C
148426	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148427	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
148428	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148429	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
148430	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
148431	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
148432	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
148433	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.6730	
148434	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
148435	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
148436	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148437	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
148438	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
148439	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	265	
148440	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	265	
148441	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations This Read Vac	4	
148442	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148443	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	4	
148444	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
148445	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
148446	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.2	
148447	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
148448	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
148449	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
148450	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148451	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
148452	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
148453	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148454	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
148455	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148456	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148457	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
148458	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	1.2900	
148459	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	75	°C
148460	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148461	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
148462	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
148463	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
148464	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
148465	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
148466	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	40	°C
148467	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
148468	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
148469	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
148470	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148471	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148472	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
148473	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
148474	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148475	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
148476	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
148477	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments	ok	
148478	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments	ok	
148479	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
148480	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148481	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	1	
148482	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
148483	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	162	
148484	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	162	
148485	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	1	
148486	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148487	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
148488	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
148489	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
148490	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	37	°C
148491	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
148492	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
148493	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
148494	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
148495	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	69597	
148496	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
148497	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
148498	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
148499	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
148500	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
148501	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	2L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
148502	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	14R	
148503	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
148504	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments		
148505	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
148506	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
148507	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
148508	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
148509	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	1R	
148510	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
148511	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
148512	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
148513	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
148514	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
148515	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	12	
148516	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148517	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148518	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148519	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	60.0	
148520	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	55.0	
148521	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	60.0	
148522	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
148523	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148524	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148525	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148526	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148527	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148528	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148529	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148530	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148531	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148532	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
148533	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
148534	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
148535	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
148536	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148537	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148538	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	2	
148539	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
148540	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	11	
148541	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148542	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148543	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148544	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180.0	
148545	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	165.0	
148546	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	160.0	
148547	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
148548	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148549	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148550	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148551	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148552	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148553	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148554	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148555	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148556	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148557	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
148558	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
148559	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
148560	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
148561	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
148562	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
148563	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
148564	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
148565	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
148566	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
148567	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148568	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
148569	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
148570	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	99998	
148571	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	99998	
148572	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations This Read Vac	4	
148573	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148574	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	4	
148575	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
148576	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148577	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
148578	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
148579	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
148580	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
148581	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	General Comments	ok	
148582	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
148583	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
148584	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
148585	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148586	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148587	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
148588	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
148589	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
148590	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
148591	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
148592	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
148593	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148594	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148595	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148596	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148597	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148598	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148599	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148600	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
148601	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	300.0	
148602	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	294.0	
148603	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	286.0	
148604	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148605	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148606	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148607	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	1	
148608	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	3	
148609	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148610	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148611	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148612	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	0.0	
148613	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	0.0	
148614	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	0.0	
148615	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
148616	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
148617	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
148618	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
148619	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
148620	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Min Tap Position	2R	
148621	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Max Tap Position	16R	
148622	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
148623	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	General Comments		
148624	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
148625	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
148626	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
148627	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
148628	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
148629	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	1.2	VDC
148630	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.6	VDC
148631	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments	ok	
148632	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
148633	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
148634	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
148635	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
148636	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
148637	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
148638	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
148639	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
148640	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
148641	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
148642	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Current Tap Position	7R	
148643	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
148644	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
148645	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
148646	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
148647	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
148648	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
148649	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
148650	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
148651	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148652	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
148653	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
148654	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
148655	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
148656	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
148657	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
148658	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
148659	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
148660	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
148661	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
148662	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
148663	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
148664	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	0	
148665	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations This Read Vac	0	
148666	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	246	
148667	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	246	
148668	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
148669	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
148670	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148671	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
148672	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
148673	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
148674	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
148675	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
148676	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
148677	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
148678	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
148679	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
148680	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
148681	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148682	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148683	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148684	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148685	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148686	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148687	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148688	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148689	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148690	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
148691	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
148692	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
148693	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
148694	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148695	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BA1001383	Battery	874-Battery Bank	Battery Patrol Inspection	Negative DC Ground	67.5	VDC
148696	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
148697	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1991.52	kw
148698	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
148699	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
148700	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
148701	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
148702	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148703	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
148704	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148705	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148706	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
148707	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
148708	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148709	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
148710	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8298	
148711	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
148712	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
148713	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148714	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148715	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148716	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148717	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
148718	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
148719	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148720	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments		
148721	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
148722	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
148723	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
148724	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148725	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	1	
148726	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	124	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148727	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	124	
148728	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
148729	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	1	
148730	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148731	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
148732	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments	ok	
148733	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	General Comments		
148734	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
148735	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments	ok	
148736	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
148737	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
148738	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
148739	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
148740	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
148741	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
148742	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
148743	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148744	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148745	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148746	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148747	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148748	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148749	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148750	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148751	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148752	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
148753	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	75.0	
148754	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	75.0	
148755	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	75.0	
148756	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148757	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		
148758	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148759	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148760	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	2	
148761	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
148762	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
148763	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1329.12	kw
148764	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
148765	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
148766	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
148767	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
148768	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148769	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
148770	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
148771	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
148772	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
148773	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
148774	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
148775	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
148776	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148777	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148778	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148779	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148780	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148781	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148782	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148783	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148784	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148785	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
148786	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
148787	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
148788	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
148789	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
148790	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
148791	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
148792	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
148793	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
148794	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
148795	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
148796	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
148797	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
148798	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
148799	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
148800	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
148801	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
148802	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
148803	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
148804	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
148805	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148806	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148807	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148808	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148809	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
148810	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
148811	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148812	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
148813	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments	ok	
148814	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
148815	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
148816	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
148817	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
148818	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148819	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
148820	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
148821	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	213	
148822	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	213	
148823	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations This Read Vac	1	
148824	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	1	
148825	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
148826	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
148827	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	General Comments		
148828	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
148829	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
148830	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
148831	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
148832	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
148833	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
148834	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
148835	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
148836	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
148837	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
148838	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	General Comments		
148839	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
148840	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
148841	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
148842	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
148843	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
148844	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
148845	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
148846	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
148847	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148848	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148849	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
148850	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
148851	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
148852	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
148853	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
148854	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.1	VDC
148855	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
148856	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
148857	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
148858	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148859	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148860	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
148861	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
148862	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148863	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
148864	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
148865	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
148866	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
148867	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments		
148868	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
148869	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
148870	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
148871	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
148872	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
148873	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
148874	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	3	
148875	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148876	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
148877	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148878	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	211.0	
148879	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	224.0	
148880	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	227.0	
148881	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
148882	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148883	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148884	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148885	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148886	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148887	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148888	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
148889	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148890	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148891	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	1	
148892	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
148893	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
148894	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
148895	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
148896	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
148897	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
148898	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
148899	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
148900	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
148901	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
148902	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
148903	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	237	
148904	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	237	
148905	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	2	
148906	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148907	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	1	
148908	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
148909	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
148910	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	2	
148911	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148912	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148913	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148914	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	69.0	
148915	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	53.0	
148916	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	76.0	
148917	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
148918	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148919	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
148920	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
148921	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
148922	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
148923	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
148924	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	50	
148925	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	50	
148926	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
148927	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
148928	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
148929	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
148930	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
148931	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
148932	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
148933	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
148934	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
148935	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
148936	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
148937	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
148938	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
148939	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
148940	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
148941	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
148942	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
148943	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
148944	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
148945	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
148946	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
148947	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
148948	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
148949	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
148950	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	550.0	
148951	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
148952	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
148953	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
148954	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
148955	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
148956	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
148957	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
148958	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
148959	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
148960	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
148961	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
148962	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
148963	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
148964	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
148965	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
148966	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	11019	
148967	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
148968	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
148969	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
148970	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
148971	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
148972	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
148973	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
148974	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	90	°C
148975	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
148976	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
148977	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
148978	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
148979	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
148980	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
148981	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	General Comments		
148982	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
148983	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
148984	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
148985	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
148986	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
148987	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	LTC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
148988	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
148989	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
148990	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	114	
148991	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
148992	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
148993	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments	ok	
148994	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
148995	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
148996	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
148997	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
148998	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
148999	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
149000	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
149001	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
149002	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
149003	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
149004	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
149005	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	126	
149006	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
149007	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
149008	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
149009	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
149010	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
149011	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
149012	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
149013	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149014	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
149015	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	11	
149016	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149017	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149018	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149019	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	50.0	
149020	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	50.0	
149021	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
149022	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
149023	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
149024	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
149025	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8268	
149026	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	50.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149027	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
149028	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149029	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149030	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149031	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149032	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149033	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149034	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149035	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149036	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149037	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
149038	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
149039	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
149040	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
149041	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
149042	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
149043	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
149044	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
149045	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments		
149046	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
149047	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149048	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	5	
149049	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
149050	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	155	
149051	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	155	
149052	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	5	
149053	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149054	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	0	
149055	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
149056	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
149057	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
149058	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
149059	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
149060	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
149061	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
149062	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	General Comments		
149063	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
149064	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
149065	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Operations Counter	1856	
149066	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
149067	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Leaks	None	
149068	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
149069	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
149070	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
149071	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
149072	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149073	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
149074	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
149075	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149076	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
149077	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	40.600	millivolts
149078	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.3	VDC
149079	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.3	VDC
149080	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
149081	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149082	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
149083	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
149084	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149085	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
149086	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
149087	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	115.0	VAC
149088	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	115.0	VAC
149089	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	115.3	VAC
149090	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
149091	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	General Comments	ok	
149092	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
149093	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	LTC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
149094	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
149095	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
149096	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
149097	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
149098	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
149099	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149100	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149101	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149102	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149103	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149104	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149105	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149106	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149107	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149108	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
149109	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	640.0	
149110	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	600.0	
149111	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	640.0	
149112	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149113	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149114	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149115	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
149116	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149117	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149118	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149119	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149120	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149121	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149122	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149123	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149124	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
149125	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
149126	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
149127	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
149128	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
149129	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
149130	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
149131	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
149132	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
149133	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
149134	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
149135	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
149136	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
149137	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1984.32	kw
149138	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
149139	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
149140	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	44	°C
149141	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
149142	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
149143	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
149144	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
149145	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
149146	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
149147	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
149148	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
149149	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
149150	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
149151	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	228	
149152	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	228	
149153	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	1	
149154	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149155	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	1	
149156	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
149157	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
149158	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
149159	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
149160	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
149161	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149162	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
149163	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments		
149164	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
149165	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
149166	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
149167	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
149168	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
149169	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
149170	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
149171	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
149172	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
149173	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
149174	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
149175	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
149176	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149177	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	394	
149178	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
149179	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
149180	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
149181	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149182	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149183	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149184	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
149185	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
149186	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
149187	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
149188	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
149189	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
149190	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
149191	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
149192	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
149193	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149194	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149195	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149196	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149197	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149198	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149199	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149200	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149201	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
149202	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
149203	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
149204	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
149205	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
149206	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
149207	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	54	*F
149208	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
149209	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
149210	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
149211	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
149212	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
149213	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments	ok	
149214	10/7/2019 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
149215	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
149216	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
149217	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
149218	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
149219	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
149220	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
149221	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
149222	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
149223	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
149224	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
149225	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
149226	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
149227	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
149228	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
149229	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
149230	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
149231	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
149232	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
149233	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
149234	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
149235	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
149236	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
149237	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments		
149238	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
149239	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
149240	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
149241	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
149242	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
149243	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
149244	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
149245	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
149246	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
149247	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
149248	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
149249	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
149250	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
149251	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149252	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
149253	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
149254	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
149255	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
149256	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
149257	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
149258	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	70	°C
149259	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
149260	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		
149261	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
149262	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
149263	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
149264	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
149265	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
149266	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
149267	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
149268	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
149269	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
149270	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
149271	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
149272	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
149273	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
149274	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
149275	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	
149276	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	General Comments		
149277	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
149278	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
149279	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
149280	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
149281	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
149282	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
149283	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Leaks	None	
149284	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
149285	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
149286	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Regulator As Left Counter	161225	
149287	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
149288	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
149289	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
149290	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
149291	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
149292	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
149293	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
149294	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
149295	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	General Comments	ok	
149296	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
149297	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
149298	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
149299	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
149300	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
149301	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
149302	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
149303	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
149304	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
149305	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
149306	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
149307	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Leaks	None	
149308	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
149309	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
149310	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61918	
149311	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
149312	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
149313	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
149314	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
149315	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
149316	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
149317	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
149318	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
149319	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments	ok	
149320	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
149321	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
149322	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
149323	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
149324	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
149325	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
149326	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149327	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
149328	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
149329	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
149330	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149331	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
149332	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149333	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments		
149334	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
149335	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
149336	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
149337	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
149338	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
149339	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	1R	
149340	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
149341	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
149342	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
149343	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
149344	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
149345	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
149346	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	5R	
149347	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
149348	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
149349	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
149350	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
149351	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
149352	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
149353	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	11729	
149354	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
149355	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
149356	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
149357	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
149358	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
149359	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
149360	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
149361	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
149362	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
149363	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	1R	
149364	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
149365	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
149366	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
149367	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
149368	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
149369	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
149370	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
149371	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
149372	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
149373	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
149374	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
149375	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
149376	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	5R	
149377	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
149378	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
149379	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
149380	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
149381	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
149382	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
149383	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	12048	
149384	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
149385	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
149386	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
149387	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
149388	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
149389	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
149390	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
149391	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
149392	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
149393	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
149394	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
149395	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
149396	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
149397	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
149398	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
149399	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
149400	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149401	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149402	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	273	
149403	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	273	
149404	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
149405	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
149406	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149407	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
149408	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
149409	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
149410	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
149411	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
149412	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
149413	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
149414	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
149415	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
149416	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
149417	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments		
149418	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149419	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
149420	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
149421	10/7/2019 13:31	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
149422	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
149423	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149424	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
149425	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
149426	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	602	
149427	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	602	
149428	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
149429	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149430	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
149431	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Bad	
149432	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
149433	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
149434	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149435	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
149436	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
149437	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
149438	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
149439	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
149440	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
149441	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
149442	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
149443	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
149444	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
149445	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
149446	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
149447	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
149448	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	1	
149449	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	65	
149450	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	65	
149451	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	0	
149452	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
149453	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
149454	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
149455	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	0	
149456	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
149457	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	0	
149458	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
149459	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
149460	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
149461	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	200.0	
149462	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	210.0	
149463	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	230.0	
149464	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
149465	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
149466	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
149467	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
149468	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0402	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
149469	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
149470	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
149471	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
149472	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
149473	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
149474	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
149475	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
149476	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149477	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
149478	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
149479	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	273	
149480	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	273	
149481	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
149482	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
149483	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
149484	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
149485	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
149486	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
149487	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
149488	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
149489	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
149490	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
149491	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
149492	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
149493	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	30	*C
149494	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
149495	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
149496	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
149497	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
149498	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
149499	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	4	
149500	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
149501	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
149502	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
149503	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	80.0	
149504	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	100.0	
149505	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	80.0	
149506	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
149507	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
149508	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
149509	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
149510	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	1	
149511	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	1	
149512	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
149513	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
149514	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
149515	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
149516	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
149517	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
149518	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
149519	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
149520	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
149521	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
149522	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
149523	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
149524	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
149525	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
149526	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
149527	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
149528	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
149529	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
149530	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
149531	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	491	
149532	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	491	
149533	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	2	
149534	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
149535	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
149536	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
149537	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
149538	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
149539	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
149540	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
149541	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
149542	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
149543	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
149544	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
149545	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	9.1	VDC
149546	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.9	VDC
149547	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
149548	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	210	
149549	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
149550	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments		
149551	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149552	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149553	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
149554	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149555	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
149556	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	45.9	
149557	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.5	
149558	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	47.4	
149559	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
149560	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
149561	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
149562	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
149563	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
149564	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.3	VDC
149565	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
149566	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149567	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	0	
149568	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
149569	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
149570	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
149571	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
149572	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
149573	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
149574	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
149575	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
149576	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
149577	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
149578	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
149579	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
149580	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
149581	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
149582	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
149583	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
149584	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
149585	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
149586	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
149587	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
149588	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
149589	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
149590	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
149591	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
149592	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
149593	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
149594	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
149595	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
149596	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
149597	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
149598	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
149599	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
149600	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
149601	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
149602	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
149603	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
149604	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
149605	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments	ok	
149606	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
149607	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
149608	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
149609	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
149610	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
149611	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
149612	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
149613	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
149614	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
149615	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
149616	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
149617	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
149618	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
149619	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
149620	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
149621	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
149622	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
149623	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
149624	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7603.20	kw
149625	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
149626	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149627	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
149628	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
149629	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
149630	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
149631	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
149632	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
149633	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
149634	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
149635	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
149636	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
149637	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7920	
149638	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	55	°C
149639	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
149640	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
149641	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149642	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149643	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149644	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
149645	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	43337	
149646	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	43337	
149647	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
149648	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
149649	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
149650	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
149651	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149652	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
149653	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	105.0	
149654	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
149655	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
149656	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
149657	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
149658	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
149659	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
149660	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	100.0	
149661	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	105.0	
149662	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149663	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149664	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149665	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	12	
149666	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
149667	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
149668	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
149669	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
149670	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
149671	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
149672	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
149673	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
149674	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
149675	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
149676	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
149677	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
149678	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
149679	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
149680	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
149681	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
149682	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
149683	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
149684	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
149685	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
149686	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
149687	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
149688	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
149689	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
149690	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
149691	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
149692	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
149693	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
149694	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
149695	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
149696	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
149697	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
149698	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
149699	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
149700	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
149701	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149702	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
149703	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
149704	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
149705	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1009	
149706	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
149707	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
149708	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
149709	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
149710	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
149711	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
149712	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	General Comments	ok	
149713	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
149714	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
149715	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
149716	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
149717	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
149718	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
149719	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
149720	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Fair	
149721	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
149722	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
149723	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
149724	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
149725	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments	There is a washout where the driveway crosses the small creek and culvert.Road is washed out again	
149726	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
149727	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
149728	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
149729	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
149730	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
149731	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	4	
149732	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149733	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	6	
149734	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	715	
149735	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	715	
149736	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
149737	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	1	
149738	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149739	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
149740	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
149741	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
149742	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
149743	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
149744	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
149745	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
149746	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
149747	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
149748	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
149749	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
149750	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
149751	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	196	
149752	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.3	
149753	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.5	
149754	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.4	
149755	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	230	
149756	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
149757	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149758	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	193	
149759	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
149760	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149761	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
149762	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	General Comments	need varmet guard	
149763	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
149764	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
149765	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
149766	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
149767	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.2	
149768	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.5	
149769	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.3	
149770	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
149771	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149772	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
149773	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149774	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
149775	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments	ok	
149776	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149777	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	784	
149778	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
149779	10/7/2019 13:05	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
149780	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	1	
149781	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149782	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149783	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	3.26	
149784	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149785	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149786	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	0	
149787	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149788	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
149789	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments	ok	
149790	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments	ok	
149791	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149792	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149793	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149794	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
149795	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
149796	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
149797	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	0	
149798	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	223	
149799	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
149800	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
149801	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149802	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
149803	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
149804	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
149805	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
149806	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
149807	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149808	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
149809	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149810	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149811	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149812	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149813	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149814	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149815	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
149816	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	260.0	
149817	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments	ok	
149818	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments	ok	
149819	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
149820	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	260.0	
149821	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	260.0	
149822	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149823	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149824	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149825	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	1	
149826	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
149827	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
149828	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
149829	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
149830	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
149831	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
149832	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
149833	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments	ok	
149834	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
149835	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
149836	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
149837	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
149838	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
149839	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
149840	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
149841	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
149842	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
149843	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	4.43	
149844	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
149845	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
149846	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
149847	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	4.43	
149848	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	4.43	
149849	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149850	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149851	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
149852	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149853	10/7/2019 10:44	Distribution	Clinton 12KV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
149854	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
149855	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
149856	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
149857	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
149858	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	General Comments		
149859	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
149860	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
149861	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
149862	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
149863	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	5891	
149864	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	5891	
149865	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
149866	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
149867	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
149868	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	0	
149869	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149870	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations This Read Vac	0	
149871	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	183	
149872	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	183	
149873	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
149874	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	0	
149875	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149876	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
149877	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments	ok	
149878	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments	ok	
149879	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
149880	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
149881	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
149882	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	4L	
149883	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
149884	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
149885	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
149886	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
149887	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
149888	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
149889	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
149890	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
149891	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
149892	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
149893	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
149894	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
149895	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
149896	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
149897	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments	ok	
149898	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
149899	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
149900	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
149901	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
149902	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
149903	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
149904	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
149905	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
149906	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
149907	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
149908	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
149909	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	2L	
149910	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
149911	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
149912	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
149913	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
149914	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	10L	
149915	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments	ok	
149916	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
149917	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
149918	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
149919	10/7/2019 11:30	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
149920	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
149921	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	828	
149922	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
149923	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
149924	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
149925	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	2	
149926	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
149927	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	0	
149928	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
149929	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	2	
149930	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	119	
149931	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	119	
149932	10/7/2019 12:18	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
149933	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	140.0	
149934	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149935	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149936	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
149937	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	58.0	
149938	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	60.0	
149939	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	54.0	
149940	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
149941	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
149942	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
149943	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	1	
149944	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	73	
149945	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
149946	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.3	
149947	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
149948	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	64	
149949	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
149950	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
149951	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	88	
149952	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
149953	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
149954	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
149955	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
149956	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
149957	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
149958	10/8/2019 7:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
149959	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	130.0	
149960	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
149961	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
149962	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
149963	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
149964	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
149965	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
149966	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
149967	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
149968	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
149969	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
149970	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
149971	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
149972	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
149973	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
149974	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
149975	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
149976	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
149977	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
149978	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
149979	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
149980	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
149981	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
149982	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
149983	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
149984	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
149985	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
149986	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	6.55	
149987	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	6.55	
149988	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
149989	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	1	
149990	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	1	
149991	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
149992	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
149993	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
149994	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
149995	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments	ok	
149996	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments	ok	
149997	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
149998	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
149999	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
150000	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
150001	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150002	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
150003	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	266	
150004	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	266	
150005	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations This Read Vac	2	
150006	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
150007	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
150008	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
150009	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150010	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150011	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150012	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
150013	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	571	
150014	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.2	
150015	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	4.7	
150016	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
150017	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	412	
150018	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
150019	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
150020	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	544	
150021	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
150022	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150023	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150024	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
150025	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	30.0	
150026	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	41.0	
150027	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	37.0	
150028	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
150029	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
150030	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150031	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150032	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150033	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150034	10/7/2019 10:39	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	25	
150035	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
150036	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
150037	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
150038	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
150039	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
150040	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
150041	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
150042	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
150043	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
150044	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
150045	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments	lower hand wont reset	
150046	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
150047	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
150048	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
150049	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
150050	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
150051	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
150052	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
150053	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
150054	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37215	
150055	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
150056	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
150057	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
150058	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
150059	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
150060	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
150061	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
150062	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150063	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
150064	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
150065	10/7/2019 11:07	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
150066	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
150067	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150068	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
150069	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
150070	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
150071	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	General Comments		
150072	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
150073	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
150074	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
150075	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	40	
150076	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150077	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150078	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150079	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	100.0	
150080	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
150081	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
150082	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
150083	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
150084	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
150085	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
150086	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
150087	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150088	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
150089	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
150090	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
150091	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
150092	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	163726	
150093	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
150094	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?		
150095	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
150096	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150097	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
150098	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
150099	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
150100	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
150101	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
150102	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
150103	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
150104	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
150105	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
150106	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
150107	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
150108	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
150109	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7L	
150110	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
150111	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	appears drag hand cable has slipped	
150112	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
150113	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
150114	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
150115	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
150116	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	10L	
150117	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
150118	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
150119	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
150120	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
150121	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
150122	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
150123	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
150124	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
150125	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
150126	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
150127	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
150128	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
150129	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
150130	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
150131	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
150132	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	General Comments	ok	
150133	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
150134	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
150135	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
150136	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
150137	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
150138	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
150139	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150140	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
150141	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150142	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
150143	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150144	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
150145	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150146	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150147	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
150148	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
150149	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
150150	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
150151	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150152	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
150153	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150154	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150155	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150156	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
150157	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
150158	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
150159	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
150160	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
150161	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
150162	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
150163	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150164	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
150165	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
150166	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150167	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150168	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150169	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150170	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
150171	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
150172	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Ground in Place?	y	
150173	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
150174	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
150175	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments	ok	
150176	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150177	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150178	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
150179	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150180	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150181	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150182	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150183	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
150184	10/7/2019 12:38	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
150185	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
150186	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	22	°C
150187	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
150188	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
150189	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
150190	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
150191	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
150192	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
150193	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150194	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
150195	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
150196	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150197	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
150198	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
150199	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150200	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
150201	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
150202	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
150203	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
150204	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	1	
150205	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	1	
150206	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	258	
150207	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	258	
150208	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
150209	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
150210	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150211	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
150212	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
150213	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
150214	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
150215	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
150216	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
150217	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
150218	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
150219	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150220	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
150221	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	177	
150222	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	177	
150223	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
150224	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
150225	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150226	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150227	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
150228	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
150229	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
150230	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
150231	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
150232	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
150233	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
150234	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
150235	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
150236	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150237	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
150238	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
150239	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
150240	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150241	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
150242	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150243	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150244	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150245	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
150246	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	225.0	
150247	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	190.0	
150248	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	225.0	
150249	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150250	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150251	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150252	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0311	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
150253	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
150254	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
150255	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	60	°C
150256	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75.00	
150257	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
150258	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
150259	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
150260	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	General Comments		
150261	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	General Comments		
150262	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150263	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
150264	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
150265	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150266	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150267	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
150268	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
150269	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
150270	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
150271	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
150272	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
150273	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
150274	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
150275	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
150276	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
150277	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	174297	
150278	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150279	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150280	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150281	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150282	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
150283	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
150284	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
150285	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
150286	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
150287	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
150288	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	
150289	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150290	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
150291	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
150292	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
150293	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
150294	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
150295	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
150296	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
150297	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
150298	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
150299	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
150300	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92557	
150301	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150302	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
150303	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
150304	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
150305	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
150306	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
150307	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150308	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150309	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150310	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
150311	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
150312	10/7/2019 15:18	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
150313	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
150314	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
150315	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
150316	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
150317	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
150318	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
150319	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
150320	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
150321	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
150322	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
150323	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
150324	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
150325	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150326	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150327	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150328	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
150329	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
150330	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
150331	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
150332	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	496452	
150333	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	496452	
150334	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
150335	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
150336	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
150337	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
150338	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
150339	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1485	
150340	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
150341	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
150342	10/7/2019 13:38	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
150343	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
150344	10/7/2019 12:16	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
150345	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
150346	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
150347	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
150348	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
150349	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150350	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
150351	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
150352	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
150353	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
150354	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
150355	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
150356	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
150357	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150358	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
150359	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
150360	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150361	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150362	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
150363	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
150364	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150365	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150366	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150367	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150368	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
150369	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
150370	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
150371	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
150372	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
150373	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments	ok	
150374	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
150375	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
150376	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150377	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150378	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150379	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
150380	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
150381	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
150382	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150383	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
150384	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150385	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150386	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150387	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
150388	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
150389	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150390	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
150391	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
150392	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
150393	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150394	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
150395	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
150396	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
150397	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
150398	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
150399	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
150400	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150401	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
150402	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150403	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
150404	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150405	10/7/2019 14:40	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
150406	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Adequate	
150407	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
150408	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
150409	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
150410	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCCControl	581-1	LTC Control Insp	All Connections OK?	y	
150411	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150412	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150413	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150414	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150415	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
150416	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
150417	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	20	°C
150418	10/8/2019 7:29	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
150419	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
150420	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCCControl	581-1	LTC Control Insp	General Comments	ok	
150421	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
150422	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
150423	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
150424	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
150425	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
150426	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
150427	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.3140	
150428	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
150429	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
150430	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
150431	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	167	
150432	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	167	
150433	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
150434	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
150435	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
150436	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
150437	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		
150438	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150439	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
150440	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
150441	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
150442	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150443	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
150444	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
150445	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
150446	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150447	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150448	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150449	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150450	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
150451	10/7/2019 11:43	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150452	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150453	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	no 911 signage	
150454	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150455	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
150456	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150457	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
150458	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
150459	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
150460	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
150461	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
150462	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
150463	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
150464	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
150465	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
150466	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1507.20	kw
150467	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
150468	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
150469	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150470	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
150471	10/7/2019 10:28	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
150472	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150473	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150474	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150475	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
150476	10/7/2019 10:44	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
150477	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
150478	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
150479	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
150480	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
150481	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
150482	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150483	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150484	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
150485	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
150486	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150487	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150488	10/7/2019 12:09	Distribution	FMC Quarterly Inspection	BB0308	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
150489	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
150490	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
150491	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
150492	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
150493	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
150494	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
150495	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
150496	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
150497	10/7/2019 14:25	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
150498	10/7/2019 10:54	Distribution	Lebanon Industrial Quarterly Inspection	LTC0000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
150499	10/7/2019 14:17	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
150500	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150501	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150502	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
150503	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
150504	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
150505	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150506	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
150507	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150508	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150509	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
150510	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150511	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
150512	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
150513	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
150514	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150515	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
150516	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150517	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150518	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
150519	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
150520	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150521	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
150522	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
150523	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
150524	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
150525	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
150526	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150527	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150528	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Foundation Condition	Good	
150529	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	General Comments		
150530	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	General Comments		
150531	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
150532	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
150533	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
150534	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
150535	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
150536	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Grounds in Place?	y	
150537	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150538	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
150539	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations This Read Vac	0	
150540	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150541	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Tank Paint Condition	Good	
150542	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
150543	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
150544	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	20.0	
150545	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps Ø	50.0	
150546	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
150547	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
150548	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
150549	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
150550	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
150551	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
150552	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
150553	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
150554	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
150555	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
150556	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150557	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
150558	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150559	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	barbwire and gate posts rusty. Briar limbs growing over one corner of the fence. Some tree limbs starting to grow over the top of the	
150560	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150561	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150562	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
150563	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150564	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150565	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
150566	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	6	
150567	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150568	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150569	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
150570	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
150571	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
150572	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
150573	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
150574	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
150575	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
150576	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
150577	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
150578	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
150579	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150580	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150581	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	50.0	
150582	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	50.0	
150583	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
150584	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150585	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150586	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
150587	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150588	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150589	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
150590	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	14.14	%
150591	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
150592	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
150593	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150594	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
150595	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
150596	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	13.52	%
150597	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	20.0	
150598	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	20.0	
150599	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150600	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
150601	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150602	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150603	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
150604	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
150605	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
150606	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
150607	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
150608	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
150609	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
150610	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
150611	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
150612	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
150613	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
150614	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
150615	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150616	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
150617	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
150618	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
150619	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
150620	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
150621	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
150622	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
150623	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
150624	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
150625	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
150626	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150627	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
150628	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
150629	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	227	
150630	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	229	
150631	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations This Read Vac	2	
150632	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150633	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	2	
150634	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
150635	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
150636	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150637	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150638	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150639	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150640	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	VRR Time Delay	30	Seconds
150641	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
150642	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
150643	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
150644	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
150645	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	LTC Operation Checked?	y	
150646	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	General Comments		
150647	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	Follow-up Action Required?	n	
150648	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCCControl	369-1	LTC Control Insp	All Connections OK?	y	
150649	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
150650	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
150651	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	
150652	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
150653	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
150654	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
150655	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
150656	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
150657	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
150658	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
150659	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	132768	
150660	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
150661	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
150662	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
150663	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150664	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
150665	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Tank Paint Condition	Good	
150666	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150667	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations This Read Vac	0	
150668	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Moisture and Leak Free?	y	
150669	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
150670	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
150671	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	8694.00	kw
150672	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
150673	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
150674	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	30	*C
150675	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	30	*C
150676	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
150677	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Heaters (All) Functioning?	y	
150678	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Grounds in Place?	y	
150679	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	General Comments		
150680	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	General Comments		
150681	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150682	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150683	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150684	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150685	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
150686	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
150687	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
150688	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
150689	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
150690	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
150691	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150692	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150693	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150694	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150695	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
150696	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	0	
150697	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
150698	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150699	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
150700	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
150701	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
150702	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.8	VDC
150703	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	4.8	VDC
150704	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
150705	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
150706	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
150707	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
150708	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
150709	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
150710	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
150711	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
150712	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
150713	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
150714	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150715	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150716	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150717	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BAT000610	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
150718	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	9 Month Operations	-1	
150719	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
150720	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150721	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
150722	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
150723	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
150724	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150725	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
150726	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushing Condition	Good	
150727	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
150728	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150729	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150730	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150731	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150732	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150733	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150734	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
150735	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150736	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
150737	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
150738	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150739	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150740	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150741	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
150742	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150743	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
150744	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
150745	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
150746	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
150747	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
150748	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150749	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
150750	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150751	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150752	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150753	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150754	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150755	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
150756	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
150757	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
150758	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
150759	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
150760	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
150761	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
150762	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
150763	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
150764	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
150765	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
150766	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
150767	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
150768	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
150769	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
150770	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
150771	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
150772	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Moisture and Leak Free?	y	
150773	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AF	625	
150774	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	625	
150775	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations This Read Vac	0	
150776	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
150777	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	0	
150778	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
150779	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
150780	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
150781	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
150782	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
150783	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
150784	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7418	
150785	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
150786	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
150787	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
150788	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
150789	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
150790	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
150791	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
150792	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
150793	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
150794	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
150795	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
150796	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
150797	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
150798	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
150799	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
150800	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
150801	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
150802	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
150803	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
150804	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
150805	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
150806	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
150807	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
150808	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
150809	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
150810	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
150811	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
150812	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
150813	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
150814	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	8	
150815	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
150816	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
150817	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
150818	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0.0	
150819	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
150820	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
150821	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
150822	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
150823	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
150824	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
150825	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
150826	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	6	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150827	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	172	
150828	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	172	
150829	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
150830	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150831	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
150832	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
150833	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
150834	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
150835	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
150836	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
150837	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments		
150838	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
150839	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
150840	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
150841	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
150842	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150843	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
150844	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
150845	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
150846	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
150847	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
150848	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
150849	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
150850	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
150851	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	52	°C
150852	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
150853	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
150854	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
150855	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
150856	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
150857	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
150858	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
150859	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
150860	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
150861	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
150862	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
150863	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
150864	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
150865	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
150866	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAPO00013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
150867	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
150868	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
150869	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
150870	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
150871	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
150872	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
150873	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
150874	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
150875	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
150876	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
150877	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
150878	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
150879	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
150880	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
150881	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
150882	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150883	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
150884	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
150885	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
150886	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
150887	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
150888	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	General Comments		
150889	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
150890	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
150891	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
150892	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
150893	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
150894	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
150895	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
150896	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
150897	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
150898	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
150899	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	General Comments		
150900	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
150901	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAPO00014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150902	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
150903	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
150904	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
150905	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
150906	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BCH000576	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
150907	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	CAP000013	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
150908	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
150909	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
150910	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
150911	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
150912	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
150913	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
150914	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
150915	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
150916	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
150917	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	7958.40	kw
150918	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
150919	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150920	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
150921	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
150922	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
150923	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150924	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
150925	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
150926	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
150927	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
150928	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
150929	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0.0	
150930	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0.0	
150931	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
150932	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
150933	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
150934	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	0	
150935	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
150936	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150937	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150938	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150939	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150940	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
150941	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
150942	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150943	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments		
150944	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
150945	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
150946	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
150947	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
150948	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
150949	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
150950	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
150951	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150952	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	170	
150953	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	170	
150954	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
150955	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
150956	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
150957	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
150958	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
150959	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
150960	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
150961	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
150962	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
150963	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
150964	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
150965	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
150966	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
150967	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
150968	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
150969	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
150970	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
150971	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
150972	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
150973	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
150974	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
150975	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
150976	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
150977	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
150978	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
150979	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
150980	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
150981	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
150982	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
150983	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
150984	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
150985	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
150986	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
150987	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
150988	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments	ABC Phase IOC	
150989	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	
150990	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
150991	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
150992	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
150993	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
150994	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
150995	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
150996	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
150997	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
150998	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
150999	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
151000	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
151001	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
151002	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
151003	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	424080	
151004	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
151005	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
151006	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
151007	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
151008	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	2	
151009	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
151010	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
151011	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
151012	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
151013	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
151014	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
151015	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
151016	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
151017	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
151018	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
151019	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
151020	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
151021	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151022	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	2	
151023	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
151024	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
151025	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
151026	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
151027	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
151028	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
151029	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
151030	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
151031	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	2	
151032	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
151033	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
151034	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
151035	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	20.0	
151036	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	20.0	
151037	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
151038	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTLC Bushing Dynamic Health	0.00	
151039	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
151040	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.8290	
151041	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
151042	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
151043	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
151044	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
151045	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
151046	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
151047	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
151048	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
151049	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	40	°C
151050	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	20.0	
151051	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	13.52	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151052	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	14.14	%
151053	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
151054	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	6	
151055	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	60	°C
151056	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
151057	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151058	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151059	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151060	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151061	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151062	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
151063	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
151064	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
151065	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
151066	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
151067	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
151068	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
151069	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1622.88	kw
151070	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
151071	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
151072	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
151073	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
151074	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
151075	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
151076	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
151077	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
151078	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
151079	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
151080	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
151081	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
151082	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6762	
151083	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151084	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
151085	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151086	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151087	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151088	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151089	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151090	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151091	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151092	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151093	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151094	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151095	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151096	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
151097	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3468	
151098	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
151099	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
151100	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
151101	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
151102	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
151103	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
151104	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
151105	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
151106	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	69	°C
151107	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
151108	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
151109	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	832.32	kw
151110	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
151111	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
151112	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
151113	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
151114	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments		
151115	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
151116	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
151117	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
151118	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
151119	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
151120	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
151121	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
151122	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
151123	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
151124	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151125	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
151126	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151127	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
151128	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
151129	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
151130	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
151131	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
151132	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
151133	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
151134	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
151135	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
151136	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
151137	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
151138	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
151139	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		
151140	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
151141	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
151142	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
151143	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
151144	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
151145	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
151146	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
151147	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
151148	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
151149	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
151150	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
151151	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
151152	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
151153	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151154	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151155	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151156	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151157	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151158	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
151159	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
151160	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151161	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
151162	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
151163	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
151164	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
151165	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
151166	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
151167	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	
151168	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	0	
151169	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151170	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151171	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151172	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151173	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151174	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151175	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
151176	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
151177	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Trash Emptied?	y	
151178	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	
151179	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments		
151180	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
151181	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151182	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151183	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151184	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
151185	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	10.0	
151186	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	10.0	
151187	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	10.0	
151188	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151189	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151190	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151191	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	13	
151192	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
151193	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
151194	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
151195	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
151196	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Evidence of Insects	None	
151197	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Doors and Locks Secure?	y	
151198	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
151199	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Control House Lighting OK?	y	
151200	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Broom on Site?	y	
151201	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151202	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
151203	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
151204	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
151205	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
151206	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
151207	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
151208	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
151209	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
151210	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
151211	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
151212	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
151213	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
151214	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
151215	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
151216	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
151217	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
151218	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
151219	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
151220	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
151221	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
151222	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
151223	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
151224	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
151225	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
151226	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
151227	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
151228	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
151229	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
151230	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	
151231	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
151232	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
151233	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
151234	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	13	
151235	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151236	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151237	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151238	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0.0	
151239	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0.0	
151240	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0.0	
151241	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
151242	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151243	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151244	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151245	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151246	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151247	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151248	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151249	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151250	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151251	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
151252	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
151253	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
151254	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
151255	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
151256	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	
151257	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
151258	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
151259	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
151260	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
151261	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
151262	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
151263	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
151264	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
151265	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	General Comments		
151266	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
151267	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
151268	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151269	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
151270	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
151271	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	234	
151272	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	236	
151273	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations This Read Vac	2	
151274	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
151275	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	2	
151276	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
151277	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
151278	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151279	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
151280	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151281	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151282	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151283	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151284	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151285	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151286	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151287	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
151288	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
151289	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
151290	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
151291	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
151292	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
151293	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
151294	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
151295	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
151296	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
151297	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
151298	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	BAT000573	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
151299	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151300	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151301	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151302	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151303	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151304	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
151305	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151306	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
151307	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
151308	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
151309	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
151310	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
151311	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
151312	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
151313	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	General Comments		
151314	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	47894	
151315	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	47894	
151316	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151317	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	6L	
151318	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	1L	
151319	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	7L	
151320	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
151321	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
151322	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
151323	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	General Comments		
151324	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
151325	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
151326	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
151327	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	563	
151328	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151329	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151330	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151331	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
151332	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	LTC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
151333	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
151334	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
151335	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
151336	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
151337	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
151338	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
151339	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
151340	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	LTC000323	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
151341	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	
151342	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
151343	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
151344	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
151345	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	86575	
151346	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	86575	
151347	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151348	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	5L	
151349	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
151350	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	8L	
151351	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151352	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	854	
151353	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151354	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151355	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151356	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
151357	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
151358	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
151359	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
151360	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
151361	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
151362	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
151363	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
151364	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151365	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
151366	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
151367	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151368	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151369	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
151370	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.8	VAC
151371	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.8	VAC
151372	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
151373	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
151374	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
151375	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
151376	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
151377	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151378	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151379	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
151380	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151381	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
151382	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
151383	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
151384	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
151385	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
151386	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
151387	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
151388	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
151389	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
151390	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
151391	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
151392	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
151393	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
151394	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
151395	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
151396	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
151397	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
151398	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
151399	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
151400	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
151401	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
151402	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
151403	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
151404	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
151405	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
151406	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
151407	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151408	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151409	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151410	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151411	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151412	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
151413	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
151414	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151415	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
151416	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
151417	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
151418	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
151419	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
151420	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
151421	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
151422	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
151423	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
151424	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
151425	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
151426	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151427	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
151428	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
151429	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
151430	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151431	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
151432	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151433	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151434	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151435	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151436	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151437	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
151438	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
151439	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
151440	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
151441	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	58240	
151442	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	58240	
151443	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151444	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	6L	
151445	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	1R	
151446	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	7L	
151447	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
151448	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	1095	
151449	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151450	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151451	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151452	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151453	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151454	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151455	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	1439	
151456	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	15L	
151457	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	2R	
151458	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	11L	
151459	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151460	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	55468	
151461	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	55462	
151462	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
151463	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151464	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
151465	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151466	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151467	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151468	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151469	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151470	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151471	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151472	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151473	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151474	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151475	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151476	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
151477	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151478	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
151479	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
151480	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
151481	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
151482	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
151483	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
151484	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
151485	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
151486	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
151487	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
151488	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
151489	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
151490	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
151491	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments		
151492	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
151493	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	n	
151494	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
151495	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	
151496	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
151497	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
151498	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10644	
151499	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
151500	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
151501	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151502	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
151503	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
151504	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
151505	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
151506	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
151507	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
151508	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151509	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
151510	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151511	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151512	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
151513	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
151514	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
151515	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
151516	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	General Comments		
151517	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
151518	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
151519	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151520	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151521	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
151522	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
151523	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
151524	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
151525	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151526	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151527	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151528	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
151529	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
151530	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
151531	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
151532	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151533	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151534	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151535	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151536	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151537	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151538	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151539	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151540	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
151541	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151542	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
151543	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
151544	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
151545	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
151546	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	156959	
151547	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	156959	
151548	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151549	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	5L	
151550	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	2R	
151551	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	9L	
151552	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
151553	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	1347	
151554	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
151555	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151556	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
151557	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
151558	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
151559	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
151560	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
151561	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
151562	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
151563	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
151564	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
151565	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
151566	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
151567	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
151568	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
151569	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
151570	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
151571	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
151572	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
151573	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
151574	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
151575	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
151576	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
151577	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	
151578	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
151579	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	4	
151580	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
151581	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations This Read Vac	4	
151582	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	191	
151583	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	191	
151584	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
151585	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
151586	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151587	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
151588	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
151589	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	1236	
151590	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
151591	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
151592	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
151593	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
151594	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	8L	
151595	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	1R	
151596	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	3L	
151597	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
151598	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	72812	
151599	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	72812	
151600	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments	No Temperature guage, needs to be removed from inspection.	
151601	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
151602	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
151603	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
151604	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
151605	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
151606	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	.6432	
151607	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
151608	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
151609	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
151610	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
151611	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
151612	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
151613	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
151614	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
151615	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	48	°C
151616	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	52	°C
151617	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
151618	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
151619	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	4631.04	kw
151620	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
151621	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		
151622	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments		
151623	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
151624	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
151625	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
151626	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
151627	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
151628	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
151629	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
151630	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
151631	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
151632	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
151633	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
151634	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
151635	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
151636	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
151637	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
151638	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
151639	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
151640	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	52	
151641	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	52	
151642	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
151643	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
151644	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151645	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
151646	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
151647	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
151648	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
151649	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
151650	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
151651	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151652	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
151653	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
151654	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
151655	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151656	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151657	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151658	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151659	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151660	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151661	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151662	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
151663	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
151664	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
151665	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
151666	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
151667	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
151668	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
151669	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	General Comments		
151670	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
151671	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
151672	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Operations Counter	0	
151673	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
151674	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
151675	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151676	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments		
151677	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151678	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151679	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151680	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151681	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151682	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151683	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151684	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151685	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151686	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151687	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
151688	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
151689	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
151690	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151691	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
151692	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151693	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
151694	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
151695	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
151696	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
151697	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
151698	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
151699	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
151700	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
151701	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments		
151702	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
151703	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations	-1	
151704	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151705	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151706	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151707	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushing Condition	Good	
151708	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151709	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151710	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151711	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151712	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151713	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151714	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151715	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151716	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151717	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Foundation Condition	Good	
151718	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	General Comments		
151719	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	General Comments		
151720	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Grounds in Place?	y	
151721	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151722	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Moisture and Leak Free?	y	
151723	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations This Read Vac	0	
151724	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
151725	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Tank Paint Condition	Good	
151726	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations	-1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
151727	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
151728	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
151729	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
151730	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	472.32	kw
151731	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
151732	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
151733	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	53	*C
151734	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	45	*C
151735	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
151736	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
151737	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
151738	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
151739	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151740	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151741	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151742	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	120.0	
151743	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	120.0	
151744	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	120.0	
151745	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	29.5	%
151746	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	35.03	%
151747	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	35.65	%
151748	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	1	
151749	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
151750	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
151751	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
151752	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
151753	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
151754	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	BCH000586	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
151755	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
151756	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
151757	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
151758	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
151759	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
151760	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	412254	
151761	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
151762	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
151763	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
151764	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
151765	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
151766	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
151767	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
151768	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
151769	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
151770	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
151771	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
151772	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
151773	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
151774	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
151775	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
151776	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
151777	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
151778	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
151779	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
151780	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
151781	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
151782	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	0	
151783	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	354	
151784	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	354	
151785	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
151786	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
151787	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
151788	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
151789	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
151790	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
151791	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
151792	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151793	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151794	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151795	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	80.0	
151796	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	80.0	
151797	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	80.0	
151798	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	29.5	%
151799	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	35.03	%
151800	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	35.65	%
151801	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	6	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
151802	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
151803	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
151804	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
151805	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
151806	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
151807	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
151808	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
151809	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
151810	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
151811	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
151812	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
151813	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	313	
151814	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	313	
151815	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
151816	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
151817	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
151818	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
151819	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
151820	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
151821	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
151822	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151823	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
151824	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
151825	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
151826	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
151827	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
151828	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
151829	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
151830	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
151831	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
151832	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
151833	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151834	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151835	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151836	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151837	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151838	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151839	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151840	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151841	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151842	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
151843	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	10.0	
151844	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	10.0	
151845	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	10.0	
151846	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151847	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151848	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151849	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	15	
151850	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151851	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151852	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151853	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushing Condition	Good	
151854	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151855	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151856	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151857	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151858	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151859	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151860	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151861	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151862	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151863	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Foundation Condition	Good	
151864	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	General Comments		
151865	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	General Comments		
151866	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Grounds in Place?	y	
151867	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Heaters (All) Functioning?	y	
151868	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Moisture and Leak Free?	y	
151869	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations This Read Vac	0	
151870	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
151871	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Tank Paint Condition	Good	
151872	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	9 Month Operations	-1	
151873	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
151874	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
151875	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
151876	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151877	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
151878	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
151879	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
151880	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
151881	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
151882	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
151883	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
151884	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
151885	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
151886	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
151887	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Foundation Condition	Good	
151888	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
151889	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
151890	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
151891	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
151892	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
151893	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3936	
151894	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
151895	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
151896	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
151897	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
151898	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
151899	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
151900	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
151901	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
151902	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
151903	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
151904	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
151905	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
151906	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
151907	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
151908	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
151909	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
151910	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
151911	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
151912	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	General Comments		
151913	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
151914	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	LTC0000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
151915	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
151916	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
151917	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
151918	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
151919	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
151920	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
151921	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117919	
151922	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
151923	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
151924	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
151925	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
151926	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
151927	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
151928	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	*C
151929	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	*C
151930	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30	
151931	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
151932	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	130	*C
151933	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	*C
151934	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
151935	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments		
151936	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
151937	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
151938	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
151939	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
151940	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
151941	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
151942	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
151943	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
151944	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
151945	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
151946	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
151947	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
151948	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
151949	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
151950	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
151951	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
151952	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
151953	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
151954	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		
151955	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
151956	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
151957	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
151958	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
151959	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
151960	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
151961	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	4	
151962	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	4	
151963	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
151964	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
151965	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151966	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151967	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151968	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151969	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151970	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
151971	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
151972	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
151973	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151974	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
151975	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
151976	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
151977	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
151978	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151979	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
151980	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
151981	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151982	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151983	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151984	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
151985	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
151986	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
151987	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
151988	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
151989	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
151990	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
151991	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
151992	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
151993	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
151994	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
151995	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
151996	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
151997	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
151998	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
151999	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
152000	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
152001	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
152002	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
152003	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
152004	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
152005	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
152006	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments		
152007	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
152008	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
152009	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
152010	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
152011	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
152012	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
152013	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
152014	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
152015	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
152016	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
152017	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
152018	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
152019	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
152020	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
152021	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
152022	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
152023	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
152024	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
152025	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
152026	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152027	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
152028	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152029	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
152030	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
152031	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
152032	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
152033	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
152034	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
152035	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	PF001218	PowerFuse	529-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
152036	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
152037	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
152038	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
152039	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
152040	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
152041	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
152042	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments		
152043	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
152044	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
152045	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
152046	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
152047	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
152048	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
152049	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
152050	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
152051	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
152052	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
152053	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
152054	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
152055	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
152056	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	General Comments		
152057	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
152058	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
152059	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Operations Counter	0	
152060	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
152061	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
152062	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	11.5	
152063	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.4	
152064	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	11.0	
152065	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
152066	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
152067	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
152068	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
152069	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
152070	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
152071	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
152072	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
152073	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
152074	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
152075	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
152076	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
152077	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	0	
152078	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
152079	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
152080	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
152081	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
152082	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
152083	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
152084	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
152085	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
152086	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
152087	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
152088	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
152089	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
152090	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
152091	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
152092	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
152093	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
152094	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
152095	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
152096	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
152097	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
152098	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
152099	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
152100	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
152101	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
152102	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
152103	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
152104	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
152105	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
152106	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
152107	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
152108	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
152109	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
152110	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
152111	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
152112	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
152113	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
152114	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments		
152115	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
152116	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
152117	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
152118	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
152119	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
152120	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
152121	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
152122	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
152123	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
152124	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
152125	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
152126	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
152127	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152128	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
152129	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
152130	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
152131	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
152132	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
152133	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
152134	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
152135	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
152136	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
152137	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
152138	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152139	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
152140	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
152141	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	901	
152142	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	901	
152143	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
152144	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
152145	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
152146	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
152147	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
152148	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
152149	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
152150	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	298312	
152151	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	
152152	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	volts
152153	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
152154	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
152155	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
152156	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
152157	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
152158	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
152159	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
152160	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
152161	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
152162	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
152163	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
152164	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
152165	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
152166	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
152167	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
152168	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
152169	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
152170	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
152171	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
152172	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
152173	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
152174	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
152175	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
152176	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152177	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
152178	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
152179	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	0	
152180	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	354	
152181	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	354	
152182	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
152183	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
152184	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
152185	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
152186	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
152187	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
152188	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	3	
152189	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	3	
152190	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	260	
152191	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	259	
152192	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
152193	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
152194	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152195	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
152196	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
152197	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
152198	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
152199	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
152200	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
152201	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
152202	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
152203	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
152204	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
152205	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152206	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152207	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152208	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152209	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152210	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152211	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152212	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152213	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152214	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
152215	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
152216	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
152217	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
152218	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152219	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152220	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152221	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	5	
152222	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
152223	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152224	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152225	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152226	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
152227	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
152228	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
152229	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
152230	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152231	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152232	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152233	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152234	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152235	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152236	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
152237	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
152238	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
152239	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
152240	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
152241	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
152242	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
152243	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
152244	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
152245	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
152246	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
152247	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
152248	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
152249	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
152250	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
152251	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
152252	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
152253	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	786	
152254	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	786	
152255	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
152256	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
152257	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	
152258	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
152259	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
152260	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
152261	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152262	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152263	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0199	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152264	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
152265	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
152266	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
152267	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
152268	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
152269	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
152270	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
152271	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
152272	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
152273	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
152274	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
152275	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
152276	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
152277	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
152278	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
152279	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.85	%
152280	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.85	%
152281	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.85	%
152282	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
152283	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
152284	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments	The bottom flood light by WH 6686 is not working. Replaced bulb and still not working	
152285	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
152286	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
152287	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
152288	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
152289	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
152290	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
152291	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
152292	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
152293	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
152294	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
152295	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
152296	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
152297	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
152298	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
152299	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
152300	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
152301	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
152302	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
152303	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
152304	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
152305	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
152306	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
152307	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
152308	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
152309	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
152310	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
152311	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
152312	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
152313	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
152314	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
152315	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
152316	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
152317	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
152318	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
152319	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
152320	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
152321	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
152322	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
152323	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
152324	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
152325	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
152326	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	Light	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152327	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
152328	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
152329	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
152330	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152331	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushing Condition	Good	
152332	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	260.0	
152333	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	280.0	
152334	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	280.0	
152335	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152336	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152337	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
152338	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Tank Paint Condition	Good	
152339	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Switching Operations	4	
152340	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152341	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations This Read Vac	4	
152342	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AL	5	
152343	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AF	5	
152344	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Moisture and Leak Free?	y	
152345	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Maintenance Operations	0	
152346	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152347	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Grounds in Place?	y	
152348	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	General Comments		
152349	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	General Comments		
152350	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Foundation Condition	Good	
152351	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Follow-up Action Required?	n	
152352	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Follow-up Action Required?	n	
152353	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations Ground	0	
152354	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations C Ø	0	
152355	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations B Ø	0	
152356	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations A Ø	0	
152357	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152358	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152359	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152360	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152361	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152362	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152363	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152364	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152365	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152366	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	
152367	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	250.0	
152368	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	250.0	
152369	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	240.0	
152370	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152371	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152372	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152373	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	9	
152374	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152375	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	3	
152376	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
152377	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	205	
152378	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	205	
152379	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations This Read Vac	0	
152380	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152381	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	0	
152382	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
152383	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
152384	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
152385	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
152386	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
152387	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	545	
152388	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	545	
152389	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
152390	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
152391	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
152392	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
152393	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
152394	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
152395	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
152396	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152397	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152398	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152399	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	280.0	
152400	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	280.0	
152401	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	300.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152402	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
152403	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152404	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152405	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152406	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152407	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
152408	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
152409	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
152410	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
152411	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
152412	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
152413	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
152414	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
152415	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
152416	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
152417	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
152418	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
152419	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
152420	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
152421	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
152422	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
152423	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
152424	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
152425	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
152426	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
152427	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
152428	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
152429	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
152430	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
152431	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	475370	
152432	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
152433	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
152434	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
152435	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152436	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152437	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Fault Adjusted Amps A Phase V	0.00	
152438	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Fault Adjusted Amps B Phase V	0.00	
152439	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Fault Adjusted Amps C Phase V	0.00	
152440	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
152441	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
152442	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
152443	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	45	*C
152444	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	70	*C
152445	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
152446	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
152447	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	11395.20	kw
152448	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
152449	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
152450	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
152451	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
152452	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
152453	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
152454	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
152455	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
152456	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
152457	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
152458	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
152459	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
152460	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
152461	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
152462	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	4	
152463	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152464	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
152465	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
152466	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
152467	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	1118	
152468	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	7L	
152469	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
152470	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	6L	
152471	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
152472	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	32919	
152473	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	32919	
152474	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
152475	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments		
152476	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152477	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
152478	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	4	
152479	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	300	
152480	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	300	
152481	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
152482	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
152483	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152484	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
152485	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments	Counter Verified 300.	
152486	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		
152487	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
152488	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
152489	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
152490	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
152491	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
152492	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
152493	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
152494	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
152495	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
152496	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
152497	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
152498	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	General Comments		
152499	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
152500	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1870	
152501	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
152502	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
152503	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
152504	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	LTC0000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
152505	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
152506	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
152507	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
152508	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152509	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152510	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152511	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152512	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152513	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152514	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152515	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152516	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152517	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
152518	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	310.0	
152519	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	310.0	
152520	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	310.0	
152521	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152522	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152523	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152524	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	9	
152525	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
152526	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
152527	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
152528	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152529	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152530	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152531	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152532	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152533	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152534	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152535	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152536	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152537	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
152538	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
152539	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
152540	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
152541	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152542	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152543	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152544	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
152545	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152546	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152547	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	125.0	
152548	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTC0000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
152549	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTC0000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
152550	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTC0000738	LTCControl	529-1	LTC Control Insp	General Comments		
152551	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTC0000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152552	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
152553	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
152554	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
152555	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
152556	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
152557	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	125.0	
152558	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	125.0	
152559	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	32.58	%
152560	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
152561	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
152562	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
152563	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	39.95	%
152564	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	43.64	%
152565	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	15	
152566	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	9	
152567	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152568	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152569	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152570	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	130.0	
152571	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	130.0	
152572	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	100.0	
152573	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
152574	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152575	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152576	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152577	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
152578	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
152579	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
152580	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	308	
152581	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	308	
152582	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
152583	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
152584	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
152585	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
152586	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
152587	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
152588	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
152589	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152590	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152591	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152592	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	100.0	
152593	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	100.0	
152594	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152595	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152596	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152597	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
152598	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
152599	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
152600	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments		
152601	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments		
152602	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	51675	
152603	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	51687	
152604	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
152605	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
152606	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
152607	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
152608	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
152609	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
152610	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
152611	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	82	
152612	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	82	
152613	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
152614	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
152615	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152616	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
152617	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
152618	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
152619	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
152620	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
152621	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
152622	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
152623	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
152624	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
152625	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
152626	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152627	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
152628	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
152629	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
152630	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
152631	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
152632	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
152633	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
152634	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
152635	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	9L	
152636	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	8L	
152637	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	16L	
152638	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	427	
152639	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
152640	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
152641	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
152642	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
152643	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	BCH001167	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
152644	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
152645	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
152646	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
152647	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	315	
152648	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	315	
152649	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
152650	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
152651	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
152652	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
152653	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
152654	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
152655	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
152656	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152657	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
152658	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
152659	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
152660	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152661	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152662	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152663	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152664	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152665	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152666	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152667	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152668	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152669	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
152670	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
152671	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
152672	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
152673	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
152674	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
152675	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
152676	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
152677	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
152678	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
152679	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
152680	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
152681	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
152682	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	903	
152683	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	8L	
152684	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	2L	
152685	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	5L	
152686	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
152687	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	23816	
152688	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	23816	
152689	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
152690	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
152691	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
152692	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
152693	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
152694	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	
152695	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
152696	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
152697	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
152698	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
152699	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
152700	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
152701	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	3	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152702	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152703	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations This Read Vac	3	
152704	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	153	
152705	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	153	
152706	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
152707	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
152708	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
152709	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments	Coal dust in cabinet.	
152710	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
152711	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
152712	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
152713	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
152714	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
152715	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
152716	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations B Ø	0	
152717	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations A Ø	0	
152718	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152719	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152720	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152721	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152722	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152723	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Internal Condition?	Dirt	
152724	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152725	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152726	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	100.0	
152727	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	28.27	%
152728	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	35.65	%
152729	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	35.03	%
152730	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	7	
152731	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152732	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152733	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152734	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152735	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152736	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152737	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
152738	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
152739	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
152740	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
152741	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
152742	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
152743	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
152744	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
152745	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
152746	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
152747	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Heaters (All) Functioning?	y	
152748	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
152749	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
152750	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	229	
152751	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	229	
152752	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	4	
152753	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152754	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	4	
152755	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
152756	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
152757	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
152758	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
152759	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
152760	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
152761	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
152762	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
152763	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
152764	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152765	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152766	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
152767	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
152768	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
152769	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
152770	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
152771	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
152772	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
152773	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
152774	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	General Comments		
152775	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
152776	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152777	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
152778	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
152779	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	14	
152780	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1169	
152781	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1169	
152782	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
152783	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
152784	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	12	
152785	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152786	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152787	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152788	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	45.0	
152789	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	57.0	
152790	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	53.0	
152791	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
152792	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152793	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
152794	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
152795	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
152796	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
152797	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
152798	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152799	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152800	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152801	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	150.0	
152802	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	150.0	
152803	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	150.0	
152804	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	31.96	%
152805	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	34.42	%
152806	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	33.8	%
152807	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	4	
152808	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
152809	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
152810	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
152811	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152812	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152813	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
152814	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
152815	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
152816	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
152817	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	166	
152818	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	166	
152819	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
152820	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
152821	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
152822	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
152823	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
152824	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
152825	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
152826	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152827	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
152828	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
152829	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
152830	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
152831	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
152832	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
152833	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
152834	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
152835	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	179	
152836	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	179	
152837	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	0	
152838	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	0	
152839	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
152840	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
152841	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	2	
152842	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152843	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152844	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152845	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	100.0	
152846	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	90.0	
152847	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	100.0	
152848	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
152849	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152850	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152851	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
152852	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152853	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152854	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152855	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152856	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152857	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152858	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	180.0	
152859	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	180.0	
152860	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	31.96	%
152861	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	34.42	%
152862	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	33.8	%
152863	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
152864	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
152865	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
152866	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
152867	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
152868	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
152869	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
152870	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
152871	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
152872	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	1	
152873	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
152874	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
152875	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
152876	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
152877	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
152878	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	n	
152879	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
152880	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
152881	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments		
152882	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
152883	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
152884	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	n	
152885	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
152886	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
152887	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
152888	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
152889	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
152890	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
152891	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
152892	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	n	
152893	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
152894	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
152895	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
152896	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
152897	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	General Comments		
152898	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
152899	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
152900	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
152901	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
152902	10/4/2019 11:15	Distribution	Harrodsburg North Quarterly Inspection	LTC0000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
152903	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
152904	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
152905	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	0	
152906	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	245	
152907	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	245	
152908	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
152909	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments		
152910	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	2	
152911	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
152912	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
152913	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
152914	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	250.0	
152915	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	220.0	
152916	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	210.0	
152917	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
152918	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152919	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152920	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152921	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152922	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152923	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152924	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	60.0	
152925	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	55.0	
152926	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
152927	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
152928	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
152929	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
152930	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	60.0	
152931	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
152932	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
152933	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
152934	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
152935	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
152936	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
152937	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
152938	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
152939	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
152940	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
152941	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
152942	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
152943	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
152944	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
152945	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
152946	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	
152947	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
152948	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
152949	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
152950	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
152951	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
152952	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
152953	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
152954	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
152955	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
152956	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
152957	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
152958	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
152959	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
152960	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
152961	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
152962	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
152963	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
152964	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	4	
152965	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
152966	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations This Read Vac	4	
152967	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	691	
152968	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	691	
152969	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	
152970	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
152971	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
152972	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	General Comments		
152973	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
152974	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
152975	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
152976	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
152977	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
152978	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
152979	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
152980	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
152981	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
152982	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
152983	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
152984	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
152985	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
152986	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
152987	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
152988	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
152989	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
152990	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
152991	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
152992	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
152993	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
152994	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
152995	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
152996	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
152997	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
152998	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
152999	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
153000	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153001	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153002	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
153003	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	189	
153004	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	189	
153005	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	0	
153006	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153007	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	0	
153008	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
153009	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
153010	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153011	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153012	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	160.0	
153013	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	160.0	
153014	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	160.0	
153015	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	7.38	%
153016	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	7.99	%
153017	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	7.99	%
153018	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	0	
153019	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
153020	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
153021	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
153022	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	166	
153023	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	166	
153024	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
153025	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
153026	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
153027	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
153028	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
153029	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
153030	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
153031	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153032	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153033	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153034	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	160.0	
153035	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	160.0	
153036	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	160.0	
153037	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	7.38	%
153038	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	7.99	%
153039	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	7.99	%
153040	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	0	
153041	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
153042	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
153043	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
153044	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
153045	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
153046	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
153047	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
153048	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
153049	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	351428	
153050	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
153051	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
153052	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	11	
153053	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153054	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153055	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153056	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
153057	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
153058	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
153059	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
153060	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
153061	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
153062	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
153063	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
153064	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
153065	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
153066	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
153067	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
153068	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments		
153069	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
153070	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	
153071	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
153072	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
153073	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
153074	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
153075	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
153076	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
153077	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
153078	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
153079	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
153080	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
153081	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
153082	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
153083	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
153084	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
153085	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
153086	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
153087	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
153088	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
153089	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	10.0	
153090	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	10.0	
153091	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	10.0	
153092	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153093	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153094	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153095	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	7	
153096	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
153097	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
153098	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
153099	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
153100	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
153101	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments		
153102	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
153103	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
153104	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
153105	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
153106	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
153107	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
153108	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
153109	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
153110	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
153111	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
153112	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
153113	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
153114	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
153115	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
153116	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
153117	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
153118	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
153119	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
153120	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
153121	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
153122	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
153123	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
153124	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
153125	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
153126	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153127	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
153128	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
153129	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153130	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
153131	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153132	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153133	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153134	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153135	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
153136	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
153137	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
153138	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153139	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153140	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153141	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153142	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
153143	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153144	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
153145	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153146	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
153147	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
153148	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
153149	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
153150	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
153151	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
153152	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
153153	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
153154	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
153155	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
153156	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
153157	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	4	
153158	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	4	
153159	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	368	
153160	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	368	
153161	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
153162	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
153163	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153164	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
153165	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
153166	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
153167	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
153168	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
153169	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
153170	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
153171	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
153172	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
153173	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
153174	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153175	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153176	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153177	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153178	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153179	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153180	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153181	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153182	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153183	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
153184	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
153185	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
153186	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
153187	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	848902	
153188	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
153189	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
153190	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
153191	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
153192	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
153193	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
153194	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
153195	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
153196	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
153197	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
153198	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	359	
153199	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	359	
153200	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
153201	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
153202	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
153203	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
153204	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
153205	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	General Comments		
153206	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
153207	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
153208	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
153209	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
153210	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
153211	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
153212	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
153213	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
153214	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153215	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153216	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
153217	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
153218	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
153219	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
153220	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	64.0	
153221	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	75.0	
153222	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
153223	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	12	
153224	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.5	
153225	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.1	
153226	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.8	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153227	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	17	
153228	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
153229	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
153230	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
153231	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	0	
153232	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	245	
153233	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
153234	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	11	
153235	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
153236	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
153237	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
153238	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		
153239	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	245	
153240	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
153241	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments		
153242	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
153243	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
153244	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
153245	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
153246	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
153247	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
153248	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
153249	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
153250	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153251	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153252	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153253	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	180.0	
153254	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
153255	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
153256	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
153257	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
153258	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
153259	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
153260	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
153261	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
153262	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
153263	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
153264	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
153265	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
153266	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
153267	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
153268	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
153269	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
153270	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
153271	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
153272	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
153273	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Operations This Read Vac	0	
153274	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153275	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
153276	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
153277	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
153278	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
153279	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
153280	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
153281	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
153282	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
153283	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
153284	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
153285	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
153286	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
153287	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
153288	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
153289	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
153290	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
153291	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
153292	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
153293	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
153294	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
153295	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	17.0	VDC
153296	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
153297	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
153298	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
153299	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
153300	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
153301	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153302	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
153303	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
153304	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
153305	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
153306	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
153307	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
153308	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
153309	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153310	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
153311	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
153312	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153313	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153314	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
153315	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153316	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
153317	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
153318	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
153319	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Transformer needs Nitro, The transformer is seeping from some of the radiators. Pics sent to Stinson	
153320	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
153321	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	0	
153322	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153323	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153324	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
153325	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	140	
153326	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153327	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153328	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
153329	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
153330	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
153331	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
153332	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153333	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153334	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153335	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
153336	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	140	
153337	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations This Read Vac	0	
153338	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	0	
153339	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	
153340	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
153341	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
153342	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
153343	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
153344	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
153345	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
153346	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
153347	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
153348	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
153349	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153350	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
153351	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	4	
153352	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153353	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations This Read Vac	4	
153354	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	471	
153355	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	471	
153356	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
153357	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
153358	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
153359	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
153360	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153361	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
153362	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
153363	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
153364	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
153365	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
153366	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
153367	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153368	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153369	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
153370	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
153371	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153372	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
153373	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
153374	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
153375	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
153376	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153377	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153378	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153379	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153380	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153381	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153382	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
153383	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153384	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153385	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153386	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153387	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
153388	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
153389	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
153390	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
153391	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99752	
153392	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
153393	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
153394	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
153395	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
153396	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
153397	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
153398	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
153399	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
153400	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
153401	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
153402	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
153403	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
153404	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
153405	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
153406	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
153407	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
153408	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
153409	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
153410	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
153411	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
153412	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
153413	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	11268.00	kw
153414	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
153415	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
153416	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	65	°C
153417	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	45	°C
153418	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
153419	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
153420	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
153421	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153422	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
153423	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
153424	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
153425	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
153426	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
153427	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
153428	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	689	
153429	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
153430	10/4/2019 12:51	Distribution	Newtown Switching Quarterly Inspection	DX0094	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
153431	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153432	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153433	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153434	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
153435	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153436	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
153437	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	43	
153438	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	43	
153439	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
153440	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
153441	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
153442	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
153443	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
153444	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
153445	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
153446	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
153447	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
153448	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
153449	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153450	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
153451	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153452	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
153453	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
153454	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
153455	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
153456	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
153457	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
153458	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153459	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153460	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153461	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153462	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B80266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153463	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
153464	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
153465	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
153466	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
153467	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
153468	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
153469	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.7644	
153470	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
153471	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153472	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
153473	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
153474	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153475	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
153476	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
153477	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
153478	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
153479	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
153480	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	54.0	
153481	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
153482	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153483	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
153484	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153485	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	35	°C
153486	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	55	°C
153487	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
153488	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
153489	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	7338.24	kw
153490	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
153491	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
153492	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
153493	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
153494	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
153495	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
153496	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
153497	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
153498	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
153499	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
153500	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
153501	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
153502	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
153503	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
153504	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
153505	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
153506	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	0	
153507	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations This Read Vac	0	
153508	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	215	
153509	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	215	
153510	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
153511	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
153512	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
153513	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
153514	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	45	°C
153515	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
153516	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
153517	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
153518	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
153519	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	617	
153520	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	617	
153521	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
153522	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
153523	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153524	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
153525	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
153526	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153527	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
153528	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
153529	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
153530	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
153531	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
153532	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
153533	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
153534	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153535	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153536	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153537	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153538	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99752	
153539	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
153540	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
153541	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153542	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
153543	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
153544	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
153545	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
153546	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
153547	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
153548	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
153549	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
153550	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
153551	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
153552	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
153553	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
153554	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	55.0	
153555	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	60.0	
153556	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	60.0	
153557	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153558	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153559	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153560	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
153561	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
153562	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
153563	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153564	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153565	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153566	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153567	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153568	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153569	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153570	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153571	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153572	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
153573	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
153574	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
153575	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	290.0	
153576	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153577	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153578	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153579	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	BB0270	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
153580	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	9	
153581	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
153582	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
153583	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	431	
153584	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
153585	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
153586	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
153587	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
153588	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.6260	
153589	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	60	°C
153590	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
153591	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
153592	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.4	
153593	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.3	
153594	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.5	
153595	10/4/2019 12:17	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	539	
153596	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
153597	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
153598	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
153599	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
153600	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	118008	
153601	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153602	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
153603	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
153604	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
153605	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	2	
153606	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
153607	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
153608	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
153609	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
153610	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
153611	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
153612	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	188.0	
153613	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	179.0	
153614	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	177.0	
153615	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153616	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
153617	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
153618	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
153619	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	0	
153620	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
153621	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
153622	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
153623	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
153624	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
153625	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
153626	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
153627	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
153628	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
153629	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
153630	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
153631	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
153632	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
153633	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
153634	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
153635	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
153636	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	0	
153637	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	1	
153638	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	210	
153639	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	210	
153640	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
153641	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	1	
153642	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
153643	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
153644	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
153645	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
153646	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
153647	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
153648	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
153649	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
153650	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
153651	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
153652	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
153653	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153654	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153655	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153656	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153657	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
153658	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
153659	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
153660	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
153661	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	1	
153662	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
153663	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	172	
153664	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	172	
153665	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations This Read Vac	1	
153666	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	0	
153667	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
153668	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
153669	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153670	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153671	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153672	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153673	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153674	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
153675	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	30.0	
153676	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	31.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
153677	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	36.0	
153678	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153679	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153680	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153681	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	2	
153682	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
153683	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
153684	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
153685	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153686	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
153687	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153688	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153689	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
153690	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
153691	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153692	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
153693	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.4830	
153694	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	55	°C
153695	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	55	°C
153696	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
153697	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
153698	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
153699	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
153700	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
153701	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
153702	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
153703	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
153704	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153705	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
153706	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
153707	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153708	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
153709	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153710	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153711	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153712	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153713	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
153714	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153715	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
153716	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
153717	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
153718	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
153719	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
153720	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
153721	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
153722	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
153723	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
153724	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
153725	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
153726	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
153727	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
153728	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
153729	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
153730	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
153731	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
153732	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
153733	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	6577.92	kw
153734	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
153735	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
153736	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	63	°C
153737	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	39	°C
153738	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153739	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
153740	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153741	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153742	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
153743	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
153744	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153745	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
153746	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.3704	
153747	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
153748	10/4/2019 12:51	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
153749	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153750	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153751	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153752	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153753	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153754	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153755	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153756	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153757	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
153758	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
153759	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
153760	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
153761	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
153762	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	101585	
153763	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
153764	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
153765	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
153766	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
153767	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
153768	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153769	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153770	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153771	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153772	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
153773	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153774	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
153775	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
153776	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153777	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
153778	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	854	
153779	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	854	
153780	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
153781	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
153782	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
153783	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
153784	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
153785	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
153786	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
153787	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
153788	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
153789	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
153790	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
153791	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
153792	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
153793	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153794	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
153795	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
153796	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
153797	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
153798	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
153799	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
153800	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
153801	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
153802	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
153803	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87141	
153804	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153805	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153806	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153807	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153808	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153809	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153810	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153811	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153812	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153813	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
153814	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
153815	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	55.0	
153816	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
153817	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153818	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
153819	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
153820	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
153821	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
153822	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
153823	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
153824	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
153825	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
153826	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153827	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153828	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153829	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	CB0201	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
153830	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
153831	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments		
153832	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
153833	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
153834	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
153835	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
153836	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
153837	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
153838	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
153839	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
153840	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
153841	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
153842	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
153843	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
153844	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
153845	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
153846	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
153847	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	0	
153848	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153849	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153850	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153851	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	645.0	
153852	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	635.0	
153853	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	640.0	
153854	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
153855	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153856	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153857	10/4/2019 12:05	Distribution	Campbellsville Industrial Quarterly Inspecti	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	3	
153858	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
153859	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153860	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153861	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153862	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153863	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
153864	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153865	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
153866	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
153867	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
153868	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
153869	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
153870	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
153871	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
153872	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
153873	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
153874	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
153875	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
153876	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
153877	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153878	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153879	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153880	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
153881	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
153882	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
153883	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
153884	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
153885	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
153886	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
153887	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
153888	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
153889	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
153890	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
153891	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
153892	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
153893	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
153894	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
153895	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
153896	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
153897	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
153898	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
153899	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
153900	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
153901	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153902	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
153903	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
153904	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	4	
153905	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
153906	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	2	
153907	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
153908	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
153909	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
153910	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	150.0	
153911	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	150.0	
153912	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	160.0	
153913	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	11.06	%
153914	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	13.52	%
153915	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
153916	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	30	°C
153917	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
153918	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	1	
153919	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	408	
153920	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.3	
153921	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.6	
153922	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.4	
153923	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	341	
153924	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
153925	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
153926	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	380	
153927	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
153928	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
153929	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
153930	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
153931	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
153932	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
153933	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	50	°C
153934	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
153935	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
153936	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
153937	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
153938	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
153939	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
153940	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
153941	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	8553.60	kw
153942	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
153943	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
153944	10/4/2019 14:01	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
153945	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
153946	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	
153947	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	0	
153948	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	157	
153949	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
153950	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
153951	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
153952	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
153953	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
153954	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
153955	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
153956	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
153957	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
153958	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	FE000440	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
153959	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
153960	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
153961	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
153962	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
153963	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
153964	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
153965	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
153966	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
153967	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
153968	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
153969	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
153970	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
153971	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
153972	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
153973	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.5940	
153974	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
153975	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
153976	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
153977	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
153978	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
153979	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
153980	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
153981	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
153982	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
153983	10/4/2019 15:30	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
153984	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
153985	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
153986	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
153987	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
153988	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
153989	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
153990	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
153991	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
153992	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
153993	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	11	
153994	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
153995	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
153996	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
153997	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A Ø	180.0	
153998	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B Ø	180.0	
153999	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C Ø	180.0	
154000	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
154001	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
154002	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
154003	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
154004	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
154005	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
154006	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
154007	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
154008	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
154009	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
154010	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
154011	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
154012	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
154013	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
154014	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
154015	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	15.81	
154016	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	15.81	
154017	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	11.86	
154018	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A Ø	2	
154019	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B Ø	2	
154020	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C Ø	1	
154021	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
154022	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
154023	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
154024	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
154025	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
154026	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments		
154027	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	
154028	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	0	
154029	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
154030	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	46	
154031	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	46	
154032	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
154033	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	157	
154034	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	157	
154035	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
154036	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
154037	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
154038	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
154039	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
154040	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
154041	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
154042	10/4/2019 13:14	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations This Read Vac	11	
154043	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
154044	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
154045	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
154046	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
154047	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
154048	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
154049	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154050	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154051	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154052	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
154053	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
154054	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
154055	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
154056	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
154057	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154058	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
154059	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
154060	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154061	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
154062	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
154063	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154064	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
154065	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
154066	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
154067	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	2466.00	kw
154068	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
154069	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	50	°C
154070	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	35	°C
154071	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154072	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
154073	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154074	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
154075	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
154076	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
154077	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154078	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
154079	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.1370	
154080	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	45	°C
154081	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	35	°C
154082	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
154083	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
154084	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
154085	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
154086	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
154087	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
154088	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
154089	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
154090	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
154091	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
154092	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
154093	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
154094	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
154095	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
154096	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
154097	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
154098	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
154099	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
154100	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
154101	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
154102	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
154103	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
154104	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments		
154105	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
154106	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
154107	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
154108	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
154109	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
154110	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	45.0	
154111	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	55.0	
154112	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
154113	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154114	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154115	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154116	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154117	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154118	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
154119	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154120	10/4/2019 13:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154121	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	157	
154122	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
154123	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
154124	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
154125	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
154126	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154127	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
154128	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
154129	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
154130	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
154131	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
154132	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154133	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
154134	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
154135	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
154136	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	126115	
154137	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
154138	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
154139	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
154140	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	90.0	
154141	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	90.0	
154142	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	90.0	
154143	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	11.06	%
154144	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	13.52	%
154145	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
154146	4/18/2019 8:54	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	1	
154147	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
154148	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
154149	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
154150	10/4/2019 13:22	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
154151	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154152	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
154153	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
154154	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
154155	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
154156	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	682	
154157	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	682	
154158	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
154159	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
154160	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
154161	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
154162	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
154163	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
154164	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
154165	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
154166	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
154167	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
154168	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
154169	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0195	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
154170	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
154171	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
154172	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154173	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
154174	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
154175	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
154176	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
154177	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154178	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154179	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154180	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
154181	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
154182	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	
154183	10/4/2019 15:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10332	
154184	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	
154185	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
154186	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	6	
154187	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
154188	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
154189	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
154190	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	160.0	
154191	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
154192	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	140.0	
154193	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
154194	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
154195	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	160.0	
154196	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
154197	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
154198	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
154199	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
154200	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
154201	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154202	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
154203	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
154204	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154205	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154206	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154207	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
154208	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
154209	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
154210	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
154211	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
154212	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Follow-up Action Required?	n	
154213	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Foundation Condition	Good	
154214	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	General Comments		
154215	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
154216	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
154217	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
154218	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
154219	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
154220	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
154221	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
154222	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
154223	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	27900.00	kw
154224	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
154225	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
154226	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154227	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
154228	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
154229	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154230	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
154231	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
154232	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154233	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
154234	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	50	°C
154235	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	30	°C
154236	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
154237	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
154238	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
154239	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
154240	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	40	°C
154241	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	90	°C
154242	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	1.5500	
154243	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
154244	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
154245	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Top Oil Temperature Max	75	°C
154246	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154247	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
154248	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
154249	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
154250	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154251	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
154252	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154253	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
154254	7/2/2019 8:58	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	0	
154255	10/4/2019 15:16	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
154256	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
154257	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
154258	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
154259	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Follow-up Action Required?	n	
154260	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations Ground	0	
154261	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations C Ø	0	
154262	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
154263	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
154264	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
154265	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
154266	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
154267	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
154268	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
154269	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
154270	10/4/2019 11:48	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
154271	10/4/2019 11:06	Distribution	Campbellsville 1 Quarterly Inspection	CB0198	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
154272	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
154273	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
154274	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
154275	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
154276	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154277	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154278	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
154279	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
154280	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
154281	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
154282	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
154283	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
154284	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154285	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
154286	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0720	
154287	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
154288	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	87	*F
154289	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
154290	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	
154291	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
154292	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
154293	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
154294	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	.0280	
154295	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
154296	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
154297	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
154298	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
154299	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
154300	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
154301	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154302	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154303	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154304	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154305	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154306	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154307	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
154308	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154309	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154310	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154311	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
154312	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154313	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154314	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154315	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154316	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
154317	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
154318	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments		
154319	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154320	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154321	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154322	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154323	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154324	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154325	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
154326	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
154327	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	173	
154328	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
154329	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
154330	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	281	
154331	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	32.6	
154332	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	40.2	
154333	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
154334	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	229	
154335	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154336	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154337	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
154338	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
154339	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154340	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
154341	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154342	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154343	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
154344	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
154345	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
154346	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
154347	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	36	*C
154348	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154349	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
154350	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154351	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154352	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154353	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154354	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
154355	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
154356	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
154357	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
154358	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
154359	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
154360	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
154361	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
154362	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
154363	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
154364	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
154365	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
154366	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
154367	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
154368	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
154369	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
154370	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.1	VDC
154371	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
154372	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
154373	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
154374	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	If no, which cells in comments
154375	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
154376	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
154377	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
154378	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	n	
154379	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
154380	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
154381	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
154382	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
154383	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
154384	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154385	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154386	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154387	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154388	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154389	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
154390	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154391	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154392	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
154393	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
154394	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
154395	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
154396	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
154397	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
154398	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
154399	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
154400	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
154401	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
154402	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	342949	
154403	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
154404	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
154405	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
154406	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
154407	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
154408	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
154409	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154410	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154411	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154412	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154413	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154414	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154415	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154416	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
154417	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
154418	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
154419	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	42.0	
154420	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	47.0	
154421	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		
154422	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
154423	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
154424	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
154425	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154426	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154427	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
154428	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154429	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154430	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154431	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154432	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
154433	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
154434	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
154435	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
154436	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
154437	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
154438	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
154439	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
154440	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
154441	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
154442	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
154443	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
154444	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
154445	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments		
154446	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
154447	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
154448	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
154449	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
154450	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
154451	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
154452	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
154453	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
154454	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
154455	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
154456	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
154457	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
154458	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
154459	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
154460	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
154461	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
154462	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
154463	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
154464	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
154465	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154466	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
154467	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
154468	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
154469	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
154470	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
154471	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154472	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154473	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154474	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154475	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154476	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
154477	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
154478	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
154479	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154480	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
154481	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
154482	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154483	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
154484	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154485	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
154486	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154487	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154488	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154489	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
154490	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154491	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
154492	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154493	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154494	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154495	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
154496	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
154497	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154498	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154499	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
154500	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154501	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154502	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
154503	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
154504	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
154505	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154506	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
154507	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments		
154508	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
154509	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
154510	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	n	
154511	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
154512	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154513	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154514	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154515	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
154516	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
154517	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
154518	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
154519	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154520	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
154521	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
154522	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154523	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
154524	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
154525	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154526	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments		
154527	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
154528	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
154529	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	78.40	kw
154530	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
154531	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
154532	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	45	°C
154533	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	42	°C
154534	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
154535	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
154536	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
154537	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
154538	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
154539	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
154540	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
154541	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
154542	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154543	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
154544	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
154545	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
154546	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
154547	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
154548	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
154549	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
154550	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
154551	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154552	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154553	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154554	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154555	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154556	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
154557	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154558	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154559	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
154560	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire is rusty, and top rail is getting rusty. Back left corner post needs replaced.	
154561	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154562	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
154563	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
154564	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
154565	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
154566	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	303944	
154567	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154568	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
154569	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
154570	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
154571	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
154572	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
154573	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
154574	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments		
154575	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
154576	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154577	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	8	
154578	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
154579	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
154580	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
154581	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154582	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154583	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
154584	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
154585	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154586	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154587	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154588	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154589	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154590	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
154591	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154592	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154593	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154594	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
154595	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
154596	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
154597	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
154598	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	152767	
154599	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
154600	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
154601	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154602	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154603	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154604	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
154605	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
154606	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154607	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
154608	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154609	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
154610	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
154611	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	81	*F
154612	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
154613	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
154614	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
154615	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
154616	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
154617	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
154618	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
154619	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
154620	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
154621	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
154622	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
154623	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
154624	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	4.0	VDC
154625	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.0	VDC
154626	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
154627	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BAT000544	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
154628	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
154629	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
154630	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
154631	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
154632	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
154633	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
154634	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
154635	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
154636	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
154637	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
154638	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154639	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154640	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154641	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154642	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154643	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154644	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
154645	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154646	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
154647	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
154648	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154649	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154650	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
154651	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154652	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154653	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154654	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
154655	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
154656	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
154657	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
154658	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
154659	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BCH000606	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
154660	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
154661	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154662	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154663	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154664	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154665	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154666	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
154667	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
154668	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
154669	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
154670	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
154671	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
154672	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
154673	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
154674	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
154675	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
154676	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
154677	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
154678	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154679	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
154680	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
154681	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154682	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
154683	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
154684	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
154685	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
154686	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
154687	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	172.80	kw
154688	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
154689	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
154690	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154691	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
154692	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
154693	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
154694	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
154695	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments		
154696	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
154697	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	Light	
154698	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
154699	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments		
154700	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154701	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154702	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154703	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154704	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154705	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
154706	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
154707	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
154708	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments		
154709	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
154710	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
154711	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154712	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154713	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
154714	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
154715	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
154716	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
154717	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
154718	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
154719	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154720	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
154721	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
154722	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154723	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154724	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
154725	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
154726	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154727	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154728	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
154729	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
154730	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
154731	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	General Comments		
154732	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Follow-up Action Required?	n	
154733	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations Ground	0	
154734	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations C Ø	0	
154735	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations B Ø	0	
154736	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations A Ø	0	
154737	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
154738	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
154739	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
154740	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	270.0	
154741	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	240.0	
154742	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	260.0	
154743	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	25.62	%
154744	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	25.62	%
154745	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	25.62	%
154746	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	10	
154747	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
154748	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154749	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154750	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154751	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154752	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154753	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
154754	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154755	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154756	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154757	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154758	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154759	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154760	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
154761	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154762	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
154763	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154764	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154765	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
154766	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154767	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154768	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154769	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154770	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154771	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
154772	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
154773	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
154774	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	
154775	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154776	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
154777	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
154778	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
154779	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
154780	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
154781	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
154782	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
154783	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
154784	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
154785	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
154786	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
154787	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
154788	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
154789	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
154790	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154791	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154792	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
154793	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
154794	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.7327	
154795	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
154796	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154797	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
154798	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
154799	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
154800	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154801	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154802	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154803	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154804	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
154805	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154806	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154807	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154808	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
154809	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
154810	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
154811	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
154812	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
154813	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
154814	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	15480	
154815	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	15480	
154816	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
154817	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	23R	
154818	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	24R	
154819	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	18R	
154820	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	362	
154821	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
154822	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	4809.60	kw
154823	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
154824	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
154825	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	40	°C
154826	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	40	°C
154827	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
154828	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
154829	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154830	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
154831	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
154832	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
154833	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154834	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
154835	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	1.0020	
154836	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
154837	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
154838	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
154839	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
154840	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
154841	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
154842	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
154843	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
154844	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
154845	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	185893	
154846	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	8.300	millivolts
154847	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
154848	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
154849	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
154850	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
154851	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
154852	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
154853	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
154854	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
154855	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	4	
154856	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations This Read Vac	4	
154857	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	351	
154858	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	185893	
154859	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
154860	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
154861	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
154862	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
154863	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1234	
154864	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
154865	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
154866	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
154867	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
154868	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
154869	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
154870	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
154871	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	93783	
154872	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	93783	
154873	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
154874	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
154875	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
154876	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
154877	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
154878	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	518	
154879	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
154880	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
154881	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
154882	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	351	
154883	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Maintenance Operations	0	
154884	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
154885	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
154886	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
154887	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
154888	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
154889	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
154890	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
154891	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1526	
154892	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
154893	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154894	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154895	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154896	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154897	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
154898	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154899	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154900	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
154901	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
154902	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
154903	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
154904	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
154905	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
154906	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
154907	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
154908	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
154909	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
154910	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
154911	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
154912	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
154913	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
154914	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
154915	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
154916	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
154917	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154918	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
154919	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154920	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154921	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
154922	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
154923	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154924	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154925	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
154926	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
154927	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
154928	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
154929	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
154930	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
154931	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
154932	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
154933	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
154934	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
154935	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
154936	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
154937	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
154938	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
154939	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
154940	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
154941	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154942	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154943	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154944	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154945	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
154946	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154947	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154948	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
154949	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
154950	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
154951	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
154952	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
154953	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
154954	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
154955	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
154956	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
154957	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154958	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154959	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154960	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
154961	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
154962	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
154963	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
154964	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	52	°C
154965	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	55	°C
154966	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
154967	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
154968	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	7033.92	kw
154969	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
154970	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
154971	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
154972	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
154973	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
154974	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
154975	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
154976	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
154977	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
154978	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
154979	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
154980	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
154981	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
154982	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
154983	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
154984	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
154985	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
154986	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
154987	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
154988	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
154989	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
154990	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
154991	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
154992	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
154993	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
154994	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
154995	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
154996	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
154997	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
154998	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
154999	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
155000	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
155001	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155002	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155003	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155004	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
155005	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
155006	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
155007	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
155008	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155009	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
155010	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
155011	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155012	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
155013	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155014	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155015	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
155016	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
155017	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155018	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
155019	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
155020	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155021	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8298.72	kw
155022	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
155023	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
155024	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
155025	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
155026	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155027	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
155028	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
155029	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
155030	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
155031	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
155032	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
155033	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155034	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
155035	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
155036	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155037	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	General Comments		
155038	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
155039	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
155040	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
155041	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
155042	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
155043	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
155044	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
155045	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
155046	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	95	°F
155047	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
155048	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
155049	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155050	10/3/2019 10:53	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	Ok	
155051	10/3/2019 10:53	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155052	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
155053	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155054	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155055	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	57	°C
155056	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
155057	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
155058	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155059	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
155060	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155061	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155062	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155063	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155064	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155065	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155066	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155067	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155068	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
155069	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7956	
155070	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155071	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155072	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155073	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155074	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155075	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
155076	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
155077	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155078	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
155079	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155080	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155081	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments		
155082	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
155083	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155084	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
155085	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155086	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2255.04	kw
155087	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
155088	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155089	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
155090	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
155091	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155092	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155093	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155094	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155095	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155096	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155097	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155098	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
155099	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9396	
155100	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
155101	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155102	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
155103	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
155104	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
155105	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
155106	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
155107	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
155108	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.2	VDC
155109	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.3	VDC
155110	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
155111	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
155112	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
155113	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
155114	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
155115	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
155116	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
155117	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
155118	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
155119	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
155120	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
155121	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
155122	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
155123	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
155124	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
155125	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
155126	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	34.0	
155127	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
155128	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
155129	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	253	
155130	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
155131	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
155132	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
155133	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
155134	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
155135	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
155136	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
155137	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
155138	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	405	
155139	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
155140	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
155141	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
155142	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
155143	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
155144	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
155145	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
155146	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	23.8	
155147	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	27.0	
155148	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.0	
155149	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	44	
155150	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	.2	
155151	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	.9	
155152	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.5	
155153	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	46	
155154	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
155155	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
155156	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	71	
155157	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
155158	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
155159	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
155160	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
155161	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
155162	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
155163	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
155164	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155165	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155166	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155167	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155168	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155169	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155170	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
155171	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155172	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155173	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		
155174	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
155175	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155176	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155177	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155178	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	636.48	kw
155179	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
155180	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	General Comments		
155181	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
155182	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
155183	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
155184	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
155185	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
155186	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
155187	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
155188	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
155189	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
155190	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155191	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155192	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
155193	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
155194	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
155195	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155196	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155197	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
155198	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
155199	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
155200	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
155201	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155202	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
155203	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
155204	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155205	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
155206	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155207	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155208	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155209	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155210	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
155211	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
155212	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
155213	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155214	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155215	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
155216	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
155217	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
155218	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
155219	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
155220	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
155221	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
155222	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments		
155223	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
155224	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
155225	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
155226	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
155227	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155228	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
155229	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
155230	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155231	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
155232	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
155233	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
155234	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
155235	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
155236	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
155237	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
155238	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
155239	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
155240	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
155241	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
155242	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
155243	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
155244	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
155245	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
155246	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
155247	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
155248	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
155249	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
155250	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
155251	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155252	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
155253	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
155254	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
155255	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
155256	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
155257	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
155258	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
155259	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
155260	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
155261	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
155262	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
155263	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
155264	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
155265	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
155266	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
155267	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
155268	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
155269	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
155270	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
155271	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
155272	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
155273	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
155274	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.3	
155275	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.3	
155276	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.0	
155277	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
155278	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
155279	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
155280	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
155281	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
155282	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
155283	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
155284	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	485	
155285	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
155286	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
155287	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	872	
155288	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
155289	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	40.0	
155290	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	40.5	
155291	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
155292	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
155293	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
155294	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1219	
155295	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
155296	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
155297	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
155298	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
155299	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC0000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
155300	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC0000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments		
155301	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC0000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
155302	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
155303	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
155304	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
155305	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BCH000386	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
155306	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
155307	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
155308	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
155309	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
155310	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
155311	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
155312	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
155313	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
155314	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
155315	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
155316	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
155317	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
155318	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments		
155319	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
155320	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
155321	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
155322	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
155323	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
155324	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
155325	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
155326	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155327	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
155328	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
155329	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
155330	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments	Wasnt able to get amps on recloser.	
155331	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
155332	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155333	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
155334	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155335	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
155336	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
155337	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	431	
155338	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
155339	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
155340	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
155341	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
155342	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
155343	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155344	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155345	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155346	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155347	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155348	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155349	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
155350	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3840	
155351	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
155352	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
155353	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155354	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155355	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
155356	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155357	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155358	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155359	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155360	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155361	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155362	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
155363	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
155364	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
155365	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155366	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
155367	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
155368	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155369	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
155370	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
155371	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155372	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
155373	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
155374	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155375	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
155376	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155377	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155378	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
155379	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
155380	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155381	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155382	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
155383	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
155384	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	60	°C
155385	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	50	°C
155386	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155387	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155388	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155389	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155390	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155391	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155392	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155393	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155394	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155395	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
155396	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	7107.84	kw
155397	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
155398	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
155399	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	50	°C
155400	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	50	°C
155401	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155402	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
155403	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155404	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
155405	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
155406	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
155407	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
155408	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
155409	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
155410	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
155411	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
155412	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
155413	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
155414	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
155415	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
155416	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
155417	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
155418	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
155419	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
155420	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
155421	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
155422	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155423	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155424	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155425	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155426	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155427	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155428	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
155429	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155430	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155431	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
155432	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
155433	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155434	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155435	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
155436	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
155437	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
155438	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
155439	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155440	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155441	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155442	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155443	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155444	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155445	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
155446	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
155447	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	75.0	
155448	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
155449	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
155450	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
155451	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
155452	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
155453	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
155454	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
155455	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
155456	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
155457	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
155458	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
155459	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
155460	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
155461	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1825	
155462	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
155463	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
155464	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
155465	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155466	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155467	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155468	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155469	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155470	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
155471	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
155472	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155473	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
155474	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155475	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155476	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155477	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
155478	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155479	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
155480	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155481	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	921.60	kw
155482	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
155483	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations This Read Vac	0	
155484	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	General Comments	breaker not installed, yet	
155485	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Follow-up Action Required?	n	
155486	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
155487	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
155488	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
155489	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
155490	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
155491	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
155492	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	9 Month Operations	-1	
155493	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155494	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	51	°C
155495	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	41	°C
155496	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155497	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.7404	
155498	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
155499	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
155500	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
155501	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
155502	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
155503	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
155504	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
155505	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
155506	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
155507	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
155508	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
155509	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
155510	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
155511	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155512	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
155513	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
155514	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155515	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
155516	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
155517	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
155518	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
155519	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155520	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155521	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
155522	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
155523	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
155524	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
155525	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155526	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
155527	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
155528	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
155529	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155530	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155531	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155532	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155533	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
155534	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155535	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
155536	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
155537	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155538	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
155539	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
155540	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
155541	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
155542	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155543	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155544	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
155545	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
155546	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
155547	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155548	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155549	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
155550	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
155551	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155552	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
155553	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
155554	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
155555	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
155556	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
155557	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
155558	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
155559	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
155560	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
155561	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
155562	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
155563	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
155564	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
155565	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
155566	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
155567	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
155568	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
155569	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
155570	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
155571	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
155572	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
155573	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
155574	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
155575	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
155576	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
155577	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
155578	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
155579	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
155580	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
155581	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
155582	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
155583	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
155584	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155585	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155586	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155587	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
155588	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155589	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155590	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments		
155591	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		
155592	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155593	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155594	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	955.44	kw
155595	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
155596	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
155597	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		
155598	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
155599	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
155600	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
155601	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
155602	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
155603	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
155604	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
155605	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
155606	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
155607	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
155608	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
155609	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
155610	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
155611	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
155612	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
155613	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	50	°C
155614	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155615	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155616	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155617	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155618	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155619	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155620	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155621	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
155622	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7962	
155623	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
155624	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
155625	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155626	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155627	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
155628	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
155629	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
155630	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
155631	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
155632	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
155633	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
155634	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
155635	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
155636	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
155637	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
155638	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
155639	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
155640	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
155641	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	General Comments	all of fence is getting rusty	
155642	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	FE00062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
155643	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155644	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
155645	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
155646	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155647	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155648	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155649	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155650	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	200.00	
155651	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
155652	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.2250	
155653	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
155654	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155655	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
155656	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
155657	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
155658	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155659	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
155660	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155661	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	34	°C
155662	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	34	°C
155663	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
155664	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
155665	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	1620.00	kw
155666	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
155667	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
155668	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
155669	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155670	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155671	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155672	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	7R	
155673	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	4	
155674	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
155675	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
155676	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
155677	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	135.0	
155678	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	115.0	
155679	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
155680	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
155681	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155682	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
155683	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
155684	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155685	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
155686	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
155687	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
155688	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
155689	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155690	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155691	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
155692	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
155693	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	120.0	
155694	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
155695	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
155696	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
155697	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
155698	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
155699	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
155700	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
155701	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155702	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
155703	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
155704	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
155705	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
155706	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
155707	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LTC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
155708	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
155709	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
155710	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
155711	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
155712	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
155713	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
155714	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
155715	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155716	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155717	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155718	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155719	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155720	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155721	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	41	°C
155722	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	57	°C
155723	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155724	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
155725	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
155726	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
155727	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155728	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155729	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155730	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155731	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
155732	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155733	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
155734	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
155735	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
155736	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
155737	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
155738	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
155739	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
155740	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
155741	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
155742	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
155743	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
155744	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
155745	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
155746	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
155747	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
155748	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
155749	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
155750	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
155751	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
155752	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
155753	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
155754	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
155755	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
155756	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
155757	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
155758	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
155759	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
155760	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
155761	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155762	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments	BALL NOT FLOATING BUT GLASS LOOKS LIKE OIL INSIDE ON ALL 3 REGULATORS?	
155763	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
155764	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
155765	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
155766	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155767	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155768	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
155769	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
155770	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
155771	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58634	
155772	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155773	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155774	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
155775	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
155776	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155777	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155778	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155779	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155780	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155781	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
155782	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155783	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
155784	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
155785	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155786	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments		
155787	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
155788	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
155789	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
155790	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155791	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155792	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
155793	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
155794	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
155795	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	55817	
155796	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155797	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155798	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
155799	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
155800	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
155801	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155802	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
155803	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
155804	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
155805	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
155806	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
155807	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	99982	
155808	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
155809	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
155810	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
155811	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
155812	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
155813	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
155814	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
155815	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
155816	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
155817	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
155818	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
155819	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
155820	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
155821	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
155822	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
155823	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
155824	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
155825	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
155826	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
155827	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
155828	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
155829	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
155830	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
155831	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
155832	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
155833	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
155834	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
155835	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
155836	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
155837	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
155838	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
155839	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
155840	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
155841	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
155842	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
155843	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
155844	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
155845	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
155846	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
155847	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
155848	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.0	VDC
155849	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
155850	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
155851	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
155852	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
155853	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
155854	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
155855	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	57105	
155856	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	57105	
155857	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
155858	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	8R	
155859	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	0	
155860	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
155861	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
155862	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
155863	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
155864	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
155865	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
155866	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
155867	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
155868	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
155869	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
155870	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
155871	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
155872	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
155873	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
155874	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
155875	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
155876	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
155877	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
155878	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2329	
155879	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155880	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
155881	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
155882	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
155883	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155884	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments	C Phase line side disc broken.	
155885	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
155886	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
155887	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
155888	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
155889	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	270	
155890	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	270	
155891	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	4	
155892	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	4	
155893	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
155894	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
155895	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155896	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
155897	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
155898	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155899	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments		
155900	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
155901	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
155902	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
155903	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
155904	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
155905	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155906	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155907	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
155908	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
155909	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155910	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155911	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155912	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155913	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155914	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
155915	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
155916	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
155917	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
155918	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
155919	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
155920	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	36	°C
155921	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	49	°C
155922	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
155923	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
155924	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
155925	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
155926	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
155927	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
155928	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
155929	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
155930	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
155931	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
155932	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
155933	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
155934	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
155935	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
155936	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
155937	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
155938	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
155939	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	91	*F
155940	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	BAT000603	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
155941	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
155942	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
155943	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
155944	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	61152	
155945	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155946	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155947	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
155948	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
155949	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
155950	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
155951	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
155952	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	99982	
155953	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
155954	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
155955	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
155956	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
155957	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
155958	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
155959	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
155960	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
155961	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	69274	
155962	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
155963	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
155964	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
155965	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
155966	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
155967	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
155968	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
155969	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
155970	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
155971	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
155972	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
155973	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
155974	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
155975	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
155976	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
155977	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
155978	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
155979	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	99	
155980	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
155981	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
155982	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
155983	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
155984	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
155985	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
155986	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
155987	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
155988	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
155989	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
155990	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
155991	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
155992	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
155993	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
155994	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
155995	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
155996	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
155997	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
155998	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
155999	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156000	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156001	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
156002	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
156003	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
156004	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
156005	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
156006	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
156007	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
156008	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
156009	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
156010	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
156011	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
156012	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
156013	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
156014	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
156015	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
156016	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
156017	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
156018	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
156019	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
156020	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156021	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156022	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
156023	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
156024	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
156025	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	375379	
156026	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156027	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156028	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
156029	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
156030	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
156031	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156032	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
156033	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156034	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156035	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
156036	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
156037	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156038	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
156039	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
156040	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
156041	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
156042	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156043	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156044	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
156045	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
156046	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
156047	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
156048	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
156049	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156050	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
156051	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
156052	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156053	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
156054	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
156055	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156056	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
156057	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
156058	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
156059	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
156060	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
156061	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
156062	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
156063	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156064	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
156065	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156066	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
156067	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
156068	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156069	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
156070	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
156071	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
156072	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
156073	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
156074	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	42	°C
156075	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	62	°C
156076	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156077	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
156078	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
156079	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
156080	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
156081	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
156082	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
156083	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
156084	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36177	
156085	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156086	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156087	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
156088	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
156089	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
156090	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156091	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156092	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156093	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156094	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
156095	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156096	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
156097	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
156098	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156099	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
156100	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
156101	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
156102	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
156103	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156104	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156105	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
156106	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
156107	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
156108	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	General Comments		
156109	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
156110	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
156111	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	LTC0000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
156112	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156113	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156114	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156115	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156116	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156117	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156118	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156119	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
156120	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
156121	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156122	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156123	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
156124	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
156125	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156126	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
156127	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
156128	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156129	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
156130	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
156131	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
156132	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
156133	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
156134	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
156135	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
156136	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	50	%
156137	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	50	%
156138	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	50	%
156139	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156140	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
156141	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156142	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
156143	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
156144	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
156145	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
156146	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
156147	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
156148	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
156149	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
156150	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
156151	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156152	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
156153	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
156154	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
156155	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
156156	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
156157	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
156158	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
156159	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156160	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
156161	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
156162	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	57.0	
156163	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
156164	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
156165	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
156166	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
156167	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
156168	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
156169	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
156170	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
156171	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
156172	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
156173	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
156174	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
156175	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
156176	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
156177	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
156178	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	130	
156179	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
156180	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
156181	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
156182	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
156183	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
156184	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
156185	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
156186	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156187	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
156188	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
156189	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156190	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156191	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156192	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156193	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156194	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
156195	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156196	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
156197	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156198	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156199	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156200	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156201	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156202	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156203	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156204	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
156205	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
156206	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
156207	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
156208	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
156209	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
156210	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
156211	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
156212	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
156213	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
156214	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
156215	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
156216	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
156217	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
156218	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
156219	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156220	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156221	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	5	
156222	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
156223	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
156224	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
156225	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	60.0	
156226	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	60.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
156227	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	50.0	
156228	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
156229	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
156230	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
156231	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
156232	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
156233	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
156234	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
156235	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
156236	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
156237	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
156238	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
156239	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
156240	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
156241	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	1	
156242	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
156243	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
156244	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
156245	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
156246	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
156247	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
156248	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
156249	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
156250	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
156251	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	198	
156252	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	198	
156253	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	5	
156254	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	4	
156255	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
156256	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
156257	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156258	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments		
156259	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
156260	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
156261	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
156262	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
156263	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
156264	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
156265	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
156266	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156267	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
156268	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
156269	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
156270	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
156271	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
156272	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
156273	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
156274	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156275	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
156276	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
156277	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156278	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156279	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156280	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156281	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156282	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156283	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156284	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
156285	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156286	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments	tower foundations are crumbling	
156287	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156288	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156289	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156290	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156291	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156292	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
156293	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
156294	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
156295	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
156296	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1409	
156297	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
156298	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
156299	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
156300	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
156301	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
156302	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	11063	
156303	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	11063	
156304	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
156305	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		
156306	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
156307	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
156308	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
156309	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
156310	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
156311	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
156312	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
156313	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156314	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156315	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156316	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156317	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	873	
156318	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	13L	
156319	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3L	
156320	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	11L	
156321	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
156322	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	28156	
156323	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	28156	
156324	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
156325	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
156326	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
156327	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
156328	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
156329	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156330	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6396	
156331	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
156332	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156333	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
156334	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
156335	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156336	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
156337	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156338	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
156339	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
156340	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
156341	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
156342	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
156343	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
156344	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
156345	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
156346	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	155422	
156347	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156348	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156349	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
156350	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
156351	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156352	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
156353	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156354	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
156355	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
156356	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
156357	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
156358	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	801	
156359	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	14L	
156360	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	8L	
156361	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	9L	
156362	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
156363	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	52462	
156364	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	52462	
156365	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156366	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
156367	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156368	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156369	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156370	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156371	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156372	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156373	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156374	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
156375	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156376	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156377	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156378	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156379	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156380	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156381	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156382	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156383	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156384	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
156385	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
156386	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156387	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
156388	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
156389	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
156390	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
156391	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156392	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156393	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156394	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156395	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156396	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156397	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
156398	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156399	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
156400	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156401	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156402	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156403	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156404	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156405	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156406	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156407	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
156408	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
156409	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156410	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
156411	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
156412	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
156413	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	34	
156414	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
156415	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
156416	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments	needs new battery	
156417	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
156418	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
156419	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
156420	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
156421	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
156422	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
156423	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
156424	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156425	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
156426	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
156427	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
156428	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156429	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Switching Operations	1	
156430	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations This Read Vac	9	
156431	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AL	168	
156432	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AF	168	
156433	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Moisture and Leak Free?	y	
156434	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Maintenance Operations	0	
156435	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Grounds in Place?	y	
156436	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	General Comments		
156437	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	General Comments		
156438	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Foundation Condition	Good	
156439	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Follow-up Action Required?	n	
156440	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Follow-up Action Required?	n	
156441	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations Ground	0	
156442	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations C Ø	0	
156443	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations B Ø	4	
156444	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations A Ø	4	
156445	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
156446	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps B Phase V	15.81	
156447	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps A Phase V	15.81	
156448	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
156449	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
156450	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
156451	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
156452	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
156453	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
156454	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushing Condition	Good	
156455	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps C Ø	72.0	
156456	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps B Ø	85.0	
156457	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps A Ø	54.0	
156458	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
156459	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
156460	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
156461	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	9 Month Operations	11	
156462	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
156463	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2135	
156464	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
156465	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156466	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156467	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156468	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156469	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
156470	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156471	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
156472	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
156473	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
156474	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	General Comments	LTC is off	
156475	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
156476	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
156477	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
156478	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
156479	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
156480	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	LTC0000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
156481	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
156482	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156483	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments		
156484	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
156485	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
156486	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
156487	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156488	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156489	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
156490	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
156491	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
156492	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	273894	
156493	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156494	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
156495	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
156496	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
156497	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156498	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156499	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156500	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156501	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
156502	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
156503	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
156504	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
156505	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
156506	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
156507	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
156508	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156509	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156510	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
156511	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156512	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
156513	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
156514	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
156515	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
156516	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	767.52	kw
156517	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
156518	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
156519	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
156520	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
156521	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
156522	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
156523	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
156524	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
156525	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
156526	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156527	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments		
156528	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Unreadable	
156529	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
156530	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
156531	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156532	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
156533	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
156534	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156535	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
156536	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
156537	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
156538	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
156539	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
156540	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156541	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
156542	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
156543	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
156544	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
156545	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156546	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156547	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
156548	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
156549	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
156550	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	108383	
156551	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156552	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Tank Paint Condition	Good	
156553	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156554	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
156555	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
156556	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
156557	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
156558	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LTC0000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
156559	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
156560	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
156561	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
156562	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
156563	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156564	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
156565	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
156566	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156567	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
156568	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
156569	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156570	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments		
156571	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments		
156572	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
156573	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
156574	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	128.10	kw
156575	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
156576	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
156577	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
156578	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
156579	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156580	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
156581	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
156582	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
156583	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
156584	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
156585	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
156586	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
156587	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
156588	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
156589	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
156590	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
156591	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
156592	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
156593	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
156594	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
156595	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
156596	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
156597	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
156598	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
156599	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments		
156600	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
156601	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
156602	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
156603	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
156604	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
156605	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
156606	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
156607	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
156608	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
156609	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
156610	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
156611	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
156612	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
156613	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
156614	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
156615	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
156616	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
156617	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
156618	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
156619	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
156620	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
156621	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156622	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
156623	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
156624	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156625	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
156626	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
156627	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156628	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
156629	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
156630	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
156631	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
156632	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
156633	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
156634	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	48499.20	kw
156635	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
156636	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
156637	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
156638	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
156639	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156640	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
156641	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156642	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
156643	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
156644	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
156645	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156646	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	96000	
156647	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5052	
156648	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
156649	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
156650	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
156651	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
156652	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
156653	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
156654	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
156655	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
156656	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
156657	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
156658	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
156659	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	200	
156660	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
156661	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
156662	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
156663	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
156664	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
156665	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
156666	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
156667	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.5	
156668	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156669	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156670	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156671	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156672	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156673	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156674	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
156675	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156676	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156677	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156678	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156679	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156680	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156681	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156682	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156683	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156684	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156685	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
156686	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
156687	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
156688	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
156689	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
156690	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
156691	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
156692	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
156693	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
156694	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
156695	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
156696	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
156697	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
156698	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
156699	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
156700	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
156701	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		
156702	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
156703	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
156704	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
156705	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
156706	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
156707	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
156708	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
156709	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
156710	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
156711	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
156712	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
156713	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
156714	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
156715	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
156716	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
156717	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
156718	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
156719	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
156720	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
156721	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
156722	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
156723	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
156724	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
156725	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
156726	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
156727	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
156728	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
156729	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
156730	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
156731	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
156732	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156733	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156734	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156735	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
156736	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156737	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
156738	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
156739	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
156740	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
156741	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
156742	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
156743	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	12888.00	kw
156744	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
156745	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
156746	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156747	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
156748	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156749	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
156750	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
156751	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156752	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156753	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Max	45	°C
156754	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
156755	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
156756	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.5370	
156757	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	45	°C
156758	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	45	°C
156759	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
156760	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
156761	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
156762	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
156763	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
156764	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
156765	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
156766	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
156767	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
156768	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
156769	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
156770	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
156771	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
156772	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
156773	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
156774	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
156775	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
156776	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
156777	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
156778	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
156779	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
156780	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
156781	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
156782	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
156783	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	19918	
156784	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Left Counter	19918	
156785	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
156786	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Current Tap Position	5L	
156787	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Max Tap Position	4R	
156788	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Min Tap Position	8L	
156789	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
156790	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
156791	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
156792	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156793	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
156794	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
156795	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
156796	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
156797	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156798	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156799	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
156800	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
156801	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	
156802	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	113437	volts
156803	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
156804	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Operations Since Last Insp	1061	
156805	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
156806	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
156807	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
156808	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156809	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156810	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
156811	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
156812	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
156813	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
156814	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LTC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
156815	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
156816	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
156817	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
156818	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
156819	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
156820	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156821	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156822	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156823	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156824	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
156825	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156826	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156827	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
156828	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
156829	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
156830	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
156831	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
156832	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
156833	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	General Comments		
156834	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
156835	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
156836	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
156837	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
156838	10/3/2019 8:43	Distribution	Shelby City Quarterly Inspection	LTC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
156839	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
156840	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
156841	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
156842	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
156843	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
156844	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
156845	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
156846	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
156847	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
156848	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
156849	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
156850	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
156851	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
156852	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
156853	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
156854	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
156855	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
156856	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
156857	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments	CHANGED BASE TO 122 VOLTS PER RON MERCER (UK ELEC)	
156858	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
156859	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
156860	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
156861	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
156862	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
156863	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	LTC000581	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
156864	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
156865	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
156866	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
156867	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
156868	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
156869	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
156870	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
156871	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
156872	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
156873	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
156874	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
156875	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
156876	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
156877	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
156878	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
156879	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
156880	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
156881	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
156882	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
156883	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
156884	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
156885	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
156886	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
156887	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
156888	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
156889	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
156890	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
156891	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
156892	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156893	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
156894	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
156895	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
156896	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
156897	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
156898	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
156899	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
156900	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
156901	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156902	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
156903	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
156904	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	31	
156905	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
156906	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments		
156907	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
156908	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
156909	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	226	
156910	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
156911	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
156912	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	180	
156913	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	29.0	
156914	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.0	
156915	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	35.7	
156916	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	210	
156917	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
156918	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
156919	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
156920	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
156921	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
156922	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
156923	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
156924	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
156925	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
156926	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
156927	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
156928	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
156929	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
156930	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
156931	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
156932	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
156933	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
156934	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
156935	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
156936	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
156937	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
156938	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
156939	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	172	
156940	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
156941	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
156942	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	200	
156943	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
156944	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.4	
156945	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.4	
156946	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	184	
156947	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
156948	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
156949	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
156950	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
156951	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	119610	
156952	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
156953	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
156954	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
156955	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
156956	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
156957	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
156958	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
156959	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
156960	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
156961	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
156962	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
156963	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
156964	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
156965	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
156966	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156967	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
156968	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
156969	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
156970	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156971	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156972	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
156973	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
156974	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
156975	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
156976	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments	FANS NOT HOOKED UP	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
156977	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
156978	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
156979	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1732.80	kw
156980	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	220.00	
156981	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
156982	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
156983	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
156984	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
156985	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
156986	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
156987	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
156988	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
156989	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
156990	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
156991	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3800	
156992	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4560	
156993	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
156994	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
156995	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
156996	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
156997	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
156998	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	1L	
156999	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157000	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
157001	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
157002	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157003	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
157004	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
157005	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
157006	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	95	°F
157007	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
157008	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
157009	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
157010	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
157011	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
157012	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
157013	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
157014	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157015	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157016	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
157017	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
157018	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
157019	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	45093	
157020	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157021	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157022	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
157023	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
157024	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
157025	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
157026	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
157027	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
157028	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
157029	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
157030	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
157031	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
157032	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
157033	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
157034	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
157035	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
157036	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
157037	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
157038	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
157039	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
157040	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
157041	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
157042	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
157043	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
157044	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
157045	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	tower foundation near battery house is crumbling	
157046	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
157047	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
157048	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
157049	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
157050	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
157051	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157052	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
157053	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	1	
157054	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations This Read Vac	9	
157055	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	187	
157056	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	186	
157057	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
157058	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
157059	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
157060	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments		
157061	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
157062	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
157063	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
157064	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
157065	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	2	
157066	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	2	
157067	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	2	
157068	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	2	
157069	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	11.74	
157070	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	11.74	
157071	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	11.74	
157072	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	
157073	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
157074	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
157075	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
157076	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
157077	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
157078	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
157079	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	6.0	
157080	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	7.0	
157081	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	4.0	
157082	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
157083	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
157084	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
157085	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	9	
157086	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
157087	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
157088	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	4	
157089	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	4	
157090	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	188	
157091	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	184	
157092	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
157093	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
157094	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
157095	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments		
157096	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
157097	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
157098	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
157099	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
157100	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
157101	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
157102	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
157103	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
157104	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
157105	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
157106	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
157107	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
157108	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
157109	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
157110	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
157111	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
157112	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
157113	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
157114	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	12.0	
157115	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	24.0	
157116	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	18.0	
157117	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
157118	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
157119	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
157120	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	4	
157121	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
157122	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
157123	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
157124	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
157125	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
157126	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157127	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
157128	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157129	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157130	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
157131	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157132	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
157133	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
157134	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157135	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
157136	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
157137	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
157138	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
157139	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157140	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157141	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
157142	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157143	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157144	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157145	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
157146	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
157147	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
157148	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
157149	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
157150	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
157151	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
157152	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
157153	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
157154	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
157155	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.900	millivolts
157156	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	119055	
157157	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157158	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157159	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
157160	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
157161	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
157162	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157163	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157164	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157165	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157166	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
157167	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157168	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
157169	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
157170	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157171	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
157172	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
157173	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
157174	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
157175	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157176	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157177	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
157178	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
157179	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
157180	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24675	
157181	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157182	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157183	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
157184	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
157185	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
157186	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
157187	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157188	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	286768	
157189	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
157190	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
157191	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
157192	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157193	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157194	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
157195	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
157196	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
157197	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments		
157198	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157199	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
157200	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
157201	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157202	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
157203	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157204	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157205	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157206	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157207	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
157208	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
157209	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
157210	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
157211	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
157212	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
157213	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
157214	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
157215	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
157216	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
157217	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
157218	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
157219	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
157220	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
157221	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
157222	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157223	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157224	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	2	
157225	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
157226	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
157227	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
157228	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	76.0	
157229	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	79.0	
157230	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
157231	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
157232	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
157233	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	125084	
157234	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157235	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
157236	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
157237	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
157238	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
157239	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
157240	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
157241	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
157242	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157243	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
157244	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
157245	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
157246	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157247	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157248	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157249	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157250	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
157251	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157252	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
157253	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
157254	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157255	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
157256	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
157257	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
157258	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
157259	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157260	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157261	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
157262	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
157263	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
157264	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	95467	
157265	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157266	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157267	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
157268	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
157269	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
157270	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
157271	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	95.0	
157272	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
157273	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
157274	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
157275	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
157276	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157277	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
157278	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
157279	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
157280	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
157281	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	72.0	
157282	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
157283	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
157284	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
157285	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
157286	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
157287	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
157288	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	B phase Arrester blown 1709	
157289	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
157290	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
157291	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
157292	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
157293	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
157294	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
157295	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
157296	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
157297	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
157298	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
157299	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
157300	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157301	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157302	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	47216	
157303	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
157304	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
157305	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
157306	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157307	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157308	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
157309	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
157310	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
157311	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
157312	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157313	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
157314	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
157315	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157316	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
157317	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157318	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157319	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157320	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157321	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
157322	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
157323	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
157324	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
157325	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	81	*F
157326	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
157327	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
157328	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
157329	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
157330	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
157331	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157332	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
157333	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
157334	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
157335	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	100581	
157336	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157337	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157338	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
157339	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
157340	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
157341	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
157342	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
157343	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
157344	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
157345	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
157346	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
157347	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
157348	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
157349	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
157350	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
157351	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
157352	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157353	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157354	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157355	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
157356	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157357	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
157358	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
157359	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157360	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
157361	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
157362	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
157363	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
157364	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
157365	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
157366	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
157367	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
157368	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
157369	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
157370	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
157371	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
157372	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
157373	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
157374	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157375	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157376	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157377	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157378	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
157379	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157380	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
157381	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
157382	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157383	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
157384	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
157385	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	3	
157386	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
157387	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
157388	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
157389	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	169.0	
157390	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	174.0	
157391	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	169.0	
157392	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
157393	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
157394	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
157395	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
157396	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
157397	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
157398	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
157399	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
157400	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
157401	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
157402	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
157403	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
157404	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	1	
157405	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
157406	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
157407	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
157408	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
157409	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
157410	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
157411	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
157412	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
157413	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
157414	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	183	
157415	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	183	
157416	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
157417	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	0	
157418	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
157419	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
157420	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
157421	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
157422	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157423	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157424	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
157425	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
157426	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157427	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	109021	
157428	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157429	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157430	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
157431	10/3/2019 13:03	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
157432	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
157433	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
157434	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
157435	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
157436	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
157437	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
157438	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
157439	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
157440	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
157441	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
157442	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
157443	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
157444	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
157445	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
157446	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
157447	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
157448	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
157449	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
157450	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
157451	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
157452	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
157453	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
157454	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
157455	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		
157456	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
157457	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
157458	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
157459	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
157460	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
157461	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
157462	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
157463	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
157464	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
157465	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
157466	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
157467	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	0	
157468	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
157469	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	174	
157470	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	174	
157471	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	0	
157472	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
157473	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
157474	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
157475	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
157476	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
157477	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
157478	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
157479	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	928	
157480	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
157481	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
157482	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
157483	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
157484	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157485	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157486	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157487	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157488	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
157489	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157490	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
157491	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
157492	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157493	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
157494	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
157495	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
157496	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
157497	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157498	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157499	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
157500	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
157501	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157502	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11142	
157503	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157504	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157505	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
157506	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
157507	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
157508	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
157509	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
157510	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
157511	10/3/2019 13:02	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
157512	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
157513	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
157514	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
157515	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
157516	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
157517	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
157518	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
157519	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
157520	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
157521	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
157522	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
157523	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
157524	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
157525	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
157526	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
157527	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
157528	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
157529	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
157530	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
157531	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
157532	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
157533	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
157534	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157535	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157536	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91800	
157537	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
157538	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
157539	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
157540	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157541	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157542	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
157543	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
157544	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
157545	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments	bad counter	
157546	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157547	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
157548	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
157549	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157550	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
157551	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157552	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
157553	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
157554	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157555	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157556	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157557	10/3/2019 14:53	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
157558	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157559	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157560	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157561	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157562	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157563	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157564	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
157565	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157566	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
157567	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
157568	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
157569	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
157570	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
157571	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157572	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
157573	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
157574	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
157575	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157576	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157577	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
157578	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	10742.40	kw
157579	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
157580	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
157581	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
157582	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	50	°C
157583	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157584	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
157585	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157586	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157587	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
157588	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
157589	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5180	
157590	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
157591	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157592	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
157593	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
157594	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157595	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157596	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
157597	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157598	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157599	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157600	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157601	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157602	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
157603	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
157604	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
157605	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
157606	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
157607	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
157608	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
157609	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	1423	
157610	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	8L	
157611	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
157612	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	3L	
157613	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
157614	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	207757	
157615	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	207757	
157616	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
157617	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
157618	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
157619	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
157620	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157621	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	General Comments		
157622	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Leak at joint of LTC and Main tank. Pic sent to Stinson	
157623	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
157624	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	50	°C
157625	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
157626	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
157627	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
157628	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
157629	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
157630	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
157631	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
157632	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
157633	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
157634	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	70	°C
157635	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157636	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
157637	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
157638	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
157639	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	70	%
157640	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	70	%
157641	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	70	%
157642	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157643	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
157644	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157645	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157646	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
157647	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
157648	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157649	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
157650	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
157651	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157652	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
157653	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157654	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	303551	
157655	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
157656	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
157657	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
157658	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157659	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157660	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
157661	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
157662	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
157663	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments		
157664	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157665	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
157666	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
157667	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157668	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
157669	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157670	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157671	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157672	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157673	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
157674	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
157675	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
157676	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
157677	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
157678	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
157679	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
157680	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
157681	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
157682	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
157683	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
157684	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
157685	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
157686	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
157687	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
157688	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
157689	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157690	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
157691	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
157692	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2174.40	kw
157693	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
157694	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
157695	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
157696	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
157697	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157698	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
157699	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157700	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157701	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
157702	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
157703	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157704	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
157705	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3020	
157706	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
157707	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	42	°C
157708	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157709	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157710	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157711	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
157712	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
157713	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157714	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
157715	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
157716	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157717	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
157718	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
157719	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
157720	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
157721	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
157722	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
157723	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	1262	
157724	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	6L	
157725	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	6L	
157726	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	6L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
157727	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
157728	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	1713	
157729	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	1701	
157730	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments		
157731	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments		
157732	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
157733	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
157734	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
157735	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
157736	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
157737	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
157738	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
157739	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
157740	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157741	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
157742	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
157743	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
157744	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
157745	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
157746	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
157747	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
157748	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
157749	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
157750	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
157751	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
157752	10/3/2019 10:45	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
157753	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157754	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
157755	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
157756	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
157757	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
157758	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4972.80	kw
157759	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
157760	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
157761	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157762	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
157763	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
157764	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
157765	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157766	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
157767	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
157768	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
157769	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
157770	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
157771	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157772	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157773	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157774	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157775	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157776	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157777	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157778	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
157779	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
157780	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157781	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
157782	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.1190	
157783	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	90	°C
157784	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	65	°C
157785	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
157786	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
157787	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157788	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157789	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
157790	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
157791	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
157792	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
157793	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
157794	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
157795	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
157796	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
157797	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
157798	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
157799	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
157800	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
157801	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
157802	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157803	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157804	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157805	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157806	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
157807	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157808	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
157809	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
157810	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
157811	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
157812	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
157813	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157814	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
157815	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
157816	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
157817	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
157818	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
157819	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
157820	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
157821	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
157822	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
157823	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
157824	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
157825	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
157826	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
157827	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
157828	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
157829	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
157830	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
157831	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
157832	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
157833	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
157834	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
157835	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
157836	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
157837	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
157838	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
157839	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
157840	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157841	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157842	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
157843	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157844	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
157845	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
157846	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157847	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
157848	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
157849	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157850	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
157851	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
157852	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
157853	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
157854	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
157855	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157856	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157857	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157858	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157859	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157860	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157861	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157862	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
157863	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
157864	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
157865	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
157866	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	265	
157867	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	265	
157868	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	1	
157869	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	1	
157870	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
157871	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
157872	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
157873	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
157874	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
157875	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
157876	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
157877	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
157878	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
157879	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
157880	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
157881	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
157882	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
157883	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
157884	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	6L	
157885	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	11L	
157886	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
157887	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
157888	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
157889	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
157890	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
157891	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	147444	
157892	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
157893	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
157894	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
157895	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
157896	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.9348	
157897	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
157898	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
157899	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
157900	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
157901	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
157902	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
157903	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157904	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	42	°C
157905	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	59	°C
157906	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
157907	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
157908	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
157909	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments		
157910	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
157911	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157912	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
157913	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
157914	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
157915	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
157916	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
157917	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
157918	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
157919	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
157920	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
157921	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
157922	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
157923	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
157924	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
157925	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
157926	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
157927	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
157928	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
157929	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
157930	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
157931	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
157932	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
157933	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
157934	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
157935	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
157936	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
157937	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
157938	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
157939	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
157940	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
157941	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
157942	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
157943	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
157944	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
157945	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
157946	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
157947	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
157948	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
157949	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
157950	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
157951	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
157952	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
157953	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
157954	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157955	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157956	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157957	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157958	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157959	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157960	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
157961	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
157962	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
157963	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
157964	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
157965	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
157966	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	2	
157967	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
157968	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
157969	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
157970	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	116.0	
157971	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	109.0	
157972	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	124.0	
157973	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
157974	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
157975	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
157976	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
157977	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
157978	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
157979	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
157980	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
157981	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
157982	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
157983	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
157984	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
157985	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
157986	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
157987	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
157988	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
157989	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
157990	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
157991	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
157992	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
157993	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
157994	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
157995	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
157996	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
157997	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1121.76	kw
157998	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
157999	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
158000	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
158001	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	General Comments		
158002	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
158003	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
158004	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
158005	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
158006	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
158007	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
158008	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
158009	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
158010	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
158011	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
158012	10/3/2019 13:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
158013	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
158014	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
158015	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
158016	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
158017	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
158018	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
158019	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
158020	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
158021	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
158022	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
158023	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
158024	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
158025	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	5L	
158026	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	11L	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158027	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
158028	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
158029	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
158030	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
158031	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
158032	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	144738	
158033	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
158034	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
158035	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
158036	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
158037	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
158038	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
158039	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
158040	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
158041	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
158042	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
158043	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
158044	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
158045	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
158046	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
158047	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
158048	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
158049	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
158050	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
158051	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
158052	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
158053	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
158054	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
158055	10/3/2019 10:38	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
158056	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
158057	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
158058	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
158059	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
158060	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
158061	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
158062	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
158063	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
158064	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
158065	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
158066	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
158067	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
158068	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
158069	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
158070	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
158071	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
158072	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
158073	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
158074	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116181	
158075	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
158076	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
158077	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
158078	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
158079	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
158080	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
158081	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
158082	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
158083	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
158084	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
158085	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
158086	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
158087	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
158088	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
158089	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
158090	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
158091	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
158092	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
158093	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
158094	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
158095	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
158096	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
158097	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	81920	
158098	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
158099	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
158100	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
158101	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158102	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
158103	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
158104	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
158105	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
158106	10/3/2019 10:19	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
158107	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
158108	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
158109	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	General Comments		
158110	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
158111	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
158112	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
158113	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
158114	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
158115	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
158116	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0	
158117	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
158118	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
158119	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
158120	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
158121	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
158122	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
158123	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
158124	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
158125	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
158126	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
158127	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load Y2 Max	60	%
158128	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load X2 Max	60	%
158129	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Present	67	°C
158130	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Max	67	°C
158131	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
158132	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.6	psi
158133	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
158134	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
158135	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Nitrogen bottle empty	
158136	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	General Comments		
158137	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
158138	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
158139	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
158140	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
158141	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
158142	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
158143	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
158144	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
158145	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments		
158146	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
158147	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
158148	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
158149	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
158150	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
158151	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
158152	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
158153	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
158154	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
158155	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
158156	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
158157	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
158158	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
158159	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
158160	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
158161	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
158162	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
158163	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
158164	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
158165	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
158166	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
158167	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
158168	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
158169	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
158170	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
158171	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
158172	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
158173	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
158174	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments		
158175	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
158176	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158177	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
158178	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
158179	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
158180	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments		
158181	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
158182	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
158183	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
158184	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
158185	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
158186	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
158187	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
158188	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
158189	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
158190	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
158191	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
158192	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
158193	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
158194	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
158195	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
158196	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
158197	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
158198	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
158199	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
158200	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
158201	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
158202	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
158203	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
158204	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
158205	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
158206	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
158207	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
158208	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
158209	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
158210	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
158211	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
158212	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
158213	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
158214	10/3/2019 9:40	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
158215	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	1	
158216	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158217	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158218	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158219	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	260.0	
158220	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	250.0	
158221	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	260.0	
158222	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158223	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	462695	
158224	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
158225	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
158226	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
158227	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
158228	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
158229	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
158230	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
158231	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
158232	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
158233	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
158234	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
158235	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
158236	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	1L	
158237	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	7L	
158238	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
158239	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
158240	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
158241	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
158242	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
158243	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	44188	
158244	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
158245	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
158246	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
158247	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
158248	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
158249	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
158250	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
158251	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158252	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
158253	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
158254	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	462695	
158255	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
158256	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
158257	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
158258	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
158259	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
158260	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
158261	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
158262	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
158263	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1215	
158264	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
158265	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
158266	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
158267	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
158268	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
158269	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
158270	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
158271	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	General Comments		
158272	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	y	
158273	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
158274	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
158275	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
158276	10/3/2019 13:58	Distribution	Robbins Quarterly Inspection	LTC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
158277	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
158278	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
158279	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
158280	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	466240	
158281	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	466240	
158282	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
158283	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
158284	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
158285	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments	LTC is off	
158286	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	
158287	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
158288	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
158289	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
158290	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
158291	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
158292	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
158293	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
158294	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
158295	10/3/2019 12:44	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
158296	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
158297	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
158298	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
158299	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
158300	10/3/2019 12:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
158301	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
158302	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
158303	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
158304	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
158305	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
158306	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
158307	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
158308	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
158309	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
158310	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
158311	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
158312	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
158313	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
158314	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
158315	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
158316	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
158317	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
158318	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
158319	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
158320	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
158321	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
158322	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
158323	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
158324	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
158325	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
158326	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158327	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
158328	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
158329	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
158330	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
158331	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	39.5	VDC
158332	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
158333	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments	13 volt neg ground	
158334	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
158335	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
158336	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
158337	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
158338	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
158339	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
158340	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
158341	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
158342	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
158343	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
158344	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
158345	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
158346	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
158347	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
158348	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
158349	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
158350	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
158351	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
158352	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
158353	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
158354	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
158355	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
158356	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
158357	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
158358	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
158359	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
158360	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
158361	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
158362	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
158363	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
158364	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
158365	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
158366	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
158367	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
158368	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
158369	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
158370	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
158371	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
158372	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	*C
158373	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	*C
158374	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	55	*C
158375	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	*C
158376	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	*C
158377	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	*C
158378	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
158379	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158380	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158381	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158382	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	0	
158383	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	0	
158384	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	0	
158385	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
158386	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
158387	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
158388	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
158389	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
158390	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
158391	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
158392	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
158393	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
158394	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
158395	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
158396	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
158397	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
158398	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
158399	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
158400	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
158401	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158402	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
158403	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
158404	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
158405	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
158406	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
158407	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
158408	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	132	
158409	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	132	
158410	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	0	
158411	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	
158412	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
158413	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
158414	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
158415	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
158416	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
158417	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
158418	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BCH001258	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	10.000	millivolts
158419	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
158420	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
158421	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
158422	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
158423	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
158424	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
158425	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
158426	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
158427	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
158428	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
158429	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
158430	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
158431	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	BAT001317	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
158432	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
158433	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
158434	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments		
158435	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments		
158436	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	44325	
158437	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	44325	
158438	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
158439	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	1R	
158440	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	4R	
158441	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	6L	
158442	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
158443	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	*C
158444	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	52	*C
158445	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	1840	
158446	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
158447	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
158448	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
158449	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
158450	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	58	*C
158451	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	*C
158452	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	60	*C
158453	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	74	*C
158454	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	60	*C
158455	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	*C
158456	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
158457	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
158458	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
158459	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations This Read AM	0	
158460	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	99996	
158461	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	99996	
158462	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
158463	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments		
158464	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
158465	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
158466	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158467	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158468	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
158469	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
158470	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
158471	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
158472	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
158473	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
158474	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
158475	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
158476	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158477	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
158478	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
158479	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
158480	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
158481	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
158482	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
158483	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
158484	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
158485	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
158486	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
158487	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
158488	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158489	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158490	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158491	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158492	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
158493	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
158494	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
158495	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158496	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158497	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158498	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
158499	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
158500	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
158501	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158502	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
158503	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
158504	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
158505	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
158506	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.16	%
158507	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
158508	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.16	%
158509	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	312.0	
158510	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
158511	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	255.0	
158512	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
158513	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
158514	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
158515	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
158516	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
158517	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
158518	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
158519	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
158520	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
158521	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
158522	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158523	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158524	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
158525	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
158526	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
158527	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
158528	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
158529	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	4	
158530	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
158531	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	4	
158532	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	291	
158533	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	291	
158534	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
158535	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
158536	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
158537	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
158538	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
158539	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
158540	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
158541	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
158542	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
158543	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
158544	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
158545	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
158546	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	0	
158547	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
158548	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
158549	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
158550	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158551	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158552	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158553	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158554	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
158555	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
158556	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
158557	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	60.0	
158558	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	60.0	
158559	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	100.0	
158560	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
158561	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
158562	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
158563	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	4	
158564	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
158565	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
158566	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
158567	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
158568	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
158569	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
158570	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
158571	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
158572	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0046	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
158573	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	0	
158574	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158575	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158576	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158577	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	359.0	
158578	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	377.0	
158579	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	432.0	
158580	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158581	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158582	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158583	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158584	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
158585	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
158586	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
158587	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
158588	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
158589	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
158590	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
158591	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
158592	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
158593	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	111	
158594	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	111	
158595	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
158596	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
158597	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
158598	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
158599	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158600	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158601	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158602	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158603	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	180.0	
158604	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	190.0	
158605	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	120.0	
158606	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158607	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158608	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158609	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	2	
158610	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	398	
158611	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
158612	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
158613	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
158614	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
158615	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	1	
158616	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	1	
158617	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	378	
158618	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	378	
158619	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
158620	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
158621	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
158622	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
158623	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
158624	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
158625	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
158626	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
158627	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
158628	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
158629	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158630	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158631	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158632	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158633	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	170.0	
158634	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	180.0	
158635	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
158636	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
158637	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
158638	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
158639	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
158640	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
158641	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2048	
158642	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2048	
158643	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
158644	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
158645	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
158646	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
158647	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
158648	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	General Comments		
158649	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
158650	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
158651	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
158652	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
158653	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
158654	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
158655	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
158656	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
158657	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158658	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158659	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
158660	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
158661	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
158662	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
158663	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	165.0	
158664	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
158665	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
158666	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	200.0	
158667	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158668	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158669	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
158670	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
158671	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
158672	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	General Comments	Actual Counter	
158673	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
158674	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
158675	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
158676	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
158677	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1334	
158678	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1334	
158679	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
158680	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
158681	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
158682	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
158683	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
158684	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
158685	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
158686	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
158687	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
158688	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
158689	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
158690	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	1	
158691	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	1	
158692	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	341	
158693	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	341	
158694	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
158695	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
158696	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
158697	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
158698	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
158699	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
158700	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
158701	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158702	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
158703	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
158704	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
158705	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
158706	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
158707	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
158708	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
158709	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
158710	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158711	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
158712	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158713	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158714	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
158715	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
158716	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
158717	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	322.0	
158718	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	297.0	
158719	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	319.0	
158720	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
158721	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
158722	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
158723	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	2	
158724	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
158725	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	398	
158726	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
158727	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
158728	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	0	
158729	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	798	
158730	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	798	
158731	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
158732	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments		
158733	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
158734	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
158735	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
158736	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
158737	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
158738	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
158739	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	0	
158740	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
158741	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
158742	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
158743	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
158744	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
158745	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
158746	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
158747	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
158748	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
158749	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0	
158750	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0	
158751	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0	
158752	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158753	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	0	
158754	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	0	
158755	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	0	
158756	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0	%
158757	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0	%
158758	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0	%
158759	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
158760	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
158761	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	0	
158762	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	16	
158763	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
158764	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
158765	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
158766	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	820	
158767	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	830	
158768	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	780	
158769	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158770	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
158771	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
158772	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
158773	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
158774	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
158775	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
158776	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158777	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
158778	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
158779	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
158780	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments	A, B and C targets	
158781	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
158782	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	332	
158783	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	332	
158784	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
158785	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
158786	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Unknown Operations	0	
158787	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	6	
158788	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158789	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158790	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
158791	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158792	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158793	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158794	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158795	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	390.0	
158796	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	360.0	
158797	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	350.0	
158798	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158799	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158800	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158801	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158802	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
158803	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
158804	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
158805	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
158806	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
158807	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
158808	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
158809	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments		
158810	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
158811	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
158812	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
158813	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
158814	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158815	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158816	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
158817	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
158818	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
158819	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
158820	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
158821	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
158822	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
158823	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
158824	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
158825	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
158826	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
158827	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
158828	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
158829	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
158830	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
158831	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	10	
158832	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
158833	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
158834	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
158835	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	55.0	
158836	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	60.0	
158837	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
158838	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	0	
158839	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	21	
158840	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	21	
158841	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
158842	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
158843	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
158844	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
158845	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
158846	10/3/2019 14:54	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
158847	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Unknown Operations	0	
158848	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	60.0	
158849	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
158850	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
158851	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158852	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158853	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158854	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
158855	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158856	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
158857	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
158858	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
158859	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
158860	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
158861	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
158862	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
158863	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
158864	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
158865	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
158866	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
158867	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
158868	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
158869	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
158870	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
158871	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
158872	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	644	
158873	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	644	
158874	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	4	
158875	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
158876	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	4	
158877	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
158878	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
158879	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	237	
158880	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	237	
158881	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
158882	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
158883	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158884	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158885	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158886	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
158887	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
158888	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
158889	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments		
158890	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
158891	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
158892	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
158893	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158894	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	460.0	
158895	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	480.0	
158896	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	470.0	
158897	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158898	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158899	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158900	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	0	
158901	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations This Read AM	0	
158902	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	1	
158903	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158904	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158905	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158906	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	50.0	
158907	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	50.0	
158908	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	50.0	
158909	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158910	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158911	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158912	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	25.0	
158913	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158914	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158915	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158916	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158917	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
158918	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
158919	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
158920	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
158921	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
158922	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
158923	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
158924	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
158925	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
158926	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	32	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
158927	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	32	
158928	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
158929	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
158930	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
158931	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158932	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
158933	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
158934	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
158935	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
158936	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
158937	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
158938	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
158939	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
158940	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
158941	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
158942	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	327	
158943	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	327	
158944	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	1	
158945	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	1	
158946	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
158947	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
158948	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
158949	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1154	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
158950	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
158951	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
158952	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	123	
158953	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	123	
158954	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	0	
158955	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
158956	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
158957	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
158958	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
158959	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
158960	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
158961	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
158962	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
158963	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
158964	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
158965	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
158966	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
158967	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
158968	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	7.6	
158969	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	1.1	
158970	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	2.0	
158971	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
158972	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
158973	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
158974	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
158975	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
158976	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
158977	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
158978	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
158979	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
158980	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
158981	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
158982	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
158983	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
158984	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
158985	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
158986	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
158987	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	0	
158988	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
158989	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
158990	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
158991	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	25.0	
158992	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	25.0	
158993	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
158994	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
158995	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
158996	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
158997	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
158998	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
158999	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
159000	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159001	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159002	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159003	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	72	
159004	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	72	
159005	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
159006	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159007	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
159008	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159009	10/3/2019 14:52	Distribution	Virginia City Distribution Quarterly Inspecti	DB0046	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
159010	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
159011	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
159012	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
159013	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	669	
159014	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	669	
159015	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
159016	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
159017	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
159018	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
159019	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
159020	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
159021	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
159022	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
159023	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
159024	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
159025	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
159026	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
159027	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
159028	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
159029	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159030	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159031	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
159032	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
159033	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
159034	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
159035	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
159036	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
159037	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
159038	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
159039	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159040	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
159041	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	160.0	
159042	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	120.0	
159043	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	225.0	
159044	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	
159045	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	
159046	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	
159047	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
159048	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
159049	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
159050	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
159051	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159052	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159053	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
159054	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159055	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1551	
159056	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1551	
159057	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
159058	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
159059	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159060	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
159061	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
159062	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
159063	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	0	
159064	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
159065	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
159066	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
159067	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
159068	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
159069	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
159070	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
159071	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159072	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159073	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
159074	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
159075	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
159076	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159077	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
159078	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	876	
159079	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	876	
159080	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
159081	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
159082	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159083	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
159084	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
159085	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
159086	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
159087	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159088	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159089	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159090	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159091	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159092	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159093	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159094	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
159095	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
159096	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
159097	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
159098	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159099	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159100	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159101	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
159102	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	1	
159103	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	1	
159104	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	297	
159105	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	297	
159106	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
159107	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	246	
159108	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	246	
159109	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	6	
159110	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159111	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	4	
159112	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
159113	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
159114	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
159115	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
159116	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
159117	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	618	
159118	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	618	
159119	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
159120	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
159121	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159122	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159123	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159124	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159125	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159126	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159127	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159128	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159129	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159130	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
159131	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	59.0	
159132	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	65.0	
159133	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
159134	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159135	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159136	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159137	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
159138	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
159139	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
159140	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
159141	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
159142	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
159143	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
159144	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
159145	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	1	
159146	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159147	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159148	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159149	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	100.0	
159150	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	120.0	
159151	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	110.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159152	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
159153	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159154	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159155	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159156	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
159157	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
159158	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
159159	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
159160	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
159161	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
159162	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
159163	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
159164	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
159165	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
159166	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
159167	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
159168	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	789	
159169	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	789	
159170	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159171	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159172	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159173	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	2	
159174	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
159175	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
159176	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
159177	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
159178	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
159179	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
159180	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159181	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
159182	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
159183	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations This Read AM	0	
159184	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	
159185	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
159186	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
159187	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
159188	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
159189	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C Ø	0	
159190	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B Ø	0	
159191	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A Ø	0	
159192	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0	
159193	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0	
159194	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0	
159195	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	1	
159196	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0	%
159197	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0	%
159198	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0	%
159199	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0	
159200	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159201	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0	
159202	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0	
159203	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
159204	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	954	
159205	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	954	
159206	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
159207	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
159208	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
159209	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
159210	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
159211	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
159212	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
159213	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
159214	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
159215	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
159216	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
159217	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
159218	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159219	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159220	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159221	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Unknown Operations	0	
159222	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	0	
159223	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	0	
159224	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	152	
159225	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	152	
159226	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159227	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	100.0	
159228	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	100.0	
159229	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	420.0	
159230	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
159231	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
159232	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
159233	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
159234	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
159235	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
159236	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159237	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159238	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159239	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
159240	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	190.0	
159241	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	200.0	
159242	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	220.0	
159243	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159244	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159245	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159246	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	6	
159247	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
159248	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
159249	10/3/2019 13:31	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
159250	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	0	
159251	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	0	
159252	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	0	
159253	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
159254	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
159255	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
159256	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
159257	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments		
159258	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
159259	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	295	
159260	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	295	
159261	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
159262	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
159263	10/3/2019 14:11	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
159264	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159265	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159266	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159267	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	7	
159268	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	1	
159269	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159270	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159271	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	9.88	
159272	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
159273	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
159274	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	523	
159275	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	523	
159276	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
159277	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
159278	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159279	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
159280	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
159281	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
159282	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
159283	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
159284	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
159285	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Months Operations	4	
159286	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
159287	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
159288	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	2	
159289	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
159290	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
159291	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
159292	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
159293	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
159294	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations C Ø	0	
159295	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations B Ø	0	
159296	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations A Ø	0	
159297	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159298	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
159299	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159300	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159301	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159302	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps C Ø	85.0	
159303	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps B Ø	57.0	
159304	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
159305	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
159306	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	4	
159307	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159308	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
159309	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
159310	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
159311	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
159312	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159313	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159314	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
159315	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159316	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1544	
159317	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1544	
159318	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
159319	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
159320	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159321	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
159322	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	6	
159323	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	636	
159324	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	636	
159325	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
159326	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
159327	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps A Ø	44.0	
159328	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159329	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159330	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159331	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	18	
159332	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159333	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159334	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159335	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159336	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	
159337	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
159338	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159339	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	13	
159340	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159341	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159342	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159343	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	1	
159344	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159345	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Unknown Operations	0	
159346	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Switching Operations	0	
159347	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations This Read AM	0	
159348	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AL	1432	
159349	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	60.0	
159350	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	65.0	
159351	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	58.0	
159352	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
159353	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159354	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159355	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159356	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AF	1432	
159357	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Maintenance Operations	0	
159358	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	General Comments		
159359	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	160.0	
159360	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	320.0	
159361	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
159362	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
159363	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
159364	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	330.0	
159365	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	335.0	
159366	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	400.0	
159367	10/3/2019 10:39	Distribution	Russell Springs Quarterly Inspection	CB0143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
159368	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159369	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
159370	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
159371	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
159372	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	75.0	
159373	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	70.0	
159374	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	70.0	
159375	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
159376	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159377	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159378	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159379	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159380	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159381	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159382	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159383	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159384	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	10.13	
159385	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
159386	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159387	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
159388	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	2	
159389	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
159390	10/3/2019 11:32	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159391	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations Ground	0	
159392	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
159393	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Follow-up Action Required?	n	
159394	10/4/2019 11:16	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
159395	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
159396	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
159397	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
159398	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
159399	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
159400	10/3/2019 10:16	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	160.0	
159401	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
159402	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
159403	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
159404	10/3/2019 13:58	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
159405	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
159406	10/3/2019 10:03	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
159407	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
159408	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
159409	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
159410	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
159411	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
159412	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	Follow-up Action Required?	n	
159413	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	General Comments		
159414	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	LTC Operation Checked?	y	
159415	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
159416	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	All Connections OK?	y	
159417	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
159418	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
159419	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	LTC0000828	LTCControl	863-1	LTC Control Insp	VRR Time Delay	30	Seconds
159420	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.2	VDC
159421	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
159422	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
159423	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
159424	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159425	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
159426	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159427	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
159428	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
159429	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	57.4	
159430	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	60.0	
159431	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	60.0	
159432	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159433	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159434	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Unknown Operations	0	
159435	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Tank Paint Condition	Good	
159436	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Switching Operations	0	
159437	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations This Read Vac	0	
159438	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AL	212	
159439	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AF	212	
159440	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Moisture and Leak Free?	y	
159441	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Maintenance Operations	0	
159442	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Grounds in Place?	y	
159443	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	General Comments		
159444	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	General Comments		
159445	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Foundation Condition	Good	
159446	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
159447	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
159448	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	General Comments		
159449	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
159450	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
159451	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC0000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159452	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
159453	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
159454	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
159455	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
159456	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.8652	
159457	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
159458	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Follow-up Action Required?	n	
159459	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Follow-up Action Required?	n	
159460	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations Ground	0	
159461	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations C Ø	0	
159462	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
159463	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
159464	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
159465	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
159466	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
159467	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
159468	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
159469	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
159470	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
159471	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
159472	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159473	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
159474	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
159475	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
159476	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	8305.92	kw
159477	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
159478	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
159479	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
159480	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
159481	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
159482	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
159483	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
159484	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
159485	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	50	°C
159486	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
159487	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	126432	
159488	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159489	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
159490	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
159491	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
159492	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
159493	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159494	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159495	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
159496	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
159497	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
159498	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
159499	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
159500	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
159501	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
159502	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
159503	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
159504	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
159505	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
159506	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	42	°C
159507	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
159508	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
159509	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
159510	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
159511	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
159512	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
159513	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
159514	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
159515	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
159516	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
159517	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
159518	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
159519	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
159520	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
159521	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
159522	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
159523	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
159524	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
159525	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments		
159526	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159527	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
159528	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments		
159529	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159530	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
159531	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
159532	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159533	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
159534	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159535	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159536	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159537	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159538	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
159539	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
159540	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
159541	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159542	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23392	
159543	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
159544	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
159545	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
159546	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
159547	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
159548	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159549	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	103217	
159550	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
159551	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
159552	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
159553	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159554	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159555	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	163	
159556	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
159557	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
159558	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
159559	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
159560	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
159561	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
159562	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
159563	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
159564	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	General Comments		
159565	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
159566	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
159567	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
159568	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
159569	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
159570	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
159571	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
159572	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
159573	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC0000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
159574	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments		
159575	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
159576	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
159577	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
159578	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
159579	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159580	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159581	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159582	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159583	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
159584	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159585	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
159586	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
159587	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
159588	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
159589	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
159590	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	87	*F
159591	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
159592	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159593	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159594	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
159595	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
159596	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
159597	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
159598	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159599	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159600	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1082	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
159601	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159602	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
159603	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
159604	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
159605	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
159606	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
159607	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	LTC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
159608	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1494	
159609	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1494	
159610	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159611	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
159612	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159613	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159614	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
159615	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
159616	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
159617	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
159618	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
159619	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
159620	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
159621	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
159622	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
159623	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations B Ø	0	
159624	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations A Ø	0	
159625	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159626	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159627	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159628	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159629	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
159630	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
159631	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
159632	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
159633	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159634	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159635	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159636	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159637	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
159638	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
159639	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159640	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
159641	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159642	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159643	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159644	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159645	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
159646	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
159647	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
159648	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
159649	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
159650	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
159651	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159652	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159653	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
159654	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
159655	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
159656	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	13440	
159657	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159658	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159659	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159660	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
159661	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
159662	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	230.0	
159663	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
159664	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159665	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159666	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159667	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159668	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
159669	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159670	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	6	
159671	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159672	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159673	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159674	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159675	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	90.0	
159676	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	110.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159677	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	70.0	
159678	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
159679	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159680	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159681	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159682	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159683	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159684	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159685	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159686	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159687	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159688	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
159689	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
159690	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
159691	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	6	
159692	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
159693	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
159694	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
159695	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
159696	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
159697	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
159698	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
159699	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	136210	
159700	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	136220	
159701	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
159702	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	7L	
159703	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	3L	
159704	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	11L	
159705	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
159706	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	543	
159707	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
159708	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
159709	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
159710	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
159711	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
159712	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
159713	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
159714	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	188	
159715	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	188	
159716	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
159717	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159718	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159719	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159720	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159721	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159722	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159723	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
159724	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
159725	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
159726	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159727	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159728	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159729	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159730	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0237	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159731	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
159732	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
159733	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159734	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
159735	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
159736	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
159737	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
159738	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
159739	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
159740	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
159741	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
159742	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
159743	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
159744	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
159745	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
159746	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence 5' Clearance To Trees?	y	
159747	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
159748	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
159749	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
159750	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
159751	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159752	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
159753	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
159754	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
159755	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
159756	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
159757	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
159758	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	23.0	
159759	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
159760	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
159761	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
159762	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
159763	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
159764	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
159765	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
159766	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
159767	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
159768	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
159769	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
159770	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
159771	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
159772	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
159773	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
159774	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
159775	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
159776	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
159777	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
159778	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments		
159779	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	595.0	
159780	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	520.0	
159781	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159782	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159783	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
159784	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
159785	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	0	
159786	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159787	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations This Read Vac	0	
159788	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	111	
159789	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	111	
159790	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
159791	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	0	
159792	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159793	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
159794	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments		
159795	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments		
159796	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
159797	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
159798	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
159799	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
159800	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
159801	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
159802	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
159803	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159804	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159805	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159806	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159807	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159808	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159809	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159810	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159811	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159812	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	1	
159813	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159814	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
159815	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
159816	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
159817	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	2	
159818	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159819	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
159820	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159821	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	100.0	
159822	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	100.0	
159823	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	105.0	
159824	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
159825	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
159826	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
159827	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
159828	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
159829	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
159830	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
159831	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
159832	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
159833	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
159834	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments		
159835	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
159836	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
159837	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
159838	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
159839	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
159840	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
159841	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
159842	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
159843	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
159844	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
159845	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
159846	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	208	
159847	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	208	
159848	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	9	
159849	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
159850	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
159851	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
159852	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
159853	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
159854	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
159855	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
159856	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
159857	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
159858	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159859	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
159860	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159861	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159862	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159863	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159864	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159865	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159866	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159867	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
159868	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	520.0	
159869	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
159870	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
159871	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
159872	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
159873	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	1R	
159874	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
159875	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
159876	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
159877	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
159878	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
159879	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	60908	
159880	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159881	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
159882	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
159883	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
159884	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
159885	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
159886	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
159887	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
159888	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
159889	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
159890	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
159891	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159892	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159893	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159894	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159895	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
159896	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
159897	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
159898	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
159899	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
159900	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
159901	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159902	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
159903	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
159904	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
159905	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
159906	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	550.56	kw
159907	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
159908	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
159909	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
159910	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
159911	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
159912	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
159913	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
159914	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	45	°C
159915	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	42	°C
159916	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
159917	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
159918	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
159919	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
159920	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
159921	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29083	
159922	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
159923	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
159924	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
159925	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
159926	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
159927	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
159928	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
159929	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
159930	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6R	
159931	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159932	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
159933	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159934	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
159935	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
159936	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
159937	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
159938	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
159939	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
159940	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	92	°F
159941	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
159942	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
159943	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
159944	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
159945	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	682	
159946	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
159947	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
159948	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
159949	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
159950	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
159951	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
159952	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
159953	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
159954	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
159955	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
159956	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6882	
159957	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
159958	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
159959	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
159960	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	General Comments		
159961	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
159962	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	All Connections OK?	y	
159963	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
159964	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
159965	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
159966	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
159967	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
159968	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
159969	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
159970	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
159971	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
159972	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
159973	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
159974	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
159975	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
159976	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
159977	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
159978	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
159979	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
159980	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
159981	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
159982	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	93	*F
159983	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
159984	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
159985	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
159986	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
159987	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
159988	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
159989	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
159990	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
159991	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
159992	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
159993	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
159994	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
159995	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
159996	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	15.59	
159997	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
159998	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
159999	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	3	
160000	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
160001	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
160002	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
160003	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
160004	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
160005	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
160006	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
160007	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
160008	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
160009	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
160010	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
160011	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
160012	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
160013	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
160014	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
160015	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
160016	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
160017	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
160018	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
160019	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
160020	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
160021	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Follow-up Action Required?	n	
160022	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
160023	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
160024	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
160025	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
160026	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
160027	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	1699.20	kw
160028	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
160029	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
160030	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Max	43	*C
160031	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Present	43	*C
160032	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
160033	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
160034	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
160035	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
160036	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
160037	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
160038	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
160039	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
160040	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Reading	.1770	
160041	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
160042	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
160043	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
160044	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
160045	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0264	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160046	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
160047	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
160048	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	LTC000705	LTCControl	060-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
160049	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
160050	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160051	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160052	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
160053	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
160054	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
160055	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
160056	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
160057	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
160058	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
160059	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
160060	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160061	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160062	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
160063	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
160064	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
160065	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160066	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160067	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	22873	
160068	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
160069	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
160070	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
160071	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160072	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160073	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	11L	
160074	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
160075	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
160076	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments		
160077	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160078	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
160079	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
160080	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160081	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
160082	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160083	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160084	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160085	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160086	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
160087	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	217	
160088	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	217	
160089	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	0	
160090	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	0	
160091	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
160092	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
160093	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160094	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	
160095	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160096	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160097	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11369	
160098	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
160099	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160100	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
160101	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160102	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160103	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
160104	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
160105	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
160106	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments		
160107	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160108	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
160109	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160110	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160111	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
160112	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160113	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160114	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160115	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160116	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160117	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
160118	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160119	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160120	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160121	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160122	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
160123	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
160124	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
160125	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
160126	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160127	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
160128	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
160129	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
160130	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
160131	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
160132	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
160133	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
160134	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
160135	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
160136	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
160137	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
160138	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
160139	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
160140	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
160141	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
160142	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
160143	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
160144	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
160145	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
160146	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
160147	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
160148	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
160149	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
160150	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
160151	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
160152	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
160153	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
160154	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
160155	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	107	
160156	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
160157	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
160158	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
160159	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
160160	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
160161	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
160162	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
160163	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	0	
160164	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
160165	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
160166	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
160167	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
160168	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
160169	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
160170	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
160171	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
160172	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0228	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.7	
160173	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
160174	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
160175	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
160176	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
160177	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160178	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160179	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
160180	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments		
160181	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
160182	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
160183	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160184	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
160185	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
160186	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
160187	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
160188	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
160189	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
160190	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
160191	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
160192	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
160193	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
160194	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
160195	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
160196	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
160197	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
160198	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
160199	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
160200	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
160201	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160202	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
160203	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
160204	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
160205	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
160206	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
160207	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
160208	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
160209	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
160210	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
160211	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
160212	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
160213	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
160214	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
160215	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
160216	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
160217	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
160218	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
160219	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
160220	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
160221	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
160222	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
160223	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
160224	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
160225	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
160226	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
160227	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
160228	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
160229	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
160230	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
160231	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
160232	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
160233	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
160234	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
160235	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
160236	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
160237	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
160238	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
160239	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
160240	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
160241	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
160242	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
160243	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
160244	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
160245	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
160246	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
160247	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
160248	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
160249	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
160250	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
160251	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
160252	10/2/2019 11:23	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
160253	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
160254	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160255	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160256	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160257	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160258	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	5R	
160259	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160260	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
160261	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
160262	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
160263	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160264	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26544	
160265	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
160266	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
160267	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
160268	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160269	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160270	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
160271	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
160272	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
160273	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments		
160274	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160275	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
160276	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160277	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160278	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
160279	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160280	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160281	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160282	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160283	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
160284	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160285	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
160286	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
160287	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160288	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160289	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160290	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
160291	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
160292	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
160293	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160294	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160295	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
160296	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160297	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160298	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160299	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160300	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
160301	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
160302	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160303	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments		
160304	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
160305	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
160306	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
160307	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160308	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160309	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
160310	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
160311	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	6	
160312	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160313	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160314	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160315	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	
160316	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
160317	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
160318	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
160319	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
160320	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
160321	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
160322	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
160323	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160324	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160325	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160326	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
160327	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
160328	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
160329	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
160330	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
160331	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
160332	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
160333	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
160334	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	General Comments		
160335	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
160336	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
160337	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
160338	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
160339	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
160340	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2308	
160341	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2308	
160342	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
160343	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
160344	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
160345	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
160346	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
160347	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
160348	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
160349	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
160350	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
160351	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160352	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
160353	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
160354	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
160355	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
160356	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
160357	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
160358	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
160359	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	830	
160360	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
160361	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
160362	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	1R	
160363	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
160364	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	20909	
160365	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	20900	
160366	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
160367	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
160368	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
160369	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
160370	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
160371	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments	OIL SEEP ON TOP VALVE ON TRANSFORMER	
160372	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
160373	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
160374	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
160375	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
160376	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
160377	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
160378	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
160379	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
160380	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160381	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
160382	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160383	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160384	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
160385	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160386	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments		
160387	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
160388	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
160389	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
160390	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
160391	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
160392	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
160393	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
160394	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
160395	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
160396	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	675	
160397	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	675	
160398	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	0	
160399	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	0	
160400	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
160401	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
160402	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
160403	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
160404	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
160405	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	0	
160406	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	258	
160407	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	258	
160408	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
160409	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	0	
160410	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
160411	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
160412	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments		
160413	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
160414	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
160415	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
160416	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
160417	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
160418	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
160419	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
160420	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
160421	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
160422	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
160423	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
160424	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
160425	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
160426	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160427	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
160428	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
160429	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
160430	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
160431	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	120.0	
160432	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	120.0	
160433	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	180.0	
160434	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160435	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160436	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160437	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	2	
160438	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
160439	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
160440	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
160441	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	PF001214	PowerFuse	060-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
160442	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
160443	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
160444	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
160445	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	PF001213	PowerFuse	060-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
160446	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	1490	
160447	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	*C
160448	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	10L	
160449	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	3R	
160450	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	2L	
160451	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
160452	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	36840	
160453	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	36840	
160454	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
160455	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
160456	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
160457	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
160458	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
160459	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
160460	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
160461	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
160462	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
160463	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
160464	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
160465	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
160466	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
160467	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
160468	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
160469	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	70	
160470	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
160471	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
160472	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
160473	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	5	
160474	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160475	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160476	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160477	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	120.0	
160478	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	120.0	
160479	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	120.0	
160480	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
160481	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
160482	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
160483	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
160484	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
160485	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
160486	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160487	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	43064	
160488	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
160489	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
160490	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
160491	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160492	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160493	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
160494	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
160495	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
160496	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
160497	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160498	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
160499	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
160500	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160501	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160502	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160503	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160504	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160505	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160506	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0682	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
160507	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
160508	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Leaks	None	
160509	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160510	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160511	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Regulator As Left Counter	109536	
160512	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
160513	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
160514	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
160515	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160516	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160517	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
160518	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
160519	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
160520	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	General Comments		
160521	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160522	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
160523	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
160524	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
160525	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
160526	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160527	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160528	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
160529	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160530	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
160531	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	26302	
160532	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160533	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
160534	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160535	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
160536	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160537	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160538	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160539	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160540	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
160541	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160542	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
160543	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
160544	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160545	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments		
160546	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
160547	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
160548	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
160549	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160550	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160551	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
160552	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
160553	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
160554	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27128	
160555	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
160556	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
160557	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
160558	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
160559	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
160560	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	497	
160561	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
160562	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
160563	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
160564	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
160565	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
160566	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	2507	
160567	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	2495	
160568	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
160569	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
160570	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
160571	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
160572	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
160573	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
160574	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
160575	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
160576	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	1223	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160577	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
160578	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	5L	
160579	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	10R	
160580	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	3R	
160581	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
160582	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	192401	
160583	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	192401	
160584	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
160585	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
160586	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
160587	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
160588	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
160589	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	XX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
160590	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	XX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
160591	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	XX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
160592	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
160593	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
160594	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments		
160595	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments		
160596	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160597	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160598	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160599	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	6L	
160600	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160601	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160602	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
160603	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
160604	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
160605	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
160606	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2998.08	kw
160607	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
160608	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
160609	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
160610	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
160611	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
160612	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
160613	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
160614	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
160615	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
160616	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
160617	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
160618	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
160619	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
160620	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
160621	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8328	
160622	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
160623	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
160624	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
160625	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160626	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments		
160627	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
160628	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
160629	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
160630	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
160631	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
160632	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
160633	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
160634	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
160635	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	7	
160636	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160637	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160638	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160639	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	160.0	
160640	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	175.0	
160641	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	160.0	
160642	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
160643	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
160644	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
160645	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
160646	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
160647	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
160648	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
160649	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
160650	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
160651	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160652	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
160653	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
160654	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
160655	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
160656	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
160657	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
160658	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
160659	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps A Ø	130.0	
160660	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160661	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160662	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160663	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations	9	
160664	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
160665	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160666	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160667	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160668	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160669	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	9R	
160670	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160671	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160672	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160673	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments	Drag hands won't reset and counter does not work.	
160674	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
160675	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160676	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160677	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160678	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
160679	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
160680	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
160681	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160682	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
160683	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
160684	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	General Comments		
160685	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	y	
160686	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
160687	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
160688	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
160689	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	LTC0000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
160690	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
160691	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
160692	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
160693	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
160694	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
160695	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
160696	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
160697	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
160698	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
160699	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
160700	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
160701	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
160702	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
160703	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
160704	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
160705	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
160706	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
160707	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
160708	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
160709	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
160710	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
160711	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
160712	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160713	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
160714	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
160715	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
160716	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
160717	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
160718	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
160719	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
160720	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
160721	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
160722	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
160723	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
160724	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
160725	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
160726	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
160727	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
160728	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160729	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
160730	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160731	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160732	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160733	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160734	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
160735	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160736	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160737	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
160738	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
160739	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
160740	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	26126	
160741	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160742	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160743	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
160744	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
160745	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
160746	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
160747	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
160748	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
160749	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
160750	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
160751	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
160752	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
160753	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
160754	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
160755	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
160756	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
160757	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
160758	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
160759	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
160760	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
160761	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	General Comments		
160762	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
160763	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	LTC000395	LTCControl	587-1	LTC Control Insp	All Connections OK?	y	
160764	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
160765	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
160766	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
160767	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
160768	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
160769	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
160770	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
160771	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
160772	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
160773	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
160774	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
160775	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
160776	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
160777	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
160778	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments		
160779	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
160780	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
160781	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
160782	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
160783	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
160784	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
160785	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
160786	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
160787	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
160788	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	87	*F
160789	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
160790	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	45.0	
160791	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
160792	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
160793	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
160794	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0164	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
160795	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
160796	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
160797	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
160798	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
160799	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
160800	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
160801	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160802	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
160803	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	180	
160804	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	181	
160805	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	1	
160806	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
160807	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	1	
160808	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
160809	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
160810	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
160811	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160812	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160813	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
160814	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160815	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
160816	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	22994	
160817	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160818	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160819	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Leaks	None	
160820	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160821	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
160822	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
160823	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
160824	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
160825	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
160826	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
160827	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
160828	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
160829	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
160830	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
160831	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
160832	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
160833	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
160834	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
160835	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
160836	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
160837	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
160838	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
160839	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
160840	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
160841	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
160842	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160843	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments		
160844	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
160845	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
160846	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
160847	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
160848	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
160849	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
160850	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160851	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115692	
160852	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
160853	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
160854	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
160855	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
160856	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
160857	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
160858	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
160859	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
160860	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments		
160861	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
160862	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
160863	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
160864	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
160865	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
160866	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
160867	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
160868	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	57	
160869	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
160870	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
160871	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
160872	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
160873	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
160874	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	4	
160875	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
160876	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations This Read Vac	4	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160877	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	286	
160878	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	286	
160879	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
160880	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
160881	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
160882	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
160883	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	washout starting in back corner	
160884	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
160885	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
160886	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
160887	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
160888	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
160889	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
160890	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
160891	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
160892	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
160893	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
160894	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
160895	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
160896	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
160897	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
160898	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
160899	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
160900	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
160901	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
160902	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
160903	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
160904	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
160905	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations	9	
160906	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
160907	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
160908	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
160909	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
160910	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
160911	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
160912	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
160913	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
160914	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
160915	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
160916	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
160917	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
160918	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps A Ø	110.0	
160919	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps B Ø	60.0	
160920	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps C Ø	115.0	
160921	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushing Condition	Good	
160922	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
160923	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
160924	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
160925	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
160926	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
160927	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
160928	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
160929	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
160930	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
160931	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
160932	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
160933	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
160934	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
160935	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
160936	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
160937	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
160938	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
160939	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	93	*F
160940	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
160941	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
160942	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	0	
160943	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
160944	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	204	
160945	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	204	
160946	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	2	
160947	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
160948	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
160949	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
160950	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
160951	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
160952	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
160953	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
160954	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
160955	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
160956	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
160957	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
160958	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
160959	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
160960	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	2	
160961	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
160962	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
160963	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
160964	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	477018	
160965	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
160966	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
160967	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
160968	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
160969	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
160970	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	
160971	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
160972	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
160973	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
160974	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
160975	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
160976	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
160977	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
160978	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
160979	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
160980	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
160981	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments		
160982	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
160983	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
160984	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	4	
160985	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
160986	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
160987	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
160988	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
160989	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	41.0	
160990	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
160991	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
160992	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
160993	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
160994	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
160995	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
160996	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
160997	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
160998	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
160999	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
161000	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
161001	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
161002	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
161003	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
161004	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
161005	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
161006	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
161007	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
161008	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
161009	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
161010	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
161011	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
161012	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
161013	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
161014	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
161015	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
161016	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
161017	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
161018	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
161019	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
161020	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161021	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161022	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161023	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161024	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23705	
161025	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
161026	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161027	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161028	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161029	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161030	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
161031	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
161032	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161033	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	General Comments		
161034	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161035	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161036	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161037	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161038	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
161039	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161040	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161041	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161042	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161043	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161044	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161045	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
161046	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
161047	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
161048	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
161049	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
161050	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Follow-up Action Required?	n	
161051	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations Ground	0	
161052	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations C Ø	0	
161053	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations B Ø	0	
161054	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations A Ø	0	
161055	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161056	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161057	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161058	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161059	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161060	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161061	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161062	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161063	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161064	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushing Condition	Good	
161065	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps C Ø	118.0	
161066	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps B Ø	121.0	
161067	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations A Ø	0	
161068	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations B Ø	0	
161069	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations C Ø	0	
161070	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
161071	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
161072	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
161073	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
161074	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
161075	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
161076	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
161077	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161078	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	
161079	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
161080	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	242	
161081	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	242	
161082	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations This Read Vac	4	
161083	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161084	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	4	
161085	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
161086	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
161087	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
161088	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
161089	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
161090	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
161091	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
161092	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
161093	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
161094	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
161095	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
161096	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
161097	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
161098	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
161099	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	General Comments		
161100	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
161101	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161102	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
161103	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161104	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161105	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161106	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161107	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161108	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161109	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Follow-up Action Required?	n	
161110	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Foundation Condition	Good	
161111	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	General Comments		
161112	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Grounds in Place?	y	
161113	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161114	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Moisture and Leak Free?	y	
161115	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161116	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
161117	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
161118	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
161119	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
161120	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
161121	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
161122	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
161123	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
161124	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
161125	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
161126	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
161127	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
161128	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
161129	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
161130	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
161131	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
161132	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
161133	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
161134	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
161135	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
161136	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
161137	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments		
161138	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161139	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
161140	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
161141	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161142	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
161143	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161144	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161145	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161146	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161147	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
161148	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
161149	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
161150	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
161151	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
161152	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
161153	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
161154	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
161155	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
161156	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
161157	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
161158	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
161159	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
161160	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
161161	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
161162	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
161163	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
161164	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
161165	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
161166	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161167	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161168	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161169	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
161170	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161171	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161172	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161173	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161174	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	General Comments		
161175	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161176	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161177	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
161178	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161179	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161180	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	13	
161181	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161182	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161183	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161184	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	60.0	
161185	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	60.0	
161186	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	60.0	
161187	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
161188	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161189	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161190	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161191	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161192	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161193	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161194	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	6.31	
161195	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
161196	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
161197	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	6.31	
161198	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	6.31	
161199	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
161200	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
161201	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
161202	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	2	
161203	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
161204	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
161205	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments	drag hand resets slowly	
161206	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161207	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
161208	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
161209	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161210	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	4R	
161211	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161212	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161213	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161214	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161215	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
161216	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161217	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161218	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161219	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161220	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	68429	
161221	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
161222	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
161223	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161224	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161225	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161226	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
161227	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
161228	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161229	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
161230	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161231	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161232	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161233	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161234	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
161235	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161236	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161237	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161238	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161239	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161240	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
161241	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
161242	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
161243	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
161244	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
161245	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
161246	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
161247	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
161248	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
161249	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
161250	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments		
161251	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
161252	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
161253	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
161254	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
161255	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
161256	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
161257	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
161258	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
161259	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
161260	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
161261	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
161262	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
161263	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
161264	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
161265	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161266	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161267	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26334	
161268	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
161269	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
161270	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
161271	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161272	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161273	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
161274	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	0	
161275	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161276	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161277	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161278	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161279	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161280	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161281	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161282	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161283	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	3	
161284	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161285	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161286	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161287	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	53.0	
161288	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	60.0	
161289	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	67.0	
161290	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
161291	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161292	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161293	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161294	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161295	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161296	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161297	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161298	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161299	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161300	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
161301	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
161302	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
161303	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
161304	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
161305	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
161306	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
161307	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
161308	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
161309	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
161310	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
161311	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
161312	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
161313	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
161314	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
161315	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments		
161316	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments		
161317	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
161318	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161319	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	0	
161320	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
161321	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	194	
161322	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	194	
161323	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	0	
161324	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161325	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
161326	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161327	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
161328	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
161329	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
161330	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
161331	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
161332	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
161333	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
161334	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2245	
161335	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2245	
161336	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
161337	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
161338	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
161339	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
161340	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
161341	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	General Comments		
161342	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
161343	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
161344	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
161345	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
161346	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
161347	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
161348	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161349	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
161350	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
161351	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	306	
161352	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	306	
161353	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Operations This Read Vac	6	
161354	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	4	
161355	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
161356	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
161357	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161358	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
161359	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
161360	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42629	
161361	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161362	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161363	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161364	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161365	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
161366	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
161367	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
161368	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161369	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	0	
161370	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	268	
161371	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	268	
161372	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161373	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161374	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
161375	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
161376	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
161377	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161378	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161379	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2R	
161380	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
161381	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
161382	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	
161383	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
161384	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.9	VAC
161385	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
161386	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
161387	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
161388	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	LTC000107	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
161389	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
161390	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	Found in manual.	
161391	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161392	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
161393	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
161394	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161395	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
161396	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161397	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161398	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161399	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161400	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
161401	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161402	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	0	
161403	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161404	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
161405	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
161406	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
161407	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
161408	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
161409	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
161410	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
161411	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
161412	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
161413	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161414	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	7R	
161415	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161416	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161417	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161418	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161419	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
161420	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161421	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
161422	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
161423	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161424	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161425	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161426	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
161427	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
161428	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43149	
161429	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161430	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161431	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161432	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
161433	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
161434	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
161435	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments		
161436	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	98046	
161437	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	98046	
161438	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
161439	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	2R	
161440	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	4R	
161441	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	8L	
161442	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161443	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161444	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161445	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62556	
161446	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
161447	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
161448	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161449	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161450	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161451	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
161452	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
161453	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161454	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments	ok	
161455	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161456	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161457	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161458	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161459	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
161460	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161461	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161462	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161463	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161464	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161465	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
161466	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
161467	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161468	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	112121	
161469	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
161470	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
161471	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
161472	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161473	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161474	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
161475	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
161476	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161477	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments	ok	
161478	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161479	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
161480	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	1471	
161481	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
161482	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
161483	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
161484	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
161485	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
161486	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments		
161487	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
161488	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	291	
161489	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
161490	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
161491	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
161492	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161493	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161494	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161495	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161496	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
161497	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161498	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
161499	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
161500	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
161501	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
161502	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
161503	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
161504	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
161505	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
161506	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
161507	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
161508	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
161509	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
161510	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
161511	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161512	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments		
161513	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
161514	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
161515	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
161516	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161517	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161518	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
161519	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
161520	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
161521	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35221	
161522	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
161523	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	
161524	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
161525	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161526	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161527	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161528	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161529	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161530	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
161531	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161532	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
161533	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
161534	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161535	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments	ok	
161536	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
161537	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
161538	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
161539	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161540	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161541	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
161542	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
161543	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
161544	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19853	
161545	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161546	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
161547	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
161548	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161549	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161550	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161551	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161552	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161553	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22040	
161554	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161555	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161556	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	
161557	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
161558	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
161559	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
161560	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
161561	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161562	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161563	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
161564	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
161565	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
161566	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47337	
161567	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161568	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161569	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
161570	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
161571	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
161572	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
161573	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
161574	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
161575	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
161576	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
161577	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
161578	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments		
161579	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
161580	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Maintenance Operations	0	
161581	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
161582	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AF	332	
161583	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AL	332	
161584	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations This Read Vac	0	
161585	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161586	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Switching Operations	0	
161587	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161588	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
161589	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
161590	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
161591	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
161592	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
161593	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161594	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161595	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
161596	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
161597	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
161598	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	General Comments		
161599	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161600	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
161601	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
161602	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161603	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
161604	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161605	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161606	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161607	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161608	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
161609	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Unknown Operations	0	
161610	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
161611	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
161612	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
161613	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161614	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161615	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	58170	
161616	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
161617	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
161618	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161619	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161620	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
161621	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
161622	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
161623	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
161624	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
161625	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161626	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161627	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161628	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
161629	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
161630	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
161631	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
161632	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
161633	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
161634	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
161635	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
161636	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
161637	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
161638	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
161639	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
161640	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments	ok	
161641	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
161642	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
161643	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
161644	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
161645	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
161646	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
161647	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
161648	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
161649	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
161650	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
161651	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	
161652	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
161653	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments	ok	
161654	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
161655	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
161656	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
161657	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
161658	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
161659	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161660	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
161661	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161662	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
161663	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
161664	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161665	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
161666	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations	15	
161667	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161668	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161669	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161670	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps A Ø	0.0	
161671	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps B Ø	0.0	
161672	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps C Ø	0.0	
161673	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
161674	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161675	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161676	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161677	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161678	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161679	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161680	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161681	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
161682	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
161683	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161684	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
161685	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161686	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161687	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161688	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161689	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
161690	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
161691	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Leaks	None	
161692	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
161693	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	267.84	kw
161694	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
161695	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
161696	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
161697	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
161698	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
161699	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
161700	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
161701	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
161702	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
161703	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
161704	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
161705	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
161706	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
161707	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
161708	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
161709	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
161710	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
161711	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	0	
161712	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161713	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations This Read Vac	0	
161714	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	443	
161715	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	443	
161716	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
161717	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
161718	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
161719	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments		
161720	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
161721	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	
161722	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
161723	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
161724	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
161725	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	0	
161726	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	0	
161727	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
161728	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161729	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161730	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161731	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161732	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161733	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161734	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161735	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161736	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161737	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
161738	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	20.0	
161739	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	20.0	
161740	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	20.0	
161741	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161742	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161743	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161744	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	16	
161745	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
161746	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
161747	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161748	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161749	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	187176	
161750	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
161751	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
161752	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
161753	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161754	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161755	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
161756	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
161757	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
161758	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
161759	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161760	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
161761	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
161762	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
161763	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
161764	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
161765	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
161766	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
161767	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
161768	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
161769	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
161770	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
161771	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments	ok	
161772	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
161773	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
161774	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
161775	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
161776	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161777	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
161778	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
161779	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
161780	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
161781	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
161782	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
161783	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
161784	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments	ok	
161785	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
161786	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
161787	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
161788	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
161789	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
161790	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
161791	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
161792	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
161793	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
161794	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
161795	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
161796	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
161797	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161798	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
161799	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161800	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
161801	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
161802	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
161803	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
161804	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
161805	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
161806	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
161807	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
161808	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
161809	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161810	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
161811	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
161812	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
161813	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
161814	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	272512	
161815	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
161816	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
161817	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
161818	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
161819	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.8928	
161820	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
161821	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
161822	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
161823	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
161824	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
161825	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
161826	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
161827	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
161828	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
161829	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
161830	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
161831	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161832	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161833	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161834	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161835	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161836	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161837	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161838	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161839	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
161840	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
161841	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
161842	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
161843	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
161844	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
161845	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
161846	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
161847	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
161848	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
161849	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161850	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	0	
161851	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
161852	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	269	
161853	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	269	
161854	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations This Read Vac	4	
161855	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161856	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	4	
161857	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
161858	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
161859	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161860	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
161861	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	0	
161862	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
161863	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
161864	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
161865	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
161866	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
161867	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments	ok	
161868	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments	ok	
161869	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
161870	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161871	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	0	
161872	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
161873	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	180	
161874	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	180	
161875	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations This Read Vac	0	
161876	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161877	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
161878	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
161879	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	0	
161880	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
161881	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
161882	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps C Ø	46.0	
161883	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
161884	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
161885	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
161886	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
161887	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
161888	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
161889	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
161890	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
161891	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
161892	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
161893	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments	Someone reset the trip counter. Initials are DTR .	
161894	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
161895	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
161896	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	0	
161897	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
161898	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
161899	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
161900	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
161901	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
161902	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
161903	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
161904	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
161905	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
161906	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	10	
161907	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
161908	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
161909	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	2	
161910	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161911	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161912	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161913	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	77.0	
161914	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	52.0	
161915	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	79.0	
161916	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
161917	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161918	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161919	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161920	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161921	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161922	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161923	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161924	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161925	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161926	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
161927	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	0	
161928	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	0	
161929	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
161930	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
161931	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
161932	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
161933	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments	ok	
161934	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments	ok	
161935	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161936	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161937	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161938	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	480.0	
161939	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	480.0	
161940	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	480.0	
161941	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
161942	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
161943	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
161944	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
161945	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
161946	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
161947	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
161948	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
161949	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
161950	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
161951	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
161952	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
161953	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	0	
161954	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
161955	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	204	
161956	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	204	
161957	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations This Read Vac	0	
161958	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
161959	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
161960	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
161961	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	0	
161962	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	4	
161963	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
161964	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
161965	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
161966	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	47.0	
161967	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	49.0	
161968	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	30.0	
161969	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
161970	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
161971	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
161972	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
161973	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
161974	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
161975	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
161976	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
161977	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
161978	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
161979	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
161980	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
161981	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
161982	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
161983	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
161984	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
161985	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
161986	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
161987	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
161988	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
161989	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments	OK	
161990	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
161991	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
161992	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
161993	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
161994	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
161995	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
161996	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
161997	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
161998	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
161999	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
162000	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments	ok	
162001	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162002	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
162003	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
162004	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
162005	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
162006	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
162007	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
162008	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
162009	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
162010	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162011	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
162012	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
162013	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
162014	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
162015	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
162016	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
162017	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
162018	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
162019	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
162020	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
162021	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162022	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162023	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162024	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162025	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162026	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162027	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162028	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162029	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162030	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
162031	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	50.0	
162032	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	65.0	
162033	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	55.0	
162034	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162035	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162036	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162037	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	4	
162038	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
162039	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
162040	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
162041	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
162042	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
162043	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
162044	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
162045	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
162046	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162047	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162048	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
162049	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
162050	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
162051	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
162052	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
162053	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	85.0	
162054	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0091	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
162055	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162056	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
162057	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	120.0	
162058	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	120.0	
162059	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	120.0	
162060	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162061	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162062	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162063	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	2	
162064	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
162065	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
162066	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	1	
162067	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	1	
162068	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	233	
162069	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	233	
162070	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
162071	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
162072	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
162073	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
162074	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
162075	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
162076	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162077	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
162078	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
162079	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
162080	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
162081	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
162082	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
162083	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
162084	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
162085	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
162086	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
162087	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
162088	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
162089	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
162090	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
162091	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
162092	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
162093	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments		
162094	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
162095	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
162096	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
162097	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
162098	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
162099	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
162100	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
162101	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
162102	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
162103	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
162104	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
162105	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
162106	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
162107	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
162108	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
162109	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
162110	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
162111	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	6	
162112	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162113	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162114	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162115	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	400.0	
162116	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	400.0	
162117	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	400.0	
162118	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
162119	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162120	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162121	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162122	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162123	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162124	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162125	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162126	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162127	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162128	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	0	
162129	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
162130	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
162131	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
162132	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
162133	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
162134	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
162135	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
162136	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
162137	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
162138	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162139	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
162140	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162141	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162142	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162143	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
162144	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
162145	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	204	
162146	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	204	
162147	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	0	
162148	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	0	
162149	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
162150	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
162151	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162152	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162153	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162154	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162155	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162156	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
162157	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162158	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
162159	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
162160	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
162161	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	drag hands do not operate	
162162	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
162163	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
162164	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
162165	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162166	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162167	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
162168	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
162169	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
162170	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	114769	
162171	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
162172	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
162173	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
162174	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
162175	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
162176	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162177	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162178	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162179	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
162180	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
162181	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
162182	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
162183	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
162184	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
162185	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
162186	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
162187	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	2	
162188	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162189	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162190	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162191	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	220.0	
162192	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	190.0	
162193	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	175.0	
162194	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
162195	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162196	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162197	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162198	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162199	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162200	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162201	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162202	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162203	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162204	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
162205	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
162206	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
162207	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
162208	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
162209	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
162210	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
162211	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
162212	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
162213	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
162214	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
162215	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
162216	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	180	
162217	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	180	
162218	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	0	
162219	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	0	
162220	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
162221	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
162222	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
162223	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
162224	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
162225	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
162226	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162227	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
162228	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
162229	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
162230	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
162231	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
162232	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
162233	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67353	
162234	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
162235	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
162236	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
162237	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162238	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162239	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
162240	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
162241	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
162242	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments		
162243	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
162244	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
162245	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
162246	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
162247	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
162248	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
162249	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	25.66	
162250	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
162251	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
162252	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
162253	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
162254	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
162255	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
162256	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
162257	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
162258	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
162259	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
162260	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162261	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
162262	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
162263	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	73	
162264	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	73	
162265	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162266	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162267	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162268	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162269	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162270	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162271	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162272	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations A Ø	0	
162273	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations B Ø	0	
162274	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations C Ø	0	
162275	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations Ground	0	
162276	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Follow-up Action Required?	n	
162277	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Follow-up Action Required?	n	
162278	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Foundation Condition	Good	
162279	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	General Comments		
162280	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	General Comments		
162281	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Grounds in Place?	y	
162282	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162283	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
162284	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
162285	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	270	
162286	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	270	
162287	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations This Read Vac	1	
162288	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	1	
162289	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
162290	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
162291	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162292	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162293	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	6	
162294	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
162295	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
162296	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
162297	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	40.0	
162298	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	46.0	
162299	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	41.0	
162300	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162301	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162302	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162303	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
162304	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162305	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162306	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
162307	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162308	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
162309	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
162310	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
162311	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
162312	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
162313	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
162314	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
162315	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
162316	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
162317	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
162318	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	45	°C
162319	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	41	°C
162320	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162321	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
162322	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
162323	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
162324	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
162325	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
162326	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
162327	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
162328	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.1440	
162329	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
162330	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
162331	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
162332	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	4	
162333	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162334	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162335	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162336	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	75.0	
162337	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps B Ø	85.0	
162338	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps C Ø	80.0	
162339	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushing Condition	Good	
162340	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162341	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162342	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
162343	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
162344	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162345	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162346	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162347	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
162348	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
162349	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162350	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
162351	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
162352	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162353	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments		
162354	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments		
162355	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
162356	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
162357	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
162358	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
162359	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
162360	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
162361	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162362	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
162363	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
162364	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
162365	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
162366	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
162367	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
162368	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	80	°C
162369	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
162370	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	45	°C
162371	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	45	°C
162372	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
162373	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
162374	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
162375	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
162376	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	680	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162377	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	680	
162378	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	680	
162379	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
162380	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162381	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162382	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162383	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162384	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162385	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162386	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	25.66	
162387	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	25.66	
162388	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162389	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162390	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162391	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162392	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162393	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162394	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162395	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162396	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162397	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
162398	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
162399	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
162400	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
162401	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
162402	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
162403	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
162404	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	41227	
162405	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
162406	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
162407	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
162408	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162409	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162410	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
162411	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
162412	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
162413	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments	ok	
162414	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
162415	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
162416	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
162417	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162418	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
162419	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162420	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162421	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162422	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162423	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
162424	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
162425	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
162426	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
162427	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
162428	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
162429	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
162430	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
162431	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
162432	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
162433	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
162434	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
162435	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
162436	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
162437	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
162438	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
162439	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
162440	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
162441	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
162442	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
162443	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
162444	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
162445	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
162446	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
162447	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
162448	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
162449	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
162450	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
162451	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162452	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
162453	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
162454	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
162455	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
162456	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
162457	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
162458	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BB0347	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
162459	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162460	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162461	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
162462	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
162463	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
162464	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	90864	
162465	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
162466	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
162467	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
162468	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
162469	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162470	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
162471	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
162472	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
162473	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
162474	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
162475	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
162476	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	135	
162477	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	135	
162478	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	0	
162479	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	0	
162480	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	0	
162481	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162482	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162483	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162484	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	10R	
162485	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162486	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
162487	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
162488	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments	Drag hands won't reset and counter does not work.	
162489	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	1	
162490	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
162491	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
162492	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
162493	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	67.0	
162494	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	41.0	
162495	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	77.0	
162496	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162497	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162498	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162499	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations A Ø	0	
162500	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations B Ø	0	
162501	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations C Ø	0	
162502	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations Ground	0	
162503	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Follow-up Action Required?	n	
162504	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	General Comments		
162505	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Maintenance Operations	0	
162506	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AF	100	
162507	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AL	100	
162508	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations This Read Vac	0	
162509	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Switching Operations	0	
162510	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Unknown Operations	0	
162511	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
162512	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162513	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162514	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
162515	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
162516	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
162517	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
162518	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
162519	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations	1	
162520	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162521	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162522	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162523	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps A Ø	150.0	
162524	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps B Ø	180.0	
162525	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps C Ø	200.0	
162526	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162527	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
162528	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
162529	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	75	°C
162530	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
162531	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162532	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
162533	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
162534	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
162535	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
162536	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
162537	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
162538	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
162539	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7344	
162540	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162541	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162542	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162543	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
162544	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162545	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162546	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
162547	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
162548	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
162549	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19865	
162550	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
162551	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
162552	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
162553	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
162554	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
162555	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162556	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162557	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162558	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162559	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
162560	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162561	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
162562	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
162563	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
162564	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments	ok	
162565	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
162566	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
162567	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments		
162568	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
162569	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
162570	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
162571	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
162572	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
162573	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
162574	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
162575	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
162576	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
162577	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
162578	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
162579	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
162580	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
162581	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
162582	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
162583	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
162584	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
162585	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
162586	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
162587	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
162588	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
162589	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162590	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162591	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162592	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
162593	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
162594	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
162595	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
162596	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
162597	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
162598	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
162599	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
162600	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.4	VDC
162601	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.7	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162602	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
162603	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
162604	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
162605	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
162606	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162607	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
162608	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162609	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
162610	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
162611	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	40	*C
162612	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	60	*C
162613	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.9620	
162614	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
162615	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Top Oil Temperature Max	60	*C
162616	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
162617	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
162618	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
162619	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
162620	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
162621	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
162622	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162623	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
162624	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.50	psi
162625	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
162626	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	13852.80	kw
162627	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
162628	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
162629	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
162630	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162631	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
162632	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
162633	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162634	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
162635	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
162636	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162637	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
162638	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
162639	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
162640	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
162641	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162642	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162643	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
162644	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
162645	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
162646	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
162647	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162648	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162649	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162650	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
162651	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
162652	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162653	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
162654	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments	ok	
162655	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
162656	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
162657	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
162658	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
162659	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162660	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments		
162661	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments		
162662	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
162663	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
162664	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
162665	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2643.84	kw
162666	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
162667	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
162668	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments		
162669	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
162670	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
162671	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
162672	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
162673	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
162674	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	Hi temp alarm- Did not reset 98 degrees outside	
162675	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
162676	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	13L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162677	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162678	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162679	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
162680	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
162681	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
162682	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24369	
162683	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
162684	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
162685	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
162686	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
162687	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
162688	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	3	
162689	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
162690	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
162691	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	366	
162692	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	366	
162693	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	1	
162694	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	1	
162695	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
162696	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
162697	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
162698	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	31.0	
162699	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	30.0	
162700	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	30.0	
162701	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162702	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162703	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162704	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	
162705	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	0	
162706	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	0	
162707	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
162708	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
162709	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
162710	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	0	
162711	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	129	
162712	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	129	
162713	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations This Read Vac	0	
162714	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	0	
162715	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
162716	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
162717	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162718	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162719	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
162720	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
162721	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
162722	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
162723	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162724	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
162725	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
162726	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162727	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
162728	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
162729	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162730	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
162731	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
162732	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
162733	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	1036.80	kw
162734	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
162735	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
162736	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162737	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162738	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162739	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162740	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162741	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162742	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162743	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162744	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162745	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
162746	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
162747	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
162748	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
162749	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
162750	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
162751	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162752	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
162753	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
162754	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
162755	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162756	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
162757	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
162758	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1341	
162759	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1341	
162760	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
162761	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
162762	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
162763	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
162764	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
162765	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
162766	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
162767	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
162768	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
162769	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
162770	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
162771	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
162772	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
162773	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	4	
162774	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162775	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162776	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162777	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	210.0	
162778	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	180.0	
162779	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	155.0	
162780	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
162781	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162782	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162783	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162784	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162785	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162786	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162787	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162788	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162789	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162790	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
162791	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
162792	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
162793	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
162794	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
162795	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
162796	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
162797	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
162798	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
162799	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
162800	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162801	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
162802	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
162803	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.7	VDC
162804	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
162805	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
162806	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
162807	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
162808	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
162809	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
162810	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
162811	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
162812	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162813	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162814	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
162815	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
162816	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
162817	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
162818	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162819	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
162820	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
162821	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162822	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	LTC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
162823	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	LTC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
162824	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	LTC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
162825	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	LTC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
162826	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspe	LTC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162827	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	LTC000805	LTCControl	401-1	LTC Control Insp	General Comments		
162828	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	LTC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
162829	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	LTC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
162830	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
162831	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
162832	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162833	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
162834	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
162835	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
162836	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	24570.00	kw
162837	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
162838	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
162839	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	75	°C
162840	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
162841	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
162842	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162843	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
162844	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
162845	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
162846	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
162847	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
162848	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
162849	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
162850	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	1.3650	
162851	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	60	°C
162852	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
162853	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
162854	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
162855	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
162856	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162857	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162858	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162859	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
162860	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
162861	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162862	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
162863	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
162864	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
162865	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments	Gauge not working properly	
162866	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments	top right fan not working. arrived and found breaker tripped, reset and rest of fans worked except previous mentioned. left breaker	
162867	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
162868	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
162869	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1925.76	kw
162870	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
162871	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
162872	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
162873	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
162874	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
162875	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
162876	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
162877	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
162878	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
162879	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
162880	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
162881	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
162882	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
162883	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
162884	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
162885	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
162886	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162887	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
162888	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
162889	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	108	
162890	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	108	
162891	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
162892	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
162893	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
162894	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
162895	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
162896	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
162897	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
162898	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
162899	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	
162900	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	72812	volts
162901	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
162902	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
162903	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
162904	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
162905	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
162906	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
162907	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
162908	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
162909	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
162910	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
162911	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
162912	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
162913	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
162914	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
162915	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
162916	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
162917	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
162918	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
162919	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
162920	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
162921	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
162922	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
162923	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
162924	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
162925	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
162926	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
162927	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
162928	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
162929	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
162930	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
162931	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162932	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162933	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162934	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	16.0	
162935	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	17.0	
162936	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	18.0	
162937	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
162938	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162939	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162940	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162941	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162942	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162943	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162944	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162945	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
162946	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
162947	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
162948	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
162949	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
162950	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
162951	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
162952	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
162953	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
162954	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	165	
162955	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
162956	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
162957	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
162958	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
162959	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
162960	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
162961	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
162962	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
162963	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
162964	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
162965	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
162966	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
162967	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
162968	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
162969	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
162970	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
162971	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
162972	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
162973	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
162974	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
162975	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
162976	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
162977	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
162978	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0		
162979	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0		
162980	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0		
162981	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0		
162982	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n		
162983	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n		
162984	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good		
162985	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments			
162986	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	General Comments			
162987	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y		
162988	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y		
162989	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1		
162990	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y		
162991	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	170		
162992	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	170		
162993	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1		
162994	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged		
162995	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0		
162996	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good		
162997	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0		
162998	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y		
162999	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y		
163000	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y		
163001	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
163002	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y		
163003	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y		
163004	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n		
163005	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y		
163006	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y		
163007	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y		
163008	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y		
163009	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y		
163010	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y		
163011	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y		
163012	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
163013	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y		
163014	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y		
163015	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None		
163016	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
163017	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
163018	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None		
163019	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good		
163020	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good		
163021	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200		
163022	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6018		
163023	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y		
163024	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good		
163025	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y		
163026	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts	
163027	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	209257		
163028	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset		
163029	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good		
163030	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None		
163031	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good		
163032	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	21.7		
163033	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good		
163034	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good		
163035	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y		
163036	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n		
163037	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments			
163038	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y		
163039	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y		
163040	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None		
163041	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good		
163042	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments			
163043	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n		
163044	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y		
163045	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y		
163046	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y		
163047	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good		
163048	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y		
163049	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y		
163050	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y		
163051	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
163052	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	98	*F
163053	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
163054	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments		
163055	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
163056	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
163057	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	0	
163058	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
163059	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
163060	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
163061	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	110.0	
163062	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	75.0	
163063	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	100.0	
163064	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
163065	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
163066	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
163067	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
163068	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations A Ø	0	
163069	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations B Ø	0	
163070	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations C Ø	0	
163071	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations Ground	0	
163072	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
163073	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Follow-up Action Required?	n	
163074	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	General Comments		
163075	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	General Comments		
163076	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
163077	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Maintenance Operations	0	
163078	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AF	410	
163079	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AL	410	
163080	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations This Read AM	0	
163081	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Switching Operations	0	
163082	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
163083	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
163084	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
163085	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
163086	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	General Comments		
163087	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
163088	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
163089	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
163090	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
163091	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
163092	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
163093	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
163094	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
163095	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
163096	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163097	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163098	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163099	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163100	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
163101	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163102	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
163103	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments	ok	
163104	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
163105	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
163106	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
163107	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
163108	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163109	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163110	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
163111	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
163112	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
163113	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
163114	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
163115	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163116	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
163117	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
163118	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163119	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
163120	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
163121	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163122	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
163123	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	both fan banks in auto.	
163124	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
163125	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
163126	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
163127	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
163128	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	59	°C
163129	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
163130	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163131	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
163132	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163133	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163134	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
163135	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
163136	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163137	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
163138	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
163139	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	58	°C
163140	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	44	°C
163141	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	61	°C
163142	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
163143	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
163144	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
163145	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
163146	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
163147	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
163148	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
163149	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	169354	
163150	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	169357	
163151	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
163152	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	1L	
163153	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
163154	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
163155	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
163156	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
163157	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
163158	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
163159	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments	ok	
163160	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments	ok	
163161	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
163162	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	
163163	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	1	
163164	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
163165	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	133	
163166	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	133	
163167	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations This Read Vac	1	
163168	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
163169	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
163170	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
163171	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
163172	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
163173	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
163174	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163175	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163176	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
163177	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
163178	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
163179	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
163180	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163181	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
163182	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
163183	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163184	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
163185	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
163186	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163187	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
163188	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
163189	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
163190	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	1299.84	kw
163191	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
163192	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
163193	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
163194	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	42	°C
163195	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163196	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
163197	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163198	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163199	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
163200	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
163201	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163202	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
163203	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4062	
163204	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
163205	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
163206	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
163207	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
163208	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
163209	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
163210	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2054	
163211	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	VCB Readings	Unknown Operations	0	
163212	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
163213	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
163214	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
163215	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
163216	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
163217	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
163218	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	246	
163219	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	246	
163220	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
163221	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
163222	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
163223	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
163224	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
163225	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
163226	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
163227	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments		
163228	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
163229	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
163230	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	86	
163231	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
163232	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163233	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163234	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163235	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163236	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163237	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	All Connections OK?	y	
163238	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
163239	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	General Comments		
163240	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
163241	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
163242	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
163243	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
163244	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
163245	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
163246	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163247	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
163248	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
163249	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
163250	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
163251	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
163252	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
163253	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
163254	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
163255	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
163256	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
163257	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
163258	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
163259	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
163260	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
163261	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
163262	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
163263	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
163264	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
163265	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
163266	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
163267	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
163268	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
163269	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
163270	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
163271	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
163272	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
163273	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
163274	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163275	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
163276	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163277	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163278	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163279	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
163280	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163281	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	65	°C
163282	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
163283	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
163284	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
163285	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
163286	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
163287	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
163288	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
163289	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments	ok	
163290	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
163291	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163292	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
163293	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
163294	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	5L	
163295	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	170	
163296	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
163297	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
163298	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
163299	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	92.56	kw
163300	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
163301	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
163302	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163303	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
163304	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
163305	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163306	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
163307	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4628	
163308	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163309	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163310	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
163311	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
163312	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
163313	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
163314	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
163315	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
163316	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2054	
163317	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
163318	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
163319	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
163320	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
163321	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
163322	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
163323	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
163324	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
163325	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
163326	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
163327	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
163328	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
163329	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
163330	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
163331	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
163332	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
163333	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163334	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163335	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163336	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163337	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163338	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163339	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
163340	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
163341	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
163342	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
163343	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
163344	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
163345	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
163346	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
163347	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
163348	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
163349	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
163350	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
163351	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163352	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
163353	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
163354	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
163355	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
163356	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
163357	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
163358	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
163359	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
163360	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
163361	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
163362	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
163363	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
163364	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps B Ø	400	
163365	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps A Ø	382	
163366	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty C Ph V	0	%
163367	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty B Ph V	0	%
163368	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty A Ph V	0	%
163369	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	9 Month Operations	33	
163370	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Unknown Operations	0	
163371	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Tank Paint Condition	Good	
163372	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Switching Operations	1	
163373	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations This Read Vac	1	
163374	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations Counter AL	185	
163375	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations Counter AF	185	
163376	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Moisture and Leak Free?	y	
163377	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Maintenance Operations	0	
163378	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Grounds in Place?	y	
163379	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	General Comments		
163380	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	General Comments		
163381	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Foundation Condition	Good	
163382	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Follow-up Action Required?	n	
163383	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Follow-up Action Required?	n	
163384	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations Ground	0	
163385	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations C Ø	0	
163386	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations B Ø	0	
163387	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations A Ø	0	
163388	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps C Phase V	0	
163389	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps B Phase V	0	
163390	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps A Phase V	0	
163391	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163392	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163393	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163394	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163395	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163396	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163397	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushing Condition	Good	
163398	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps C Ø	216	
163399	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps B Ø	250	
163400	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps A Ø	214	
163401	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty C Ph V	0	%
163402	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty B Ph V	0	%
163403	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty A Ph V	0	%
163404	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations	1	
163405	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	37	°C
163406	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	30	°C
163407	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	30	°C
163408	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	30	°C
163409	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	47	°C
163410	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	43	°C
163411	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	40	°C
163412	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	40	°C
163413	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	47	°C
163414	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	43	°C
163415	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	°C
163416	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
163417	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9438	
163418	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
163419	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163420	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
163421	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
163422	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163423	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163424	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
163425	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163426	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163427	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Switching Operations	0	
163428	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
163429	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations This Read Vac	0	
163430	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AL	164	
163431	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AF	164	
163432	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Moisture and Leak Free?	y	
163433	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Maintenance Operations	0	
163434	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Heaters (All) Functioning?	y	
163435	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Grounds in Place?	y	
163436	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	General Comments		
163437	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	General Comments		
163438	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Foundation Condition	Good	
163439	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Follow-up Action Required?	n	
163440	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Follow-up Action Required?	n	
163441	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations Ground	0	
163442	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations C Ø	0	
163443	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations B Ø	0	
163444	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations A Ø	0	
163445	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps C Phase V	0	
163446	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps B Phase V	0	
163447	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps A Phase V	0	
163448	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163449	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163450	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163451	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163452	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163453	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163454	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushing Condition	Good	
163455	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps C Ø	0	
163456	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps B Ø	0	
163457	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps A Ø	0	
163458	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty C Ph V	0	%
163459	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty B Ph V	0	%
163460	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty A Ph V	0	%
163461	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	9 Month Operations	0	
163462	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Unknown Operations	0	
163463	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Tank Paint Condition	Good	
163464	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Switching Operations	0	
163465	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations This Read Vac	0	
163466	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AL	162	
163467	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AF	162	
163468	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Moisture and Leak Free?	y	
163469	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Maintenance Operations	0	
163470	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Grounds in Place?	y	
163471	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	General Comments		
163472	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	General Comments		
163473	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Foundation Condition	Good	
163474	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Follow-up Action Required?	n	
163475	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Follow-up Action Required?	n	
163476	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations Ground	0	
163477	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations C Ø	0	
163478	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations B Ø	0	
163479	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations A Ø	0	
163480	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps C Phase V	0	
163481	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps B Phase V	0	
163482	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps A Phase V	0	
163483	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163484	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163485	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163486	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163487	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163488	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163489	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushing Condition	Good	
163490	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps C Ø	300	
163491	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
163492	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
163493	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163494	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163495	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
163496	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
163497	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
163498	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
163499	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	
163500	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
163501	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
163502	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
163503	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163504	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
163505	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
163506	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163507	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	1	
163508	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
163509	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
163510	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
163511	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	360.0	
163512	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	340.0	
163513	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	380.0	
163514	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
163515	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
163516	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
163517	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	4	
163518	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
163519	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
163520	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
163521	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	18540.00	kw
163522	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
163523	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	70	°C
163524	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	60	°C
163525	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163526	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	95	°F
163527	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
163528	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
163529	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
163530	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
163531	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
163532	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
163533	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
163534	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
163535	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
163536	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments	2 yard lights by control house are out need boom truck	
163537	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
163538	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
163539	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
163540	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
163541	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
163542	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
163543	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Vegetation	None	
163544	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
163545	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
163546	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
163547	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163548	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163549	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
163550	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
163551	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163552	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
163553	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	1.0300	
163554	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	70	°C
163555	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
163556	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	566.28	kw
163557	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
163558	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
163559	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
163560	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163561	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163562	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163563	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163564	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163565	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163566	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
163567	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	200.0	
163568	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	175.0	
163569	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	200.0	
163570	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
163571	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
163572	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
163573	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	11	
163574	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
163575	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163576	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
163577	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
163578	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
163579	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BCH000399	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
163580	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
163581	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
163582	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Both guages broke. 2 bottom fans not working	
163583	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
163584	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163585	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
163586	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
163587	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163588	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
163589	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
163590	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163591	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163592	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163593	10/2/2019 11:23	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
163594	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
163595	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
163596	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	1	
163597	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	160	
163598	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	160	
163599	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
163600	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments	A Phase IOC, VC Did not change	
163601	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
163602	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
163603	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
163604	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
163605	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	
163606	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
163607	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments		
163608	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
163609	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	201734	
163610	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	201734	
163611	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
163612	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	10L	
163613	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	7L	
163614	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	10L	
163615	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	357	
163616	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
163617	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
163618	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
163619	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
163620	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
163621	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163622	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163623	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
163624	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
163625	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
163626	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
163627	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163628	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
163629	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
163630	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163631	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
163632	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
163633	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163634	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
163635	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
163636	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
163637	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
163638	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	General Comments		
163639	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
163640	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Found Counter	24927	
163641	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Left Counter	24927	
163642	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
163643	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
163644	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
163645	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
163646	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
163647	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	*C
163648	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	43	*C
163649	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1429	
163650	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
163651	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163652	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
163653	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
163654	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
163655	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
163656	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	2954.88	kw
163657	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
163658	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
163659	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	65	°C
163660	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	55	°C
163661	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163662	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
163663	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163664	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163665	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
163666	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
163667	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163668	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
163669	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	1.2312	
163670	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
163671	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
163672	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
163673	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
163674	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163675	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
163676	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163677	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	10.0	VDC
163678	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	12.0	VDC
163679	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
163680	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
163681	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163682	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163683	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.0	VDC
163684	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	6.0	VDC
163685	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
163686	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
163687	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
163688	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163689	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
163690	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163691	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163692	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163693	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
163694	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	96	°F
163695	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
163696	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
163697	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
163698	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
163699	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
163700	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
163701	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
163702	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
163703	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
163704	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments		
163705	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	Cannot read nitrogen psi gauge	
163706	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
163707	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
163708	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
163709	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
163710	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
163711	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	48	°C
163712	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	48	°C
163713	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
163714	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
163715	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
163716	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
163717	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
163718	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
163719	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
163720	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
163721	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
163722	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
163723	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
163724	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
163725	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
163726	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163727	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
163728	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
163729	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
163730	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
163731	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
163732	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
163733	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
163734	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
163735	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
163736	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163737	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
163738	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
163739	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
163740	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
163741	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163742	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
163743	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163744	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163745	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163746	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
163747	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
163748	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163749	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	11.6	VDC
163750	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.9	VDC
163751	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
163752	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
163753	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163754	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163755	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163756	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163757	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
163758	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
163759	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
163760	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
163761	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163762	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
163763	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
163764	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
163765	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
163766	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
163767	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163768	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	134.3	VDC
163769	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
163770	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments		
163771	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
163772	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
163773	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	1	
163774	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
163775	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	1	
163776	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	488	
163777	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	488	
163778	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
163779	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
163780	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
163781	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
163782	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
163783	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
163784	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Unknown Operations	0	
163785	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Tank Paint Condition	Good	
163786	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
163787	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
163788	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
163789	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
163790	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
163791	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
163792	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
163793	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
163794	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
163795	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163796	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
163797	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163798	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163799	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163800	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
163801	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	98	*F

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
163802	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
163803	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
163804	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163805	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.3	VDC
163806	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
163807	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
163808	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
163809	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	37	°C
163810	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	30	°C
163811	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163812	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163813	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
163814	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	98	°F
163815	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000386	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
163816	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Tank Paint Condition	Good	
163817	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
163818	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Moisture and Leak Free?	y	
163819	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
163820	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Grounds in Place?	y	
163821	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	General Comments		
163822	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Foundation Condition	Good	
163823	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Follow-up Action Required?	n	
163824	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
163825	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
163826	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
163827	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
163828	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
163829	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
163830	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushing Condition	Good	
163831	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
163832	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163833	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.3	VDC
163834	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
163835	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163836	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
163837	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	12.0	VDC
163838	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
163839	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
163840	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
163841	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163842	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
163843	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163844	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163845	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163846	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
163847	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
163848	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
163849	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
163850	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
163851	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
163852	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
163853	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
163854	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
163855	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
163856	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
163857	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
163858	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
163859	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
163860	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
163861	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
163862	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
163863	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
163864	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
163865	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
163866	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
163867	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
163868	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
163869	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
163870	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
163871	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
163872	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
163873	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
163874	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BAT000586	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	93	°F
163875	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
163876	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163877	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
163878	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
163879	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
163880	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
163881	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
163882	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
163883	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	
163884	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	General Comments		
163885	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
163886	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
163887	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
163888	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
163889	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
163890	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
163891	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
163892	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
163893	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
163894	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
163895	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
163896	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
163897	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
163898	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
163899	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
163900	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
163901	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
163902	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
163903	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
163904	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
163905	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
163906	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
163907	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
163908	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
163909	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
163910	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
163911	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
163912	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
163913	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
163914	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	1	
163915	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
163916	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations This Read Vac	3	
163917	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	223	
163918	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	222	
163919	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
163920	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	
163921	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
163922	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
163923	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
163924	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
163925	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
163926	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
163927	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
163928	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
163929	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
163930	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
163931	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	General Comments		
163932	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
163933	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	LTC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
163934	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
163935	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
163936	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
163937	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
163938	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
163939	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
163940	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
163941	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
163942	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
163943	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
163944	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
163945	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments	ok	
163946	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
163947	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
163948	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
163949	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
163950	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
163951	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
163952	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
163953	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
163954	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
163955	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
163956	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments	ok	
163957	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
163958	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
163959	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
163960	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
163961	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
163962	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
163963	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
163964	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
163965	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
163966	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
163967	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
163968	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
163969	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
163970	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
163971	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
163972	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
163973	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
163974	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
163975	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
163976	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
163977	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
163978	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
163979	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
163980	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
163981	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
163982	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
163983	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
163984	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
163985	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
163986	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
163987	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
163988	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
163989	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
163990	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
163991	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
163992	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
163993	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
163994	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
163995	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
163996	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
163997	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
163998	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
163999	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
164000	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164001	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164002	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
164003	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
164004	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
164005	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
164006	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
164007	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
164008	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
164009	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
164010	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
164011	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
164012	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
164013	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
164014	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
164015	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
164016	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
164017	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
164018	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
164019	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	
164020	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14494	volts
164021	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
164022	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
164023	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
164024	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
164025	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
164026	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164027	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
164028	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
164029	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
164030	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
164031	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
164032	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
164033	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
164034	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
164035	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
164036	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
164037	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	14R	
164038	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
164039	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
164040	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
164041	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
164042	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
164043	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
164044	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	14954	
164045	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
164046	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
164047	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
164048	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
164049	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
164050	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
164051	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
164052	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
164053	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments		
164054	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
164055	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
164056	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
164057	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164058	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164059	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164060	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164061	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164062	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
164063	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
164064	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
164065	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
164066	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
164067	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
164068	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
164069	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
164070	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
164071	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
164072	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
164073	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
164074	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
164075	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments		
164076	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
164077	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
164078	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
164079	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
164080	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
164081	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
164082	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
164083	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
164084	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
164085	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	2	
164086	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
164087	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	0	
164088	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	9.88	
164089	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164090	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164091	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164092	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
164093	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
164094	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
164095	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
164096	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
164097	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
164098	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
164099	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
164100	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
164101	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164102	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
164103	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
164104	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
164105	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
164106	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
164107	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	78.0	
164108	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	80.0	
164109	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	74.0	
164110	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164111	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164112	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164113	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	5	
164114	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
164115	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	DRAG HANDS STUCK TOGETHER	
164116	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
164117	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
164118	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
164119	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
164120	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
164121	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
164122	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
164123	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
164124	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14342	
164125	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
164126	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
164127	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
164128	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
164129	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
164130	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
164131	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	1.2348	
164132	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
164133	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
164134	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
164135	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
164136	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
164137	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
164138	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
164139	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
164140	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
164141	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
164142	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	.9940	
164143	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
164144	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
164145	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
164146	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164147	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	57.0	VDC
164148	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164149	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164150	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
164151	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
164152	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
164153	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164154	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
164155	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
164156	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164157	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164158	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
164159	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
164160	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
164161	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164162	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164163	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
164164	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
164165	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
164166	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
164167	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
164168	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164169	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
164170	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
164171	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164172	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164173	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
164174	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
164175	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BAT000108	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
164176	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164177	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164178	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
164179	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
164180	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
164181	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
164182	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
164183	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
164184	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
164185	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
164186	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164187	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164188	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164189	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164190	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164191	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164192	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164193	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
164194	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	60	°C
164195	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
164196	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
164197	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
164198	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164199	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.4	VDC
164200	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
164201	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164202	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
164203	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52	VDC
164204	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52	VDC
164205	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
164206	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
164207	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
164208	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
164209	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
164210	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
164211	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
164212	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
164213	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
164214	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
164215	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
164216	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
164217	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
164218	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
164219	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
164220	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
164221	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
164222	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
164223	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
164224	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	5964.00	kw
164225	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
164226	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
164227	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	60	°C
164228	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	50	°C
164229	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
164230	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
164231	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
164232	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
164233	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
164234	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
164235	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
164236	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
164237	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
164238	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
164239	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
164240	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
164241	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
164242	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
164243	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
164244	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments		
164245	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
164246	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
164247	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	9878.4	kw
164248	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
164249	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
164250	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	65	°C
164251	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164252	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
164253	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
164254	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
164255	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
164256	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
164257	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
164258	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
164259	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
164260	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
164261	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
164262	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
164263	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
164264	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
164265	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
164266	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
164267	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
164268	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
164269	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
164270	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
164271	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
164272	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	n	
164273	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
164274	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
164275	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
164276	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
164277	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
164278	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
164279	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
164280	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
164281	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
164282	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
164283	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
164284	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
164285	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	LTC0000189	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
164286	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
164287	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
164288	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
164289	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
164290	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
164291	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
164292	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
164293	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
164294	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
164295	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	130	°C
164296	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	290.00	
164297	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	307.50	
164298	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
164299	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
164300	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
164301	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
164302	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments	ok	
164303	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
164304	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
164305	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
164306	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
164307	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
164308	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
164309	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
164310	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
164311	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
164312	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
164313	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
164314	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
164315	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164316	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164317	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164318	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164319	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164320	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
164321	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	CAPO00023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
164322	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
164323	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments		
164324	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
164325	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
164326	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164327	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164328	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164329	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164330	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164331	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164332	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
164333	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
164334	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations This Read Vac	0	
164335	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	163	
164336	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	163	
164337	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
164338	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	General Comments		
164339	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
164340	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
164341	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
164342	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
164343	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	
164344	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164345	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164346	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164347	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	50.0	
164348	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	25.0	
164349	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	25.0	
164350	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
164351	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
164352	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164353	5/6/2019 12:51	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	1	
164354	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
164355	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
164356	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
164357	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164358	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164359	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164360	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164361	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164362	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164363	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164364	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
164365	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
164366	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments		
164367	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
164368	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
164369	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
164370	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164371	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164372	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164373	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164374	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
164375	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164376	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
164377	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments		
164378	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
164379	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
164380	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
164381	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
164382	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
164383	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
164384	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
164385	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
164386	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	12	
164387	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	15L	
164388	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	7L	
164389	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	8L	
164390	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
164391	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	3300	
164392	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	3300	
164393	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments	Counter not working	
164394	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
164395	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
164396	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
164397	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
164398	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
164399	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
164400	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
164401	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164402	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
164403	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
164404	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
164405	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
164406	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
164407	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
164408	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
164409	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
164410	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
164411	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
164412	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
164413	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
164414	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
164415	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
164416	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
164417	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
164418	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
164419	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	
164420	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
164421	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
164422	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
164423	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164424	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164425	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations	6	
164426	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Unknown Operations	0	
164427	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Switching Operations	0	
164428	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations This Read Vac	0	
164429	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AL	259	
164430	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AF	259	
164431	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	0	
164432	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	General Comments		
164433	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	General Comments		
164434	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Follow-up Action Required?	n	
164435	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
164436	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations Ground	0	
164437	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations C Ø	0	
164438	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations B Ø	0	
164439	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
164440	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164441	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164442	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164443	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164444	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	198.0	
164445	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	194.0	
164446	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	210.0	
164447	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
164448	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
164449	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164450	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations	0	
164451	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Unknown Operations	0	
164452	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Switching Operations	0	
164453	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations This Read Vac	1	
164454	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AL	174	
164455	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AF	174	
164456	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Maintenance Operations	0	
164457	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	General Comments	IOC A phase	
164458	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	General Comments		
164459	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Follow-up Action Required?	n	
164460	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
164461	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations Ground	0	
164462	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations C Ø	0	
164463	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations B Ø	0	
164464	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations A Ø	1	
164465	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164466	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164467	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
164468	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164469	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps C Ø	130.0	
164470	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps B Ø	99.0	
164471	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps A Ø	96.0	
164472	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164473	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
164474	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
164475	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
164476	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164477	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
164478	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
164479	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
164480	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
164481	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
164482	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
164483	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
164484	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
164485	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
164486	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
164487	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
164488	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
164489	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
164490	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
164491	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	7994.88	kw
164492	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
164493	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
164494	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	48	°C
164495	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	28	°C
164496	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
164497	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
164498	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
164499	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
164500	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
164501	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
164502	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
164503	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
164504	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.8328	
164505	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	25	°C
164506	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	25	°C
164507	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
164508	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
164509	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
164510	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
164511	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
164512	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
164513	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
164514	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
164515	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	1467	
164516	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	11L	
164517	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	1L	
164518	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	4L	
164519	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
164520	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	119688	
164521	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	119688	
164522	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
164523	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
164524	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
164525	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
164526	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164527	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164528	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164529	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164530	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
164531	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164532	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164533	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
164534	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
164535	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
164536	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164537	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164538	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164539	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	5	
164540	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	0	
164541	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164542	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164543	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164544	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
164545	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
164546	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	0	
164547	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
164548	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations This Read Vac	0	
164549	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	219	
164550	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	219	
164551	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164552	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	0	
164553	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
164554	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
164555	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments		
164556	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments		
164557	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
164558	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
164559	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
164560	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
164561	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	0	
164562	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	0	
164563	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	0	
164564	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164565	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164566	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164567	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164568	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
164569	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	1020.0	
164570	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	865.0	
164571	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	995.0	
164572	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
164573	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
164574	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
164575	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
164576	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
164577	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
164578	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
164579	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
164580	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164581	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
164582	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
164583	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
164584	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164585	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
164586	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164587	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164588	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164589	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164590	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
164591	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
164592	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
164593	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
164594	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
164595	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
164596	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164597	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164598	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164599	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164600	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	7	
164601	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Unknown Operations	1	
164602	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	0	
164603	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations This Read Vac	1	
164604	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	170	
164605	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	170	
164606	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	0	
164607	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments	1 unknown operation. nothing logged in station log book	
164608	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
164609	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
164610	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
164611	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
164612	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
164613	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
164614	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
164615	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
164616	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
164617	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
164618	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164619	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	104.0	
164620	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	86.0	
164621	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	51.0	
164622	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164623	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164624	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164625	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164626	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164627	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
164628	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164629	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164630	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164631	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164632	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164633	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164634	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164635	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
164636	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
164637	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments	A manhole cover missing. the hole is 36 1/2 X 36 1/2 manhole cover needs to be bigger than that. the first one on left by the gate and	
164638	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
164639	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
164640	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
164641	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164642	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164643	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
164644	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
164645	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
164646	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
164647	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
164648	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
164649	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
164650	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
164651	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
164652	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164653	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164654	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	1.93	
164655	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164656	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
164657	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
164658	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
164659	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
164660	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
164661	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
164662	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
164663	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
164664	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
164665	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
164666	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
164667	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
164668	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
164669	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99951	
164670	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.900	millivolts
164671	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
164672	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
164673	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	9951	
164674	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
164675	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
164676	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
164677	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
164678	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
164679	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
164680	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
164681	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
164682	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
164683	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
164684	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
164685	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
164686	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
164687	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
164688	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
164689	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
164690	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
164691	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	153313	
164692	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	153317	
164693	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
164694	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164695	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164696	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.0	VDC
164697	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.6	VDC
164698	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
164699	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
164700	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164701	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164702	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164703	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164704	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
164705	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
164706	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
164707	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
164708	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
164709	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	155221	
164710	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	155221	
164711	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
164712	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	2L	
164713	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	1R	
164714	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	11L	
164715	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	764	
164716	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
164717	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
164718	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
164719	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164720	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164721	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.3	VDC
164722	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
164723	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	General Comments		
164724	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
164725	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164726	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
164727	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164728	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164729	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
164730	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	89	*F
164731	10/2/2019 10:12	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
164732	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164733	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164734	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
164735	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
164736	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
164737	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
164738	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164739	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
164740	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164741	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164742	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
164743	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	96	*F
164744	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
164745	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
164746	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
164747	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
164748	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
164749	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
164750	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
164751	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
164752	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
164753	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
164754	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments		
164755	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
164756	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
164757	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
164758	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
164759	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
164760	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
164761	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
164762	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
164763	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
164764	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
164765	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
164766	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
164767	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
164768	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164769	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	800.0	
164770	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	800.0	
164771	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164772	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164773	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164774	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	0	
164775	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
164776	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164777	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
164778	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
164779	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
164780	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
164781	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
164782	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
164783	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
164784	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
164785	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Unknown Operations	0	
164786	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	
164787	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations This Read Vac	0	
164788	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	150	
164789	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	150	
164790	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
164791	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
164792	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
164793	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
164794	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
164795	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
164796	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations C Ø	0	
164797	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations B Ø	0	
164798	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations A Ø	0	
164799	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164800	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164801	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164802	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164803	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
164804	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
164805	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
164806	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164807	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164808	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
164809	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
164810	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Unknown Operations	0	
164811	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
164812	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations This Read Vac	0	
164813	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	137	
164814	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	137	
164815	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
164816	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments		
164817	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
164818	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
164819	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
164820	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	
164821	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	0	
164822	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	0	
164823	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	0	
164824	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164825	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164826	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164827	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164828	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps C Ø	26.0	
164829	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps B Ø	31.0	
164830	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps A Ø	41.0	
164831	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
164832	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
164833	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	98	*F
164834	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
164835	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
164836	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
164837	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	7L	
164838	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	294	
164839	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
164840	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
164841	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
164842	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
164843	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
164844	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	0	
164845	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
164846	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	0	
164847	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	160	
164848	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	160	
164849	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
164850	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
164851	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
164852	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
164853	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
164854	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
164855	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
164856	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
164857	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
164858	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
164859	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
164860	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
164861	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
164862	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
164863	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164864	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
164865	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
164866	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
164867	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
164868	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
164869	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
164870	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	General Comments		
164871	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
164872	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
164873	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
164874	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
164875	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
164876	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
164877	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
164878	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
164879	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
164880	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
164881	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
164882	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
164883	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
164884	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
164885	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
164886	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164887	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164888	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
164889	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164890	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
164891	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
164892	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
164893	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
164894	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
164895	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
164896	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	800.0	
164897	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	25.0	
164898	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164899	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164900	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
164901	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
164902	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
164903	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
164904	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
164905	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
164906	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
164907	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
164908	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
164909	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
164910	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
164911	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	91	*F
164912	10/2/2019 16:09	Distribution	Traffon Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
164913	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	75.0	
164914	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	75.0	
164915	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
164916	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
164917	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
164918	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
164919	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
164920	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	40	*C
164921	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	44	*C
164922	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7224	
164923	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
164924	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
164925	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
164926	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
164927	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
164928	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
164929	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
164930	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
164931	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
164932	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	47	°C
164933	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
164934	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
164935	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	5201.28	kw
164936	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
164937	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
164938	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
164939	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
164940	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
164941	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments		
164942	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
164943	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
164944	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
164945	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
164946	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
164947	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
164948	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
164949	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
164950	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
164951	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
164952	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
164953	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
164954	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
164955	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
164956	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
164957	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
164958	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
164959	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
164960	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
164961	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
164962	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
164963	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
164964	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
164965	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
164966	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
164967	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	15.11	
164968	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
164969	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
164970	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	2	
164971	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	0	
164972	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
164973	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
164974	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
164975	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
164976	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
164977	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments		
164978	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments		
164979	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
164980	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
164981	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	1	
164982	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
164983	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	271	
164984	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	271	
164985	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	3	
164986	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
164987	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
164988	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
164989	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
164990	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	0	
164991	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
164992	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments		
164993	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
164994	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
164995	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
164996	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
164997	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
164998	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
164999	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.2	VDC
165000	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.9	VDC
165001	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165002	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
165003	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
165004	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
165005	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
165006	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
165007	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
165008	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	98	*F
165009	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	BAT000456	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
165010	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
165011	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.9	VDC
165012	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.7	VDC
165013	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
165014	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
165015	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
165016	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
165017	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
165018	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
165019	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
165020	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
165021	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
165022	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
165023	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
165024	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C Ø	0	
165025	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
165026	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
165027	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
165028	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
165029	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	General Comments		
165030	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
165031	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
165032	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
165033	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
165034	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	157	
165035	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	158	
165036	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations This Read Vac	1	
165037	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	1	
165038	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
165039	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
165040	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
165041	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.3	VDC
165042	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.8	VDC
165043	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
165044	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
165045	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
165046	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
165047	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
165048	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
165049	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
165050	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	92	*F
165051	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
165052	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
165053	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
165054	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
165055	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
165056	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
165057	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
165058	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
165059	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
165060	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
165061	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
165062	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
165063	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
165064	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
165065	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
165066	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
165067	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
165068	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
165069	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
165070	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
165071	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
165072	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	BAT000557	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
165073	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
165074	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
165075	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
165076	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
165077	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		
165078	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
165079	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
165080	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
165081	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165082	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165083	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
165084	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
165085	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
165086	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
165087	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	98	*F
165088	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
165089	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
165090	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
165091	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
165092	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
165093	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
165094	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	419	
165095	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	419	
165096	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	0	
165097	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	0	
165098	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
165099	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
165100	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
165101	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
165102	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
165103	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
165104	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
165105	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
165106	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
165107	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
165108	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	79075	
165109	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	79075	
165110	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
165111	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	1L	
165112	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	2R	
165113	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	8L	
165114	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	286	
165115	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
165116	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
165117	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
165118	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
165119	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
165120	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
165121	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
165122	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
165123	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
165124	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
165125	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
165126	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspect	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
165127	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
165128	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
165129	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
165130	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
165131	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
165132	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BCH000589	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
165133	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	3	
165134	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165135	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165136	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165137	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A Ø	33.0	
165138	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B Ø	80.0	
165139	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C Ø	36.0	
165140	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
165141	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165142	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165143	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165144	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165145	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165146	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165147	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165148	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165149	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165150	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A Ø	0	
165151	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
165152	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	0	
165153	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
165154	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	203	
165155	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	203	
165156	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations This Read Vac	0	
165157	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	0	
165158	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
165159	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	
165160	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
165161	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
165162	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
165163	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
165164	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
165165	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
165166	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
165167	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	216	
165168	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	216	
165169	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	28	
165170	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
165171	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
165172	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
165173	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
165174	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	General Comments		
165175	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
165176	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
165177	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
165178	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
165179	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
165180	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
165181	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
165182	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165183	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165184	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
165185	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
165186	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
165187	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	75.0	
165188	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	90.0	
165189	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0187	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
165190	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
165191	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
165192	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
165193	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	General Comments		
165194	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
165195	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
165196	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
165197	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
165198	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
165199	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
165200	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
165201	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
165202	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
165203	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
165204	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	General Comments		
165205	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
165206	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
165207	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
165208	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
165209	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
165210	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
165211	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
165212	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
165213	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
165214	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
165215	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
165216	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165217	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
165218	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
165219	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
165220	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
165221	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
165222	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
165223	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
165224	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
165225	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
165226	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165227	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments		
165228	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
165229	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165230	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165231	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165232	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	
165233	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
165234	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	478.80	
165235	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
165236	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
165237	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	50	
165238	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	43	
165239	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
165240	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
165241	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
165242	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165243	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
165244	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
165245	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
165246	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
165247	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
165248	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
165249	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
165250	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3990	
165251	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165252	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
165253	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
165254	10/2/2019 13:55	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	0	
165255	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
165256	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
165257	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
165258	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
165259	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165260	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165261	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165262	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
165263	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
165264	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
165265	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
165266	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
165267	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
165268	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations This Read SF6	0	
165269	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	58	
165270	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	58	
165271	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	0	
165272	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
165273	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
165274	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
165275	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
165276	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
165277	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
165278	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
165279	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
165280	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
165281	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
165282	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165283	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165284	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
165285	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
165286	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
165287	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
165288	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	83	
165289	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
165290	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments		
165291	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
165292	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
165293	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
165294	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
165295	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
165296	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
165297	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
165298	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
165299	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
165300	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
165301	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165302	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
165303	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
165304	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
165305	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
165306	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
165307	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
165308	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
165309	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
165310	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
165311	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
165312	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
165313	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Follow-up Action Required?	n	
165314	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
165315	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
165316	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165317	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165318	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
165319	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
165320	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
165321	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Ambient Temp	92	*F
165322	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
165323	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
165324	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	12	
165325	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165326	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
165327	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
165328	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
165329	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
165330	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Follow-up Action Required?	n	
165331	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
165332	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
165333	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
165334	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	y	
165335	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165336	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165337	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	40.0	
165338	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	20.0	
165339	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	0.0	
165340	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
165341	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165342	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165343	10/2/2019 12:53	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165344	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
165345	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
165346	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
165347	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
165348	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165349	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
165350	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
165351	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	93	*F
165352	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
165353	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
165354	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.8020	
165355	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
165356	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
165357	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
165358	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
165359	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
165360	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
165361	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	98	*F
165362	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
165363	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
165364	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
165365	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	40	*C
165366	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	50	*C
165367	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
165368	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
165369	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	6416.00	kw
165370	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
165371	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
165372	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
165373	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
165374	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
165375	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
165376	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165377	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
165378	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
165379	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
165380	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
165381	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
165382	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
165383	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
165384	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
165385	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
165386	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
165387	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
165388	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
165389	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
165390	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
165391	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
165392	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
165393	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments		
165394	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
165395	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
165396	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
165397	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
165398	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
165399	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
165400	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
165401	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
165402	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
165403	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
165404	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	Light	
165405	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
165406	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments	Johnson Grass behind Transformer	
165407	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
165408	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
165409	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
165410	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
165411	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
165412	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
165413	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	14	
165414	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165415	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165416	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165417	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
165418	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	
165419	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
165420	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
165421	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165422	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165423	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165424	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165425	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165426	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165427	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165428	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165429	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165430	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
165431	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
165432	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
165433	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
165434	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
165435	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
165436	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
165437	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
165438	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
165439	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
165440	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
165441	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
165442	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	239	
165443	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	239	
165444	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations This Read Vac	1	
165445	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
165446	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	4	
165447	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations This Read Vac	4	
165448	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	99989	
165449	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	99989	
165450	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
165451	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165452	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
165453	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
165454	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
165455	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
165456	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
165457	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
165458	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
165459	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
165460	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
165461	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
165462	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
165463	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
165464	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
165465	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
165466	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
165467	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165468	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165469	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
165470	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
165471	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
165472	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
165473	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
165474	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	115.2	
165475	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.5	
165476	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.4	
165477	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
165478	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165479	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165480	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165481	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165482	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165483	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165484	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	10.39	
165485	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	10.39	
165486	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	10.39	
165487	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
165488	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
165489	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
165490	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
165491	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
165492	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
165493	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
165494	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
165495	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
165496	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
165497	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
165498	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
165499	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
165500	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	2	
165501	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
165502	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	252	
165503	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	252	
165504	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	10	
165505	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
165506	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
165507	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
165508	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	2	
165509	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
165510	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
165511	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
165512	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
165513	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
165514	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
165515	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
165516	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
165517	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
165518	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
165519	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
165520	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
165521	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
165522	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
165523	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
165524	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
165525	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2744	
165526	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165527	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165528	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165529	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165530	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps A Ø	393.0	
165531	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps B Ø	405.0	
165532	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps C Ø	466.0	
165533	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	1	
165534	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
165535	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
165536	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
165537	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
165538	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
165539	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	111	
165540	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
165541	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
165542	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments		
165543	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
165544	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
165545	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
165546	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
165547	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
165548	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
165549	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
165550	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
165551	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
165552	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
165553	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
165554	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
165555	10/2/2019 8:50	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
165556	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165557	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165558	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165559	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165560	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations A Ø	0	
165561	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations B Ø	0	
165562	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations C Ø	0	
165563	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations Ground	0	
165564	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
165565	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Follow-up Action Required?	n	
165566	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	General Comments		
165567	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	General Comments		
165568	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Maintenance Operations	0	
165569	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AF	139	
165570	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	139	
165571	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations This Read Vac	0	
165572	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
165573	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
165574	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165575	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165576	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165577	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165578	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165579	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165580	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165581	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165582	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165583	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
165584	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	45.0	
165585	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	60.0	
165586	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	4	
165587	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165588	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165589	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165590	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	240.0	
165591	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	240.0	
165592	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	240.0	
165593	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
165594	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165595	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165596	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165597	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165598	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165599	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165600	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165601	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
165602	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	60.0	
165603	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165604	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165605	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165606	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectic	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	4	
165607	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
165608	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
165609	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
165610	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
165611	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
165612	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
165613	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
165614	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
165615	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
165616	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
165617	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
165618	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
165619	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments	ok	
165620	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
165621	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
165622	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
165623	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3058.56	kw
165624	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
165625	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
165626	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
165627	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
165628	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
165629	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
165630	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	50.0	
165631	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
165632	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165633	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165634	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165635	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165636	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165637	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165638	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165639	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165640	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165641	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
165642	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
165643	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
165644	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
165645	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
165646	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments		
165647	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
165648	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
165649	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
165650	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
165651	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
165652	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
165653	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	26	
165654	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165655	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165656	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165657	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
165658	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
165659	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
165660	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
165661	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
165662	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
165663	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
165664	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
165665	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
165666	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
165667	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
165668	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
165669	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
165670	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
165671	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
165672	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
165673	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
165674	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
165675	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
165676	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8738	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
165677	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
165678	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
165679	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
165680	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
165681	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
165682	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
165683	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
165684	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
165685	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
165686	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
165687	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
165688	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
165689	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
165690	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
165691	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
165692	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
165693	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
165694	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
165695	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
165696	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
165697	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
165698	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
165699	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
165700	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
165701	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
165702	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
165703	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
165704	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
165705	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
165706	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
165707	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
165708	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
165709	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
165710	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
165711	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
165712	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9570	
165713	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	11	
165714	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165715	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165716	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165717	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
165718	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
165719	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
165720	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
165721	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
165722	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
165723	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
165724	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
165725	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
165726	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
165727	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
165728	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
165729	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
165730	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
165731	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
165732	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
165733	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
165734	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
165735	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
165736	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
165737	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
165738	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
165739	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	40.0	
165740	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	100.0	
165741	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
165742	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
165743	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
165744	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
165745	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	494	
165746	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	495	
165747	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	1	
165748	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
165749	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	1	
165750	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
165751	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
165752	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
165753	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
165754	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
165755	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
165756	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
165757	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
165758	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
165759	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
165760	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
165761	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
165762	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
165763	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
165764	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
165765	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
165766	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
165767	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
165768	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
165769	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
165770	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
165771	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
165772	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
165773	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
165774	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
165775	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
165776	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
165777	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
165778	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
165779	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
165780	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
165781	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
165782	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
165783	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
165784	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
165785	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
165786	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
165787	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
165788	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
165789	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
165790	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
165791	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	948	
165792	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
165793	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
165794	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
165795	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
165796	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
165797	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
165798	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
165799	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
165800	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
165801	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
165802	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
165803	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
165804	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
165805	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
165806	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	7R	
165807	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
165808	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
165809	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
165810	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
165811	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	
165812	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7941	volts
165813	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
165814	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
165815	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
165816	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
165817	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
165818	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
165819	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
165820	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
165821	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
165822	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
165823	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
165824	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
165825	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
165826	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165827	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
165828	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
165829	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
165830	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
165831	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
165832	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
165833	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
165834	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
165835	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0 volts	
165836	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9244	
165837	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
165838	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
165839	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
165840	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
165841	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
165842	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
165843	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
165844	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
165845	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
165846	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
165847	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
165848	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
165849	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
165850	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
165851	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
165852	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
165853	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6 VDC	
165854	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.7 VDC	
165855	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
165856	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
165857	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y If no, which cells in comments	
165858	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y If no, which cells in comments	
165859	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y If no, which cells in comments	
165860	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y If no, which cells in comments	
165861	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
165862	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	79 °F	
165863	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
165864	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0638	
165865	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
165866	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
165867	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
165868	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
165869	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
165870	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
165871	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
165872	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
165873	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	40 °C	
165874	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	50 °C	
165875	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
165876	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
165877	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3829.68 kw	
165878	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
165879	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.5 psi	
165880	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
165881	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments	all fans running	
165882	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
165883	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
165884	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
165885	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
165886	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
165887	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
165888	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
165889	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
165890	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
165891	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
165892	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
165893	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
165894	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	0	
165895	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
165896	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	0	
165897	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
165898	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations This Read Vac	0	
165899	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	133	
165900	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	133	
165901	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165902	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	0	
165903	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
165904	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
165905	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments		
165906	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments		
165907	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
165908	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
165909	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
165910	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
165911	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments		
165912	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
165913	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
165914	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
165915	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165916	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165917	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
165918	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
165919	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
165920	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
165921	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
165922	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
165923	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
165924	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	1	
165925	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
165926	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	1	
165927	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	229	
165928	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	228	
165929	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
165930	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
165931	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
165932	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
165933	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
165934	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
165935	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
165936	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
165937	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
165938	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
165939	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
165940	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
165941	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165942	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165943	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165944	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165945	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165946	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165947	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165948	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
165949	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
165950	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
165951	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	114.0	
165952	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	160.0	
165953	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	110.0	
165954	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
165955	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
165956	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
165957	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	6	
165958	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
165959	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
165960	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
165961	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
165962	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
165963	10/2/2019 11:10	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
165964	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165965	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165966	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
165967	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
165968	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
165969	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
165970	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
165971	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
165972	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
165973	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
165974	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
165975	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
165976	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
165977	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
165978	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
165979	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
165980	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
165981	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
165982	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
165983	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
165984	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
165985	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
165986	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
165987	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
165988	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
165989	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
165990	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
165991	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
165992	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
165993	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
165994	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
165995	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
165996	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
165997	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
165998	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
165999	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	76	
166000	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	76	
166001	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
166002	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166003	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
166004	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
166005	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
166006	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	0	
166007	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
166008	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
166009	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
166010	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	50.0	
166011	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
166012	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	170.0	
166013	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
166014	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
166015	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
166016	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
166017	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
166018	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
166019	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	
166020	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
166021	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
166022	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
166023	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
166024	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
166025	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166026	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166027	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166028	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166029	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166030	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166031	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166032	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166033	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166034	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
166035	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	50.0	
166036	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	70.0	
166037	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	50.0	
166038	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166039	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166040	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166041	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	2	
166042	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
166043	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
166044	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
166045	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
166046	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166047	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166048	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
166049	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166050	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166051	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166052	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166053	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166054	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166055	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
166056	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166057	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166058	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
166059	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
166060	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
166061	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
166062	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166063	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166064	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166065	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
166066	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166067	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166068	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166069	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
166070	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
166071	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
166072	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
166073	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166074	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166075	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166076	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166077	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166078	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166079	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166080	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166081	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
166082	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166083	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments		
166084	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166085	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166086	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166087	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
166088	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166089	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
166090	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
166091	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5892	
166092	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166093	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166094	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166095	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166096	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	General Comments		
166097	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166098	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166099	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166100	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166101	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166102	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166103	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166104	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166105	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166106	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
166107	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166108	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
166109	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166110	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments		
166111	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166112	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166113	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166114	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166115	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166116	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166117	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166118	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166119	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	98	*F
166120	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
166121	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments		
166122	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
166123	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
166124	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166125	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166126	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166127	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166128	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166129	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
166130	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Unknown Operations	0	
166131	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166132	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
166133	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
166134	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
166135	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
166136	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
166137	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
166138	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
166139	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166140	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166141	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166142	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
166143	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
166144	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166145	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
166146	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
166147	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
166148	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
166149	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
166150	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
166151	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	0	
166152	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
166153	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	305	
166154	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
166155	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166156	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments		
166157	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments		
166158	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
166159	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
166160	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
166161	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4242.24	kw
166162	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
166163	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
166164	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
166165	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
166166	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
166167	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
166168	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
166169	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166170	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
166171	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
166172	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166173	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	305	
166174	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	0	
166175	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166176	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	0	
166177	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
166178	10/2/2019 14:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
166179	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166180	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	Vegetation	None	
166181	10/2/2019 13:04	Distribution	Dawson Springs Industrial Quarterly Inspec	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
166182	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166183	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166184	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
166185	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
166186	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
166187	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
166188	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
166189	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
166190	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	General Comments		
166191	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
166192	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
166193	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
166194	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
166195	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
166196	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1933	
166197	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1933	
166198	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
166199	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
166200	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
166201	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
166202	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
166203	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
166204	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	15	
166205	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
166206	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
166207	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
166208	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	32.0	
166209	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	44.0	
166210	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	50.0	
166211	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
166212	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166213	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166214	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166215	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166216	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166217	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166218	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166219	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166220	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166221	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	
166222	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
166223	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
166224	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
166225	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
166226	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
166227	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
166228	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
166229	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
166230	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
166231	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
166232	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	1	
166233	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
166234	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	184	
166235	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	184	
166236	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	1	
166237	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166238	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
166239	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
166240	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
166241	10/2/2019 12:44	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166242	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166243	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166244	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166245	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
166246	10/2/2019 14:09	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166247	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166248	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166249	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
166250	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166251	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166252	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166253	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
166254	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
166255	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166256	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166257	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166258	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
166259	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166260	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
166261	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166262	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166263	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166264	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
166265	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166266	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
166267	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166268	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166269	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166270	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166271	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
166272	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
166273	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166274	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		
166275	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166276	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166277	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166278	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166279	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166280	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166281	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166282	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166283	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166284	10/3/2019 8:25	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
166285	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	200.0	
166286	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
166287	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180.0	
166288	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
166289	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
166290	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
166291	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
166292	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166293	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166294	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
166295	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
166296	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
166297	10/2/2019 14:46	Distribution	Lancaster 2 Quarterly Inspection	CB0069	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
166298	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
166299	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
166300	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
166301	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	75	*C
166302	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
166303	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
166304	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	3589.92	kw
166305	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
166306	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
166307	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
166308	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166309	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
166310	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
166311	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166312	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
166313	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166314	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
166315	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
166316	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166317	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
166318	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7176	
166319	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166320	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166321	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166322	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
166323	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166324	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166325	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166326	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
166327	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
166328	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166329	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166330	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
166331	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166332	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166333	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166334	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166335	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166336	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166337	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166338	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166339	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
166340	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
166341	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
166342	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
166343	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166344	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166345	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
166346	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166347	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
166348	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments	ok	
166349	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166350	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166351	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166352	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166353	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166354	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166355	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
166356	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	156.0	
166357	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166358	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
166359	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
166360	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
166361	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4986	
166362	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
166363	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166364	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
166365	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
166366	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166367	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
166368	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
166369	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
166370	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166371	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166372	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
166373	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166374	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
166375	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166376	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
166377	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166378	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166379	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
166380	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
166381	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
166382	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
166383	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166384	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
166385	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
166386	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166387	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
166388	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
166389	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166390	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	42	°C
166391	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
166392	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
166393	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
166394	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
166395	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
166396	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
166397	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6888.96	kw
166398	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
166399	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
166400	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
166401	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
166402	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
166403	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments	needs some varmint guardng 3 hoods missing	
166404	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
166405	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
166406	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	0	
166407	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166408	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166409	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
166410	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166411	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	30.0	
166412	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	30.0	
166413	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	20.0	
166414	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
166415	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
166416	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
166417	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
166418	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	60739	
166419	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	60739	
166420	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
166421	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	3R	
166422	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	5R	
166423	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	4L	
166424	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	1042	
166425	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
166426	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
166427	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
166428	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
166429	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166430	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166431	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166432	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166433	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166434	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166435	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
166436	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
166437	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
166438	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
166439	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
166440	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
166441	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
166442	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
166443	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
166444	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166445	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166446	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166447	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
166448	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
166449	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
166450	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
166451	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
166452	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
166453	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	114	
166454	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166455	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166456	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166457	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166458	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166459	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166460	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166461	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166462	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
166463	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166464	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence -5' Clearance To Trees?	y	
166465	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166466	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166467	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
166468	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
166469	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
166470	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
166471	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166472	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166473	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166474	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
166475	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	W0319	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
166476	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
166477	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166478	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166479	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166480	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166481	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
166482	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166483	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166484	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
166485	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166486	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166487	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
166488	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
166489	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
166490	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
166491	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166492	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166493	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	0	
166494	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
166495	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
166496	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166497	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166498	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166499	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166500	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	1	
166501	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	172	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166502	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	172	
166503	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
166504	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	1	
166505	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
166506	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166507	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166508	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	100	*F
166509	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
166510	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
166511	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.0	VDC
166512	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	-2.0	VDC
166513	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
166514	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
166515	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
166516	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
166517	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
166518	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166519	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
166520	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
166521	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166522	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
166523	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0020	
166524	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166525	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166526	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166527	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166528	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
166529	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
166530	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166531	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166532	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166533	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
166534	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166535	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments		
166536	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166537	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166538	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
166539	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166540	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
166541	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
166542	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166543	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
166544	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non Ltc Trn Health	50.00	
166545	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Dry Cell Battery Install Date	2015-05-05 00:00:00.000000	
166546	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
166547	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
166548	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
166549	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
166550	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.8	VDC
166551	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
166552	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
166553	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments	ok	
166554	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
166555	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166556	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	93	*F
166557	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	BAT001180	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
166558	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166559	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166560	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166561	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
166562	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
166563	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166564	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
166565	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	93	*F
166566	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166567	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166568	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166569	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166570	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166571	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
166572	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
166573	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166574	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166575	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166576	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166577	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166578	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
166579	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
166580	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166581	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
166582	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
166583	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
166584	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
166585	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
166586	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2404.80	kw
166587	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
166588	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
166589	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
166590	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
166591	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments		
166592	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
166593	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
166594	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
166595	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
166596	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
166597	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
166598	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166599	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166600	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
166601	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166602	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments	ok	
166603	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166604	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166605	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166606	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166607	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166608	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
166609	10/2/2019 13:27	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166610	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
166611	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166612	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166613	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166614	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166615	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166616	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166617	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
166618	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
166619	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
166620	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166621	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166622	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166623	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
166624	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166625	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
166626	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166627	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166628	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166629	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
166630	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166631	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
166632	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166633	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166634	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166635	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166636	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166637	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166638	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
166639	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
166640	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
166641	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
166642	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
166643	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
166644	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
166645	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	331482	
166646	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	331482	
166647	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
166648	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7R	
166649	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10R	
166650	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4R	
166651	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	276	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
166652	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
166653	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
166654	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
166655	10/2/2019 13:54	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
166656	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166657	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166658	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166659	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166660	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166661	10/2/2019 13:39	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
166662	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
166663	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
166664	10/2/2019 7:45	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166665	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
166666	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
166667	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
166668	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
166669	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
166670	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166671	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166672	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166673	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166674	10/2/2019 10:06	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
166675	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166676	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
166677	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166678	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166679	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37592	
166680	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166681	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
166682	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
166683	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
166684	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
166685	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
166686	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
166687	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
166688	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
166689	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
166690	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
166691	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
166692	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166693	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166694	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
166695	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166696	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166697	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
166698	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166699	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166700	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166701	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
166702	10/2/2019 12:10	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166703	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
166704	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
166705	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
166706	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
166707	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
166708	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
166709	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
166710	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
166711	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
166712	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
166713	10/2/2019 12:03	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
166714	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
166715	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
166716	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
166717	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
166718	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
166719	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166720	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
166721	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166722	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166723	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
166724	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
166725	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
166726	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
166727	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
166728	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
166729	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
166730	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
166731	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
166732	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
166733	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
166734	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
166735	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
166736	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166737	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	23	
166738	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166739	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166740	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166741	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	24.0	
166742	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
166743	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	48.0	
166744	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
166745	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166746	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166747	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166748	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166749	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166750	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166751	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166752	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166753	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	
166754	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
166755	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
166756	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
166757	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
166758	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166759	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
166760	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	
166761	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
166762	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
166763	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
166764	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
166765	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
166766	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
166767	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
166768	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
166769	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
166770	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments		
166771	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments		
166772	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
166773	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166774	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166775	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166776	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166777	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166778	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166779	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166780	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166781	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166782	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
166783	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	0	
166784	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
166785	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
166786	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
166787	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	
166788	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
166789	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
166790	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
166791	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
166792	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	0	
166793	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	0	
166794	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
166795	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	148	
166796	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	148	
166797	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	0	
166798	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166799	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
166800	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
166801	10/2/2019 9:37	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166802	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166803	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166804	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
166805	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
166806	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
166807	10/2/2019 13:21	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
166808	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166809	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
166810	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
166811	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	1	
166812	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166813	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166814	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
166815	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166816	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166817	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166818	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166819	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
166820	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
166821	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
166822	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166823	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
166824	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
166825	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
166826	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
166827	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
166828	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
166829	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
166830	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
166831	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
166832	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
166833	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
166834	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	*F
166835	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
166836	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
166837	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
166838	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
166839	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
166840	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	231	
166841	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	231	
166842	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations This Read Vac	0	
166843	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
166844	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
166845	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
166846	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166847	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
166848	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
166849	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	147	
166850	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB00045	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	147	
166851	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166852	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >'S' Clearance To Trees?	y	
166853	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166854	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
166855	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
166856	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
166857	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
166858	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
166859	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166860	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166861	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166862	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
166863	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments	ok	
166864	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments	ok	
166865	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
166866	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
166867	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
166868	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
166869	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
166870	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
166871	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
166872	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
166873	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
166874	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
166875	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
166876	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
166877	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	131.0	
166878	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	186.0	
166879	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	185.0	
166880	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166881	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166882	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166883	10/2/2019 11:57	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	3	
166884	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
166885	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
166886	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
166887	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166888	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations This Read Vac	1	
166889	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	172	
166890	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	172	
166891	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
166892	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
166893	10/2/2019 13:53	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
166894	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
166895	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments	ok	
166896	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
166897	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
166898	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166899	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166900	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
166901	10/2/2019 8:39	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166902	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166903	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
166904	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
166905	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	114	
166906	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
166907	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
166908	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
166909	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
166910	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
166911	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
166912	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166913	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
166914	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
166915	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166916	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
166917	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
166918	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
166919	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
166920	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	7	
166921	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
166922	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
166923	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
166924	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
166925	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
166926	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	4904.64	kw
166927	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
166928	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
166929	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	*C
166930	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	45	*C
166931	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
166932	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
166933	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
166934	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
166935	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
166936	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
166937	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
166938	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
166939	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
166940	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
166941	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
166942	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166943	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166944	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166945	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
166946	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
166947	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
166948	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	68.0	
166949	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	66.0	
166950	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	68.0	
166951	10/2/2019 12:54	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
166952	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
166953	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
166954	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
166955	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
166956	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
166957	10/2/2019 16:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
166958	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
166959	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
166960	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
166961	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
166962	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
166963	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
166964	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
166965	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
166966	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
166967	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
166968	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
166969	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
166970	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	125.0	
166971	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	147.0	
166972	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	157.0	
166973	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
166974	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
166975	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
166976	10/3/2019 7:21	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
166977	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
166978	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
166979	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
166980	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
166981	10/2/2019 9:22	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	1	
166982	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
166983	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
166984	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
166985	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
166986	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
166987	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
166988	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
166989	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
166990	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
166991	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
166992	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
166993	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
166994	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	1.0218	
166995	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
166996	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
166997	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments		
166998	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
166999	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
167000	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
167001	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
167002	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
167003	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
167004	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
167005	10/2/2019 9:28	Distribution	Kentucky State Hospital Quarterly Inspectio	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
167006	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
167007	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
167008	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
167009	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
167010	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
167011	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2296.80	kw
167012	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
167013	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
167014	10/2/2019 13:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
167015	10/2/2019 10:16	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
167016	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3516	
167017	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
167018	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	50	°C
167019	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
167020	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
167021	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1125.12	kw
167022	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
167023	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
167024	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
167025	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
167026	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
167027	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
167028	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
167029	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
167030	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
167031	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
167032	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
167033	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
167034	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
167035	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
167036	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
167037	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
167038	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
167039	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
167040	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
167041	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
167042	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
167043	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
167044	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
167045	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
167046	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
167047	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
167048	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
167049	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
167050	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
167051	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
167052	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	190.0	
167053	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	195.0	
167054	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
167055	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	190.0	
167056	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
167057	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
167058	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
167059	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
167060	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	71	
167061	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
167062	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
167063	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
167064	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
167065	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
167066	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
167067	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
167068	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	4	
167069	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations This Read Vac	4	
167070	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	339	
167071	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	339	
167072	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
167073	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
167074	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167075	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
167076	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
167077	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
167078	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
167079	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
167080	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
167081	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
167082	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
167083	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167084	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167085	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	1	
167086	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
167087	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
167088	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167089	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
167090	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
167091	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
167092	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Present	40	°C
167093	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Max	50	°C
167094	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
167095	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
167096	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
167097	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
167098	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
167099	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
167100	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
167101	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
167102	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
167103	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
167104	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
167105	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167106	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167107	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
167108	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
167109	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
167110	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
167111	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
167112	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
167113	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
167114	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
167115	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
167116	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps C Ø	180.0	
167117	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps B Ø	195.0	
167118	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	203548	
167119	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
167120	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
167121	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
167122	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushing Condition	Good	
167123	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167124	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
167125	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
167126	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
167127	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
167128	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
167129	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
167130	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
167131	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
167132	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
167133	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
167134	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
167135	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
167136	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
167137	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
167138	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
167139	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
167140	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167141	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167142	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167143	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	4	
167144	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
167145	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
167146	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
167147	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
167148	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	71	
167149	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
167150	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
167151	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.5640	
167152	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
167153	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
167154	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
167155	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
167156	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
167157	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
167158	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
167159	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
167160	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
167161	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	LTC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
167162	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167163	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
167164	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
167165	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	280.0	
167166	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
167167	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
167168	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
167169	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
167170	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
167171	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167172	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167173	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
167174	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
167175	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167176	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167177	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167178	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
167179	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167180	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167181	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
167182	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
167183	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
167184	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
167185	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	230.0	
167186	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
167187	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	240.0	
167188	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
167189	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
167190	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
167191	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
167192	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
167193	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
167194	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	4	
167195	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations This Read Vac	4	
167196	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	384	
167197	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	384	
167198	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
167199	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
167200	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167201	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
167202	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
167203	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
167204	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations C Ø	0	
167205	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
167206	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
167207	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
167208	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
167209	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
167210	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
167211	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
167212	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
167213	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
167214	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
167215	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
167216	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
167217	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
167218	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
167219	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
167220	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
167221	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
167222	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
167223	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
167224	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
167225	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
167226	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations Ground	0	
167227	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
167228	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	30	
167229	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	30	
167230	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
167231	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
167232	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
167233	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
167234	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
167235	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
167236	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
167237	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
167238	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments		
167239	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments		
167240	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
167241	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
167242	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
167243	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
167244	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments		
167245	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments		
167246	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushing Condition	Good	
167247	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167248	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167249	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167250	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167251	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167252	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167253	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
167254	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
167255	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
167256	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
167257	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
167258	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
167259	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
167260	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
167261	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
167262	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
167263	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
167264	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
167265	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
167266	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
167267	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	97	*F
167268	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
167269	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
167270	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
167271	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	General Comments		
167272	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
167273	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
167274	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167275	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167276	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167277	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations A Ø	0	
167278	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps C Ø	100.0	
167279	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps B Ø	64.0	
167280	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps A Ø	85.0	
167281	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167282	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167283	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations B Ø	0	
167284	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
167285	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
167286	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
167287	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
167288	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
167289	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
167290	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
167291	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
167292	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
167293	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
167294	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
167295	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
167296	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	322	
167297	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	322	
167298	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
167299	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
167300	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
167301	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
167302	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
167303	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
167304	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
167305	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
167306	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
167307	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
167308	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	0	
167309	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	220	
167310	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	220	
167311	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
167312	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
167313	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167314	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
167315	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
167316	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
167317	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
167318	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
167319	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
167320	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
167321	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
167322	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
167323	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
167324	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
167325	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
167326	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167327	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
167328	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
167329	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
167330	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments		
167331	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
167332	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
167333	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
167334	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
167335	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
167336	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
167337	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
167338	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
167339	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
167340	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
167341	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
167342	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
167343	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
167344	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments		
167345	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
167346	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
167347	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
167348	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
167349	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
167350	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
167351	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
167352	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
167353	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
167354	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
167355	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
167356	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
167357	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
167358	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
167359	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
167360	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
167361	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
167362	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
167363	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
167364	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
167365	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
167366	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167367	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167368	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167369	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167370	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167371	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
167372	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
167373	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
167374	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
167375	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
167376	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
167377	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
167378	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
167379	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
167380	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
167381	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
167382	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
167383	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
167384	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
167385	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
167386	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
167387	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
167388	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
167389	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
167390	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
167391	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
167392	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
167393	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
167394	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
167395	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
167396	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
167397	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
167398	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
167399	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
167400	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
167401	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167402	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
167403	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
167404	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
167405	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
167406	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
167407	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
167408	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
167409	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
167410	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
167411	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
167412	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
167413	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
167414	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
167415	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
167416	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
167417	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
167418	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167419	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	0	
167420	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
167421	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	161	
167422	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	161	
167423	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations This Read Vac	0	
167424	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
167425	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	0	
167426	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
167427	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
167428	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	120.0	
167429	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
167430	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	0	
167431	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
167432	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
167433	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	0	
167434	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
167435	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167436	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167437	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167438	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	4	
167439	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
167440	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
167441	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
167442	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
167443	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	56509	
167444	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	56509	
167445	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
167446	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	3R	
167447	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	7R	
167448	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	5L	
167449	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
167450	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
167451	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
167452	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
167453	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
167454	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
167455	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments		
167456	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
167457	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	196	
167458	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	196	
167459	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	2	
167460	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	0	
167461	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	2	
167462	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	1530	
167463	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
167464	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
167465	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
167466	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
167467	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
167468	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
167469	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	1.1040	
167470	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	80	°C
167471	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
167472	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Bushing Dynamic Health	0.00	
167473	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	9	
167474	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167475	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167476	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167477	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
167478	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
167479	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
167480	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
167481	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
167482	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
167483	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
167484	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
167485	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
167486	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
167487	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
167488	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
167489	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
167490	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
167491	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	129	
167492	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	129	
167493	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
167494	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
167495	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167496	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
167497	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
167498	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
167499	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
167500	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
167501	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
167502	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
167503	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
167504	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
167505	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
167506	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167507	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167508	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167509	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167510	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167511	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167512	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167513	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167514	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167515	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
167516	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
167517	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
167518	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
167519	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
167520	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
167521	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
167522	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
167523	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
167524	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
167525	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
167526	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
167527	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Did not amp meter this time	
167528	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
167529	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	489	
167530	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
167531	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
167532	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
167533	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
167534	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
167535	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
167536	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
167537	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
167538	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167539	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
167540	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
167541	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	2	
167542	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167543	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167544	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167545	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	150.0	
167546	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	200.0	
167547	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	200.0	
167548	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167549	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167550	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167551	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167552	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
167553	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
167554	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	4	
167555	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167556	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167557	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167558	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	240.0	
167559	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	180.0	
167560	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	180.0	
167561	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	240.0	
167562	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	240.0	
167563	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	250.0	
167564	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167565	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
167566	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
167567	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
167568	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167569	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167570	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167571	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	0	
167572	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	0	
167573	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	0	
167574	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
167575	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
167576	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
167577	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
167578	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
167579	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
167580	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	173	
167581	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	173	
167582	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	0	
167583	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
167584	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
167585	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
167586	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
167587	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
167588	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
167589	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
167590	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
167591	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Did not amp meter this time	
167592	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
167593	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	503	
167594	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
167595	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
167596	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
167597	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
167598	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
167599	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	General Comments		
167600	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
167601	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
167602	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
167603	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC0000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
167604	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
167605	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
167606	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
167607	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
167608	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
167609	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
167610	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
167611	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
167612	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
167613	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
167614	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
167615	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	0	
167616	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167617	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167618	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167619	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	240.0	
167620	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	11R	
167621	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
167622	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
167623	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
167624	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments		
167625	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	200.0	
167626	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167627	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
167628	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
167629	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	230.0	
167630	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167631	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167632	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167633	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167634	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
167635	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
167636	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
167637	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
167638	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
167639	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
167640	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
167641	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
167642	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
167643	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
167644	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
167645	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
167646	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
167647	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
167648	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
167649	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
167650	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
167651	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
167652	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
167653	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
167654	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167655	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167656	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167657	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167658	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167659	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167660	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167661	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
167662	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	260.0	
167663	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	280.0	
167664	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
167665	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167666	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167667	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167668	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
167669	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
167670	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
167671	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
167672	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
167673	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
167674	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
167675	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
167676	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
167677	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
167678	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
167679	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
167680	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
167681	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	275999	
167682	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
167683	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
167684	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
167685	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
167686	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
167687	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
167688	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	13R	
167689	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
167690	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
167691	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
167692	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
167693	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments		
167694	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
167695	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
167696	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
167697	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
167698	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
167699	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
167700	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
167701	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167702	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
167703	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
167704	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
167705	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
167706	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
167707	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
167708	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	15897.60	kw
167709	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
167710	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
167711	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	45	*C
167712	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
167713	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
167714	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
167715	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
167716	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
167717	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	34	
167718	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167719	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167720	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167721	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	265.0	
167722	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	200.0	
167723	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	240.0	
167724	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167725	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
167726	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
167727	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
167728	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
167729	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments		
167730	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
167731	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	51	
167732	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	51	
167733	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
167734	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
167735	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
167736	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
167737	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
167738	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
167739	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
167740	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
167741	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
167742	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
167743	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
167744	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
167745	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
167746	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
167747	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Leaks	None	
167748	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
167749	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Regulator As Left Counter	144668	
167750	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
167751	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
167752	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
167753	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
167754	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
167755	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
167756	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
167757	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	General Comments		
167758	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
167759	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
167760	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
167761	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
167762	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
167763	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
167764	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
167765	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
167766	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
167767	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
167768	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
167769	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
167770	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
167771	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
167772	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
167773	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
167774	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
167775	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
167776	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
167777	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
167778	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
167779	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
167780	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments		
167781	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
167782	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
167783	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
167784	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
167785	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
167786	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
167787	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
167788	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
167789	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
167790	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
167791	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
167792	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
167793	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
167794	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
167795	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
167796	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
167797	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
167798	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
167799	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
167800	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
167801	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
167802	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
167803	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
167804	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
167805	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
167806	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
167807	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
167808	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
167809	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
167810	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
167811	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	0	
167812	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	0	
167813	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations	10	
167814	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167815	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167816	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
167817	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
167818	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
167819	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
167820	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
167821	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
167822	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
167823	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
167824	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
167825	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
167826	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
167827	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
167828	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
167829	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
167830	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
167831	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
167832	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
167833	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
167834	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
167835	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
167836	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
167837	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
167838	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
167839	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
167840	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
167841	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
167842	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
167843	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
167844	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
167845	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
167846	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
167847	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
167848	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
167849	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
167850	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
167851	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
167852	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
167853	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
167854	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
167855	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	70723	
167856	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
167857	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
167858	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	215.0	
167859	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	
167860	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167861	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167862	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167863	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167864	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167865	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167866	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167867	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167868	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167869	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
167870	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
167871	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
167872	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
167873	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
167874	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
167875	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
167876	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
167877	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
167878	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
167879	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
167880	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
167881	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
167882	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
167883	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
167884	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
167885	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
167886	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
167887	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
167888	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
167889	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
167890	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
167891	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
167892	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
167893	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
167894	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
167895	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		
167896	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
167897	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	1804.80	kw
167898	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
167899	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
167900	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167901	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps A Ø	180.0	
167902	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	366	
167903	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	366	
167904	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
167905	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
167906	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
167907	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
167908	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
167909	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	General Comments		
167910	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
167911	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
167912	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
167913	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
167914	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
167915	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
167916	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	
167917	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167918	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167919	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167920	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167921	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167922	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167923	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167924	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167925	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167926	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
167927	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	300.0	
167928	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	250.0	
167929	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	250.0	
167930	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167931	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167932	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167933	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	9	
167934	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
167935	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	10R	
167936	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
167937	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	12	
167938	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167939	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167940	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167941	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	200.0	
167942	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	210.0	
167943	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
167944	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
167945	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
167946	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
167947	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	28	
167948	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	28	
167949	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
167950	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	0.0	
167951	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	0.0	
167952	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	0.0	
167953	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167954	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
167955	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
167956	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
167957	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
167958	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
167959	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
167960	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
167961	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
167962	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
167963	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
167964	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
167965	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
167966	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments		
167967	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
167968	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	153	
167969	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	153	
167970	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	1	
167971	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
167972	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	1	
167973	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
167974	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
167975	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
167976	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
167977	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
167978	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
167979	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
167980	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
167981	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
167982	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
167983	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
167984	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
167985	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
167986	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
167987	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
167988	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
167989	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
167990	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
167991	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
167992	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
167993	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
167994	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
167995	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
167996	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
167997	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
167998	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
167999	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
168000	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
168001	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168002	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments		
168003	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments		
168004	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
168005	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168006	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	1	
168007	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
168008	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
168009	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
168010	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
168011	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
168012	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
168013	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
168014	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	154	
168015	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	154	
168016	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	1	
168017	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
168018	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
168019	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
168020	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
168021	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
168022	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	198	
168023	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	198	
168024	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	0	
168025	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
168026	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
168027	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	3	
168028	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
168029	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
168030	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
168031	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
168032	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
168033	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
168034	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
168035	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
168036	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
168037	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
168038	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
168039	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
168040	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
168041	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
168042	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
168043	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
168044	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
168045	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
168046	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
168047	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
168048	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
168049	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
168050	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
168051	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
168052	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
168053	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
168054	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
168055	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
168056	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
168057	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
168058	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
168059	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
168060	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
168061	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments		
168062	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
168063	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
168064	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
168065	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
168066	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
168067	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
168068	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
168069	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
168070	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
168071	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
168072	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
168073	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BB0276	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
168074	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
168075	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
168076	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168077	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
168078	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
168079	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
168080	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
168081	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
168082	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
168083	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
168084	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
168085	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	60	°C
168086	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	65	°C
168087	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.7122	
168088	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
168089	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
168090	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
168091	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
168092	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
168093	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
168094	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
168095	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
168096	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	60	°C
168097	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	60	°C
168098	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
168099	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
168100	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	12819.60	kw
168101	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
168102	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
168103	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
168104	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
168105	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
168106	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
168107	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
168108	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
168109	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
168110	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
168111	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
168112	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
168113	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168114	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168115	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168116	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168117	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168118	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168119	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168120	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168121	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
168122	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
168123	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
168124	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
168125	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168126	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168127	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168128	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
168129	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
168130	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
168131	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
168132	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
168133	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	180.0	
168134	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
168135	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
168136	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
168137	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
168138	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
168139	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
168140	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
168141	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
168142	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
168143	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
168144	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
168145	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
168146	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
168147	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
168148	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
168149	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1531	
168150	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1531	
168151	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168152	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
168153	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
168154	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
168155	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	95	*F
168156	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
168157	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
168158	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
168159	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
168160	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
168161	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
168162	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
168163	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
168164	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		
168165	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
168166	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
168167	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
168168	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
168169	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
168170	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
168171	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
168172	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
168173	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
168174	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
168175	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
168176	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
168177	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
168178	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
168179	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
168180	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
168181	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
168182	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
168183	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
168184	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
168185	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
168186	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
168187	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
168188	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
168189	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
168190	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
168191	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
168192	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
168193	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
168194	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
168195	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168196	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
168197	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
168198	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	191	
168199	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	191	
168200	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	0	
168201	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	0	
168202	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
168203	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
168204	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168205	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168206	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168207	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	581	
168208	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
168209	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	12L	
168210	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	4L	
168211	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	9L	
168212	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168213	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	591431	
168214	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	591431	
168215	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments		
168216	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
168217	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168218	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
168219	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Unknown Operations	0	
168220	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
168221	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Switching Operations	3	
168222	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
168223	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations This Read Vac	3	
168224	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AL	187	
168225	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AF	187	
168226	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168227	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Maintenance Operations	0	
168228	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
168229	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	General Comments		
168230	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
168231	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
168232	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Follow-up Action Required?	n	
168233	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
168234	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations Ground	0	
168235	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations C Ø	0	
168236	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations B Ø	0	
168237	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations A Ø	0	
168238	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168239	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168240	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168241	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168242	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168243	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168244	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168245	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168246	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168247	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
168248	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps C Ø	250.0	
168249	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps B Ø	285.0	
168250	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps A Ø	305.0	
168251	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168252	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168253	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168254	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations	9	
168255	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
168256	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
168257	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
168258	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
168259	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
168260	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
168261	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
168262	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
168263	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
168264	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
168265	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
168266	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
168267	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
168268	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	91	*F
168269	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
168270	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
168271	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
168272	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168273	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	160.0	
168274	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	172.0	
168275	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	160.0	
168276	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168277	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168278	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
168279	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
168280	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
168281	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
168282	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
168283	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
168284	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	10R	
168285	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
168286	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
168287	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
168288	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
168289	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
168290	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
168291	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
168292	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
168293	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
168294	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
168295	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
168296	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
168297	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	258162	
168298	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
168299	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
168300	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
168301	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168302	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
168303	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
168304	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
168305	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
168306	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168307	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	9	
168308	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
168309	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168310	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
168311	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
168312	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	28880	
168313	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	28880	
168314	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
168315	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
168316	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168317	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
168318	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
168319	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
168320	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1384	
168321	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
168322	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168323	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168324	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168325	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
168326	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
168327	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
168328	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
168329	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
168330	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
168331	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
168332	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	1354	
168333	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
168334	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
168335	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	
168336	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
168337	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	4	
168338	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations This Read Vac	4	
168339	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	193	
168340	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	193	
168341	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
168342	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
168343	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168344	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
168345	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments		
168346	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	General Comments		
168347	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
168348	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
168349	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
168350	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
168351	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	0	
168352	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
168353	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	CAPO00025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
168354	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
168355	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
168356	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	4	
168357	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations This Read Vac	4	
168358	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	306	
168359	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	306	
168360	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
168361	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations	5	
168362	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168363	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168364	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168365	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
168366	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
168367	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
168368	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
168369	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168370	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168371	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168372	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
168373	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
168374	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
168375	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
168376	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168377	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
168378	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
168379	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
168380	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
168381	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
168382	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
168383	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168384	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168385	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168386	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168387	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168388	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168389	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
168390	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
168391	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
168392	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
168393	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
168394	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168395	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168396	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168397	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168398	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168399	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168400	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168401	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168402	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168403	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
168404	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
168405	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
168406	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
168407	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
168408	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
168409	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
168410	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
168411	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
168412	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
168413	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168414	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
168415	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
168416	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
168417	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	4	
168418	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
168419	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations This Read Vac	4	
168420	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2109	
168421	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	2109	
168422	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
168423	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	0	
168424	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
168425	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments		
168426	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
168427	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
168428	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
168429	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
168430	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
168431	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
168432	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
168433	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
168434	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
168435	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	10R	
168436	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
168437	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
168438	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
168439	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
168440	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
168441	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
168442	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
168443	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
168444	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
168445	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
168446	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
168447	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
168448	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
168449	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	173967	
168450	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
168451	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168452	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
168453	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
168454	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
168455	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
168456	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
168457	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
168458	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	5	
168459	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168460	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168461	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168462	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	100.0	
168463	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	95.0	
168464	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	75.0	
168465	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
168466	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168467	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168468	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168469	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168470	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168471	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168472	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168473	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168474	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168475	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168476	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168477	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168478	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	538	
168479	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
168480	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
168481	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
168482	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
168483	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168484	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	7233	
168485	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	7233	
168486	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
168487	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
168488	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168489	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCM000050	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
168490	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
168491	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
168492	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
168493	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
168494	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
168495	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
168496	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Foundation Condition	Good	
168497	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	General Comments		
168498	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	General Comments		
168499	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Grounds in Place?	y	
168500	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Maintenance Operations	0	
168501	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Moisture and Leak Free?	y	
168502	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AF	241	
168503	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AL	241	
168504	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations This Read Vac	4	
168505	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
168506	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	4	
168507	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
168508	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
168509	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCCControl	834-1	LTC Control Insp	All Connections OK?	y	
168510	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
168511	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCCControl	834-1	LTC Control Insp	General Comments		
168512	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCCControl	834-1	LTC Control Insp	LTC Operation Checked?	n	
168513	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCCControl	834-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
168514	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
168515	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
168516	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
168517	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
168518	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	280.0	
168519	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	310.0	
168520	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	320.0	
168521	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
168522	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	9 Month Operations	10	
168523	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168524	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168525	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168526	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps A Ø	180.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168527	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps B Ø	180.0	
168528	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps C Ø	180.0	
168529	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
168530	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168531	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168532	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168533	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168534	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168535	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168536	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168537	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168538	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168539	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations A Ø	0	
168540	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations B Ø	0	
168541	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations C Ø	0	
168542	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations Ground	0	
168543	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
168544	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Follow-up Action Required?	n	
168545	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
168546	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
168547	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	General Comments		
168548	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
168549	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Maintenance Operations	0	
168550	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
168551	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AF	306	
168552	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AL	306	
168553	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations This Read Vac	1	
168554	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
168555	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Switching Operations	1	
168556	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
168557	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Unknown Operations	0	
168558	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
168559	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
168560	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
168561	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
168562	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
168563	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
168564	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
168565	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
168566	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
168567	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
168568	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
168569	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
168570	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	499	
168571	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	499	
168572	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
168573	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
168574	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
168575	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
168576	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
168577	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
168578	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
168579	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
168580	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
168581	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		
168582	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
168583	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
168584	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
168585	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
168586	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
168587	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC000381	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
168588	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC000381	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
168589	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC000381	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
168590	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
168591	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
168592	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
168593	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
168594	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168595	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	964	
168596	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	5L	
168597	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	7R	
168598	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	1R	
168599	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168600	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	44869	
168601	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	44869	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168602	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
168603	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
168604	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168605	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
168606	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
168607	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168608	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168609	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168610	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	919	
168611	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	9L	
168612	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	4R	
168613	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	5L	
168614	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168615	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	140812	
168616	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	140812	
168617	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
168618	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
168619	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168620	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
168621	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
168622	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
168623	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
168624	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
168625	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
168626	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
168627	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
168628	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
168629	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
168630	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
168631	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
168632	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
168633	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
168634	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
168635	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
168636	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	269	
168637	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	269	
168638	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
168639	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
168640	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168641	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
168642	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
168643	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
168644	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
168645	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
168646	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
168647	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
168648	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
168649	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	7	
168650	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168651	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168652	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168653	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
168654	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
168655	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
168656	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
168657	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168658	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168659	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168660	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168661	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168662	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168663	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168664	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168665	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168666	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
168667	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
168668	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
168669	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	
168670	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
168671	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
168672	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
168673	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
168674	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC000628	LTCControl	834-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
168675	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
168676	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168677	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds
168678	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
168679	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
168680	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
168681	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
168682	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
168683	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
168684	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
168685	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
168686	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
168687	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
168688	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
168689	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
168690	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
168691	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
168692	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BAT000498	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
168693	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
168694	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
168695	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.6	VDC
168696	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.5	VDC
168697	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
168698	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
168699	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
168700	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	0	
168701	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	0	
168702	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	179	
168703	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	179	
168704	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
168705	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
168706	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168707	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
168708	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
168709	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
168710	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
168711	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
168712	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
168713	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
168714	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168715	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168716	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	97	*F
168717	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
168718	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
168719	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
168720	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
168721	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
168722	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
168723	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
168724	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
168725	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
168726	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
168727	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
168728	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
168729	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
168730	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
168731	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
168732	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
168733	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
168734	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
168735	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	3	
168736	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168737	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168738	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168739	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	600.0	
168740	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	630.0	
168741	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	680.0	
168742	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
168743	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168744	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168745	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168746	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168747	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168748	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168749	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168750	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168751	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168752	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
168753	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
168754	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
168755	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168756	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168757	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168758	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168759	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168760	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168761	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
168762	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
168763	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
168764	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
168765	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
168766	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
168767	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
168768	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
168769	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
168770	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
168771	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168772	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
168773	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
168774	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2	
168775	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2	
168776	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
168777	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
168778	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
168779	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
168780	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
168781	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
168782	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
168783	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
168784	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
168785	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
168786	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		
168787	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
168788	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	88961	
168789	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	88961	
168790	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
168791	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	4L	
168792	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	2L	
168793	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	12L	
168794	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	868	
168795	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
168796	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
168797	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
168798	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
168799	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
168800	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
168801	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
168802	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
168803	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
168804	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
168805	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
168806	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
168807	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
168808	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
168809	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
168810	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
168811	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
168812	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
168813	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
168814	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
168815	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
168816	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
168817	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
168818	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
168819	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
168820	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
168821	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
168822	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
168823	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
168824	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
168825	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	9R	
168826	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168827	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
168828	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
168829	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
168830	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
168831	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
168832	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
168833	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
168834	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
168835	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
168836	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	0	
168837	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	0	
168838	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	330	
168839	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	330	
168840	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
168841	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
168842	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
168843	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
168844	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
168845	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
168846	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
168847	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
168848	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
168849	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
168850	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
168851	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
168852	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
168853	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
168854	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
168855	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
168856	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
168857	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
168858	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
168859	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168860	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168861	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168862	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
168863	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	200.0	
168864	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	250.0	
168865	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	200.0	
168866	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168867	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168868	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168869	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	8	
168870	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
168871	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
168872	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
168873	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
168874	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
168875	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
168876	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
168877	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
168878	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
168879	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
168880	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
168881	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
168882	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
168883	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
168884	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
168885	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		
168886	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
168887	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
168888	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	17604.00	kw
168889	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
168890	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
168891	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	60	°C
168892	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
168893	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
168894	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
168895	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
168896	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
168897	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
168898	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
168899	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
168900	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.9780	
168901	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	90	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
168902	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
168903	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
168904	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
168905	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
168906	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
168907	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
168908	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
168909	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	497.0	
168910	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	501.0	
168911	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
168912	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
168913	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
168914	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
168915	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
168916	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5981	
168917	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
168918	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
168919	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
168920	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
168921	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
168922	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
168923	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
168924	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
168925	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
168926	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
168927	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
168928	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
168929	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
168930	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
168931	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
168932	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
168933	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
168934	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
168935	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
168936	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
168937	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
168938	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
168939	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
168940	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
168941	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
168942	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
168943	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
168944	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
168945	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
168946	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
168947	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
168948	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
168949	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
168950	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
168951	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
168952	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
168953	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
168954	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
168955	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
168956	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
168957	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	General Comments		
168958	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
168959	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
168960	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
168961	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
168962	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
168963	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
168964	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
168965	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
168966	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5673	
168967	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
168968	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
168969	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Leaks	None	
168970	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
168971	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
168972	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
168973	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
168974	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
168975	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
168976	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Current Tap Position	8L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
168977	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
168978	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
168979	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
168980	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
168981	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	General Comments		
168982	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
168983	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
168984	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
168985	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
168986	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6740	
168987	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
168988	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
168989	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
168990	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
168991	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
168992	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
168993	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
168994	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
168995	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
168996	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
168997	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
168998	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	135296	
168999	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
169000	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
169001	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
169002	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169003	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
169004	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
169005	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169006	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
169007	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
169008	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
169009	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	60	°C
169010	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
169011	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	60	°C
169012	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
169013	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
169014	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
169015	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
169016	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
169017	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.1960	
169018	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
169019	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169020	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
169021	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
169022	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169023	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
169024	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169025	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	49	°C
169026	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	53	°C
169027	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
169028	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
169029	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	940.80	kw
169030	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
169031	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
169032	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
169033	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
169034	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169035	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
169036	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
169037	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
169038	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
169039	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
169040	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
169041	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
169042	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
169043	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
169044	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
169045	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
169046	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
169047	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
169048	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
169049	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
169050	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
169051	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
169052	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
169053	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
169054	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
169055	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
169056	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
169057	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
169058	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
169059	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
169060	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
169061	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
169062	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
169063	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
169064	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
169065	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
169066	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
169067	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
169068	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
169069	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
169070	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
169071	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169072	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169073	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169074	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
169075	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
169076	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169077	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169078	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169079	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169080	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169081	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169082	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169083	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
169084	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
169085	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	185.0	
169086	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	190.0	
169087	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169088	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169089	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169090	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
169091	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
169092	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
169093	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169094	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169095	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169096	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
169097	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
169098	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169099	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments		
169100	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
169101	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
169102	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
169103	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
169104	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
169105	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
169106	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	84	°C
169107	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	45	°C
169108	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169109	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
169110	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169111	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
169112	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	9 Month Operations	13	
169113	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169114	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169115	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169116	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps A Ø	240.0	
169117	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps B Ø	300.0	
169118	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps C Ø	200.0	
169119	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
169120	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169121	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169122	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169123	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169124	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169125	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169126	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169127	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169128	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169129	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations A Ø	0	
169130	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations B Ø	0	
169131	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations C Ø	0	
169132	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations Ground	0	
169133	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	
169134	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Follow-up Action Required?	n	
169135	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
169136	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
169137	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	General Comments		
169138	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
169139	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Maintenance Operations	0	
169140	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
169141	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AF	326	
169142	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AL	326	
169143	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations This Read Vac	1	
169144	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
169145	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Switching Operations	1	
169146	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
169147	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Unknown Operations	0	
169148	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
169149	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169150	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
169151	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments		
169152	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
169153	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
169154	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
169155	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
169156	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
169157	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169158	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169159	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169160	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169161	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169162	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169163	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169164	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169165	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169166	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
169167	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	210.0	
169168	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	190.0	
169169	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	240.0	
169170	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169171	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169172	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169173	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	7	
169174	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
169175	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
169176	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
169177	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
169178	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
169179	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
169180	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
169181	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
169182	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
169183	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
169184	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
169185	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
169186	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
169187	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
169188	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
169189	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
169190	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
169191	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
169192	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
169193	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
169194	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
169195	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
169196	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
169197	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
169198	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
169199	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
169200	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
169201	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
169202	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
169203	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
169204	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
169205	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
169206	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
169207	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
169208	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
169209	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
169210	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
169211	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
169212	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
169213	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
169214	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
169215	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
169216	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
169217	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
169218	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
169219	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
169220	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
169221	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
169222	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
169223	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169224	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
169225	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
169226	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
169227	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
169228	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
169229	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
169230	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
169231	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
169232	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
169233	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
169234	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169235	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169236	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
169237	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
169238	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
169239	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
169240	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169241	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
169242	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169243	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169244	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
169245	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
169246	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169247	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
169248	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
169249	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
169250	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
169251	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	22727	
169252	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	22727	
169253	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
169254	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
169255	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
169256	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
169257	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1303	
169258	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
169259	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
169260	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
169261	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
169262	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169263	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169264	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169265	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169266	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169267	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169268	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169269	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169270	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169271	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
169272	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps C Ø	0.0	
169273	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps B Ø	0.0	
169274	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps A Ø	0.0	
169275	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169276	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169277	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
169278	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	0	
169279	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations This Read Vac	0	
169280	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	158	
169281	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	158	
169282	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
169283	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	0	
169284	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169285	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
169286	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
169287	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
169288	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
169289	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
169290	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
169291	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
169292	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
169293	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
169294	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169295	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169296	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	9 Month Operations	9	
169297	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
169298	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169299	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169300	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169301	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169302	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169303	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169304	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169305	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169306	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169307	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
169308	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	640.0	
169309	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	610.0	
169310	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	560.0	
169311	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169312	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169313	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169314	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	3	
169315	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	
169316	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
169317	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
169318	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
169319	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
169320	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
169321	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
169322	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
169323	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
169324	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
169325	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
169326	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
169327	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169328	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169329	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169330	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169331	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
169332	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
169333	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169334	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
169335	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
169336	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
169337	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
169338	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	674.64	kw
169339	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
169340	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
169341	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
169342	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
169343	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169344	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
169345	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169346	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169347	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
169348	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
169349	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169350	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
169351	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.5622	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169352	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
169353	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169354	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169355	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169356	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
169357	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
169358	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
169359	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169360	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations A Ø	0	
169361	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations B Ø	0	
169362	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations C Ø	0	
169363	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations Ground	0	
169364	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
169365	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Follow-up Action Required?	n	
169366	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
169367	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	General Comments		
169368	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	General Comments		
169369	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
169370	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Maintenance Operations	0	
169371	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
169372	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AF	197	
169373	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AL	197	
169374	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations This Read Vac	4	
169375	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Switching Operations	4	
169376	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
169377	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Unknown Operations	0	
169378	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
169379	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
169380	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
169381	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
169382	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
169383	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
169384	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
169385	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
169386	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
169387	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
169388	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
169389	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
169390	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
169391	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
169392	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
169393	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
169394	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
169395	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
169396	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	W0116	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169397	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
169398	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
169399	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
169400	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Unknown Operations	0	
169401	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Tank Paint Condition	Good	
169402	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Switching Operations	2	
169403	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	100.0	
169404	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169405	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169406	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169407	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	7	
169408	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations This Read Vac	2	
169409	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AL	149	
169410	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AF	149	
169411	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Moisture and Leak Free?	y	
169412	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Maintenance Operations	0	
169413	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Grounds in Place?	y	
169414	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	General Comments		
169415	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
169416	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	General Comments		
169417	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Foundation Condition	Good	
169418	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Follow-up Action Required?	n	
169419	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Follow-up Action Required?	n	
169420	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations Ground	0	
169421	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations C Ø	0	
169422	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations B Ø	0	
169423	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
169424	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
169425	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169426	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169427	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
169428	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	General Comments		
169429	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
169430	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
169431	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
169432	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
169433	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
169434	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds
169435	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
169436	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
169437	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169438	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169439	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169440	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169441	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
169442	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
169443	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169444	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
169445	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
169446	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
169447	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
169448	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
169449	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
169450	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
169451	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
169452	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
169453	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169454	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
169455	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
169456	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
169457	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
169458	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
169459	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
169460	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
169461	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
169462	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169463	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169464	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169465	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169466	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	977.0	
169467	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	951.0	
169468	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	955.0	
169469	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169470	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169471	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169472	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
169473	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	0	
169474	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	0	
169475	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	272	
169476	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	272	
169477	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
169478	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
169479	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169480	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
169481	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
169482	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
169483	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
169484	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
169485	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
169486	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
169487	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
169488	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
169489	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
169490	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169491	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169492	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169493	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169494	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169495	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169496	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169497	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169498	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169499	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
169500	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	150.0	
169501	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	100.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169502	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Left Counter	208603	
169503	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
169504	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Current Tap Position	1L	
169505	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Max Tap Position	4R	
169506	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Min Tap Position	4L	
169507	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Operations Since Last Insp	1105	
169508	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
169509	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
169510	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
169511	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
169512	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
169513	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
169514	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	BCH000879	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
169515	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169516	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
169517	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
169518	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
169519	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
169520	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
169521	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
169522	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
169523	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
169524	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
169525	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
169526	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169527	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169528	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169529	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169530	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169531	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169532	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169533	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169534	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169535	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
169536	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	200.0	
169537	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	200.0	
169538	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	150.0	
169539	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169540	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169541	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	
169542	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
169543	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	General Comments		
169544	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
169545	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
169546	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
169547	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
169548	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
169549	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	LTC0000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	39	Seconds
169550	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169551	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	7	
169552	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169553	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
169554	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
169555	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169556	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
169557	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Reading	.8930	
169558	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
169559	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
169560	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
169561	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
169562	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169563	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169564	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
169565	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
169566	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
169567	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
169568	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169569	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
169570	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
169571	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169572	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
169573	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
169574	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
169575	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
169576	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169577	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169578	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
169579	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169580	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169581	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169582	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Follow-up Action Required?	n	
169583	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
169584	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
169585	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169586	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	General Comments		
169587	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	General Comments		
169588	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
169589	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	LTC Totalizer Reading	5358.00	kw
169590	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
169591	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
169592	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Max	70	°C
169593	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169594	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
169595	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations A Ø	0	
169596	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169597	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169598	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
169599	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169600	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
169601	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
169602	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
169603	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
169604	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
169605	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169606	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
169607	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
169608	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	LTC0000252	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
169609	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169610	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169611	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169612	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169613	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169614	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169615	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushing Condition	Good	
169616	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps C Ø	95.0	
169617	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps B Ø	90.0	
169618	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps A Ø	95.0	
169619	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169620	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169621	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC0000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
169622	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC0000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
169623	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC0000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
169624	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LTC0000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
169625	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
169626	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
169627	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	0	
169628	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations This Read Vac	0	
169629	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	322	
169630	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	322	
169631	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
169632	10/1/2019 8:22	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
169633	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
169634	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
169635	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
169636	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
169637	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
169638	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
169639	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
169640	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
169641	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
169642	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
169643	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
169644	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
169645	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
169646	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	243	
169647	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	243	
169648	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
169649	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
169650	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
169651	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
169652	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
169653	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
169654	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
169655	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169656	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
169657	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
169658	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169659	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations Ground	0	
169660	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations C Ø	0	
169661	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations B Ø	0	
169662	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations A Ø	0	
169663	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169664	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169665	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169666	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169667	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169668	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169669	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169670	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169671	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169672	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
169673	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps C Ø	240.0	
169674	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps B Ø	200.0	
169675	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps A Ø	200.0	
169676	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169677	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169678	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169679	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations	14	
169680	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
169681	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
169682	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169683	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	General Comments		
169684	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
169685	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
169686	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	15465.60	kw
169687	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
169688	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	75	°C
169689	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	55	°C
169690	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169691	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
169692	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169693	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169694	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169695	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
169696	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	520.0	
169697	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	600.0	
169698	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	500.0	
169699	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169700	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169701	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169702	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	120.0	
169703	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	160.0	
169704	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169705	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169706	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169707	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	4	
169708	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
169709	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments		
169710	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169711	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	1	
169712	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Unknown Operations	0	
169713	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
169714	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169715	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169716	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169717	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169718	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169719	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169720	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations A Ø	0	
169721	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations B Ø	0	
169722	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations C Ø	0	
169723	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations Ground	0	
169724	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Follow-up Action Required?	n	
169725	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Follow-up Action Required?	n	
169726	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
169727	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
169728	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
169729	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169730	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169731	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
169732	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
169733	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
169734	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
169735	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	1200.0	
169736	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	1000.0	
169737	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	1200.0	
169738	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Switching Operations	2	
169739	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
169740	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations This Read Vac	2	
169741	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AL	341	
169742	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AF	341	
169743	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
169744	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Maintenance Operations	0	
169745	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
169746	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	General Comments		
169747	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	General Comments		
169748	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
169749	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Follow-up Action Required?	n	
169750	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
169751	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	199	
169752	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	1	
169753	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
169754	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
169755	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
169756	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
169757	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Follow-up Action Required?	n	
169758	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
169759	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	General Comments		
169760	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
169761	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
169762	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
169763	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
169764	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
169765	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
169766	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
169767	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
169768	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
169769	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
169770	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
169771	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Found Counter	208603	
169772	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
169773	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
169774	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
169775	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
169776	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
169777	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
169778	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
169779	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
169780	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
169781	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
169782	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
169783	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
169784	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
169785	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169786	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
169787	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169788	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169789	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
169790	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
169791	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169792	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
169793	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
169794	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
169795	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
169796	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
169797	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
169798	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
169799	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
169800	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
169801	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
169802	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
169803	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	103	
169804	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	103	
169805	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
169806	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
169807	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
169808	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
169809	10/2/2019 12:41	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
169810	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169811	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
169812	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
169813	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
169814	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
169815	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
169816	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Reading	.8592	
169817	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
169818	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
169819	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Follow-up Action Required?	n	
169820	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
169821	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	General Comments		
169822	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
169823	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Found Counter	5162	
169824	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Left Counter	5162	
169825	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
169826	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Current Tap Position	1L	
169827	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Max Tap Position	3R	
169828	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Min Tap Position	5L	
169829	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Operations Since Last Insp	819	
169830	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
169831	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
169832	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
169833	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	120.0	
169834	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
169835	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169836	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169837	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169838	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169839	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169840	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169841	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169842	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169843	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169844	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
169845	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
169846	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
169847	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
169848	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
169849	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
169850	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
169851	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments		
169852	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments		
169853	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
169854	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169855	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	1	
169856	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
169857	10/1/2019 14:19	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	199	
169858	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	General Comments		
169859	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	General Comments		
169860	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Grounds in Place?	y	
169861	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169862	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Maintenance Operations	0	
169863	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
169864	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AF	112	
169865	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AL	112	
169866	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations This Read Vac	0	
169867	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Switching Operations	0	
169868	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Tank Paint Condition	Good	
169869	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
169870	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169871	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169872	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
169873	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
169874	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	
169875	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	0	
169876	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169877	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
169878	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations	3	
169879	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169880	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps A Ø	90.0	
169881	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps B Ø	95.0	
169882	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps C Ø	100.0	
169883	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushing Condition	Good	
169884	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169885	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169886	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169887	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169888	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169889	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169890	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169891	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169892	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169893	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations A Ø	0	
169894	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations B Ø	0	
169895	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations C Ø	0	
169896	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations Ground	0	
169897	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Follow-up Action Required?	n	
169898	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Follow-up Action Required?	n	
169899	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Foundation Condition	Good	
169900	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	General Comments		
169901	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	General Comments		
169902	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Grounds in Place?	y	
169903	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Maintenance Operations	0	
169904	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Moisture and Leak Free?	y	
169905	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AF	190	
169906	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AL	190	
169907	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
169908	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	General Comments		
169909	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	General Comments		
169910	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Grounds in Place?	y	
169911	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Heaters (All) Functioning?	y	
169912	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Maintenance Operations	0	
169913	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Moisture and Leak Free?	y	
169914	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AF	391	
169915	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AL	391	
169916	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations This Read Vac	4	
169917	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Switching Operations	4	
169918	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Tank Paint Condition	Good	
169919	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Unknown Operations	0	
169920	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169921	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169922	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169923	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169924	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169925	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169926	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169927	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushing Condition	Good	
169928	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Grounds in Place?	y	
169929	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	General Comments		
169930	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	General Comments		
169931	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Foundation Condition	Good	
169932	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Follow-up Action Required?	n	
169933	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	9 Month Operations	11	
169934	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169935	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169936	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Follow-up Action Required?	n	
169937	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations Ground	0	
169938	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations C Ø	0	
169939	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations B Ø	0	
169940	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations A Ø	0	
169941	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169942	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169943	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169944	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169945	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169946	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169947	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169948	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169949	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169950	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushing Condition	Good	
169951	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps C Ø	139.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
169952	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps B Ø	106.0	
169953	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps A Ø	79.0	
169954	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
169955	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
169956	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169957	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
169958	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	9 Month Operations	9	
169959	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Unknown Operations	0	
169960	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Tank Paint Condition	Good	
169961	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Switching Operations	3	
169962	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations This Read Vac	3	
169963	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AL	171	
169964	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AF	171	
169965	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Moisture and Leak Free?	y	
169966	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Maintenance Operations	0	
169967	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Grounds in Place?	y	
169968	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	General Comments		
169969	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	General Comments		
169970	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Foundation Condition	Good	
169971	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Follow-up Action Required?	n	
169972	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Follow-up Action Required?	n	
169973	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations Ground	0	
169974	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations C Ø	0	
169975	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations B Ø	0	
169976	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations A Ø	0	
169977	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
169978	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
169979	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
169980	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
169981	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
169982	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
169983	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
169984	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
169985	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
169986	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments		
169987	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	General Comments		
169988	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
169989	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	LTC Totalizer Reading	5258.88	kw
169990	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
169991	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Switching Operations	3	
169992	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Tank Paint Condition	Good	
169993	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Unknown Operations	0	
169994	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
169995	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Max	70	°C
169996	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
169997	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
169998	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
169999	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
170000	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
170001	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
170002	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170003	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
170004	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Reading	.5478	
170005	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
170006	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
170007	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	4	
170008	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170009	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170010	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
170011	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	8.0	
170012	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	13.0	
170013	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	19.0	
170014	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
170015	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
170016	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
170017	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
170018	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
170019	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
170020	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
170021	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
170022	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
170023	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
170024	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
170025	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
170026	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170027	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
170028	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
170029	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
170030	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
170031	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments		
170032	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments		
170033	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
170034	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
170035	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	1	
170036	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
170037	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	184	
170038	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	184	
170039	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations This Read Vac	1	
170040	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
170041	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	0	
170042	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	
170043	10/1/2019 14:39	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
170044	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps C Ø	60.0	
170045	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps B Ø	50.0	
170046	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps A Ø	55.0	
170047	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
170048	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
170049	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
170050	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
170051	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170052	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170053	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	9 Month Operations	12	
170054	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
170055	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations This Read Vac	2	
170056	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Switching Operations	2	
170057	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Tank Paint Condition	Good	
170058	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Unknown Operations	0	
170059	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	9 Month Operations	13	
170060	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
170061	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170062	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170063	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
170064	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps A Ø	175.0	
170065	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps B Ø	200.0	
170066	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps C Ø	195.0	
170067	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushing Condition	Good	
170068	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushings Connection/Risers	Good	
170069	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
170070	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
170071	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
170072	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170073	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
170074	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
170075	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
170076	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
170077	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
170078	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Paint Condition	Good	
170079	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Equipment Properly Labeled?	y	
170080	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
170081	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
170082	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
170083	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations A Ø	0	
170084	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations B Ø	0	
170085	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations C Ø	0	
170086	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations Ground	0	
170087	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Follow-up Action Required?	n	
170088	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Follow-up Action Required?	n	
170089	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Foundation Condition	Good	
170090	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	General Comments		
170091	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	General Comments		
170092	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Grounds in Place?	y	
170093	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Maintenance Operations	0	
170094	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Moisture and Leak Free?	y	
170095	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AF	191	
170096	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AL	191	
170097	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations This Read Vac	3	
170098	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170099	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Follow-up Action Required?	n	
170100	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
170101	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170102	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
170103	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
170104	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170105	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
170106	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170107	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
170108	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
170109	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
170110	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170111	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
170112	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170113	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
170114	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
170115	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations A Ø	0	
170116	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations B Ø	0	
170117	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	.8300	
170118	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
170119	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
170120	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	16	
170121	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170122	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170123	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
170124	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	60.0	
170125	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations C Ø	0	
170126	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations Ground	0	
170127	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Follow-up Action Required?	n	
170128	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170129	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
170130	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
170131	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
170132	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	90.0	
170133	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	75.0	
170134	10/1/2019 14:38	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
170135	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
170136	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
170137	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
170138	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170139	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170140	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
170141	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
170142	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
170143	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
170144	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
170145	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
170146	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
170147	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
170148	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	183	
170149	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	182	
170150	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations This Read Vac	1	
170151	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	1	
170152	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
170153	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
170154	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170155	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
170156	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
170157	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170158	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170159	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
170160	10/1/2019 10:51	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170161	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
170162	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	45	°C
170163	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
170164	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
170165	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
170166	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	4980.00	kw
170167	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
170168	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
170169	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170170	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushing Condition	Good	
170171	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps Ø	75.0	
170172	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps B Ø	113.0	
170173	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps A Ø	76.0	
170174	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
170175	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170176	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
170177	10/1/2019 9:21	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170178	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170179	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations	3	
170180	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Unknown Operations	0	
170181	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Tank Paint Condition	Good	
170182	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Switching Operations	1	
170183	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations This Read Vac	1	
170184	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AL	171	
170185	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AF	171	
170186	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Moisture and Leak Free?	y	
170187	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Maintenance Operations	0	
170188	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
170189	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
170190	10/1/2019 13:22	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
170191	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
170192	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
170193	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
170194	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
170195	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
170196	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
170197	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
170198	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
170199	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
170200	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
170201	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
170202	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
170203	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
170204	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
170205	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
170206	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
170207	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
170208	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
170209	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
170210	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
170211	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
170212	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
170213	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
170214	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
170215	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
170216	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
170217	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
170218	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
170219	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
170220	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
170221	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170222	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
170223	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170224	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
170225	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
170226	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170227	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
170228	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
170229	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
170230	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
170231	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
170232	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
170233	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
170234	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
170235	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170236	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
170237	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
170238	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
170239	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
170240	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
170241	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
170242	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
170243	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
170244	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
170245	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
170246	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
170247	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
170248	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
170249	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
170250	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
170251	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
170252	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
170253	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170254	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
170255	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
170256	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
170257	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
170258	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
170259	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
170260	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
170261	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
170262	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
170263	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
170264	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
170265	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
170266	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
170267	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
170268	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170269	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
170270	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170271	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
170272	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
170273	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
170274	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
170275	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
170276	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
170277	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
170278	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
170279	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
170280	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
170281	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
170282	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
170283	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
170284	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
170285	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
170286	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments	ok	
170287	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
170288	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
170289	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
170290	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
170291	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
170292	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
170293	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
170294	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
170295	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
170296	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
170297	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
170298	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
170299	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170300	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
170301	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
170302	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170303	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
170304	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
170305	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
170306	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
170307	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
170308	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
170309	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
170310	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
170311	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
170312	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
170313	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
170314	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
170315	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
170316	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
170317	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
170318	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
170319	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170320	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
170321	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170322	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
170323	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
170324	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170325	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
170326	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
170327	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
170328	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
170329	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
170330	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
170331	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
170332	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
170333	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
170334	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
170335	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
170336	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
170337	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
170338	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
170339	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
170340	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
170341	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
170342	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
170343	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
170344	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
170345	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
170346	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
170347	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
170348	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
170349	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Eyewash Solution	Good	
170350	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
170351	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
170352	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
170353	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
170354	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	2786	
170355	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
170356	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
170357	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
170358	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
170359	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
170360	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
170361	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
170362	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
170363	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
170364	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
170365	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
170366	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	6340	
170367	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	6340	
170368	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
170369	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
170370	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
170371	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
170372	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
170373	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
170374	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
170375	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
170376	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
170377	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
170378	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
170379	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
170380	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	257683	
170381	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	257683	
170382	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
170383	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
170384	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
170385	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
170386	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
170387	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
170388	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
170389	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
170390	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
170391	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
170392	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
170393	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
170394	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
170395	9/30/2019 13:04	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
170396	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
170397	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170398	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
170399	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170400	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170401	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
170402	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
170403	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
170404	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
170405	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
170406	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
170407	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
170408	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170409	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
170410	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
170411	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
170412	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
170413	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
170414	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
170415	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
170416	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
170417	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
170418	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
170419	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
170420	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
170421	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
170422	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
170423	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
170424	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
170425	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
170426	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170427	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170428	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
170429	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
170430	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
170431	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
170432	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
170433	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
170434	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
170435	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170436	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170437	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170438	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
170439	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
170440	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
170441	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
170442	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
170443	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
170444	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
170445	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
170446	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	68	
170447	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
170448	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
170449	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	5	
170450	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
170451	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.5	
170452	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.2	
170453	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	60	
170454	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170455	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
170456	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170457	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170458	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	793	
170459	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
170460	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
170461	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
170462	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
170463	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
170464	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
170465	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
170466	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170467	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4812	
170468	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
170469	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170470	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170471	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170472	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170473	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170474	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170475	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	34	*C
170476	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	46	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
170477	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
170478	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
170479	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	192.48	kw
170480	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
170481	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
170482	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
170483	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.0	
170484	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.3	
170485	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.1	
170486	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
170487	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
170488	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
170489	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
170490	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
170491	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170492	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170493	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
170494	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170495	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170496	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
170497	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen	
170498	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
170499	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170500	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
170501	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
170502	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170503	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
170504	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
170505	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments	Front posts near gate not aligned.	
170506	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
170507	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
170508	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
170509	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
170510	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
170511	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
170512	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
170513	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
170514	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
170515	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
170516	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
170517	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
170518	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
170519	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
170520	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
170521	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
170522	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
170523	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
170524	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
170525	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
170526	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
170527	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
170528	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
170529	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
170530	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
170531	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
170532	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170533	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
170534	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
170535	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170536	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
170537	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments	Bushing animal guard has fallen off of X3 bushing	
170538	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
170539	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
170540	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
170541	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	645.12	kw
170542	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
170543	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
170544	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
170545	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
170546	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170547	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170548	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
170549	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170550	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170551	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170552	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
170553	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
170554	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
170555	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
170556	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
170557	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
170558	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
170559	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
170560	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
170561	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5376	
170562	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
170563	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
170564	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
170565	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
170566	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
170567	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
170568	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
170569	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
170570	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
170571	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
170572	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
170573	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170574	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170575	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
170576	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170577	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170578	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170579	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	553	
170580	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
170581	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
170582	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
170583	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
170584	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
170585	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
170586	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
170587	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.0	
170588	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.0	
170589	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.0	
170590	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170591	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170592	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170593	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170594	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
170595	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170596	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170597	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
170598	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170599	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170600	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170601	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170602	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170603	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
170604	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.0	
170605	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.8	
170606	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
170607	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
170608	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
170609	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
170610	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
170611	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
170612	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
170613	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	118	
170614	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
170615	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	DX0143	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
170616	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
170617	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
170618	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
170619	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
170620	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170621	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170622	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170623	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170624	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	9L	
170625	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170626	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170627	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
170628	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170629	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	Counter shows vmuch lower number than last quarterly. Cascade and opeptions card both show	
170630	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
170631	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
170632	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
170633	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
170634	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
170635	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
170636	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170637	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
170638	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170639	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
170640	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
170641	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170642	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
170643	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
170644	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
170645	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
170646	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170647	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170648	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
170649	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
170650	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
170651	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
170652	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
170653	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
170654	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	169589	
170655	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170656	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170657	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
170658	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
170659	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
170660	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
170661	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
170662	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
170663	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
170664	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170665	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170666	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
170667	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
170668	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
170669	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
170670	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
170671	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170672	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170673	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
170674	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
170675	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
170676	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1735	
170677	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
170678	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
170679	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
170680	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170681	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170682	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
170683	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
170684	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170685	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
170686	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
170687	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
170688	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170689	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	12L	
170690	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170691	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
170692	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170693	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170694	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170695	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
170696	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
170697	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	Light	
170698	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
170699	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments	Vegetation touching and vines growing under the fence.	
170700	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
170701	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170702	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
170703	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	13L	
170704	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170705	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170706	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
170707	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
170708	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
170709	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	835	
170710	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170711	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170712	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
170713	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000170	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
170714	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
170715	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170716	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170717	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170718	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170719	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
170720	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170721	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
170722	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
170723	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170724	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
170725	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
170726	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
170727	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
170728	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
170729	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
170730	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
170731	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
170732	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
170733	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
170734	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
170735	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
170736	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
170737	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170738	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170739	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8519	
170740	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
170741	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
170742	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
170743	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
170744	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
170745	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
170746	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
170747	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
170748	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170749	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170750	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
170751	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
170752	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
170753	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments		
170754	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170755	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
170756	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
170757	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
170758	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170759	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170760	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170761	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170762	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170763	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
170764	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
170765	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
170766	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
170767	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
170768	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
170769	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
170770	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
170771	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
170772	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
170773	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
170774	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
170775	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
170776	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170777	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
170778	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
170779	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	296021	
170780	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170781	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170782	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
170783	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
170784	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170785	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170786	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170787	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
170788	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
170789	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
170790	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
170791	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
170792	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
170793	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
170794	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
170795	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
170796	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
170797	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
170798	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
170799	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
170800	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
170801	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
170802	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
170803	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
170804	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
170805	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
170806	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
170807	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
170808	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
170809	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
170810	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
170811	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
170812	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
170813	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
170814	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
170815	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
170816	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
170817	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
170818	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
170819	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
170820	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
170821	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
170822	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments		
170823	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
170824	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
170825	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
170826	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
170827	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
170828	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
170829	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
170830	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
170831	9/27/2019 9:56	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
170832	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
170833	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
170834	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
170835	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
170836	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
170837	9/27/2019 11:02	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
170838	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
170839	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
170840	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79891	
170841	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
170842	9/27/2019 10:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
170843	9/27/2019 15:03	Distribution	Big Stone Gap Storeroom Spare Transform	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
170844	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
170845	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
170846	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
170847	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
170848	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
170849	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
170850	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
170851	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170852	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
170853	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
170854	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
170855	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	K80011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	1	
170856	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	K80011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
170857	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	K80011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
170858	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
170859	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
170860	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
170861	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	General Comments	breaker not here new siemens breaker	
170862	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
170863	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
170864	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
170865	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
170866	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
170867	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
170868	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
170869	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
170870	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
170871	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
170872	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	breaker not here new siemens breaker	
170873	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
170874	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
170875	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
170876	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
170877	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
170878	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
170879	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
170880	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	n	
170881	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
170882	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
170883	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
170884	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
170885	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
170886	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
170887	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
170888	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
170889	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
170890	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
170891	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
170892	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
170893	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
170894	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	2082	
170895	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
170896	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
170897	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
170898	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	8L	
170899	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	5R	
170900	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	2R	
170901	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
170902	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	156830	
170903	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	156830	
170904	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
170905	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
170906	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	9L	
170907	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	3R	
170908	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
170909	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	66	°C
170910	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	1493	
170911	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
170912	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
170913	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
170914	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	2L	
170915	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
170916	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	62305	
170917	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	62305	
170918	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
170919	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
170920	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
170921	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
170922	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
170923	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
170924	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
170925	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
170926	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
170927	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
170928	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
170929	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	All Connections OK?	y	
170930	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
170931	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	Follow-up Action Required?	n	
170932	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	General Comments		
170933	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	LTC Operation Checked?	y	
170934	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
170935	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
170936	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
170937	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	LTCC000047	LTCControl	427-1 C	LTC Control Insp	VRR Time Delay	30	Seconds
170938	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
170939	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
170940	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
170941	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
170942	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
170943	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
170944	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
170945	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
170946	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
170947	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
170948	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
170949	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
170950	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
170951	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
170952	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
170953	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
170954	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
170955	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	5137.92	kw
170956	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
170957	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
170958	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
170959	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
170960	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
170961	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
170962	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
170963	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
170964	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
170965	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	45	°C
170966	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	45	°C
170967	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
170968	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
170969	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
170970	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
170971	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
170972	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
170973	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
170974	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
170975	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
170976	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
170977	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
170978	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
170979	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
170980	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
170981	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
170982	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
170983	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
170984	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
170985	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
170986	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
170987	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
170988	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.5352	
170989	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
170990	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
170991	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
170992	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
170993	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
170994	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
170995	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
170996	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
170997	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
170998	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
170999	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
171000	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
171001	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171002	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
171003	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
171004	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
171005	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
171006	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
171007	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
171008	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
171009	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
171010	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
171011	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
171012	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
171013	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
171014	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
171015	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
171016	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
171017	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
171018	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
171019	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
171020	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171021	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171022	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
171023	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
171024	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
171025	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
171026	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
171027	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
171028	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
171029	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
171030	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
171031	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
171032	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
171033	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
171034	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
171035	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
171036	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
171037	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
171038	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
171039	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	377.0	
171040	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	327.0	
171041	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
171042	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
171043	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
171044	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171045	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
171046	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
171047	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171048	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	335.0	
171049	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
171050	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
171051	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
171052	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171053	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
171054	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
171055	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
171056	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
171057	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
171058	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
171059	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
171060	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
171061	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
171062	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
171063	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
171064	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
171065	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
171066	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
171067	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
171068	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
171069	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	206	
171070	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	206	
171071	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
171072	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
171073	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
171074	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
171075	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.047	millivolts
171076	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171077	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
171078	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
171079	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
171080	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BCH000617	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
171081	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
171082	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171083	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171084	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
171085	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171086	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171087	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171088	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171089	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171090	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
171091	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
171092	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
171093	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
171094	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
171095	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	480.0	
171096	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	480.0	
171097	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	480.0	
171098	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
171099	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
171100	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
171101	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	1	
171102	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
171103	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
171104	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
171105	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
171106	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
171107	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
171108	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
171109	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
171110	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
171111	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
171112	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
171113	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
171114	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
171115	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
171116	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
171117	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	236	
171118	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	236	
171119	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
171120	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
171121	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
171122	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
171123	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
171124	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
171125	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
171126	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
171127	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
171128	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
171129	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
171130	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
171131	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
171132	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
171133	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
171134	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
171135	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
171136	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
171137	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
171138	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
171139	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
171140	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
171141	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
171142	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
171143	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
171144	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
171145	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
171146	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
171147	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
171148	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
171149	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	167	
171150	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	167	
171151	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171152	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
171153	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
171154	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
171155	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
171156	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
171157	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171158	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171159	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
171160	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
171161	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
171162	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171163	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171164	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171165	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171166	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
171167	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171168	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
171169	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
171170	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
171171	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
171172	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
171173	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
171174	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
171175	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
171176	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
171177	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
171178	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171179	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
171180	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
171181	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
171182	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
171183	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
171184	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
171185	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
171186	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
171187	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
171188	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
171189	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
171190	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
171191	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
171192	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
171193	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
171194	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
171195	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
171196	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
171197	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171198	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
171199	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
171200	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171201	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
171202	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
171203	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
171204	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
171205	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
171206	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
171207	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
171208	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
171209	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
171210	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
171211	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
171212	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
171213	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
171214	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
171215	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
171216	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
171217	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
171218	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
171219	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
171220	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
171221	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171222	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171223	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
171224	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
171225	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
171226	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171227	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
171228	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
171229	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
171230	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
171231	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
171232	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
171233	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
171234	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
171235	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171236	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
171237	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
171238	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
171239	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
171240	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
171241	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
171242	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
171243	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
171244	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
171245	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CB0227	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	31	
171246	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
171247	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
171248	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
171249	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
171250	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
171251	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
171252	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
171253	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
171254	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
171255	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
171256	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
171257	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
171258	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
171259	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
171260	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
171261	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
171262	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
171263	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
171264	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
171265	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
171266	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
171267	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
171268	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
171269	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
171270	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1413	
171271	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
171272	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
171273	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
171274	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
171275	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
171276	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
171277	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
171278	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
171279	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
171280	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
171281	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
171282	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
171283	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171284	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
171285	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
171286	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	n	
171287	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
171288	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
171289	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
171290	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
171291	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	Breaker not here new siemens breaker	
171292	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	General Comments	Breaker not here new siemens breaker	
171293	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
171294	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
171295	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
171296	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
171297	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
171298	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	5326	
171299	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	5326	
171300	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
171301	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171302	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
171303	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
171304	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
171305	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-4	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
171306	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
171307	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
171308	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
171309	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
171310	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
171311	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1516	
171312	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1516	
171313	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
171314	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
171315	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
171316	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
171317	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
171318	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-1	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
171319	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
171320	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
171321	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
171322	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	165	
171323	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
171324	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
171325	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
171326	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
171327	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	4614	
171328	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	4614	
171329	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
171330	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
171331	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
171332	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
171333	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
171334	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
171335	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
171336	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
171337	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
171338	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
171339	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171340	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
171341	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
171342	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	n	
171343	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
171344	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
171345	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	y	
171346	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
171347	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	breaker not here new siemens breaker	
171348	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	General Comments	Breaker not here new siemens breaker	
171349	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
171350	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
171351	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
171352	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
171353	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
171354	9/26/2019 9:34	Distribution	Barton City Customer Quarterly Inspection	BtnCty-3	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1413	
171355	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
171356	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
171357	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
171358	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
171359	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
171360	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
171361	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
171362	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
171363	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
171364	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
171365	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
171366	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
171367	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
171368	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
171369	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
171370	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAP000043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
171371	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
171372	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171373	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171374	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171375	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171376	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171377	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171378	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171379	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171380	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171381	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171382	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171383	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171384	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
171385	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171386	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
171387	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171388	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171389	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171390	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171391	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171392	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171393	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
171394	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
171395	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
171396	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
171397	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
171398	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	LTC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
171399	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
171400	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
171401	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
171402	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
171403	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
171404	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
171405	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
171406	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
171407	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
171408	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
171409	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
171410	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
171411	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
171412	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	73	*F
171413	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	BAT000614	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
171414	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
171415	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
171416	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
171417	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
171418	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
171419	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
171420	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
171421	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
171422	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
171423	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
171424	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
171425	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	CAPO00043	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
171426	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
171427	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
171428	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
171429	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
171430	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	Need size info and qty
171431	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
171432	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
171433	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
171434	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
171435	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
171436	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
171437	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
171438	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
171439	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
171440	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
171441	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
171442	9/26/2019 11:27	Distribution	Bardstown Industrial Customer Quarterly Ir	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
171443	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
171444	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
171445	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
171446	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
171447	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
171448	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
171449	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
171450	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
171451	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171452	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
171453	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
171454	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
171455	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
171456	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
171457	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
171458	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
171459	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
171460	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171461	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171462	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
171463	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171464	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171465	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
171466	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171467	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171468	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171469	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171470	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
171471	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171472	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
171473	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
171474	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
171475	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
171476	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
171477	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
171478	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
171479	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
171480	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
171481	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
171482	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
171483	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
171484	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
171485	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
171486	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
171487	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
171488	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171489	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171490	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171491	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171492	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171493	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171494	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171495	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171496	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
171497	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171498	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171499	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171500	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171501	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171502	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
171503	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171504	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171505	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171506	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
171507	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
171508	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2019	
171509	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	82.0	
171510	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
171511	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
171512	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
171513	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
171514	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
171515	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
171516	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
171517	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
171518	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
171519	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
171520	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
171521	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
171522	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
171523	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
171524	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
171525	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
171526	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171527	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
171528	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
171529	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
171530	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
171531	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
171532	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	46	
171533	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
171534	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
171535	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
171536	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
171537	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
171538	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
171539	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
171540	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
171541	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
171542	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
171543	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
171544	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
171545	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
171546	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
171547	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
171548	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
171549	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
171550	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
171551	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
171552	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
171553	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
171554	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
171555	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
171556	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
171557	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	ST000494	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
171558	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
171559	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
171560	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
171561	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
171562	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
171563	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
171564	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
171565	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
171566	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
171567	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
171568	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
171569	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171570	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171571	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
171572	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
171573	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
171574	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
171575	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
171576	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
171577	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
171578	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
171579	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
171580	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	16938.00	kw
171581	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
171582	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
171583	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	60	°C
171584	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	45	°C
171585	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
171586	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
171587	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
171588	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
171589	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
171590	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
171591	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
171592	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
171593	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.9410	
171594	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	45	°C
171595	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	45	°C
171596	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
171597	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
171598	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
171599	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171600	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171601	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171602	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171603	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171604	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171605	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171606	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171607	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
171608	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
171609	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
171610	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
171611	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
171612	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
171613	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
171614	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
171615	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
171616	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	4351.68	kw
171617	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
171618	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
171619	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	70	°C
171620	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	45	°C
171621	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
171622	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
171623	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
171624	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
171625	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
171626	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
171627	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
171628	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
171629	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.9066	
171630	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
171631	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
171632	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171633	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171634	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
171635	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171636	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171637	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171638	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171639	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171640	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171641	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171642	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
171643	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171644	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
171645	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
171646	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
171647	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
171648	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
171649	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	General Comments		
171650	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
171651	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	LTC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
171652	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
171653	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
171654	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
171655	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
171656	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	242	
171657	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	242	
171658	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
171659	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
171660	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
171661	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
171662	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
171663	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
171664	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
171665	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
171666	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
171667	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
171668	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
171669	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
171670	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
171671	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
171672	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
171673	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
171674	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
171675	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
171676	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171677	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
171678	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
171679	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
171680	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
171681	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	495.0	
171682	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	480.0	
171683	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	486.0	
171684	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
171685	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
171686	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
171687	9/26/2019 9:06	Distribution	Barton Quarterly Inspection	K0080	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
171688	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
171689	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171690	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171691	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
171692	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171693	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171694	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171695	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171696	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171697	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171698	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171699	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171700	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
171701	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171702	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171703	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
171704	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
171705	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
171706	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	19749	
171707	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	19749	
171708	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
171709	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	1L	
171710	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	2R	
171711	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	7L	
171712	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
171713	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	1642	
171714	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
171715	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171716	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171717	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
171718	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171719	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
171720	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171721	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171722	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171723	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171724	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171725	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171726	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171727	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171728	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171729	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
171730	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
171731	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171732	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171733	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171734	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171735	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171736	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
171737	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171738	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
171739	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
171740	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
171741	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171742	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171743	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171744	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171745	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
171746	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
171747	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
171748	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
171749	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
171750	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
171751	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
171752	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y		
171753	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y		
171754	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y		
171755	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n		
171756	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments			
171757	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y		
171758	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y		
171759	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good		
171760	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y		
171761	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y		
171762	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y		
171763	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000		
171764	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty	
171765	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None		
171766	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y		
171767	9/26/2019 10:30	Distribution	Bardstown City Customer Quarterly Inspect YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y		
171768	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y		
171769	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean		
171770	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y		
171771	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y		
171772	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
171773	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good		
171774	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good		
171775	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000		
171776	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.6912		
171777	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	74	°C	
171778	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	60	°C	
171779	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00		
171780	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00		
171781	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n		
171782	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n		
171783	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good		
171784	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged		
171785	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y		
171786	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
171787	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
171788	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
171789	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
171790	9/26/2019 13:04	Distribution	Woodlawn Quarterly Inspection CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good		
171791	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y		
171792	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y		
171793	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments			
171794	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good		
171795	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n		
171796	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y		
171797	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None		
171798	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
171799	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	56	°C	
171800	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	73	°C	
171801	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi	
171802	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
171803	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	12441.60	kw	
171804	9/27/2019 7:29	Distribution	Bardstown City Quarterly Inspection CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good		
171805	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y		
171806	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	General Comments			
171807	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments			
171808	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
171809	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good		
171810	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n		
171811	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
171812	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y		
171813	9/26/2019 11:40	Distribution	Bardstown Industrial Quarterly Inspection S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good		
171814	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y		
171815	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments	
171816	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC	
171817	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC	
171818	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments			
171819	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n		
171820	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good		
171821	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments	
171822	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s	
171823	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments	
171824	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments	
171825	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y		
171826	9/25/2019 11:35	Distribution	West Point Quarterly Inspection BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
171827	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
171828	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
171829	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
171830	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
171831	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	162	
171832	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
171833	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	5	
171834	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
171835	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
171836	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
171837	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
171838	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
171839	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
171840	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
171841	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
171842	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
171843	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
171844	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
171845	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	152	
171846	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	152	
171847	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
171848	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
171849	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
171850	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
171851	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
171852	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
171853	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
171854	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
171855	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
171856	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
171857	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
171858	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
171859	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
171860	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
171861	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171862	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171863	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
171864	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171865	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
171866	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
171867	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
171868	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
171869	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
171870	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
171871	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
171872	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
171873	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
171874	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	9288.00	kw
171875	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
171876	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
171877	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
171878	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
171879	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
171880	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
171881	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
171882	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
171883	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
171884	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
171885	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
171886	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
171887	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.5160	
171888	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	60	°C
171889	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	40	°C
171890	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
171891	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
171892	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
171893	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
171894	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171895	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171896	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
171897	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
171898	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
171899	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	6	
171900	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
171901	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
171902	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
171903	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
171904	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
171905	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
171906	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
171907	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
171908	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
171909	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
171910	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
171911	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
171912	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
171913	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
171914	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
171915	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
171916	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
171917	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
171918	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
171919	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
171920	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
171921	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
171922	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
171923	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
171924	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
171925	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
171926	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
171927	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
171928	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
171929	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	321	
171930	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
171931	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
171932	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
171933	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
171934	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
171935	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
171936	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
171937	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
171938	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
171939	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
171940	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
171941	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
171942	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
171943	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
171944	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
171945	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
171946	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
171947	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
171948	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
171949	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
171950	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
171951	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
171952	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
171953	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
171954	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
171955	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
171956	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BCH000481	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
171957	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
171958	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
171959	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	19.6	VDC
171960	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	17.3	VDC
171961	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
171962	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
171963	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
171964	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
171965	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
171966	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
171967	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
171968	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	1	
171969	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
171970	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
171971	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
171972	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
171973	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
171974	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
171975	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
171976	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
171977	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
171978	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
171979	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
171980	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
171981	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
171982	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
171983	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
171984	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
171985	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
171986	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
171987	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
171988	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
171989	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
171990	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
171991	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
171992	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
171993	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
171994	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
171995	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	302	
171996	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
171997	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
171998	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
171999	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
172000	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
172001	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172002	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172003	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172004	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172005	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
172006	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172007	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
172008	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
172009	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172010	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
172011	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
172012	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
172013	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
172014	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172015	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172016	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
172017	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
172018	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
172019	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	339	
172020	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172021	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
172022	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
172023	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
172024	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
172025	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172026	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
172027	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
172028	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
172029	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
172030	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
172031	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
172032	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172033	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172034	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172035	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172036	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172037	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172038	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172039	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172040	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172041	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
172042	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	153.0	
172043	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	313.0	
172044	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	132.0	
172045	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172046	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172047	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172048	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	4	
172049	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172050	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	1	
172051	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172052	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
172053	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
172054	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
172055	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
172056	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
172057	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
172058	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
172059	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
172060	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
172061	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
172062	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
172063	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
172064	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
172065	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
172066	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
172067	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
172068	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
172069	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
172070	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
172071	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
172072	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
172073	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
172074	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
172075	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
172076	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	7232	
172077	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	7232	
172078	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
172079	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	7L	
172080	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
172081	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
172082	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
172083	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
172084	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
172085	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
172086	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
172087	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	4L	
172088	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	9L	
172089	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
172090	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
172091	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
172092	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
172093	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172094	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	118210	
172095	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
172096	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
172097	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
172098	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	11	
172099	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172100	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172101	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172102	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
172103	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
172104	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments	...	
172105	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
172106	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
172107	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
172108	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
172109	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
172110	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
172111	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
172112	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	190.0	
172113	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	240.0	
172114	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
172115	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
172116	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172117	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172118	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172119	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172120	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172121	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172122	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172123	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172124	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172125	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
172126	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172127	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
172128	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
172129	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
172130	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
172131	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
172132	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
172133	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
172134	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
172135	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172136	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
172137	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
172138	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	336	
172139	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	341	
172140	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	7	
172141	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172142	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	7	
172143	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172144	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
172145	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
172146	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
172147	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	1	
172148	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
172149	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	99985	
172150	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	99985	
172151	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
172152	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
172153	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172154	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
172155	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
172156	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
172157	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
172158	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
172159	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
172160	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
172161	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
172162	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
172163	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
172164	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
172165	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
172166	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172167	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172168	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
172169	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172170	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
172171	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
172172	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	702	
172173	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	702	
172174	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
172175	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
172176	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172177	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
172178	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
172179	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
172180	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
172181	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
172182	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
172183	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
172184	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
172185	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
172186	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
172187	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
172188	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
172189	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
172190	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
172191	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
172192	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
172193	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172194	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172195	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172196	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172197	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172198	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172199	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	
172200	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If low,note cell #'s
172201	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172202	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
172203	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
172204	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
172205	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
172206	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BAT000419	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
172207	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172208	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172209	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172210	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
172211	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Amps C Ø	135.0	
172212	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
172213	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
172214	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172215	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172216	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172217	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
172218	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172219	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	180.0	
172220	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	240.0	
172221	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	240.0	
172222	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	5.05	%
172223	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	4.49	%
172224	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	4.49	%
172225	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	6	
172226	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
172227	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
172228	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
172229	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
172230	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172231	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172232	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	5R	
172233	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	14R	
172234	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
172235	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
172236	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172237	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
172238	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
172239	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172240	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	10R	
172241	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172242	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172243	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172244	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172245	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
172246	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
172247	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
172248	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
172249	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172250	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
172251	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
172252	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
172253	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
172254	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
172255	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
172256	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
172257	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
172258	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
172259	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
172260	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
172261	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
172262	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
172263	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
172264	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
172265	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
172266	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172267	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172268	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
172269	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	6R	
172270	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	1552	
172271	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
172272	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
172273	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
172274	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
172275	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
172276	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
172277	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172278	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
172279	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
172280	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172281	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	4R	
172282	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172283	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172284	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172285	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172286	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
172287	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
172288	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
172289	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
172290	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	436	
172291	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	436	
172292	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
172293	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
172294	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
172295	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
172296	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
172297	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
172298	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
172299	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
172300	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
172301	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
172302	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
172303	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
172304	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172305	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172306	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172307	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
172308	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
172309	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
172310	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
172311	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172312	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172313	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172314	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	200.0	
172315	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	200.0	
172316	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	200.0	
172317	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	200.0	
172318	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
172319	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	17.18	%
172320	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.18	%
172321	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
172322	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
172323	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
172324	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	10	
172325	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
172326	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172327	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
172328	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172329	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
172330	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	212	
172331	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	207	
172332	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
172333	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
172334	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172335	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
172336	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
172337	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
172338	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
172339	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
172340	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
172341	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
172342	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
172343	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
172344	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.46	%
172345	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
172346	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
172347	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
172348	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
172349	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
172350	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	380.0	
172351	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	175.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172352	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	135.0	
172353	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172354	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172355	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172356	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
172357	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
172358	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
172359	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
172360	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
172361	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
172362	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
172363	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	418	
172364	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	418	
172365	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
172366	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
172367	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
172368	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
172369	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172370	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172371	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172372	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
172373	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
172374	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172375	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172376	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172377	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
172378	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
172379	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
172380	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
172381	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
172382	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
172383	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
172384	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
172385	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
172386	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
172387	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
172388	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
172389	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
172390	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
172391	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
172392	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.9750	
172393	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	85	°C
172394	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	65	°C
172395	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
172396	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
172397	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
172398	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
172399	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
172400	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
172401	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	200.0	
172402	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	270.0	
172403	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	245.0	
172404	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172405	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172406	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172407	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
172408	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
172409	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
172410	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
172411	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
172412	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
172413	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
172414	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	511	
172415	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	511	
172416	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
172417	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
172418	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
172419	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
172420	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
172421	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
172422	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
172423	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
172424	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
172425	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
172426	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
172427	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
172428	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
172429	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
172430	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
172431	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
172432	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
172433	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
172434	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
172435	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172436	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172437	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172438	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
172439	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
172440	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
172441	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
172442	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
172443	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
172444	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
172445	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
172446	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
172447	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
172448	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	301	
172449	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	301	
172450	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
172451	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
172452	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
172453	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
172454	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
172455	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
172456	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
172457	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
172458	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
172459	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
172460	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
172461	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
172462	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
172463	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
172464	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172465	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
172466	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
172467	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	6R	
172468	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
172469	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172470	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172471	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
172472	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
172473	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
172474	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	29790	
172475	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172476	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
172477	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
172478	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172479	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
172480	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
172481	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	239	
172482	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	245	
172483	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
172484	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172485	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
172486	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172487	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B80292	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
172488	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
172489	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
172490	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
172491	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
172492	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172493	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
172494	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	163	
172495	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	63	
172496	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
172497	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
172498	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172499	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
172500	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
172501	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172502	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
172503	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
172504	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
172505	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
172506	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C \emptyset	0	
172507	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B \emptyset	0	
172508	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A \emptyset	0	
172509	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172510	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172511	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172512	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172513	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172514	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172515	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172516	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172517	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172518	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
172519	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C \emptyset	485.0	
172520	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B \emptyset	475.0	
172521	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A \emptyset	470.0	
172522	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172523	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172524	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172525	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	2	
172526	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps B \emptyset	100.0	
172527	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
172528	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
172529	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
172530	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
172531	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
172532	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	General Comments		
172533	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
172534	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
172535	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
172536	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
172537	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
172538	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
172539	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
172540	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
172541	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
172542	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
172543	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
172544	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps C \emptyset	120.0	
172545	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
172546	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172547	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172548	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172549	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
172550	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A \emptyset	0	
172551	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172552	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172553	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172554	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172555	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172556	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172557	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172558	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172559	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172560	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172561	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172562	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172563	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
172564	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C \emptyset	150.0	
172565	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B \emptyset	170.0	
172566	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A \emptyset	150.0	
172567	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172568	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172569	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172570	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
172571	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
172572	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
172573	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
172574	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
172575	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
172576	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172577	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
172578	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172579	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172580	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172581	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
172582	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
172583	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
172584	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
172585	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
172586	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
172587	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
172588	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
172589	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
172590	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
172591	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
172592	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172593	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172594	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172595	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172596	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	4R	
172597	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172598	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
172599	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
172600	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
172601	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
172602	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
172603	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
172604	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
172605	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
172606	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
172607	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
172608	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
172609	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
172610	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
172611	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
172612	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
172613	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
172614	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
172615	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
172616	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
172617	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172618	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172619	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
172620	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
172621	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
172622	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172623	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
172624	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
172625	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
172626	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172627	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172628	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
172629	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
172630	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172631	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
172632	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
172633	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172634	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
172635	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
172636	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172637	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
172638	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
172639	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
172640	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
172641	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
172642	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
172643	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
172644	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
172645	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
172646	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172647	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172648	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172649	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172650	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172651	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172652	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172653	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172654	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
172655	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
172656	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
172657	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
172658	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	
172659	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
172660	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
172661	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172662	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations This Read Vac	0	
172663	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	201	
172664	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	201	
172665	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
172666	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
172667	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172668	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
172669	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
172670	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
172671	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
172672	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
172673	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
172674	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
172675	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
172676	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
172677	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
172678	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172679	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
172680	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
172681	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
172682	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
172683	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
172684	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
172685	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
172686	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	25	
172687	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	20	
172688	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	17	
172689	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
172690	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
172691	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
172692	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
172693	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	General Comments		
172694	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
172695	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
172696	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
172697	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
172698	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
172699	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
172700	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
172701	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	18	
172702	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
172703	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
172704	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
172705	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	190.0	
172706	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	190.0	
172707	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	190.0	
172708	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172709	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172710	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172711	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
172712	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
172713	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
172714	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
172715	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
172716	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments		
172717	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
172718	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	859	
172719	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	859	
172720	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations This Read AM	0	
172721	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	0	
172722	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
172723	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
172724	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172725	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172726	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172727	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
172728	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
172729	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
172730	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
172731	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0156	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
172732	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
172733	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
172734	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
172735	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
172736	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
172737	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
172738	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
172739	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
172740	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
172741	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
172742	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
172743	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
172744	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
172745	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
172746	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
172747	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
172748	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
172749	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172750	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172751	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
172752	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
172753	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
172754	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
172755	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
172756	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	800.0	
172757	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	720.0	
172758	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	720.0	
172759	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172760	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172761	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172762	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	1	
172763	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
172764	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
172765	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
172766	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
172767	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
172768	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
172769	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
172770	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172771	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172772	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172773	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172774	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172775	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172776	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172777	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172778	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172779	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	160	
172780	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
172781	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
172782	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172783	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
172784	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172785	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
172786	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
172787	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
172788	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
172789	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
172790	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
172791	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
172792	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
172793	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
172794	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
172795	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
172796	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
172797	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
172798	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
172799	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
172800	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
172801	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172802	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
172803	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
172804	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	17550.00	kw
172805	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
172806	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
172807	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	60	*C
172808	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	50	*C
172809	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
172810	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
172811	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
172812	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
172813	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
172814	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
172815	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	400.0	
172816	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	460.0	
172817	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	400.0	
172818	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172819	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172820	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172821	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
172822	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
172823	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
172824	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
172825	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	244	
172826	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	244	
172827	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
172828	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
172829	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
172830	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
172831	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
172832	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
172833	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
172834	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
172835	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
172836	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
172837	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
172838	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
172839	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
172840	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
172841	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
172842	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
172843	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
172844	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
172845	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
172846	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
172847	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
172848	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
172849	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172850	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172851	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172852	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
172853	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
172854	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
172855	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
172856	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
172857	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
172858	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
172859	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	163	
172860	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	163	
172861	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
172862	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
172863	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
172864	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172865	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
172866	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
172867	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
172868	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
172869	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
172870	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
172871	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
172872	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
172873	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
172874	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
172875	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	145	
172876	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	145	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172877	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
172878	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
172879	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
172880	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
172881	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172882	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172883	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
172884	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
172885	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
172886	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
172887	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
172888	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
172889	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
172890	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
172891	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
172892	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
172893	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
172894	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
172895	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
172896	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
172897	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
172898	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
172899	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
172900	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
172901	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
172902	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
172903	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
172904	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172905	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172906	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172907	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172908	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172909	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
172910	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
172911	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
172912	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
172913	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
172914	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
172915	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
172916	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	28	°C
172917	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
172918	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
172919	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
172920	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
172921	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
172922	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
172923	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
172924	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	3	
172925	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
172926	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
172927	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
172928	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	19.0	
172929	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	18.0	
172930	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	17.0	
172931	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
172932	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
172933	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
172934	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
172935	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
172936	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
172937	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
172938	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
172939	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
172940	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
172941	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
172942	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
172943	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
172944	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
172945	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
172946	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
172947	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
172948	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
172949	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
172950	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
172951	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
172952	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
172953	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
172954	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
172955	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
172956	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
172957	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	50.0	
172958	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	70.0	
172959	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	40.0	
172960	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
172961	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
172962	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
172963	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
172964	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
172965	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
172966	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
172967	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
172968	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
172969	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
172970	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	343	
172971	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	343	
172972	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
172973	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	234	
172974	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	234	
172975	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
172976	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172977	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
172978	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
172979	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
172980	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
172981	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
172982	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
172983	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
172984	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
172985	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	6	
172986	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
172987	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
172988	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
172989	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
172990	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
172991	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
172992	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
172993	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
172994	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
172995	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
172996	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
172997	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
172998	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	224.16	kw
172999	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
173000	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
173001	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
173002	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	28	°C
173003	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
173004	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
173005	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173006	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
173007	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
173008	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
173009	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173010	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
173011	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2802	
173012	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
173013	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173014	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173015	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173016	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173017	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
173018	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
173019	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
173020	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
173021	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
173022	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
173023	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
173024	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
173025	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
173026	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173027	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
173028	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
173029	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
173030	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
173031	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
173032	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173033	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
173034	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
173035	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
173036	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
173037	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
173038	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
173039	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
173040	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
173041	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	23	°C
173042	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
173043	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
173044	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173045	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
173046	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
173047	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
173048	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173049	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
173050	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173051	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173052	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173053	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173054	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
173055	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
173056	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173057	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
173058	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
173059	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
173060	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
173061	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
173062	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
173063	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
173064	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
173065	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
173066	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	177	
173067	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	177	
173068	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	0	
173069	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	0	
173070	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
173071	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
173072	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
173073	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
173074	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
173075	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
173076	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
173077	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173078	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173079	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
173080	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
173081	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
173082	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
173083	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173084	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
173085	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
173086	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173087	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
173088	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
173089	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173090	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
173091	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
173092	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
173093	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	13966.08	kw
173094	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
173095	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
173096	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	65	°C
173097	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	50	°C
173098	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
173099	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
173100	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173101	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173102	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
173103	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
173104	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173105	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
173106	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	1.4548	
173107	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
173108	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
173109	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
173110	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	75	°C
173111	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	55	°C
173112	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	95.00	
173113	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
173114	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
173115	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
173116	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
173117	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
173118	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
173119	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
173120	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
173121	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
173122	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
173123	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
173124	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
173125	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
173126	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
173127	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.43	%
173128	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.43	%
173129	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.43	%
173130	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
173131	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
173132	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
173133	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
173134	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
173135	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
173136	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
173137	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
173138	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
173139	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
173140	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
173141	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
173142	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
173143	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
173144	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
173145	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
173146	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
173147	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
173148	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
173149	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
173150	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	1	
173151	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173152	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173153	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173154	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	129.0	
173155	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	134.0	
173156	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	124.0	
173157	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
173158	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
173159	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
173160	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
173161	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
173162	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99774	
173163	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99767	
173164	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
173165	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
173166	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173167	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
173168	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
173169	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
173170	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
173171	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
173172	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
173173	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
173174	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
173175	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
173176	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173177	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173178	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173179	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173180	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173181	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173182	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173183	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173184	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173185	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173186	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173187	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173188	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173189	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
173190	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
173191	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
173192	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
173193	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
173194	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
173195	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173196	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173197	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173198	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173199	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173200	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173201	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
173202	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
173203	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
173204	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
173205	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173206	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173207	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0455	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173208	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
173209	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
173210	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	0	
173211	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
173212	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
173213	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173214	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173215	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
173216	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
173217	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
173218	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
173219	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173220	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
173221	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
173222	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173223	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
173224	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
173225	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
173226	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
173227	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
173228	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
173229	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
173230	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	19	
173231	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	19	
173232	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
173233	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
173234	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173235	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
173236	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
173237	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
173238	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
173239	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
173240	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
173241	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
173242	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
173243	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
173244	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
173245	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173246	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173247	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173248	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173249	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173250	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173251	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173252	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173253	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173254	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
173255	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173256	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
173257	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
173258	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
173259	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	15818.40	kw
173260	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
173261	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
173262	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	45	°C
173263	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	45	°C
173264	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
173265	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
173266	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
173267	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
173268	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173269	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
173270	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
173271	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
173272	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173273	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
173274	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	1.0985	
173275	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	70	°C
173276	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	45	°C
173277	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
173278	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
173279	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	0	
173280	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
173281	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	.56	%
173282	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
173283	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
173284	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
173285	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
173286	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	6.0	
173287	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
173288	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
173289	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
173290	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
173291	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
173292	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
173293	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
173294	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
173295	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
173296	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
173297	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	375	
173298	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	375	
173299	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
173300	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
173301	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
173302	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
173303	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
173304	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
173305	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
173306	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
173307	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
173308	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
173309	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
173310	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173311	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173312	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
173313	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173314	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
173315	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
173316	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
173317	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
173318	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	220.0	
173319	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	200.0	
173320	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	120.0	
173321	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
173322	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
173323	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
173324	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
173325	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
173326	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	856.80	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173327	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
173328	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
173329	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	44	°C
173330	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	28	°C
173331	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
173332	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
173333	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
173334	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
173335	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173336	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173337	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173338	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
173339	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
173340	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
173341	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
173342	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173343	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173344	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173345	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173346	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173347	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173348	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173349	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
173350	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173351	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
173352	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
173353	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173354	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
173355	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.0476	
173356	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	40	°C
173357	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
173358	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
173359	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
173360	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
173361	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
173362	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
173363	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
173364	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
173365	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
173366	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
173367	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
173368	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
173369	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
173370	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
173371	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
173372	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
173373	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
173374	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
173375	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173376	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173377	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173378	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173379	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173380	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173381	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173382	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173383	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173384	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
173385	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	55.0	
173386	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	32.0	
173387	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
173388	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
173389	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
173390	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	53.0	
173391	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173392	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173393	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173394	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	23	
173395	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
173396	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173397	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173398	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173399	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
173400	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
173401	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173402	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173403	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	100.0	
173404	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
173405	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	100.0	
173406	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
173407	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173408	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173409	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173410	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173411	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173412	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173413	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173414	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173415	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173416	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
173417	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
173418	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
173419	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
173420	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
173421	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
173422	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
173423	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
173424	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
173425	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
173426	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173427	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
173428	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
173429	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	21	
173430	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	27	
173431	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	6	
173432	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	.56	%
173433	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
173434	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	207.0	
173435	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	195.0	
173436	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173437	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173438	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173439	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
173440	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	80.0	
173441	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	70.0	
173442	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	70.0	
173443	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
173444	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
173445	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
173446	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
173447	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
173448	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
173449	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
173450	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
173451	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
173452	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
173453	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	351	
173454	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	351	
173455	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	26	°C
173456	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173457	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173458	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
173459	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
173460	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
173461	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
173462	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
173463	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
173464	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
173465	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
173466	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
173467	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
173468	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173469	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
173470	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
173471	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	29	
173472	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	31	
173473	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
173474	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
173475	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
173476	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173477	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
173478	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
173479	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
173480	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	0	
173481	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
173482	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	0	
173483	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	892	
173484	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	892	
173485	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
173486	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
173487	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
173488	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
173489	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
173490	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
173491	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
173492	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
173493	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
173494	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
173495	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
173496	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
173497	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
173498	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
173499	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
173500	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
173501	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
173502	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
173503	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173504	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
173505	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
173506	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	34	
173507	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
173508	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
173509	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	38	
173510	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	38	
173511	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
173512	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
173513	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
173514	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
173515	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
173516	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
173517	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
173518	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
173519	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
173520	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
173521	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
173522	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
173523	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
173524	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
173525	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	Neutral	
173526	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	6R	
173527	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
173528	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
173529	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	4R	
173530	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
173531	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
173532	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173533	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173534	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173535	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
173536	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
173537	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
173538	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
173539	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173540	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173541	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
173542	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
173543	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
173544	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
173545	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
173546	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
173547	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
173548	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
173549	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC000642	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
173550	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
173551	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173552	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
173553	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
173554	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
173555	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
173556	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
173557	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
173558	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
173559	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
173560	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
173561	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
173562	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
173563	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
173564	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
173565	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
173566	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	General Comments		
173567	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
173568	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
173569	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173570	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173571	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173572	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173573	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173574	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173575	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173576	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
173577	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
173578	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
173579	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
173580	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
173581	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
173582	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
173583	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
173584	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
173585	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
173586	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
173587	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173588	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173589	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173590	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	19.0	
173591	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	18.0	
173592	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
173593	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
173594	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
173595	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
173596	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
173597	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
173598	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	17.0	
173599	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
173600	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173601	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173602	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173603	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173604	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173605	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
173606	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
173607	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
173608	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
173609	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
173610	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
173611	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
173612	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	10R	
173613	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
173614	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
173615	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	14R	
173616	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	5R	
173617	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
173618	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
173619	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
173620	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
173621	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
173622	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	118210	
173623	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	118210	
173624	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
173625	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
173626	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
173627	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173628	9/25/2019 14:32	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
173629	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173630	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173631	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
173632	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
173633	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
173634	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
173635	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
173636	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
173637	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
173638	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
173639	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
173640	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
173641	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
173642	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
173643	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
173644	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
173645	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
173646	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
173647	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
173648	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
173649	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
173650	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
173651	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
173652	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
173653	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
173654	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
173655	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
173656	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
173657	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
173658	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	361	
173659	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	361	
173660	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
173661	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
173662	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
173663	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
173664	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
173665	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
173666	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
173667	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
173668	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
173669	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
173670	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
173671	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
173672	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
173673	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
173674	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
173675	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
173676	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
173677	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
173678	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
173679	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BAT000628	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
173680	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
173681	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
173682	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	32	*C
173683	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	72	*C
173684	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.9960	
173685	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
173686	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
173687	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
173688	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
173689	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
173690	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
173691	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
173692	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
173693	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
173694	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
173695	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	22	*C
173696	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	70	*C
173697	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
173698	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
173699	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	17928.00	kw
173700	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
173701	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173702	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
173703	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173704	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
173705	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
173706	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173707	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
173708	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
173709	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
173710	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
173711	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
173712	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
173713	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
173714	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
173715	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
173716	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
173717	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
173718	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
173719	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
173720	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
173721	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
173722	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
173723	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
173724	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
173725	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	81	*F
173726	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
173727	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
173728	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
173729	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
173730	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BAT000550	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
173731	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
173732	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
173733	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
173734	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
173735	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
173736	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
173737	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
173738	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
173739	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
173740	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
173741	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
173742	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
173743	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
173744	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
173745	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
173746	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
173747	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
173748	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
173749	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
173750	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
173751	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
173752	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
173753	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
173754	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
173755	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
173756	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
173757	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
173758	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
173759	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
173760	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	BB0277	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
173761	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
173762	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
173763	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	FE000365	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
173764	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	6	
173765	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
173766	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
173767	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
173768	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
173769	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
173770	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	BCH000563	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
173771	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
173772	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
173773	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
173774	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
173775	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
173776	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	BCH000574	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
173777	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.064	millivolts
173778	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
173779	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
173780	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
173781	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
173782	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BCH000392	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
173783	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
173784	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	1.68	%
173785	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	2.25	%
173786	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	130.0	
173787	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	130.0	
173788	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	130.0	
173789	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
173790	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
173791	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
173792	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
173793	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
173794	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
173795	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
173796	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
173797	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
173798	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
173799	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
173800	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
173801	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
173802	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	General Comments		
173803	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
173804	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	LTC0000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
173805	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
173806	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173807	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173808	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173809	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173810	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173811	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173812	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173813	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
173814	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
173815	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
173816	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
173817	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
173818	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
173819	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
173820	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
173821	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
173822	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
173823	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
173824	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
173825	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	163	
173826	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	163	
173827	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	1	
173828	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	1	
173829	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
173830	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
173831	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
173832	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
173833	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
173834	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
173835	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
173836	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
173837	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
173838	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
173839	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
173840	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
173841	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
173842	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
173843	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	8985.60	kw
173844	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
173845	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
173846	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	70	°C
173847	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	40	°C
173848	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
173849	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	49.5	VDC
173850	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	49.5	VDC
173851	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
173852	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
173853	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
173854	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
173855	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
173856	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
173857	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
173858	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
173859	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
173860	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
173861	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	45.0	
173862	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
173863	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	4	
173864	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173865	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173866	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173867	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	19.0	
173868	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	16.0	
173869	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	7.0	
173870	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
173871	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173872	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173873	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173874	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173875	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173876	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173877	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
173878	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
173879	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
173880	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
173881	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
173882	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
173883	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
173884	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
173885	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
173886	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
173887	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
173888	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
173889	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
173890	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1870	
173891	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1870	
173892	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
173893	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
173894	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
173895	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
173896	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
173897	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
173898	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	15	
173899	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
173900	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
173901	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
173902	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
173903	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
173904	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
173905	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
173906	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
173907	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
173908	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
173909	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
173910	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
173911	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
173912	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
173913	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
173914	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
173915	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
173916	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
173917	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
173918	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
173919	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
173920	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
173921	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
173922	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
173923	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
173924	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
173925	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
173926	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
173927	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
173928	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
173929	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	11.0	
173930	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
173931	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
173932	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
173933	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
173934	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
173935	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
173936	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
173937	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
173938	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	92	
173939	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
173940	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
173941	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
173942	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
173943	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
173944	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
173945	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	3	
173946	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173947	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173948	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173949	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	65.0	
173950	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	86.0	
173951	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	85.0	
173952	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
173953	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173954	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173955	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
173956	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
173957	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
173958	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
173959	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
173960	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
173961	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
173962	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
173963	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
173964	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
173965	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
173966	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
173967	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
173968	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
173969	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
173970	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
173971	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
173972	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	3	
173973	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
173974	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
173975	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
173976	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	422.0	
173977	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	431.0	
173978	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	418.0	
173979	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
173980	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
173981	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
173982	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
173983	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
173984	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
173985	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
173986	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	10.13	
173987	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	10.13	
173988	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	10.13	
173989	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
173990	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
173991	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
173992	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
173993	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
173994	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
173995	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
173996	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
173997	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
173998	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
173999	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
174000	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
174001	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174002	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
174003	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
174004	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174005	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
174006	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
174007	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	237	
174008	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	237	
174009	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	2	
174010	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174011	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	0	
174012	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
174013	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	2	
174014	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
174015	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
174016	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
174017	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
174018	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
174019	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
174020	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
174021	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
174022	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
174023	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
174024	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
174025	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
174026	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
174027	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
174028	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
174029	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
174030	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
174031	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
174032	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
174033	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
174034	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
174035	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
174036	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
174037	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	
174038	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
174039	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
174040	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
174041	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
174042	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174043	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
174044	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
174045	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
174046	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
174047	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
174048	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
174049	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	158	
174050	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	158	
174051	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	1	
174052	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	1	
174053	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
174054	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
174055	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174056	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174057	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
174058	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
174059	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174060	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
174061	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.4992	
174062	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	50 °C	
174063	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	50 °C	
174064	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
174065	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
174066	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
174067	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
174068	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
174069	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
174070	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
174071	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
174072	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
174073	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
174074	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
174075	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
174076	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174077	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
174078	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
174079	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
174080	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
174081	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
174082	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
174083	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
174084	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	2472.00	kw
174085	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
174086	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
174087	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	45	*C
174088	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	40	*C
174089	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174090	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
174091	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174092	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174093	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
174094	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
174095	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174096	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
174097	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.5150	
174098	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
174099	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
174100	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
174101	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
174102	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
174103	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
174104	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
174105	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
174106	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
174107	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
174108	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
174109	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
174110	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
174111	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
174112	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
174113	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
174114	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
174115	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
174116	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
174117	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
174118	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
174119	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
174120	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
174121	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
174122	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
174123	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174124	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
174125	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
174126	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
174127	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
174128	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
174129	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
174130	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
174131	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
174132	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
174133	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
174134	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
174135	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
174136	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
174137	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
174138	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
174139	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
174140	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
174141	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
174142	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
174143	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
174144	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
174145	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
174146	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
174147	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
174148	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	FE000301	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
174149	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
174150	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
174151	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174152	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
174153	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
174154	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
174155	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
174156	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
174157	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
174158	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
174159	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
174160	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
174161	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
174162	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
174163	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174164	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
174165	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
174166	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
174167	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
174168	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
174169	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
174170	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
174171	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
174172	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
174173	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
174174	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
174175	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
174176	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
174177	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
174178	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
174179	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
174180	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
174181	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
174182	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
174183	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
174184	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
174185	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
174186	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
174187	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
174188	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174189	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174190	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174191	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174192	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174193	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174194	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174195	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174196	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174197	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
174198	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	92.0	
174199	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	90.0	
174200	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	88.0	
174201	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174202	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174203	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174204	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	1	
174205	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174206	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
174207	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
174208	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
174209	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
174210	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
174211	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
174212	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
174213	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
174214	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
174215	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
174216	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
174217	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
174218	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
174219	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
174220	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
174221	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
174222	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
174223	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
174224	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
174225	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174226	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174227	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174228	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174229	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174230	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174231	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174232	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174233	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174234	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
174235	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	312.0	
174236	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	311.0	
174237	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	306.0	
174238	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174239	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174240	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174241	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	1	
174242	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174243	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4317	
174244	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4317	
174245	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
174246	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
174247	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
174248	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
174249	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174250	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
174251	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	957	
174252	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	957	
174253	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
174254	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
174255	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174256	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
174257	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	no targets besides on ground relay	
174258	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
174259	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
174260	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
174261	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
174262	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
174263	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
174264	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174265	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174266	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174267	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	1486	
174268	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	11L	
174269	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	2R	
174270	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
174271	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
174272	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
174273	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
174274	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174275	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174276	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174277	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
174278	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174279	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174280	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174281	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174282	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174283	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174284	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174285	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
174286	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
174287	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
174288	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
174289	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
174290	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
174291	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	0	
174292	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	7.3	%
174293	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	480.0	
174294	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	445.0	
174295	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	9.54	%
174296	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	6.17	%
174297	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	220.0	
174298	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	100.0	
174299	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	140.0	
174300	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
174301	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174302	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
174303	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	475.0	
174304	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174305	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174306	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174307	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174308	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174309	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174310	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	0	
174311	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
174312	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	2R	
174313	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	2R	
174314	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	2R	
174315	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
174316	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
174317	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	0	
174318	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174319	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	0	
174320	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	276	
174321	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	276	
174322	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
174323	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
174324	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174325	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
174326	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
174327	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
174328	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
174329	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
174330	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
174331	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
174332	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
174333	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
174334	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
174335	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
174336	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
174337	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
174338	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
174339	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
174340	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
174341	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
174342	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	20	
174343	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
174344	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
174345	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	20.48	%
174346	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	300.0	
174347	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	300.0	
174348	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	300.0	
174349	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
174350	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
174351	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
174352	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
174353	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
174354	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
174355	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
174356	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	0	
174357	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
174358	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	
174359	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	
174360	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
174361	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments		
174362	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
174363	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	308	
174364	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	308	
174365	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	0	
174366	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
174367	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
174368	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
174369	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
174370	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
174371	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
174372	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
174373	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
174374	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
174375	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
174376	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174377	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
174378	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	17863.20	kw
174379	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
174380	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174381	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174382	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174383	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174384	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
174385	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
174386	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
174387	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
174388	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
174389	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
174390	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
174391	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
174392	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
174393	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
174394	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174395	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
174396	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
174397	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	702	
174398	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	702	
174399	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
174400	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174401	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
174402	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
174403	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
174404	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
174405	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments	Barbed Wire broke on south fence. needs to be replaced.	
174406	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
174407	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
174408	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174409	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174410	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174411	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	493.0	
174412	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	504.0	
174413	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	471.0	
174414	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
174415	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174416	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174417	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174418	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174419	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174420	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174421	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174422	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174423	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174424	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
174425	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
174426	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	5	
174427	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
174428	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
174429	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
174430	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
174431	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
174432	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
174433	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
174434	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
174435	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
174436	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
174437	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
174438	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
174439	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
174440	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
174441	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
174442	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	190.0	
174443	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
174444	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
174445	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
174446	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
174447	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
174448	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
174449	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
174450	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
174451	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174452	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
174453	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	2	
174454	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	2	
174455	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
174456	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
174457	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
174458	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
174459	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
174460	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
174461	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	126115	
174462	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	126115	
174463	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174464	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
174465	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
174466	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
174467	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
174468	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
174469	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
174470	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
174471	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
174472	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
174473	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
174474	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
174475	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
174476	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
174477	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
174478	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
174479	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
174480	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
174481	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
174482	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	1R	
174483	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	10R	
174484	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	8L	
174485	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	1677	
174486	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
174487	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174488	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174489	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174490	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
174491	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	*C
174492	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
174493	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
174494	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174495	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
174496	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174497	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174498	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
174499	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
174500	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
174501	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
174502	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174503	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
174504	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.9924	
174505	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Max	70	*C
174506	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
174507	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
174508	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
174509	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
174510	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
174511	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
174512	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
174513	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
174514	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
174515	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
174516	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
174517	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
174518	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
174519	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
174520	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
174521	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
174522	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
174523	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
174524	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
174525	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	0	
174526	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174527	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	0	
174528	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	310	
174529	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	310	
174530	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
174531	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
174532	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174533	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	8	
174534	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
174535	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
174536	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
174537	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	230.0	
174538	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	230.0	
174539	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
174540	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
174541	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
174542	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
174543	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
174544	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
174545	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
174546	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
174547	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
174548	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
174549	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174550	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	166831	
174551	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	166831	
174552	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Needs Desiccant replaced.	
174553	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
174554	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
174555	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
174556	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	721	
174557	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
174558	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
174559	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
174560	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
174561	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
174562	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
174563	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
174564	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
174565	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
174566	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
174567	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	0.0	
174568	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	0.0	
174569	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	0.0	
174570	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
174571	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	.56	%
174572	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	15L	
174573	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	2494	
174574	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174575	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174576	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174577	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
174578	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
174579	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
174580	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
174581	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
174582	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
174583	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
174584	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
174585	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
174586	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
174587	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
174588	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
174589	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
174590	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
174591	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
174592	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
174593	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
174594	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
174595	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
174596	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
174597	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
174598	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
174599	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
174600	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
174601	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
174602	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174603	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
174604	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
174605	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
174606	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
174607	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
174608	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
174609	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
174610	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
174611	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	125283	
174612	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	125283	
174613	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174614	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	4L	
174615	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
174616	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	10	
174617	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174618	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
174619	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
174620	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
174621	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
174622	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
174623	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
174624	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
174625	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174626	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174627	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	50.0	
174628	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	60.0	
174629	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	50.0	
174630	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
174631	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
174632	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	0	
174633	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	721	
174634	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
174635	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174636	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174637	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174638	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174639	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174640	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174641	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174642	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174643	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174644	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
174645	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
174646	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
174647	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
174648	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
174649	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
174650	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174651	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174652	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174653	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
174654	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	212	
174655	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
174656	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
174657	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	226	
174658	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	226	
174659	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	4	
174660	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174661	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	4	
174662	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
174663	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
174664	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174665	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
174666	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
174667	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174668	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
174669	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
174670	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
174671	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
174672	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
174673	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
174674	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
174675	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
174676	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174677	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
174678	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174679	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174680	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
174681	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174682	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	*C
174683	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
174684	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
174685	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
174686	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
174687	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
174688	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
174689	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
174690	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
174691	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
174692	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
174693	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
174694	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
174695	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
174696	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
174697	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
174698	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
174699	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
174700	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
174701	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
174702	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
174703	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
174704	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
174705	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
174706	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
174707	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
174708	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
174709	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
174710	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
174711	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
174712	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
174713	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
174714	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
174715	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
174716	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174717	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174718	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174719	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174720	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174721	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174722	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
174723	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	2.0	
174724	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	2.0	
174725	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	7.0	
174726	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174727	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174728	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174729	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	2	
174730	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
174731	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
174732	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
174733	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	248834	
174734	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	248834	
174735	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174736	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	6L	
174737	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
174738	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	13L	
174739	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	2384	
174740	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174741	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174742	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	.56	%
174743	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	0	
174744	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
174745	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
174746	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
174747	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
174748	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
174749	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
174750	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
174751	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174752	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
174753	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
174754	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
174755	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
174756	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
174757	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
174758	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
174759	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
174760	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
174761	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
174762	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
174763	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
174764	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
174765	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
174766	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
174767	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	30	°C
174768	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	30	°C
174769	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
174770	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
174771	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
174772	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
174773	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
174774	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
174775	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
174776	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	79	°C
174777	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	63	°C
174778	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
174779	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
174780	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	89	°C
174781	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	69	°C
174782	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	89	°C
174783	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	69	°C
174784	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	82	°C
174785	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	69	°C
174786	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
174787	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
174788	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
174789	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
174790	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
174791	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
174792	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
174793	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
174794	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
174795	6/12/2019 10:47	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
174796	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	0	
174797	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	11.22	%
174798	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	11.22	%
174799	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	10.66	%
174800	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	250.0	
174801	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	240.0	
174802	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	180.0	
174803	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
174804	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
174805	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
174806	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
174807	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
174808	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
174809	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
174810	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
174811	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
174812	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
174813	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
174814	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
174815	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
174816	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
174817	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
174818	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
174819	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
174820	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	6L	
174821	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174822	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	8132	
174823	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	8132	
174824	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
174825	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
174826	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174827	9/25/2019 10:59	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
174828	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
174829	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
174830	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
174831	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
174832	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
174833	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	422	
174834	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	422	
174835	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
174836	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174837	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174838	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
174839	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
174840	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
174841	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
174842	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
174843	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
174844	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
174845	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
174846	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
174847	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
174848	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
174849	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
174850	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
174851	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
174852	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
174853	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
174854	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
174855	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	2	
174856	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
174857	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
174858	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
174859	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	10.92	
174860	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	10.92	
174861	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	10.92	
174862	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
174863	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
174864	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
174865	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
174866	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
174867	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
174868	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
174869	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
174870	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
174871	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
174872	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
174873	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
174874	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0212	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
174875	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174876	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
174877	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174878	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	30	*C
174879	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
174880	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
174881	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
174882	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	1623	
174883	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	12L	
174884	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
174885	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	7L	
174886	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
174887	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	114281	
174888	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	114281	
174889	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
174890	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
174891	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
174892	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
174893	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	40	*C
174894	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
174895	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
174896	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
174897	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
174898	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
174899	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
174900	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
174901	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174902	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
174903	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
174904	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
174905	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
174906	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
174907	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
174908	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
174909	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
174910	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
174911	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
174912	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
174913	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
174914	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
174915	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
174916	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
174917	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
174918	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
174919	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
174920	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
174921	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
174922	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
174923	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
174924	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
174925	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
174926	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
174927	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
174928	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
174929	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	987	
174930	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
174931	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
174932	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
174933	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
174934	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
174935	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
174936	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
174937	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
174938	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
174939	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
174940	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
174941	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
174942	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
174943	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
174944	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
174945	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
174946	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
174947	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
174948	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
174949	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
174950	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
174951	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
174952	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
174953	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	0	
174954	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
174955	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
174956	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
174957	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
174958	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0 psi	
174959	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
174960	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
174961	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
174962	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
174963	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174964	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
174965	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
174966	9/11/2019 14:20	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174967	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
174968	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
174969	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
174970	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	0	
174971	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	987	
174972	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
174973	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
174974	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
174975	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	581	
174976	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	581	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
174977	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	0	
174978	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
174979	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
174980	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
174981	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
174982	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
174983	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
174984	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
174985	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
174986	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
174987	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
174988	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
174989	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
174990	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
174991	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
174992	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
174993	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
174994	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
174995	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
174996	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	213	
174997	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	213	
174998	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	8	
174999	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
175000	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175001	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175002	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175003	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175004	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
175005	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
175006	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
175007	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
175008	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175009	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
175010	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
175011	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	85	*F
175012	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
175013	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
175014	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
175015	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	1611	
175016	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	58	*C
175017	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	*C
175018	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
175019	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	6L	
175020	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	4R	
175021	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
175022	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175023	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175024	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175025	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
175026	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	1R	
175027	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
175028	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175029	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175030	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175031	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175032	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175033	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	400.0	
175034	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	400.0	
175035	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	400.0	
175036	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175037	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
175038	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
175039	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
175040	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
175041	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
175042	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175043	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
175044	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175045	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175046	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175047	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175048	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
175049	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
175050	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
175051	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175052	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175053	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175054	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175055	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175056	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
175057	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	284	
175058	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	288	
175059	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	10	
175060	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175061	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	10	
175062	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
175063	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175064	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175065	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175066	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175067	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175068	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175069	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	12.26	
175070	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175071	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	12.26	
175072	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	2	
175073	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
175074	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
175075	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
175076	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	50	
175077	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	50	
175078	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	2	
175079	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
175080	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
175081	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
175082	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
175083	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
175084	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
175085	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
175086	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175087	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	0	
175088	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
175089	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
175090	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
175091	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
175092	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
175093	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
175094	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
175095	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
175096	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
175097	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	263	
175098	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	263	
175099	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
175100	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
175101	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175102	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
175103	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
175104	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
175105	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
175106	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
175107	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
175108	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
175109	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
175110	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
175111	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
175112	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
175113	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
175114	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
175115	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
175116	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
175117	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
175118	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
175119	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
175120	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
175121	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
175122	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
175123	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
175124	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
175125	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
175126	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175127	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
175128	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
175129	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
175130	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
175131	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
175132	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
175133	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
175134	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
175135	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
175136	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
175137	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
175138	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
175139	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
175140	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
175141	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
175142	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175143	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175144	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
175145	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
175146	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
175147	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
175148	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
175149	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
175150	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	2.30	MegaVars
175151	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.29	MegaVars
175152	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175153	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	4	
175154	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
175155	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
175156	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.50	MegaWatts
175157	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.19	MegaWatts
175158	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
175159	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
175160	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	59954	
175161	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	59954	
175162	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
175163	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
175164	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
175165	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
175166	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
175167	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
175168	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
175169	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
175170	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	6178	
175171	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
175172	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
175173	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
175174	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
175175	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
175176	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	6178	
175177	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
175178	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
175179	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
175180	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
175181	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
175182	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2121	
175183	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
175184	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
175185	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
175186	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
175187	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
175188	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
175189	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
175190	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
175191	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
175192	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
175193	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
175194	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
175195	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
175196	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		
175197	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
175198	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
175199	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
175200	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	197	
175201	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175202	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
175203	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
175204	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
175205	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	0	Seconds
175206	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
175207	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
175208	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
175209	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
175210	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	
175211	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	General Comments	OUT OF SERVICE	
175212	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
175213	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
175214	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	11	
175215	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175216	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175217	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175218	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	90.0	
175219	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	90.0	
175220	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	90.0	
175221	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175222	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175223	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
175224	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
175225	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	44	°C
175226	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	62	°C
175227	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.4010	
175228	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
175229	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Present	40	°C
175230	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Top Oil Temperature Max	64	°C
175231	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
175232	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
175233	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
175234	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
175235	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
175236	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
175237	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
175238	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
175239	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
175240	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	13449.60	kw
175241	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
175242	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
175243	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
175244	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
175245	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
175246	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
175247	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
175248	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
175249	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
175250	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
175251	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
175252	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
175253	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
175254	9/25/2019 10:21	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
175255	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
175256	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
175257	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
175258	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
175259	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	661	
175260	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	10L	
175261	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	4L	
175262	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	7L	
175263	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
175264	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	83879	
175265	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	83879	
175266	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
175267	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
175268	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
175269	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
175270	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
175271	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
175272	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
175273	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
175274	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
175275	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
175276	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175277	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
175278	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
175279	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	General Comments		
175280	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
175281	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
175282	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
175283	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
175284	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	LTC0000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
175285	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
175286	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	General Comments		
175287	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
175288	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	LTC0000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
175289	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
175290	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
175291	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
175292	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
175293	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	212676	
175294	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	212676	
175295	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
175296	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
175297	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
175298	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
175299	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	LTC0000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
175300	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175301	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175302	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175303	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175304	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
175305	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
175306	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
175307	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
175308	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
175309	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
175310	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
175311	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
175312	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
175313	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
175314	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
175315	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
175316	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
175317	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments	WORKED ON COUNTER	
175318	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
175319	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175320	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
175321	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
175322	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	320	
175323	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175324	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175325	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
175326	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
175327	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
175328	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
175329	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
175330	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	BB0317	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
175331	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	330	
175332	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
175333	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175334	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	5	
175335	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
175336	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
175337	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
175338	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
175339	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	5	
175340	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175341	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
175342	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	500	
175343	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	448	
175344	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
175345	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
175346	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175347	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
175348	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments	WORKED ON COUNTER	
175349	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
175350	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
175351	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175352	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
175353	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
175354	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
175355	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
175356	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
175357	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
175358	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	13	
175359	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175360	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175361	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175362	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	80.0	
175363	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	87.0	
175364	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	74.0	
175365	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
175366	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
175367	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175368	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175369	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175370	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175371	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175372	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
175373	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
175374	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
175375	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
175376	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	General Comments		
175377	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
175378	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
175379	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
175380	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
175381	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
175382	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	LTC0000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
175383	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
175384	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
175385	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175386	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
175387	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
175388	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175389	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175390	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175391	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175392	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175393	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
175394	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175395	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
175396	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175397	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175398	9/25/2019 11:32	Distribution	Corporate Drive Quarterly Inspection	WB0170	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175399	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	246	
175400	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	246	
175401	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
175402	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
175403	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
175404	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
175405	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	82	psi
175406	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175407	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175408	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175409	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175410	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
175411	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
175412	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
175413	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
175414	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
175415	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175416	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	0	
175417	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
175418	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
175419	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments	A phase ct bonding strap not connected	
175420	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
175421	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
175422	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
175423	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
175424	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
175425	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
175426	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175427	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
175428	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
175429	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
175430	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
175431	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
175432	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
175433	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
175434	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
175435	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
175436	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
175437	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
175438	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
175439	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
175440	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175441	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
175442	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
175443	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
175444	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
175445	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
175446	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
175447	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
175448	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
175449	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
175450	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC0000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
175451	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC0000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
175452	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC0000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.5	VAC
175453	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
175454	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
175455	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
175456	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC0000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
175457	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC0000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
175458	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
175459	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
175460	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
175461	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
175462	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
175463	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
175464	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
175465	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
175466	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
175467	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
175468	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
175469	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
175470	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
175471	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
175472	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
175473	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
175474	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175475	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175476	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
175477	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
175478	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
175479	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
175480	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175481	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175482	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175483	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	9.55	
175484	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175485	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175486	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	9.55	
175487	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.55	
175488	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
175489	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
175490	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
175491	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
175492	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175493	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175494	9/25/2019 10:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175495	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175496	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
175497	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	220.0	
175498	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175499	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175500	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175501	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175502	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
175503	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175504	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175505	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
175506	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	213	
175507	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	213	
175508	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	0	
175509	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
175510	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
175511	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175512	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
175513	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
175514	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments	No Spill Kit	
175515	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
175516	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
175517	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
175518	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
175519	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
175520	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175521	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
175522	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	65.0	
175523	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
175524	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175525	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175526	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175527	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
175528	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	1	
175529	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175530	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
175531	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
175532	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175533	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175534	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175535	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175536	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175537	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175538	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	69.0	
175539	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	68.0	
175540	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	52.0	
175541	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175542	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175543	9/25/2019 14:01	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
175544	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175545	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175546	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175547	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
175548	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
175549	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
175550	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
175551	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
175552	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
175553	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
175554	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
175555	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175556	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
175557	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
175558	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
175559	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	LTC000061	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
175560	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
175561	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
175562	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
175563	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
175564	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
175565	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
175566	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
175567	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
175568	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
175569	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
175570	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
175571	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175572	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175573	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
175574	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
175575	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
175576	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	256.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175577	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	220.0	
175578	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175579	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175580	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175581	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175582	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175583	9/25/2019 11:51	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175584	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175585	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175586	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175587	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175588	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
175589	9/25/2019 11:14	Distribution	Radcliff Quarterly Inspection	CB0131	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
175590	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
175591	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175592	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
175593	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
175594	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
175595	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175596	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
175597	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
175598	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
175599	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
175600	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	2	
175601	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175602	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175603	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
175604	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175605	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	0	
175606	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	445	
175607	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	445	
175608	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
175609	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175610	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
175611	9/25/2019 10:25	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
175612	9/25/2019 14:03	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
175613	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175614	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175615	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175616	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
175617	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175618	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175619	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
175620	9/25/2019 11:35	Distribution	West Point Quarterly Inspection	LB1143	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
175621	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
175622	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
175623	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
175624	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
175625	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
175626	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
175627	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
175628	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
175629	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
175630	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
175631	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
175632	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
175633	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
175634	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
175635	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
175636	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
175637	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175638	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
175639	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
175640	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175641	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
175642	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
175643	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
175644	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175645	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
175646	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175647	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
175648	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
175649	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
175650	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
175651	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
175652	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
175653	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	30	°C
175654	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	60	°C
175655	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
175656	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
175657	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
175658	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
175659	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
175660	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
175661	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
175662	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
175663	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
175664	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
175665	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
175666	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
175667	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
175668	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
175669	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
175670	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
175671	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
175672	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
175673	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
175674	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
175675	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
175676	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
175677	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
175678	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
175679	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
175680	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
175681	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
175682	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
175683	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
175684	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175685	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175686	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175687	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
175688	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
175689	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
175690	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
175691	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	3	
175692	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
175693	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	3	
175694	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	334	
175695	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	331	
175696	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
175697	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
175698	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
175699	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
175700	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
175701	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
175702	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
175703	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
175704	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
175705	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
175706	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
175707	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
175708	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
175709	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
175710	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
175711	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
175712	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
175713	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
175714	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
175715	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
175716	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
175717	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
175718	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175719	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175720	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	1	
175721	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
175722	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
175723	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
175724	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175725	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
175726	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
175727	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
175728	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
175729	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
175730	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
175731	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
175732	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
175733	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
175734	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
175735	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
175736	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
175737	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
175738	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
175739	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
175740	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BAT000381	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
175741	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments	WORKED ON COUNTER	
175742	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
175743	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
175744	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
175745	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
175746	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
175747	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	174	
175748	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	192	
175749	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
175750	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
175751	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
175752	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
175753	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
175754	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
175755	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
175756	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
175757	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
175758	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
175759	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175760	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175761	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
175762	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
175763	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
175764	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
175765	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
175766	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
175767	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	53	*C
175768	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
175769	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
175770	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
175771	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
175772	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
175773	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
175774	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
175775	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
175776	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
175777	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
175778	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
175779	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	65	*C
175780	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
175781	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
175782	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
175783	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	30	*C
175784	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	*C
175785	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	225.0	
175786	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	225.0	
175787	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	225.0	
175788	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
175789	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
175790	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
175791	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
175792	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
175793	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
175794	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
175795	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
175796	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
175797	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
175798	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
175799	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
175800	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
175801	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
175802	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
175803	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
175804	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
175805	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
175806	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
175807	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
175808	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	11	
175809	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
175810	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
175811	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
175812	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
175813	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175814	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
175815	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175816	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
175817	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
175818	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
175819	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
175820	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
175821	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
175822	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
175823	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
175824	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
175825	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
175826	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
175827	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
175828	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
175829	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
175830	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
175831	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
175832	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
175833	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
175834	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
175835	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
175836	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
175837	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
175838	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	26	
175839	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
175840	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
175841	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
175842	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
175843	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
175844	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
175845	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
175846	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
175847	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
175848	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
175849	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
175850	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	35	°C
175851	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
175852	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1493	
175853	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1489	
175854	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
175855	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
175856	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
175857	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
175858	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
175859	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	402	
175860	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	402	
175861	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
175862	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
175863	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
175864	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	6	
175865	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
175866	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
175867	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	6.4	%
175868	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	80.0	
175869	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	110.0	
175870	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
175871	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
175872	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
175873	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
175874	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
175875	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
175876	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Oil Temp Present	0	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
175877	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
175878	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
175879	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	120.0	
175880	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
175881	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
175882	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
175883	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
175884	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
175885	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
175886	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
175887	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
175888	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
175889	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
175890	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9828	
175891	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
175892	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
175893	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
175894	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	401	
175895	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	General Comments		
175896	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
175897	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
175898	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
175899	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
175900	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	401	
175901	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
175902	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
175903	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
175904	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
175905	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	408	
175906	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	408	
175907	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
175908	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
175909	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
175910	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
175911	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	0	
175912	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
175913	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
175914	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
175915	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	250.0	
175916	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	220.0	
175917	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	220.0	
175918	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
175919	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
175920	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
175921	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
175922	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
175923	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
175924	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
175925	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
175926	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
175927	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
175928	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
175929	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
175930	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
175931	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
175932	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
175933	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
175934	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
175935	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
175936	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
175937	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
175938	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
175939	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
175940	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
175941	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
175942	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
175943	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
175944	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
175945	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	4	
175946	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	4	
175947	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	412	
175948	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	412	
175949	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
175950	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
175951	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
175952	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
175953	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
175954	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
175955	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
175956	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
175957	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
175958	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1179.36	kw
175959	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
175960	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
175961	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
175962	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
175963	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	0	
175964	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
175965	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
175966	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
175967	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	65.0	
175968	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	65.0	
175969	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	65.0	
175970	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
175971	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
175972	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
175973	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
175974	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
175975	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	2	
175976	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
175977	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
175978	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
175979	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
175980	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	120.0	
175981	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	120.0	
175982	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
175983	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
175984	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
175985	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
175986	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	175.0	
175987	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
175988	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
175989	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
175990	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
175991	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
175992	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
175993	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
175994	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
175995	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
175996	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
175997	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
175998	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
175999	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
176000	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176001	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176002	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176003	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176004	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176005	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
176006	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
176007	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
176008	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
176009	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
176010	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
176011	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176012	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
176013	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	85	°C
176014	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	85	°C
176015	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176016	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176017	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176018	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176019	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	100.0	
176020	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	100.0	
176021	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	170.0	
176022	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176023	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176024	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176025	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
176026	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176027	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
176028	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
176029	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
176030	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
176031	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
176032	8/21/2019 14:25	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
176033	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
176034	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176035	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
176036	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
176037	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
176038	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
176039	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
176040	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176041	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176042	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176043	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176044	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176045	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176046	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176047	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
176048	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
176049	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176050	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
176051	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
176052	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	BAT000081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
176053	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
176054	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
176055	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
176056	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
176057	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
176058	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
176059	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
176060	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
176061	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
176062	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
176063	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
176064	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
176065	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
176066	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
176067	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
176068	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
176069	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
176070	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
176071	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
176072	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	401	
176073	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	401	
176074	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
176075	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
176076	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
176077	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
176078	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
176079	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
176080	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
176081	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
176082	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	1	
176083	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
176084	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
176085	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
176086	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
176087	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
176088	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
176089	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
176090	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
176091	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
176092	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
176093	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
176094	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
176095	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
176096	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
176097	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176098	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
176099	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
176100	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
176101	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176102	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
176103	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
176104	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
176105	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
176106	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
176107	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
176108	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
176109	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176110	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176111	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176112	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176113	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176114	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176115	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
176116	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
176117	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176118	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
176119	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
176120	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
176121	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	n	
176122	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176123	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments	lights out on door	
176124	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
176125	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
176126	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176127	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
176128	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176129	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
176130	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
176131	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
176132	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
176133	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
176134	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
176135	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176136	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176137	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176138	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
176139	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
176140	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
176141	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
176142	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
176143	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
176144	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176145	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176146	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
176147	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
176148	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176149	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
176150	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	2	
176151	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
176152	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176153	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
176154	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	50.0	
176155	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
176156	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	100.0	
176157	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176158	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
176159	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
176160	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
176161	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	3919.68	kw
176162	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176163	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
176164	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	50	°C
176165	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	40	°C
176166	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176167	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
176168	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176169	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
176170	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
176171	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
176172	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176173	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
176174	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	.8166	
176175	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
176176	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
176177	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	212	
176178	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	210	
176179	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
176180	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	9	
176181	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
176182	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
176183	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
176184	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
176185	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	424959	
176186	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	424959	
176187	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
176188	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
176189	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
176190	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
176191	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
176192	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	225	
176193	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
176194	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
176195	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
176196	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
176197	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176198	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
176199	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
176200	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176201	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	105.0	
176202	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	130.0	
176203	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	160.0	
176204	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176205	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176206	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176207	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
176208	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
176209	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
176210	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
176211	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
176212	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	111440	
176213	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
176214	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
176215	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
176216	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
176217	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
176218	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
176219	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
176220	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
176221	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
176222	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
176223	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
176224	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
176225	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
176226	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
176227	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
176228	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
176229	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
176230	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
176231	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
176232	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
176233	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
176234	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
176235	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
176236	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49075	
176237	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
176238	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
176239	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
176240	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	467	
176241	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	467	
176242	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
176243	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176244	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
176245	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
176246	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
176247	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
176248	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
176249	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
176250	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	8	
176251	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176252	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
176253	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
176254	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
176255	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
176256	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
176257	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
176258	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	2	
176259	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
176260	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
176261	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
176262	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
176263	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
176264	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176265	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176266	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176267	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176268	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
176269	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
176270	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
176271	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
176272	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	3	
176273	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
176274	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	BCH000919	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
176275	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	150.0	
176276	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	120.0	
176277	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	200.0	
176278	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176279	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176280	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176281	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	11	
176282	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
176283	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
176284	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
176285	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
176286	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
176287	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
176288	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
176289	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
176290	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
176291	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
176292	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
176293	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
176294	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
176295	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
176296	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	1	
176297	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
176298	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
176299	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
176300	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
176301	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
176302	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
176303	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
176304	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
176305	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
176306	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
176307	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
176308	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
176309	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
176310	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	General Comments		
176311	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	25.0	
176312	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176313	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176314	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176315	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
176316	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
176317	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	LTC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
176318	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
176319	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
176320	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
176321	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
176322	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
176323	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
176324	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
176325	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	324	
176326	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176327	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
176328	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
176329	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	89188	
176330	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
176331	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
176332	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
176333	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	324	
176334	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	324	
176335	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
176336	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
176337	4/4/2019 13:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
176338	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	0	
176339	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
176340	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176341	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	324	
176342	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
176343	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
176344	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
176345	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
176346	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
176347	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
176348	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
176349	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176350	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176351	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176352	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	110.0	
176353	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	125.0	
176354	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	130.0	
176355	7/12/2019 10:01	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
176356	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
176357	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
176358	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
176359	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
176360	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
176361	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
176362	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
176363	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
176364	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
176365	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
176366	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
176367	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
176368	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
176369	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
176370	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176371	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
176372	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
176373	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176374	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
176375	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176376	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
176377	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
176378	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
176379	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
176380	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
176381	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
176382	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176383	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
176384	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
176385	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
176386	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176387	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
176388	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
176389	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176390	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
176391	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
176392	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
176393	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176394	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176395	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
176396	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
176397	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
176398	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
176399	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
176400	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
176401	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176402	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
176403	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	273	
176404	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	273	
176405	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
176406	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
176407	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
176408	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	8	
176409	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
176410	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
176411	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
176412	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
176413	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
176414	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
176415	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
176416	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
176417	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	95.0	
176418	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	80.0	
176419	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	55.0	
176420	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
176421	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
176422	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
176423	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
176424	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
176425	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
176426	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
176427	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
176428	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
176429	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176430	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
176431	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
176432	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176433	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176434	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176435	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
176436	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
176437	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
176438	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
176439	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
176440	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
176441	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
176442	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
176443	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
176444	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
176445	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
176446	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
176447	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
176448	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
176449	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
176450	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	0	
176451	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
176452	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
176453	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
176454	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	235.0	
176455	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	185.0	
176456	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	50.0	
176457	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176458	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176459	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176460	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
176461	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
176462	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
176463	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
176464	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
176465	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
176466	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
176467	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	484	
176468	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	484	
176469	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
176470	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
176471	4/24/2019 14:45	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
176472	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	0	
176473	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
176474	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
176475	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
176476	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	230.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
176477	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	220.0	
176478	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	250.0	
176479	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176480	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176481	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176482	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
176483	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
176484	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
176485	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
176486	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
176487	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
176488	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
176489	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	484	
176490	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	484	
176491	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
176492	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
176493	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
176494	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
176495	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
176496	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
176497	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
176498	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
176499	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
176500	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
176501	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
176502	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
176503	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176504	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176505	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176506	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
176507	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
176508	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176509	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
176510	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
176511	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
176512	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176513	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
176514	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	125.00	
176515	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	120.00	
176516	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	52	°C
176517	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	35	°C
176518	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176519	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
176520	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176521	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
176522	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
176523	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176524	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
176525	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
176526	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
176527	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	1179	
176528	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
176529	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	13L	
176530	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	35	
176531	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
176532	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
176533	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
176534	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
176535	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176536	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176537	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176538	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	140.0	
176539	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	100.0	
176540	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	100.0	
176541	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176542	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176543	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176544	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176545	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	0	
176546	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	0	
176547	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	0	
176548	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	
176549	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
176550	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
176551	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
176552	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments		
176553	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176554	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
176555	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	469	
176556	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	469	
176557	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	0	
176558	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
176559	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
176560	9/24/2019 12:20	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
176561	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
176562	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
176563	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176564	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
176565	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
176566	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176567	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
176568	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176569	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	32	°C
176570	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	54	°C
176571	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
176572	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	221.67	
176573	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
176574	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176575	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
176576	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
176577	9/24/2019 8:35	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
176578	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
176579	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
176580	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
176581	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
176582	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
176583	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
176584	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
176585	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
176586	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
176587	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
176588	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	273	
176589	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
176590	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
176591	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
176592	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
176593	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
176594	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
176595	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
176596	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
176597	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
176598	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
176599	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
176600	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
176601	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
176602	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
176603	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	273	
176604	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
176605	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
176606	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
176607	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
176608	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
176609	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
176610	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
176611	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
176612	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
176613	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
176614	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
176615	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176616	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176617	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	180.0	
176618	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	200.0	
176619	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	240.0	
176620	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	2L	
176621	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	7L	
176622	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
176623	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	5497	
176624	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	5497	
176625	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
176626	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176627	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
176628	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
176629	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176630	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176631	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
176632	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
176633	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
176634	9/24/2019 8:34	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
176635	7/8/2019 13:16	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176636	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
176637	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176638	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
176639	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	50.0	
176640	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	100.0	
176641	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176642	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176643	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176644	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176645	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176646	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
176647	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176648	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176649	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
176650	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
176651	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
176652	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
176653	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176654	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176655	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
176656	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
176657	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
176658	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
176659	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
176660	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
176661	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
176662	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
176663	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
176664	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176665	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
176666	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
176667	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
176668	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
176669	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	421	
176670	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	421	
176671	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
176672	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176673	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
176674	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	1	
176675	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	0	
176676	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	
176677	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176678	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176679	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176680	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
176681	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	*F
176682	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176683	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
176684	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176685	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176686	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176687	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176688	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	280.0	
176689	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	250.0	
176690	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	350.0	
176691	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176692	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176693	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176694	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176695	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176696	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176697	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
176698	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
176699	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
176700	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
176701	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176702	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176703	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176704	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
176705	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
176706	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
176707	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
176708	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
176709	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
176710	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
176711	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
176712	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
176713	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
176714	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
176715	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176716	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
176717	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
176718	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
176719	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
176720	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	
176721	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176722	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	311	
176723	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	311	
176724	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
176725	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
176726	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176727	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176728	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176729	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176730	7/8/2019 14:46	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176731	4/3/2019 13:51	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
176732	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
176733	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
176734	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
176735	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
176736	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
176737	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
176738	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176739	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176740	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176741	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	100.0	
176742	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	90.0	
176743	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	180.0	
176744	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176745	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176746	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
176747	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	3	
176748	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
176749	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
176750	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
176751	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
176752	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
176753	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
176754	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176755	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176756	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	230.0	
176757	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	180.0	
176758	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	120.0	
176759	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
176760	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
176761	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
176762	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
176763	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
176764	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
176765	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
176766	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
176767	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
176768	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
176769	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
176770	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
176771	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
176772	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
176773	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
176774	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	533	
176775	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
176776	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176777	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
176778	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
176779	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
176780	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
176781	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
176782	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
176783	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176784	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
176785	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
176786	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
176787	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
176788	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176789	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176790	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176791	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176792	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	50.0	
176793	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	0.0	
176794	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	0.0	
176795	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176796	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176797	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176798	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
176799	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
176800	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
176801	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	1	
176802	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
176803	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
176804	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176805	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176806	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
176807	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
176808	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
176809	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
176810	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
176811	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	150.0	
176812	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	190.0	
176813	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	240.0	
176814	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
176815	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
176816	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
176817	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
176818	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
176819	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
176820	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
176821	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176822	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176823	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176824	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
176825	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
176826	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
176827	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
176828	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
176829	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
176830	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
176831	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
176832	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
176833	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176834	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
176835	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
176836	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
176837	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
176838	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
176839	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
176840	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
176841	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
176842	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
176843	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
176844	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
176845	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
176846	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.80	MegaVars
176847	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.75	MegaWatts
176848	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.45	MegaWatts
176849	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176850	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
176851	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176852	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
176853	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176854	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
176855	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176856	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
176857	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
176858	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
176859	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
176860	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
176861	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
176862	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
176863	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
176864	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
176865	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
176866	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
176867	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176868	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
176869	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
176870	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
176871	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
176872	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
176873	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
176874	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
176875	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
176876	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	301	
176877	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	301	
176878	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
176879	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
176880	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
176881	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
176882	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
176883	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	2.00	MegaWatts
176884	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	4.00	MegaWatts
176885	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.40	MegaVars
176886	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.40	MegaVars
176887	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
176888	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
176889	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
176890	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
176891	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
176892	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
176893	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
176894	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
176895	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
176896	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
176897	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
176898	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
176899	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	301	
176900	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	301	
176901	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
176902	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
176903	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
176904	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
176905	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	533	
176906	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
176907	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
176908	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
176909	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
176910	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
176911	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
176912	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
176913	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
176914	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
176915	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
176916	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
176917	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
176918	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
176919	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176920	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176921	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176922	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176923	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176924	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
176925	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
176926	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
176927	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
176928	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
176929	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
176930	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
176931	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
176932	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
176933	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
176934	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
176935	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
176936	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
176937	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	344	
176938	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
176939	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
176940	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
176941	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
176942	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
176943	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	232667	
176944	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	232667	
176945	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
176946	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
176947	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
176948	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
176949	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
176950	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
176951	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
176952	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
176953	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	330	
176954	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
176955	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
176956	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
176957	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
176958	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176959	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176960	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176961	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	150.0	
176962	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	150.0	
176963	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	200.0	
176964	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176965	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176966	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176967	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
176968	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
176969	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	13972	
176970	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	13972	
176971	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
176972	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
176973	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
176974	9/23/2019 8:53	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
176975	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	160.0	
176976	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	150.0	
176977	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
176978	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
176979	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
176980	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	0	
176981	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	100.0	
176982	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
176983	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
176984	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
176985	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
176986	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
176987	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
176988	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
176989	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
176990	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
176991	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	0	
176992	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	487	
176993	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	487	
176994	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
176995	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
176996	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
176997	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
176998	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
176999	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
177000	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
177001	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue		AssetInspectionQuestionUnit
177002	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
177003	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
177004	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
177005	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
177006	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
177007	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
177008	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
177009	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	100.0	
177010	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	160.0	
177011	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	150.0	
177012	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
177013	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
177014	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
177015	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	8	
177016	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
177017	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
177018	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
177019	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
177020	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
177021	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
177022	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	418	
177023	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	418	
177024	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	
177025	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
177026	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
177027	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
177028	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
177029	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
177030	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
177031	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
177032	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
177033	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
177034	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
177035	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
177036	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
177037	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
177038	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
177039	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
177040	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
177041	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
177042	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
177043	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
177044	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
177045	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
177046	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
177047	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
177048	9/23/2019 8:53	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
177049	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
177050	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	180.0	
177051	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	100.0	
177052	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
177053	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
177054	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
177055	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
177056	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
177057	9/23/2019 8:53	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
177058	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
177059	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
177060	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	2	
177061	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	311	
177062	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	311	
177063	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
177064	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments	A and B phase IOC	
177065	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	140.0	
177066	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
177067	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
177068	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
177069	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	1	
177070	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	1	
177071	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
177072	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
177073	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
177074	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
177075	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
177076	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177077	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
177078	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
177079	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
177080	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
177081	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
177082	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
177083	9/23/2019 8:53	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
177084	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
177085	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
177086	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
177087	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
177088	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
177089	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
177090	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
177091	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
177092	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
177093	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
177094	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
177095	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
177096	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
177097	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
177098	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
177099	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
177100	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
177101	9/23/2019 8:53	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
177102	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
177103	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
177104	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
177105	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
177106	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
177107	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
177108	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	3	
177109	6/19/2019 14:19	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
177110	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
177111	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
177112	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
177113	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
177114	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
177115	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
177116	9/23/2019 8:53	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
177117	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
177118	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
177119	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
177120	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
177121	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
177122	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BCH000503	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
177123	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
177124	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
177125	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	17	
177126	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	560	
177127	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	560	
177128	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	15	
177129	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
177130	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
177131	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
177132	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	52	
177133	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177134	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177135	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177136	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
177137	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	135.0	
177138	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
177139	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177140	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177141	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177142	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
177143	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
177144	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
177145	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
177146	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177147	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
177148	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177149	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
177150	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
177151	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177152	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
177153	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177154	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177155	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177156	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177157	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177158	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177159	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
177160	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	25	
177161	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	362	
177162	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	362	
177163	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	27	
177164	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
177165	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
177166	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	31	
177167	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	85.0	
177168	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177169	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177170	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177171	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
177172	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
177173	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177174	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177175	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177176	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
177177	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
177178	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
177179	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
177180	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
177181	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
177182	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177183	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177184	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177185	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
177186	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177187	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
177188	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177189	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
177190	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177191	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
177192	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
177193	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
177194	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
177195	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177196	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177197	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
177198	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	1548	
177199	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	16L	
177200	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
177201	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	9L	
177202	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	89458	
177203	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	89458	
177204	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
177205	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
177206	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
177207	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
177208	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
177209	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
177210	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
177211	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
177212	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
177213	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	1.2018	
177214	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	50	°C
177215	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	70	°C
177216	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	11537.28	kw
177217	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
177218	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
177219	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
177220	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
177221	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
177222	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
177223	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
177224	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
177225	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
177226	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177227	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
177228	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
177229	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
177230	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
177231	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
177232	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
177233	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
177234	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
177235	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
177236	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
177237	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
177238	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
177239	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
177240	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
177241	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
177242	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
177243	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
177244	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
177245	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
177246	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	50	°C
177247	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
177248	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12R	
177249	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
177250	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	14R	
177251	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	310	
177252	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
177253	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	97487	
177254	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
177255	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
177256	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
177257	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
177258	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
177259	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
177260	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
177261	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
177262	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
177263	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177264	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	9	
177265	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177266	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177267	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177268	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177269	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177270	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177271	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177272	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
177273	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
177274	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
177275	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
177276	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
177277	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
177278	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
177279	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
177280	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	120.0	
177281	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	90.0	
177282	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	120.0	
177283	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
177284	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177285	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177286	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177287	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177288	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
177289	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177290	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177291	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
177292	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	12	
177293	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	5.42	%
177294	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	5.81	%
177295	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	1.94	%
177296	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	350	
177297	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	400	
177298	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	380	
177299	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
177300	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
177301	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5120	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177302	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
177303	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
177304	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
177305	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
177306	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
177307	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
177308	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
177309	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
177310	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
177311	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
177312	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
177313	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
177314	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
177315	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
177316	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4915.20	kw
177317	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
177318	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
177319	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
177320	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
177321	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
177322	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
177323	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
177324	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
177325	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
177326	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
177327	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
177328	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
177329	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
177330	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
177331	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
177332	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
177333	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
177334	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
177335	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
177336	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
177337	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
177338	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
177339	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
177340	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
177341	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
177342	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
177343	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
177344	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	674	
177345	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	670	
177346	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
177347	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
177348	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
177349	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
177350	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
177351	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
177352	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
177353	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	248	
177354	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
177355	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
177356	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
177357	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
177358	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	12538.8	kw
177359	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
177360	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
177361	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	58	°C
177362	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
177363	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177364	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
177365	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
177366	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	316	
177367	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	321	
177368	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	5	
177369	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177370	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	70	°C
177371	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
177372	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
177373	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	5	
177374	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
177375	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
177376	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177377	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
177378	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
177379	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
177380	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177381	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177382	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
177383	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
177384	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
177385	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
177386	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
177387	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
177388	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
177389	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
177390	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
177391	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	General Comments		
177392	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
177393	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
177394	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
177395	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
177396	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
177397	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
177398	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
177399	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
177400	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
177401	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
177402	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallel	IND Position
177403	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
177404	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
177405	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
177406	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
177407	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
177408	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	General Comments		
177409	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTC0000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
177410	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	50	°C
177411	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	97487	
177412	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
177413	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.6966	
177414	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
177415	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
177416	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177417	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177418	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177419	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
177420	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
177421	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
177422	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	20.0	
177423	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	20.0	
177424	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	20.0	
177425	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
177426	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
177427	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
177428	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
177429	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177430	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177431	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177432	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	9	
177433	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
177434	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
177435	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	5	
177436	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177437	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	5	
177438	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
177439	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
177440	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
177441	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
177442	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
177443	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
177444	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	251	
177445	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	246	
177446	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
177447	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
177448	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177449	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
177450	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
177451	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177452	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
177453	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
177454	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
177455	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
177456	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
177457	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
177458	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
177459	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	BB0052	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
177460	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
177461	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
177462	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
177463	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
177464	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
177465	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
177466	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
177467	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
177468	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
177469	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
177470	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
177471	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
177472	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
177473	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
177474	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
177475	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
177476	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
177477	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
177478	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
177479	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
177480	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
177481	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
177482	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
177483	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
177484	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
177485	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
177486	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
177487	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
177488	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
177489	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
177490	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
177491	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
177492	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
177493	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
177494	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
177495	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
177496	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
177497	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
177498	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
177499	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
177500	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
177501	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
177502	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	BAT000119	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
177503	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
177504	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
177505	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
177506	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
177507	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
177508	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
177509	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
177510	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
177511	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
177512	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
177513	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
177514	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
177515	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
177516	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
177517	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
177518	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
177519	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
177520	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
177521	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
177522	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
177523	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
177524	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
177525	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
177526	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177527	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
177528	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
177529	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
177530	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
177531	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
177532	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	0.0	
177533	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	0.0	
177534	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	0.0	
177535	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
177536	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
177537	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	4	
177538	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
177539	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
177540	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
177541	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
177542	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
177543	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
177544	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
177545	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
177546	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
177547	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
177548	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
177549	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
177550	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
177551	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
177552	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
177553	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
177554	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
177555	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
177556	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
177557	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
177558	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
177559	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
177560	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
177561	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
177562	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
177563	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
177564	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
177565	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177566	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
177567	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	105.0	
177568	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	130.0	
177569	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	115.0	
177570	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177571	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177572	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177573	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	6	
177574	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
177575	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
177576	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
177577	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
177578	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	221770	
177579	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	221770	
177580	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
177581	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	1L	
177582	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	12R	
177583	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	7L	
177584	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
177585	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	1232	
177586	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
177587	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
177588	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
177589	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
177590	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
177591	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
177592	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
177593	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
177594	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	13142	
177595	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
177596	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
177597	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
177598	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
177599	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
177600	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
177601	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177602	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
177603	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
177604	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
177605	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
177606	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
177607	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
177608	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
177609	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
177610	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
177611	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177612	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
177613	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
177614	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
177615	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
177616	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
177617	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
177618	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
177619	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
177620	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
177621	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
177622	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177623	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177624	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177625	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177626	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177627	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177628	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177629	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177630	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177631	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
177632	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	175.0	
177633	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	180.0	
177634	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	175.0	
177635	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177636	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177637	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177638	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	8	
177639	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
177640	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
177641	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
177642	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	1571	
177643	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	11L	
177644	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	2R	
177645	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	2L	
177646	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
177647	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
177648	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
177649	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
177650	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
177651	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
177652	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
177653	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	23947	
177654	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	23947	
177655	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
177656	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
177657	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
177658	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
177659	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
177660	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
177661	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
177662	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
177663	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
177664	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
177665	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
177666	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
177667	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
177668	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
177669	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
177670	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
177671	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
177672	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
177673	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	14933	
177674	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
177675	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
177676	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
177677	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
177678	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
177679	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
177680	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
177681	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
177682	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
177683	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
177684	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
177685	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
177686	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
177687	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
177688	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
177689	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
177690	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
177691	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
177692	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
177693	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
177694	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
177695	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
177696	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
177697	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
177698	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
177699	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
177700	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
177701	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
177702	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
177703	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
177704	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
177705	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
177706	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
177707	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
177708	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
177709	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
177710	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
177711	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
177712	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	4	
177713	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177714	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	4	
177715	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	266	
177716	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	262	
177717	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
177718	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
177719	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	7R	
177720	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
177721	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
177722	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
177723	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
177724	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
177725	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
177726	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
177727	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
177728	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
177729	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
177730	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
177731	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
177732	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
177733	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
177734	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
177735	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
177736	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
177737	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
177738	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
177739	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
177740	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
177741	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
177742	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
177743	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	4	
177744	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
177745	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
177746	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
177747	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
177748	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
177749	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
177750	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
177751	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177752	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
177753	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
177754	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
177755	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
177756	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
177757	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177758	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	4	
177759	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	295	
177760	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
177761	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
177762	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
177763	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
177764	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
177765	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
177766	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
177767	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
177768	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
177769	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
177770	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	291	
177771	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
177772	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
177773	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177774	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
177775	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
177776	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
177777	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
177778	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
177779	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
177780	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
177781	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
177782	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
177783	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
177784	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177785	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177786	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177787	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
177788	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
177789	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
177790	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
177791	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
177792	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
177793	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177794	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177795	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177796	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177797	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177798	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177799	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	5.2	
177800	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	5.2	
177801	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	5.2	
177802	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	1	
177803	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	1	
177804	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	1	
177805	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
177806	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
177807	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
177808	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
177809	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
177810	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
177811	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
177812	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
177813	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
177814	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	211	
177815	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	211	
177816	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	3	
177817	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	0	
177818	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
177819	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
177820	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177821	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177822	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177823	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177824	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177825	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177826	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177827	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177828	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177829	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
177830	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	40.0	
177831	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	60.0	
177832	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	40.0	
177833	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177834	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177835	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177836	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	9	
177837	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
177838	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
177839	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
177840	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
177841	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
177842	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
177843	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
177844	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
177845	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
177846	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
177847	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
177848	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
177849	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
177850	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
177851	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
177852	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	11868	
177853	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
177854	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
177855	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
177856	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
177857	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
177858	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177859	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177860	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177861	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177862	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177863	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177864	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177865	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177866	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177867	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177868	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177869	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177870	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177871	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
177872	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	220.0	
177873	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	180.0	
177874	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
177875	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
177876	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
177877	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	180.0	
177878	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177879	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177880	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177881	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	8	
177882	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
177883	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
177884	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
177885	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
177886	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
177887	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
177888	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
177889	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
177890	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
177891	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
177892	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
177893	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
177894	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
177895	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
177896	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
177897	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	54.0	VDC
177898	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
177899	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
177900	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
177901	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177902	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
177903	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
177904	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
177905	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
177906	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
177907	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
177908	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
177909	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
177910	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
177911	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
177912	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
177913	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
177914	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
177915	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
177916	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	2	
177917	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
177918	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
177919	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	2	
177920	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
177921	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	2	
177922	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	260	
177923	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	358	
177924	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
177925	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
177926	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
177927	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177928	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
177929	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
177930	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
177931	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
177932	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
177933	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
177934	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
177935	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
177936	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
177937	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
177938	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
177939	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
177940	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
177941	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
177942	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
177943	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
177944	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
177945	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
177946	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
177947	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
177948	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	360.0	
177949	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	380.0	
177950	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
177951	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
177952	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
177953	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
177954	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
177955	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
177956	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
177957	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
177958	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
177959	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
177960	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
177961	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
177962	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
177963	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
177964	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
177965	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	360.0	
177966	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
177967	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
177968	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
177969	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	6	
177970	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
177971	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
177972	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	2	
177973	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	6	
177974	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	181	
177975	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	181	
177976	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
177977	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	4	
177978	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
177979	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
177980	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
177981	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
177982	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
177983	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
177984	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
177985	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
177986	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
177987	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
177988	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
177989	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
177990	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
177991	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
177992	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
177993	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
177994	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
177995	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
177996	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
177997	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
177998	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
177999	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
178000	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	4	
178001	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178002	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	4	
178003	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	192	
178004	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	192	
178005	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
178006	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
178007	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178008	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
178009	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
178010	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
178011	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
178012	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
178013	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
178014	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.6690	
178015	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
178016	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
178017	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
178018	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
178019	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
178020	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
178021	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
178022	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
178023	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
178024	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	50	°C
178025	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
178026	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
178027	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	6422.40	kw
178028	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
178029	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
178030	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
178031	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
178032	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
178033	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
178034	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
178035	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
178036	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
178037	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
178038	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
178039	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
178040	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
178041	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
178042	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
178043	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
178044	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
178045	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
178046	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
178047	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
178048	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
178049	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
178050	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
178051	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178052	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
178053	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
178054	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
178055	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
178056	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
178057	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
178058	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
178059	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
178060	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
178061	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
178062	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
178063	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
178064	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
178065	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
178066	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36864	
178067	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
178068	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
178069	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
178070	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
178071	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
178072	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
178073	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
178074	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
178075	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
178076	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
178077	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
178078	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
178079	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
178080	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
178081	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
178082	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
178083	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
178084	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
178085	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
178086	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
178087	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
178088	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
178089	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
178090	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
178091	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
178092	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
178093	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
178094	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
178095	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
178096	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
178097	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
178098	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
178099	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
178100	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
178101	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
178102	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
178103	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
178104	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
178105	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
178106	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
178107	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
178108	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
178109	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
178110	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
178111	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
178112	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
178113	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
178114	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
178115	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
178116	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
178117	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
178118	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
178119	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
178120	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
178121	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
178122	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
178123	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
178124	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
178125	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
178126	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
178127	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
178128	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
178129	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
178130	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
178131	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
178132	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
178133	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
178134	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
178135	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
178136	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
178137	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
178138	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
178139	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
178140	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
178141	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
178142	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
178143	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
178144	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
178145	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
178146	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
178147	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
178148	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
178149	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
178150	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
178151	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
178152	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
178153	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
178154	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
178155	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
178156	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
178157	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
178158	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
178159	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
178160	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	*F
178161	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
178162	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
178163	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
178164	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
178165	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
178166	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
178167	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
178168	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
178169	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
178170	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
178171	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
178172	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
178173	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
178174	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
178175	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
178176	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
178177	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
178178	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
178179	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
178180	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
178181	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
178182	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
178183	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
178184	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
178185	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
178186	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
178187	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
178188	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
178189	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
178190	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
178191	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
178192	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	39417	
178193	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
178194	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
178195	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
178196	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
178197	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
178198	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
178199	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
178200	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
178201	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
178202	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
178203	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
178204	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
178205	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
178206	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
178207	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
178208	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
178209	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	1	
178210	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0	
178211	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0	
178212	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	5.2	
178213	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178214	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178215	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178216	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178217	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178218	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
178219	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
178220	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
178221	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
178222	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
178223	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
178224	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178225	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
178226	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
178227	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	33	
178228	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	472	
178229	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	472	
178230	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
178231	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	31	
178232	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178233	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
178234	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
178235	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
178236	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
178237	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178238	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
178239	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
178240	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1046	
178241	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
178242	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
178243	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
178244	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
178245	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
178246	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
178247	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
178248	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
178249	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
178250	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
178251	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
178252	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
178253	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
178254	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
178255	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
178256	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
178257	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
178258	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
178259	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
178260	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
178261	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
178262	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
178263	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
178264	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
178265	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
178266	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
178267	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
178268	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
178269	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
178270	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
178271	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
178272	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
178273	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
178274	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
178275	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
178276	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178277	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
178278	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
178279	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
178280	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
178281	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
178282	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
178283	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
178284	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
178285	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
178286	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
178287	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178288	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178289	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178290	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178291	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178292	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
178293	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
178294	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178295	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178296	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178297	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178298	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
178299	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	75.0	
178300	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	55.0	
178301	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	55.0	
178302	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178303	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178304	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178305	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	38	
178306	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
178307	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
178308	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
178309	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
178310	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.4292	
178311	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
178312	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
178313	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
178314	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
178315	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
178316	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
178317	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
178318	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
178319	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
178320	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
178321	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
178322	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
178323	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	4573.44	kw
178324	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1046	
178325	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	1	
178326	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
178327	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
178328	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
178329	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
178330	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
178331	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
178332	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
178333	9/20/2019 13:41	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
178334	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178335	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	0	
178336	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
178337	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
178338	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
178339	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
178340	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
178341	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
178342	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
178343	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
178344	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178345	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
178346	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	117	
178347	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	124	
178348	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	137	
178349	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	.83	%
178350	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
178351	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178352	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
178353	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
178354	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	FE000374	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
178355	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	2.5	%
178356	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	1.67	%
178357	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	6	
178358	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
178359	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
178360	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
178361	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
178362	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
178363	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
178364	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
178365	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
178366	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
178367	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
178368	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
178369	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
178370	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
178371	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
178372	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
178373	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
178374	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
178375	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
178376	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
178377	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
178378	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
178379	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
178380	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
178381	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
178382	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
178383	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
178384	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
178385	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
178386	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
178387	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	34624	
178388	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
178389	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
178390	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178391	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
178392	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
178393	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
178394	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
178395	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
178396	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
178397	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
178398	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
178399	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
178400	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
178401	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
178402	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
178403	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	*C
178404	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
178405	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
178406	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	2457.60	kw
178407	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
178408	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
178409	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
178410	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
178411	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
178412	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
178413	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
178414	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
178415	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
178416	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
178417	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
178418	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
178419	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
178420	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178421	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
178422	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
178423	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
178424	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
178425	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
178426	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178427	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
178428	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
178429	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
178430	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
178431	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
178432	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
178433	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
178434	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
178435	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
178436	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
178437	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
178438	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
178439	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
178440	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
178441	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
178442	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	3	
178443	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
178444	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
178445	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
178446	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
178447	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
178448	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
178449	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
178450	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178451	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
178452	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
178453	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.7680	
178454	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
178455	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
178456	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
178457	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
178458	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
178459	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	277	
178460	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	282	
178461	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	5	
178462	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178463	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	5	
178464	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
178465	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
178466	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
178467	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
178468	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
178469	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
178470	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	2	
178471	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	2	
178472	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	194	
178473	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	192	
178474	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
178475	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
178476	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178477	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
178478	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	164	
178479	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	164	
178480	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
178481	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
178482	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
178483	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
178484	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
178485	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
178486	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
178487	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000590	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
178488	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
178489	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
178490	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178491	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
178492	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C ∅	135.0	
178493	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
178494	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178495	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178496	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
178497	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
178498	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178499	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
178500	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
178501	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
178502	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
178503	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
178504	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	3690	
178505	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	3690	
178506	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
178507	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	9L	
178508	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
178509	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
178510	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
178511	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
178512	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
178513	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
178514	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
178515	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
178516	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
178517	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
178518	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
178519	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
178520	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
178521	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
178522	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	480	
178523	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	520	
178524	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
178525	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
178526	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
178527	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
178528	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
178529	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
178530	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178531	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178532	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178533	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178534	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178535	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178536	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178537	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178538	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
178539	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
178540	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
178541	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	480	
178542	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
178543	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
178544	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178545	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178546	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178547	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	4	
178548	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178549	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178550	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178551	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	LTC000280	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
178552	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	140.0	
178553	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	140.0	
178554	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
178555	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
178556	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	1336	
178557	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
178558	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	16L	
178559	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	1L	
178560	9/19/2019 8:32	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
178561	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
178562	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
178563	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
178564	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
178565	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
178566	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
178567	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178568	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178569	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178570	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178571	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178572	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178573	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
178574	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
178575	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
178576	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Insp	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178577	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
178578	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
178579	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
178580	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
178581	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
178582	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178583	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178584	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178585	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178586	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
178587	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
178588	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
178589	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
178590	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
178591	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
178592	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178593	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178594	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
178595	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	90.0	
178596	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	95.0	
178597	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	100.0	
178598	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178599	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178600	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178601	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	6	
178602	9/20/2019 14:58	Distribution	Winchester Fence Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
178603	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
178604	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
178605	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
178606	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
178607	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
178608	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
178609	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
178610	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
178611	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
178612	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
178613	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
178614	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	General Comments		
178615	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
178616	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
178617	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
178618	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
178619	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
178620	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
178621	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
178622	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
178623	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
178624	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
178625	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
178626	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
178627	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
178628	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
178629	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
178630	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
178631	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
178632	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
178633	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	77	*F
178634	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	0.0	
178635	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	0.0	
178636	9/20/2019 10:52	Distribution	Southern Baptist Seminary Quarterly Inspe	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	0.0	
178637	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
178638	9/20/2019 14:46	Distribution	Winchester South Quarterly Inspection	LTC0000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
178639	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
178640	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
178641	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
178642	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
178643	9/20/2019 14:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
178644	9/20/2019 11:43	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178645	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
178646	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
178647	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	50.0	
178648	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
178649	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
178650	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
178651	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	209	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178652	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	217	
178653	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
178654	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
178655	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
178656	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178657	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178658	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178659	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
178660	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
178661	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
178662	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178663	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	28.0	
178664	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	24.0	
178665	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178666	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178667	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
178668	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
178669	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
178670	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
178671	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178672	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178673	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
178674	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178675	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
178676	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178677	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178678	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178679	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178680	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
178681	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
178682	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
178683	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
178684	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
178685	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
178686	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BCH000476	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
178687	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
178688	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments	4kv is out of service.	
178689	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
178690	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	1	
178691	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178692	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
178693	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	y	
178694	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
178695	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
178696	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	1	
178697	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	170	
178698	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	126.0	
178699	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	1R	
178700	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	7L	
178701	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	715	
178702	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
178703	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
178704	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
178705	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
178706	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
178707	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
178708	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	129275	
178709	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
178710	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
178711	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	2	
178712	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
178713	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
178714	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
178715	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
178716	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	4	
178717	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178718	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	169	
178719	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
178720	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178721	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178722	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	22.0	
178723	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
178724	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	26.0	
178725	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178726	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178727	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
178728	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
178729	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
178730	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
178731	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	4	
178732	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178733	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178734	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178735	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	252.0	
178736	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	254.0	
178737	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	217.0	
178738	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
178739	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
178740	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	*F
178741	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
178742	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
178743	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
178744	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
178745	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	82902	
178746	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	82909	
178747	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
178748	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
178749	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
178750	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
178751	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
178752	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
178753	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
178754	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
178755	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
178756	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
178757	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
178758	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
178759	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	4L	
178760	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
178761	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
178762	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
178763	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178764	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178765	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178766	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178767	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178768	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178769	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178770	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178771	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178772	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
178773	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
178774	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
178775	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	148.0	
178776	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	143.0	
178777	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
178778	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
178779	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
178780	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
178781	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
178782	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
178783	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
178784	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
178785	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
178786	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
178787	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
178788	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
178789	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
178790	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
178791	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	153795	
178792	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
178793	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
178794	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
178795	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
178796	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
178797	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
178798	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
178799	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
178800	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
178801	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178802	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178803	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178804	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	300.0	
178805	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	284.0	
178806	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	315.0	
178807	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
178808	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
178809	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
178810	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
178811	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
178812	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
178813	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
178814	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
178815	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
178816	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
178817	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
178818	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
178819	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
178820	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
178821	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
178822	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
178823	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
178824	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
178825	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments	4kv is out of service	
178826	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
178827	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	2	
178828	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	2	
178829	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	181	
178830	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
178831	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178832	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
178833	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
178834	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	613	
178835	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	618	
178836	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	General Comments	4 kv is out of service due to structure on transformer.	
178837	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
178838	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178839	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178840	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178841	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178842	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178843	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178844	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178845	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178846	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178847	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
178848	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
178849	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
178850	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
178851	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
178852	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
178853	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
178854	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
178855	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
178856	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
178857	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178858	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
178859	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
178860	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
178861	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178862	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178863	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178864	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178865	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178866	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178867	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	125.0	
178868	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	125.0	
178869	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
178870	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178871	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178872	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178873	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178874	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178875	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178876	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178877	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.33	
178878	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.33	
178879	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
178880	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
178881	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
178882	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
178883	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
178884	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
178885	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
178886	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
178887	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
178888	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178889	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
178890	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178891	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178892	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
178893	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
178894	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
178895	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
178896	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
178897	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
178898	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
178899	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
178900	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
178901	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
178902	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
178903	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
178904	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
178905	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	169	
178906	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	173	
178907	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
178908	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178909	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
178910	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
178911	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
178912	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	125.0	
178913	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178914	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178915	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
178916	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
178917	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
178918	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
178919	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
178920	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0344	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178921	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
178922	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	171	
178923	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	170	
178924	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
178925	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
178926	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
178927	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	1	
178928	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
178929	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
178930	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
178931	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
178932	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
178933	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	1	
178934	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	242	
178935	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	241	
178936	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
178937	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
178938	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
178939	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
178940	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
178941	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
178942	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
178943	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
178944	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
178945	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
178946	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
178947	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
178948	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
178949	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
178950	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
178951	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
178952	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
178953	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
178954	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178955	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178956	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178957	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178958	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178959	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178960	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
178961	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
178962	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
178963	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
178964	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178965	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178966	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178967	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
178968	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
178969	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
178970	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
178971	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
178972	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
178973	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
178974	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
178975	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
178976	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
178977	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
178978	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
178979	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
178980	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
178981	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	24.0	
178982	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
178983	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	168	
178984	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
178985	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	Follow-up Action Required?	y	
178986	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
178987	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
178988	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
178989	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
178990	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
178991	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	B0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
178992	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	B0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
178993	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	B0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
178994	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	B0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
178995	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	B0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
178996	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	180	
178997	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
178998	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
178999	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
179000	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
179001	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
179002	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
179003	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
179004	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
179005	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
179006	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
179007	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
179008	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
179009	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179010	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179011	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179012	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179013	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179014	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
179015	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
179016	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179017	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179018	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179019	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179020	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
179021	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
179022	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
179023	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
179024	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
179025	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
179026	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179027	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
179028	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	104.0	
179029	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	168	
179030	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
179031	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
179032	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
179033	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
179034	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
179035	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	99.0	
179036	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	81.0	
179037	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179038	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179039	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179040	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	3	
179041	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
179042	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
179043	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	2	
179044	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	2	
179045	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	60.0	
179046	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	56.0	
179047	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179048	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179049	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179050	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	5	
179051	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
179052	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
179053	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	
179054	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
179055	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	171	
179056	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	171	
179057	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
179058	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
179059	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
179060	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
179061	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
179062	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
179063	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
179064	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
179065	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
179066	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
179067	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
179068	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
179069	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179070	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179071	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179072	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179073	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179074	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179075	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179076	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
179077	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
179078	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
179079	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
179080	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
179081	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
179082	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
179083	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
179084	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
179085	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
179086	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
179087	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179088	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179089	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179090	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179091	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179092	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179093	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
179094	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
179095	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
179096	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
179097	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
179098	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
179099	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
179100	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
179101	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179102	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
179103	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
179104	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
179105	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
179106	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
179107	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
179108	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
179109	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
179110	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	93.0	
179111	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	104.0	
179112	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	107.0	
179113	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179114	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
179115	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
179116	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
179117	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
179118	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	55896	
179119	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
179120	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
179121	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
179122	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
179123	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	154	
179124	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
179125	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
179126	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
179127	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	LTC000176	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
179128	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
179129	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
179130	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
179131	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
179132	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
179133	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
179134	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
179135	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	30	Seconds
179136	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
179137	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
179138	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
179139	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
179140	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	General Comments		
179141	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
179142	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	LTC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
179143	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
179144	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
179145	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
179146	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
179147	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
179148	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179149	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179150	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179151	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179152	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179153	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179154	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179155	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179156	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179157	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
179158	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	73.0	
179159	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	73.0	
179160	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	67.0	
179161	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179162	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179163	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179164	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	3	
179165	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
179166	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
179167	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	0	
179168	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations This Read Vac	0	
179169	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	152	
179170	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	152	
179171	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
179172	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
179173	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
179174	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
179175	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
179176	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179177	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
179178	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Follow-up Action Required?	n	
179179	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
179180	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
179181	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
179182	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
179183	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179184	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179185	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179186	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179187	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179188	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179189	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179190	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179191	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179192	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
179193	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	61.0	
179194	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
179195	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	9	
179196	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	243	
179197	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	234	
179198	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
179199	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
179200	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
179201	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
179202	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
179203	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
179204	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
179205	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
179206	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
179207	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
179208	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	General Comments		
179209	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
179210	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
179211	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
179212	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
179213	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
179214	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
179215	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
179216	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
179217	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
179218	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
179219	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
179220	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
179221	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	General Comments		
179222	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
179223	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
179224	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
179225	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
179226	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
179227	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
179228	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
179229	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
179230	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
179231	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
179232	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	414661	
179233	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
179234	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
179235	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
179236	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
179237	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
179238	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
179239	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
179240	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
179241	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
179242	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
179243	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments	4kv is out of service	
179244	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
179245	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
179246	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
179247	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
179248	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
179249	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
179250	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
179251	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179252	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179253	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179254	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
179255	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
179256	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
179257	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
179258	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
179259	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
179260	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
179261	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
179262	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
179263	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
179264	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
179265	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
179266	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
179267	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
179268	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	55896	
179269	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
179270	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	2L	
179271	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	10R	
179272	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	14L	
179273	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	3826	
179274	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
179275	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
179276	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
179277	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
179278	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations	5	
179279	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179280	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179281	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179282	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps A Ø	0.0	
179283	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps B Ø	0.0	
179284	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps C Ø	0.0	
179285	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
179286	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179287	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179288	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179289	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179290	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179291	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179292	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179293	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179294	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179295	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations A Ø	0	
179296	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations B Ø	0	
179297	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations C Ø	0	
179298	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations Ground	0	
179299	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
179300	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Follow-up Action Required?	y	
179301	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
179302	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
179303	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	General Comments	4kv is out of sevice.	
179304	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179305	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179306	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
179307	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
179308	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Maintenance Operations	0	
179309	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	1	
179310	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
179311	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
179312	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
179313	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
179314	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
179315	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
179316	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
179317	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
179318	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
179319	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
179320	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
179321	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
179322	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
179323	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
179324	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
179325	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AF	303	
179326	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
179327	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
179328	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
179329	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
179330	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AL	303	
179331	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations This Read Vac	1	
179332	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
179333	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Switching Operations	1	
179334	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
179335	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Unknown Operations	0	
179336	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
179337	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
179338	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
179339	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
179340	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
179341	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
179342	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	9	
179343	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
179344	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
179345	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
179346	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179347	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
179348	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
179349	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179350	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179351	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179352	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
179353	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179354	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179355	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
179356	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
179357	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179358	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
179359	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179360	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179361	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
179362	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
179363	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
179364	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
179365	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
179366	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
179367	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	2	
179368	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
179369	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
179370	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179371	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179372	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
179373	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179374	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179375	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
179376	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
179377	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
179378	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
179379	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
179380	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
179381	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
179382	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
179383	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
179384	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
179385	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
179386	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
179387	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
179388	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
179389	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
179390	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
179391	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
179392	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
179393	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
179394	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
179395	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
179396	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
179397	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
179398	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
179399	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
179400	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
179401	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179402	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
179403	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
179404	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179405	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179406	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179407	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179408	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
179409	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
179410	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
179411	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
179412	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	4	
179413	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
179414	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	4	
179415	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	314	
179416	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	310	
179417	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
179418	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
179419	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
179420	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.2084	
179421	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
179422	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179423	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179424	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179425	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	95.0	
179426	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	125.0	
179427	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	110.0	
179428	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
179429	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179430	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179431	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179432	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179433	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179434	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179435	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
179436	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
179437	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179438	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179439	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179440	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179441	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179442	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179443	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179444	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179445	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
179446	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
179447	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
179448	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
179449	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
179450	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
179451	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
179452	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
179453	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
179454	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
179455	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	45	°C
179456	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
179457	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
179458	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	236	
179459	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	45	°C
179460	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
179461	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179462	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8700.48	kw
179463	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
179464	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
179465	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
179466	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179467	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
179468	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
179469	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179470	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
179471	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
179472	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179473	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
179474	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179475	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179476	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179477	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
179478	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
179479	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	238	
179480	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	2	
179481	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179482	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179483	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179484	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179485	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
179486	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
179487	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
179488	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
179489	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
179490	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
179491	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
179492	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
179493	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
179494	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
179495	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
179496	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
179497	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
179498	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
179499	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
179500	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
179501	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
179502	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
179503	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
179504	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179505	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179506	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179507	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
179508	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
179509	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
179510	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
179511	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179512	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179513	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
179514	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179515	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179516	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179517	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179518	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
179519	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179520	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
179521	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
179522	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
179523	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
179524	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
179525	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
179526	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
179527	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
179528	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
179529	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
179530	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
179531	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
179532	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	325	
179533	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	325	
179534	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
179535	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
179536	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
179537	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
179538	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	MB0122	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
179539	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
179540	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
179541	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
179542	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
179543	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
179544	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
179545	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
179546	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	85	*F
179547	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
179548	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
179549	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
179550	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
179551	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179552	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
179553	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
179554	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
179555	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	40.0	
179556	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	40.0	
179557	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	40.0	
179558	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179559	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179560	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179561	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	9	
179562	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
179563	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
179564	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	0	
179565	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations This Read Vac	0	
179566	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	154	
179567	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
179568	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
179569	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
179570	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
179571	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
179572	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
179573	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
179574	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
179575	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
179576	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
179577	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
179578	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
179579	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
179580	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
179581	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
179582	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
179583	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
179584	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179585	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
179586	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
179587	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
179588	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179589	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179590	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179591	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
179592	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
179593	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179594	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
179595	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
179596	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179597	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
179598	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
179599	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
179600	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	4982.40	kw
179601	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179602	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
179603	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	40	*C
179604	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179605	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179606	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179607	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
179608	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
179609	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179610	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179611	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
179612	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.5190	
179613	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
179614	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
179615	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
179616	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
179617	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
179618	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
179619	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
179620	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
179621	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
179622	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
179623	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
179624	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
179625	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
179626	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
179627	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
179628	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
179629	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
179630	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
179631	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
179632	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
179633	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
179634	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
179635	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
179636	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
179637	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
179638	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
179639	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
179640	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
179641	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
179642	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
179643	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
179644	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
179645	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
179646	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
179647	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
179648	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
179649	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
179650	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
179651	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
179652	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
179653	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
179654	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
179655	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
179656	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
179657	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179658	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
179659	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
179660	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
179661	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
179662	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
179663	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
179664	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
179665	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
179666	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
179667	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
179668	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	n	
179669	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
179670	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
179671	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
179672	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
179673	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
179674	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179675	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179676	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179677	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
179678	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
179679	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
179680	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
179681	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
179682	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
179683	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
179684	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE00066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
179685	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
179686	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
179687	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179688	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
179689	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
179690	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
179691	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
179692	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
179693	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179694	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179695	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
179696	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
179697	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
179698	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179699	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
179700	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
179701	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179702	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition?	Good	
179703	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
179704	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
179705	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
179706	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
179707	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
179708	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
179709	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
179710	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
179711	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
179712	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
179713	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
179714	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
179715	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
179716	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
179717	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
179718	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
179719	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
179720	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
179721	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
179722	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
179723	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	138649	
179724	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
179725	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
179726	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
179727	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
179728	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
179729	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179730	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179731	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179732	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
179733	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
179734	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
179735	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179736	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
179737	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
179738	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
179739	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
179740	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
179741	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
179742	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
179743	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
179744	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
179745	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
179746	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179747	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179748	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179749	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179750	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
179751	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
179752	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
179753	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
179754	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
179755	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
179756	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	226	
179757	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	226	
179758	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
179759	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
179760	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
179761	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
179762	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
179763	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
179764	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
179765	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
179766	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	3	
179767	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
179768	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
179769	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
179770	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	156.0	
179771	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE000666	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
179772	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE000666	Fence	361-Fence	Fence Patrol Inspection	General Comments		
179773	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	FE000666	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
179774	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
179775	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
179776	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
179777	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
179778	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
179779	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
179780	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
179781	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
179782	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
179783	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
179784	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
179785	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
179786	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
179787	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
179788	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
179789	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
179790	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
179791	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
179792	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.8130	
179793	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
179794	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179795	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179796	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
179797	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
179798	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179799	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179800	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179801	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	48	*C
179802	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	58	*C
179803	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
179804	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179805	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	7804.80	kw
179806	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
179807	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
179808	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
179809	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179810	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
179811	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
179812	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179813	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
179814	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
179815	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
179816	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	88831	
179817	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	88840	
179818	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
179819	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	2L	
179820	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	3R	
179821	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	10L	
179822	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1615	
179823	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
179824	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
179825	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	58	*C
179826	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	43	*C
179827	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179828	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179829	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179830	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
179831	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
179832	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179833	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179834	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
179835	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	.8958	
179836	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
179837	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
179838	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
179839	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
179840	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179841	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
179842	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179843	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
179844	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
179845	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179846	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
179847	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
179848	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
179849	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
179850	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
179851	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179852	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
179853	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
179854	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
179855	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
179856	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
179857	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
179858	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
179859	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
179860	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179861	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
179862	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
179863	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
179864	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
179865	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	63430	
179866	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
179867	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
179868	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
179869	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
179870	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
179871	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
179872	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
179873	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
179874	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
179875	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
179876	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
179877	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
179878	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
179879	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
179880	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
179881	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
179882	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
179883	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
179884	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
179885	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
179886	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
179887	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
179888	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
179889	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
179890	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
179891	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	250	
179892	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	250	
179893	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
179894	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
179895	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
179896	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
179897	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
179898	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
179899	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
179900	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
179901	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
179902	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
179903	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
179904	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
179905	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
179906	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
179907	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
179908	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
179909	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
179910	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
179911	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
179912	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
179913	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
179914	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
179915	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
179916	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
179917	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
179918	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
179919	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	50	°C
179920	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	50	°C
179921	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.7670	
179922	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
179923	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
179924	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
179925	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
179926	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
179927	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
179928	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
179929	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
179930	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	50	°C
179931	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	70	°C
179932	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
179933	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
179934	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179935	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	13806.00	kw
179936	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
179937	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
179938	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
179939	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179940	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
179941	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
179942	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179943	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
179944	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
179945	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
179946	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
179947	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179948	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
179949	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
179950	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
179951	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
179952	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
179953	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
179954	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5846.40	kw
179955	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	108.33	
179956	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
179957	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
179958	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
179959	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
179960	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
179961	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
179962	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
179963	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.6090	
179964	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
179965	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
179966	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
179967	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
179968	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
179969	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
179970	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
179971	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
179972	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
179973	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
179974	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
179975	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
179976	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
179977	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
179978	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
179979	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
179980	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
179981	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
179982	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
179983	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
179984	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
179985	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
179986	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	655	
179987	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	655	
179988	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
179989	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
179990	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
179991	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
179992	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
179993	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
179994	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
179995	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
179996	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments		
179997	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
179998	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
179999	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
180000	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
180001	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1105.92	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180002	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
180003	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
180004	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
180005	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
180006	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
180007	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	1.5	AMPS
180008	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
180009	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
180010	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
180011	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
180012	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
180013	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
180014	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
180015	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
180016	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
180017	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
180018	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
180019	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
180020	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
180021	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
180022	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
180023	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
180024	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
180025	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
180026	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
180027	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
180028	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
180029	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
180030	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
180031	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
180032	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
180033	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
180034	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
180035	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
180036	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
180037	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
180038	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
180039	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCCControl	728-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
180040	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
180041	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCCControl	728-1	LTC Control Insp	General Comments		
180042	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
180043	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCCControl	728-1	LTC Control Insp	All Connections OK?	y	
180044	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
180045	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
180046	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180047	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180048	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
180049	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
180050	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
180051	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
180052	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
180053	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180054	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180055	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180056	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
180057	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
180058	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
180059	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
180060	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180061	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180062	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
180063	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
180064	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
180065	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
180066	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments	NEW COUNTER	
180067	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
180068	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
180069	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
180070	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
180071	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	26	
180072	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
180073	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
180074	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180075	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
180076	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180077	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
180078	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
180079	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
180080	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	35	°C
180081	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	35	°C
180082	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.5307	
180083	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
180084	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
180085	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
180086	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
180087	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
180088	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
180089	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
180090	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
180091	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	45	°C
180092	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	50	°C
180093	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
180094	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
180095	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
180096	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
180097	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
180098	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
180099	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
180100	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
180101	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
180102	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
180103	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
180104	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
180105	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
180106	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
180107	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
180108	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
180109	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
180110	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
180111	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
180112	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	5094.72	kw
180113	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
180114	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
180115	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6912	
180116	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
180117	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
180118	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
180119	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
180120	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
180121	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
180122	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
180123	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
180124	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
180125	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
180126	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
180127	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
180128	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
180129	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
180130	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
180131	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180132	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180133	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180134	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180135	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180136	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180137	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180138	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
180139	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
180140	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
180141	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
180142	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
180143	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
180144	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
180145	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
180146	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
180147	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
180148	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
180149	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
180150	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
180151	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
180152	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
180153	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
180154	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
180155	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
180156	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
180157	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0115	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
180158	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180159	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180160	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
180161	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
180162	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
180163	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
180164	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
180165	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
180166	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
180167	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180168	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
180169	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	158	
180170	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	158	
180171	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180172	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180173	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180174	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180175	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180176	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180177	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
180178	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	307.0	
180179	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	332.0	
180180	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	334.0	
180181	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180182	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180183	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180184	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	1	
180185	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
180186	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
180187	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180188	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
180189	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
180190	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
180191	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
180192	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
180193	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
180194	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
180195	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
180196	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
180197	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
180198	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
180199	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
180200	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
180201	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	175.0	
180202	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	156.0	
180203	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
180204	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180205	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180206	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180207	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180208	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180209	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180210	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
180211	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180212	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180213	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	1	
180214	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
180215	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
180216	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
180217	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
180218	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
180219	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
180220	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
180221	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
180222	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
180223	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180224	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
180225	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
180226	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	163	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
180227	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
180228	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
180229	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
180230	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
180231	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
180232	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
180233	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
180234	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
180235	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	163	
180236	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	1	
180237	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180238	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
180239	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
180240	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
180241	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
180242	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
180243	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180244	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
180245	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
180246	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
180247	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
180248	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
180249	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
180250	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
180251	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
180252	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
180253	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180254	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180255	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180256	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180257	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180258	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180259	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
180260	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
180261	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180262	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180263	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180264	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
180265	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	645.0	
180266	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	655.0	
180267	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	660.0	
180268	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180269	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180270	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180271	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	6	
180272	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
180273	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
180274	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	LTC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
180275	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180276	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180277	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
180278	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
180279	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
180280	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
180281	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
180282	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
180283	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
180284	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
180285	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
180286	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
180287	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
180288	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
180289	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
180290	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
180291	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
180292	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
180293	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
180294	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
180295	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
180296	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
180297	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
180298	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
180299	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
180300	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
180301	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180302	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
180303	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
180304	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
180305	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
180306	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180307	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180308	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180309	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180310	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180311	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180312	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180313	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180314	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180315	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
180316	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	480.0	
180317	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480.0	
180318	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480.0	
180319	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180320	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
180321	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
180322	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
180323	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180324	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	0	
180325	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	225	
180326	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	225	
180327	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
180328	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
180329	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180330	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
180331	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
180332	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
180333	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	14L	
180334	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
180335	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
180336	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
180337	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
180338	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
180339	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
180340	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
180341	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BCH001235	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
180342	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
180343	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
180344	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
180345	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
180346	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
180347	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
180348	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
180349	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
180350	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	96565	
180351	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
180352	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
180353	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
180354	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
180355	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
180356	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
180357	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
180358	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
180359	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
180360	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
180361	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
180362	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
180363	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
180364	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
180365	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
180366	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
180367	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
180368	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
180369	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
180370	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
180371	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
180372	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
180373	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
180374	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180375	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180376	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
180377	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	6	
180378	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
180379	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
180380	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
180381	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
180382	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
180383	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
180384	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
180385	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
180386	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
180387	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
180388	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
180389	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
180390	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
180391	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments	4kv wooden structure is leaning on transformer. 4kv is out of service.	
180392	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
180393	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
180394	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
180395	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
180396	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
180397	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
180398	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
180399	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
180400	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
180401	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
180402	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
180403	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
180404	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
180405	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
180406	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
180407	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
180408	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
180409	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
180410	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
180411	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
180412	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
180413	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
180414	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
180415	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
180416	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
180417	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
180418	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
180419	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180420	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
180421	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
180422	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
180423	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
180424	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
180425	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
180426	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
180427	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
180428	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
180429	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
180430	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
180431	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
180432	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
180433	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
180434	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
180435	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	410.0	
180436	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	410.0	
180437	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
180438	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
180439	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
180440	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
180441	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
180442	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
180443	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
180444	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
180445	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
180446	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
180447	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
180448	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
180449	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
180450	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	6R	
180451	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	410.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180452	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180453	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180454	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180455	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	4	
180456	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
180457	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
180458	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	2	
180459	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	2	
180460	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180461	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
180462	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	255	
180463	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	255	
180464	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
180465	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
180466	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180467	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
180468	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
180469	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
180470	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
180471	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
180472	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
180473	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
180474	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
180475	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
180476	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
180477	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180478	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180479	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
180480	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
180481	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
180482	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
180483	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
180484	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
180485	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180486	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180487	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180488	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180489	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180490	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180491	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
180492	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
180493	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
180494	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
180495	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
180496	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
180497	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
180498	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
180499	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
180500	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
180501	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
180502	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
180503	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
180504	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
180505	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
180506	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	40	°C
180507	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	50	°C
180508	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
180509	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	4L	
180510	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	2L	
180511	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	11L	
180512	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
180513	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	9797.76	kw
180514	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
180515	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	899	
180516	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
180517	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
180518	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
180519	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
180520	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
180521	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
180522	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
180523	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
180524	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	193544	
180525	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	193553	
180526	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
180527	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	4L	
180528	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	2R	
180529	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	15L	
180530	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	2433	
180531	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
180532	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
180533	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
180534	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
180535	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
180536	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	4	
180537	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	4	
180538	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	284	
180539	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	8	
180540	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180541	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180542	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180543	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	350.0	
180544	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	380.0	
180545	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	380.0	
180546	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180547	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
180548	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180549	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180550	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	2	
180551	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
180552	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
180553	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
180554	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
180555	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	399401	
180556	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	399412	
180557	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
180558	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	5R	
180559	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	9R	
180560	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	5L	
180561	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	2046	
180562	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
180563	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
180564	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
180565	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
180566	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
180567	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
180568	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
180569	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	13475	
180570	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	13483	
180571	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
180572	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
180573	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
180574	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
180575	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
180576	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	1578	
180577	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
180578	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
180579	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	40	°C
180580	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	55	°C
180581	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.6804	
180582	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
180583	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
180584	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
180585	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
180586	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
180587	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
180588	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
180589	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
180590	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
180591	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
180592	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
180593	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
180594	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
180595	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
180596	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
180597	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
180598	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
180599	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
180600	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
180601	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180602	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
180603	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
180604	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180605	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180606	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180607	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180608	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
180609	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
180610	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
180611	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
180612	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
180613	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
180614	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments		
180615	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
180616	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
180617	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
180618	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
180619	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
180620	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
180621	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
180622	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	89	°F
180623	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180624	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180625	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180626	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180627	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180628	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
180629	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	435.0	
180630	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	425.0	
180631	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	405.0	
180632	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
180633	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180634	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180635	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180636	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180637	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180638	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180639	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180640	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180641	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180642	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
180643	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
180644	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
180645	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
180646	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
180647	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
180648	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
180649	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
180650	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
180651	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
180652	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180653	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
180654	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
180655	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	376	
180656	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	380	
180657	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	4	
180658	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180659	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	4	
180660	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
180661	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
180662	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	280	
180663	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
180664	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
180665	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
180666	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
180667	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
180668	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
180669	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
180670	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
180671	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
180672	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
180673	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
180674	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
180675	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
180676	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180677	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
180678	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
180679	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
180680	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
180681	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
180682	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
180683	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
180684	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
180685	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
180686	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
180687	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
180688	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
180689	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
180690	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
180691	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
180692	9/19/2019 9:54	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
180693	9/19/2019 9:54	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
180694	9/19/2019 9:54	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
180695	9/19/2019 9:54	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
180696	9/19/2019 9:54	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
180697	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
180698	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
180699	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
180700	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
180701	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
180702	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	260.0	
180703	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	250.0	
180704	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	247.0	
180705	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180706	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180707	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180708	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	69	
180709	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
180710	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
180711	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
180712	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
180713	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
180714	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
180715	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
180716	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
180717	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
180718	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
180719	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
180720	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	2101.44	kw
180721	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
180722	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
180723	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
180724	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
180725	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
180726	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
180727	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
180728	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
180729	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
180730	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
180731	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
180732	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180733	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
180734	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
180735	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
180736	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
180737	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180738	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180739	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
180740	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
180741	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
180742	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
180743	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
180744	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
180745	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
180746	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
180747	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
180748	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
180749	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180750	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180751	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180752	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180753	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180754	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180755	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
180756	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
180757	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	72.0	
180758	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
180759	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180760	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180761	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180762	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180763	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180764	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
180765	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
180766	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
180767	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
180768	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
180769	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
180770	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
180771	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
180772	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	General Comments		
180773	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
180774	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
180775	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
180776	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
180777	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
180778	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	956	
180779	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	960	
180780	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
180781	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
180782	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
180783	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
180784	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
180785	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
180786	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180787	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180788	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180789	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
180790	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
180791	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
180792	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
180793	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180794	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180795	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180796	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180797	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180798	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180799	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180800	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180801	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180802	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
180803	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
180804	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0116	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
180805	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
180806	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
180807	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
180808	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	1.2780	
180809	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
180810	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
180811	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
180812	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
180813	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
180814	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
180815	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
180816	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
180817	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	50	*C
180818	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	70	*C
180819	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
180820	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
180821	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	12268.80	kw
180822	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
180823	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
180824	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
180825	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
180826	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180827	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
180828	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
180829	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
180830	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
180831	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
180832	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
180833	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
180834	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
180835	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
180836	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
180837	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
180838	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
180839	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
180840	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	6449.76	kw
180841	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	90.0	
180842	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	95.0	
180843	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	110.0	
180844	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
180845	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
180846	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
180847	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0095	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
180848	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
180849	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
180850	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
180851	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
180852	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
180853	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
180854	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
180855	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
180856	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
180857	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
180858	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
180859	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
180860	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
180861	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
180862	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
180863	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
180864	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
180865	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
180866	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
180867	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
180868	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
180869	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
180870	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
180871	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
180872	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
180873	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
180874	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
180875	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
180876	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
180877	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
180878	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
180879	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
180880	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
180881	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
180882	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
180883	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments	lightening arrester has come loose at the chance clamp.	
180884	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
180885	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
180886	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
180887	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
180888	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
180889	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
180890	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
180891	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	212	
180892	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	210	
180893	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
180894	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
180895	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
180896	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
180897	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
180898	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
180899	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
180900	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
180901	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180902	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
180903	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
180904	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
180905	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180906	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180907	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180908	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180909	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180910	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180911	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180912	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180913	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180914	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
180915	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	80.0	
180916	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	50.0	
180917	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	60.0	
180918	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
180919	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
180920	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
180921	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	54	
180922	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
180923	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
180924	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	2	
180925	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	1L	
180926	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
180927	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	189862	
180928	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	189862	
180929	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
180930	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
180931	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	2	
180932	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	204	
180933	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	202	
180934	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
180935	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
180936	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
180937	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
180938	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
180939	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
180940	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
180941	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
180942	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
180943	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
180944	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
180945	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
180946	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
180947	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
180948	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
180949	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
180950	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
180951	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
180952	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
180953	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
180954	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
180955	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
180956	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
180957	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
180958	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
180959	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
180960	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
180961	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
180962	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
180963	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
180964	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
180965	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.4378	
180966	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
180967	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Present	42	*C
180968	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Top Oil Temperature Max	58	*C
180969	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
180970	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
180971	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
180972	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
180973	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
180974	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
180975	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
180976	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
180977	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
180978	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
180979	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
180980	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
180981	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
180982	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
180983	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
180984	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
180985	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
180986	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
180987	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
180988	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
180989	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
180990	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
180991	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
180992	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
180993	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
180994	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
180995	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
180996	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
180997	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
180998	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
180999	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	154	
181000	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	146	
181001	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
181002	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
181003	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
181004	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
181005	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
181006	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
181007	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
181008	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
181009	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
181010	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
181011	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
181012	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
181013	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
181014	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
181015	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
181016	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
181017	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
181018	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
181019	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
181020	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
181021	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
181022	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
181023	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
181024	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
181025	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
181026	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
181027	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
181028	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
181029	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
181030	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
181031	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
181032	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	563	
181033	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	567	
181034	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
181035	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181036	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
181037	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
181038	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
181039	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
181040	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
181041	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
181042	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
181043	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
181044	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
181045	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
181046	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
181047	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
181048	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
181049	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
181050	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
181051	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181052	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
181053	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
181054	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
181055	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
181056	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
181057	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
181058	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	11692.80	kw
181059	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
181060	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
181061	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
181062	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
181063	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
181064	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
181065	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
181066	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
181067	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
181068	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
181069	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	1378	
181070	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	53	°C
181071	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
181072	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	10L	
181073	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	2L	
181074	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	4L	
181075	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
181076	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	49067	
181077	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	49067	
181078	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
181079	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
181080	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
181081	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
181082	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
181083	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
181084	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
181085	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
181086	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
181087	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
181088	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
181089	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181090	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181091	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181092	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
181093	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
181094	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
181095	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
181096	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181097	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181098	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181099	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181100	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181101	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
181102	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181103	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
181104	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
181105	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
181106	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
181107	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
181108	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
181109	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	297	
181110	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	302	
181111	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
181112	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181113	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
181114	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
181115	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
181116	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
181117	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
181118	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
181119	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
181120	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
181121	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
181122	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
181123	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
181124	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
181125	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
181126	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
181127	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
181128	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
181129	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
181130	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
181131	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
181132	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181133	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
181134	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	161	
181135	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	161	
181136	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
181137	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
181138	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
181139	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
181140	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
181141	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
181142	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
181143	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
181144	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
181145	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
181146	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
181147	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
181148	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
181149	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
181150	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
181151	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
181152	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
181153	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181154	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181155	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181156	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181157	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181158	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181159	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181160	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181161	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181162	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
181163	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	470.0	
181164	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	470.0	
181165	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
181166	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Max	70	°C
181167	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Top Oil Temperature Present	55	°C
181168	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
181169	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.8120	
181170	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	70	°C
181171	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	60	°C
181172	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
181173	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
181174	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.8388	
181175	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	68	°C
181176	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	43	°C
181177	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
181178	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
181179	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
181180	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
181181	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
181182	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.5928	
181183	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
181184	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
181185	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
181186	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
181187	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
181188	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
181189	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
181190	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
181191	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	42	°C
181192	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
181193	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
181194	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
181195	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
181196	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
181197	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
181198	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
181199	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
181200	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
181201	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
181202	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
181203	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
181204	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
181205	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
181206	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
181207	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
181208	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
181209	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	48	°C
181210	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
181211	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
181212	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	5690.88	kw
181213	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
181214	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
181215	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
181216	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
181217	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
181218	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
181219	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
181220	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
181221	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
181222	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
181223	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	General Comments		
181224	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
181225	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
181226	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
181227	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
181228	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
181229	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99981	
181230	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99985	
181231	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
181232	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
181233	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
181234	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
181235	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
181236	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
181237	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
181238	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
181239	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
181240	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	0	
181241	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	0	
181242	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	169	
181243	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	169	
181244	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
181245	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
181246	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
181247	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
181248	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
181249	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
181250	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
181251	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
181252	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
181253	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
181254	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
181255	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
181256	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
181257	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
181258	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
181259	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
181260	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
181261	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
181262	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
181263	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	5L	
181264	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	2R	
181265	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	10L	
181266	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	1020	
181267	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
181268	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
181269	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
181270	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
181271	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1850	psi
181272	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181273	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	2	
181274	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
181275	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
181276	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	9871.20	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181277	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
181278	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
181279	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
181280	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
181281	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
181282	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
181283	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
181284	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
181285	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Max	79	°C
181286	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Top Oil Temperature Present	71	°C
181287	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
181288	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
181289	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181290	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181291	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181292	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	95.0	
181293	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
181294	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
181295	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
181296	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
181297	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
181298	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
181299	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
181300	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
181301	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
181302	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
181303	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
181304	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
181305	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
181306	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
181307	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
181308	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
181309	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BAT000422	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
181310	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181311	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
181312	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
181313	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
181314	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
181315	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
181316	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
181317	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
181318	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
181319	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
181320	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
181321	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
181322	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
181323	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.9230	
181324	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	82	°C
181325	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181326	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
181327	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
181328	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
181329	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
181330	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
181331	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
181332	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
181333	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
181334	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
181335	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
181336	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
181337	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
181338	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
181339	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
181340	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
181341	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
181342	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
181343	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
181344	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
181345	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
181346	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
181347	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181348	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
181349	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
181350	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BCH000282	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
181351	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	74	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
181352	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
181353	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
181354	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
181355	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
181356	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
181357	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
181358	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
181359	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
181360	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
181361	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
181362	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
181363	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
181364	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
181365	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	
181366	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181367	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181368	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181369	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181370	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181371	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181372	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181373	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181374	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181375	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
181376	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	6.0	
181377	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	5.0	
181378	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	6.0	
181379	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181380	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181381	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181382	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	37	
181383	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
181384	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181385	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181386	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181387	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181388	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181389	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181390	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181391	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0265	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181392	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
181393	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
181394	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
181395	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	16614.00	kw
181396	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
181397	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
181398	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	78	°C
181399	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	67	°C
181400	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
181401	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181402	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
181403	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
181404	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
181405	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
181406	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	BCH000484	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
181407	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
181408	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
181409	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
181410	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
181411	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
181412	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
181413	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	General Comments		
181414	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
181415	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
181416	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
181417	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
181418	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
181419	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
181420	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
181421	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
181422	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
181423	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181424	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181425	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181426	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
181427	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181428	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181429	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181430	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181431	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181432	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
181433	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	56.0	
181434	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	53.0	
181435	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	61.0	
181436	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181437	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	6.2	VDC
181438	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	45.2	VDC
181439	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
181440	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
181441	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
181442	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
181443	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
181444	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
181445	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
181446	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
181447	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
181448	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
181449	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
181450	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181451	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181452	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	1	
181453	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1149	
181454	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.5	psi
181455	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
181456	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
181457	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
181458	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
181459	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
181460	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
181461	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
181462	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
181463	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
181464	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
181465	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
181466	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
181467	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
181468	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
181469	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
181470	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
181471	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
181472	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
181473	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
181474	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
181475	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
181476	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
181477	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
181478	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
181479	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
181480	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
181481	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
181482	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
181483	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
181484	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
181485	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
181486	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
181487	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
181488	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
181489	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
181490	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
181491	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
181492	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	1	
181493	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181494	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	1	
181495	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	173	
181496	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	172	
181497	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
181498	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
181499	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
181500	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
181501	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181502	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
181503	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
181504	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
181505	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
181506	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
181507	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
181508	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
181509	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
181510	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
181511	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
181512	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
181513	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
181514	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
181515	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
181516	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
181517	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
181518	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	General Comments		
181519	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
181520	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	All Connections OK?	y	
181521	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
181522	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
181523	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
181524	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
181525	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
181526	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181527	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
181528	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
181529	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
181530	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
181531	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181532	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
181533	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
181534	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
181535	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
181536	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
181537	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
181538	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	121.8	VAC
181539	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
181540	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
181541	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
181542	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
181543	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
181544	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
181545	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
181546	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
181547	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
181548	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
181549	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
181550	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
181551	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
181552	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
181553	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
181554	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
181555	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	16786	
181556	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
181557	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
181558	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
181559	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
181560	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
181561	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
181562	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
181563	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
181564	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
181565	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
181566	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
181567	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
181568	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	16786	
181569	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
181570	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
181571	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
181572	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
181573	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
181574	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
181575	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
181576	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181577	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
181578	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
181579	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
181580	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
181581	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
181582	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
181583	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
181584	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
181585	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
181586	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
181587	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
181588	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
181589	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
181590	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
181591	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
181592	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
181593	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
181594	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
181595	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
181596	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
181597	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
181598	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	LTC0000243	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
181599	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	LTC0000250	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
181600	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181601	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181602	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181603	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181604	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
181605	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
181606	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
181607	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
181608	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181609	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181610	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181611	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181612	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181613	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181614	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181615	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181616	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181617	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
181618	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	
181619	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	0	
181620	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
181621	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
181622	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
181623	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
181624	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
181625	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
181626	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
181627	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
181628	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
181629	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	186	
181630	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	186	
181631	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	0	
181632	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	0	
181633	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
181634	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
181635	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
181636	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	8737.92	kw
181637	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
181638	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
181639	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	45	°C
181640	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
181641	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
181642	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
181643	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
181644	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
181645	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
181646	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
181647	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	LTC0000045	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
181648	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	470.0	
181649	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181650	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181651	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181652	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	0	
181653	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
181654	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
181655	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	5	
181656	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	4	
181657	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181658	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181659	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181660	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	73.0	
181661	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
181662	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
181663	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
181664	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
181665	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
181666	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
181667	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
181668	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
181669	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
181670	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
181671	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
181672	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
181673	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
181674	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	94.0	
181675	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	97.0	
181676	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
181677	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181678	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	5	
181679	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	198	
181680	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	194	
181681	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
181682	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
181683	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
181684	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
181685	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
181686	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
181687	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
181688	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
181689	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
181690	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
181691	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
181692	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
181693	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
181694	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181695	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181696	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181697	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
181698	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
181699	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
181700	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
181701	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
181702	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
181703	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
181704	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
181705	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
181706	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
181707	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
181708	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
181709	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
181710	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
181711	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
181712	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
181713	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
181714	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
181715	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
181716	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
181717	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
181718	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
181719	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	45	*C
181720	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
181721	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
181722	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
181723	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
181724	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
181725	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
181726	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181727	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
181728	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	.9102	
181729	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	40	°C
181730	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
181731	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
181732	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
181733	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
181734	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
181735	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
181736	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
181737	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
181738	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
181739	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
181740	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
181741	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
181742	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
181743	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
181744	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
181745	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181746	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181747	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
181748	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	300.0	
181749	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	295.0	
181750	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	295.0	
181751	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181752	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181753	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181754	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	9	
181755	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
181756	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
181757	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
181758	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
181759	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	2714	
181760	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	2714	
181761	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
181762	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
181763	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	4R	
181764	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	11L	
181765	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
181766	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	1531	
181767	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
181768	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
181769	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
181770	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
181771	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
181772	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
181773	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
181774	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
181775	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
181776	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
181777	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
181778	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
181779	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
181780	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
181781	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
181782	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
181783	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
181784	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
181785	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
181786	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
181787	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
181788	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
181789	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
181790	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
181791	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
181792	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
181793	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
181794	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181795	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181796	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181797	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181798	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181799	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181800	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181801	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181802	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181803	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181804	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181805	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	30.0	
181806	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	30.0	
181807	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	35.0	
181808	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
181809	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181810	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
181811	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
181812	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
181813	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
181814	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
181815	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
181816	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181817	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181818	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181819	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181820	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181821	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181822	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181823	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181824	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181825	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
181826	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	120.0	
181827	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	92.0	
181828	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	130.0	
181829	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181830	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181831	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181832	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	37	
181833	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181834	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181835	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181836	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181837	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
181838	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181839	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
181840	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	69.0	
181841	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	82.0	
181842	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
181843	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
181844	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
181845	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
181846	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
181847	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
181848	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
181849	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
181850	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
181851	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
181852	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
181853	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
181854	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
181855	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
181856	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
181857	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
181858	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
181859	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
181860	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
181861	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
181862	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
181863	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
181864	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
181865	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
181866	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
181867	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
181868	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
181869	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
181870	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
181871	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
181872	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
181873	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
181874	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
181875	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
181876	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181877	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
181878	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
181879	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
181880	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
181881	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	8	
181882	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181883	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181884	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181885	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	120.0	
181886	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	120.0	
181887	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	120.0	
181888	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
181889	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
181890	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
181891	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
181892	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
181893	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
181894	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
181895	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
181896	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181897	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181898	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181899	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
181900	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
181901	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
181902	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
181903	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
181904	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
181905	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
181906	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
181907	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
181908	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
181909	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
181910	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
181911	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
181912	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
181913	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	253	
181914	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	255	
181915	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	2	
181916	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
181917	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	2	
181918	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
181919	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
181920	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
181921	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
181922	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.1	VDC
181923	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	67.6	VDC
181924	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
181925	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
181926	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
181927	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
181928	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
181929	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
181930	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
181931	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
181932	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
181933	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
181934	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
181935	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
181936	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
181937	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
181938	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	70.0	
181939	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
181940	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
181941	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
181942	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	6	
181943	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
181944	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
181945	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
181946	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
181947	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
181948	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
181949	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181950	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
181951	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
181952	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
181953	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
181954	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
181955	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
181956	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
181957	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
181958	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
181959	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
181960	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
181961	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
181962	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
181963	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
181964	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
181965	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
181966	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
181967	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
181968	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
181969	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
181970	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
181971	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
181972	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
181973	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
181974	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
181975	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
181976	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
181977	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
181978	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
181979	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	177	
181980	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	178	
181981	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	1	
181982	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	1	
181983	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
181984	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
181985	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
181986	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
181987	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
181988	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
181989	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	86	*F
181990	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
181991	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
181992	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
181993	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
181994	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
181995	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
181996	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
181997	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
181998	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
181999	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	3	
182000	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182001	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182002	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182003	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
182004	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
182005	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
182006	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
182007	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
182008	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
182009	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
182010	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
182011	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
182012	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
182013	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	2	
182014	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	198	
182015	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	198	
182016	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
182017	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	2	
182018	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
182019	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
182020	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
182021	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
182022	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
182023	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
182024	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
182025	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	324.0	
182026	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	319.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182027	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	332.0	
182028	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
182029	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182030	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182031	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182032	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182033	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182034	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182035	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
182036	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
182037	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
182038	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
182039	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
182040	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
182041	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
182042	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
182043	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
182044	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
182045	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	0	
182046	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
182047	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
182048	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
182049	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
182050	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
182051	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
182052	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
182053	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
182054	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
182055	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
182056	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
182057	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
182058	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
182059	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
182060	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
182061	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
182062	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
182063	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
182064	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
182065	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
182066	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
182067	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
182068	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	1	
182069	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	47	
182070	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	47	
182071	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
182072	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
182073	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	87	psi
182074	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
182075	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
182076	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
182077	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
182078	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
182079	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
182080	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
182081	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
182082	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182083	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
182084	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
182085	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
182086	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	159283	
182087	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	159293	
182088	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
182089	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
182090	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
182091	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
182092	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
182093	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
182094	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
182095	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
182096	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
182097	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
182098	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
182099	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
182100	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
182101	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182102	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182103	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182104	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182105	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182106	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182107	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
182108	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
182109	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
182110	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
182111	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182112	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182113	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182114	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	31	
182115	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
182116	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
182117	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	4R	
182118	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	11L	
182119	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	3071	
182120	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
182121	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
182122	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
182123	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
182124	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
182125	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	0	
182126	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	0	
182127	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	187	
182128	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	187	
182129	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
182130	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
182131	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182132	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182133	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182134	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
182135	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
182136	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
182137	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
182138	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
182139	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
182140	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
182141	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
182142	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
182143	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
182144	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
182145	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
182146	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
182147	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	177	
182148	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	177	
182149	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	0	
182150	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182151	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
182152	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
182153	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
182154	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
182155	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	4	
182156	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182157	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182158	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182159	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
182160	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
182161	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182162	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182163	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182164	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182165	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182166	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182167	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182168	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	21.0	
182169	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	20.0	
182170	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	25.0	
182171	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
182172	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
182173	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182174	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	11	
182175	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1671	
182176	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1663	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182177	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
182178	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	D80050	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
182179	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
182180	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182181	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182182	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182183	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182184	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182185	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
182186	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	449.0	
182187	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	450.0	
182188	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	463.0	
182189	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182190	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182191	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
182192	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
182193	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
182194	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
182195	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
182196	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
182197	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
182198	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
182199	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
182200	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
182201	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
182202	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
182203	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	General Comments		
182204	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
182205	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
182206	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
182207	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
182208	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
182209	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
182210	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
182211	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
182212	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
182213	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
182214	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
182215	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
182216	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
182217	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
182218	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
182219	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
182220	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
182221	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
182222	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	General Comments		
182223	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
182224	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTC0000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
182225	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
182226	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
182227	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
182228	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
182229	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
182230	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
182231	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
182232	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
182233	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
182234	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
182235	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
182236	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
182237	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
182238	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
182239	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
182240	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
182241	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
182242	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
182243	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
182244	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
182245	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
182246	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
182247	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
182248	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
182249	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
182250	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
182251	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182252	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
182253	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
182254	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
182255	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
182256	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
182257	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
182258	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
182259	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
182260	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
182261	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
182262	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
182263	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
182264	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
182265	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
182266	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
182267	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
182268	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
182269	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
182270	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
182271	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
182272	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182273	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182274	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182275	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182276	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
182277	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
182278	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	12078.72	kw
182279	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
182280	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
182281	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
182282	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	45	*C
182283	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	55	*C
182284	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.5484	
182285	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
182286	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
182287	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
182288	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
182289	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
182290	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
182291	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
182292	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
182293	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
182294	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
182295	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
182296	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
182297	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
182298	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
182299	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182300	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CB0094	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182301	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
182302	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	40	*C
182303	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	45	*C
182304	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
182305	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
182306	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
182307	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
182308	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	56071	
182309	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	56084	
182310	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
182311	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	7L	
182312	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	1L	
182313	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	12L	
182314	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	1071	
182315	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
182316	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
182317	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
182318	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
182319	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
182320	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
182321	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
182322	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	11268	
182323	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	11268	
182324	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
182325	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	1781	
182326	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
182327	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
182328	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
182329	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	BAT000440	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
182330	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
182331	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
182332	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
182333	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
182334	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
182335	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
182336	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
182337	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
182338	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
182339	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
182340	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
182341	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
182342	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
182343	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
182344	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
182345	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	*C
182346	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	*C
182347	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
182348	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	2L	
182349	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	10L	
182350	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
182351	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	27001	
182352	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	27001	
182353	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
182354	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
182355	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
182356	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
182357	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
182358	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
182359	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
182360	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
182361	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
182362	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
182363	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
182364	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
182365	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
182366	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
182367	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
182368	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
182369	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
182370	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
182371	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
182372	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
182373	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
182374	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
182375	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182376	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182377	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182378	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182379	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182380	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182381	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182382	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182383	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182384	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
182385	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
182386	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
182387	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
182388	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
182389	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
182390	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
182391	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
182392	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
182393	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
182394	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
182395	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
182396	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
182397	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	182.0	
182398	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	174.0	
182399	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	170.0	
182400	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182401	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182402	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182403	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
182404	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	0	
182405	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182406	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182407	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182408	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	320.0	
182409	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	160.0	
182410	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	160.0	
182411	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
182412	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182413	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182414	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
182415	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
182416	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
182417	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
182418	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
182419	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
182420	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
182421	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
182422	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
182423	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
182424	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
182425	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
182426	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
182427	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
182428	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
182429	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
182430	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
182431	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
182432	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
182433	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182434	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
182435	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
182436	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
182437	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
182438	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
182439	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
182440	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
182441	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
182442	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
182443	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
182444	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
182445	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
182446	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
182447	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
182448	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
182449	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182450	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182451	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
182452	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
182453	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
182454	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
182455	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
182456	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
182457	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
182458	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
182459	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
182460	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
182461	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
182462	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
182463	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
182464	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	270	
182465	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	274	
182466	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	4	
182467	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182468	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	4	
182469	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
182470	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
182471	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
182472	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
182473	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
182474	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
182475	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	64	
182476	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	64	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
182477	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
182478	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182479	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182480	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182481	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182482	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182483	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182484	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
182485	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	120.0	
182486	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	84.0	
182487	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	84.0	
182488	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182489	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182490	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182491	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	8	
182492	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182493	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
182494	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
182495	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
182496	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
182497	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
182498	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
182499	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
182500	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
182501	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
182502	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
182503	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
182504	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
182505	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
182506	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
182507	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
182508	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
182509	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
182510	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
182511	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
182512	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
182513	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
182514	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	162	
182515	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	162	
182516	9/19/2019 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
182517	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
182518	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
182519	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
182520	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
182521	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
182522	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
182523	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
182524	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
182525	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
182526	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
182527	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
182528	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	BAT000414	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
182529	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
182530	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182531	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
182532	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
182533	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	4	
182534	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182535	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	4	
182536	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	251	
182537	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	251	
182538	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
182539	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
182540	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
182541	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
182542	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
182543	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
182544	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
182545	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
182546	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
182547	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
182548	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
182549	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
182550	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182551	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182552	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182553	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182554	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182555	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182556	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182557	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182558	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182559	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
182560	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
182561	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
182562	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
182563	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
182564	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
182565	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
182566	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
182567	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
182568	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
182569	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
182570	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
182571	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
182572	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
182573	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	4	
182574	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182575	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182576	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182577	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	65.0	
182578	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	53.0	
182579	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	54.0	
182580	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
182581	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182582	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182583	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182584	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182585	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182586	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182587	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182588	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182589	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182590	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
182591	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
182592	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
182593	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
182594	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
182595	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
182596	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
182597	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
182598	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
182599	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
182600	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	2	
182601	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
182602	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	187	
182603	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	187	
182604	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	2	
182605	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
182606	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
182607	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
182608	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
182609	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
182610	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
182611	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.700	millivolts
182612	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
182613	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
182614	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
182615	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
182616	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182617	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182618	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182619	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
182620	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
182621	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
182622	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
182623	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
182624	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
182625	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
182626	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182627	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
182628	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182629	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
182630	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
182631	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
182632	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
182633	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
182634	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
182635	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
182636	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		
182637	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
182638	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
182639	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
182640	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
182641	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
182642	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
182643	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
182644	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
182645	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
182646	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
182647	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
182648	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
182649	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
182650	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
182651	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
182652	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
182653	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
182654	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
182655	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
182656	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
182657	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
182658	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
182659	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
182660	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182661	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
182662	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
182663	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
182664	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
182665	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
182666	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	12.0	
182667	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	12.0	
182668	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
182669	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182670	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182671	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182672	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182673	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
182674	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
182675	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
182676	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
182677	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
182678	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
182679	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
182680	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
182681	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
182682	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182683	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182684	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182685	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182686	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182687	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
182688	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
182689	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
182690	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
182691	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
182692	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	933.12	kw
182693	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
182694	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
182695	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	45	°C
182696	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
182697	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
182698	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
182699	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
182700	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
182701	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182702	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
182703	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
182704	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
182705	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1944	
182706	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
182707	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
182708	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
182709	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
182710	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
182711	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
182712	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	149	
182713	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	149	
182714	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
182715	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BCH000976	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
182716	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
182717	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
182718	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
182719	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
182720	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
182721	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
182722	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
182723	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
182724	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
182725	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
182726	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
182727	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
182728	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
182729	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
182730	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
182731	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
182732	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	4	
182733	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182734	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182735	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182736	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
182737	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
182738	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
182739	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
182740	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
182741	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
182742	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
182743	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
182744	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
182745	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
182746	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
182747	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
182748	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
182749	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
182750	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
182751	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
182752	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	12.0	
182753	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
182754	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
182755	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
182756	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
182757	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
182758	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
182759	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
182760	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
182761	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
182762	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
182763	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
182764	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
182765	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
182766	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
182767	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
182768	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
182769	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
182770	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
182771	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182772	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182773	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182774	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182775	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182776	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182777	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182778	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182779	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182780	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
182781	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	15.0	
182782	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	15.0	
182783	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	25.0	
182784	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182785	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182786	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182787	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	5	
182788	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
182789	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	10L	
182790	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	6R	
182791	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	3R	
182792	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
182793	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
182794	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
182795	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	8	
182796	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
182797	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	8	
182798	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	481	
182799	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	473	
182800	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
182801	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
182802	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?		
182803	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
182804	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
182805	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
182806	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
182807	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
182808	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	0	
182809	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
182810	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
182811	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
182812	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
182813	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
182814	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
182815	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
182816	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
182817	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
182818	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
182819	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
182820	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
182821	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
182822	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
182823	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
182824	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
182825	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
182826	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
182827	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
182828	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
182829	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
182830	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
182831	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
182832	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
182833	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
182834	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
182835	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
182836	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments	69 KV tower leg crumbing.	
182837	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
182838	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
182839	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
182840	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
182841	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
182842	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
182843	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
182844	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
182845	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
182846	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
182847	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
182848	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
182849	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
182850	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	3	
182851	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	3	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182852	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	240	
182853	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	237	
182854	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
182855	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
182856	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
182857	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
182858	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
182859	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	1490	
182860	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
182861	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
182862	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
182863	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
182864	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
182865	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	72790	
182866	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	72790	
182867	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
182868	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
182869	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
182870	9/19/2019 13:35	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
182871	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	70	*C
182872	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	70	*C
182873	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9944	
182874	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
182875	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
182876	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
182877	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
182878	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
182879	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
182880	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
182881	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
182882	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	55	*C
182883	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	55	*C
182884	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
182885	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
182886	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9546.24	kw
182887	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
182888	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
182889	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
182890	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
182891	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
182892	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
182893	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
182894	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
182895	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
182896	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
182897	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
182898	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
182899	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
182900	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
182901	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	LTC000201	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
182902	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
182903	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182904	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182905	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182906	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
182907	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182908	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182909	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182910	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182911	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0141	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182912	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
182913	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
182914	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
182915	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
182916	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
182917	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
182918	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
182919	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
182920	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
182921	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	120.0	
182922	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
182923	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
182924	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
182925	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
182926	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
182927	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
182928	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
182929	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
182930	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
182931	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
182932	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
182933	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
182934	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
182935	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
182936	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
182937	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
182938	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
182939	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
182940	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
182941	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
182942	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
182943	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
182944	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
182945	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
182946	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
182947	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
182948	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments	Trailers and material in yard	
182949	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
182950	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
182951	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
182952	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
182953	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
182954	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
182955	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
182956	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	132.0	
182957	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	108.0	
182958	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
182959	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
182960	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
182961	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	18	
182962	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
182963	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
182964	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
182965	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
182966	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
182967	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
182968	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
182969	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
182970	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
182971	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
182972	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments	fence is rusty, large gap beneath fenced, but has barb wire spanning it. One fence post washed out and is loose	
182973	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
182974	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
182975	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
182976	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
182977	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
182978	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
182979	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
182980	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
182981	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
182982	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
182983	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
182984	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
182985	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
182986	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
182987	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments	Barb wire rusty	
182988	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
182989	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
182990	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
182991	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
182992	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
182993	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
182994	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
182995	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
182996	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
182997	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
182998	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
182999	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
183000	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
183001	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183002	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
183003	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
183004	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
183005	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
183006	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183007	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC0000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
183008	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC0000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
183009	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC0000139	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
183010	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC0000139	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
183011	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
183012	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
183013	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
183014	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
183015	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
183016	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
183017	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
183018	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	567.0	
183019	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	583.0	
183020	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	578.0	
183021	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183022	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183023	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
183024	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183025	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183026	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183027	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183028	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183029	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183030	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183031	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183032	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183033	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
183034	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	570.0	
183035	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	565.0	
183036	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	550.0	
183037	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183038	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183039	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183040	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
183041	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183042	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	1	
183043	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
183044	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
183045	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	1	
183046	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	1	
183047	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	251	
183048	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	251	
183049	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
183050	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
183051	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
183052	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
183053	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
183054	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
183055	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments	*	
183056	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
183057	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
183058	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
183059	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
183060	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
183061	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
183062	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
183063	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
183064	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
183065	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
183066	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
183067	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
183068	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
183069	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183070	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
183071	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
183072	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	167	
183073	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	169	
183074	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	2	
183075	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183076	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	2	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183077	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
183078	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
183079	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
183080	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
183081	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
183082	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
183083	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
183084	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
183085	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	1	
183086	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
183087	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
183088	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
183089	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	1	
183090	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	176	
183091	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	176	
183092	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
183093	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
183094	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
183095	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
183096	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
183097	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
183098	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
183099	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
183100	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
183101	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
183102	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
183103	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
183104	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
183105	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
183106	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
183107	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
183108	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
183109	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
183110	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
183111	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
183112	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
183113	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTCC000139	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
183114	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183115	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183116	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183117	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183118	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183119	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183120	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183121	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183122	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
183123	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	100.0	
183124	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	118.0	
183125	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	104.0	
183126	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183127	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183128	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183129	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	2	
183130	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183131	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183132	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
183133	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
183134	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
183135	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	4	
183136	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183137	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	All Connections OK?	y	
183138	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
183139	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	General Comments		
183140	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183141	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
183142	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
183143	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
183144	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183145	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	70.0	
183146	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	70.0	
183147	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	65.0	
183148	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
183149	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183150	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183151	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183152	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183153	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183154	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183155	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183156	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183157	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183158	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
183159	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
183160	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
183161	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
183162	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
183163	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
183164	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
183165	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
183166	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
183167	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
183168	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
183169	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
183170	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
183171	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
183172	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
183173	9/19/2019 12:02	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
183174	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
183175	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
183176	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
183177	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
183178	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
183179	9/19/2019 11:06	Distribution	Sylvania Quarterly Inspection	LTC000199	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
183180	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
183181	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
183182	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
183183	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
183184	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
183185	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
183186	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
183187	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	LTC000190	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
183188	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
183189	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
183190	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
183191	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
183192	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
183193	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
183194	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
183195	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
183196	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
183197	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
183198	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	206.0	
183199	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	207.0	
183200	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	205.0	
183201	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
183202	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183203	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183204	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183205	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
183206	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
183207	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
183208	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
183209	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
183210	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
183211	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
183212	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
183213	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
183214	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
183215	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
183216	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
183217	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
183218	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
183219	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
183220	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	72	*F
183221	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
183222	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
183223	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
183224	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
183225	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
183226	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183227	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
183228	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
183229	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
183230	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
183231	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
183232	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		lightening arrestor has come loose at the chance clamp.
183233	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
183234	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
183235	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
183236	9/19/2019 14:06	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
183237	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	2	
183238	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183239	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183240	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183241	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrestor Condition	Good	
183242	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
183243	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
183244	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
183245	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
183246	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
183247	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
183248	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
183249	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183250	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
183251	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
183252	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	284	
183253	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	284	
183254	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	0	
183255	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183256	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
183257	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
183258	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
183259	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
183260	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
183261	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
183262	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
183263	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
183264	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
183265	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
183266	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
183267	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
183268	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183269	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183270	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183271	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183272	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183273	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183274	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183275	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183276	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183277	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
183278	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
183279	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
183280	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
183281	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183282	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183283	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183284	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
183285	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
183286	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
183287	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
183288	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
183289	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
183290	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
183291	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
183292	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183293	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183294	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183295	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183296	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183297	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183298	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183299	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
183300	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
183301	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
183302	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
183303	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BCH001150	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
183304	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183305	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183306	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183307	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
183308	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
183309	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
183310	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
183311	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
183312	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
183313	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
183314	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
183315	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
183316	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
183317	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
183318	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
183319	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
183320	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
183321	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	207	
183322	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	207	
183323	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
183324	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
183325	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183326	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
183327	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
183328	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
183329	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
183330	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
183331	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
183332	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
183333	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
183334	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
183335	9/19/2019 12:53	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
183336	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
183337	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183338	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183339	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183340	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
183341	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
183342	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
183343	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
183344	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
183345	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
183346	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
183347	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
183348	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
183349	9/19/2019 12:28	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
183350	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
183351	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183352	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
183353	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	291	
183354	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	291	
183355	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
183356	9/19/2019 11:16	Distribution	Caron Quarterly Inspection	MB0114	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
183357	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
183358	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
183359	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
183360	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
183361	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
183362	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
183363	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
183364	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
183365	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
183366	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
183367	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
183368	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
183369	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
183370	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
183371	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	20932	
183372	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	20932	
183373	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
183374	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
183375	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
183376	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183377	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
183378	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
183379	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
183380	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	44	°C
183381	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	65	°C
183382	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
183383	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
183384	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
183385	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
183386	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
183387	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	10	
183388	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183389	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183390	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183391	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	230.0	
183392	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	241.0	
183393	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	220.0	
183394	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
183395	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183396	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183397	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183398	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183399	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183400	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183401	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183402	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183403	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183404	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
183405	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
183406	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
183407	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
183408	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
183409	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
183410	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
183411	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
183412	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
183413	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
183414	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183415	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
183416	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183417	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183418	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	12L	
183419	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
183420	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
183421	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
183422	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
183423	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
183424	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183425	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
183426	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183427	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183428	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183429	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183430	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
183431	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
183432	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
183433	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
183434	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
183435	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	10160	
183436	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
183437	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
183438	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
183439	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
183440	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
183441	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
183442	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
183443	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1290	
183444	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
183445	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
183446	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183447	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
183448	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
183449	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
183450	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
183451	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183452	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
183453	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
183454	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
183455	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
183456	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
183457	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
183458	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
183459	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
183460	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
183461	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
183462	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
183463	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
183464	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
183465	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
183466	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
183467	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
183468	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
183469	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
183470	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	86	*F
183471	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
183472	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
183473	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
183474	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
183475	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
183476	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
183477	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
183478	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
183479	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
183480	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
183481	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
183482	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	112101	
183483	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	112090	
183484	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
183485	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
183486	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
183487	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
183488	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
183489	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
183490	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
183491	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
183492	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
183493	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
183494	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
183495	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
183496	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
183497	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
183498	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
183499	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
183500	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
183501	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
183502	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
183503	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
183504	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
183505	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
183506	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
183507	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	7286.40	kw
183508	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
183509	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
183510	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
183511	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
183512	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
183513	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
183514	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183515	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183516	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183517	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183518	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
183519	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
183520	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
183521	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
183522	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
183523	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
183524	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
183525	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
183526	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183527	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
183528	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
183529	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
183530	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
183531	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
183532	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
183533	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	353	
183534	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	355	
183535	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
183536	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
183537	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
183538	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	65953	
183539	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
183540	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
183541	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
183542	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183543	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183544	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
183545	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
183546	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
183547	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
183548	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
183549	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
183550	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
183551	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183552	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
183553	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183554	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183555	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183556	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183557	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
183558	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	2	
183559	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	2	
183560	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
183561	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
183562	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
183563	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
183564	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
183565	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	1370	
183566	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
183567	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	8L	
183568	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
183569	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
183570	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
183571	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	13461.12	kw
183572	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
183573	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
183574	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
183575	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
183576	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
183577	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
183578	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	5R	
183579	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
183580	9/19/2019 11:44	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
183581	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
183582	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183583	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
183584	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
183585	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
183586	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
183587	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
183588	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
183589	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183590	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
183591	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
183592	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
183593	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
183594	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183595	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
183596	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
183597	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
183598	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
183599	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
183600	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
183601	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183602	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91083	
183603	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
183604	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
183605	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
183606	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
183607	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	.7590	
183608	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
183609	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
183610	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
183611	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
183612	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
183613	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
183614	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
183615	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
183616	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
183617	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
183618	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
183619	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
183620	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
183621	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	34	°C
183622	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	52	°C
183623	9/19/2019 11:16	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
183624	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
183625	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
183626	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
183627	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
183628	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	1403	
183629	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
183630	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	57	°C
183631	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
183632	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
183633	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
183634	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183635	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183636	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
183637	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
183638	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
183639	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	63686	
183640	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
183641	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
183642	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
183643	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
183644	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
183645	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183646	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
183647	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
183648	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183649	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183650	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183651	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
183652	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
183653	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
183654	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183655	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
183656	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
183657	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
183658	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
183659	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
183660	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
183661	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
183662	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
183663	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
183664	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183665	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183666	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
183667	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
183668	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments	69kv 603 switch has all three arcing horns broke off. Line arrestor circuit 756 has blown and needs replaced	
183669	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
183670	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
183671	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
183672	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
183673	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	10294	
183674	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
183675	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
183676	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183677	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183678	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
183679	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
183680	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
183681	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	11608	
183682	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
183683	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
183684	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
183685	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
183686	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
183687	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
183688	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
183689	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	n	
183690	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
183691	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
183692	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183693	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183694	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
183695	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183696	9/20/2019 13:45	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
183697	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
183698	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
183699	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
183700	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
183701	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
183702	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
183703	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
183704	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
183705	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
183706	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
183707	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
183708	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
183709	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
183710	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
183711	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	7L	
183712	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	5L	
183713	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
183714	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
183715	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
183716	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
183717	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
183718	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
183719	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
183720	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	General Comments		
183721	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
183722	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
183723	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	.9348	
183724	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
183725	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
183726	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
183727	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
183728	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
183729	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
183730	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
183731	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
183732	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
183733	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
183734	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
183735	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	12L	
183736	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	66	°C
183737	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	45	°C
183738	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	119.9	VAC
183739	9/19/2019 12:58	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
183740	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
183741	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
183742	9/19/2019 11:52	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
183743	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
183744	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
183745	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
183746	9/19/2019 15:23	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
183747	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
183748	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
183749	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
183750	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
183751	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183752	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
183753	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
183754	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
183755	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
183756	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
183757	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
183758	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
183759	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
183760	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	75	"F
183761	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
183762	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
183763	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
183764	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
183765	9/23/2019 7:28	Distribution	Gates Rubber Quarterly Inspection	LTC0000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
183766	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	18428	
183767	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	18428	
183768	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
183769	9/19/2019 13:16	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
183770	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
183771	9/19/2019 14:06	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
183772	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
183773	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
183774	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
183775	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
183776	9/19/2019 11:08	Distribution	Elizabethtown 3 Quarterly Inspection	BCH000552	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
183777	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B PHASE IOC	
183778	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	525	
183779	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
183780	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
183781	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
183782	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	65	"C
183783	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
183784	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
183785	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
183786	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
183787	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
183788	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	525	
183789	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
183790	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
183791	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
183792	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
183793	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
183794	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
183795	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
183796	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
183797	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
183798	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183799	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	1	
183800	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
183801	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
183802	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	450.0	
183803	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
183804	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
183805	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	500.0	
183806	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	376	
183807	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	377	
183808	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
183809	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
183810	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
183811	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
183812	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
183813	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
183814	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
183815	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	475.0	
183816	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
183817	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
183818	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
183819	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
183820	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
183821	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
183822	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
183823	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
183824	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
183825	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
183826	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183827	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
183828	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
183829	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
183830	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
183831	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
183832	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
183833	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
183834	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
183835	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	72002	
183836	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	72002	
183837	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
183838	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	2L	
183839	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
183840	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	8L	
183841	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	509	
183842	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
183843	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
183844	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
183845	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	1	
183846	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183847	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183848	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183849	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
183850	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183851	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183852	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183853	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
183854	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
183855	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
183856	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
183857	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
183858	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
183859	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1766	
183860	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1766	
183861	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183862	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
183863	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
183864	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
183865	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
183866	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
183867	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
183868	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
183869	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
183870	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
183871	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
183872	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99951	
183873	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99951	
183874	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183875	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183876	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	.93	
183877	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183878	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
183879	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
183880	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
183881	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
183882	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
183883	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183884	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183885	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	171.0	
183886	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	179.0	
183887	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	4	
183888	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183889	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	4	
183890	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
183891	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
183892	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
183893	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
183894	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
183895	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
183896	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
183897	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
183898	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
183899	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
183900	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183901	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	1	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
183902	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	219	
183903	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	219	
183904	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
183905	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
183906	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183907	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
183908	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments		
183909	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	185.0	
183910	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
183911	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183912	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183913	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183914	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183915	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183916	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183917	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183918	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183919	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183920	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
183921	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
183922	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
183923	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
183924	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
183925	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
183926	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
183927	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
183928	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
183929	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
183930	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
183931	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
183932	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
183933	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
183934	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
183935	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
183936	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	145	
183937	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	146	
183938	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	2	
183939	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
183940	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	1	
183941	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
183942	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	1	
183943	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	2	
183944	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183945	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
183946	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
183947	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
183948	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
183949	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
183950	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
183951	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
183952	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183953	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183954	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183955	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183956	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183957	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183958	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
183959	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	102.0	
183960	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	101.0	
183961	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	106.0	
183962	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183963	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183964	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183965	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	2	
183966	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
183967	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
183968	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
183969	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
183970	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
183971	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
183972	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	4	
183973	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
183974	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
183975	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
183976	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	177.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
183977	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	192.0	
183978	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	181.0	
183979	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
183980	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
183981	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
183982	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
183983	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
183984	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
183985	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
183986	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
183987	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
183988	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
183989	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
183990	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
183991	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
183992	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
183993	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
183994	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
183995	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
183996	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
183997	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
183998	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
183999	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184000	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
184001	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
184002	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	382	
184003	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	383	
184004	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	1	
184005	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184006	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	1	
184007	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
184008	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
184009	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
184010	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
184011	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
184012	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
184013	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
184014	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
184015	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
184016	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
184017	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
184018	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
184019	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
184020	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
184021	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
184022	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184023	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
184024	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
184025	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	178	
184026	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	179	
184027	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	1	
184028	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184029	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments	2 screw on dessicant filters, main fan breaker carded	
184030	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
184031	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
184032	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
184033	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
184034	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
184035	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
184036	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
184037	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
184038	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	1	
184039	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
184040	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
184041	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments		
184042	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
184043	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
184044	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
184045	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
184046	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
184047	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
184048	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
184049	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184050	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184051	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184052	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	85.0	
184053	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	85.0	
184054	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	85.0	
184055	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	6	
184056	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184057	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184058	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
184059	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	235.0	
184060	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184061	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184062	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184063	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	42	
184064	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
184065	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
184066	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
184067	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	591	
184068	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
184069	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
184070	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184071	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
184072	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
184073	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
184074	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
184075	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
184076	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
184077	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
184078	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
184079	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
184080	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
184081	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
184082	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184083	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184084	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184085	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184086	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184087	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184088	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
184089	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
184090	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
184091	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
184092	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
184093	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
184094	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
184095	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	60.0	
184096	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	60.0	
184097	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	60.0	
184098	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
184099	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
184100	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
184101	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
184102	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
184103	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
184104	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
184105	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
184106	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
184107	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
184108	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
184109	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
184110	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
184111	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
184112	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
184113	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
184114	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
184115	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
184116	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
184117	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
184118	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
184119	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
184120	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
184121	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
184122	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
184123	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
184124	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	6	
184125	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	6	
184126	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	185	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184127	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	184	
184128	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
184129	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
184130	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
184131	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
184132	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
184133	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
184134	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
184135	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
184136	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
184137	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
184138	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
184139	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
184140	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184141	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184142	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184143	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184144	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184145	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184146	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184147	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184148	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184149	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
184150	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	179.0	
184151	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	222.0	
184152	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n		
184153	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n		
184154	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good		
184155	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good		
184156	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments			
184157	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	General Comments			
184158	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y		
184159	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	15318.00		kw
184160	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y		
184161	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0		psi
184162	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	75		°C
184163	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	65		°C
184164	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y		
184165	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None		
184166	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good		
184167	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good		
184168	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None		
184169	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good		
184170	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good		
184171	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000		
184172	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.8510		
184173	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	70		°C
184174	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	70		°C
184175	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00		
184176	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	80.0	
184177	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	80.0	
184178	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
184179	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
184180	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
184181	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
184182	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		
184183	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
184184	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
184185	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	0	
184186	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	392	
184187	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	392	
184188	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
184189	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
184190	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184191	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
184192	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
184193	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
184194	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
184195	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
184196	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
184197	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00		
184198	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
184199	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	
184200	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		chg 1st quarter
184201	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184202	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	0	
184203	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	776	
184204	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	776	
184205	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
184206	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
184207	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
184208	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
184209	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	30	°C
184210	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
184211	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
184212	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
184213	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
184214	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
184215	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	needs 6 pack	
184216	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
184217	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
184218	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
184219	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
184220	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
184221	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
184222	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
184223	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184224	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184225	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184226	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184227	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
184228	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	80.0	
184229	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
184230	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
184231	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
184232	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184233	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.5	%
184234	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184235	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
184236	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
184237	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
184238	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
184239	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184240	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
184241	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
184242	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
184243	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
184244	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
184245	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
184246	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184247	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
184248	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
184249	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184250	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184251	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184252	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
184253	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
184254	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
184255	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184256	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
184257	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	122	
184258	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	122	
184259	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
184260	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
184261	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184262	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
184263	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
184264	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
184265	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
184266	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
184267	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
184268	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
184269	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
184270	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
184271	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
184272	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184273	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184274	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184275	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
184276	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184277	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
184278	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
184279	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184280	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184281	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184282	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184283	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184284	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184285	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184286	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
184287	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	625.0	
184288	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	625.0	
184289	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	630.0	
184290	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184291	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
184292	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184293	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184294	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
184295	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
184296	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
184297	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
184298	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
184299	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
184300	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
184301	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
184302	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
184303	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	n	
184304	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
184305	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184306	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
184307	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
184308	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
184309	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
184310	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
184311	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184312	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
184313	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
184314	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
184315	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
184316	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
184317	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
184318	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1416	
184319	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1416	
184320	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
184321	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
184322	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
184323	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
184324	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
184325	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
184326	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
184327	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
184328	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
184329	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
184330	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
184331	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
184332	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
184333	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184334	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184335	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184336	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184337	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184338	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184339	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184340	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184341	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184342	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
184343	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	263.0	
184344	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	259.0	
184345	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	273.0	
184346	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
184347	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184348	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184349	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
184350	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	12.0	
184351	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	12.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184352	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	12.0	
184353	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
184354	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
184355	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
184356	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
184357	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
184358	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
184359	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
184360	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
184361	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
184362	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
184363	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
184364	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
184365	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
184366	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
184367	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
184368	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
184369	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
184370	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
184371	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	113	
184372	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	113	
184373	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
184374	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
184375	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
184376	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
184377	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
184378	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
184379	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
184380	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
184381	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
184382	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	280.0	
184383	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	280.0	
184384	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	280.0	
184385	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
184386	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184387	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184388	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
184389	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99996	
184390	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99996	
184391	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
184392	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
184393	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
184394	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
184395	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
184396	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
184397	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
184398	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
184399	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
184400	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
184401	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
184402	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
184403	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
184404	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
184405	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
184406	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
184407	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
184408	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
184409	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
184410	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
184411	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
184412	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
184413	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000151	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
184414	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
184415	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184416	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
184417	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	596	
184418	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
184419	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
184420	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
184421	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
184422	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
184423	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
184424	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
184425	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
184426	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
184427	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
184428	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
184429	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
184430	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
184431	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
184432	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
184433	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
184434	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
184435	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	155.0	
184436	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
184437	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	130.0	
184438	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
184439	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184440	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184441	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
184442	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
184443	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
184444	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184445	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
184446	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
184447	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
184448	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
184449	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
184450	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
184451	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
184452	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
184453	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
184454	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
184455	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
184456	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184457	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184458	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
184459	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
184460	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
184461	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
184462	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
184463	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
184464	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
184465	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
184466	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
184467	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
184468	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
184469	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
184470	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
184471	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184472	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184473	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
184474	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
184475	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	88	°F
184476	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
184477	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
184478	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
184479	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
184480	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
184481	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
184482	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
184483	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
184484	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
184485	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
184486	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
184487	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
184488	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
184489	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
184490	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
184491	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
184492	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
184493	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments	base actually checked as 125 and is set that way 3 volta bandwith	
184494	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
184495	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
184496	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
184497	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
184498	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	LTC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
184499	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184500	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184501	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184502	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184503	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184504	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184505	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184506	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184507	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184508	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
184509	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
184510	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
184511	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
184512	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184513	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184514	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184515	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	0	
184516	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
184517	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
184518	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
184519	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
184520	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
184521	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BAT000620	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
184522	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Leaks	None	
184523	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
184524	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
184525	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
184526	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Switching Operations	0	
184527	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
184528	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations This Read Oil	0	
184529	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AL	1406	
184530	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AF	1406	
184531	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Number of Ops last 9 Months	0	
184532	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
184533	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Maintenance Operations	0	
184534	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
184535	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	General Comments		
184536	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	General Comments		
184537	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
184538	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
184539	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Follow-up Action Required?	n	
184540	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
184541	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Fault Operations	0	
184542	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
184543	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
184544	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184545	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184546	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
184547	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
184548	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
184549	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
184550	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps C Ø	0.0	
184551	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps B Ø	0.0	
184552	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Amps A Ø	0.0	
184553	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
184554	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
184555	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Leaks	None	
184556	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
184557	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184558	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184559	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184560	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184561	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184562	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
184563	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	74.0	
184564	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	107.0	
184565	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	92.0	
184566	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184567	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184568	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184569	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	6	
184570	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184571	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184572	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184573	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184574	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184575	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
184576	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	109.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184577	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	108.0	
184578	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	110.0	
184579	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184580	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184581	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184582	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	5	
184583	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
184584	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000585	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
184585	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000585	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
184586	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000585	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
184587	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
184588	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
184589	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184590	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
184591	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	207	
184592	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
184593	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
184594	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
184595	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
184596	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
184597	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	207	
184598	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
184599	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
184600	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
184601	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
184602	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
184603	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
184604	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
184605	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
184606	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
184607	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
184608	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
184609	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
184610	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
184611	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
184612	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
184613	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
184614	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
184615	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
184616	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
184617	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
184618	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
184619	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
184620	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
184621	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
184622	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
184623	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
184624	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
184625	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
184626	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184627	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
184628	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
184629	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
184630	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184631	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
184632	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184633	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
184634	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
184635	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
184636	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
184637	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
184638	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments	Not in service	
184639	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
184640	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LTC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
184641	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
184642	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
184643	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
184644	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
184645	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
184646	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
184647	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
184648	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
184649	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184650	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
184651	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184652	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
184653	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
184654	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
184655	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
184656	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
184657	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
184658	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
184659	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
184660	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
184661	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
184662	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
184663	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
184664	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
184665	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
184666	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
184667	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
184668	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments		
184669	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments		
184670	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
184671	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
184672	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
184673	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2300	psi
184674	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	200.00	
184675	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
184676	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
184677	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
184678	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
184679	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
184680	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
184681	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	77	
184682	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	77	
184683	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	5	
184684	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
184685	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
184686	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
184687	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
184688	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
184689	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
184690	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
184691	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	60.0	
184692	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	60.0	
184693	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	60.0	
184694	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
184695	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
184696	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
184697	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	1112	
184698	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
184699	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
184700	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184701	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
184702	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
184703	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
184704	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
184705	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
184706	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	725	
184707	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7R	
184708	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
184709	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9R	
184710	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
184711	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	1407	
184712	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	1407	
184713	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
184714	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
184715	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
184716	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
184717	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
184718	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
184719	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
184720	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
184721	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1410	
184722	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
184723	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
184724	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
184725	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
184726	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	84039	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184727	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	14L	
184728	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	2L	
184729	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	5L	
184730	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
184731	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	312485	
184732	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	312485	
184733	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
184734	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
184735	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
184736	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
184737	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	84039	
184738	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
184739	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
184740	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
184741	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
184742	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
184743	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
184744	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
184745	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
184746	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	17.0	
184747	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	12.0	
184748	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	12.0	
184749	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
184750	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
184751	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
184752	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
184753	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
184754	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
184755	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
184756	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
184757	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
184758	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
184759	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
184760	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
184761	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
184762	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
184763	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	205	
184764	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	205	
184765	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
184766	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Fault Operations	9	
184767	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
184768	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	100.0	
184769	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	100.0	
184770	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	100.0	
184771	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
184772	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184773	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
184774	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
184775	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
184776	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	7	
184777	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184778	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184779	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184780	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
184781	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
184782	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
184783	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
184784	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184785	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184786	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184787	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184788	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184789	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184790	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184791	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184792	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184793	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
184794	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
184795	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
184796	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
184797	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
184798	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	550.0	
184799	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184800	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	C80208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184801	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184802	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
184803	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	6	
184804	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184805	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
184806	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
184807	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	60.0	
184808	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	45.0	
184809	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	70.0	
184810	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
184811	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184812	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184813	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184814	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184815	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184816	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184817	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	1	
184818	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
184819	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
184820	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
184821	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14L	
184822	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
184823	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
184824	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
184825	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
184826	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
184827	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
184828	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
184829	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
184830	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
184831	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
184832	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
184833	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
184834	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
184835	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
184836	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
184837	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	General Comments		
184838	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
184839	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	50360	
184840	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	50360	
184841	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
184842	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
184843	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
184844	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
184845	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
184846	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	555.0	
184847	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	640.0	
184848	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
184849	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184850	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184851	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184852	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184853	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184854	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184855	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184856	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184857	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184858	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
184859	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
184860	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
184861	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
184862	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
184863	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
184864	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	0	
184865	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	9	
184866	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	662	
184867	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	662	
184868	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	27	
184869	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	0	
184870	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments	ABC PHASE IOC AND TOC	
184871	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	General Comments		
184872	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Follow-up Action Required?	n	
184873	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
184874	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
184875	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
184876	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184877	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
184878	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
184879	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
184880	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
184881	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
184882	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
184883	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
184884	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments	Station under construction, breaker #11 will not reset in cabinet	
184885	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
184886	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
184887	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
184888	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
184889	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
184890	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
184891	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
184892	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
184893	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
184894	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
184895	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
184896	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
184897	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
184898	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
184899	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
184900	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
184901	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
184902	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
184903	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
184904	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
184905	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
184906	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
184907	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
184908	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
184909	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
184910	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
184911	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
184912	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
184913	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
184914	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
184915	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
184916	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
184917	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
184918	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
184919	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
184920	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
184921	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
184922	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
184923	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
184924	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
184925	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184926	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184927	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184928	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184929	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
184930	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
184931	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
184932	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184933	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
184934	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	100	
184935	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	100	
184936	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
184937	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
184938	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184939	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
184940	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
184941	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
184942	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
184943	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
184944	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
184945	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
184946	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
184947	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
184948	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
184949	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184950	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184951	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
184952	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184953	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
184954	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
184955	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
184956	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
184957	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
184958	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
184959	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	108.0	
184960	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	107.0	
184961	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	108.0	
184962	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
184963	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
184964	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
184965	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	15	
184966	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
184967	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
184968	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
184969	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
184970	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
184971	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	186	
184972	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	186	
184973	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
184974	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
184975	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184976	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
184977	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
184978	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
184979	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
184980	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
184981	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
184982	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
184983	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
184984	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
184985	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
184986	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
184987	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
184988	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
184989	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
184990	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Unknown Operations	0	
184991	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
184992	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
184993	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
184994	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
184995	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
184996	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
184997	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	373	
184998	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	375	
184999	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	2	
185000	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185001	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	2	
185002	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
185003	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
185004	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185005	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
185006	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
185007	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
185008	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
185009	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185010	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185011	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185012	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185013	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
185014	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
185015	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
185016	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
185017	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
185018	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
185019	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
185020	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
185021	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
185022	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
185023	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185024	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
185025	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
185026	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	247	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185027	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	249	
185028	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	2	
185029	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	2	
185030	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
185031	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
185032	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121457	
185033	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121457	
185034	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185035	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	5R	
185036	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	4R	
185037	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	7R	
185038	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	12	
185039	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185040	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
185041	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
185042	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
185043	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
185044	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
185045	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
185046	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
185047	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
185048	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
185049	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
185050	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
185051	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
185052	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	5	
185053	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185054	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	5	
185055	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185056	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	1128	
185057	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	11L	
185058	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	3L	
185059	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	7L	
185060	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185061	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	67417	
185062	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	67417	
185063	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	178	
185064	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	177	
185065	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
185066	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
185067	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185068	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
185069	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
185070	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
185071	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
185072	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
185073	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
185074	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185075	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
185076	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
185077	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
185078	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
185079	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
185080	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
185081	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
185082	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
185083	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
185084	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
185085	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185086	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185087	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185088	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185089	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185090	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185091	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
185092	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
185093	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185094	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
185095	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
185096	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185097	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	7	
185098	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
185099	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
185100	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
185101	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185102	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
185103	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
185104	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	15487.20	kw
185105	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185106	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
185107	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	67	*C
185108	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	55	*C
185109	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
185110	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
185111	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185112	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
185113	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185114	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185115	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
185116	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
185117	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185118	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
185119	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
185120	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	
185121	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
185122	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
185123	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
185124	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
185125	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
185126	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185127	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
185128	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
185129	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185130	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
185131	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
185132	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185133	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
185134	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Heater fuses are good. Heater is not working	
185135	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
185136	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185137	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
185138	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
185139	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	*C
185140	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	*C
185141	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185142	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185143	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
185144	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
185145	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185146	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185147	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
185148	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
185149	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185150	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
185151	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
185152	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	*C
185153	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	*C
185154	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
185155	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
185156	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185157	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
185158	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
185159	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	3	
185160	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	3	
185161	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	165	
185162	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	162	
185163	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
185164	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
185165	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	4	
185166	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
185167	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
185168	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
185169	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185170	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185171	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185172	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
185173	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
185174	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185175	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	45	*C
185176	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	35	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
185177	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
185178	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
185179	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	734	
185180	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
185181	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	734	
185182	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
185183	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185184	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
185185	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
185186	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185187	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185188	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185189	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185190	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185191	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
185192	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
185193	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
185194	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185195	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	14.06	
185196	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185197	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
185198	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	3	
185199	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
185200	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
185201	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
185202	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
185203	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
185204	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
185205	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
185206	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185207	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185208	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
185209	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185210	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
185211	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
185212	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	178	
185213	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	187	
185214	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185215	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185216	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	8	
185217	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	5	
185218	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
185219	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
185220	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185221	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185222	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-5TA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
185223	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-5TA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
185224	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
185225	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
185226	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185227	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185228	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185229	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
185230	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	200.0	
185231	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	180.0	
185232	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	215.0	
185233	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185234	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
185235	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
185236	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	5	
185237	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
185238	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185239	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
185240	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	215.0	
185241	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	205.0	
185242	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	175.0	
185243	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
185244	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185245	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185246	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185247	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185248	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185249	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185250	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185251	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185252	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
185253	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	132	
185254	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
185255	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
185256	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
185257	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	1	
185258	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
185259	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
185260	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
185261	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
185262	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
185263	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
185264	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
185265	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185266	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
185267	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
185268	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	175	
185269	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	177	
185270	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	3	
185271	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	2	
185272	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
185273	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
185274	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	11	
185275	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	1.75	%
185276	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	2.45	%
185277	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	.7	%
185278	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	165.0	
185279	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	197.0	
185280	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	135.0	
185281	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	132	
185282	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
185283	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185284	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
185285	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
185286	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
185287	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.8604	
185288	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	80	°C
185289	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	60	°C
185290	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
185291	9/18/2019 12:54	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
185292	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
185293	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
185294	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	62	°C
185295	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
185296	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	39	°C
185297	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	59	°C
185298	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	39	°C
185299	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	61	°C
185300	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	39	°C
185301	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
185302	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185303	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185304	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185305	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185306	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185307	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185308	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
185309	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185310	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	6	
185311	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
185312	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
185313	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
185314	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
185315	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	1	
185316	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185317	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	0.0	
185318	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	0.0	
185319	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	0.0	
185320	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
185321	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185322	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185323	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185324	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185325	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185326	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185327	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185328	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
185329	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185330	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185331	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185332	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185333	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
185334	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
185335	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185336	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
185337	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185338	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
185339	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185340	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
185341	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
185342	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185343	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
185344	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
185345	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	
185346	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185347	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	0	
185348	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
185349	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
185350	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
185351	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
185352	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
185353	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
185354	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
185355	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
185356	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
185357	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
185358	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
185359	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
185360	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185361	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185362	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185363	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185364	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185365	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185366	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
185367	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185368	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
185369	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
185370	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185371	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
185372	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
185373	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185374	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
185375	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitrogen needs to be refilled	
185376	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
185377	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185378	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
185379	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	59	°C
185380	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	39	°C
185381	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
185382	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
185383	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
185384	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
185385	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
185386	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
185387	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185388	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
185389	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185390	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185391	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
185392	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Unknown Operations	0	
185393	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Switching Operations	0	
185394	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Operations This Read SF6	1	
185395	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Operations Counter AL	682	
185396	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Operations Counter AF	682	
185397	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	13	
185398	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	Maintenance Operations	0	
185399	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Readings	General Comments	B PHASE IOC	
185400	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakersSF6	SH-1282	GCB Patrol Inspection	General Comments		
185401	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185402	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185403	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
185404	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185405	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185406	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185407	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	120.0	
185408	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	120.0	
185409	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
185410	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
185411	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
185412	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
185413	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185414	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185415	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185416	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185417	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185418	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
185419	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185420	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
185421	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
185422	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
185423	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
185424	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
185425	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
185426	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
185427	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments	station under construction	
185428	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
185429	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
185430	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
185431	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
185432	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
185433	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
185434	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
185435	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
185436	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
185437	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
185438	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
185439	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptable	y	
185440	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
185441	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
185442	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
185443	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
185444	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
185445	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
185446	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
185447	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	144.0	
185448	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	154.0	
185449	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	149.0	
185450	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
185451	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
185452	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
185453	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	4	
185454	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185455	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185456	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185457	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185458	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185459	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185460	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	104	
185461	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	104	
185462	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
185463	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
185464	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
185465	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
185466	9/18/2019 9:48	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	120.0	
185467	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185468	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
185469	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
185470	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
185471	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
185472	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
185473	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
185474	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
185475	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
185476	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185477	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
185478	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185479	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185480	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185481	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185482	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185483	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185484	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185485	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185486	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185487	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
185488	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
185489	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
185490	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	50	°C
185491	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	35	°C
185492	9/18/2019 10:36	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
185493	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
185494	9/18/2019 12:45	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
185495	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
185496	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
185497	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	1	
185498	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185499	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	1	
185500	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	273	
185501	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	272	
185502	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
185503	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
185504	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185505	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
185506	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
185507	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
185508	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
185509	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
185510	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
185511	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
185512	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
185513	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
185514	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
185515	9/18/2019 14:52	Distribution	Elizabethtown Industrial Quarterly Inspecti	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185516	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
185517	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
185518	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
185519	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
185520	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
185521	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
185522	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
185523	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	252	
185524	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
185525	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
185526	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	243	
185527	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	37.8	
185528	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	50.3	
185529	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	32.6	
185530	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	325	
185531	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
185532	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
185533	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
185534	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
185535	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
185536	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
185537	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
185538	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	87.0	
185539	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
185540	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	69.0	
185541	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
185542	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
185543	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
185544	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
185545	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
185546	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
185547	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	347	
185548	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
185549	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
185550	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	CX0867	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
185551	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	219916	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185552	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	219916	
185553	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185554	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
185555	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
185556	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
185557	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
185558	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	421	
185559	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
185560	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
185561	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
185562	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
185563	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
185564	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
185565	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185566	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185567	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
185568	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
185569	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185570	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
185571	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9366	
185572	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
185573	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
185574	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
185575	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
185576	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
185577	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
185578	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
185579	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	212	
185580	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
185581	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments		
185582	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
185583	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
185584	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
185585	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
185586	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.4	
185587	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.6	
185588	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.1	
185589	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
185590	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
185591	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
185592	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
185593	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
185594	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185595	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
185596	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
185597	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185598	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185599	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
185600	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
185601	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	LTC0000562	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
185602	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185603	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
185604	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
185605	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
185606	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
185607	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
185608	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185609	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185610	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185611	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
185612	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
185613	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185614	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
185615	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
185616	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185617	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
185618	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments	ok	
185619	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
185620	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
185621	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2997.12	kw
185622	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
185623	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
185624	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	316606	
185625	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	316606	
185626	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185627	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
185628	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
185629	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
185630	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
185631	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	424	
185632	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
185633	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185634	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
185635	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
185636	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0368	
185637	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
185638	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185639	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
185640	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
185641	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185642	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185643	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185644	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185645	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
185646	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
185647	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
185648	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
185649	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185650	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185651	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	47	°C
185652	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
185653	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
185654	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
185655	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
185656	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185657	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	0	
185658	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
185659	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
185660	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	8	
185661	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
185662	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	8	
185663	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	402	
185664	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	394	
185665	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
185666	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
185667	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1658.88	kw
185668	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
185669	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
185670	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
185671	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
185672	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments		
185673	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
185674	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
185675	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185676	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTC000550	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
185677	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
185678	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
185679	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185680	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185681	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185682	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185683	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	40.0	
185684	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	50.0	
185685	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	40.0	
185686	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
185687	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185688	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185689	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185690	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185691	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185692	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
185693	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
185694	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
185695	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	411	
185696	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	411	
185697	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
185698	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
185699	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185700	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185701	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185702	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185703	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185704	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185705	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
185706	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	240.0	
185707	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	200.0	
185708	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	220.0	
185709	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185710	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
185711	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
185712	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
185713	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185714	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185715	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185716	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185717	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185718	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185719	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185720	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185721	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185722	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185723	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185724	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185725	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185726	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
185727	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
185728	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
185729	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
185730	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
185731	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
185732	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
185733	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
185734	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
185735	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
185736	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185737	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
185738	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
185739	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
185740	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
185741	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	442	
185742	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	447	
185743	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	5	
185744	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
185745	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	80.0	
185746	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
185747	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185748	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
185749	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185750	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
185751	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
185752	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185753	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
185754	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185755	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
185756	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
185757	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185758	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185759	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185760	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185761	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185762	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185763	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
185764	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99950	
185765	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99950	
185766	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
185767	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
185768	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185769	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
185770	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments	ok	
185771	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments	ok	
185772	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
185773	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
185774	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
185775	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
185776	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185777	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185778	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
185779	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
185780	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
185781	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
185782	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
185783	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
185784	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
185785	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
185786	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185787	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0626	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
185788	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
185789	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
185790	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
185791	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	75314	
185792	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
185793	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
185794	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
185795	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
185796	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
185797	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
185798	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
185799	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
185800	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
185801	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
185802	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
185803	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
185804	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
185805	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
185806	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
185807	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
185808	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
185809	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
185810	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
185811	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
185812	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
185813	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
185814	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
185815	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
185816	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
185817	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCC000550	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
185818	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
185819	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
185820	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
185821	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
185822	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
185823	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
185824	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
185825	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
185826	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
185827	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
185828	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
185829	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
185830	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1844.64	kw
185831	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
185832	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
185833	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
185834	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
185835	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
185836	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
185837	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
185838	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
185839	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
185840	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
185841	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
185842	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
185843	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
185844	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
185845	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
185846	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
185847	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
185848	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
185849	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
185850	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
185851	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185852	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
185853	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
185854	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
185855	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
185856	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
185857	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185858	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185859	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
185860	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
185861	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
185862	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
185863	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
185864	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
185865	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
185866	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
185867	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
185868	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
185869	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
185870	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
185871	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
185872	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
185873	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
185874	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
185875	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
185876	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
185877	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
185878	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
185879	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
185880	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
185881	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
185882	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	423	
185883	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	428	
185884	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	94	*F
185885	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
185886	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
185887	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	314	
185888	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
185889	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
185890	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
185891	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
185892	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
185893	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
185894	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
185895	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
185896	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
185897	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
185898	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
185899	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
185900	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
185901	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	LTC0000650	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
185902	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
185903	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
185904	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
185905	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
185906	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
185907	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
185908	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
185909	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
185910	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
185911	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
185912	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
185913	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
185914	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
185915	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
185916	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments	ok	
185917	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
185918	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
185919	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185920	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185921	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
185922	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
185923	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
185924	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
185925	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
185926	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
185927	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.0	
185928	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
185929	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
185930	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
185931	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments	ok	
185932	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
185933	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
185934	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
185935	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
185936	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
185937	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
185938	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
185939	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
185940	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	36.0	
185941	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KX0011	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	36.0	
185942	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
185943	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
185944	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
185945	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0248	
185946	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
185947	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
185948	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
185949	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
185950	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
185951	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
185952	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	228951	
185953	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	228951	
185954	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185955	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	1L	
185956	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
185957	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	6L	
185958	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
185959	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	924	
185960	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185961	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
185962	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
185963	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
185964	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	964	
185965	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	11L	
185966	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	2L	
185967	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	6L	
185968	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
185969	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
185970	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	58	°C
185971	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
185972	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
185973	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
185974	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	38720	
185975	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	39712	
185976	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments	ok	
185977	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments	ok	
185978	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
185979	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
185980	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
185981	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
185982	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
185983	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
185984	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
185985	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
185986	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
185987	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	57514	
185988	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
185989	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
185990	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
185991	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
185992	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
185993	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
185994	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
185995	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
185996	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments	ok	
185997	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
185998	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
185999	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
186000	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186001	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	1R	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186002	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186003	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186004	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186005	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186006	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
186007	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
186008	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
186009	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
186010	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000202	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
186011	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186012	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186013	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
186014	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
186015	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186016	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186017	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186018	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
186019	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
186020	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
186021	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
186022	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186023	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
186024	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
186025	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186026	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0252	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
186027	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
186028	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
186029	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
186030	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
186031	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
186032	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
186033	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
186034	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
186035	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
186036	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
186037	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
186038	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
186039	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
186040	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
186041	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
186042	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
186043	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
186044	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
186045	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	ok	
186046	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
186047	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
186048	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
186049	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186050	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
186051	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
186052	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
186053	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
186054	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186055	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	9	
186056	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
186057	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186058	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
186059	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	830	
186060	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	7L	
186061	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
186062	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	2L	
186063	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
186064	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	82514	
186065	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	82514	
186066	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
186067	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
186068	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186069	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
186070	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186071	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186072	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
186073	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186074	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
186075	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186076	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186077	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
186078	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
186079	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
186080	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186081	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
186082	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments	ok	
186083	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
186084	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
186085	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186086	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
186087	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
186088	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
186089	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
186090	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186091	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186092	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186093	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186094	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186095	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186096	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186097	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186098	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186099	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
186100	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
186101	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
186102	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
186103	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
186104	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
186105	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186106	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186107	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186108	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186109	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186110	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186111	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186112	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
186113	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
186114	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186115	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
186116	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
186117	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186118	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
186119	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
186120	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
186121	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	6194.88	kw
186122	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186123	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
186124	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	60	°C
186125	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186126	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
186127	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186128	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186129	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
186130	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
186131	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186132	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
186133	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	.8604	
186134	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
186135	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.4	VDC
186136	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.9	VDC
186137	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
186138	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
186139	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
186140	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
186141	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
186142	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
186143	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186144	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
186145	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
186146	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
186147	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BCH000478	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
186148	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	2R	
186149	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	15R	
186150	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	6L	
186151	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	2092	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186152	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
186153	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186154	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186155	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
186156	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186157	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186158	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186159	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
186160	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
186161	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186162	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186163	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186164	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186165	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186166	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
186167	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments	ok	
186168	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
186169	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186170	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
186171	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	*C
186172	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
186173	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
186174	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186175	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
186176	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186177	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
186178	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	5	
186179	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
186180	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	*F
186181	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
186182	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186183	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186184	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186185	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
186186	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186187	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
186188	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
186189	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
186190	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	60	*C
186191	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	40	*C
186192	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186193	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
186194	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186195	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186196	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
186197	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
186198	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186199	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
186200	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
186201	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186202	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186203	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186204	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186205	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186206	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186207	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186208	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
186209	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
186210	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186211	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
186212	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
186213	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186214	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
186215	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
186216	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	83	*F
186217	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186218	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
186219	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186220	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
186221	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
186222	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	37383	
186223	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	37383	
186224	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
186225	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	2L	
186226	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	Neutral	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186227	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	8L	
186228	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
186229	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
186230	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	1094	
186231	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
186232	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
186233	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186234	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186235	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
186236	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186237	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
186238	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
186239	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
186240	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
186241	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
186242	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
186243	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
186244	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	243	
186245	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	239	
186246	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
186247	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
186248	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
186249	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
186250	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
186251	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
186252	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
186253	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
186254	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
186255	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
186256	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
186257	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
186258	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
186259	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments	ok	
186260	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
186261	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
186262	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
186263	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186264	9/17/2019 12:06	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186265	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4584	
186266	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
186267	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186268	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
186269	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
186270	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186271	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186272	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
186273	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186274	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
186275	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
186276	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
186277	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
186278	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1100.16	kw
186279	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
186280	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
186281	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
186282	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments	ok	
186283	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
186284	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186285	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
186286	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
186287	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186288	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
186289	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
186290	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186291	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186292	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186293	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
186294	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
186295	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
186296	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186297	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
186298	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
186299	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186300	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186301	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186302	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
186303	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
186304	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186305	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
186306	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186307	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
186308	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186309	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186310	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186311	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
186312	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
186313	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
186314	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186315	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	73088	
186316	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
186317	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
186318	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
186319	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186320	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186321	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
186322	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
186323	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
186324	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
186325	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186326	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
186327	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
186328	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186329	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
186330	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186331	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186332	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186333	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186334	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
186335	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
186336	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
186337	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
186338	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186339	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	369972	
186340	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
186341	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
186342	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
186343	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186344	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186345	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
186346	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
186347	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
186348	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments	ok	
186349	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186350	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
186351	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
186352	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186353	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
186354	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186355	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186356	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186357	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186358	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
186359	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186360	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
186361	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
186362	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
186363	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
186364	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	8277.12	kw
186365	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186366	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
186367	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
186368	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186369	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186370	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186371	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
186372	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	120.0	
186373	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	120.0	
186374	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	120.0	
186375	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186376	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186377	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186378	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
186379	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
186380	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
186381	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
186382	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
186383	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
186384	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
186385	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
186386	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
186387	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
186388	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
186389	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
186390	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
186391	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
186392	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
186393	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
186394	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
186395	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
186396	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
186397	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
186398	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments		
186399	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
186400	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
186401	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
186402	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
186403	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
186404	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
186405	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
186406	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186407	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186408	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186409	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
186410	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
186411	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
186412	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186413	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186414	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186415	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186416	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
186417	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
186418	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186419	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
186420	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
186421	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186422	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
186423	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
186424	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments	ok	
186425	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186426	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
186427	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
186428	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186429	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
186430	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186431	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186432	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186433	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186434	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
186435	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
186436	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
186437	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
186438	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
186439	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
186440	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
186441	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
186442	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
186443	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
186444	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	5L	
186445	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	1307	
186446	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
186447	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186448	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186449	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
186450	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186451	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186452	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
186453	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	121261	
186454	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	121269	
186455	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
186456	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
186457	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
186458	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186459	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186460	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
186461	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186462	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
186463	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186464	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186465	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186466	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186467	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
186468	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186469	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
186470	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186471	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
186472	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
186473	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
186474	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186475	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
186476	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
186477	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186478	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
186479	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
186480	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	50	*C
186481	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186482	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
186483	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186484	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186485	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
186486	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
186487	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186488	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
186489	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.8622	
186490	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
186491	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
186492	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
186493	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
186494	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
186495	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
186496	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	135	
186497	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	139	
186498	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	8	
186499	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
186500	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
186501	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
186502	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	4	
186503	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
186504	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	4	
186505	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
186506	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
186507	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99956	
186508	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99961	
186509	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	5	
186510	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
186511	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	5	
186512	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
186513	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
186514	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186515	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
186516	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186517	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
186518	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
186519	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	93785	
186520	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	93794	
186521	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
186522	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	6R	
186523	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	8R	
186524	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
186525	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
186526	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186527	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186528	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	25422	
186529	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
186530	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
186531	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
186532	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186533	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186534	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
186535	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
186536	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
186537	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
186538	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
186539	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
186540	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
186541	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
186542	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
186543	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
186544	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
186545	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
186546	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
186547	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	ok	
186548	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
186549	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
186550	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	109	
186551	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
186552	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
186553	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186554	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
186555	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186556	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186557	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186558	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186559	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	92	*F
186560	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186561	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186562	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186563	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	4.0	VDC
186564	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.7	VDC
186565	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
186566	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186567	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186568	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186569	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186570	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186571	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186572	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	92	*F
186573	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186574	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186575	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186576	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186577	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186578	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186579	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186580	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186581	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
186582	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
186583	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186584	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
186585	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
186586	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186587	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
186588	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
186589	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
186590	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	10650.24	kw
186591	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186592	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
186593	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
186594	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186595	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186596	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
186597	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
186598	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186599	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
186600	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4974	
186601	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	40	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186602	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
186603	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
186604	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186605	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	94963	
186606	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
186607	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
186608	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
186609	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186610	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186611	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186612	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186613	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
186614	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
186615	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
186616	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186617	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186618	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
186619	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
186620	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	15R	
186621	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
186622	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments	ok	
186623	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186624	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
186625	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
186626	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186627	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	8R	
186628	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186629	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186630	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186631	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186632	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
186633	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BAT000186	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186634	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186635	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186636	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186637	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186638	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
186639	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
186640	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
186641	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186642	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186643	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
186644	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
186645	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
186646	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186647	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	100.0	
186648	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	119.0	
186649	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	101.0	
186650	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
186651	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
186652	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
186653	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
186654	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
186655	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
186656	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
186657	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
186658	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
186659	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	1	
186660	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
186661	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
186662	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	1	
186663	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	193	
186664	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	193	
186665	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
186666	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	0	
186667	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
186668	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
186669	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments	ok	
186670	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments	ok	
186671	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
186672	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
186673	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
186674	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
186675	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
186676	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
186677	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
186678	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
186679	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
186680	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
186681	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
186682	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
186683	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
186684	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
186685	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
186686	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
186687	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
186688	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	20.0	
186689	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	25.0	
186690	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	20.0	
186691	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186692	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186693	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186694	9/17/2019 12:06	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	3	
186695	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
186696	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
186697	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	5	
186698	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
186699	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	1	
186700	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186701	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186702	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186703	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	100.0	
186704	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	100.0	
186705	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	13	
186706	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	50	*C
186707	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	50	*C
186708	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186709	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
186710	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186711	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186712	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
186713	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
186714	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186715	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
186716	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	1.1094	
186717	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
186718	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
186719	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
186720	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
186721	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
186722	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
186723	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
186724	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
186725	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
186726	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
186727	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
186728	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
186729	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
186730	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
186731	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments	ok	
186732	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
186733	9/18/2019 8:18	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
186734	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
186735	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186736	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186737	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186738	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186739	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
186740	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186741	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
186742	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
186743	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186744	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
186745	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
186746	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
186747	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
186748	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186749	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186750	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
186751	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186752	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
186753	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	81882	
186754	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186755	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
186756	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
186757	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
186758	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
186759	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
186760	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
186761	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments	ok	
186762	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
186763	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
186764	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
186765	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186766	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
186767	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
186768	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
186769	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
186770	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
186771	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186772	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
186773	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
186774	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186775	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
186776	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
186777	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	BCH000236	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
186778	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
186779	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
186780	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
186781	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
186782	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
186783	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
186784	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
186785	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
186786	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
186787	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
186788	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
186789	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
186790	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
186791	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
186792	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
186793	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
186794	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
186795	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps A Ø	0.0	
186796	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps B Ø	0.0	
186797	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Amps C Ø	0.0	
186798	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
186799	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
186800	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
186801	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
186802	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations A Ø	0	
186803	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations B Ø	0	
186804	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations C Ø	0	
186805	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Operations Ground	0	
186806	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
186807	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
186808	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
186809	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
186810	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
186811	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Maintenance Operations	0	
186812	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
186813	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
186814	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
186815	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Switching Operations	0	
186816	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Unknown Operations	0	
186817	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
186818	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
186819	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
186820	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
186821	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
186822	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
186823	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
186824	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
186825	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
186826	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186827	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
186828	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
186829	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186830	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
186831	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
186832	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
186833	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
186834	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
186835	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
186836	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
186837	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
186838	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
186839	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
186840	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
186841	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
186842	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
186843	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
186844	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
186845	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
186846	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
186847	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
186848	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
186849	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186850	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186851	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186852	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BB0253	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
186853	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
186854	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
186855	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	142878	
186856	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	142878	
186857	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
186858	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
186859	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
186860	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1551	
186861	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186862	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
186863	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
186864	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
186865	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
186866	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
186867	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
186868	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
186869	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
186870	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
186871	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
186872	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
186873	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
186874	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
186875	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BAT000416	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
186876	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
186877	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
186878	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
186879	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
186880	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
186881	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
186882	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
186883	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
186884	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
186885	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
186886	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
186887	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
186888	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
186889	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
186890	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	59150	
186891	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	59150	
186892	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
186893	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	4L	
186894	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
186895	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
186896	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
186897	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
186898	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	1R	
186899	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	8L	
186900	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	793	
186901	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186902	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
186903	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
186904	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
186905	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
186906	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
186907	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
186908	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
186909	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
186910	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
186911	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
186912	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
186913	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
186914	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
186915	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
186916	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
186917	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
186918	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
186919	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
186920	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
186921	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
186922	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments	ok	
186923	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
186924	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
186925	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
186926	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
186927	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1790.64	kw
186928	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
186929	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
186930	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
186931	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
186932	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
186933	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
186934	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
186935	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
186936	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
186937	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
186938	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
186939	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
186940	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
186941	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	4	
186942	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
186943	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
186944	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
186945	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	85.0	
186946	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	90.0	
186947	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	110.0	
186948	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
186949	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
186950	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
186951	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
186952	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
186953	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
186954	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
186955	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
186956	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
186957	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
186958	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	0	
186959	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
186960	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
186961	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
186962	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
186963	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
186964	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
186965	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
186966	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
186967	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
186968	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
186969	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
186970	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	223	
186971	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	225	
186972	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	2	
186973	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	2	
186974	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
186975	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
186976	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
186977	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
186978	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
186979	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
186980	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
186981	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
186982	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
186983	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
186984	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31649	
186985	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
186986	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
186987	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
186988	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
186989	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
186990	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
186991	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
186992	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
186993	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
186994	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
186995	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
186996	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
186997	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
186998	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
186999	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
187000	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
187001	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
187002	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	3	
187003	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
187004	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
187005	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
187006	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
187007	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187008	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187009	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187010	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187011	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
187012	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187013	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
187014	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
187015	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187016	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
187017	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
187018	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
187019	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
187020	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187021	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187022	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
187023	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	n	
187024	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
187025	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	68799	
187026	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187027	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
187028	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
187029	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
187030	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
187031	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
187032	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
187033	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
187034	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
187035	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
187036	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
187037	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
187038	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
187039	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
187040	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
187041	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
187042	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
187043	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
187044	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
187045	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
187046	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
187047	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
187048	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
187049	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
187050	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
187051	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187052	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
187053	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
187054	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
187055	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	3	
187056	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
187057	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187058	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187059	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187060	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187061	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
187062	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187063	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
187064	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
187065	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187066	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments	ok	
187067	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187068	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
187069	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187070	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
187071	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
187072	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187073	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	General Comments		
187074	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
187075	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
187076	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
187077	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187078	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187079	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
187080	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
187081	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
187082	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Regulator As Left Counter	25809	
187083	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187084	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187085	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Leaks	None	
187086	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
187087	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.2	
187088	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	37.1	
187089	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.2	
187090	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
187091	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
187092	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
187093	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
187094	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
187095	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
187096	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	600	
187097	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
187098	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
187099	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
187100	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
187101	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
187102	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
187103	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	2088	
187104	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	12L	
187105	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	2R	
187106	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	4L	
187107	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
187108	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	294097	
187109	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	294086	
187110	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
187111	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
187112	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
187113	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
187114	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
187115	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
187116	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
187117	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
187118	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
187119	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
187120	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
187121	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
187122	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
187123	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
187124	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
187125	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
187126	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
187127	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
187128	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
187129	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
187130	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
187131	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
187132	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
187133	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
187134	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
187135	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
187136	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
187137	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
187138	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
187139	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
187140	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
187141	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
187142	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
187143	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
187144	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
187145	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
187146	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
187147	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
187148	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments	ok	
187149	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
187150	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
187151	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
187152	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
187153	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
187154	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
187155	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
187156	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
187157	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
187158	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
187159	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
187160	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
187161	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments	ok	
187162	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
187163	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
187164	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
187165	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
187166	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
187167	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
187168	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
187169	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
187170	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
187171	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
187172	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187173	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
187174	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
187175	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	1	
187176	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	1	
187177	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	181	
187178	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	180	
187179	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
187180	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
187181	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
187182	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
187183	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
187184	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
187185	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
187186	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
187187	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
187188	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
187189	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
187190	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
187191	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
187192	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
187193	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
187194	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
187195	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
187196	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
187197	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
187198	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
187199	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
187200	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
187201	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	127.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187202	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	138.0	
187203	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	141.0	
187204	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
187205	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
187206	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
187207	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	2	
187208	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187209	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187210	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187211	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	9R	
187212	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187213	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
187214	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
187215	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187216	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments	ok	
187217	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
187218	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	15R	
187219	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
187220	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187221	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187222	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
187223	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
187224	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
187225	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
187226	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187227	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187228	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
187229	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
187230	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
187231	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	75839	
187232	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187233	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
187234	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
187235	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
187236	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
187237	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
187238	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	170.0	
187239	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	190.0	
187240	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	225.0	
187241	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
187242	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
187243	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
187244	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
187245	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
187246	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
187247	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
187248	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
187249	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
187250	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
187251	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
187252	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
187253	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
187254	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
187255	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
187256	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
187257	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
187258	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
187259	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187260	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187261	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187262	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187263	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
187264	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187265	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
187266	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
187267	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187268	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments	ok	
187269	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
187270	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
187271	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
187272	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187273	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187274	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
187275	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
187276	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
187277	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	79520	
187278	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187279	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
187280	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
187281	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments	ok	
187282	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments	ok	
187283	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
187284	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
187285	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	1	
187286	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
187287	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	110	
187288	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	110	
187289	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	2	
187290	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
187291	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
187292	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	1	
187293	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
187294	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
187295	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
187296	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
187297	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
187298	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
187299	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
187300	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
187301	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
187302	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
187303	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	34.0	
187304	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	36.0	
187305	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.0	
187306	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
187307	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
187308	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
187309	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
187310	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
187311	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
187312	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
187313	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	742	
187314	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
187315	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
187316	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
187317	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187318	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187319	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187320	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187321	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
187322	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187323	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
187324	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
187325	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187326	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments	ok	
187327	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
187328	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
187329	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
187330	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187331	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187332	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
187333	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
187334	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
187335	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	25527	
187336	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
187337	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
187338	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	General Comments		
187339	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
187340	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
187341	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
187342	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
187343	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTC0000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
187344	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187345	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187346	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
187347	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
187348	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
187349	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187350	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187351	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187352	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187353	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
187354	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187355	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
187356	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
187357	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187358	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments	ok	
187359	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
187360	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
187361	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
187362	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
187363	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
187364	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	4	
187365	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
187366	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	8	
187367	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	182	
187368	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	178	
187369	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
187370	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
187371	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
187372	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
187373	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
187374	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
187375	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
187376	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
187377	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
187378	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
187379	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
187380	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
187381	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
187382	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
187383	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
187384	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
187385	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
187386	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
187387	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
187388	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
187389	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	220.0	
187390	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	240.0	
187391	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	240.0	
187392	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
187393	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
187394	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
187395	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	51	
187396	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
187397	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
187398	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
187399	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
187400	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
187401	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
187402	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
187403	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
187404	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
187405	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
187406	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
187407	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
187408	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
187409	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
187410	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
187411	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
187412	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
187413	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
187414	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
187415	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
187416	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	496	
187417	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	496	
187418	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
187419	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
187420	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
187421	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
187422	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
187423	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
187424	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
187425	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
187426	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
187427	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
187428	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
187429	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
187430	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
187431	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
187432	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
187433	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
187434	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
187435	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
187436	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
187437	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
187438	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
187439	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
187440	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments	ok	
187441	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments	secondary side bushings need to be vermint guarded.	
187442	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
187443	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	6969.60	kw
187444	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
187445	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
187446	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	62	°C
187447	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	47	°C
187448	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
187449	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
187450	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
187451	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
187452	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
187453	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
187454	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
187455	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9500	
187456	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.7260	
187457	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
187458	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187459	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187460	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187461	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187462	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
187463	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187464	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
187465	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
187466	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187467	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments	ok	
187468	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
187469	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
187470	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
187471	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187472	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187473	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
187474	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
187475	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
187476	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	94076	
187477	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187478	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187479	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
187480	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
187481	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
187482	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
187483	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
187484	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
187485	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
187486	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
187487	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
187488	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
187489	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
187490	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
187491	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
187492	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
187493	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
187494	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
187495	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
187496	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
187497	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
187498	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
187499	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	430	
187500	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	430	
187501	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
187502	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
187503	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
187504	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
187505	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
187506	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
187507	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
187508	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
187509	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
187510	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
187511	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
187512	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
187513	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
187514	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
187515	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	120.0	
187516	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	60.0	
187517	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	130.0	
187518	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
187519	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
187520	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
187521	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	0	
187522	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
187523	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
187524	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
187525	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
187526	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
187527	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
187528	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
187529	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
187530	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
187531	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187532	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187533	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Heaters Functioning?	y	
187534	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187535	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	1	
187536	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	1	
187537	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	2	
187538	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
187539	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
187540	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	12.82	
187541	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
187542	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
187543	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
187544	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187545	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187546	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
187547	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
187548	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
187549	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25220	
187550	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
187551	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187552	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
187553	9/17/2019 12:06	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
187554	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
187555	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
187556	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
187557	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
187558	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	290.0	
187559	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	295.0	
187560	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	260.0	
187561	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
187562	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
187563	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
187564	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	13	
187565	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
187566	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187567	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187568	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187569	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187570	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
187571	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187572	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
187573	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
187574	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187575	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	ok	
187576	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187652	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187653	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187654	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
187655	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
187656	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	4	
187657	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
187658	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	4	
187659	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	397	
187660	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	393	
187661	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
187662	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
187663	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
187664	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
187665	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
187666	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
187667	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
187668	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
187669	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
187670	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
187671	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	166310	
187672	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	166310	
187673	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
187674	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
187675	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	1R	
187676	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
187677	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1366	
187678	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
187679	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
187680	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
187681	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
187682	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
187683	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
187684	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
187685	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
187686	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
187687	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
187688	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
187689	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
187690	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
187691	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
187692	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
187693	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
187694	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
187695	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
187696	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
187697	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
187698	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
187699	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
187700	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
187701	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
187702	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
187703	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
187704	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
187705	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
187706	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	3312.00	kw
187707	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
187708	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
187709	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
187710	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
187711	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
187712	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
187713	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
187714	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
187715	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
187716	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
187717	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
187718	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
187719	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
187720	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
187721	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
187722	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
187723	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
187724	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
187725	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
187726	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187727	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.3450	
187728	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
187729	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
187730	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
187731	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
187732	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
187733	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
187734	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
187735	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
187736	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	50	*C
187737	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	50	*C
187738	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
187739	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
187740	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	2070.00	kw
187741	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
187742	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
187743	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
187744	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
187745	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
187746	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
187747	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
187748	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
187749	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
187750	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
187751	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
187752	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
187753	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
187754	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
187755	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
187756	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
187757	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
187758	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
187759	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
187760	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187761	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187762	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187763	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187764	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	9R	
187765	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187766	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
187767	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
187768	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187769	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
187770	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
187771	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
187772	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
187773	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
187774	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
187775	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
187776	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
187777	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
187778	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
187779	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
187780	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
187781	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
187782	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
187783	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
187784	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
187785	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
187786	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
187787	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
187788	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
187789	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
187790	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
187791	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
187792	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187793	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187794	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187795	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187796	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
187797	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187798	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
187799	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
187800	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187801	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187802	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
187803	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
187804	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
187805	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187806	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187807	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
187808	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
187809	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
187810	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	63826	
187811	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187812	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
187813	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
187814	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
187815	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
187816	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
187817	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
187818	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
187819	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
187820	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
187821	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
187822	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	LTC000109	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
187823	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
187824	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187825	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187826	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187827	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187828	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
187829	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
187830	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
187831	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
187832	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187833	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments	ok	
187834	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
187835	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
187836	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
187837	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187838	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187839	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
187840	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
187841	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
187842	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	199482	
187843	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
187844	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187845	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
187846	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
187847	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
187848	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
187849	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
187850	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
187851	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
187852	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
187853	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	240.0	
187854	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	240.0	
187855	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	180.0	
187856	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
187857	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
187858	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
187859	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	10	
187860	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
187861	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
187862	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
187863	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
187864	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
187865	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
187866	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
187867	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
187868	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
187869	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
187870	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
187871	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
187872	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
187873	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187874	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
187875	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
187876	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187877	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
187878	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
187879	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
187880	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
187881	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
187882	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
187883	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
187884	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
187885	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
187886	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
187887	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
187888	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
187889	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	78456	
187890	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
187891	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
187892	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
187893	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
187894	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
187895	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
187896	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
187897	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
187898	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
187899	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
187900	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
187901	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
187902	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
187903	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
187904	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
187905	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
187906	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
187907	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
187908	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
187909	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
187910	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
187911	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
187912	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
187913	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
187914	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
187915	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
187916	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
187917	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
187918	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
187919	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	B0093	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
187920	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
187921	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
187922	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
187923	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
187924	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
187925	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps C Ø	0.0	
187926	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps B Ø	0.0	
187927	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Amps A Ø	0.0	
187928	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
187929	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
187930	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
187931	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
187932	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
187933	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
187934	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
187935	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
187936	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
187937	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
187938	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
187939	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
187940	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
187941	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
187942	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
187943	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
187944	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
187945	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
187946	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
187947	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
187948	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
187949	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
187950	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
187951	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
187952	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
187953	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
187954	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
187955	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
187956	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
187957	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
187958	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
187959	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
187960	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
187961	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
187962	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
187963	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
187964	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
187965	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
187966	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
187967	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
187968	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
187969	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
187970	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
187971	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
187972	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
187973	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
187974	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
187975	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
187976	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
187977	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
187978	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
187979	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
187980	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
187981	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	32.6	
187982	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	51.3	
187983	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	36.0	
187984	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	157	
187985	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
187986	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
187987	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	113	
187988	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
187989	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
187990	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
187991	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments	ok	
187992	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
187993	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
187994	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
187995	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
187996	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
187997	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
187998	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
187999	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
188000	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
188001	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
188002	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
188003	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
188004	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
188005	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	95613	
188006	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
188007	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
188008	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
188009	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
188010	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
188011	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
188012	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
188013	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
188014	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
188015	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
188016	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
188017	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
188018	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
188019	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
188020	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments	ok	
188021	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
188022	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
188023	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
188024	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
188025	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
188026	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188027	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
188028	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
188029	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	322902	
188030	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
188031	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
188032	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
188033	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
188034	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Unknown Operations	0	
188035	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Switching Operations	0	
188036	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
188037	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18463	
188038	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18463	
188039	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Maintenance Operations	0	
188040	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
188041	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
188042	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
188043	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4236	
188044	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
188045	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
188046	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
188047	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
188048	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
188049	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
188050	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
188051	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
188052	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	49	°C
188053	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	52	°C
188054	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
188055	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
188056	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	338.88	kw
188057	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
188058	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
188059	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
188060	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
188061	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments		
188062	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
188063	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
188064	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
188065	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
188066	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
188067	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
188068	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
188069	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
188070	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
188071	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
188072	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
188073	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations Ground	0	
188074	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
188075	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
188076	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
188077	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
188078	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
188079	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
188080	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
188081	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188082	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188083	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188084	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188085	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188086	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188087	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
188088	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
188089	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188090	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188091	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188092	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188093	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188094	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
188095	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188096	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188097	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188098	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188099	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188100	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188101	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188102	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188103	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188104	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188105	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
188106	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
188107	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
188108	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188109	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
188110	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
188111	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
188112	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188113	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188114	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188115	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188116	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188117	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188118	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188119	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188120	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188121	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
188122	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188123	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
188124	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188125	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
188126	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188127	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188128	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188129	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188130	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188131	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188132	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188133	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188134	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188135	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188136	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188137	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188138	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
188139	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
188140	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.3450	
188141	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
188142	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
188143	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
188144	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
188145	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
188146	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
188147	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
188148	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
188149	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	*C
188150	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	60	*C
188151	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
188152	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188153	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188154	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188155	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188156	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188157	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188158	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188159	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
188160	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
188161	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
188162	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
188163	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
188164	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
188165	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
188166	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
188167	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
188168	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
188169	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	
188170	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27681	volts
188171	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
188172	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
188173	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
188174	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
188175	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
188176	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
188177	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
188178	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
188179	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	322	
188180	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	317	
188181	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
188182	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
188183	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
188184	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
188185	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
188186	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
188187	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
188188	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
188189	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
188190	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
188191	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
188192	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
188193	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
188194	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
188195	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
188196	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
188197	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
188198	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
188199	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
188200	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
188201	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
188202	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
188203	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
188204	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
188205	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
188206	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
188207	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
188208	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
188209	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28657	
188210	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
188211	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
188212	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
188213	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
188214	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
188215	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
188216	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
188217	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
188218	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
188219	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
188220	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
188221	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
188222	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188223	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188224	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188225	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188226	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188227	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188228	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
188229	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
188230	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
188231	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
188232	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188233	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188234	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188235	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
188236	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188237	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
188238	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
188239	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
188240	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
188241	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
188242	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
188243	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
188244	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
188245	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
188246	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
188247	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
188248	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
188249	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
188250	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
188251	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
188252	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188253	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188254	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188255	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188256	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188257	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
188258	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	440.0	
188259	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	440.0	
188260	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	400.0	
188261	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188262	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188263	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188264	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	0	
188265	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188266	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188267	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188268	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188269	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188270	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188271	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188272	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188273	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188274	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188275	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188276	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188277	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments	ok	
188278	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188279	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188280	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188281	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188282	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188283	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188284	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188285	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188286	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188287	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188288	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
188289	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188290	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments	ok	
188291	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188292	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188293	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188294	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188295	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188296	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188297	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188298	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188299	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188300	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
188301	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188302	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
188303	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188304	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
188305	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188306	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188307	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188308	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	8	
188309	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188310	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188311	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188312	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188313	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188314	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188315	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
188316	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188317	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
188318	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188319	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
188320	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188321	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188322	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188323	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188324	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188325	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188326	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
188327	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188328	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188329	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments		
188330	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188331	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
188332	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188333	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188334	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188335	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188336	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188337	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188338	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188339	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188340	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188341	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188342	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188343	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188344	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188345	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
188346	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188347	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188348	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188349	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188350	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188351	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188352	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188353	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188354	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188355	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188356	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
188357	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
188358	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188359	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
188360	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188361	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188362	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188363	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188364	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188365	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188366	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188367	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188368	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188369	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
188370	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188371	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
188372	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188373	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
188374	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188375	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188376	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188377	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188378	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188379	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188380	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188381	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188382	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188383	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188384	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188385	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
188386	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
188387	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
188388	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
188389	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	0	
188390	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	241	
188391	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	241	
188392	9/17/2019 10:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
188393	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188394	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188395	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188396	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	ok	
188397	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
188398	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
188399	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
188400	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188401	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
188402	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188403	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188404	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188405	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188406	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188407	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188408	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188409	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188410	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188411	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188412	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188413	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188414	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188415	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
188416	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188417	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
188418	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188419	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188420	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188421	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments	ok	
188422	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188423	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
188424	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188425	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188426	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188427	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188428	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188429	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188430	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188431	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188432	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188433	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188434	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	5	
188435	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188436	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188437	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188438	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	220.0	
188439	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	155.0	
188440	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	180.0	
188441	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
188442	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188443	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188444	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188445	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188446	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188447	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188448	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	7.67	
188449	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	7.67	
188450	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	7.67	
188451	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
188452	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
188453	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
188454	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
188455	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
188456	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
188457	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
188458	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
188459	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		
188460	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
188461	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
188462	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	2	
188463	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
188464	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	140	
188465	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	140	
188466	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	4	
188467	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
188468	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
188469	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	2	
188470	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
188471	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188472	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188473	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188474	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188475	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188476	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	60.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188477	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	100.0	
188478	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	120.0	
188479	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
188480	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188481	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188482	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188483	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188484	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188485	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188486	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
188487	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
188488	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
188489	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
188490	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
188491	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
188492	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
188493	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
188494	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
188495	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
188496	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
188497	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
188498	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
188499	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
188500	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
188501	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	211	
188502	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	215	
188503	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	4	
188504	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
188505	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	4	
188506	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
188507	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
188508	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188509	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188510	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188511	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188512	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188513	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188514	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188515	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188516	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188517	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188518	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188519	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
188520	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188521	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments	n0 911 signage	
188522	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188523	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188524	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188525	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188526	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
188527	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188528	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188529	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188530	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188531	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188532	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188533	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188534	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188535	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188536	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188537	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188538	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
188539	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188540	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments	ok	
188541	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188542	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
188543	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188544	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188545	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188546	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188547	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188548	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188549	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
188550	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
188551	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188552	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments	trees are getting large around station	
188553	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188554	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
188555	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188556	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
188557	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188558	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188559	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188560	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188561	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188562	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188563	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188564	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
188565	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188566	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
188567	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
188568	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
188569	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
188570	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
188571	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
188572	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
188573	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
188574	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
188575	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
188576	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
188577	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
188578	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
188579	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
188580	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
188581	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
188582	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
188583	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
188584	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
188585	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
188586	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
188587	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8186.40	kw
188588	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
188589	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
188590	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
188591	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
188592	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
188593	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
188594	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
188595	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
188596	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
188597	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
188598	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
188599	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1370	
188600	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	3	
188601	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188602	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188603	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188604	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	210.0	
188605	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	160.0	
188606	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	190.0	
188607	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
188608	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188609	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188610	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188611	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188612	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188613	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188614	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
188615	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
188616	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
188617	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
188618	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
188619	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
188620	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
188621	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
188622	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
188623	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
188624	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments	ok	
188625	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments	ok	
188626	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188627	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
188628	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	315	
188629	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	315	
188630	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	2	
188631	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
188632	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
188633	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
188634	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
188635	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
188636	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
188637	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
188638	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
188639	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
188640	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
188641	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
188642	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
188643	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
188644	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	2	
188645	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
188646	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
188647	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
188648	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
188649	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188650	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188651	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188652	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188653	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188654	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188655	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
188656	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	340.0	
188657	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	340.0	
188658	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	320.0	
188659	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188660	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188661	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188662	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	2	
188663	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
188664	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188665	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188666	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188667	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188668	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188669	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188670	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188671	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188672	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188673	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
188674	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188675	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
188676	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188677	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188678	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188679	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188680	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188681	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188682	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188683	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188684	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188685	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188686	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
188687	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188688	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188689	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188690	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188691	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188692	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188693	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188694	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188695	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188696	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188697	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188698	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188699	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
188700	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
188701	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTC000142	LTCControl	406-1	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188702	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
188703	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCCControl	406-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
188704	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
188705	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
188706	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
188707	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
188708	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
188709	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
188710	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
188711	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
188712	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
188713	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
188714	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
188715	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
188716	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
188717	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
188718	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
188719	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
188720	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
188721	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188722	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188723	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188724	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188725	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188726	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188727	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188728	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188729	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188730	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188731	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188732	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188733	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
188734	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188735	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188736	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188737	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188738	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188739	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188740	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188741	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188742	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188743	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
188744	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
188745	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
188746	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
188747	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188748	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188749	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188750	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188751	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188752	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188753	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188754	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188755	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188756	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
188757	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188758	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
188759	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188760	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
188761	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188762	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188763	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188764	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188765	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188766	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188767	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188768	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188769	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188770	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >'5' Clearance To Trees?	y	
188771	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188772	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188773	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >'5' Clearance To Trees?	y	
188774	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188775	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188776	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188777	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188778	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188779	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188780	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188781	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188782	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188783	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
188784	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	1	
188785	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
188786	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	139	
188787	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	139	
188788	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	2	
188789	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
188790	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
188791	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	1	
188792	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188793	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188794	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188795	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188796	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188797	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188798	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
188799	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188800	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188801	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188802	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188803	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188804	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments	ok	
188805	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188806	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188807	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188808	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188809	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188810	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
188811	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
188812	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
188813	9/17/2019 12:06	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
188814	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
188815	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
188816	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
188817	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	ok	
188818	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
188819	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
188820	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
188821	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
188822	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
188823	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
188824	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
188825	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
188826	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
188827	9/17/2019 12:06	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
188828	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
188829	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments	no 911 signage	
188830	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
188831	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
188832	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
188833	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
188834	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
188835	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
188836	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
188837	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
188838	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
188839	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
188840	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
188841	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence 'S' Clearance To Trees?	y	
188842	9/17/2019 12:06	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
188843	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
188844	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
188845	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.5238	
188846	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
188847	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
188848	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
188849	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
188850	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
188851	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188852	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
188853	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
188854	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	47	°C
188855	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
188856	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
188857	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
188858	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3771.36	kw
188859	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
188860	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
188861	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
188862	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
188863	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
188864	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
188865	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
188866	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
188867	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
188868	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
188869	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
188870	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	4	
188871	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
188872	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
188873	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
188874	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
188875	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
188876	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
188877	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
188878	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
188879	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
188880	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
188881	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
188882	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
188883	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
188884	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
188885	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
188886	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
188887	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	218	
188888	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
188889	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
188890	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
188891	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188892	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188893	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188894	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	263.0	
188895	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	253.0	
188896	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	374.0	
188897	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
188898	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188899	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188900	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188901	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188902	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188903	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188904	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	15.20	
188905	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	15.20	
188906	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	15.20	
188907	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
188908	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
188909	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
188910	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
188911	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
188912	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
188913	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
188914	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
188915	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments		
188916	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
188917	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
188918	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	1	
188919	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
188920	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	175	
188921	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	175	
188922	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	4	
188923	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
188924	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
188925	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	3	
188926	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
188927	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
188928	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
188929	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
188930	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
188931	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
188932	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
188933	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
188934	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
188935	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
188936	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
188937	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
188938	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
188939	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
188940	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
188941	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
188942	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
188943	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
188944	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
188945	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
188946	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
188947	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
188948	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
188949	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
188950	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
188951	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
188952	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
188953	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
188954	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
188955	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	298	
188956	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
188957	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
188958	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	2	
188959	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
188960	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
188961	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
188962	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	145.0	
188963	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	144.0	
188964	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	125.0	
188965	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
188966	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
188967	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
188968	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
188969	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
188970	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
188971	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
188972	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
188973	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
188974	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
188975	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
188976	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
188977	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
188978	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
188979	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
188980	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
188981	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
188982	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
188983	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments		
188984	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
188985	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
188986	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	1	
188987	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
188988	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	189	
188989	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	189	
188990	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	2	
188991	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
188992	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
188993	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	1	
188994	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
188995	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
188996	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
188997	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7578	
188998	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
188999	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189000	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
189001	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189002	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189003	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189004	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
189005	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189006	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	50	°C
189007	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
189008	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
189009	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
189010	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	909.36	kw
189011	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
189012	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
189013	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments	ok	
189014	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
189015	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189016	9/17/2019 14:36	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
189017	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
189018	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
189019	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
189020	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
189021	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
189022	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
189023	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
189024	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments	ok	
189025	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
189026	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
189027	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
189028	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
189029	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
189030	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
189031	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
189032	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
189033	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
189034	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	86.0	
189035	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	74.0	
189036	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	81.0	
189037	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189038	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189039	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
189040	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
189041	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
189042	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189043	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189044	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189045	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189046	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
189047	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
189048	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
189049	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
189050	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	96	
189051	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
189052	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
189053	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189054	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
189055	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
189056	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	80	°C
189057	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	84	°C
189058	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.7808	
189059	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
189060	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189061	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
189062	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
189063	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189064	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189065	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
189066	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189067	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	55	°C
189068	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	85	°C
189069	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
189070	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189071	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	17095.68	kw
189072	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
189073	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
189074	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
189075	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189076	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189077	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
189078	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189079	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
189080	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
189081	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189082	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189083	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189084	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189085	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189086	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189087	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189088	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
189089	9/17/2019 10:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
189090	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
189091	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
189092	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
189093	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189094	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189095	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
189096	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
189097	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
189098	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
189099	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
189100	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
189101	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
189102	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
189103	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
189104	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
189105	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
189106	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
189107	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
189108	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
189109	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
189110	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
189111	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
189112	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
189113	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
189114	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
189115	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
189116	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
189117	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
189118	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
189119	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
189120	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
189121	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
189122	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
189123	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
189124	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
189125	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
189126	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
189127	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
189128	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
189129	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
189130	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
189131	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
189132	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
189133	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
189134	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
189135	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
189136	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
189137	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
189138	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189139	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189140	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
189141	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
189142	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
189143	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189144	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189145	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189146	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189147	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
189148	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
189149	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
189150	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
189151	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	29	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189152	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
189153	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
189154	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189155	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
189156	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
189157	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	n	
189158	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments	ok	
189159	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
189160	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
189161	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
189162	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
189163	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
189164	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
189165	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
189166	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
189167	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
189168	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
189169	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
189170	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
189171	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
189172	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
189173	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
189174	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
189175	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
189176	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
189177	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
189178	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
189179	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
189180	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
189181	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
189182	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
189183	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
189184	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
189185	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
189186	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
189187	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
189188	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
189189	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
189190	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
189191	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
189192	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
189193	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
189194	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
189195	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
189196	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
189197	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
189198	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
189199	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	4	
189200	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
189201	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
189202	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
189203	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	30.0	
189204	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	61.0	
189205	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	29.0	
189206	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
189207	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
189208	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
189209	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
189210	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
189211	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
189212	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
189213	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
189214	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
189215	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	2	
189216	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	380	
189217	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	380	
189218	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
189219	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
189220	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
189221	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
189222	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
189223	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
189224	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
189225	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
189226	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189227	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	1	
189228	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	1	
189229	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
189230	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	5.99	
189231	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	5.99	
189232	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
189233	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
189234	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189235	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189236	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189237	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189238	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189239	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189240	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189241	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
189242	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
189243	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189244	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
189245	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
189246	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189247	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
189248	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
189249	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
189250	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	5308.80	kw
189251	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
189252	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
189253	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189254	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189255	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
189256	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
189257	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
189258	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189259	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189260	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189261	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189262	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
189263	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
189264	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
189265	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
189266	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	21	
189267	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
189268	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
189269	9/17/2019 15:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189270	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
189271	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
189272	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
189273	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
189274	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
189275	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
189276	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
189277	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
189278	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
189279	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
189280	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
189281	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
189282	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
189283	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
189284	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
189285	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	55.0	
189286	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	61.0	
189287	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.0	
189288	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
189289	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
189290	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
189291	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
189292	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
189293	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
189294	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
189295	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
189296	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
189297	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
189298	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
189299	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
189300	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
189301	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189302	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
189303	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
189304	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
189305	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
189306	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
189307	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
189308	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
189309	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
189310	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
189311	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
189312	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
189313	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
189314	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
189315	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
189316	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
189317	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
189318	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
189319	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
189320	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
189321	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
189322	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
189323	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
189324	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
189325	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
189326	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
189327	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
189328	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
189329	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189330	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
189331	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
189332	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
189333	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189334	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189335	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189336	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189337	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
189338	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
189339	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
189340	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
189341	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
189342	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	90	
189343	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
189344	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
189345	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189346	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
189347	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
189348	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
189349	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
189350	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
189351	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
189352	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
189353	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
189354	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
189355	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
189356	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
189357	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
189358	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
189359	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
189360	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
189361	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
189362	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
189363	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
189364	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
189365	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
189366	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
189367	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	General Comments	ok	
189368	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
189369	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
189370	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
189371	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
189372	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	LTC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
189373	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
189374	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
189375	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
189376	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189377	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	1773	
189378	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	1773	
189379	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
189380	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	6L	
189381	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
189382	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	12L	
189383	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
189384	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	1551	
189385	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
189386	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
189387	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
189388	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
189389	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189390	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
189391	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
189392	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189393	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189394	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
189395	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189396	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
189397	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189398	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
189399	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
189400	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189401	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
189402	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189403	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
189404	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
189405	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189406	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	0624	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189407	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189408	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
189409	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	50	*C
189410	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	45	*C
189411	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189412	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
189413	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189414	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189415	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
189416	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
189417	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189418	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
189419	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.5530	
189420	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
189421	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
189422	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
189423	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
189424	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
189425	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
189426	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
189427	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
189428	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
189429	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
189430	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	320.0	
189431	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	320.0	
189432	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	320.0	
189433	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
189434	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
189435	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
189436	9/17/2019 10:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	4	
189437	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	53.0	
189438	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
189439	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
189440	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189441	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
189442	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
189443	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
189444	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
189445	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
189446	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
189447	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	1	
189448	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
189449	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
189450	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
189451	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189452	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
189453	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
189454	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189455	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189456	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189457	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189458	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
189459	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
189460	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
189461	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
189462	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	291	
189463	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
189464	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
189465	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189466	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
189467	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
189468	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
189469	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments	ok	
189470	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments	ok	
189471	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
189472	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
189473	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	0	
189474	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
189475	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	188	
189476	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	188	
189477	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	1	
189478	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
189479	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
189480	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
189481	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
189482	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
189483	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	53.0	
189484	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
189485	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
189486	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
189487	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
189488	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
189489	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
189490	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments	ok	
189491	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
189492	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC0000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
189493	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC0000373	LTCControl	845-1	LTC Control Insp	General Comments		
189494	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC0000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
189495	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC0000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
189496	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189497	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
189498	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
189499	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189500	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
189501	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189502	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189503	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189504	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189505	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
189506	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
189507	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
189508	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
189509	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189510	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189511	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189512	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
189513	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
189514	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189515	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
189516	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
189517	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
189518	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	10	
189519	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
189520	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189521	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
189522	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments	ok	
189523	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
189524	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
189525	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
189526	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189527	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
189528	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
189529	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	210.0	
189530	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	280.0	
189531	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	290.0	
189532	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
189533	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
189534	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
189535	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
189536	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
189537	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
189538	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
189539	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
189540	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
189541	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
189542	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	1	
189543	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
189544	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
189545	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
189546	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
189547	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
189548	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
189549	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
189550	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
189551	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
189552	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
189553	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189554	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189555	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189556	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
189557	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
189558	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
189559	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
189560	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189561	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6513	
189562	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
189563	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	1.2620	
189564	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
189565	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
189566	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
189567	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
189568	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
189569	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
189570	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
189571	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
189572	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
189573	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
189574	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
189575	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
189576	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
189577	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
189578	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
189579	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
189580	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
189581	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
189582	9/17/2019 13:30	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
189583	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
189584	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
189585	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
189586	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
189587	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
189588	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
189589	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
189590	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
189591	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
189592	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
189593	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
189594	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
189595	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	PT conduit needs attention. 603 switch handle needs ground braid. Need 2 more fuses	
189596	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
189597	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
189598	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
189599	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
189600	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
189601	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189602	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
189603	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
189604	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
189605	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
189606	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
189607	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
189608	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
189609	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
189610	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
189611	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
189612	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
189613	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
189614	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
189615	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
189616	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
189617	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
189618	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
189619	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	LTC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
189620	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
189621	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
189622	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189623	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189624	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189625	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189626	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189627	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189628	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189629	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
189630	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
189631	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189632	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
189633	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
189634	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189635	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189636	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
189637	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
189638	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
189639	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
189640	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189641	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
189642	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
189643	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
189644	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
189645	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
189646	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
189647	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
189648	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
189649	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
189650	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
189651	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
189652	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
189653	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
189654	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
189655	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	4911.84	kw
189656	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
189657	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments	ok	
189658	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
189659	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
189660	9/17/2019 13:05	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
189661	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189662	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	35	*C
189663	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
189664	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189665	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR00043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189666	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189667	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
189668	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	*C
189669	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	47	*C
189670	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189671	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
189672	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189673	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189674	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
189675	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
189676	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189677	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
189678	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.6822	
189679	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
189680	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
189681	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
189682	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189683	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189684	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189685	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189686	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
189687	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189688	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
189689	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
189690	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
189691	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	231	
189692	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	235	
189693	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	5	
189694	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
189695	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	4	
189696	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
189697	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
189698	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
189699	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
189700	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	All Connections OK?	y	
189701	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
189702	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
189703	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21439	
189704	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189705	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
189706	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Leaks	None	
189707	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Current Tap Position	1L	
189708	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
189709	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	General Comments		
189710	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Max Tap Position	Neutral	
189711	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Min Tap Position	13L	
189712	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
189713	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
189714	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
189715	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
189716	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
189717	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AF	25809	
189718	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Counter AL	25809	
189719	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
189720	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
189721	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC001278	RegulatorControl	891-1 A	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
189722	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
189723	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189724	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189725	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189726	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189727	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	4L	
189728	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189729	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
189730	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
189731	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189732	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
189733	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
189734	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
189735	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2134.08	kw
189736	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
189737	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
189738	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189739	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31590	
189740	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
189741	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
189742	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
189743	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
189744	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
189745	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
189746	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
189747	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
189748	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
189749	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
189750	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
189751	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189752	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
189753	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
189754	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
189755	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	33253	
189756	9/17/2019 13:28	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
189757	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
189758	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189759	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
189760	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
189761	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189762	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189763	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
189764	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189765	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
189766	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
189767	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
189768	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
189769	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	3	
189770	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
189771	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189772	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
189773	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
189774	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	52	°C
189775	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	64	°C
189776	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
189777	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
189778	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7408.80	kw
189779	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
189780	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
189781	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189782	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
189783	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
189784	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
189785	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189786	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
189787	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
189788	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1004	
189789	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
189790	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189791	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
189792	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
189793	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189794	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189795	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
189796	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189797	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
189798	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
189799	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189800	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189801	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189802	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189803	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189804	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	60	°C
189805	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
189806	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
189807	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
189808	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10563.84	kw
189809	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
189810	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
189811	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
189812	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments		
189813	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189814	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189815	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189816	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
189817	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189818	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
189819	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
189820	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	0	
189821	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
189822	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
189823	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	40	°C
189824	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	50	°C
189825	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
189826	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189827	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
189828	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
189829	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
189830	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189831	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189832	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
189833	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189834	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	60	°C
189835	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	65	°C
189836	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
189837	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189838	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	4038.40	kw
189839	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
189840	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
189841	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
189842	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
189843	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
189844	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
189845	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
189846	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
189847	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
189848	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
189849	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
189850	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
189851	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
189852	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
189853	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
189854	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
189855	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
189856	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
189857	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
189858	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
189859	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
189860	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
189861	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
189862	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
189863	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
189864	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
189865	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
189866	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
189867	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189868	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
189869	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
189870	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189871	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
189872	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
189873	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189874	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
189875	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189876	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189877	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189878	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189879	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189880	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189881	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
189882	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
189883	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
189884	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments	ok	
189885	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments	ok	
189886	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
189887	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
189888	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	0	
189889	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
189890	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	155	
189891	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	155	
189892	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0290	
189893	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
189894	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
189895	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
189896	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments	ok	
189897	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189898	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
189899	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
189900	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189901	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	2R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
189902	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189903	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189904	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189905	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189906	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
189907	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
189908	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
189909	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
189910	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189911	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6981	
189912	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
189913	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
189914	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
189915	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
189916	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189917	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
189918	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
189919	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189920	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189921	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189922	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
189923	9/17/2019 14:31	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
189924	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189925	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
189926	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
189927	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
189928	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
189929	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
189930	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
189931	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
189932	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments	ok	
189933	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189934	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
189935	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
189936	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
189937	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
189938	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
189939	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	20602	
189940	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
189941	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
189942	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
189943	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
189944	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
189945	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
189946	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
189947	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
189948	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
189949	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
189950	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
189951	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189952	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
189953	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189954	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
189955	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189956	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
189957	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
189958	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
189959	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
189960	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
189961	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.8334	
189962	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
189963	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
189964	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
189965	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
189966	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
189967	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
189968	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
189969	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
189970	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	55	°C
189971	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	75	°C
189972	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
189973	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
189974	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	12000.96	
189975	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
189976	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
189977	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments		
189978	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
189979	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
189980	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
189981	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
189982	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
189983	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
189984	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
189985	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
189986	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
189987	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
189988	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
189989	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
189990	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
189991	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
189992	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
189993	9/17/2019 10:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
189994	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
189995	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
189996	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
189997	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
189998	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
189999	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
190000	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
190001	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
190002	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
190003	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
190004	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
190005	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
190006	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	General Comments		
190007	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
190008	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
190009	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
190010	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190011	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190012	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
190013	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
190014	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
190015	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
190016	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
190017	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	45	
190018	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
190019	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
190020	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
190021	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
190022	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
190023	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
190024	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6987	
190025	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
190026	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
190027	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
190028	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190029	9/17/2019 11:30	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190030	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190031	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190032	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	460.0	
190033	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	440.0	
190034	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	496.0	
190035	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
190036	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
190037	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
190038	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
190039	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
190040	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
190041	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
190042	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
190043	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
190044	9/17/2019 10:39	Distribution	London Quarterly Inspection	LTCC000241	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
190045	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
190046	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
190047	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
190048	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
190049	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190050	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190051	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
190052	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190053	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
190054	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
190055	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
190056	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
190057	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
190058	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
190059	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
190060	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
190061	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
190062	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
190063	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
190064	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
190065	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	142	
190066	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	142	
190067	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	0	
190068	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
190069	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
190070	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
190071	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
190072	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
190073	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
190074	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
190075	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
190076	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AL	25253	
190077	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Counter AF	25253	
190078	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
190079	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
190080	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190081	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190082	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190083	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
190084	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
190085	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
190086	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
190087	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
190088	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
190089	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
190090	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
190091	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
190092	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Min Tap Position	14L	
190093	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Max Tap Position	1L	
190094	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	General Comments		
190095	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
190096	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	Current Tap Position	3L	
190097	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
190098	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
190099	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
190100	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7128	
190101	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
190102	9/17/2019 13:27	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
190103	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
190104	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
190105	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
190106	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
190107	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
190108	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
190109	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
190110	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
190111	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
190112	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
190113	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	3	
190114	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	197	
190115	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	197	
190116	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
190117	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	0	
190118	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
190119	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
190120	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	ok	
190121	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments	ok	
190122	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
190123	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
190124	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
190125	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
190126	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
190127	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	2	
190128	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
190129	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
190130	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	8.38	
190131	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
190132	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	0	
190133	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190134	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190135	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
190136	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
190137	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
190138	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
190139	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
190140	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	0	
190141	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
190142	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
190143	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	240.0	
190144	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	210.0	
190145	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	188.0	
190146	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
190147	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
190148	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	196.0	
190149	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	203.0	
190150	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	202.0	
190151	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190152	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190153	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190154	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	5	
190155	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Min Tap Position	15L	
190156	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Max Tap Position	3L	
190157	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	General Comments		
190158	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Follow-up Action Required?	n	
190159	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Current Tap Position	5L	
190160	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	All Connections OK?	y	
190161	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
190162	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
190163	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	0	
190164	9/17/2019 10:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190165	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
190166	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
190167	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190168	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
190169	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
190170	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
190171	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	
190172	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	If low,note cell #'s
190173	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
190174	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
190175	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190176	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
190177	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
190178	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
190179	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
190180	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
190181	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
190182	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
190183	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
190184	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
190185	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
190186	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
190187	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
190188	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
190189	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
190190	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
190191	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
190192	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
190193	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	77	
190194	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	77	
190195	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
190196	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	155627	
190197	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
190198	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
190199	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190200	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190201	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190202	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
190203	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
190204	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		
190205	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
190206	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
190207	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
190208	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
190209	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5R	
190210	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
190211	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
190212	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
190213	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
190214	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
190215	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
190216	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
190217	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	240.0	
190218	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
190219	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
190220	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	120.0	
190221	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	200.0	
190222	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
190223	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
190224	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
190225	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
190226	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
190227	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
190228	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
190229	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
190230	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
190231	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
190232	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000096	RegulatorControl	891-1 B	Regulator Annual Control Inspection	All Connections OK?	y	
190233	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
190234	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
190235	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4446	
190236	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
190237	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
190238	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
190239	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
190240	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
190241	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
190242	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
190243	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
190244	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
190245	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
190246	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments	ok	
190247	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
190248	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
190249	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
190250	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
190251	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
190252	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	216727	
190253	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
190254	9/17/2019 13:59	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
190255	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
190256	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
190257	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
190258	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
190259	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
190260	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
190261	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	1148	
190262	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	12L	
190263	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
190264	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	6L	
190265	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
190266	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	17235	
190267	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	17235	
190268	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
190269	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
190270	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
190271	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
190272	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
190273	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
190274	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
190275	9/17/2019 15:16	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
190276	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	15.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190277	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
190278	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
190279	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
190280	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
190281	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
190282	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
190283	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
190284	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
190285	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
190286	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
190287	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
190288	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
190289	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
190290	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1967	
190291	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
190292	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
190293	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
190294	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
190295	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
190296	9/17/2019 13:40	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
190297	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
190298	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
190299	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
190300	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
190301	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
190302	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
190303	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
190304	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
190305	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
190306	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
190307	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
190308	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
190309	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
190310	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AF	21439	
190311	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
190312	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
190313	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	0	
190314	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
190315	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	0	
190316	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
190317	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
190318	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
190319	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	227	
190320	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	227	
190321	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
190322	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
190323	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
190324	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
190325	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
190326	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
190327	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
190328	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
190329	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
190330	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
190331	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
190332	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
190333	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
190334	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190335	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190336	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190337	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190338	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
190339	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
190340	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
190341	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
190342	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
190343	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
190344	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
190345	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	105.0	
190346	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	168.0	
190347	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	165.0	
190348	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	162.0	
190349	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	120.0	
190350	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	120.0	
190351	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190352	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190353	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190354	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
190355	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
190356	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Leaks	None	
190357	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
190358	9/17/2019 14:49	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	2	
190359	9/17/2019 14:37	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
190360	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	8	
190361	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
190362	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
190363	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
190364	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
190365	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	General Comments		
190366	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	General Comments		
190367	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
190368	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
190369	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
190370	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190371	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190372	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
190373	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
190374	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
190375	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
190376	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
190377	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
190378	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
190379	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
190380	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
190381	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
190382	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
190383	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.7	VDC
190384	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
190385	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
190386	9/17/2019 9:43	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
190387	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25253	
190388	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
190389	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
190390	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
190391	9/17/2019 12:31	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
190392	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
190393	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
190394	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
190395	9/17/2019 13:56	Distribution	Salt Lick Quarterly Inspection	KRC000097	RegulatorControl	891-1 C	Regulator Annual Control Inspection	VRR Counter AL	21439	
190396	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
190397	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
190398	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
190399	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
190400	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
190401	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
190402	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	41	°C
190403	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
190404	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
190405	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
190406	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	855.36	kw
190407	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
190408	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
190409	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
190410	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments	ok	
190411	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
190412	9/17/2019 11:20	Distribution	Morehead Quarterly Inspection	LTC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
190413	9/17/2019 12:06	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
190414	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
190415	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
190416	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
190417	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
190418	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
190419	9/17/2019 14:00	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
190420	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
190421	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	10	
190422	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
190423	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	7L	
190424	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
190425	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	36764	
190426	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	36764	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
190577	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
190578	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
190579	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
190580	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
190581	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
190582	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
190583	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
190584	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
190585	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
190586	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
190587	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
190588	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
190589	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
190590	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
190591	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
190592	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
190593	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	1	
190594	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
190595	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
190596	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
190597	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
190598	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7536	
190599	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190600	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
190601	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
190602	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
190603	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
190604	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
190605	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
190606	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190607	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190608	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	155.0	
190609	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	158.0	
190610	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
190611	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
190612	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
190613	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
190614	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
190615	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
190616	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments		
190617	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
190618	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
190619	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
190620	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
190621	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
190622	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
190623	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
190624	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
190625	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
190626	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
190627	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
190628	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
190629	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
190630	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
190631	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	86076	
190632	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
190633	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
190634	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
190635	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
190636	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
190637	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
190638	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
190639	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
190640	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
190641	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
190642	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
190643	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
190644	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	154	
190645	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	5	
190646	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
190647	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	0	
190648	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
190649	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
190650	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
190651	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190652	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
190653	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
190654	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
190655	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
190656	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
190657	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1226	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
190658	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
190659	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	0	
190660	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190661	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190662	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190663	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A Ø	0.0	
190664	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B Ø	0.0	
190665	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C Ø	0.0	
190666	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190667	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
190668	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
190669	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
190670	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	106	
190671	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
190672	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
190673	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
190674	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
190675	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
190676	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
190677	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
190678	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
190679	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
190680	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
190681	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
190682	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190683	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
190684	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
190685	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
190686	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190687	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190688	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190689	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
190690	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
190691	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
190692	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
190693	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
190694	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
190695	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
190696	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	5	
190697	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
190698	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
190699	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
190700	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
190701	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
190702	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
190703	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
190704	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
190705	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
190706	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	149	
190707	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
190708	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
190709	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
190710	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
190711	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
190712	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
190713	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
190714	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
190715	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
190716	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
190717	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
190718	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
190719	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190720	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99844	
190721	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99844	
190722	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
190723	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
190724	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
190725	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
190726	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190727	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
190728	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
190729	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
190730	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
190731	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
190732	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	66	°C
190733	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
190734	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
190735	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
190736	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190737	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1750	psi
190738	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
190739	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
190740	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
190741	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	oil at bottom of the transformer on tr pad pics are sent to Stinson	
190742	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
190743	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190744	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190745	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190746	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
190747	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
190748	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
190749	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
190750	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	120.0	
190751	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	120.0	
190752	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	541	°C
190753	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
190754	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
190755	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
190756	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
190757	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
190758	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	120.0	
190759	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190760	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190761	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190762	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
190763	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
190764	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
190765	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
190766	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
190767	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	106	
190768	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
190769	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190770	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190771	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190772	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
190773	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
190774	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
190775	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
190776	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
190777	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
190778	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
190779	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
190780	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
190781	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
190782	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	60	
190783	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	60	
190784	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	
190785	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	
190786	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
190787	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
190788	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
190789	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
190790	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
190791	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
190792	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	100.0	
190793	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	100.0	
190794	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	100.0	
190795	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190796	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190797	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190798	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	9	
190799	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
190800	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
190801	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190802	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
190803	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
190804	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
190805	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
190806	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
190807	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
190808	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
190809	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
190810	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
190811	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
190812	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
190813	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
190814	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
190815	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
190816	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
190817	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190818	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190819	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190820	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190821	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
190822	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
190823	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
190824	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190825	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190826	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
190827	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	2	
190828	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	0	
190829	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
190830	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations This Read Vac	0	
190831	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	93	
190832	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	93	
190833	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
190834	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		
190835	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
190836	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
190837	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
190838	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
190839	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
190840	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
190841	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
190842	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190843	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190844	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190845	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190846	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C Ø	153.0	
190847	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B Ø	156.0	
190848	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A Ø	158.0	
190849	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190850	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
190851	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190852	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	5	
190853	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
190854	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
190855	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
190856	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	80	
190857	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	80	
190858	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
190859	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
190860	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
190861	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
190862	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
190863	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
190864	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
190865	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
190866	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
190867	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
190868	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
190869	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
190870	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
190871	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
190872	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
190873	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
190874	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
190875	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
190876	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
190877	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments	no temp gauge on ltc	
190878	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	44405	
190879	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	44405	
190880	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
190881	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	3R	
190882	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	16R	
190883	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	88	*F
190884	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
190885	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	6L	
190886	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
190887	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	*C
190888	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	*C
190889	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1493	
190890	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
190891	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
190892	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
190893	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
190894	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
190895	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	66	*C
190896	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	54	*C
190897	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
190898	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
190899	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
190900	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
190901	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
190902	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
190903	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
190904	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
190905	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
190906	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	70	*C
190907	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	57	*C
190908	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	*C
190909	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	57	*C
190910	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	70	*C
190911	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	57	*C
190912	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
190913	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
190914	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
190915	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
190916	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
190917	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
190918	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
190919	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations This Read Vac	0	
190920	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	87	
190921	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	87	
190922	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
190923	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments		
190924	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments		
190925	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
190926	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Follow-up Action Required?	n	
190927	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations Ground	0	
190928	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
190929	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	7653	
190930	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	7662	
190931	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
190932	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	1L	
190933	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
190934	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	10L	
190935	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	1296	
190936	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
190937	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
190938	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
190939	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	71.6	
190940	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	41.5	
190941	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.6	
190942	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
190943	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
190944	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
190945	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
190946	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
190947	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
190948	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
190949	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
190950	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
190951	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
190952	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
190953	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
190954	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
190955	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
190956	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
190957	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
190958	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
190959	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BAT000164	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
190960	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
190961	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
190962	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
190963	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	582	
190964	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
190965	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	X0081	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
190966	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
190967	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
190968	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
190969	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
190970	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	22844	
190971	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	22844	
190972	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
190973	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
190974	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
190975	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
190976	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	*C
190977	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	880	
190978	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
190979	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
190980	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
190981	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
190982	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
190983	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
190984	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
190985	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
190986	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
190987	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
190988	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
190989	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
190990	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
190991	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
190992	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
190993	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
190994	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
190995	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
190996	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
190997	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
190998	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	21180	
190999	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	21180	
191000	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
191001	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2R	
191002	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
191003	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
191004	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	57	*C
191005	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	779	
191006	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
191007	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
191008	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
191009	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
191010	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
191011	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
191012	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
191013	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
191014	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
191015	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
191016	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
191017	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
191018	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
191019	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
191020	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		
191021	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
191022	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
191023	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
191024	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
191025	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
191026	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191027	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
191028	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
191029	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
191030	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
191031	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A Ø	0.0	
191032	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191033	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191034	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191035	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	0	
191036	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
191037	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
191038	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
191039	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
191040	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
191041	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments		
191042	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
191043	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
191044	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191045	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191046	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191047	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	0	
191048	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
191049	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	49	
191050	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	49	
191051	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
191052	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
191053	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
191054	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
191055	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
191056	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
191057	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
191058	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
191059	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
191060	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191061	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191062	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191063	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191064	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
191065	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
191066	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
191067	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191068	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191069	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191070	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	0	
191071	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
191072	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
191073	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
191074	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	57	°C
191075	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
191076	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	57	°C
191077	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
191078	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	57	°C
191079	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
191080	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191081	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191082	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191083	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
191084	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
191085	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191086	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
191087	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
191088	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
191089	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
191090	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
191091	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
191092	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
191093	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191094	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
191095	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
191096	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
191097	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
191098	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
191099	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191100	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
191101	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191102	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
191103	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
191104	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
191105	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
191106	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
191107	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
191108	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
191109	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
191110	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
191111	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
191112	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
191113	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
191114	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
191115	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191116	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
191117	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
191118	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
191119	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
191120	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
191121	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
191122	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
191123	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
191124	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
191125	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
191126	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
191127	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
191128	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
191129	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
191130	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
191131	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
191132	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
191133	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
191134	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
191135	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
191136	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
191137	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
191138	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
191139	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
191140	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	170	
191141	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	170	
191142	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
191143	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
191144	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
191145	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
191146	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
191147	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
191148	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
191149	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
191150	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
191151	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191152	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191153	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191154	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191155	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
191156	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
191157	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	90	°C
191158	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	69	°C
191159	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
191160	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
191161	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
191162	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
191163	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	182	
191164	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	182	
191165	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	0	
191166	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
191167	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
191168	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
191169	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
191170	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
191171	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191172	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191173	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191174	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191175	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
191176	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191177	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
191178	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
191179	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
191180	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
191181	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments		
191182	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
191183	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
191184	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	49	
191185	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	49	
191186	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
191187	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
191188	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
191189	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
191190	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
191191	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
191192	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
191193	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
191194	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
191195	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
191196	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
191197	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
191198	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
191199	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
191200	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
191201	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BAT000426	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
191202	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191203	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
191204	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
191205	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
191206	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
191207	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191208	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
191209	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
191210	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191211	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
191212	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
191213	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191214	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	0	
191215	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191216	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191217	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191218	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
191219	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
191220	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
191221	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191222	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191223	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191224	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191225	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
191226	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
191227	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
191228	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
191229	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
191230	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
191231	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
191232	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
191233	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
191234	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
191235	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	0	
191236	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191237	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191238	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191239	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
191240	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
191241	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
191242	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191243	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
191244	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
191245	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
191246	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
191247	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191248	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
191249	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
191250	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191251	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191252	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
191253	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191254	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
191255	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
191256	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
191257	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	17776.80	kw
191258	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
191259	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
191260	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	64	°C
191261	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	60	°C
191262	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191263	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
191264	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
191265	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
191266	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
191267	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
191268	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191269	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
191270	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.9876	
191271	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
191272	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
191273	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
191274	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
191275	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
191276	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
191277	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
191278	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
191279	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
191280	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
191281	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
191282	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
191283	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
191284	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
191285	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
191286	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
191287	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
191288	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments	ok	
191289	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
191290	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
191291	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
191292	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191293	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
191294	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
191295	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
191296	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
191297	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191298	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
191299	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
191300	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191301	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
191302	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
191303	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191304	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
191305	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
191306	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
191307	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
191308	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	1	
191309	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	253	
191310	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	253	
191311	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
191312	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	1	
191313	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
191314	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
191315	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
191316	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
191317	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
191318	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
191319	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
191320	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
191321	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
191322	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
191323	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
191324	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191325	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191326	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191327	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191328	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
191329	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
191330	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
191331	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	0	
191332	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191333	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191334	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191335	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments	added 1 lb nitrogen	
191336	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
191337	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	132.48	kw
191338	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
191339	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
191340	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	50	°C
191341	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	42	°C
191342	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191343	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
191344	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
191345	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
191346	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
191347	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191348	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
191349	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0414	
191350	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
191351	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	9	
191352	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191353	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191354	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191355	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	10.0	
191356	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	10.0	
191357	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	10.0	
191358	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
191359	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
191360	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
191361	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
191362	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
191363	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
191364	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191365	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191366	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191367	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191368	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
191369	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
191370	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
191371	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
191372	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
191373	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
191374	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
191375	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
191376	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
191377	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
191378	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
191379	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
191380	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
191381	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	539	
191382	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	544	
191383	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	5	
191384	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
191385	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	5	
191386	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
191387	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
191388	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
191389	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
191390	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
191391	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
191392	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
191393	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
191394	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
191395	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
191396	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
191397	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191398	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
191399	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
191400	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
191401	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191402	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
191403	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
191404	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
191405	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191406	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191407	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191408	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
191409	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
191410	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
191411	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
191412	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
191413	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
191414	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	10.7	
191415	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	10.0	
191416	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	32.5	
191417	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191418	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191419	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191420	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
191421	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
191422	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	21.35	%
191423	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	21.35	%
191424	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	21.35	%
191425	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
191426	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
191427	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
191428	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
191429	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
191430	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	0	
191431	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191432	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191433	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191434	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191435	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
191436	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
191437	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
191438	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
191439	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
191440	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
191441	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
191442	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
191443	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
191444	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
191445	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
191446	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	1	
191447	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
191448	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	312	
191449	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
191450	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
191451	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
191452	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
191453	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
191454	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
191455	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
191456	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191457	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
191458	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
191459	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
191460	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
191461	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
191462	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
191463	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191464	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
191465	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
191466	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
191467	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
191468	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
191469	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	312	
191470	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	1	
191471	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
191472	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
191473	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
191474	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
191475	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
191476	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191477	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
191478	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	88	
191479	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	88	
191480	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
191481	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
191482	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
191483	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
191484	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
191485	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
191486	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
191487	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
191488	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
191489	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191490	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	0	
191491	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191492	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191493	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191494	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
191495	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
191496	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191497	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191498	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191499	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
191500	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
191501	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
191502	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
191503	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments		
191504	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
191505	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
191506	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191507	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
191508	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
191509	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
191510	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
191511	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	89.0	
191512	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	88.0	
191513	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	89.0	
191514	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191515	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191516	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
191517	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
191518	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191519	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
191520	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191521	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
191522	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
191523	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
191524	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
191525	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
191526	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
191527	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
191528	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
191529	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
191530	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
191531	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	120.0	
191532	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	170.0	
191533	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	120.0	
191534	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191535	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191536	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191537	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	3	
191538	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	99	
191539	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	99	
191540	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
191541	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
191542	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
191543	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	2	
191544	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191545	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191546	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191547	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	210.0	
191548	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	150.0	
191549	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	250.0	
191550	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
191551	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
191552	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
191553	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
191554	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
191555	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
191556	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
191557	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
191558	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	143	
191559	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	143	
191560	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
191561	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
191562	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
191563	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
191564	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191565	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
191566	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
191567	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
191568	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
191569	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
191570	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
191571	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191572	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
191573	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
191574	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
191575	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
191576	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
191577	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
191578	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	
191579	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191580	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191581	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191582	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191583	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	157.0	
191584	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	160.0	
191585	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	160.0	
191586	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191587	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191588	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191589	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
191590	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191591	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191592	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191593	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191594	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
191595	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
191596	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
191597	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
191598	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
191599	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
191600	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
191601	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
191602	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
191603	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
191604	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	405	
191605	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	405	
191606	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
191607	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
191608	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
191609	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments		
191610	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
191611	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
191612	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
191613	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
191614	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
191615	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
191616	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
191617	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
191618	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
191619	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
191620	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
191621	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
191622	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
191623	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
191624	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
191625	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations This Read Vac	0	
191626	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	66	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
191627	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	66	
191628	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
191629	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments		
191630	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments		
191631	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
191632	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
191633	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
191634	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
191635	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
191636	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
191637	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
191638	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
191639	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
191640	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
191641	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
191642	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
191643	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
191644	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
191645	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
191646	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
191647	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
191648	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
191649	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
191650	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
191651	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
191652	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
191653	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
191654	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
191655	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
191656	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
191657	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
191658	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
191659	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
191660	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
191661	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
191662	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
191663	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
191664	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
191665	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
191666	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
191667	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
191668	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191669	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
191670	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
191671	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
191672	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
191673	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
191674	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191675	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	*C
191676	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
191677	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
191678	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
191679	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
191680	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	Can Not determine oil temps, gauge broken	
191681	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
191682	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
191683	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
191684	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
191685	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
191686	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
191687	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191688	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
191689	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
191690	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191691	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	0223	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191692	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
191693	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
191694	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
191695	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
191696	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
191697	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTO285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
191698	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTO285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
191699	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTO285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
191700	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTO285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
191701	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTO285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	881	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191702	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	56	°C
191703	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
191704	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
191705	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3R	
191706	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	25289	
191707	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	25289	
191708	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
191709	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
191710	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
191711	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
191712	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
191713	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
191714	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
191715	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
191716	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
191717	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
191718	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
191719	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
191720	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
191721	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
191722	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
191723	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191724	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
191725	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
191726	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
191727	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
191728	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
191729	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments	No Spare Fuses	
191730	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
191731	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
191732	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
191733	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
191734	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
191735	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
191736	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
191737	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
191738	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
191739	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
191740	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
191741	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
191742	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
191743	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
191744	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
191745	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
191746	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
191747	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
191748	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
191749	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
191750	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
191751	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
191752	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191753	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
191754	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
191755	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
191756	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
191757	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
191758	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
191759	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
191760	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
191761	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
191762	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
191763	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	23201	
191764	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	23201	
191765	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
191766	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
191767	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	9R	
191768	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	8L	
191769	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
191770	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
191771	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
191772	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
191773	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	1727	
191774	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
191775	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
191776	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
191777	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
191778	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
191779	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
191780	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191781	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191782	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191783	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191784	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
191785	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
191786	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
191787	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191788	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191789	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191790	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	0	
191791	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
191792	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	True reading taken with Amp meter	
191793	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
191794	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
191795	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
191796	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
191797	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
191798	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
191799	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
191800	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
191801	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191802	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
191803	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
191804	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
191805	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
191806	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
191807	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
191808	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
191809	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
191810	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
191811	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
191812	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
191813	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
191814	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
191815	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
191816	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
191817	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
191818	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191819	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191820	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191821	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
191822	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	K0099	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
191823	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
191824	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
191825	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
191826	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
191827	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
191828	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
191829	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
191830	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
191831	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191832	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191833	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191834	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
191835	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
191836	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
191837	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
191838	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
191839	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
191840	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
191841	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
191842	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191843	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
191844	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
191845	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
191846	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
191847	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
191848	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
191849	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
191850	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
191851	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191852	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
191853	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
191854	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
191855	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
191856	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
191857	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
191858	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
191859	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191860	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191861	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191862	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
191863	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
191864	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
191865	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191866	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191867	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191868	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191869	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
191870	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
191871	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
191872	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
191873	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
191874	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
191875	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		
191876	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
191877	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	88	*F
191878	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
191879	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
191880	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
191881	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
191882	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
191883	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
191884	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
191885	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
191886	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
191887	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
191888	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
191889	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
191890	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
191891	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
191892	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
191893	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
191894	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191895	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191896	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191897	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
191898	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
191899	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
191900	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
191901	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
191902	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
191903	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
191904	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
191905	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	223	
191906	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	223	
191907	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
191908	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
191909	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
191910	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
191911	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
191912	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
191913	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	44	
191914	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	44	
191915	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
191916	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
191917	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
191918	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
191919	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
191920	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
191921	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
191922	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
191923	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
191924	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
191925	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
191926	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
191927	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
191928	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
191929	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
191930	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
191931	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
191932	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
191933	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
191934	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
191935	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
191936	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
191937	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
191938	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	0	°C
191939	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
191940	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
191941	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
191942	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
191943	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	temp unreadable	
191944	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
191945	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
191946	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
191947	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
191948	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
191949	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
191950	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
191951	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
191952	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
191953	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	0	
191954	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191955	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191956	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191957	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	63.0	
191958	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	61.0	
191959	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	65.0	
191960	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191961	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
191962	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
191963	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
191964	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
191965	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B Ø	0	
191966	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C Ø	0	
191967	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
191968	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
191969	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
191970	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
191971	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments		
191972	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
191973	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	188	
191974	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	188	
191975	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations This Read Vac	0	
191976	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
191977	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	0	
191978	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	0	
191979	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191980	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191981	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191982	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
191983	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
191984	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
191985	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
191986	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	171.0	
191987	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	174.0	
191988	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191989	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191990	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191991	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	0	
191992	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	0	
191993	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
191994	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
191995	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
191996	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
191997	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
191998	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
191999	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192000	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192001	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192002	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192003	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
192004	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
192005	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
192006	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
192007	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192008	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192009	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192010	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192011	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192012	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192013	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192014	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192015	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192016	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192017	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192018	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
192019	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192020	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments	Barbed wire needs attention	
192021	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192022	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
192023	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
192024	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
192025	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192026	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
192027	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
192028	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
192029	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
192030	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BCH000820	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
192031	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
192032	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
192033	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.7	VDC
192034	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
192035	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
192036	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
192037	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
192038	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
192039	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
192040	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
192041	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
192042	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
192043	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	BAT000833	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
192044	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192045	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192046	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
192047	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
192048	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
192049	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
192050	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
192051	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192052	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
192053	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192054	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
192055	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192056	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192057	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
192058	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
192059	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
192060	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
192061	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
192062	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
192063	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
192064	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
192065	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
192066	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
192067	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192068	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
192069	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192070	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192071	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
192072	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
192073	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
192074	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments	Station under construction, 2 yard lights out	
192075	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
192076	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
192077	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192078	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
192079	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
192080	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192081	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
192082	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
192083	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
192084	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
192085	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
192086	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
192087	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
192088	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
192089	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
192090	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
192091	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
192092	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
192093	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
192094	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
192095	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
192096	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
192097	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
192098	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
192099	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192100	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192101	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192102	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
192103	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
192104	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
192105	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
192106	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
192107	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192108	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
192109	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
192110	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192111	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
192112	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192113	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192114	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192115	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192116	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
192117	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
192118	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192119	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
192120	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
192121	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
192122	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
192123	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
192124	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
192125	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	89550	
192126	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
192127	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
192128	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
192129	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	162.0	
192130	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BCH000488	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
192131	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
192132	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
192133	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
192134	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
192135	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
192136	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1205.76	kw
192137	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
192138	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
192139	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	*C
192140	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192141	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
192142	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192143	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192144	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0169	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
192145	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192146	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192147	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192148	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
192149	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
192150	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
192151	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192152	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
192153	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
192154	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
192155	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
192156	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
192157	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	229	
192158	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	229	
192159	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
192160	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
192161	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
192162	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
192163	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
192164	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
192165	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
192166	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
192167	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
192168	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
192169	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
192170	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
192171	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
192172	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
192173	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
192174	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
192175	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	0	
192176	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
192177	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192178	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192179	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192180	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
192181	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
192182	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192183	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192184	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192185	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192186	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
192187	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
192188	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192189	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
192190	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
192191	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192192	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
192193	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
192194	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
192195	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	3835.20	kw
192196	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
192197	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
192198	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192199	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
192200	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192201	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192202	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
192203	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192204	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192205	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
192206	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
192207	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
192208	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.4794	
192209	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
192210	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
192211	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192212	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192213	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192214	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192215	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192216	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192217	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192218	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192219	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
192220	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192221	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments	Station under construction	
192222	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192223	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
192224	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
192225	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
192226	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192227	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192228	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
192229	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
192230	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192231	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
192232	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
192233	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192234	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192235	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
192236	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192237	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192238	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192239	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
192240	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
192241	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
192242	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
192243	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
192244	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
192245	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
192246	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
192247	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
192248	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	98	
192249	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	98	
192250	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
192251	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
192252	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
192253	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
192254	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
192255	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
192256	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
192257	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
192258	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
192259	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
192260	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
192261	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
192262	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
192263	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
192264	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
192265	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
192266	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
192267	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
192268	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
192269	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192270	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192271	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192272	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
192273	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
192274	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
192275	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
192276	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
192277	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
192278	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	0	
192279	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
192280	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
192281	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	0	
192282	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	49	
192283	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	49	
192284	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
192285	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
192286	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
192287	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
192288	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
192289	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
192290	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
192291	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
192292	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
192293	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192294	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192295	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
192296	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
192297	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
192298	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	181	
192299	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	181	
192300	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
192301	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192302	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments		
192303	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
192304	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
192305	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
192306	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
192307	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
192308	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
192309	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
192310	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
192311	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192312	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192313	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192314	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192315	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192316	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192317	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192318	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192319	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192320	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192321	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192322	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
192323	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192324	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
192325	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192326	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	94	*F
192327	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
192328	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
192329	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192330	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
192331	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192332	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192333	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
192334	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
192335	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
192336	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
192337	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
192338	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192339	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
192340	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192341	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
192342	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
192343	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
192344	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
192345	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
192346	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
192347	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
192348	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
192349	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
192350	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
192351	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
192352	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
192353	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
192354	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
192355	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
192356	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
192357	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
192358	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
192359	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
192360	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
192361	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
192362	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
192363	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	847.0	
192364	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	839.0	
192365	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	823.0	
192366	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192367	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9402	
192368	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
192369	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192370	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
192371	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
192372	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192373	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192374	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
192375	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192376	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	40	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192377	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
192378	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
192379	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
192380	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2256.48	kw
192381	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
192382	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
192383	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
192384	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
192385	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
192386	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
192387	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
192388	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
192389	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
192390	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
192391	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
192392	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
192393	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
192394	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
192395	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
192396	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
192397	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
192398	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
192399	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments		
192400	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
192401	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
192402	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
192403	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
192404	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
192405	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
192406	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
192407	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
192408	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
192409	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	
192410	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
192411	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
192412	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	
192413	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192414	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192415	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192416	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192417	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
192418	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
192419	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
192420	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192421	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192422	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
192423	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
192424	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
192425	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
192426	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
192427	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
192428	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
192429	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
192430	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
192431	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
192432	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
192433	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
192434	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
192435	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
192436	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
192437	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
192438	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
192439	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
192440	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
192441	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	0	
192442	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
192443	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
192444	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
192445	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
192446	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
192447	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	78	
192448	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	78	
192449	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
192450	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
192451	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
192452	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
192453	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
192454	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
192455	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
192456	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
192457	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
192458	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192459	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192460	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192461	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192462	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	165.0	
192463	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
192464	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
192465	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
192466	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
192467	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
192468	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192469	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192470	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
192471	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192472	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192473	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192474	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192475	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
192476	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
192477	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192478	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192479	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	868.0	
192480	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	887.0	
192481	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	895.0	
192482	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192483	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192484	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
192485	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	1	
192486	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192487	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
192488	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
192489	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
192490	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
192491	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
192492	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
192493	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	48	°C
192494	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192495	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
192496	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192497	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192498	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
192499	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
192500	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192501	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
192502	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
192503	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
192504	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
192505	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
192506	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
192507	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
192508	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
192509	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
192510	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments	2 4ft bulbs out	
192511	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
192512	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
192513	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
192514	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
192515	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
192516	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
192517	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
192518	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
192519	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
192520	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
192521	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
192522	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
192523	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
192524	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192525	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192526	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192527	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
192528	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
192529	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
192530	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
192531	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
192532	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	0	
192533	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
192534	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
192535	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
192536	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
192537	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
192538	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations This Read Vac	0	
192539	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	174	
192540	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	174	
192541	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
192542	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments		
192543	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
192544	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	123665	
192545	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	123665	
192546	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
192547	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	3L	
192548	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	5R	
192549	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	9L	
192550	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
192551	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
192552	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
192553	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
192554	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	1611	
192555	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
192556	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192557	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
192558	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
192559	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
192560	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		
192561	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
192562	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
192563	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.3	psi
192564	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
192565	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192566	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192567	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192568	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	56	
192569	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	56	
192570	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
192571	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
192572	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
192573	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192574	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
192575	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
192576	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
192577	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	60	°C
192578	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192579	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
192580	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192581	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192582	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
192583	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
192584	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192585	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	60	°C
192586	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
192587	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
192588	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
192589	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45898	
192590	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
192591	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
192592	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
192593	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
192594	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
192595	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
192596	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
192597	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
192598	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
192599	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
192600	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
192601	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192602	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
192603	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
192604	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
192605	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
192606	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
192607	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
192608	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
192609	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192610	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
192611	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192612	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
192613	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
192614	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
192615	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
192616	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
192617	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192618	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192619	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
192620	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192621	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
192622	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
192623	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
192624	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
192625	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
192626	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
192627	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
192628	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		
192629	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
192630	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
192631	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192632	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192633	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
192634	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
192635	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
192636	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192637	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192638	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192639	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192640	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
192641	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
192642	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
192643	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
192644	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
192645	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
192646	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
192647	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
192648	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
192649	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	69	
192650	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	69	
192651	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
192652	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
192653	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
192654	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192655	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
192656	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192657	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
192658	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192659	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192660	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192661	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192662	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192663	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192664	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192665	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	0	
192666	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
192667	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192668	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192669	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
192670	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
192671	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
192672	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192673	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192674	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192675	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192676	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192677	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
192678	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
192679	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
192680	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
192681	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
192682	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
192683	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
192684	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
192685	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	179	
192686	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	179	
192687	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
192688	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
192689	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
192690	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
192691	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192692	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192693	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192694	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
192695	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
192696	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192697	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
192698	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
192699	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
192700	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
192701	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
192702	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
192703	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
192704	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
192705	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
192706	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
192707	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
192708	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
192709	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
192710	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
192711	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
192712	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
192713	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
192714	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
192715	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
192716	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
192717	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
192718	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
192719	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
192720	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
192721	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	1	
192722	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
192723	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
192724	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
192725	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192726	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192727	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192728	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
192729	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
192730	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
192731	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
192732	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
192733	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
192734	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
192735	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
192736	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
192737	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
192738	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
192739	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
192740	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	4	
192741	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Bushing Dynamic Health	0.00	
192742	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
192743	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.8418	
192744	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
192745	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192746	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192747	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
192748	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192749	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192750	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
192751	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192752	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
192753	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
192754	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
192755	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
192756	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
192757	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
192758	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
192759	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192760	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
192761	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192762	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
192763	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192764	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192765	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192766	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192767	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
192768	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
192769	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
192770	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
192771	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
192772	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99946	
192773	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99946	
192774	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
192775	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
192776	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
192777	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
192778	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
192779	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
192780	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
192781	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
192782	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
192783	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192784	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192785	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
192786	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
192787	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
192788	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
192789	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192790	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
192791	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
192792	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
192793	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
192794	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	1	
192795	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	141	
192796	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	141	
192797	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
192798	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	0	
192799	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
192800	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
192801	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
192802	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
192803	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
192804	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192805	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
192806	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192807	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
192808	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
192809	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192810	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192811	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192812	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192813	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192814	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
192815	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192816	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
192817	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
192818	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192819	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
192820	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
192821	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
192822	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
192823	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
192824	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
192825	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	*C
192826	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	52	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192827	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192828	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
192829	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192830	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192831	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192832	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192833	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192834	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
192835	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
192836	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192837	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192838	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
192839	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192840	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192841	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
192842	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
192843	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	68	°C
192844	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	55	°C
192845	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	68	°C
192846	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	55	°C
192847	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	68	°C
192848	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	55	°C
192849	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
192850	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
192851	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
192852	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
192853	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
192854	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
192855	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
192856	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
192857	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
192858	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
192859	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
192860	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
192861	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
192862	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
192863	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
192864	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192865	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
192866	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
192867	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192868	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192869	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192870	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
192871	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
192872	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192873	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
192874	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
192875	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
192876	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
192877	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
192878	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
192879	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
192880	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	60	°C
192881	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192882	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
192883	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192884	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
192885	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192886	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192887	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
192888	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
192889	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
192890	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
192891	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
192892	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
192893	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
192894	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations B Ø	0	
192895	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations A Ø	0	
192896	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
192897	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
192898	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
192899	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
192900	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
192901	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192902	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
192903	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
192904	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
192905	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
192906	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
192907	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
192908	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
192909	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
192910	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
192911	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
192912	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
192913	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
192914	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
192915	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
192916	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
192917	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	143.0	
192918	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	147.0	
192919	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	150.0	
192920	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
192921	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
192922	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
192923	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	8	
192924	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
192925	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
192926	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations This Read Vac	0	
192927	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	95	
192928	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	95	
192929	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
192930	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments		
192931	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
192932	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
192933	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
192934	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
192935	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
192936	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
192937	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
192938	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
192939	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
192940	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
192941	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192942	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
192943	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192944	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192945	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
192946	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192947	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
192948	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
192949	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
192950	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
192951	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
192952	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
192953	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
192954	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192955	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
192956	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
192957	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192958	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
192959	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
192960	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192961	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
192962	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
192963	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
192964	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
192965	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192966	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
192967	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
192968	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	60	°C
192969	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
192970	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
192971	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	38400.00	kw
192972	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
192973	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
192974	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
192975	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
192976	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
192977	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
192978	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
192979	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
192980	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
192981	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
192982	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
192983	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
192984	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
192985	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
192986	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
192987	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
192988	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
192989	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
192990	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
192991	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
192992	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
192993	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
192994	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
192995	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
192996	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
192997	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
192998	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
192999	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
193000	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193001	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
193002	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
193003	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
193004	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
193005	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
193006	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments	Temp guage needs replaced.	
193007	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
193008	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193009	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
193010	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
193011	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193012	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
193013	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
193014	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193015	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
193016	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
193017	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
193018	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
193019	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
193020	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193021	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
193022	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
193023	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193024	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
193025	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
193026	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
193027	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
193028	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	577.44	kw
193029	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
193030	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
193031	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	45	°C
193032	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193033	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
193034	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	5408.64	kw
193035	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
193036	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
193037	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	70	°C
193038	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	44	°C
193039	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193040	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
193041	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193042	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193043	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
193044	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
193045	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193046	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
193047	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.5634	
193048	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
193049	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
193050	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
193051	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193052	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193053	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193054	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	0	
193055	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	0	
193056	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations This Read Vac	0	
193057	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	185	
193058	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	185	
193059	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
193060	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
193061	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
193062	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
193063	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
193064	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
193065	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193066	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193067	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
193068	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
193069	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193070	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
193071	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4812	
193072	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	
193073	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
193074	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
193075	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193076	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193077	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193078	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193079	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C Ø	136.0	
193080	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B Ø	139.0	
193081	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A Ø	141.0	
193082	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193083	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193084	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193085	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	0	
193086	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	0	
193087	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193088	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	0	
193089	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
193090	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
193091	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
193092	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
193093	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
193094	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
193095	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193096	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193097	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193098	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193099	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
193100	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
193101	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193102	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	80	*F
193103	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193104	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
193105	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
193106	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
193107	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	145	
193108	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	145	
193109	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
193110	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
193111	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
193112	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
193113	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
193114	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193115	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
193116	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
193117	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
193118	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193119	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193120	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
193121	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
193122	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193123	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193124	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	195.0	
193125	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	192.0	
193126	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	197.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193127	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193128	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193129	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193130	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	0	
193131	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
193132	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
193133	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
193134	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
193135	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
193136	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193137	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193138	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193139	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193140	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
193141	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
193142	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
193143	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193144	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193145	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
193146	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
193147	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
193148	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
193149	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193150	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	45	°C
193151	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
193152	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
193153	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
193154	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
193155	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
193156	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
193157	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
193158	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193159	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
193160	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
193161	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193162	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193163	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193164	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193165	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	C0171	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
193166	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193167	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
193168	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
193169	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193170	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
193171	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
193172	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193173	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
193174	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
193175	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
193176	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193177	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193178	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193179	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
193180	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
193181	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	220.0	
193182	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
193183	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
193184	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
193185	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
193186	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
193187	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
193188	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193189	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193190	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193191	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193192	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
193193	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
193194	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
193195	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
193196	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
193197	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
193198	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
193199	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
193200	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
193201	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193202	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
193203	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
193204	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
193205	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
193206	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1516	
193207	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
193208	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
193209	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
193210	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
193211	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
193212	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	365876	
193213	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	365876	
193214	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
193215	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
193216	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
193217	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
193218	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
193219	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	0	
193220	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
193221	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	181	
193222	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	181	
193223	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	0	
193224	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
193225	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
193226	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	0	
193227	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
193228	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193229	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193230	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193231	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193232	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
193233	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
193234	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193235	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
193236	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
193237	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
193238	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
193239	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2807.04	kw
193240	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
193241	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
193242	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
193243	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
193244	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	42	*C
193245	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193246	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
193247	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193248	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193249	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
193250	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
193251	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193252	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
193253	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.8772	
193254	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
193255	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
193256	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations This Read Vac	0	
193257	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	207	
193258	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
193259	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
193260	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193261	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193262	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
193263	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193264	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	54	*C
193265	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	66	*C
193266	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
193267	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
193268	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
193269	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	55	
193270	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	55	
193271	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	0	
193272	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
193273	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	0	
193274	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
193275	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
193276	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193277	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
193278	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
193279	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
193280	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	103235	
193281	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	103235	
193282	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
193283	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
193284	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
193285	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
193286	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
193287	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193288	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
193289	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
193290	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193291	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
193292	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
193293	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193294	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
193295	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
193296	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
193297	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
193298	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193299	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193300	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
193301	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
193302	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	14R	
193303	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	16R	
193304	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	5L	
193305	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
193306	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	70	°C
193307	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	58	°C
193308	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	3795	
193309	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
193310	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
193311	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
193312	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
193313	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
193314	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
193315	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
193316	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	41518	
193317	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
193318	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
193319	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
193320	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
193321	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
193322	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
193323	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	4	
193324	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193325	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193326	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193327	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	250.0	
193328	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	200.0	
193329	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
193330	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
193331	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
193332	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
193333	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
193334	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
193335	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
193336	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
193337	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
193338	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
193339	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
193340	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
193341	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
193342	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
193343	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
193344	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
193345	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193346	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193347	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
193348	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
193349	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
193350	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
193351	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193352	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193353	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
193354	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
193355	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193356	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
193357	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
193358	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193359	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
193360	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193361	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193362	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193363	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193364	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
193365	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
193366	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
193367	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193368	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193369	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193370	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	0	
193371	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
193372	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
193373	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
193374	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	14385.60	kw
193375	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
193376	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
193377	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	45	°C
193378	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	45	°C
193379	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193380	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
193381	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193382	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193383	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
193384	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
193385	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193386	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
193387	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.7992	
193388	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	40	°C
193389	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	40	°C
193390	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
193391	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
193392	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
193393	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
193394	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
193395	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	146	
193396	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	146	
193397	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
193398	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
193399	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
193400	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
193401	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
193402	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
193403	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
193404	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	0	
193405	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193406	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193407	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193408	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	124.0	
193409	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	133.0	
193410	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	148.0	
193411	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193412	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193413	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193414	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193415	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
193416	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
193417	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	207	
193418	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
193419	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments		
193420	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments		
193421	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
193422	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
193423	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	
193424	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
193425	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
193426	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193427	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193428	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193429	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193430	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193431	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
193432	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
193433	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
193434	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
193435	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
193436	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	1	
193437	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	198	
193438	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	198	
193439	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
193440	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	1	
193441	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
193442	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
193443	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
193444	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
193445	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
193446	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
193447	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
193448	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
193449	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
193450	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
193451	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
193452	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193453	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193454	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193455	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193456	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
193457	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
193458	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
193459	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
193460	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
193461	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
193462	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	20.0	
193463	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	20.0	
193464	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	20.0	
193465	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193466	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193467	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193468	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	2	
193469	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
193470	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
193471	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
193472	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
193473	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
193474	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
193475	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
193476	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
193477	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
193478	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	772	
193479	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	7L	
193480	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	2L	
193481	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	7L	
193482	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
193483	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	82918	
193484	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	82918	
193485	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
193486	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
193487	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
193488	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	80366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
193489	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
193490	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
193491	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
193492	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	169	
193493	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	169	
193494	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
193495	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
193496	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
193497	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	75	°C
193498	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
193499	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
193500	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	6060.96	kw
193501	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193502	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments	fans dont work	
193503	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments		
193504	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193505	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
193506	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
193507	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193508	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
193509	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
193510	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193511	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
193512	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
193513	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
193514	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
193515	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193516	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193517	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
193518	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
193519	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
193520	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
193521	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
193522	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
193523	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
193524	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
193525	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
193526	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments		
193527	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
193528	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
193529	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
193530	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
193531	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
193532	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
193533	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
193534	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
193535	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
193536	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
193537	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
193538	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
193539	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
193540	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
193541	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
193542	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
193543	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
193544	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
193545	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
193546	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
193547	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
193548	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
193549	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
193550	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
193551	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
193552	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
193553	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
193554	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
193555	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
193556	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
193557	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
193558	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
193559	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
193560	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
193561	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	82618	
193562	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
193563	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
193564	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
193565	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
193566	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
193567	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
193568	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
193569	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
193570	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
193571	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
193572	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
193573	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
193574	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	1	
193575	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193576	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193577	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
193578	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
193579	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
193580	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
193581	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
193582	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193583	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193584	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193585	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193586	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
193587	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
193588	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
193589	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
193590	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
193591	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
193592	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	630.0	
193593	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	640.0	
193594	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	630.0	
193595	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193596	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193597	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193598	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
193599	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
193600	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
193601	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
193602	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
193603	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
193604	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
193605	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
193606	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
193607	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
193608	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
193609	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
193610	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments	ok	
193611	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
193612	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
193613	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
193614	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
193615	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
193616	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
193617	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
193618	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
193619	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
193620	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
193621	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments	New Construction Begun	
193622	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
193623	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
193624	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
193625	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
193626	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
193627	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
193628	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
193629	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
193630	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
193631	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
193632	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
193633	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
193634	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
193635	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	theres an order to replace the drag hand cable	
193636	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	242406	
193637	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	242414	
193638	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
193639	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
193640	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
193641	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
193642	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	1092	
193643	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
193644	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
193645	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
193646	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
193647	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
193648	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
193649	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
193650	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
193651	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193652	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
193653	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
193654	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193655	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	54	°C
193656	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
193657	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
193658	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
193659	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	21	
193660	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193661	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193662	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193663	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	0.0	
193664	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	50.0	
193665	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	80.0	
193666	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
193667	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
193668	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
193669	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
193670	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
193671	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
193672	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193673	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	201.45	
193674	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	201.45	
193675	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	201.45	
193676	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
193677	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
193678	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
193679	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
193680	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
193681	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
193682	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
193683	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments		
193684	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments		
193685	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
193686	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
193687	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	2	
193688	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
193689	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	221	
193690	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	221	
193691	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	17	
193692	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
193693	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
193694	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
193695	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	15	
193696	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
193697	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
193698	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	4	
193699	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193700	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193701	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193702	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
193703	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
193704	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
193705	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
193706	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
193707	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
193708	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
193709	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
193710	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
193711	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193712	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193713	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193714	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193715	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
193716	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
193717	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
193718	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
193719	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
193720	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
193721	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
193722	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
193723	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
193724	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
193725	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
193726	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	57	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193727	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
193728	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	57	°C
193729	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
193730	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	57	°C
193731	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
193732	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
193733	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
193734	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
193735	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193736	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193737	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
193738	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
193739	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
193740	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193741	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193742	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193743	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193744	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
193745	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
193746	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
193747	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
193748	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
193749	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
193750	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments		
193751	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments	Actual counter	
193752	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
193753	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	149	
193754	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	149	
193755	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations This Read Vac	0	
193756	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
193757	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
193758	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
193759	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments	Fence grounds missing. R and K notified as off 10am on 8-19-19	
193760	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
193761	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
193762	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
193763	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
193764	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
193765	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
193766	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
193767	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
193768	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
193769	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
193770	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
193771	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
193772	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
193773	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
193774	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
193775	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
193776	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
193777	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
193778	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
193779	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
193780	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
193781	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
193782	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
193783	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
193784	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
193785	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
193786	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
193787	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
193788	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
193789	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
193790	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47003	
193791	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
193792	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
193793	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
193794	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
193795	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
193796	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
193797	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
193798	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
193799	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
193800	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
193801	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
193802	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
193803	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
193804	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
193805	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
193806	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
193807	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
193808	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
193809	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
193810	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
193811	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
193812	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
193813	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37380	
193814	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
193815	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
193816	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
193817	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
193818	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
193819	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
193820	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
193821	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
193822	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
193823	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
193824	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	188	
193825	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
193826	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
193827	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments		
193828	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
193829	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
193830	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
193831	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
193832	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
193833	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
193834	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
193835	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193836	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193837	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193838	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193839	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	860.0	
193840	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	873.0	
193841	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	883.0	
193842	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193843	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193844	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193845	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	0	
193846	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
193847	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
193848	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
193849	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
193850	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
193851	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
193852	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
193853	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
193854	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
193855	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
193856	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
193857	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
193858	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
193859	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
193860	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
193861	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
193862	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
193863	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193864	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	111.0	
193865	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	112.0	
193866	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	115.0	
193867	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
193868	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
193869	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	2.69	%
193870	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	0	
193871	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
193872	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
193873	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
193874	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
193875	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
193876	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193877	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
193878	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
193879	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
193880	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
193881	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
193882	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
193883	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
193884	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
193885	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	16.19	
193886	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	0	
193887	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193888	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193889	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193890	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	96.0	
193891	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	75.0	
193892	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	81.0	
193893	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
193894	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
193895	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
193896	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
193897	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
193898	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
193899	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations	0	
193900	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
193901	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
193902	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
193903	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
193904	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
193905	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
193906	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
193907	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
193908	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
193909	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
193910	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
193911	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
193912	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
193913	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
193914	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
193915	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
193916	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
193917	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
193918	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
193919	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
193920	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
193921	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
193922	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
193923	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
193924	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
193925	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
193926	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
193927	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
193928	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	1	
193929	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
193930	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
193931	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
193932	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
193933	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
193934	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
193935	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
193936	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
193937	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
193938	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
193939	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
193940	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	16.19	
193941	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
193942	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
193943	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
193944	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
193945	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
193946	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
193947	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
193948	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
193949	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
193950	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
193951	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
193952	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
193953	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	10R	
193954	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
193955	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
193956	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
193957	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
193958	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	151499	
193959	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
193960	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
193961	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
193962	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
193963	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
193964	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
193965	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
193966	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
193967	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
193968	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
193969	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
193970	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
193971	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
193972	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
193973	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
193974	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
193975	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
193976	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	29	
193977	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
193978	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
193979	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
193980	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
193981	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000266	LTCControl	799-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
193982	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
193983	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
193984	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
193985	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
193986	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
193987	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
193988	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
193989	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
193990	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
193991	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	145.0	
193992	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	91.0	
193993	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	93.0	
193994	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
193995	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
193996	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
193997	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
193998	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
193999	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
194000	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
194001	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
194002	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
194003	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
194004	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
194005	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
194006	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
194007	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	336	
194008	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194009	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194010	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
194011	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
194012	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
194013	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
194014	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
194015	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194016	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
194017	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
194018	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
194019	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
194020	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
194021	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
194022	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
194023	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
194024	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC0000206	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
194025	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194026	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194027	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194028	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
194029	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194030	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194031	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194032	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194033	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
194034	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
194035	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
194036	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
194037	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194038	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
194039	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
194040	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
194041	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
194042	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194043	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
194044	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
194045	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
194046	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	85486	
194047	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194048	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
194049	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1227	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
194050	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
194051	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194052	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194053	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194054	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194055	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194056	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
194057	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
194058	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
194059	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
194060	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194061	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
194062	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments		
194063	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments		
194064	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
194065	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	107	
194066	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	107	
194067	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations This Read Vac	0	
194068	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
194069	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
194070	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194071	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194072	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194073	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194074	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194075	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
194076	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
194077	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	40.0	
194078	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	20.0	
194079	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	20.0	
194080	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194081	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194082	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194083	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	6	
194084	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
194085	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	0	
194086	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194087	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194088	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194089	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
194090	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
194091	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
194092	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194093	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194094	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194095	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194096	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
194097	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
194098	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
194099	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
194100	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
194101	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194102	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments		
194103	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments		
194104	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
194105	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	158	
194106	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	158	
194107	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations This Read Vac	0	
194108	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
194109	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
194110	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
194111	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
194112	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	141.0	
194113	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	130.0	
194114	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	129.0	
194115	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
194116	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
194117	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
194118	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
194119	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
194120	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
194121	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
194122	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
194123	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
194124	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
194125	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
194126	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
194127	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
194128	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
194129	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194130	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194131	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
194132	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
194133	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194134	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194135	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
194136	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
194137	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
194138	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
194139	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
194140	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
194141	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
194142	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
194143	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
194144	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
194145	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	125	
194146	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194147	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194148	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194149	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
194150	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
194151	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
194152	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
194153	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
194154	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194155	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194156	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194157	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	2	
194158	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
194159	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
194160	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
194161	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
194162	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
194163	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
194164	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
194165	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
194166	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	4	
194167	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
194168	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
194169	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	5	
194170	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	168	
194171	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	168	
194172	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	0	
194173	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194174	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194175	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194176	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	123.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
194177	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	122.0	
194178	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	118.0	
194179	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194180	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194181	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194182	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194183	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
194184	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
194185	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
194186	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
194187	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
194188	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
194189	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
194190	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
194191	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
194192	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	128	
194193	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	128	
194194	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
194195	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
194196	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
194197	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
194198	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	1	
194199	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
194200	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
194201	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
194202	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
194203	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
194204	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
194205	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
194206	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
194207	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
194208	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
194209	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
194210	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	64.76	
194211	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	64.76	
194212	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	150.0	
194213	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
194214	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	130.0	
194215	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
194216	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
194217	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194218	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194219	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194220	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194221	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194222	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194223	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194224	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194225	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
194226	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
194227	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
194228	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
194229	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
194230	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
194231	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
194232	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
194233	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
194234	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
194235	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
194236	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
194237	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
194238	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	209	
194239	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	209	
194240	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
194241	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	9	
194242	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
194243	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
194244	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	4.27	%
194245	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	220.0	
194246	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	210.0	
194247	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	230.0	
194248	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
194249	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
194250	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
194251	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194252	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
194253	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
194254	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
194255	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
194256	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
194257	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
194258	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
194259	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
194260	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
194261	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
194262	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99961	
194263	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99961	
194264	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	1	
194265	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	1	
194266	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
194267	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
194268	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
194269	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
194270	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
194271	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
194272	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	1	
194273	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	1	
194274	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	264	
194275	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	263	
194276	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
194277	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
194278	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
194279	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
194280	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
194281	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
194282	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
194283	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
194284	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
194285	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
194286	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
194287	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
194288	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
194289	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194290	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194291	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194292	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
194293	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194294	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194295	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194296	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194297	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194298	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194299	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194300	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
194301	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
194302	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
194303	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
194304	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	General Comments		
194305	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
194306	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
194307	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
194308	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
194309	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
194310	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194311	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
194312	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
194313	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
194314	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
194315	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
194316	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
194317	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
194318	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
194319	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	4	
194320	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
194321	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
194322	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
194323	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194324	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194325	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
194326	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194327	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
194328	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
194329	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	190.0	
194330	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	195.0	
194331	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
194332	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
194333	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
194334	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
194335	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
194336	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194337	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
194338	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
194339	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
194340	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
194341	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194342	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194343	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194344	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194345	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
194346	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
194347	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
194348	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
194349	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	89	
194350	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	1	
194351	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
194352	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
194353	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	2	
194354	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	210	
194355	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	210	
194356	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	89	
194357	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
194358	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
194359	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
194360	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
194361	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
194362	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
194363	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
194364	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
194365	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
194366	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194367	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194368	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194369	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194370	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
194371	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	64.76	
194372	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194373	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194374	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194375	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194376	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194377	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
194378	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
194379	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	50.0	
194380	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	40.0	
194381	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	50.0	
194382	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194383	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194384	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194385	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	5	
194386	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
194387	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
194388	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
194389	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
194390	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	783	
194391	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	57	°C
194392	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	3L	
194393	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6R	
194394	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	2R	
194395	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
194396	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	25186	
194397	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
194398	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
194399	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
194400	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	0	
194401	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194402	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	0	
194403	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	482	
194404	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194405	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194406	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194407	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	482	
194408	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
194409	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
194410	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
194411	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments	open	
194412	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
194413	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
194414	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194415	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
194416	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
194417	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
194418	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
194419	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194420	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
194421	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
194422	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
194423	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
194424	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194425	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
194426	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
194427	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	206888	
194428	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194429	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
194430	9/16/2019 10:25	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
194431	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
194432	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
194433	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
194434	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
194435	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
194436	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194437	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	296705	
194438	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
194439	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
194440	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
194441	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194442	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
194443	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
194444	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
194445	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	25186	
194446	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
194447	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	121	
194448	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
194449	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	
194450	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
194451	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
194452	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
194453	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
194454	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	0	
194455	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194456	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194457	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194458	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
194459	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
194460	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
194461	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194462	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194463	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194464	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194465	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
194466	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
194467	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
194468	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
194469	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
194470	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
194471	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments		
194472	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments		
194473	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
194474	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	149	
194475	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	149	
194476	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
194477	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
194478	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
194479	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
194480	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Unknown Operations	0	
194481	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	0	
194482	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194483	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194484	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194485	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
194486	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
194487	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
194488	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194489	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194490	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194491	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194492	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
194493	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
194494	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
194495	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
194496	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
194497	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
194498	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
194499	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
194500	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
194501	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	150	
194502	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	150	
194503	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
194504	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
194505	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
194506	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Switching Operations	0	
194507	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations This Read Vac	0	
194508	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AL	171	
194509	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AF	171	
194510	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Maintenance Operations	0	
194511	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	General Comments		
194512	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	General Comments		
194513	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Follow-up Action Required?	n	
194514	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194515	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations Ground	0	
194516	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations C Ø	0	
194517	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
194518	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
194519	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
194520	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
194521	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
194522	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
194523	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
194524	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
194525	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments	Broken Insulator Bypass center phase x0081	
194526	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
194527	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
194528	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
194529	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
194530	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
194531	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
194532	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194533	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194534	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194535	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194536	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
194537	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
194538	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
194539	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
194540	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
194541	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds In Place?	y	
194542	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
194543	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
194544	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
194545	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
194546	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
194547	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
194548	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
194549	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
194550	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
194551	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194552	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
194553	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
194554	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	11	
194555	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
194556	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
194557	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
194558	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
194559	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
194560	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
194561	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
194562	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
194563	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
194564	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
194565	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	0.0	
194566	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	0.0	
194567	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	0.0	
194568	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194569	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194570	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194571	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194572	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
194573	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
194574	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
194575	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
194576	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194577	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
194578	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
194579	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
194580	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
194581	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	85	
194582	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	85	
194583	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	0	
194584	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
194585	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
194586	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
194587	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
194588	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
194589	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
194590	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
194591	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
194592	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
194593	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
194594	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
194595	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
194596	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
194597	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
194598	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194599	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
194600	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
194601	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
194602	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
194603	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194604	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
194605	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
194606	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
194607	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
194608	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	63135	
194609	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194610	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194611	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194612	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194613	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	0.0	
194614	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	0.0	
194615	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	0.0	
194616	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194617	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194618	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194619	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194620	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	
194621	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
194622	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
194623	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	
194624	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
194625	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
194626	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194627	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
194628	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
194629	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
194630	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
194631	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	0	
194632	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
194633	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
194634	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
194635	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments		
194636	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
194637	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	175	
194638	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	175	
194639	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
194640	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations This Read Vac	0	
194641	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	111	
194642	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	111	
194643	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
194644	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments		
194645	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments		
194646	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
194647	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194648	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
194649	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
194650	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
194651	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
194652	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
194653	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
194654	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
194655	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
194656	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
194657	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
194658	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
194659	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
194660	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
194661	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	98	*F
194662	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	
194663	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
194664	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
194665	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
194666	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194667	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194668	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194669	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194670	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	133.0	
194671	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	136.0	
194672	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	137.0	
194673	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations This Read Vac	0	
194674	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194675	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	*C
194676	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	*C
194677	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	*C
194678	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	85	*C
194679	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	55	*C
194680	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	*C
194681	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
194682	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
194683	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
194684	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194685	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194686	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	3	
194687	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
194688	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
194689	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
194690	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
194691	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
194692	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
194693	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
194694	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
194695	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
194696	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTC000266	LTCControl	799-2	LTC Control Insp	General Comments		
194697	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
194698	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
194699	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
194700	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
194701	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	4282	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194702	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	4286	
194703	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
194704	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	4R	
194705	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	4R	
194706	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
194707	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	1249	
194708	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
194709	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
194710	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
194711	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
194712	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
194713	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
194714	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
194715	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194716	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194717	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194718	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
194719	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments		
194720	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
194721	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
194722	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
194723	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194724	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194725	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194726	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194727	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
194728	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
194729	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
194730	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
194731	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
194732	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
194733	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
194734	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
194735	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
194736	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	48.0000	
194737	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
194738	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
194739	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
194740	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
194741	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
194742	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
194743	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
194744	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
194745	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
194746	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
194747	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
194748	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
194749	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
194750	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
194751	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
194752	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
194753	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
194754	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
194755	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
194756	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
194757	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
194758	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
194759	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
194760	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
194761	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
194762	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
194763	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
194764	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
194765	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
194766	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
194767	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
194768	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	0	
194769	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194770	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194771	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194772	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194773	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194774	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
194775	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
194776	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
194777	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
194778	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
194779	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
194780	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		
194781	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
194782	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
194783	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194784	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194785	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194786	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194787	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194788	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194789	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194790	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194791	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194792	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194793	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194794	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194795	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194796	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194797	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194798	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194799	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	196	
194800	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
194801	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
194802	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
194803	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
194804	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Amps A Ø	30.0	
194805	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Amps B Ø	40.0	
194806	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Amps C Ø	50.0	
194807	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
194808	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
194809	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
194810	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
194811	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194812	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194813	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194814	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194815	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Operations A Ø	0	
194816	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Operations B Ø	0	
194817	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Operations C Ø	0	
194818	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Fault Operations Ground	0	
194819	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194820	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Readings	Follow-up Action Required?	n	
194821	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	Foundation Condition	Good	
194822	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	Pi-4	VCB Patrol Inspection	General Comments		
194823	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194824	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194825	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194826	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	3	
194827	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
194828	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
194829	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
194830	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	153.0	
194831	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	150.0	
194832	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	146.0	
194833	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194834	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194835	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194836	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194837	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
194838	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
194839	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
194840	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
194841	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
194842	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
194843	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
194844	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
194845	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
194846	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	279	
194847	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	279	
194848	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194849	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194850	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
194851	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
194852	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
194853	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
194854	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194855	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
194856	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
194857	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
194858	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
194859	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194860	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
194861	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
194862	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
194863	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	62745	
194864	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194865	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
194866	9/16/2019 8:52	Distribution	Beech Creek Quarterly Inspection	R1228	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
194867	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
194868	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
194869	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
194870	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
194871	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
194872	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
194873	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
194874	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
194875	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
194876	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
194877	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
194878	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
194879	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
194880	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
194881	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
194882	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
194883	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
194884	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
194885	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
194886	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43411	
194887	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
194888	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
194889	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
194890	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
194891	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
194892	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
194893	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	97.0	
194894	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
194895	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	100.0	
194896	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
194897	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
194898	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
194899	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
194900	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
194901	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194902	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194903	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194904	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194905	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
194906	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194907	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
194908	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194909	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194910	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194911	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194912	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194913	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194914	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194915	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
194916	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194917	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194918	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194919	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194920	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194921	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194922	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194923	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194924	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194925	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194926	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
194927	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194928	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
194929	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
194930	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
194931	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
194932	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
194933	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
194934	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
194935	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
194936	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
194937	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
194938	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
194939	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
194940	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
194941	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
194942	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
194943	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
194944	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
194945	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
194946	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
194947	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
194948	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
194949	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
194950	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
194951	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
194952	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
194953	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
194954	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5662.08	kw
194955	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
194956	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
194957	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
194958	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
194959	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
194960	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
194961	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
194962	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
194963	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
194964	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
194965	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
194966	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
194967	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
194968	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
194969	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
194970	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
194971	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
194972	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
194973	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
194974	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
194975	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
194976	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	0	
194977	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
194978	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
194979	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
194980	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
194981	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
194982	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
194983	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
194984	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
194985	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
194986	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
194987	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
194988	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
194989	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
194990	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
194991	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
194992	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194993	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
194994	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
194995	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
194996	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
194997	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
194998	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
194999	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
195000	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	52	
195001	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	52	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195002	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
195003	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
195004	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
195005	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
195006	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
195007	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	0	
195008	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	0	
195009	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
195010	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
195011	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
195012	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
195013	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
195014	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
195015	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
195016	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
195017	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
195018	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
195019	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
195020	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
195021	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
195022	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
195023	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
195024	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
195025	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
195026	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
195027	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
195028	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
195029	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
195030	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
195031	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
195032	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
195033	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
195034	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
195035	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
195036	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
195037	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
195038	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
195039	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
195040	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
195041	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
195042	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
195043	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
195044	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
195045	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
195046	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
195047	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
195048	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
195049	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
195050	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
195051	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
195052	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
195053	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
195054	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
195055	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
195056	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
195057	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
195058	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
195059	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46060	
195060	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
195061	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
195062	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
195063	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
195064	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
195065	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195066	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
195067	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
195068	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	40	
195069	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	40	
195070	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
195071	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
195072	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
195073	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
195074	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
195075	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
195076	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195077	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
195078	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
195079	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
195080	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
195081	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
195082	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
195083	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	CAPO00069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
195084	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	40	*C
195085	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	52	*C
195086	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5898	
195087	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	5	
195088	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	9	
195089	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	81	
195090	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
195091	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
195092	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
195093	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
195094	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
195095	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Present	0	*C
195096	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Winding Temp Max	0	*C
195097	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.8052	
195098	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
195099	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Present	55	*C
195100	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
195101	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
195102	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	4	
195103	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195104	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195105	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195106	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	125.0	
195107	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	165.0	
195108	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	150.0	
195109	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
195110	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195111	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195112	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195113	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195114	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195115	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195116	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195117	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195118	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195119	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
195120	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
195121	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
195122	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
195123	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
195124	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
195125	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
195126	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
195127	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
195128	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
195129	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
195130	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Top Oil Temperature Max	65	*C
195131	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
195132	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
195133	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
195134	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
195135	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
195136	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
195137	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
195138	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
195139	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
195140	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	110	
195141	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	112	
195142	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	2	
195143	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	2	
195144	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
195145	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
195146	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
195147	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
195148	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
195149	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
195150	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	98	*F
195151	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195152	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
195153	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
195154	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
195155	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
195156	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195157	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
195158	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
195159	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	247	
195160	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	148	
195161	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	1	
195162	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	1	
195163	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
195164	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
195165	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
195166	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	0	
195167	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations This Read Vac	0	
195168	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	95	
195169	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	95	
195170	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
195171	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments		
195172	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments		
195173	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
195174	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
195175	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
195176	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
195177	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
195178	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
195179	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195180	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195181	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195182	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195183	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	170.0	
195184	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	172.0	
195185	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	179.0	
195186	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195187	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195188	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195189	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	2	
195190	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
195191	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	227	
195192	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	227	
195193	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
195194	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
195195	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
195196	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
195197	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
195198	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
195199	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
195200	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
195201	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	81	
195202	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
195203	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
195204	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	5	
195205	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
195206	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
195207	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
195208	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195209	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195210	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195211	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195212	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	82.0	
195213	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	79.0	
195214	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	83.0	
195215	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195216	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
195217	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	4.48	%
195218	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	5	
195219	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
195220	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
195221	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
195222	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
195223	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195224	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195225	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195226	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195227	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
195228	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
195229	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
195230	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
195231	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	
195232	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
195233	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
195234	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		
195235	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
195236	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	87	
195237	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	87	
195238	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
195239	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
195240	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
195241	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195242	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	0	
195243	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	9	
195244	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195245	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195246	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	3	
195247	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195248	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195249	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195250	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	97.0	
195251	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	112.0	
195252	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	130.0	
195253	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
195254	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195255	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195256	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195257	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195258	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195259	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195260	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195261	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195262	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195263	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
195264	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	0	
195265	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195266	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	360.0	
195267	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	450.0	
195268	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	440.0	
195269	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
195270	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	408	
195271	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	403	
195272	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195273	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195274	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195275	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195276	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195277	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195278	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195279	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195280	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195281	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	250.0	
195282	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	260.0	
195283	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	230.0	
195284	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
195285	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195286	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
195287	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
195288	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
195289	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
195290	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
195291	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
195292	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
195293	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	7729.92	kw
195294	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
195295	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
195296	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
195297	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
195298	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
195299	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
195300	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
195301	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195302	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
195303	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
195304	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
195305	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
195306	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
195307	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
195308	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
195309	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
195310	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
195311	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
195312	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
195313	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
195314	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
195315	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
195316	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
195317	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
195318	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations B Ø	0	
195319	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations A Ø	0	
195320	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195321	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195322	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195323	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195324	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	72.0	
195325	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps B Ø	72.0	
195326	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps A Ø	73.0	
195327	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
195328	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
195329	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
195330	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
195331	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
195332	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
195333	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
195334	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
195335	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments		
195336	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
195337	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195338	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	0	
195339	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
195340	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	190	
195341	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	190	
195342	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	4	
195343	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
195344	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
195345	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
195346	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	4	
195347	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195348	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195349	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	0	
195350	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195351	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195352	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195353	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC0000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
195354	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC0000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
195355	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC0000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
195356	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
195357	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
195358	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
195359	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
195360	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
195361	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
195362	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
195363	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
195364	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
195365	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	10	
195366	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195367	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BK0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195368	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
195369	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
195370	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
195371	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8268	
195372	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
195373	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
195374	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
195375	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
195376	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
195377	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195378	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	189.0	
195379	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	188.0	
195380	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	191.0	
195381	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195382	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195383	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	0	
195384	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195385	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195386	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195387	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
195388	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
195389	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
195390	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195391	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195392	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195393	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195394	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
195395	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
195396	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
195397	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
195398	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195399	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	0	
195400	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
195401	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
195402	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
195403	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
195404	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
195405	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	125	
195406	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	125	
195407	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
195408	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
195409	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
195410	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195411	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	343.0	
195412	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195413	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	0	
195414	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
195415	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	0	
195416	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195417	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	0	
195418	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	355.0	
195419	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations B Ø	0	
195420	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations A Ø	0	
195421	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195422	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195423	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195424	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195425	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps C Ø	0.0	
195426	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps B Ø	0.0	
195427	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps A Ø	0.0	
195428	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195429	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195430	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195431	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations	0	
195432	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
195433	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
195434	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
195435	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	
195436	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
195437	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
195438	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195439	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195440	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
195441	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
195442	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
195443	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
195444	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195445	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195446	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195447	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
195448	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
195449	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
195450	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
195451	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195452	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
195453	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
195454	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
195455	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
195456	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.7	VDC
195457	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.6	VDC
195458	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
195459	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
195460	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
195461	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
195462	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
195463	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
195464	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
195465	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
195466	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
195467	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
195468	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
195469	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
195470	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
195471	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
195472	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
195473	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
195474	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
195475	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
195476	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
195477	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195478	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
195479	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
195480	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
195481	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195482	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
195483	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
195484	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
195485	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
195486	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
195487	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
195488	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
195489	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
195490	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
195491	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
195492	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
195493	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
195494	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
195495	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
195496	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
195497	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
195498	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
195499	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
195500	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
195501	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	All Connections OK?	y	
195502	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
195503	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	General Comments		
195504	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
195505	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
195506	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
195507	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
195508	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
195509	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	All Connections OK?	y	
195510	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
195511	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	General Comments		
195512	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
195513	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
195514	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
195515	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
195516	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
195517	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	348.0	
195518	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
195519	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195520	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195521	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195522	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195523	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195524	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195525	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
195526	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195527	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195528	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
195529	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195530	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195531	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195532	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
195533	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
195534	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
195535	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
195536	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments		
195537	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
195538	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
195539	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
195540	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	General Comments		
195541	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
195542	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
195543	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
195544	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
195545	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	LTC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
195546	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
195547	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
195548	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
195549	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
195550	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
195551	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
195552	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
195553	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
195554	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
195555	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
195556	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
195557	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
195558	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
195559	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
195560	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
195561	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
195562	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
195563	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
195564	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
195565	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
195566	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
195567	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
195568	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
195569	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
195570	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
195571	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7887	
195572	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
195573	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
195574	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
195575	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
195576	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
195577	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
195578	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
195579	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
195580	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
195581	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
195582	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
195583	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
195584	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
195585	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
195586	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
195587	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
195588	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
195589	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
195590	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
195591	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
195592	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
195593	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
195594	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
195595	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7340	
195596	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
195597	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
195598	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
195599	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
195600	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
195601	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.5964	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195602	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
195603	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
195604	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
195605	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
195606	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
195607	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
195608	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
195609	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
195610	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	55	°C
195611	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
195612	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
195613	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
195614	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	5725.44	kw
195615	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
195616	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments		
195617	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
195618	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
195619	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	167	
195620	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	1	
195621	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	0	
195622	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
195623	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
195624	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195625	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195626	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
195627	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
195628	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
195629	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195630	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
195631	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
195632	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	175	
195633	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	176	
195634	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	1	
195635	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	1	
195636	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
195637	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
195638	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195639	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195640	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195641	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
195642	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
195643	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
195644	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
195645	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195646	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195647	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195648	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195649	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
195650	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
195651	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	1	
195652	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	1	
195653	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	264	
195654	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	263	
195655	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
195656	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
195657	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195658	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
195659	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
195660	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
195661	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
195662	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
195663	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
195664	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
195665	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
195666	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
195667	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
195668	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195669	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195670	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195671	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195672	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195673	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195674	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195675	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195676	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
195677	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
195678	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	505.0	
195679	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	511.0	
195680	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	490.0	
195681	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195682	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195683	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195684	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	2	
195685	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
195686	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
195687	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
195688	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
195689	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
195690	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
195691	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
195692	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
195693	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
195694	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
195695	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
195696	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
195697	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
195698	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
195699	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
195700	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	2	
195701	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195702	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195703	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195704	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps Ø	38.0	
195705	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	46.0	
195706	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	48.0	
195707	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
195708	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195709	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195710	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195711	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195712	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195713	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195714	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	190.0	
195715	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	185.0	
195716	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	185.0	
195717	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195718	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195719	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195720	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195721	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	
195722	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	
195723	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195724	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
195725	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195726	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
195727	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	143	
195728	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	143	
195729	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
195730	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
195731	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
195732	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
195733	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
195734	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
195735	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
195736	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
195737	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
195738	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195739	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	1	
195740	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
195741	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
195742	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
195743	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
195744	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
195745	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
195746	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
195747	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
195748	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
195749	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
195750	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
195751	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	167	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195752	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
195753	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
195754	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
195755	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
195756	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
195757	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
195758	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	1	
195759	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195760	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195761	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195762	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	150.0	
195763	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	110.0	
195764	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	150.0	
195765	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
195766	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195767	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195768	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195769	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195770	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
195771	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
195772	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	84.0	
195773	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	131.0	
195774	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	218	
195775	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
195776	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
195777	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195778	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
195779	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
195780	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195781	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195782	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195783	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195784	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195785	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
195786	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
195787	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
195788	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
195789	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
195790	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
195791	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
195792	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
195793	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
195794	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
195795	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
195796	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
195797	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
195798	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
195799	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
195800	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
195801	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
195802	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
195803	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
195804	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
195805	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	11.0	VDC
195806	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	13.0	VDC
195807	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
195808	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
195809	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
195810	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
195811	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
195812	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	119	
195813	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	119	
195814	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
195815	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
195816	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
195817	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
195818	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
195819	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
195820	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
195821	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	28.94	%
195822	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	28.94	%
195823	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	28.94	%
195824	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	0	
195825	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
195826	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195827	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195828	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195829	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195830	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195831	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.63	
195832	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
195833	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
195834	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
195835	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
195836	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	1657	
195837	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	5L	
195838	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	11R	
195839	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	5R	
195840	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
195841	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	9882	
195842	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	161	
195843	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
195844	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
195845	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
195846	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
195847	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
195848	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
195849	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	9870	
195850	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
195851	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
195852	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
195853	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
195854	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
195855	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
195856	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195857	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195858	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195859	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195860	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
195861	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
195862	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
195863	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195864	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195865	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195866	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	0	
195867	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
195868	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
195869	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	85.0	
195870	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
195871	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
195872	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
195873	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
195874	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
195875	9/16/2019 9:57	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	218	
195876	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
195877	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
195878	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
195879	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	159	
195880	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
195881	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
195882	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
195883	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
195884	9/16/2019 10:48	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
195885	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195886	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195887	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195888	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
195889	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
195890	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
195891	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	2	
195892	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195893	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195894	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
195895	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	127.0	
195896	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	147.0	
195897	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	143.0	
195898	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
195899	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195900	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195901	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195902	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195903	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	0	
195904	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195905	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195906	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195907	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195908	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195909	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195910	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195911	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
195912	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
195913	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
195914	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
195915	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
195916	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
195917	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
195918	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
195919	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
195920	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
195921	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195922	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	1	
195923	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
195924	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	186	
195925	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	186	
195926	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	1	
195927	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
195928	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
195929	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
195930	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
195931	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
195932	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195933	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195934	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195935	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195936	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195937	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195938	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
195939	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
195940	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
195941	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
195942	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
195943	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
195944	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
195945	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
195946	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
195947	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
195948	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
195949	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
195950	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
195951	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
195952	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
195953	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
195954	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195955	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
195956	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
195957	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
195958	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
195959	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
195960	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
195961	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	0	
195962	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
195963	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
195964	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
195965	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
195966	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
195967	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195968	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
195969	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
195970	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
195971	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
195972	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
195973	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
195974	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
195975	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
195976	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
195977	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
195978	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
195979	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
195980	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
195981	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
195982	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
195983	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
195984	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments		
195985	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
195986	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
195987	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	0	
195988	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
195989	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	183	
195990	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	183	
195991	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	0	
195992	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
195993	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
195994	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
195995	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
195996	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	1	
195997	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
195998	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
195999	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196000	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	36.0	
196001	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	59.0	
196002	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	63.0	
196003	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196004	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196005	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196006	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196007	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196008	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196009	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
196010	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
196011	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
196012	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
196013	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
196014	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
196015	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
196016	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
196017	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
196018	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
196019	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196020	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
196021	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
196022	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
196023	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
196024	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
196025	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
196026	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	192	
196027	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	196	
196028	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	4	
196029	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
196030	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	4	
196031	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
196032	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
196033	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	0	
196034	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196035	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196036	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196037	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	784.0	
196038	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	773.0	
196039	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	767.0	
196040	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196041	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196042	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196043	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196044	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
196045	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
196046	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
196047	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
196048	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
196049	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
196050	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
196051	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196052	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
196053	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	3	
196054	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	3	
196055	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
196056	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
196057	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
196058	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	27.0	
196059	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	14.0	
196060	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	23.0	
196061	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
196062	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196063	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196064	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196065	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196066	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196067	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196068	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196069	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196070	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196071	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
196072	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
196073	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
196074	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	2	
196075	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
196076	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
196077	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
196078	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
196079	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	148	
196080	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	144	
196081	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
196082	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
196083	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
196084	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
196085	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
196086	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
196087	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	166	
196088	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	167	
196089	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	1	
196090	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	1	
196091	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
196092	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
196093	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
196094	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
196095	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
196096	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
196097	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	171	
196098	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	175	
196099	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	4	
196100	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
196101	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	4	
196102	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
196103	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
196104	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	2	
196105	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196106	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196107	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196108	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196109	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196110	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196111	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196112	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196113	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196114	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
196115	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	50.0	
196116	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	50.0	
196117	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	50.0	
196118	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196119	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196120	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196121	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	9	
196122	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
196123	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
196124	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
196125	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
196126	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
196127	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
196128	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
196129	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
196130	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
196131	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
196132	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
196133	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
196134	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
196135	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
196136	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196137	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196138	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
196139	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
196140	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
196141	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196142	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
196143	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2018-03-08 00:00:00.000000	
196144	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196145	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
196146	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196147	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196148	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196149	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196150	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
196151	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
196152	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
196153	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
196154	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
196155	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
196156	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196157	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196158	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	250.0	
196159	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	257.0	
196160	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	249.0	
196161	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196162	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196163	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196164	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196165	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
196166	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
196167	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
196168	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
196169	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196170	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
196171	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
196172	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
196173	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
196174	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
196175	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
196176	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
196177	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
196178	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
196179	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
196180	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	General Comments		
196181	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
196182	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
196183	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
196184	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
196185	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
196186	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
196187	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
196188	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
196189	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
196190	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
196191	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
196192	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
196193	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
196194	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Unknown Operations	0	
196195	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Switching Operations	0	
196196	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations This Read Vac	0	
196197	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AL	191	
196198	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AF	191	
196199	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Maintenance Operations	0	
196200	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments		
196201	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196202	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	0	
196203	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	208	
196204	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	208	
196205	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
196206	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
196207	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
196208	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
196209	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
196210	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
196211	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
196212	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
196213	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196214	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
196215	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
196216	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
196217	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
196218	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196219	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196220	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196221	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196222	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196223	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196224	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196225	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196226	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196227	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
196228	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	857.0	
196229	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	874.0	
196230	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	867.0	
196231	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196232	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196233	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196234	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	0	
196235	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
196236	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
196237	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
196238	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
196239	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
196240	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
196241	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
196242	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
196243	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
196244	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
196245	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	0	
196246	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196247	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
196248	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
196249	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
196250	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
196251	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
196252	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
196253	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196254	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196255	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196256	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196257	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
196258	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
196259	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
196260	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
196261	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
196262	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
196263	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
196264	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
196265	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
196266	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
196267	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196268	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196269	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196270	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196271	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
196272	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	0	
196273	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
196274	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
196275	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
196276	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196277	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196278	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	2	
196279	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
196280	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
196281	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	0	
196282	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	189	
196283	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	189	
196284	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
196285	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
196286	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
196287	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
196288	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
196289	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
196290	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
196291	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
196292	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
196293	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196294	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196295	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196296	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
196297	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
196298	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
196299	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	353	
196300	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments		
196301	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
196302	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
196303	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	6301.44	kw
196304	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
196305	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
196306	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
196307	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
196308	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
196309	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
196310	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
196311	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
196312	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
196313	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Max	65	°C
196314	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Top Oil Temperature Present	50	°C
196315	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
196316	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.6564	
196317	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Max	0	°C
196318	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Winding Temp Present	0	°C
196319	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
196320	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
196321	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196322	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	96	°F
196323	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196324	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196325	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196326	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196327	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
196328	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196329	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196330	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
196331	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	3.5	VDC
196332	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	3.7	VDC
196333	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196334	9/16/2019 13:14	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196335	9/16/2019 16:42	Distribution	Somerset GE Quarterly Inspection	LTC0000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
196336	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
196337	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
196338	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
196339	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
196340	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	0	
196341	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
196342	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
196343	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196344	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
196345	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	0	
196346	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	179	
196347	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	179	
196348	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
196349	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
196350	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
196351	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196352	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
196353	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196354	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
196355	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
196356	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
196357	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196358	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196359	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
196360	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196361	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196362	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196363	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196364	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	92	*F
196365	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196366	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196367	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196368	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
196369	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
196370	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
196371	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196372	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196373	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
196374	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196375	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196376	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196377	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196378	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	100	*F
196379	9/16/2019 12:44	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196380	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
196381	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
196382	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
196383	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
196384	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
196385	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
196386	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments		
196387	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
196388	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
196389	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
196390	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
196391	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
196392	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
196393	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
196394	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	158	
196395	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	158	
196396	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
196397	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
196398	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	General Comments		
196399	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196400	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196401	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
196402	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
196403	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
196404	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196405	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196406	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
196407	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196408	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196409	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196410	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196411	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	93	*F
196412	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196413	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	0	
196414	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196415	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196416	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196417	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
196418	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	
196419	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
196420	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196421	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196422	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196423	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196424	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
196425	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
196426	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196427	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
196428	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196429	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
196430	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196431	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196432	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
196433	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
196434	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments		
196435	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
196436	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196437	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196438	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196439	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196440	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
196441	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	99	*F
196442	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
196443	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
196444	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments		
196445	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196446	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
196447	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	70	
196448	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	70	
196449	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
196450	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
196451	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
196452	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
196453	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196454	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	0	
196455	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
196456	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
196457	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
196458	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
196459	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
196460	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196461	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196462	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196463	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
196464	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
196465	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
196466	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
196467	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	72	
196468	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	72	
196469	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
196470	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
196471	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
196472	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
196473	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
196474	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
196475	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
196476	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
196477	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
196478	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196479	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196480	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196481	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196482	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
196483	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
196484	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196485	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
196486	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
196487	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
196488	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196489	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196490	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196491	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
196492	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
196493	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196494	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196495	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196496	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
196497	9/16/2019 12:13	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
196498	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
196499	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
196500	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
196501	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196502	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
196503	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
196504	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196505	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196506	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196507	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196508	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
196509	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
196510	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
196511	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196512	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196513	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments		
196514	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
196515	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
196516	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
196517	9/16/2019 12:08	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.3	VDC
196518	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
196519	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
196520	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
196521	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
196522	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
196523	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	
196524	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	205	
196525	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	205	
196526	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
196527	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments		
196528	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments		
196529	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
196530	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
196531	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
196532	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
196533	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
196534	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
196535	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196536	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196537	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196538	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196539	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
196540	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
196541	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
196542	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196543	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196544	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196545	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
196546	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
196547	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
196548	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196549	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196550	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196551	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	158.0	
196552	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	156.0	
196553	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	153.0	
196554	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
196555	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
196556	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
196557	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
196558	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
196559	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
196560	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
196561	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
196562	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
196563	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
196564	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
196565	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
196566	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196567	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196568	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196569	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196570	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	0	
196571	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
196572	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
196573	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
196574	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
196575	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
196576	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196577	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
196578	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
196579	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Follow-up Action Required?	n	
196580	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	General Comments		
196581	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments		
196582	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
196583	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	101	
196584	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	101	
196585	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations This Read Vac	0	
196586	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
196587	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
196588	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	0	
196589	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196590	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196591	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196592	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	182.0	
196593	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	188.0	
196594	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	187.0	
196595	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	182.0	
196596	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	0	
196597	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
196598	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
196599	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
196600	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	200.0	
196601	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	250.0	
196602	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	250.0	
196603	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	0	
196604	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	60	
196605	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	60	
196606	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
196607	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	95	
196608	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	95	
196609	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
196610	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		
196611	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
196612	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
196613	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
196614	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
196615	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
196616	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
196617	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
196618	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
196619	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
196620	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
196621	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
196622	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1195	check oil cup
196623	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
196624	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
196625	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
196626	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196627	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196628	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196629	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196630	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196631	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196632	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196633	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
196634	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	21253	
196635	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	21253	
196636	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196637	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
196638	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
196639	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
196640	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
196641	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
196642	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	175.0	
196643	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	127.0	
196644	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	0	
196645	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	0.0	
196646	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
196647	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
196648	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	6	
196649	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196650	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196651	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196652	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	70.0	
196653	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	73.0	
196654	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	93.0	
196655	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
196656	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196657	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196658	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196659	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
196660	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
196661	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
196662	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
196663	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
196664	9/16/2019 12:49	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
196665	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196666	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196667	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196668	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
196669	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
196670	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
196671	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
196672	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
196673	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
196674	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	174	
196675	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
196676	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
196677	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
196678	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
196679	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
196680	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
196681	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
196682	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
196683	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
196684	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
196685	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
196686	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Switching Operations	0	
196687	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196688	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
196689	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
196690	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
196691	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
196692	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	General Comments		
196693	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
196694	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
196695	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
196696	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
196697	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
196698	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
196699	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
196700	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
196701	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
196702	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
196703	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
196704	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
196705	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	353	
196706	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
196707	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
196708	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
196709	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
196710	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
196711	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
196712	9/17/2019 11:33	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
196713	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196714	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	0	
196715	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations C Ø	0	
196716	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations Ground	0	
196717	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Follow-up Action Required?	n	
196718	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Follow-up Action Required?	n	
196719	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	General Comments		
196720	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	General Comments		
196721	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments		
196722	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments		
196723	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
196724	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	56	
196725	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	56	
196726	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
196727	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
196728	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
196729	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations This Read Vac	0	
196730	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
196731	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	
196732	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
196733	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	General Comments		
196734	9/16/2019 8:42	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
196735	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
196736	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	LTC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
196737	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
196738	9/16/2019 14:02	Distribution	Beaver Dam North Quarterly Inspection	LTC0000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
196739	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Maintenance Operations	0	
196740	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AF	65	
196741	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AL	65	
196742	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations This Read Vac	0	
196743	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Unknown Operations	0	
196744	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
196745	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
196746	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
196747	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196748	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196749	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196750	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	53.72	
196751	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	53.72	
196752	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	53.72	
196753	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
196754	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
196755	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
196756	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
196757	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196758	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196759	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196760	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
196761	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
196762	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
196763	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
196764	9/16/2019 13:22	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
196765	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
196766	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
196767	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
196768	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
196769	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
196770	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	174	
196771	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
196772	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
196773	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
196774	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
196775	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
196776	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
196777	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
196778	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	General Comments		
196779	9/17/2019 13:21	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196780	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
196781	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
196782	9/16/2019 13:09	Distribution	Muhlenberg Prison Quarterly Inspection	LTC0000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
196783	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
196784	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
196785	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTC0000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
196786	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
196787	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	9514	
196788	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
196789	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	9514	
196790	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	9R	
196791	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	1R	
196792	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	14R	
196793	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	416	
196794	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
196795	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
196796	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
196797	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
196798	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
196799	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
196800	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	50	*C
196801	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	60	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
196877	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
196878	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
196879	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
196880	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
196881	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
196882	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
196883	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
196884	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
196885	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
196886	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
196887	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
196888	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	2L	
196889	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
196890	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
196891	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
196892	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
196893	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
196894	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
196895	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
196896	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
196897	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
196898	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.51	%
196899	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.52	%
196900	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.06	%
196901	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	50.0	
196902	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
196903	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
196904	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
196905	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
196906	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
196907	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
196908	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
196909	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
196910	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
196911	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196912	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196913	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196914	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196915	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
196916	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
196917	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196918	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196919	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	3.15	
196920	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196921	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196922	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
196923	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
196924	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
196925	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	244	
196926	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	248	
196927	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
196928	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
196929	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
196930	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
196931	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
196932	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
196933	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
196934	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
196935	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
196936	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
196937	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
196938	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
196939	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
196940	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
196941	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
196942	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
196943	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
196944	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
196945	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
196946	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
196947	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
196948	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
196949	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
196950	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
196951	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
196952	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
196953	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
196954	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BAT000417	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
196955	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
196956	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
196957	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
196958	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
196959	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
196960	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
196961	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
196962	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
196963	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
196964	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
196965	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
196966	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
196967	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
196968	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
196969	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Amps C Ø	60.0	
196970	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
196971	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
196972	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
196973	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
196974	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
196975	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
196976	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
196977	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
196978	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
196979	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
196980	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
196981	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
196982	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
196983	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
196984	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
196985	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
196986	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
196987	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
196988	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
196989	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
196990	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
196991	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
196992	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
196993	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	65	°C
196994	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	55	°C
196995	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
196996	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
196997	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
196998	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
196999	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
197000	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
197001	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
197002	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
197003	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
197004	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
197005	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
197006	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
197007	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
197008	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
197009	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
197010	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
197011	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
197012	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197013	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
197014	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197015	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
197016	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
197017	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
197018	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
197019	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
197020	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BCH000479	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
197021	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
197022	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
197023	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
197024	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
197025	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
197026	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197027	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
197028	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
197029	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
197030	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
197031	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
197032	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
197033	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
197034	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
197035	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
197036	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
197037	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
197038	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
197039	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
197040	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
197041	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
197042	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
197043	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BAT000012	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
197044	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
197045	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
197046	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
197047	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
197048	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
197049	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
197050	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
197051	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
197052	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
197053	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
197054	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197055	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
197056	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0170	
197057	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 inches?	y	
197058	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
197059	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
197060	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
197061	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
197062	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
197063	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197064	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
197065	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.9384	
197066	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
197067	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	200.00	
197068	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
197069	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
197070	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
197071	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
197072	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
197073	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
197074	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
197075	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
197076	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
197077	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	79	*F
197078	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
197079	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197080	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197081	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
197082	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
197083	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
197084	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
197085	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197086	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
197087	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197088	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
197089	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
197090	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197091	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
197092	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197093	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
197094	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
197095	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
197096	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197097	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
197098	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	1.1826	
197099	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
197100	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
197101	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197102	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
197103	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
197104	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
197105	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
197106	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
197107	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
197108	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
197109	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197110	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	9008.64	kw
197111	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197112	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
197113	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
197114	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.7	psi
197115	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	47	°C
197116	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	47	°C
197117	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197118	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
197119	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	94094	
197120	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
197121	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197122	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
197123	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
197124	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
197125	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
197126	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
197127	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3254.40	kw
197128	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
197129	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
197130	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
197131	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
197132	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
197133	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
197134	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
197135	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
197136	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
197137	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
197138	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
197139	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
197140	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197141	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	2928.96	kw
197142	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197143	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
197144	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
197145	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
197146	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
197147	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
197148	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
197149	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
197150	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
197151	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	General Comments		
197152	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
197153	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
197154	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
197155	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
197156	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
197157	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
197158	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
197159	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
197160	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
197161	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
197162	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
197163	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
197164	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
197165	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	8L	
197166	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	LTC0000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
197167	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
197168	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
197169	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197170	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
197171	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
197172	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
197173	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197174	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
197175	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	0	
197176	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	42	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197177	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	42	
197178	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	Neutral	
197179	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	2	
197180	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
197181	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
197182	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
197183	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
197184	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
197185	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
197186	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
197187	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197188	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	78	%
197189	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	64	%
197190	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	72	%
197191	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
197192	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	54	°C
197193	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
197194	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197195	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	2.20	MegaWatts
197196	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	4.00	MegaWatts
197197	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.50	MegaVars
197198	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	1.00	MegaVars
197199	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197200	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
197201	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
197202	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
197203	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
197204	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
197205	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
197206	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
197207	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197208	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197209	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197210	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197211	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
197212	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
197213	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197214	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	0.0	
197215	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197216	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197217	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197218	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197219	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
197220	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
197221	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
197222	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
197223	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
197224	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
197225	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
197226	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
197227	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
197228	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
197229	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
197230	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
197231	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
197232	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
197233	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
197234	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
197235	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
197236	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
197237	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
197238	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
197239	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
197240	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
197241	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
197242	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
197243	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	241	
197244	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	241	
197245	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
197246	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
197247	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	0.0	
197248	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	0.0	
197249	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
197250	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
197251	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197252	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
197253	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
197254	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
197255	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
197256	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
197257	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
197258	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197259	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197260	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197261	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	2	
197262	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
197263	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
197264	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
197265	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
197266	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
197267	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
197268	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
197269	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
197270	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
197271	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
197272	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
197273	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
197274	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
197275	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	8418	
197276	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	8418	
197277	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
197278	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
197279	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
197280	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
197281	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
197282	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
197283	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
197284	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
197285	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
197286	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
197287	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
197288	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
197289	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197290	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
197291	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197292	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
197293	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197294	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
197295	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
197296	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
197297	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1072	
197298	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
197299	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
197300	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
197301	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
197302	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
197303	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
197304	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
197305	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
197306	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
197307	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
197308	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
197309	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
197310	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
197311	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
197312	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
197313	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
197314	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
197315	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
197316	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
197317	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
197318	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
197319	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
197320	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
197321	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197322	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
197323	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
197324	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	272	
197325	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	272	
197326	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197327	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
197328	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197329	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
197330	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
197331	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197332	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
197333	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197334	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
197335	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
197336	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
197337	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
197338	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
197339	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
197340	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
197341	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
197342	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
197343	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
197344	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
197345	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
197346	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
197347	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
197348	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
197349	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
197350	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
197351	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197352	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
197353	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
197354	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
197355	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197356	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197357	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
197358	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
197359	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197360	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
197361	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	7095.60	kw
197362	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197363	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
197364	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	60	°C
197365	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
197366	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
197367	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	12L	
197368	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
197369	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
197370	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
197371	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
197372	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	55	°C
197373	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
197374	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
197375	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
197376	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
197377	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
197378	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
197379	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
197380	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
197381	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
197382	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
197383	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
197384	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
197385	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
197386	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197387	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197388	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197389	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	0	
197390	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
197391	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
197392	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
197393	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
197394	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
197395	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
197396	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
197397	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
197398	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
197399	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
197400	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
197401	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197402	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
197403	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
197404	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
197405	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
197406	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
197407	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
197408	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
197409	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240.0	
197410	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
197411	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197412	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
197413	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
197414	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
197415	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
197416	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197417	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197418	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197419	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	180.0	
197420	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	200.0	
197421	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	AS Found Float Voltage	53.6	VDC
197422	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197423	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
197424	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197425	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
197426	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
197427	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
197428	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
197429	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
197430	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
197431	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
197432	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197433	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197434	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
197435	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
197436	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
197437	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
197438	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
197439	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
197440	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
197441	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
197442	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197443	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197444	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197445	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
197446	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197447	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197448	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
197449	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
197450	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
197451	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
197452	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
197453	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
197454	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
197455	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
197456	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
197457	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
197458	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
197459	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
197460	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
197461	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
197462	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
197463	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
197464	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
197465	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
197466	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197467	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197468	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197469	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
197470	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
197471	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
197472	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
197473	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
197474	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
197475	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
197476	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197477	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
197478	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
197479	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
197480	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
197481	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
197482	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
197483	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
197484	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
197485	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	4	
197486	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197487	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197488	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
197489	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
197490	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
197491	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
197492	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	13424	
197493	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
197494	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
197495	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
197496	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
197497	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197498	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	153.0	
197499	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	151.0	
197500	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	141.0	
197501	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197502	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197503	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
197504	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197505	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
197506	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197507	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197508	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197509	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197510	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	2	
197511	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
197512	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197513	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197514	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
197515	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
197516	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197517	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197518	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
197519	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
197520	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
197521	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
197522	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
197523	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
197524	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
197525	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
197526	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
197527	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
197528	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
197529	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
197530	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
197531	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197532	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	8098.56	kw
197533	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197534	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
197535	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	60	°C
197536	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	45	°C
197537	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197538	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
197539	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197540	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
197541	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
197542	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
197543	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197544	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
197545	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
197546	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
197547	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
197548	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
197549	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
197550	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
197551	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197552	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
197553	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
197554	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
197555	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
197556	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
197557	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
197558	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
197559	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
197560	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
197561	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
197562	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
197563	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
197564	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.2	VDC
197565	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
197566	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
197567	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
197568	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
197569	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BCH001168	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
197570	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.8436	
197571	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
197572	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
197573	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
197574	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
197575	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
197576	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
197577	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99972	
197578	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99972	
197579	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
197580	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
197581	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
197582	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
197583	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
197584	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
197585	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
197586	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
197587	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
197588	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	
197589	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	271	
197590	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	271	
197591	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
197592	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
197593	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
197594	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
197595	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
197596	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
197597	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
197598	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
197599	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
197600	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197601	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197602	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
197603	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
197604	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
197605	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	1	
197606	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	1	
197607	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
197608	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	3.95	
197609	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	3.95	
197610	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197611	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197612	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197613	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197614	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197615	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197616	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197617	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
197618	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197619	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197620	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	680.0	
197621	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	600.0	
197622	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	750.0	
197623	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197624	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197625	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	120.0	
197626	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	120.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197627	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	120.0	
197628	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197629	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197630	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197631	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	6	
197632	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197633	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	3	
197634	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197635	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
197636	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
197637	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	15	
197638	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197639	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197640	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197641	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	960.0	
197642	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	960.0	
197643	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	960.0	
197644	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
197645	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197646	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197647	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197648	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197649	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197650	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197651	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197652	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
197653	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197654	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197655	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
197656	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
197657	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
197658	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
197659	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
197660	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
197661	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197662	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197663	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197664	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197665	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
197666	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197667	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197668	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	1	
197669	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
197670	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
197671	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
197672	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
197673	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
197674	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
197675	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
197676	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
197677	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
197678	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
197679	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
197680	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
197681	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
197682	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
197683	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
197684	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
197685	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
197686	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
197687	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
197688	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
197689	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	159	
197690	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	159	
197691	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	1	
197692	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	0	
197693	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
197694	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
197695	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
197696	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
197697	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
197698	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
197699	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
197700	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
197701	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197702	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197703	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
197704	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
197705	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
197706	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
197707	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
197708	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
197709	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197710	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	2	
197711	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	482	
197712	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	482	
197713	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
197714	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
197715	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
197716	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
197717	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
197718	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
197719	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
197720	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
197721	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
197722	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
197723	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	General Comments		
197724	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
197725	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
197726	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
197727	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	13	
197728	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	142	
197729	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
197730	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
197731	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
197732	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197733	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
197734	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
197735	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197736	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
197737	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197738	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
197739	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
197740	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
197741	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
197742	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197743	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197744	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197745	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197746	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197747	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197748	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197749	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197750	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197751	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
197752	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
197753	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
197754	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
197755	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197756	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197757	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197758	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
197759	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
197760	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197761	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
197762	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197763	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
197764	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	118	
197765	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	118	
197766	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
197767	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
197768	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
197769	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197770	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
197771	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
197772	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197773	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
197774	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197775	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
197776	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
197777	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
197778	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
197779	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197780	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197781	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197782	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197783	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197784	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197785	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197786	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
197787	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
197788	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197789	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
197790	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
197791	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
197792	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	115	
197793	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	115	
197794	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
197795	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197796	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197797	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197798	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197799	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197800	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197801	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197802	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
197803	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197804	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197805	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197806	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197807	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
197808	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	450.0	
197809	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	450.0	
197810	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	450.0	
197811	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197812	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197813	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197814	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
197815	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
197816	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197817	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
197818	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197819	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197820	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197821	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197822	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197823	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197824	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
197825	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
197826	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
197827	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
197828	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	104	
197829	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	104	
197830	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
197831	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
197832	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
197833	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
197834	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
197835	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
197836	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
197837	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
197838	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197839	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
197840	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
197841	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
197842	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
197843	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197844	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
197845	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197846	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
197847	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197848	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
197849	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
197850	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
197851	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197852	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
197853	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
197854	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
197855	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
197856	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
197857	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
197858	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
197859	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
197860	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
197861	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197862	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197863	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197864	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197865	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
197866	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
197867	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
197868	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
197869	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197870	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197871	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197872	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
197873	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
197874	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197875	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	1	
197876	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197877	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
197878	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	142	
197879	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197880	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197881	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197882	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197883	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
197884	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
197885	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
197886	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197887	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197888	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
197889	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	2	
197890	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
197891	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	113	
197892	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
197893	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
197894	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
197895	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197896	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
197897	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
197898	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
197899	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations This Read AM	0	
197900	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99968	
197901	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99968	
197902	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
197903	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments		
197904	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
197905	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
197906	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
197907	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
197908	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
197909	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
197910	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
197911	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
197912	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
197913	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
197914	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
197915	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
197916	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
197917	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
197918	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
197919	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
197920	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
197921	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
197922	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
197923	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
197924	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
197925	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
197926	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
197927	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
197928	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
197929	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	5676.48	kw
197930	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
197931	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
197932	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	64	°C
197933	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	48	°C
197934	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
197935	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
197936	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
197937	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
197938	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
197939	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
197940	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
197941	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
197942	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
197943	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
197944	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
197945	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
197946	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
197947	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
197948	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.7884	
197949	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
197950	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
197951	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
197952	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
197953	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
197954	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
197955	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
197956	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
197957	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197958	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197959	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197960	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
197961	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
197962	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
197963	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
197964	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197965	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197966	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197967	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
197968	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
197969	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
197970	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
197971	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
197972	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	200.0	
197973	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	200.0	
197974	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
197975	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
197976	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
197977	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
197978	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
197979	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
197980	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
197981	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
197982	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	692	
197983	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	692	
197984	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
197985	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
197986	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
197987	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
197988	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
197989	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
197990	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
197991	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
197992	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
197993	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
197994	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
197995	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
197996	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
197997	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
197998	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
197999	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
198000	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
198001	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CAPO00057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198077	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198078	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
198079	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	140	
198080	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	140	
198081	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198082	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
198083	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198084	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198085	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
198086	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
198087	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
198088	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198089	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
198090	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
198091	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
198092	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
198093	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198094	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198095	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198096	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198097	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198098	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
198099	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.03	%
198100	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.03	%
198101	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.03	%
198102	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
198103	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
198104	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
198105	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
198106	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
198107	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
198108	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
198109	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
198110	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
198111	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
198112	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
198113	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
198114	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
198115	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	2	
198116	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198117	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
198118	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	236	
198119	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	236	
198120	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198121	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
198122	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198123	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198124	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
198125	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
198126	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
198127	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198128	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
198129	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
198130	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
198131	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
198132	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198133	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198134	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198135	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198136	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198137	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198138	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
198139	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
198140	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
198141	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
198142	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
198143	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
198144	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
198145	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
198146	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
198147	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
198148	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
198149	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
198150	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
198151	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198152	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
198153	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
198154	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
198155	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198156	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198157	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198158	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198159	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
198160	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198161	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198162	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198163	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198164	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
198165	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
198166	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198167	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
198168	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	145	
198169	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	145	
198170	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198171	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
198172	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198173	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198174	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
198175	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
198176	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
198177	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198178	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
198179	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
198180	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
198181	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198182	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198183	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
198184	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
198185	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
198186	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
198187	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
198188	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
198189	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
198190	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	26	
198191	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	21	
198192	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
198193	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
198194	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
198195	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
198196	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
198197	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	General Comments		
198198	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
198199	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
198200	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
198201	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
198202	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
198203	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
198204	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
198205	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
198206	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198207	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198208	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
198209	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
198210	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
198211	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
198212	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
198213	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
198214	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
198215	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
198216	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	461	
198217	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	457	
198218	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
198219	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
198220	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
198221	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
198222	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
198223	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	General Comments		
198224	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
198225	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
198226	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198227	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
198228	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
198229	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
198230	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
198231	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
198232	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198233	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198234	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
198235	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
198236	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
198237	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
198238	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
198239	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
198240	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
198241	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
198242	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
198243	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
198244	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
198245	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
198246	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
198247	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
198248	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.4068	
198249	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
198250	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
198251	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
198252	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
198253	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
198254	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
198255	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
198256	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
198257	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
198258	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198259	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198260	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198261	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
198262	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198263	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198264	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198265	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198266	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
198267	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
198268	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198269	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
198270	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
198271	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
198272	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198273	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
198274	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
198275	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
198276	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
198277	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198278	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198279	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
198280	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198281	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	143	
198282	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	143	
198283	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
198284	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198285	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
198286	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
198287	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
198288	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
198289	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
198290	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
198291	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0331	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
198292	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
198293	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
198294	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
198295	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
198296	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
198297	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
198298	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
198299	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	
198300	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	
198301	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198302	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
198303	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
198304	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
198305	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
198306	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
198307	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
198308	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
198309	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
198310	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
198311	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
198312	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
198313	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
198314	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
198315	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	General Comments		
198316	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
198317	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
198318	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
198319	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
198320	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
198321	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
198322	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
198323	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
198324	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	LTC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
198325	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198326	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198327	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198328	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198329	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
198330	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198331	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198332	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
198333	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
198334	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198335	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198336	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198337	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198338	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
198339	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198340	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198341	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198342	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
198343	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
198344	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	12.0	
198345	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	12.0	
198346	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	12.0	
198347	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
198348	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
198349	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
198350	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	1	
198351	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
198352	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
198353	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
198354	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	4	
198355	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
198356	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
198357	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	0	
198358	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	454	
198359	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	454	
198360	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
198361	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
198362	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
198363	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
198364	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
198365	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
198366	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
198367	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
198368	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	
198369	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
198370	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
198371	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
198372	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
198373	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198374	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	310.0	
198375	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	210.0	
198376	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	380.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198377	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
198378	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
198379	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
198380	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	1	
198381	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	160.0	
198382	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	200.0	
198383	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	240.0	
198384	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198385	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
198386	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
198387	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
198388	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
198389	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
198390	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
198391	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
198392	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
198393	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
198394	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
198395	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
198396	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
198397	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
198398	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	377	
198399	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	377	
198400	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
198401	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
198402	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
198403	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
198404	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
198405	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
198406	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
198407	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198408	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198409	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
198410	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
198411	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
198412	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
198413	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
198414	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
198415	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
198416	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
198417	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
198418	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
198419	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198420	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
198421	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
198422	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	161	
198423	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	165	
198424	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	4	
198425	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198426	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	4	
198427	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
198428	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
198429	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
198430	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
198431	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
198432	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
198433	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
198434	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
198435	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
198436	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
198437	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	LTC000141	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
198438	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
198439	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
198440	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
198441	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
198442	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
198443	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
198444	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
198445	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
198446	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
198447	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
198448	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
198449	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
198450	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
198451	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198452	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
198453	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
198454	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
198455	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
198456	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
198457	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
198458	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
198459	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
198460	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
198461	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
198462	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
198463	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
198464	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
198465	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
198466	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
198467	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
198468	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
198469	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198470	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	0	
198471	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	180	
198472	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	180	
198473	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
198474	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
198475	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
198476	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
198477	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
198478	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
198479	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
198480	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
198481	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
198482	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
198483	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
198484	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
198485	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
198486	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
198487	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
198488	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
198489	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
198490	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	General Comments		
198491	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
198492	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
198493	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
198494	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
198495	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	611	
198496	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	615	
198497	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	4	
198498	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198499	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	4	
198500	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
198501	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B80377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
198502	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
198503	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
198504	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
198505	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	398	
198506	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	12L	
198507	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	5L	
198508	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	11L	
198509	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
198510	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	20371	
198511	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	20371	
198512	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
198513	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
198514	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
198515	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
198516	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
198517	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
198518	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
198519	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	1132	
198520	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	8L	
198521	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	4R	
198522	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	3R	
198523	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
198524	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	230576	
198525	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	230576	
198526	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198527	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
198528	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
198529	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
198530	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
198531	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
198532	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
198533	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
198534	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8895	
198535	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
198536	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
198537	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
198538	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
198539	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
198540	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
198541	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
198542	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
198543	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
198544	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
198545	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
198546	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
198547	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
198548	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
198549	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
198550	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
198551	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
198552	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
198553	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
198554	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
198555	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
198556	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
198557	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
198558	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11647	
198559	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	91339	
198560	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
198561	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
198562	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
198563	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
198564	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	25.4	VDC
198565	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	25.4	VDC
198566	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
198567	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
198568	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
198569	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
198570	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.300	millivolts
198571	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
198572	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
198573	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
198574	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
198575	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
198576	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
198577	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
198578	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
198579	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
198580	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
198581	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
198582	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
198583	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
198584	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
198585	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
198586	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
198587	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
198588	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
198589	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
198590	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
198591	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
198592	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
198593	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
198594	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
198595	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
198596	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
198597	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	116921	
198598	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
198599	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	9	
198600	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
198601	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198602	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
198603	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
198604	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
198605	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
198606	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
198607	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
198608	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
198609	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
198610	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
198611	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
198612	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
198613	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	2R	
198614	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
198615	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
198616	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
198617	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
198618	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
198619	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
198620	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
198621	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
198622	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
198623	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
198624	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
198625	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
198626	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198627	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198628	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198629	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
198630	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198631	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198632	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198633	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198634	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
198635	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
198636	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
198637	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	123	
198638	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
198639	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
198640	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
198641	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
198642	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
198643	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
198644	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
198645	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
198646	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
198647	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
198648	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
198649	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
198650	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
198651	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
198652	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
198653	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
198654	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
198655	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
198656	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
198657	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
198658	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments	Can not read counter, it is working though	
198659	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
198660	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
198661	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
198662	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
198663	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
198664	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
198665	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
198666	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
198667	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
198668	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
198669	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
198670	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	531	
198671	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	531	
198672	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
198673	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198674	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
198675	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
198676	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198677	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
198678	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
198679	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198680	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
198681	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
198682	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
198683	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
198684	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
198685	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
198686	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
198687	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
198688	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
198689	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
198690	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
198691	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
198692	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
198693	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	60	
198694	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
198695	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
198696	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
198697	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
198698	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
198699	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
198700	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
198701	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
198702	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6817	
198703	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
198704	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
198705	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
198706	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
198707	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
198708	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
198709	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
198710	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
198711	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
198712	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
198713	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
198714	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
198715	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1227.06	kw
198716	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
198717	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
198718	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
198719	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
198720	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
198721	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
198722	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
198723	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
198724	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
198725	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
198726	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
198727	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
198728	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
198729	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
198730	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
198731	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
198732	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
198733	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
198734	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
198735	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
198736	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
198737	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
198738	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
198739	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
198740	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
198741	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
198742	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
198743	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
198744	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
198745	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0138	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
198746	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
198747	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198748	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
198749	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
198750	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
198751	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
198752	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
198753	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
198754	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
198755	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	58	
198756	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
198757	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
198758	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
198759	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
198760	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
198761	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
198762	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
198763	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
198764	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
198765	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
198766	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
198767	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
198768	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
198769	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	39.0	
198770	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
198771	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
198772	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
198773	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
198774	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
198775	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
198776	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
198777	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
198778	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
198779	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
198780	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
198781	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
198782	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
198783	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
198784	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
198785	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
198786	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
198787	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
198788	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
198789	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.4	VAC
198790	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
198791	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
198792	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
198793	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
198794	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
198795	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
198796	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
198797	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
198798	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198799	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
198800	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
198801	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
198802	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
198803	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments		
198804	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
198805	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
198806	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
198807	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
198808	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	302.40	kw
198809	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
198810	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
198811	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
198812	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
198813	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
198814	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
198815	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
198816	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
198817	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
198818	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
198819	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198820	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
198821	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
198822	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
198823	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
198824	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
198825	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
198826	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198827	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
198828	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
198829	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
198830	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
198831	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
198832	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
198833	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
198834	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
198835	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
198836	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
198837	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
198838	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
198839	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
198840	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198841	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
198842	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
198843	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
198844	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
198845	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
198846	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
198847	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
198848	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
198849	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
198850	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
198851	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
198852	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
198853	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
198854	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
198855	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
198856	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
198857	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
198858	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
198859	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
198860	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
198861	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
198862	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
198863	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
198864	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
198865	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
198866	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
198867	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
198868	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
198869	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
198870	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
198871	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
198872	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
198873	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
198874	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
198875	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
198876	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
198877	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
198878	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
198879	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
198880	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
198881	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
198882	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
198883	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
198884	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
198885	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
198886	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
198887	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
198888	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
198889	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
198890	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
198891	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
198892	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
198893	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
198894	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
198895	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
198896	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
198897	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
198898	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
198899	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
198900	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
198901	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198902	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
198903	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198904	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
198905	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
198906	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	7.0	
198907	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
198908	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
198909	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
198910	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
198911	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
198912	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
198913	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
198914	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
198915	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
198916	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
198917	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
198918	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
198919	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
198920	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
198921	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198922	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
198923	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
198924	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
198925	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
198926	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
198927	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
198928	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
198929	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
198930	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	215.00	
198931	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
198932	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
198933	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
198934	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
198935	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
198936	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
198937	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
198938	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
198939	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
198940	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
198941	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
198942	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
198943	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
198944	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
198945	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
198946	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
198947	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
198948	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
198949	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
198950	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
198951	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
198952	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
198953	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
198954	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
198955	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
198956	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
198957	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
198958	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
198959	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198960	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
198961	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
198962	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
198963	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
198964	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
198965	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
198966	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
198967	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
198968	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
198969	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
198970	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
198971	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
198972	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
198973	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
198974	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
198975	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
198976	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
198977	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
198978	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
198979	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
198980	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
198981	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
198982	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
198983	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
198984	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
198985	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
198986	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
198987	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
198988	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
198989	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
198990	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
198991	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
198992	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
198993	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
198994	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
198995	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
198996	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
198997	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
198998	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
198999	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
199000	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
199001	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
199002	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
199003	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
199004	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
199005	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
199006	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
199007	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
199008	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
199009	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
199010	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
199011	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
199012	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
199013	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
199014	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
199015	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
199016	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199017	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
199018	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199019	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
199020	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
199021	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
199022	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
199023	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	272148	
199024	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	272148	
199025	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
199026	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
199027	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
199028	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
199029	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199030	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
199031	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199032	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	60	
199033	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
199034	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
199035	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
199036	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
199037	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
199038	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
199039	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
199040	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
199041	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
199042	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
199043	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
199044	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
199045	9/12/2019 8:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
199046	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
199047	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
199048	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	1015	
199049	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
199050	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
199051	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199052	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
199053	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
199054	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
199055	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	459	
199056	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
199057	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
199058	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199059	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199060	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	459	
199061	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
199062	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
199063	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
199064	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
199065	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
199066	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
199067	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
199068	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
199069	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
199070	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199071	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199072	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199073	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199074	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
199075	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	150.0	
199076	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
199077	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199078	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199079	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199080	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
199081	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
199082	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
199083	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
199084	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
199085	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	73891	
199086	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
199087	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
199088	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
199089	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
199090	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
199091	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
199092	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
199093	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
199094	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
199095	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
199096	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
199097	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199098	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199099	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199100	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199101	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199102	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199103	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199104	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	MB0134	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199105	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
199106	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
199107	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
199108	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
199109	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
199110	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
199111	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
199112	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
199113	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
199114	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
199115	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
199116	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
199117	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
199118	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
199119	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
199120	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
199121	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
199122	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
199123	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
199124	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
199125	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
199126	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199127	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
199128	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
199129	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
199130	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
199131	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
199132	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
199133	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
199134	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
199135	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
199136	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
199137	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
199138	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
199139	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
199140	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
199141	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
199142	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
199143	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
199144	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
199145	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
199146	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
199147	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
199148	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
199149	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
199150	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
199151	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
199152	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
199153	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
199154	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
199155	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
199156	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
199157	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199158	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199159	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199160	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	97	*F
199161	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
199162	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
199163	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
199164	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199165	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199166	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199167	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
199168	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
199169	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
199170	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
199171	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
199172	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
199173	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
199174	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
199175	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
199176	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
199177	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
199178	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
199179	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
199180	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
199181	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
199182	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
199183	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
199184	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
199185	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
199186	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
199187	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
199188	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
199189	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
199190	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
199191	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
199192	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
199193	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
199194	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
199195	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199196	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
199197	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199198	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
199199	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
199200	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
199201	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199202	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
199203	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
199204	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	General Comments		
199205	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
199206	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
199207	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199208	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
199209	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199210	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	285	
199211	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	285	
199212	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
199213	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
199214	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
199215	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199216	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
199217	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCCControl	175-5	LTC Control Insp	All Connections OK?	y	
199218	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
199219	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
199220	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
199221	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
199222	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	Gap under fence in back right corner. Barb wire and some of the posts and rails have some rust.	
199223	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
199224	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
199225	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
199226	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
199227	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
199228	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
199229	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
199230	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
199231	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199232	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
199233	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
199234	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
199235	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
199236	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
199237	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
199238	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
199239	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199240	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
199241	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
199242	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
199243	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199244	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
199245	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
199246	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
199247	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
199248	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments	Breaker 234,235 the foundation is crumbling.	
199249	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
199250	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
199251	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Good	
199252	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
199253	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
199254	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
199255	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
199256	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
199257	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199258	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
199259	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
199260	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
199261	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199262	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199263	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
199264	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
199265	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
199266	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
199267	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
199268	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
199269	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	435.00	
199270	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	420.00	
199271	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
199272	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
199273	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199274	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
199275	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
199276	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199277	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
199278	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
199279	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
199280	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
199281	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
199282	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
199283	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
199284	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
199285	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199286	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
199287	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
199288	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
199289	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199290	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199291	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199292	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	2	
199293	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
199294	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199295	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
199296	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
199297	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
199298	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
199299	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
199300	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
199301	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
199302	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
199303	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
199304	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
199305	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
199306	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
199307	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
199308	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
199309	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
199310	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	220	
199311	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	216	
199312	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
199313	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
199314	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
199315	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
199316	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
199317	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
199318	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
199319	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
199320	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
199321	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
199322	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
199323	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
199324	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199325	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
199326	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
199327	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199328	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
199329	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
199330	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
199331	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
199332	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
199333	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
199334	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199335	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
199336	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199337	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
199338	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
199339	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
199340	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
199341	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
199342	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199343	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199344	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199345	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199346	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
199347	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
199348	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
199349	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
199350	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
199351	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199352	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
199353	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
199354	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
199355	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
199356	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
199357	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
199358	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
199359	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
199360	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	204232	
199361	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
199362	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
199363	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
199364	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
199365	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
199366	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
199367	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
199368	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
199369	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
199370	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
199371	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
199372	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
199373	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
199374	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
199375	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
199376	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
199377	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
199378	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
199379	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
199380	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
199381	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199382	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199383	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199384	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
199385	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
199386	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
199387	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199388	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199389	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199390	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199391	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199392	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
199393	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
199394	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199395	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199396	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199397	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199398	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199399	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199400	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
199401	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199402	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
199403	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
199404	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199405	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Max	45	°C
199406	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
199407	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
199408	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1890	
199409	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
199410	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199411	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199412	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199413	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
199414	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
199415	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
199416	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
199417	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	338476	
199418	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	338488	
199419	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
199420	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	4L	
199421	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	2L	
199422	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	13L	
199423	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199424	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
199425	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	2228	
199426	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199427	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
199428	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
199429	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
199430	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
199431	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
199432	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
199433	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199434	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199435	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199436	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
199437	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
199438	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
199439	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199440	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199441	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199442	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199443	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
199444	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
199445	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
199446	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
199447	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
199448	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
199449	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
199450	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
199451	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
199452	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
199453	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
199454	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
199455	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
199456	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
199457	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
199458	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
199459	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
199460	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
199461	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
199462	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
199463	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments		
199464	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Maintenance Operations	0	
199465	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AF	39	
199466	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
199467	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
199468	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
199469	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
199470	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
199471	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
199472	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	39	
199473	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations This Read AM	0	
199474	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199475	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199476	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199477	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199478	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
199479	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
199480	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
199481	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199482	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199483	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199484	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
199485	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
199486	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
199487	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
199488	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	M80162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199489	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	M80162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199490	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	M80162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199491	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
199492	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
199493	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
199494	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
199495	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	3313	
199496	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	7L	
199497	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	5R	
199498	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	1R	
199499	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
199500	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	20164	
199501	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	20154	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199502	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
199503	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
199504	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
199505	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
199506	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
199507	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
199508	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
199509	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
199510	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
199511	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
199512	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
199513	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
199514	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
199515	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
199516	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
199517	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199518	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
199519	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
199520	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
199521	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
199522	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
199523	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	572	
199524	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	572	
199525	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
199526	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
199527	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
199528	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
199529	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
199530	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
199531	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
199532	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
199533	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
199534	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
199535	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
199536	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199537	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
199538	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	0	
199539	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199540	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199541	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199542	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	60.0	
199543	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	60.0	
199544	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	60.0	
199545	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199546	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199547	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199548	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199549	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
199550	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
199551	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199552	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
199553	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
199554	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199555	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	281	
199556	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	285	
199557	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
199558	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
199559	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
199560	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199561	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
199562	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	5	
199563	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199564	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199565	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199566	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
199567	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
199568	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
199569	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199570	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199571	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199572	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199573	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199574	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
199575	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
199576	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199577	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199578	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
199579	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199580	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
199581	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
199582	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
199583	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199584	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	258	
199585	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	258	
199586	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
199587	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
199588	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
199589	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
199590	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
199591	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTCC000502	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
199592	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
199593	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
199594	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199595	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
199596	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
199597	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199598	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199599	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199600	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	25.0	
199601	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
199602	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
199603	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
199604	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
199605	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
199606	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
199607	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199608	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199609	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199610	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199611	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199612	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199613	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
199614	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
199615	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
199616	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
199617	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199618	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
199619	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	50	°C
199620	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199621	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
199622	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
199623	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
199624	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
199625	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
199626	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199627	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199628	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199629	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199630	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	100.0	
199631	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	140.0	
199632	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	140.0	
199633	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199634	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199635	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199636	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
199637	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
199638	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
199639	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
199640	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199641	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199642	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
199643	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
199644	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
199645	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	carded	
199646	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
199647	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
199648	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	235.00	
199649	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
199650	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
199651	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199652	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199653	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
199654	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199655	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199656	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199657	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
199658	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
199659	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
199660	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
199661	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199662	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
199663	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199664	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
199665	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0110	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
199666	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	46	°C
199667	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199668	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
199669	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199670	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
199671	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
199672	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199673	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
199674	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.7700	
199675	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
199676	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
199677	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
199678	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199679	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
199680	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
199681	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199682	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
199683	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
199684	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199685	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	450	
199686	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	454	
199687	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
199688	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
199689	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
199690	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
199691	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
199692	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
199693	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	180	
199694	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	184	
199695	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	25.0	
199696	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	25.0	
199697	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
199698	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
199699	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199700	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
199701	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
199702	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
199703	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
199704	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199705	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
199706	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
199707	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
199708	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
199709	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
199710	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
199711	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
199712	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
199713	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
199714	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
199715	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
199716	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
199717	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
199718	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199719	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
199720	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
199721	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199722	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
199723	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199724	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
199725	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
199726	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
199727	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199728	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199729	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
199730	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
199731	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
199732	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments	Can not reset guage	
199733	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
199734	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
199735	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	435.00	
199736	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	420.00	
199737	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
199738	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
199739	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199740	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
199741	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
199742	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199743	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
199744	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
199745	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199746	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
199747	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
199748	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
199749	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments		
199750	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
199751	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
199752	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	3696.00	kw
199753	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
199754	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
199755	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	67	°C
199756	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
199757	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
199758	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
199759	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
199760	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
199761	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
199762	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	419	
199763	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
199764	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
199765	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
199766	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
199767	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
199768	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
199769	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
199770	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
199771	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
199772	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments	TR-2 replacement going on	
199773	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
199774	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
199775	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
199776	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	419	
199777	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
199778	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
199779	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
199780	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
199781	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199782	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
199783	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
199784	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	10.0	
199785	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199786	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199787	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199788	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	11	
199789	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
199790	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
199791	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
199792	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
199793	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	3883	
199794	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	3883	
199795	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
199796	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	6L	
199797	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
199798	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
199799	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
199800	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
199801	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199802	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
199803	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
199804	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
199805	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	200605	
199806	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
199807	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
199808	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
199809	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
199810	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199811	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199812	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199813	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199814	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
199815	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
199816	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
199817	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
199818	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
199819	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
199820	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
199821	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
199822	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
199823	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
199824	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
199825	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
199826	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	10.0	
199827	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	10.0	
199828	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
199829	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
199830	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
199831	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
199832	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199833	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
199834	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
199835	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
199836	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199837	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199838	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
199839	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
199840	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
199841	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
199842	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
199843	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
199844	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
199845	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
199846	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
199847	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
199848	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTC0000502	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
199849	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTC0000502	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
199850	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTC0000502	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
199851	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTC0000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
199852	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
199853	9/13/2019 10:54	Distribution	Williamsburg South Quarterly Inspection	LTC0000502	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
199854	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
199855	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
199856	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
199857	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	8L	
199858	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	605	
199859	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
199860	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
199861	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	240	
199862	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199863	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
199864	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
199865	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
199866	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
199867	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
199868	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
199869	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
199870	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199871	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199872	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199873	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199874	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199875	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199876	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199877	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199878	9/13/2019 7:46	Distribution	Rodburn Quarterly Inspection	BB0197	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199879	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
199880	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
199881	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
199882	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
199883	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
199884	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
199885	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
199886	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	240	
199887	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
199888	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
199889	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
199890	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
199891	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199892	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
199893	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
199894	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	21382	
199895	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	21382	
199896	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
199897	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	5L	
199898	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
199899	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	6L	
199900	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	1037	
199901	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
199902	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
199903	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
199904	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
199905	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199906	9/13/2019 11:13	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199907	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
199908	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199909	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199910	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
199911	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	310.0	
199912	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	400.0	
199913	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
199914	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
199915	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
199916	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
199917	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199918	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199919	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199920	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199921	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199922	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199923	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199924	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199925	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
199926	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
199927	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
199928	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
199929	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
199930	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
199931	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
199932	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
199933	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
199934	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
199935	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
199936	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
199937	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
199938	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199939	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199940	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199941	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
199942	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
199943	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
199944	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.5784	
199945	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
199946	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
199947	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
199948	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
199949	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
199950	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
199951	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
199952	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
199953	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	45	°C
199954	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
199955	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
199956	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
199957	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
199958	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
199959	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
199960	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
199961	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	2	
199962	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
199963	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
199964	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
199965	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
199966	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
199967	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	10	
199968	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
199969	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
199970	9/13/2019 15:22	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
199971	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199972	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199973	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
199974	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
199975	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199976	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	750.0	
199977	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	750.0	
199978	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	750.0	
199979	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	B80332	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
199980	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	B80332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
199981	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	B80332	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
199982	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	B80332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
199983	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
199984	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
199985	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
199986	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
199987	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	504	
199988	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	504	
199989	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
199990	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
199991	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
199992	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
199993	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
199994	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
199995	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
199996	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
199997	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
199998	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
199999	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	General Comments		
200000	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200001	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
200002	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	130.0	
200003	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	120.0	
200004	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	150.0	
200005	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B80295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200006	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
200007	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
200008	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
200009	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
200010	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
200011	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	LTC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
200012	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
200013	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
200014	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
200015	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
200016	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
200017	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
200018	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
200019	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
200020	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
200021	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
200022	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
200023	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
200024	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
200025	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
200026	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200027	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
200028	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
200029	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
200030	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
200031	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
200032	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
200033	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
200034	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
200035	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments		
200036	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	
200037	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	105	
200038	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
200039	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
200040	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
200041	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200042	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200043	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
200044	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
200045	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
200046	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0112	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	carded	
200047	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	105	
200048	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations This Read AM	0	
200049	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	0	
200050	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
200051	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
200052	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
200053	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
200054	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
200055	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
200056	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
200057	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
200058	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
200059	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
200060	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	4164.48	kw
200061	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
200062	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
200063	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99978	
200064	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99978	
200065	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
200066	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
200067	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
200068	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
200069	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	General Comments		
200070	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
200071	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
200072	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
200073	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
200074	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
200075	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
200076	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
200077	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	y	
200078	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
200079	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
200080	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
200081	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	201	
200082	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	197	
200083	9/13/2019 15:03	Distribution	Farmers Quarterly Inspection	BB0332	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
200084	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
200085	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
200086	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200087	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200088	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
200089	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
200090	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
200091	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
200092	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
200093	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200094	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200095	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
200096	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
200097	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200098	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
200099	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
200100	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
200101	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200102	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	y	
200103	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
200104	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
200105	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
200106	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
200107	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
200108	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
200109	9/13/2019 13:32	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
200110	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
200111	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
200112	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
200113	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
200114	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
200115	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
200116	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
200117	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
200118	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
200119	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
200120	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
200121	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
200122	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
200123	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
200124	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
200125	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
200126	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
200127	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
200128	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
200129	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
200130	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
200131	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
200132	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
200133	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200134	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	308	
200135	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	308	
200136	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
200137	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
200138	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
200139	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	0	
200140	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
200141	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
200142	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
200143	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	0	
200144	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	92	
200145	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200146	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
200147	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	92	
200148	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
200149	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
200150	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
200151	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
200152	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
200153	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
200154	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
200155	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
200156	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
200157	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
200158	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
200159	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
200160	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	5	
200161	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200162	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	5	
200163	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
200164	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
200165	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
200166	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
200167	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
200168	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
200169	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
200170	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
200171	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
200172	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
200173	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
200174	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
200175	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
200176	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200177	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
200178	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
200179	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
200180	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
200181	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
200182	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
200183	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
200184	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
200185	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
200186	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
200187	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
200188	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
200189	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
200190	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
200191	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
200192	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
200193	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
200194	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
200195	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
200196	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
200197	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
200198	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
200199	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
200200	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
200201	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
200202	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
200203	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
200204	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
200205	9/13/2019 8:51	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
200206	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
200207	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200208	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
200209	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
200210	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
200211	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	0	°C
200212	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
200213	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
200214	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
200215	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
200216	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
200217	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200218	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
200219	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
200220	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
200221	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
200222	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
200223	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
200224	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
200225	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
200226	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
200227	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	0.0	
200228	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	0.0	
200229	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	0.0	
200230	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
200231	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
200232	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
200233	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
200234	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LT0111	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
200235	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
200236	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	0	
200237	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
200238	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
200239	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
200240	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200241	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
200242	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
200243	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
200244	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
200245	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
200246	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
200247	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
200248	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
200249	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
200250	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
200251	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200252	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
200253	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
200254	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
200255	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
200256	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
200257	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	232	
200258	9/13/2019 9:51	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	237	
200259	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
200260	9/16/2019 9:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments		
200261	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200262	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200263	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200264	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200265	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200266	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
200267	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	3.36	%
200268	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	8.82	%
200269	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
200270	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
200271	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
200272	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
200273	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
200274	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
200275	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
200276	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
200277	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
200278	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
200279	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0	
200280	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
200281	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0	
200282	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0	
200283	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200284	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200285	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200286	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200287	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
200288	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	4	
200289	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200290	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	4	
200291	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	295	
200292	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	291	
200293	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	100.0	
200294	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	3.36	%
200295	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	100.0	
200296	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	100.0	
200297	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
200298	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
200299	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
200300	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
200301	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200302	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
200303	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
200304	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
200305	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
200306	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
200307	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
200308	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
200309	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
200310	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
200311	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
200312	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
200313	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
200314	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
200315	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
200316	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
200317	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
200318	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
200319	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
200320	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
200321	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
200322	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
200323	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
200324	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
200325	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
200326	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200327	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
200328	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
200329	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
200330	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
200331	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
200332	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
200333	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
200334	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
200335	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
200336	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
200337	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	11	
200338	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200339	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16.8	%
200340	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.86	%
200341	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.76	%
200342	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	12.0	
200343	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
200344	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	12.0	
200345	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
200346	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200347	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
200348	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
200349	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
200350	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
200351	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
200352	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
200353	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
200354	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
200355	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.250	millivolts
200356	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
200357	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
200358	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
200359	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
200360	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
200361	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
200362	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
200363	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments		
200364	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
200365	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
200366	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
200367	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
200368	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
200369	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
200370	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
200371	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
200372	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
200373	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
200374	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
200375	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
200376	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
200377	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
200378	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
200379	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
200380	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
200381	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
200382	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
200383	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
200384	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
200385	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
200386	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
200387	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
200388	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
200389	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
200390	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
200391	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
200392	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
200393	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
200394	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
200395	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
200396	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
200397	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
200398	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
200399	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
200400	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
200401	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200402	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	n	
200403	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
200404	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
200405	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
200406	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
200407	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
200408	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
200409	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
200410	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
200411	9/12/2019 14:44	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
200412	9/12/2019 14:44	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
200413	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
200414	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
200415	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
200416	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
200417	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
200418	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
200419	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
200420	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
200421	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
200422	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
200423	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20	
200424	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25	
200425	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
200426	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
200427	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
200428	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
200429	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
200430	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
200431	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
200432	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
200433	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200434	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
200435	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
200436	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200437	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
200438	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
200439	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
200440	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
200441	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
200442	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
200443	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
200444	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
200445	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
200446	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
200447	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
200448	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
200449	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
200450	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
200451	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
200452	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
200453	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
200454	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
200455	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
200456	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
200457	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
200458	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
200459	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
200460	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	167	
200461	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	167	
200462	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
200463	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
200464	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
200465	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
200466	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
200467	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
200468	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200469	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
200470	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
200471	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	MB0120	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
200472	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
200473	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
200474	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
200475	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
200476	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200477	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
200478	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
200479	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
200480	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments	tower leg foundations crumbling, as well as transformer	
200481	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
200482	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
200483	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
200484	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
200485	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
200486	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
200487	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
200488	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
200489	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
200490	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
200491	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
200492	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
200493	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
200494	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
200495	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
200496	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
200497	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
200498	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200499	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200500	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200501	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
200502	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200503	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
200504	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
200505	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
200506	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200507	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200508	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
200509	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200510	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
200511	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200512	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200513	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200514	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200515	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.3834	
200516	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
200517	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200518	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200519	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200520	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200521	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200522	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
200523	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	100.0	
200524	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	100.0	
200525	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	100.0	
200526	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200527	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
200528	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
200529	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
200530	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
200531	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
200532	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
200533	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
200534	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
200535	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
200536	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
200537	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	50	°C
200538	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
200539	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
200540	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
200541	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
200542	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
200543	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
200544	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
200545	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
200546	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
200547	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	195	
200548	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	195	
200549	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	2	
200550	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	2	
200551	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200552	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
200553	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	4	
200554	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200555	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200556	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200557	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
200558	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
200559	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
200560	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
200561	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
200562	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
200563	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
200564	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
200565	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
200566	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
200567	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
200568	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
200569	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
200570	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
200571	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
200572	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
200573	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	7	
200574	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200575	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	0.0	
200576	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
200577	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
200578	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
200579	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
200580	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
200581	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
200582	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	4	
200583	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200584	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	4	
200585	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	104	
200586	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	100	
200587	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
200588	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
200589	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200590	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
200591	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
200592	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
200593	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
200594	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
200595	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
200596	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
200597	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
200598	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200599	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200600	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	340.0	
200601	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	420.0	
200602	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	480.0	
200603	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
200604	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200605	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B Ø	0	
200606	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C Ø	0	
200607	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
200608	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
200609	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
200610	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
200611	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
200612	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
200613	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
200614	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
200615	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
200616	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	200	
200617	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	200	
200618	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	2	
200619	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	2	
200620	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
200621	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
200622	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	4	
200623	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200624	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200625	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200626	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200627	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	0.0	
200628	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	0.0	
200629	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
200630	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200631	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200632	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200633	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200634	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200635	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200636	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200637	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200638	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200639	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
200640	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
200641	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
200642	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
200643	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
200644	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
200645	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
200646	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
200647	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments		
200648	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
200649	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
200650	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
200651	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
200652	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
200653	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
200654	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	185	
200655	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
200656	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
200657	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
200658	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
200659	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
200660	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
200661	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
200662	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
200663	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
200664	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
200665	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
200666	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
200667	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
200668	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
200669	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
200670	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
200671	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
200672	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
200673	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
200674	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
200675	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
200676	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	185	
200677	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	2	
200678	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	2	
200679	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
200680	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
200681	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3067.20	kw
200682	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
200683	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
200684	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
200685	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
200686	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
200687	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
200688	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200689	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
200690	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
200691	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200692	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
200693	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
200694	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
200695	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
200696	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
200697	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
200698	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
200699	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
200700	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200701	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200702	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition?	Good	
200703	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
200704	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
200705	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
200706	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
200707	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200708	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200709	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
200710	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
200711	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
200712	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
200713	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
200714	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	8	
200715	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
200716	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
200717	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
200718	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
200719	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
200720	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
200721	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
200722	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
200723	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
200724	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
200725	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	n	
200726	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
200727	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
200728	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
200729	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
200730	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
200731	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments	NEW FENCE BEING INSTALLED TEMPORARY FENCE UP	
200732	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
200733	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	0.0	
200734	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	0.0	
200735	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
200736	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200737	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200738	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200739	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200740	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200741	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200742	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200743	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
200744	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
200745	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
200746	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
200747	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
200748	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
200749	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
200750	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
200751	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
200752	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
200753	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
200754	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
200755	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200756	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200757	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
200758	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
200759	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
200760	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
200761	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	1.0000	
200762	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
200763	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTCT Bushing Dynamic Health	0.00	
200764	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200765	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200766	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
200767	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
200768	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
200769	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
200770	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
200771	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	4	
200772	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200773	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200774	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200775	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200776	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200777	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200778	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200779	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
200780	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
200781	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
200782	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
200783	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
200784	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
200785	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
200786	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
200787	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
200788	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
200789	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200790	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	4	
200791	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	149	
200792	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	145	
200793	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
200794	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
200795	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
200796	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
200797	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	98	
200798	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	102	
200799	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	4	
200800	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
200801	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	4	
200802	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
200803	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
200804	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200805	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
200806	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
200807	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
200808	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
200809	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	177174	
200810	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
200811	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
200812	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
200813	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
200814	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
200815	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
200816	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
200817	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	177174	
200818	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
200819	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	1L	
200820	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
200821	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	6L	
200822	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
200823	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
200824	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
200825	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
200826	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
200827	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
200828	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	95	*F
200829	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
200830	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	8	
200831	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200832	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200833	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200834	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	150.0	
200835	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	150.0	
200836	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	120.0	
200837	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
200838	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
200839	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
200840	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
200841	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	General Comments		
200842	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
200843	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
200844	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
200845	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
200846	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	LTC000851	LTCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
200847	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
200848	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
200849	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
200850	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
200851	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	8	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
200852	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200853	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
200854	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200855	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200856	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200857	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
200858	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
200859	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	10	
200860	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
200861	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
200862	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
200863	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
200864	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200865	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200866	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	120.0	
200867	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	120.0	
200868	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	120.0	
200869	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
200870	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200871	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200872	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200873	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200874	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
200875	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
200876	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	6000.00	kw
200877	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
200878	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
200879	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	55	°C
200880	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	°C
200881	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
200882	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
200883	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
200884	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
200885	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
200886	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
200887	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	120.0	
200888	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	150.0	
200889	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	100.0	
200890	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
200891	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
200892	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
200893	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
200894	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
200895	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	495	
200896	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	12L	
200897	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	4L	
200898	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	5L	
200899	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
200900	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
200901	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
200902	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
200903	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
200904	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
200905	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
200906	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
200907	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
200908	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
200909	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
200910	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
200911	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
200912	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
200913	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
200914	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
200915	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
200916	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
200917	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
200918	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
200919	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
200920	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
200921	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
200922	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
200923	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
200924	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
200925	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	If no, which cells in comments
200926	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	92	*F

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
200927	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
200928	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
200929	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
200930	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
200931	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
200932	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
200933	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
200934	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
200935	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
200936	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
200937	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
200938	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
200939	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
200940	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BAT000430	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
200941	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
200942	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
200943	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BCH000534	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
200944	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	80962	
200945	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	80962	
200946	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
200947	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
200948	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
200949	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
200950	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	614	
200951	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
200952	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
200953	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
200954	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
200955	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
200956	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
200957	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200958	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200959	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200960	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
200961	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
200962	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
200963	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
200964	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
200965	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
200966	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
200967	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
200968	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
200969	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
200970	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
200971	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
200972	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	General Comments		
200973	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
200974	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
200975	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
200976	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
200977	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	LTC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
200978	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
200979	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
200980	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
200981	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
200982	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
200983	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
200984	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
200985	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
200986	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
200987	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
200988	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
200989	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments	NEW COUNTER	
200990	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
200991	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
200992	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
200993	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
200994	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
200995	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
200996	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	15	
200997	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	19	
200998	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	4	
200999	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
201000	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	4	
201001	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201002	9/11/2019 8:09	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
201003	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201004	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201005	9/11/2019 8:58	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201006	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
201007	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
201008	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
201009	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
201010	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
201011	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
201012	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
201013	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTC0000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
201014	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
201015	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
201016	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Positive lead on battery one has small crack and fluid is seeping out	
201017	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
201018	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
201019	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
201020	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
201021	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
201022	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
201023	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
201024	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
201025	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
201026	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
201027	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.500	millivolts
201028	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.8	VDC
201029	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.8	VDC
201030	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
201031	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
201032	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
201033	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
201034	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
201035	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
201036	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
201037	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201038	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201039	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201040	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201041	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
201042	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
201043	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	72	*C
201044	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
201045	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
201046	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
201047	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	554.0	
201048	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	594.0	
201049	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	621.0	
201050	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201051	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201052	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
201053	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
201054	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201055	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	0	
201056	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	*C
201057	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
201058	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
201059	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
201060	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
201061	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
201062	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
201063	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
201064	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	*C
201065	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
201066	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
201067	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
201068	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	223	
201069	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
201070	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	223	
201071	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
201072	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
201073	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
201074	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
201075	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs to be replaced	
201076	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	111281	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201077	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	111281	
201078	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
201079	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
201080	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
201081	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
201082	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1742	
201083	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
201084	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
201085	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
201086	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
201087	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
201088	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
201089	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
201090	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
201091	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
201092	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
201093	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
201094	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
201095	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
201096	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	n	
201097	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
201098	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
201099	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
201100	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	2	
201101	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	65.51	%
201102	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	68.02	%
201103	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
201104	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
201105	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
201106	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
201107	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
201108	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
201109	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
201110	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
201111	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
201112	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201113	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
201114	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201115	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201116	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
201117	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
201118	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
201119	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
201120	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
201121	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
201122	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
201123	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201124	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201125	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201126	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
201127	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
201128	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
201129	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
201130	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
201131	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
201132	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
201133	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
201134	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
201135	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201136	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
201137	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
201138	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
201139	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
201140	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
201141	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
201142	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
201143	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
201144	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
201145	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
201146	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
201147	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
201148	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
201149	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
201150	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
201151	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201152	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
201153	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
201154	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
201155	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
201156	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
201157	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
201158	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
201159	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
201160	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
201161	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
201162	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
201163	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
201164	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
201165	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
201166	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201167	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
201168	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
201169	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
201170	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
201171	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
201172	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
201173	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
201174	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
201175	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
201176	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
201177	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
201178	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
201179	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
201180	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
201181	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
201182	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
201183	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
201184	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.6260	
201185	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
201186	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Present	50	°C
201187	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Top Oil Temperature Max	70	°C
201188	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
201189	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
201190	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
201191	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
201192	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
201193	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
201194	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201195	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201196	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201197	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201198	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
201199	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
201200	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
201201	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	4507.20	kw
201202	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
201203	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
201204	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
201205	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
201206	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
201207	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
201208	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
201209	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
201210	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
201211	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201212	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
201213	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
201214	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201215	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201216	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201217	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201218	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
201219	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
201220	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
201221	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
201222	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
201223	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
201224	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201225	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201226	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201227	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201228	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
201229	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
201230	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
201231	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
201232	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
201233	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
201234	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
201235	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
201236	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
201237	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
201238	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.6054	
201239	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
201240	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
201241	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
201242	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
201243	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
201244	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
201245	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
201246	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
201247	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
201248	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201249	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
201250	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
201251	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201252	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201253	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201254	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201255	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
201256	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
201257	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201258	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201259	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201260	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
201261	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
201262	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
201263	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
201264	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
201265	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
201266	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
201267	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
201268	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
201269	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
201270	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
201271	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
201272	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
201273	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	
201274	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
201275	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	4	
201276	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
201277	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	4	
201278	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
201279	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
201280	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
201281	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
201282	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
201283	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
201284	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
201285	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
201286	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
201287	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	369	
201288	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	369	
201289	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
201290	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2025	
201291	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2021	
201292	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
201293	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
201294	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
201295	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
201296	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
201297	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
201298	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
201299	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
201300	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
201301	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201302	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
201303	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
201304	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
201305	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
201306	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
201307	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
201308	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
201309	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
201310	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
201311	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
201312	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
201313	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
201314	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
201315	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
201316	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
201317	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
201318	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
201319	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
201320	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
201321	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
201322	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201323	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201324	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	1	
201325	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	181	
201326	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	180	
201327	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
201328	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
201329	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
201330	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
201331	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
201332	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
201333	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
201334	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
201335	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
201336	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
201337	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
201338	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
201339	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201340	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201341	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201342	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201343	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
201344	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
201345	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
201346	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
201347	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
201348	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
201349	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	82.0	
201350	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	91.0	
201351	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	46.0	
201352	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
201353	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
201354	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
201355	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	2	
201356	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
201357	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	1	
201358	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	1	
201359	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	707	
201360	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	707	
201361	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
201362	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
201363	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
201364	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
201365	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
201366	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
201367	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
201368	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201369	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201370	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201371	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	0.0	
201372	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	0.0	
201373	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	0.0	
201374	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201375	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
201376	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	64.67	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201377	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
201378	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
201379	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
201380	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
201381	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	n	
201382	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
201383	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments		
201384	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
201385	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201386	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
201387	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201388	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
201389	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
201390	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
201391	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
201392	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
201393	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
201394	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
201395	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
201396	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
201397	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
201398	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
201399	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
201400	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	50	°C
201401	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	60	°C
201402	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
201403	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
201404	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	208	
201405	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
201406	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	220.0	
201407	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	240.0	
201408	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	200.0	
201409	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
201410	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201411	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	208	
201412	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	1	
201413	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
201414	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
201415	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	4358.88	kw
201416	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
201417	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
201418	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
201419	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
201420	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
201421	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
201422	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
201423	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
201424	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
201425	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201426	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
201427	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
201428	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201429	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201430	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201431	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201432	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
201433	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
201434	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	1	
201435	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
201436	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
201437	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
201438	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
201439	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	1	
201440	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201441	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201442	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	10	
201443	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
201444	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
201445	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
201446	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
201447	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
201448	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
201449	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
201450	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
201451	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201452	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
201453	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
201454	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
201455	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
201456	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
201457	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
201458	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201459	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
201460	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
201461	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
201462	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
201463	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201464	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201465	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201466	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201467	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201468	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
201469	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
201470	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201471	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
201472	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
201473	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
201474	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
201475	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
201476	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201477	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201478	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201479	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201480	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
201481	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
201482	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
201483	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
201484	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
201485	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
201486	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	45.0	
201487	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	45.0	
201488	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	45.0	
201489	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201490	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201491	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201492	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	9	
201493	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
201494	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
201495	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
201496	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
201497	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	205	
201498	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	205	
201499	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
201500	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
201501	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
201502	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
201503	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
201504	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
201505	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		
201506	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
201507	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
201508	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
201509	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
201510	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
201511	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201512	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201513	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201514	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201515	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	75.0	
201516	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	84.0	
201517	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	136.0	
201518	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201519	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201520	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201521	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	5	
201522	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
201523	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
201524	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
201525	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
201526	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201527	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
201528	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
201529	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
201530	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
201531	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
201532	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
201533	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
201534	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201535	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201536	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201537	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201538	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
201539	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
201540	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
201541	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
201542	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
201543	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
201544	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201545	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201546	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201547	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201548	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
201549	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
201550	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
201551	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
201552	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
201553	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
201554	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	75.0	
201555	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	70.0	
201556	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
201557	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
201558	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
201559	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
201560	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
201561	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
201562	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2003	
201563	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
201564	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
201565	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
201566	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
201567	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	60.0	
201568	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201569	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
201570	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
201571	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
201572	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
201573	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
201574	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201575	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201576	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	9	
201577	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
201578	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
201579	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
201580	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
201581	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
201582	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
201583	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	5	
201584	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
201585	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	5	
201586	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	913	
201587	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	909	
201588	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
201589	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
201590	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
201591	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
201592	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
201593	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
201594	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
201595	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
201596	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
201597	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201598	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201599	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201600	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201601	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201602	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
201603	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
201604	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
201605	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
201606	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
201607	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
201608	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
201609	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
201610	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
201611	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201612	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201613	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
201614	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
201615	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
201616	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
201617	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
201618	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
201619	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
201620	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
201621	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
201622	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
201623	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
201624	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
201625	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
201626	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201627	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201628	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
201629	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
201630	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
201631	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201632	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
201633	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
201634	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
201635	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
201636	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
201637	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
201638	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
201639	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
201640	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
201641	9/12/2019 10:05	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
201642	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
201643	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201644	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	101	*F
201645	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
201646	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201647	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201648	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
201649	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
201650	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
201651	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
201652	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201653	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201654	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201655	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201656	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201657	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
201658	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201659	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
201660	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
201661	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
201662	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
201663	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
201664	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
201665	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
201666	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
201667	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
201668	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	599	
201669	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	599	
201670	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
201671	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
201672	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
201673	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
201674	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
201675	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
201676	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201677	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
201678	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
201679	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
201680	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	620.0	
201681	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	637.0	
201682	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	650.0	
201683	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
201684	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
201685	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
201686	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
201687	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
201688	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
201689	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
201690	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
201691	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	229	
201692	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
201693	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
201694	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
201695	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
201696	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
201697	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
201698	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
201699	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
201700	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
201701	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
201702	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
201703	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
201704	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
201705	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
201706	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
201707	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
201708	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
201709	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
201710	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
201711	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	229	
201712	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
201713	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments	Open	
201714	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
201715	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
201716	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
201717	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
201718	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
201719	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
201720	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
201721	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
201722	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
201723	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201724	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
201725	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
201726	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
201727	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
201728	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
201729	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
201730	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
201731	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
201732	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
201733	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
201734	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
201735	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201736	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201737	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
201738	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
201739	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201740	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
201741	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201742	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
201743	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.41	%
201744	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	19.41	%
201745	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	19.41	%
201746	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	199.0	
201747	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	184.0	
201748	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	179.0	
201749	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
201750	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
201751	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
201752	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
201753	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
201754	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
201755	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
201756	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
201757	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
201758	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	1	
201759	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1191	
201760	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1191	
201761	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
201762	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
201763	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
201764	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
201765	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
201766	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
201767	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
201768	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	1	
201769	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	1	
201770	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
201771	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
201772	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
201773	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
201774	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
201775	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
201776	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
201777	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
201778	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
201779	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
201780	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
201781	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	191	
201782	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	191	
201783	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
201784	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
201785	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
201786	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
201787	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
201788	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
201789	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
201790	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
201791	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	70	*C
201792	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	79	*C
201793	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1760	
201794	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
201795	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
201796	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
201797	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
201798	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
201799	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
201800	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
201801	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
201802	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
201803	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
201804	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
201805	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
201806	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
201807	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
201808	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
201809	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
201810	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
201811	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
201812	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
201813	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
201814	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	60	*C
201815	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	77	*C
201816	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
201817	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
201818	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	11289.60	kw
201819	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
201820	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
201821	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
201822	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201823	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
201824	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
201825	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
201826	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201827	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
201828	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
201829	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
201830	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
201831	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
201832	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
201833	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
201834	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
201835	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
201836	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
201837	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
201838	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
201839	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
201840	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
201841	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
201842	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	100	°C
201843	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
201844	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
201845	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
201846	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
201847	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
201848	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
201849	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
201850	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
201851	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4320.00	kw
201852	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
201853	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
201854	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
201855	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
201856	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
201857	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
201858	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
201859	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
201860	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
201861	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
201862	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
201863	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
201864	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4500	
201865	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
201866	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
201867	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
201868	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
201869	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
201870	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
201871	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
201872	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
201873	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
201874	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
201875	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	102	
201876	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
201877	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
201878	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
201879	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
201880	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
201881	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
201882	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
201883	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
201884	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
201885	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
201886	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
201887	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
201888	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
201889	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
201890	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
201891	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
201892	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
201893	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201894	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
201895	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
201896	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	87954	
201897	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	87954	
201898	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	102	
201899	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	3	
201900	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	0	
201901	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	3	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201902	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
201903	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
201904	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
201905	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
201906	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
201907	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
201908	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
201909	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
201910	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
201911	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
201912	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
201913	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
201914	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
201915	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
201916	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
201917	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
201918	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
201919	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
201920	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
201921	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
201922	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	240.0	
201923	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	230.0	
201924	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	200.0	
201925	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
201926	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
201927	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
201928	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	3	
201929	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
201930	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
201931	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
201932	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
201933	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
201934	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
201935	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
201936	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
201937	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
201938	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
201939	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
201940	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
201941	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
201942	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	101	*F
201943	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
201944	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
201945	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
201946	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
201947	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
201948	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
201949	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
201950	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
201951	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
201952	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	18	
201953	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
201954	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
201955	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
201956	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	4	
201957	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
201958	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	4	
201959	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	272	
201960	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	268	
201961	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
201962	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
201963	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
201964	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
201965	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	100.0	
201966	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	100.0	
201967	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	100.0	
201968	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
201969	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
201970	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
201971	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
201972	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
201973	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
201974	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
201975	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
201976	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
201977	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
201978	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
201979	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
201980	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
201981	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
201982	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
201983	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
201984	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	394	
201985	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	394	
201986	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	0	
201987	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
201988	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
201989	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
201990	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
201991	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
201992	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
201993	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
201994	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
201995	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
201996	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
201997	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
201998	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
201999	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
202000	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
202001	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
202002	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
202003	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
202004	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
202005	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
202006	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
202007	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
202008	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
202009	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
202010	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
202011	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
202012	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
202013	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
202014	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
202015	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
202016	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
202017	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
202018	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1929.60	kw
202019	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
202020	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
202021	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
202022	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
202023	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
202024	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
202025	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
202026	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
202027	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
202028	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
202029	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
202030	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
202031	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
202032	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
202033	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202034	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
202035	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
202036	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202037	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
202038	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	4	
202039	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
202040	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	419	
202041	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	419	
202042	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
202043	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-11 00:00:00.000000	
202044	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
202045	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
202046	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
202047	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202048	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202049	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202050	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202051	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202052	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202053	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
202054	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
202055	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
202056	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
202057	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202058	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202059	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
202060	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR-1 needs nitrogen	
202061	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202062	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	55	°C
202063	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	55	°C
202064	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202065	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
202066	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
202067	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
202068	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202069	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
202070	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
202071	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202072	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202073	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
202074	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
202075	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
202076	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
202077	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202078	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
202079	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202080	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202081	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202082	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202083	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202084	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202085	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
202086	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
202087	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
202088	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202089	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202090	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202091	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202092	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
202093	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202094	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202095	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
202096	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
202097	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
202098	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	65	°C
202099	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
202100	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
202101	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	84	°C
202102	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
202103	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	3	
202104	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
202105	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202106	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202107	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202108	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202109	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	220.0	
202110	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	230.0	
202111	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	215.0	
202112	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202113	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
202114	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202115	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202116	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
202117	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
202118	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
202119	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
202120	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
202121	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
202122	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202123	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202124	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
202125	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
202126	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
202127	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202128	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202129	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202130	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
202131	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202132	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202133	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202134	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202135	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
202136	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
202137	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
202138	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
202139	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	5	
202140	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202141	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
202142	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	357	
202143	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	357	
202144	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations This Read Oil	0	
202145	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
202146	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
202147	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
202148	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
202149	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202150	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
202151	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202152	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202153	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	100.0	
202154	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	95.0	
202155	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
202156	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
202157	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
202158	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
202159	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
202160	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
202161	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	10	
202162	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
202163	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	14	
202164	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	297	
202165	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	287	
202166	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
202167	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
202168	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
202169	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
202170	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
202171	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
202172	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
202173	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
202174	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
202175	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
202176	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
202177	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
202178	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
202179	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	87	*F
202180	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
202181	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
202182	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
202183	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
202184	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
202185	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
202186	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
202187	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
202188	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
202189	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
202190	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
202191	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
202192	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
202193	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
202194	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
202195	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
202196	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
202197	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
202198	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
202199	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
202200	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
202201	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202202	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
202203	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202204	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202205	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202206	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202207	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202208	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202209	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202210	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
202211	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
202212	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
202213	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
202214	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202215	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202216	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
202217	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
202218	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202219	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	4829.76	kw
202220	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202221	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
202222	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	62	°C
202223	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	40	°C
202224	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
202225	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments	A Phase IOC	
202226	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
202227	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	591	
202228	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	591	
202229	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	4	
202230	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
202231	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
202232	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
202233	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
202234	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
202235	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
202236	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202237	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202238	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202239	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202240	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202241	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
202242	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
202243	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
202244	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
202245	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
202246	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
202247	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
202248	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202249	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
202250	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
202251	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
202252	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
202253	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1079	
202254	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1079	
202255	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
202256	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
202257	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	General Comments		
202258	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
202259	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
202260	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
202261	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
202262	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	Need size info and qty
202263	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
202264	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
202265	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
202266	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	25	
202267	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202268	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202269	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202270	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	204.0	
202271	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	208.0	
202272	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	200.0	
202273	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	9	
202274	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202275	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202276	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202277	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	30.0	
202278	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	30.0	
202279	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	30.0	
202280	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
202281	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
202282	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
202283	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
202284	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
202285	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
202286	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202287	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	1.48	
202288	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202289	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202290	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202291	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	1	
202292	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
202293	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
202294	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
202295	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
202296	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
202297	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
202298	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202299	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202300	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
202301	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments		
202302	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
202303	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
202304	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
202305	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
202306	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
202307	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
202308	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
202309	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
202310	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
202311	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	0	
202312	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	449	
202313	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	449	
202314	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
202315	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
202316	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
202317	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
202318	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
202319	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
202320	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
202321	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	0	
202322	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
202323	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202324	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202325	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
202326	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202327	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	46.0	
202328	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
202329	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
202330	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202331	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
202332	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202333	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202334	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202335	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202336	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202337	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202338	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
202339	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202340	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202341	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
202342	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	54	°C
202343	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
202344	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	54	°C
202345	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
202346	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
202347	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
202348	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	1	
202349	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
202350	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	1	
202351	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	343	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202352	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	343	
202353	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
202354	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
202355	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
202356	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
202357	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
202358	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
202359	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
202360	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
202361	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
202362	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
202363	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
202364	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
202365	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202366	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	76.0	
202367	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	110.0	
202368	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	97.0	
202369	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202370	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202371	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202372	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	1	
202373	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
202374	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202375	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202376	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
202377	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202378	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202379	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202380	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202381	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
202382	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	52	°C
202383	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1850	psi
202384	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
202385	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202386	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202387	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
202388	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
202389	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202390	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202391	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
202392	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
202393	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
202394	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202395	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202396	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202397	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202398	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202399	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
202400	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
202401	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
202402	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
202403	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
202404	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
202405	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
202406	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
202407	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
202408	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
202409	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
202410	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
202411	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
202412	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
202413	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
202414	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
202415	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
202416	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
202417	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
202418	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
202419	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
202420	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
202421	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202422	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202423	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202424	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202425	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202426	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202427	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	top rail rusty .bottom of alot of the fence has a large gap	
202428	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
202429	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
202430	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202431	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202432	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202433	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202434	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	5	
202435	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
202436	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	4	
202437	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
202438	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202439	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202440	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
202441	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
202442	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
202443	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	70	
202444	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	73	
202445	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	
202446	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	
202447	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	
202448	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	
202449	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
202450	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
202451	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202452	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
202453	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202454	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
202455	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202456	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202457	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202458	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202459	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
202460	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
202461	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	
202462	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	
202463	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	
202464	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	
202465	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202466	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
202467	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
202468	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202469	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202470	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
202471	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
202472	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
202473	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
202474	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
202475	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
202476	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202477	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202478	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202479	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202480	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202481	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202482	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
202483	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
202484	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	56.0	
202485	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	20.0	
202486	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
202487	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
202488	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
202489	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	8	
202490	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
202491	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
202492	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
202493	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	30	
202494	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	34	
202495	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
202496	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
202497	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202498	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
202499	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202500	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
202501	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202502	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
202503	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
202504	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
202505	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202506	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202507	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202508	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202509	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202510	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
202511	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202512	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202513	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202514	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
202515	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
202516	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
202517	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
202518	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
202519	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
202520	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
202521	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
202522	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
202523	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
202524	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
202525	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
202526	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
202527	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
202528	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	112	
202529	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
202530	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
202531	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
202532	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
202533	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
202534	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
202535	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
202536	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
202537	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
202538	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
202539	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
202540	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
202541	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	33.97	%
202542	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	30	
202543	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
202544	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
202545	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	0	
202546	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2466	
202547	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2466	
202548	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
202549	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments		
202550	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
202551	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
202552	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
202553	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	0	
202554	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	0	
202555	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
202556	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
202557	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
202558	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	340.0	
202559	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	320.0	
202560	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	300.0	
202561	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
202562	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
202563	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
202564	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	15	
202565	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
202566	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
202567	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
202568	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	934	
202569	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	934	
202570	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
202571	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
202572	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	General Comments		
202573	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
202574	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
202575	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
202576	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202577	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
202578	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	General Comments		
202579	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
202580	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTC0000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
202581	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
202582	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
202583	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
202584	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
202585	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
202586	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
202587	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
202588	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
202589	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	251675	
202590	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	748	
202591	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
202592	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
202593	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	8L	
202594	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
202595	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
202596	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	2L	
202597	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
202598	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	7L	
202599	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	1088	
202600	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
202601	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
202602	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
202603	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
202604	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8040	
202605	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	59	°C
202606	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
202607	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	4L	
202608	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
202609	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	10462	
202610	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	10462	
202611	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202612	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202613	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
202614	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
202615	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
202616	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
202617	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
202618	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
202619	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
202620	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
202621	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
202622	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
202623	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
202624	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
202625	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	157	
202626	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	159	
202627	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	2	
202628	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	2	
202629	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
202630	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
202631	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	29	
202632	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.92	%
202633	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.56	%
202634	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
202635	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	137.0	
202636	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	154.0	
202637	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	151.0	
202638	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
202639	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
202640	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
202641	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
202642	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
202643	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
202644	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
202645	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
202646	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202647	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	23	
202648	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	
202649	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	6	
202650	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1330	
202651	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1330	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202652	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	6	
202653	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
202654	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
202655	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202656	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
202657	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
202658	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
202659	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
202660	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
202661	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
202662	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
202663	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1061	
202664	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1061	
202665	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	1	
202666	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	---	
202667	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
202668	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
202669	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
202670	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
202671	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
202672	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
202673	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
202674	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
202675	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	162.0	
202676	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
202677	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	251675	
202678	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	181.0	
202679	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	170.0	
202680	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	50.96	%
202681	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	63.1	%
202682	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
202683	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	A couple of trees are starting to have some limbs to grow over the top of the fence line at the back of the station.	
202684	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
202685	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
202686	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
202687	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
202688	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
202689	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
202690	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
202691	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
202692	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
202693	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
202694	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
202695	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
202696	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
202697	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
202698	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202699	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
202700	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
202701	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202702	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
202703	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
202704	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202705	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202706	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202707	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202708	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202709	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
202710	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
202711	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202712	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202713	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202714	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
202715	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202716	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202717	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
202718	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
202719	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
202720	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
202721	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	16312	
202722	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	16312	
202723	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
202724	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
202725	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
202726	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202727	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
202728	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1861	
202729	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202730	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202731	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202732	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
202733	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202734	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202735	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202736	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202737	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	35	°C
202738	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	45	°C
202739	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
202740	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
202741	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202742	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	5074.56	kw
202743	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202744	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
202745	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
202746	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202747	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202748	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
202749	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
202750	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
202751	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
202752	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
202753	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
202754	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
202755	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
202756	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
202757	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
202758	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202759	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
202760	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
202761	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202762	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
202763	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
202764	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202765	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	2	
202766	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202767	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202768	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202769	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	52.0	
202770	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	36.0	
202771	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	35.0	
202772	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202773	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202774	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202775	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202776	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202777	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase....one structure leg foundation is crumbling and another is starting to	
202778	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
202779	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
202780	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
202781	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202782	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
202783	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	2	
202784	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
202785	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
202786	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
202787	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
202788	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
202789	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments	B Phase IOC	
202790	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202791	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202792	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202793	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
202794	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202795	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
202796	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	212	
202797	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	212	
202798	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	2	
202799	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	0	
202800	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
202801	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202802	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202803	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202804	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
202805	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
202806	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	30	°C
202807	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	40	°C
202808	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
202809	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
202810	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
202811	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
202812	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.0572	
202813	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
202814	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202815	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
202816	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
202817	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
202818	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
202819	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
202820	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
202821	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
202822	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
202823	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
202824	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
202825	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
202826	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
202827	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	55	°C
202828	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202829	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202830	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202831	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202832	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
202833	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
202834	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
202835	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
202836	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
202837	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
202838	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interrupters/Puffrs Visual OK?	y	
202839	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
202840	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
202841	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
202842	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202843	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
202844	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202845	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202846	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
202847	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.7158	
202848	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
202849	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
202850	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
202851	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
202852	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
202853	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
202854	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
202855	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
202856	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202857	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202858	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
202859	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	78.0	
202860	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
202861	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	75.0	
202862	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202863	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202864	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202865	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202866	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202867	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202868	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
202869	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
202870	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
202871	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
202872	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
202873	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
202874	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
202875	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
202876	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202877	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
202878	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
202879	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
202880	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
202881	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
202882	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
202883	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
202884	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
202885	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
202886	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
202887	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
202888	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
202889	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
202890	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
202891	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
202892	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
202893	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
202894	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
202895	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
202896	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
202897	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
202898	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
202899	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
202900	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	115.0	
202901	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
202902	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
202903	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
202904	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
202905	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
202906	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
202907	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
202908	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
202909	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	2	
202910	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
202911	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
202912	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
202913	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
202914	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
202915	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
202916	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
202917	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
202918	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
202919	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
202920	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
202921	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
202922	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
202923	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
202924	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
202925	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
202926	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
202927	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
202928	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
202929	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
202930	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
202931	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
202932	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
202933	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
202934	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202935	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
202936	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
202937	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
202938	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
202939	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
202940	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
202941	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
202942	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	3435.84	kw
202943	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
202944	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
202945	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
202946	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
202947	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	.6708	
202948	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
202949	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
202950	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
202951	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
202952	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
202953	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
202954	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
202955	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
202956	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
202957	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
202958	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
202959	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
202960	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
202961	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
202962	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
202963	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0053	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
202964	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
202965	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
202966	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	712	
202967	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	712	
202968	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
202969	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
202970	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
202971	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
202972	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
202973	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
202974	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
202975	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
202976	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	40.04	%
202977	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	65	
202978	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
202979	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
202980	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
202981	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
202982	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
202983	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
202984	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
202985	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
202986	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	157	
202987	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	159	
202988	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	3	
202989	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	3	
202990	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
202991	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
202992	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	4	
202993	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
202994	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
202995	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
202996	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	95.0	
202997	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	75.0	
202998	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	60.0	
202999	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
203000	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
203001	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
203002	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
203003	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
203004	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
203005	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203006	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
203007	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203008	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203009	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203010	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203011	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203012	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
203013	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	390.0	
203014	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	486.0	
203015	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	442.0	
203016	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203017	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203018	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203019	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
203020	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	2	
203021	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203022	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203023	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203024	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	55.0	
203025	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	94.0	
203026	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	83.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203027	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
203028	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203029	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203030	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203031	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
203032	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
203033	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
203034	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203035	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
203036	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
203037	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
203038	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
203039	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
203040	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
203041	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
203042	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
203043	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
203044	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
203045	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
203046	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
203047	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
203048	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
203049	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
203050	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
203051	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
203052	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
203053	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
203054	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
203055	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
203056	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
203057	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
203058	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
203059	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
203060	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
203061	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
203062	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
203063	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
203064	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203065	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203066	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
203067	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
203068	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
203069	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	582	
203070	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	582	
203071	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203072	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0306	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203073	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203074	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203075	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
203076	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	123	
203077	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	123	
203078	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	2	
203079	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
203080	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203081	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
203082	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
203083	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
203084	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
203085	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
203086	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
203087	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
203088	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203089	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203090	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203091	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203092	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203093	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203094	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203095	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	165.0	
203096	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	180.0	
203097	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	202.0	
203098	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	18.2	%
203099	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	43.68	%
203100	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
203101	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203102	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
203103	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
203104	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
203105	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Readings	General Comments		
203106	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
203107	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203108	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
203109	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203110	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203111	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203112	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
203113	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
203114	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
203115	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
203116	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203117	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203118	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
203119	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203120	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203121	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
203122	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203123	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
203124	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203125	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203126	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
203127	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
203128	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
203129	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
203130	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
203131	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
203132	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
203133	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
203134	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
203135	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
203136	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
203137	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
203138	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
203139	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BAT000179	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
203140	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	C Phase IOC	
203141	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203142	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1287	
203143	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1287	
203144	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
203145	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203146	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0303	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203147	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203148	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203149	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
203150	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	109	
203151	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	109	
203152	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203153	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203154	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203155	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203156	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203157	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203158	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203159	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203160	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
203161	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
203162	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
203163	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
203164	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
203165	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
203166	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
203167	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
203168	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
203169	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
203170	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
203171	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	166	
203172	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	166	
203173	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	1	
203174	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	1	
203175	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
203176	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	27	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
203177	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203178	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203179	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203180	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
203181	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
203182	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
203183	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
203184	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203185	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203186	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203187	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203188	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203189	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203190	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203191	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
203192	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203193	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203194	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203195	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203196	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
203197	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
203198	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
203199	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
203200	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1798	
203201	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
203202	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
203203	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
203204	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
203205	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	73537	
203206	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	73537	
203207	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
203208	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
203209	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
203210	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
203211	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
203212	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
203213	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
203214	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
203215	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1858	
203216	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
203217	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
203218	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
203219	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
203220	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
203221	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	54976	
203222	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	54976	
203223	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
203224	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
203225	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
203226	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
203227	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	892	
203228	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	892	
203229	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
203230	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	7R	
203231	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	4R	
203232	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
203233	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	36178	
203234	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	36178	
203235	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
203236	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments		
203237	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
203238	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
203239	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	4	
203240	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203241	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203242	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203243	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	138.0	
203244	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	165.0	
203245	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	137.0	
203246	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
203247	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
203248	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
203249	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
203250	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
203251	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203252	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203253	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
203254	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
203255	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
203256	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
203257	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
203258	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
203259	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
203260	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
203261	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
203262	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
203263	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
203264	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
203265	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
203266	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
203267	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
203268	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	164	
203269	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	165	
203270	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	1	
203271	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	1	
203272	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
203273	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
203274	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
203275	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	93	*F
203276	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
203277	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
203278	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
203279	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
203280	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
203281	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
203282	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
203283	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
203284	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
203285	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
203286	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
203287	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
203288	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
203289	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
203290	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
203291	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
203292	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
203293	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
203294	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
203295	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
203296	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
203297	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203298	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203299	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	148.0	
203300	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	144.0	
203301	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	162.0	
203302	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.35	%
203303	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	20.63	%
203304	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.99	%
203305	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	64	
203306	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
203307	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
203308	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
203309	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
203310	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
203311	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
203312	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
203313	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
203314	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
203315	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
203316	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
203317	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
203318	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
203319	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
203320	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
203321	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
203322	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
203323	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
203324	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
203325	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
203326	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203327	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
203328	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
203329	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
203330	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
203331	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
203332	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
203333	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
203334	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
203335	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
203336	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
203337	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
203338	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
203339	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
203340	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
203341	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
203342	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
203343	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
203344	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
203345	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
203346	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
203347	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
203348	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
203349	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
203350	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
203351	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
203352	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	1038	
203353	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
203354	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	3L	
203355	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
203356	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
203357	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
203358	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
203359	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
203360	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
203361	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
203362	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
203363	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
203364	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
203365	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
203366	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
203367	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
203368	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
203369	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
203370	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203371	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203372	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
203373	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1071	
203374	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1071	
203375	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	3	
203376	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
203377	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203378	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203379	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203380	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203381	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203382	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203383	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203384	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	30	
203385	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.4	%
203386	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	10.4	%
203387	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203388	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	166.0	
203389	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	176.0	
203390	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	167.0	
203391	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
203392	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	16.99	%
203393	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.28	%
203394	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
203395	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.4	%
203396	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
203397	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
203398	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
203399	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203400	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203401	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203402	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203403	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203404	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203405	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203406	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203407	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
203408	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	1	
203409	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	955	
203410	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	955	
203411	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
203412	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203413	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203414	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	17	
203415	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	3.64	%
203416	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	3.64	%
203417	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
203418	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
203419	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
203420	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
203421	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
203422	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
203423	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
203424	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
203425	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
203426	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
203427	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	4	
203428	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
203429	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
203430	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
203431	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
203432	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	General Comments		
203433	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
203434	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
203435	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
203436	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
203437	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
203438	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
203439	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
203440	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
203441	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
203442	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
203443	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
203444	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
203445	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
203446	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
203447	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
203448	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
203449	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
203450	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
203451	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
203452	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
203453	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
203454	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
203455	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	General Comments		
203456	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
203457	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
203458	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
203459	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
203460	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	LTC0000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
203461	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	100.00	
203462	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
203463	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.9168	
203464	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
203465	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
203466	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
203467	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
203468	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
203469	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
203470	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
203471	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
203472	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	50	°C
203473	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	60	°C
203474	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
203475	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
203476	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	4400.64	kw

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203477	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
203478	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
203479	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
203480	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	126.0	
203481	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	99.0	
203482	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203483	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203484	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203485	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	2	
203486	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
203487	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
203488	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
203489	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
203490	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
203491	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
203492	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
203493	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
203494	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
203495	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-26 00:00:00.000000	
203496	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
203497	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
203498	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
203499	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
203500	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
203501	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
203502	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	1	
203503	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203504	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203505	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203506	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	411.0	
203507	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	350.0	
203508	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	325.0	
203509	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
203510	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
203511	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
203512	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
203513	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
203514	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
203515	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
203516	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
203517	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
203518	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
203519	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
203520	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
203521	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
203522	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
203523	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
203524	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
203525	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
203526	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
203527	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
203528	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
203529	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
203530	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
203531	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
203532	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203533	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
203534	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
203535	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
203536	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
203537	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
203538	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
203539	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
203540	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
203541	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
203542	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203543	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	270.0	
203544	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	480.0	
203545	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	400.0	
203546	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203547	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203548	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203549	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
203550	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
203551	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203552	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
203553	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
203554	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments		
203555	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
203556	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	418	
203557	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	418	
203558	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	0	
203559	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
203560	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
203561	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
203562	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
203563	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
203564	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
203565	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
203566	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
203567	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
203568	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
203569	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
203570	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
203571	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
203572	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
203573	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	LTC0000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
203574	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
203575	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
203576	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	1	
203577	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
203578	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	1	
203579	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	210	
203580	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	210	
203581	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
203582	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
203583	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
203584	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
203585	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
203586	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
203587	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
203588	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
203589	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
203590	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
203591	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
203592	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
203593	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
203594	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
203595	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
203596	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
203597	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203598	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
203599	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
203600	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
203601	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
203602	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
203603	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
203604	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	108.0	
203605	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	44	°C
203606	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
203607	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
203608	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
203609	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
203610	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
203611	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
203612	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
203613	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
203614	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
203615	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
203616	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
203617	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203618	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
203619	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
203620	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	133	
203621	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	133	
203622	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203623	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203624	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203625	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203626	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203627	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203628	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203629	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203630	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203631	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203632	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203633	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203634	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
203635	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	69.0	%
203636	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	88.0	%
203637	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	65.0	%
203638	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203639	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203640	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203641	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	20	
203642	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
203643	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
203644	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	0	
203645	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	3	
203646	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	181	
203647	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	181	
203648	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
203649	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
203650	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
203651	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203652	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203653	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
203654	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	574	
203655	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	574	
203656	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	2	
203657	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
203658	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203659	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203660	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203661	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203662	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203663	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203664	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203665	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203666	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	158.0	
203667	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
203668	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
203669	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
203670	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
203671	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
203672	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
203673	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	.9444	
203674	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
203675	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
203676	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
203677	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
203678	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
203679	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
203680	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
203681	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
203682	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
203683	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
203684	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
203685	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
203686	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
203687	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
203688	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
203689	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
203690	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
203691	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
203692	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
203693	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
203694	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
203695	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
203696	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
203697	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
203698	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	66	°C
203699	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	43	°C
203700	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
203701	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203702	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
203703	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
203704	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
203705	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
203706	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
203707	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
203708	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
203709	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	57	°C
203710	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	36	°C
203711	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
203712	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
203713	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
203714	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
203715	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
203716	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
203717	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
203718	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
203719	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
203720	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
203721	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
203722	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	93	°F
203723	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
203724	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
203725	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
203726	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
203727	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	44	°C
203728	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	71	°C
203729	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
203730	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
203731	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
203732	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
203733	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
203734	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
203735	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
203736	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
203737	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	50	
203738	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203739	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203740	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
203741	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
203742	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
203743	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
203744	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
203745	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
203746	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
203747	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
203748	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
203749	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
203750	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203751	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203752	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
203753	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203754	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203755	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203756	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203757	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
203758	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
203759	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
203760	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
203761	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
203762	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
203763	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
203764	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
203765	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
203766	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
203767	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
203768	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
203769	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
203770	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
203771	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
203772	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
203773	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
203774	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
203775	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
203776	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
203777	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
203778	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
203779	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
203780	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
203781	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
203782	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
203783	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
203784	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
203785	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
203786	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
203787	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
203788	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
203789	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
203790	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
203791	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
203792	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
203793	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
203794	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
203795	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	145.0	
203796	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	147.0	
203797	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
203798	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
203799	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
203800	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	23	
203801	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
203802	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
203803	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
203804	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
203805	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LTC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
203806	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments		
203807	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
203808	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
203809	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
203810	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
203811	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
203812	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	2	
203813	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
203814	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
203815	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
203816	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
203817	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
203818	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
203819	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
203820	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
203821	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
203822	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
203823	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
203824	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
203825	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
203826	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
203827	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
203828	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	1	
203829	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
203830	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
203831	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
203832	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203833	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
203834	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
203835	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
203836	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
203837	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
203838	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
203839	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	219.0	
203840	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	218.0	
203841	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	187.0	
203842	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203843	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203844	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203845	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	11	
203846	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
203847	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
203848	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
203849	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
203850	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
203851	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203852	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
203853	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
203854	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
203855	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
203856	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
203857	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
203858	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
203859	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
203860	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
203861	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
203862	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
203863	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
203864	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
203865	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
203866	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments		
203867	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
203868	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
203869	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
203870	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
203871	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
203872	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_sprayed	
203873	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
203874	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
203875	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
203876	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
203877	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
203878	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
203879	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
203880	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203881	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
203882	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
203883	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	49	
203884	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	49	
203885	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203886	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
203887	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203888	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
203889	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
203890	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
203891	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
203892	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
203893	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203894	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
203895	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203896	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
203897	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
203898	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
203899	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
203900	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
203901	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
203902	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
203903	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
203904	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
203905	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	..	
203906	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
203907	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
203908	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
203909	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
203910	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
203911	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
203912	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
203913	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
203914	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
203915	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
203916	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
203917	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
203918	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
203919	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
203920	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
203921	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
203922	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
203923	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
203924	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
203925	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
203926	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
203927	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
203928	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
203929	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
203930	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
203931	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
203932	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
203933	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
203934	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	y	
203935	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
203936	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
203937	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
203938	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
203939	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
203940	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
203941	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
203942	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
203943	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	5	
203944	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	5	
203945	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	249	
203946	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	249	
203947	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
203948	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
203949	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
203950	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
203951	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
203952	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
203953	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
203954	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
203955	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
203956	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
203957	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
203958	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
203959	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
203960	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
203961	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
203962	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
203963	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
203964	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
203965	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
203966	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	21	
203967	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
203968	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
203969	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
203970	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
203971	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
203972	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
203973	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
203974	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
203975	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
203976	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
203977	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
203978	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
203979	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
203980	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
203981	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
203982	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
203983	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
203984	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
203985	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
203986	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
203987	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
203988	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
203989	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
203990	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	135	
203991	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	135	
203992	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
203993	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B Phase IOC	
203994	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
203995	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
203996	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
203997	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
203998	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
203999	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
204000	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
204001	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204002	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
204003	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
204004	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
204005	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	65.0	
204006	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	65.0	
204007	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	65.0	
204008	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
204009	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
204010	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
204011	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	46	
204012	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
204013	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
204014	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
204015	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
204016	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
204017	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
204018	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
204019	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
204020	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
204021	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
204022	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
204023	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
204024	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
204025	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
204026	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
204027	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
204028	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
204029	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
204030	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
204031	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
204032	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
204033	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
204034	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	9066.24	kw
204035	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
204036	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
204037	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	48	°C
204038	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	48	°C
204039	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
204040	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
204041	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
204042	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
204043	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
204044	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
204045	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
204046	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
204047	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
204048	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
204049	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
204050	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
204051	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
204052	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	320.0	
204053	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
204054	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
204055	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
204056	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
204057	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	40	
204058	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
204059	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
204060	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	0	
204061	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	0	
204062	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	200	
204063	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	200	
204064	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
204065	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
204066	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
204067	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
204068	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
204069	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
204070	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
204071	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
204072	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
204073	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
204074	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
204075	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
204076	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
204077	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204078	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204079	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204080	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
204081	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
204082	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
204083	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
204084	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
204085	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
204086	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	211.0	
204087	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	216.0	
204088	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	234.0	
204089	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204090	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204091	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204092	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	70	
204093	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
204094	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
204095	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
204096	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
204097	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
204098	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
204099	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
204100	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
204101	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
204102	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
204103	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
204104	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
204105	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
204106	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	141	
204107	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	141	
204108	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
204109	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204110	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
204111	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
204112	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
204113	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
204114	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
204115	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
204116	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
204117	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
204118	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204119	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204120	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204121	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204122	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
204123	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
204124	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
204125	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204126	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204127	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204128	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
204129	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
204130	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
204131	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
204132	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
204133	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
204134	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
204135	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204136	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
204137	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
204138	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
204139	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
204140	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
204141	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
204142	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
204143	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
204144	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204145	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204146	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204147	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204148	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
204149	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
204150	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
204151	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
204152	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204153	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204154	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
204155	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204156	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
204157	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
204158	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204159	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204160	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204161	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
204162	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
204163	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
204164	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204165	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58164	
204166	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
204167	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
204168	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
204169	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
204170	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204171	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204172	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
204173	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
204174	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
204175	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
204176	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204177	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
204178	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
204179	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	153	
204180	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	153	
204181	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
204182	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204183	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
204184	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
204185	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
204186	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
204187	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
204188	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
204189	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
204190	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
204191	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204192	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204193	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
204194	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
204195	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204196	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
204197	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
204198	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204199	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204200	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204201	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204202	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204203	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	778.0	
204204	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	685.0	
204205	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	703.0	
204206	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204207	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204208	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204209	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	0	
204210	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
204211	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
204212	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
204213	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204214	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62061	
204215	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
204216	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
204217	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
204218	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204219	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204220	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
204221	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
204222	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
204223	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
204224	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204225	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
204226	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204227	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
204228	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
204229	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	0	
204230	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	151	
204231	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	151	
204232	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
204233	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204234	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
204235	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
204236	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
204237	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
204238	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
204239	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
204240	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
204241	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
204242	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204243	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204244	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204245	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204246	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	195.0	
204247	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	160.0	
204248	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	178.0	
204249	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204250	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204251	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204252	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	13	
204253	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204254	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	8	
204255	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	45	
204256	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	67.06	%
204257	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	65.4	%
204258	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	62.63	%
204259	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	149.0	
204260	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	145.0	
204261	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	145.0	
204262	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204263	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204264	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204265	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
204266	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
204267	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
204268	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
204269	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
204270	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
204271	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
204272	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
204273	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
204274	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
204275	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	161	
204276	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	161	
204277	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	0	
204278	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
204279	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	
204280	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	145	
204281	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	145	
204282	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
204283	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204284	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
204285	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
204286	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
204287	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
204288	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
204289	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
204290	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1-A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
204291	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
204292	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
204293	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations This Read Vac	0	
204294	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	120	
204295	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	120	
204296	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
204297	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204298	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
204299	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
204300	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
204301	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204302	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	
204303	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
204304	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
204305	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
204306	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204307	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204308	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204309	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204310	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	222.0	
204311	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	227.0	
204312	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	221.0	
204313	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204314	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204315	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204316	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
204317	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
204318	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
204319	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204320	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204321	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
204322	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
204323	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
204324	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
204325	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204326	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
204327	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
204328	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204329	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
204330	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
204331	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204332	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204333	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204334	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
204335	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
204336	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
204337	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204338	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204339	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204340	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204341	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
204342	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
204343	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
204344	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
204345	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
204346	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
204347	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	30.0	
204348	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	45.0	
204349	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	45.0	
204350	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204351	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204352	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
204353	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
204354	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
204355	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
204356	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
204357	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
204358	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
204359	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
204360	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
204361	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
204362	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
204363	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
204364	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
204365	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
204366	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	71477	
204367	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	71480	
204368	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
204369	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	4L	
204370	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
204371	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	8L	
204372	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	477	
204373	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
204374	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
204375	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
204376	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204377	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
204378	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204379	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
204380	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
204381	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
204382	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
204383	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
204384	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
204385	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	31361	
204386	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	31361	
204387	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
204388	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
204389	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
204390	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2281	
204391	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
204392	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
204393	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204394	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
204395	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
204396	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
204397	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
204398	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204399	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204400	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
204401	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
204402	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
204403	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42672	
204404	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204405	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
204406	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
204407	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
204408	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204409	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204410	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204411	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
204412	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
204413	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204414	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
204415	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
204416	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
204417	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
204418	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
204419	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
204420	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
204421	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
204422	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
204423	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
204424	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
204425	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
204426	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	91	°F
204427	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
204428	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
204429	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204430	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44205	
204431	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
204432	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
204433	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
204434	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204435	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204436	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
204437	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
204438	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
204439	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
204440	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204441	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
204442	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
204443	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
204444	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
204445	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
204446	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204447	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204448	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204449	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
204450	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
204451	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204452	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
204453	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
204454	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	11880	
204455	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	11886	
204456	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
204457	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	3L	
204458	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	3L	
204459	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	3L	
204460	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	454	
204461	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
204462	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
204463	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
204464	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
204465	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
204466	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
204467	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
204468	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
204469	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
204470	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
204471	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
204472	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
204473	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
204474	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
204475	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
204476	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
204477	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
204478	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
204479	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
204480	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC0000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
204481	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	0	
204482	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
204483	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
204484	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
204485	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
204486	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
204487	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
204488	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
204489	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
204490	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
204491	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
204492	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
204493	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
204494	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
204495	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
204496	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
204497	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
204498	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
204499	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
204500	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	3870.72	kw
204501	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
204502	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
204503	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
204504	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
204505	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
204506	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
204507	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
204508	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
204509	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
204510	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
204511	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Top Oil Temperature Present	45	°C
204512	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
204513	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	1.2096	
204514	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Max	54	°C
204515	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	54	°C
204516	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
204517	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
204518	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
204519	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
204520	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	4	
204521	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
204522	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	4	
204523	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	294	
204524	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	290	
204525	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
204526	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204527	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204528	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
204529	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
204530	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
204531	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
204532	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
204533	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
204534	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
204535	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
204536	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
204537	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
204538	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204539	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57260	
204540	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
204541	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
204542	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
204543	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
204544	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
204545	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
204546	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
204547	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
204548	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
204549	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
204550	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
204551	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49541	
204552	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
204553	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
204554	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
204555	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	6	
204556	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204557	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204558	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204559	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
204560	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	0.0	
204561	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
204562	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204563	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204564	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204565	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204566	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
204567	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
204568	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
204569	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
204570	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
204571	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
204572	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
204573	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
204574	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
204575	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
204576	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
204577	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
204578	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
204579	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
204580	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
204581	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
204582	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
204583	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
204584	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		
204585	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
204586	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	197	
204587	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	197	
204588	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	0	
204589	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
204590	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
204591	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
204592	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
204593	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
204594	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
204595	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
204596	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
204597	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
204598	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
204599	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
204600	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	General Comments		
204601	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204602	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	LTC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
204603	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
204604	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
204605	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
204606	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
204607	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
204608	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
204609	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
204610	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
204611	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
204612	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
204613	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
204614	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
204615	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
204616	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
204617	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
204618	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
204619	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
204620	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
204621	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
204622	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
204623	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
204624	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	106	
204625	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
204626	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
204627	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
204628	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
204629	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
204630	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
204631	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
204632	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
204633	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
204634	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
204635	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
204636	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
204637	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
204638	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	57.0	
204639	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
204640	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
204641	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204642	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204643	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204644	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
204645	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
204646	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	118.0	
204647	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
204648	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
204649	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
204650	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
204651	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
204652	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
204653	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204654	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	17.75	
204655	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	17.75	
204656	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	17.75	
204657	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
204658	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
204659	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
204660	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	4	
204661	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
204662	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
204663	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
204664	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
204665	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
204666	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
204667	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
204668	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
204669	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
204670	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
204671	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
204672	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
204673	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
204674	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
204675	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
204676	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204677	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
204678	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
204679	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	130	
204680	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	130	
204681	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
204682	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
204683	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
204684	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	23	
204685	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	8.87	%
204686	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	11.64	%
204687	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	7.2	%
204688	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	116.0	
204689	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	124.0	
204690	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	114.0	
204691	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204692	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204693	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204694	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
204695	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
204696	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
204697	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
204698	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
204699	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
204700	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
204701	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	72	
204702	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	72	
204703	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	0	
204704	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
204705	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
204706	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
204707	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
204708	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.200	millivolts
204709	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
204710	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.4074	
204711	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
204712	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
204713	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
204714	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
204715	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
204716	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
204717	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
204718	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
204719	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	40	°C
204720	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	60	°C
204721	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
204722	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
204723	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	3911.04	kw
204724	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
204725	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Readings	General Comments		
204726	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
204727	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	00233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
204728	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
204729	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
204730	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
204731	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
204732	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
204733	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	232021	
204734	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	232021	
204735	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
204736	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	2R	
204737	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	3R	
204738	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
204739	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	791	
204740	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
204741	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
204742	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
204743	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
204744	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
204745	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
204746	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LTO225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
204747	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
204748	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
204749	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
204750	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
204751	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204752	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
204753	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204754	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
204755	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
204756	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	231	
204757	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	235	
204758	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	4	
204759	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
204760	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
204761	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
204762	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
204763	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
204764	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
204765	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
204766	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
204767	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
204768	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
204769	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
204770	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
204771	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
204772	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
204773	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
204774	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
204775	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
204776	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
204777	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
204778	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
204779	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
204780	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
204781	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
204782	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
204783	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
204784	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
204785	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
204786	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
204787	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
204788	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
204789	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
204790	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
204791	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
204792	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204793	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
204794	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
204795	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	20	
204796	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	30	
204797	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	14	
204798	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
204799	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	10	
204800	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
204801	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
204802	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
204803	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
204804	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
204805	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
204806	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
204807	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	General Comments		
204808	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
204809	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	LTC000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
204810	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
204811	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		
204812	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
204813	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
204814	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
204815	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
204816	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
204817	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
204818	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	9	
204819	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204820	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204821	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204822	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	150.0	
204823	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	110.0	
204824	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	150.0	
204825	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
204826	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204827	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
204828	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
204829	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
204830	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
204831	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204832	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204833	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204834	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204835	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
204836	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
204837	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
204838	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
204839	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
204840	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
204841	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
204842	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
204843	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	192511	
204844	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	192520	
204845	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
204846	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	3L	
204847	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	9R	
204848	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	9L	
204849	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1657	
204850	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
204851	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
204852	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
204853	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
204854	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
204855	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
204856	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
204857	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
204858	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
204859	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
204860	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
204861	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
204862	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
204863	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
204864	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
204865	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
204866	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
204867	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
204868	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
204869	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
204870	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
204871	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
204872	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
204873	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
204874	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
204875	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
204876	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
204877	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
204878	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
204879	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
204880	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
204881	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
204882	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
204883	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
204884	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
204885	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
204886	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
204887	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
204888	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
204889	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
204890	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
204891	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
204892	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
204893	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
204894	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
204895	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
204896	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
204897	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
204898	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
204899	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
204900	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
204901	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204902	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
204903	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
204904	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
204905	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
204906	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
204907	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
204908	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
204909	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
204910	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
204911	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	100	*F
204912	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	28	
204913	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.07	%
204914	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.07	%
204915	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
204916	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
204917	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204918	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204919	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204920	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204921	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	325.0	
204922	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	259.0	
204923	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	248.0	
204924	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204925	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204926	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204927	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	11	
204928	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	1	
204929	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204930	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204931	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204932	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	323.0	
204933	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	306.0	
204934	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	304.0	
204935	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204936	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
204937	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
204938	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
204939	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
204940	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	1	
204941	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
204942	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	1	
204943	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	202	
204944	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	202	
204945	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
204946	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
204947	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
204948	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
204949	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
204950	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
204951	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
204952	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
204953	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
204954	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
204955	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
204956	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
204957	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
204958	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
204959	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	41.0	
204960	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	43.0	
204961	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	46.0	
204962	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
204963	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
204964	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
204965	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	32	
204966	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
204967	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
204968	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
204969	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
204970	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
204971	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
204972	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
204973	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
204974	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	363	
204975	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	363	
204976	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
204977	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
204978	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	38	
204979	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
204980	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	101	*F
204981	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
204982	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
204983	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
204984	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
204985	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
204986	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
204987	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
204988	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
204989	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
204990	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	6.0	VDC
204991	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	13.0	VDC
204992	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
204993	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
204994	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
204995	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
204996	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
204997	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
204998	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
204999	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
205000	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205001	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
205002	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	9	
205003	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1775	
205004	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1775	
205005	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
205006	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
205007	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
205008	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205009	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
205010	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205011	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
205012	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	3	
205013	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
205014	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
205015	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
205016	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
205017	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
205018	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
205019	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	180.0	
205020	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	140.0	
205021	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
205022	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
205023	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
205024	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB0302	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
205025	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
205026	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
205027	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
205028	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
205029	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	70.0	
205030	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	70.0	
205031	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	70.0	
205032	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
205033	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205034	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205035	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205036	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205037	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
205038	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
205039	9/10/2019 14:08	Distribution	Radcliff South Quarterly Inspection	LTC000716	LTCControl	594-1	LTC Control Insp	General Comments		
205040	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.21	%
205041	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	142.0	
205042	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	191.0	
205043	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	147.0	
205044	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205045	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205046	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205047	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205048	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205049	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205050	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205051	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205052	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
205053	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	4	
205054	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	940	
205055	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	940	
205056	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
205057	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
205058	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205059	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
205060	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	"F
205061	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
205062	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
205063	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
205064	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
205065	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
205066	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
205067	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
205068	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
205069	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
205070	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
205071	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
205072	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
205073	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205074	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
205075	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
205076	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1399	
205077	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1399	
205078	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
205079	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
205080	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
205081	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205082	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
205083	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205084	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205085	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205086	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205087	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205088	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
205089	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
205090	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
205091	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
205092	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205093	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
205094	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205095	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205096	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
205097	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
205098	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
205099	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
205100	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
205101	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
205102	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
205103	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
205104	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	80	
205105	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	88	
205106	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
205107	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
205108	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
205109	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
205110	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
205111	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
205112	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
205113	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
205114	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	49	
205115	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	49	
205116	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
205117	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
205118	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205119	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	17	
205120	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	55.42	%
205121	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	51.54	%
205122	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	50.43	%
205123	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
205124	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
205125	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
205126	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205127	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
205128	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
205129	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
205130	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
205131	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
205132	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
205133	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
205134	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
205135	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
205136	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
205137	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
205138	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
205139	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
205140	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
205141	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
205142	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5143	
205143	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
205144	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
205145	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
205146	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205147	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205148	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205149	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205150	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205151	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	118.0	
205152	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	123.0	
205153	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	175.0	
205154	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205155	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205156	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205157	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
205158	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
205159	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
205160	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
205161	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
205162	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	320.0	
205163	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
205164	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
205165	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205166	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205167	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205168	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205169	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205170	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	6	
205171	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205172	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205173	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
205174	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205175	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205176	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205177	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
205178	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
205179	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
205180	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
205181	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
205182	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
205183	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
205184	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
205185	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
205186	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
205187	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
205188	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
205189	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
205190	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
205191	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
205192	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
205193	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
205194	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
205195	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
205196	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
205197	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
205198	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
205199	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205200	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205201	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C Ø	110.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205202	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B Ø	80.0	
205203	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A Ø	80.0	
205204	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205205	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205206	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205207	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	15	
205208	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
205209	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	*F
205210	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	109.0	
205211	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	105.0	
205212	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	106.0	
205213	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205214	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205215	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205216	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
205217	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
205218	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
205219	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
205220	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
205221	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
205222	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
205223	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
205224	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
205225	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
205226	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
205227	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
205228	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
205229	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
205230	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
205231	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
205232	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
205233	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205234	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
205235	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	57	
205236	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	900	
205237	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	900	
205238	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	57	
205239	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
205240	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205241	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205242	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205243	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205244	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205245	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205246	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205247	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205248	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	130.0	
205249	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	142.0	
205250	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	143.0	
205251	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
205252	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
205253	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.85	%
205254	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	73	
205255	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
205256	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	6	
205257	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	6	
205258	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	308	
205259	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	308	
205260	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
205261	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments		
205262	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
205263	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
205264	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
205265	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
205266	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C Ø	0	
205267	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B Ø	0	
205268	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A Ø	0	
205269	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205270	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205271	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
205272	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
205273	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
205274	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
205275	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	548.0	
205276	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
205277	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	442	
205278	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	446	
205279	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	4	
205280	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
205281	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	4	
205282	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
205283	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
205284	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
205285	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
205286	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
205287	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
205288	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	14934	
205289	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	14939	
205290	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
205291	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	8L	
205292	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	3L	
205293	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	13L	
205294	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	742	
205295	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
205296	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
205297	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
205298	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
205299	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	513.0	
205300	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
205301	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
205302	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	.55	%
205303	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	21	
205304	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
205305	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
205306	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205307	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
205308	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
205309	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
205310	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
205311	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	8.000	millivolts
205312	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
205313	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
205314	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
205315	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	TR-2 desiccant needs to be replaced	
205316	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	51847	
205317	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	51847	
205318	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
205319	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
205320	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	10	
205321	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205322	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205323	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205324	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	260.0	
205325	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	280.0	
205326	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	260.0	
205327	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
205328	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205329	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205330	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205331	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205332	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205333	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205334	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205335	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205336	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205337	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
205338	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
205339	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
205340	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
205341	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
205342	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
205343	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
205344	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
205345	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
205346	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
205347	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
205348	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	333	
205349	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	333	
205350	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
205351	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205352	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
205353	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
205354	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
205355	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
205356	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
205357	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205358	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205359	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205360	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	502.0	
205361	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
205362	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
205363	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	0	
205364	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	399	
205365	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	399	
205366	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
205367	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
205368	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
205369	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
205370	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
205371	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
205372	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
205373	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
205374	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
205375	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
205376	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	1267	
205377	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
205378	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	9L	
205379	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	7R	
205380	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	1R	
205381	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
205382	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	1292	
205383	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	1281	
205384	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
205385	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
205386	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
205387	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
205388	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
205389	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
205390	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	17	
205391	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205392	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205393	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205394	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
205395	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	85.0	
205396	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	75.0	
205397	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
205398	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205399	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205400	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205401	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205402	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205403	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	DB0055	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205404	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
205405	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
205406	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
205407	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
205408	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
205409	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
205410	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2432	
205411	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
205412	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
205413	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
205414	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
205415	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
205416	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
205417	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
205418	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
205419	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
205420	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205421	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
205422	9/10/2019 7:49	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
205423	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
205424	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
205425	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
205426	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	151	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205427	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	151	
205428	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
205429	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
205430	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
205431	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
205432	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
205433	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
205434	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
205435	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
205436	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
205437	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205438	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205439	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205440	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205441	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
205442	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
205443	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
205444	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205445	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205446	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205447	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	0	
205448	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205449	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	122.0	
205450	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	115.0	
205451	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	136.0	
205452	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
205453	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205454	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205455	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205456	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205457	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205458	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205459	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205460	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205461	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205462	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
205463	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
205464	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
205465	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
205466	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
205467	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
205468	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
205469	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
205470	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
205471	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
205472	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
205473	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
205474	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	238	
205475	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	239	
205476	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	4	
205477	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
205478	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205479	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	4	
205480	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
205481	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
205482	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
205483	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205484	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205485	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205486	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
205487	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
205488	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
205489	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205490	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205491	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205492	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
205493	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	24.0	
205494	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	24.0	
205495	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	24.0	
205496	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205497	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205498	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205499	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
205500	9/10/2019 13:37	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205501	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	10	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205502	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	20.51	%
205503	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	159.0	
205504	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	157.0	
205505	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	154.0	
205506	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205507	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205508	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205509	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
205510	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
205511	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
205512	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
205513	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
205514	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
205515	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
205516	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	509	
205517	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	509	
205518	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
205519	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
205520	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
205521	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
205522	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205523	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
205524	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205525	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	6	
205526	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
205527	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205528	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205529	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
205530	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205531	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
205532	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205533	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205534	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205535	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205536	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205537	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A Ø	0	
205538	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B Ø	0	
205539	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C Ø	0	
205540	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
205541	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
205542	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
205543	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
205544	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments		
205545	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
205546	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	280	
205547	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	280	
205548	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	4	
205549	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	4	
205550	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	0	
205551	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
205552	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
205553	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
205554	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
205555	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
205556	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
205557	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
205558	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
205559	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
205560	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
205561	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
205562	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
205563	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
205564	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
205565	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
205566	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
205567	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
205568	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LTC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
205569	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
205570	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205571	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
205572	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205573	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
205574	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205575	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
205576	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205577	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205578	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205579	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
205580	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
205581	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
205582	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
205583	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
205584	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
205585	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
205586	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments	Not in service	
205587	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
205588	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	
205589	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
205590	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
205591	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
205592	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
205593	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
205594	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
205595	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
205596	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
205597	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205598	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	BCH000977	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
205599	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
205600	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
205601	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
205602	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
205603	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
205604	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	General Comments	1 operation unaccounted for	
205605	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
205606	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
205607	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1617	
205608	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1617	
205609	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
205610	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
205611	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
205612	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	9	
205613	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205614	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205615	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205616	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	127.0	
205617	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	130.0	
205618	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	130.0	
205619	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205620	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
205621	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
205622	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
205623	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
205624	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
205625	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
205626	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
205627	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
205628	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
205629	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
205630	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
205631	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
205632	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
205633	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
205634	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
205635	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
205636	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
205637	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
205638	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
205639	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	
205640	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24024	volts
205641	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
205642	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
205643	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
205644	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
205645	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	157	
205646	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	157	
205647	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	0	
205648	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
205649	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
205650	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205651	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205652	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
205653	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BCH000229	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
205654	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
205655	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
205656	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
205657	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
205658	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
205659	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
205660	9/10/2019 14:06	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	43.000	millivolts
205661	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
205662	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
205663	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
205664	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	44	
205665	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
205666	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
205667	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
205668	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
205669	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
205670	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
205671	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
205672	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205673	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205674	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205675	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205676	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205677	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205678	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205679	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
205680	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
205681	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
205682	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
205683	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
205684	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205685	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
205686	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
205687	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
205688	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	83	
205689	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	83	
205690	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
205691	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
205692	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205693	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments	counter was enterd wrong on las qtr check. the las qtr was 21458	
205694	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
205695	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
205696	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
205697	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
205698	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
205699	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
205700	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
205701	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	
205702	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22682	volts
205703	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
205704	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
205705	9/10/2019 14:40	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
205706	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
205707	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
205708	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
205709	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	General Comments	.	
205710	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
205711	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
205712	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1411	
205713	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1411	
205714	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
205715	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
205716	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
205717	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
205718	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
205719	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	4	
205720	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
205721	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	4	
205722	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	304	
205723	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
205724	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
205725	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	300	
205726	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205727	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
205728	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
205729	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
205730	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
205731	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
205732	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
205733	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
205734	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
205735	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
205736	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
205737	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
205738	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205739	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205740	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205741	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205742	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205743	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	115	
205744	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	28.26	%
205745	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	41.57	%
205746	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205747	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205748	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205749	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
205750	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
205751	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
205752	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
205753	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
205754	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
205755	9/10/2019 14:06	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
205756	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
205757	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
205758	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	1	
205759	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	1	
205760	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	178	
205761	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	177	
205762	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
205763	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
205764	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
205765	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
205766	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
205767	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
205768	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
205769	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
205770	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
205771	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
205772	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
205773	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
205774	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205775	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205776	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205777	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205778	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205779	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205780	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205781	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205782	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205783	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
205784	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	58.0	
205785	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	55.0	
205786	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	52.0	
205787	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205788	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205789	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205790	9/10/2019 14:20	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	3	
205791	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
205792	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
205793	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205794	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205795	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	12	
205796	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	117.0	
205797	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
205798	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
205799	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
205800	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	70	°C
205801	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.13	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
205802	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
205803	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
205804	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	23.05	%
205805	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
205806	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
205807	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
205808	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
205809	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
205810	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
205811	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
205812	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
205813	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
205814	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
205815	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
205816	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
205817	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
205818	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
205819	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
205820	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
205821	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
205822	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
205823	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
205824	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
205825	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
205826	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
205827	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
205828	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
205829	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
205830	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
205831	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
205832	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	n	
205833	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
205834	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
205835	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
205836	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
205837	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
205838	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
205839	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	26.69	%
205840	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
205841	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
205842	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
205843	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
205844	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
205845	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
205846	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	115.0	
205847	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
205848	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	118.0	
205849	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
205850	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
205851	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
205852	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
205853	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
205854	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
205855	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205856	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	26.75	
205857	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	26.75	
205858	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	26.75	
205859	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
205860	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
205861	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
205862	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
205863	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
205864	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
205865	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
205866	9/10/2019 12:55	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
205867	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
205868	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
205869	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
205870	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
205871	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
205872	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
205873	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
205874	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
205875	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
205876	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
205877	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments		
205878	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
205879	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205880	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
205881	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
205882	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
205883	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
205884	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
205885	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
205886	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
205887	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
205888	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
205889	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
205890	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
205891	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
205892	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
205893	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
205894	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
205895	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
205896	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
205897	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
205898	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
205899	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
205900	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	290.0	
205901	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	190.0	
205902	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	300.0	
205903	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205904	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	224	
205905	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
205906	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
205907	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
205908	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	7	
205909	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	160	
205910	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
205911	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
205912	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
205913	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
205914	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
205915	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	167	
205916	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	167	
205917	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	3	
205918	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	3	
205919	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
205920	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
205921	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	60	
205922	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	60	
205923	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
205924	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	3	
205925	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
205926	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	4	
205927	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
205928	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	7	
205929	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
205930	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
205931	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
205932	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
205933	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
205934	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
205935	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
205936	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
205937	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
205938	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
205939	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
205940	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
205941	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
205942	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
205943	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
205944	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
205945	9/10/2019 11:20	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
205946	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	41	°C
205947	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	63	°C
205948	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
205949	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
205950	9/10/2019 11:49	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
205951	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
205952	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
205953	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
205954	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
205955	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
205956	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
205957	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
205958	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
205959	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
205960	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
205961	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
205962	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
205963	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
205964	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
205965	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
205966	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
205967	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
205968	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
205969	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
205970	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
205971	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
205972	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
205973	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
205974	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
205975	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
205976	9/10/2019 14:20	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
205977	9/10/2019 13:33	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	220	
205978	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
205979	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
205980	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	0.0	
205981	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
205982	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	42	*C
205983	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	71	*C
205984	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	42	*C
205985	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	66	*C
205986	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	42	*C
205987	9/10/2019 9:38	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	160	
205988	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	663	
205989	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	5	
205990	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
205991	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments	21-Z1 target	
205992	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
205993	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
205994	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	18.0	
205995	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	19.0	
205996	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	19.0	
205997	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	3	
205998	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
205999	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	3	
206000	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	663	
206001	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
206002	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
206003	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
206004	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
206005	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
206006	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
206007	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1493	
206008	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
206009	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
206010	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
206011	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
206012	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
206013	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
206014	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
206015	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
206016	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
206017	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
206018	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
206019	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
206020	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
206021	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	19.0	
206022	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	19.0	
206023	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	18.0	
206024	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
206025	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
206026	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206027	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
206028	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	7	
206029	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	607	
206030	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	607	
206031	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
206032	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
206033	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
206034	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
206035	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
206036	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Unknown Operations	0	
206037	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	421	
206038	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	421	
206039	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps A Ø	0.0	
206040	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps B Ø	0.0	
206041	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Amps C Ø	0.0	
206042	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
206043	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
206044	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
206045	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
206046	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	10	
206047	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
206048	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
206049	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206050	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
206051	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
206052	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
206053	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
206054	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
206055	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
206056	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
206057	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
206058	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
206059	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
206060	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
206061	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
206062	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
206063	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206064	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
206065	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
206066	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
206067	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
206068	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
206069	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
206070	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
206071	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
206072	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
206073	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
206074	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
206075	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
206076	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
206077	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
206078	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
206079	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
206080	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
206081	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
206082	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
206083	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
206084	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
206085	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
206086	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
206087	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206088	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
206089	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206090	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206091	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
206092	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	120.0	
206093	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	100.0	
206094	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	120.0	
206095	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206096	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206097	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206098	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	2	
206099	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206100	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
206101	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206102	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
206103	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
206104	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206105	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206106	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206107	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206108	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206109	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206110	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206111	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206112	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206113	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
206114	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206115	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206116	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206117	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206118	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206119	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206120	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206121	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206122	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
206123	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206124	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206125	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206126	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
206127	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
206128	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
206129	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
206130	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206131	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206132	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206133	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206134	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
206135	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206136	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
206137	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
206138	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
206139	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
206140	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments	ok	
206141	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206142	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206143	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
206144	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments	ok	
206145	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206146	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
206147	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
206148	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206149	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
206150	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206151	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206152	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206153	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206154	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
206155	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206156	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	12869	
206157	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
206158	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
206159	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206160	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206161	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206162	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206163	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
206164	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
206165	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
206166	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
206167	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
206168	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments	ok	
206169	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
206170	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
206171	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
206172	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
206173	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
206174	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
206175	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
206176	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206177	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
206178	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206179	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206180	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206181	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206182	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206183	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	ok	
206184	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
206185	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
206186	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
206187	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
206188	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
206189	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206190	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206191	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206192	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206193	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206194	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206195	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206196	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206197	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206198	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments	ok	
206199	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206200	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206201	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206202	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206203	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206204	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206205	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206206	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206207	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206208	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206209	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206210	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206211	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
206212	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
206213	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
206214	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
206215	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
206216	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
206217	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
206218	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
206219	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
206220	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	173732	
206221	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206222	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
206223	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
206224	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
206225	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
206226	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
206227	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
206228	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
206229	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	LTC000067	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
206230	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
206231	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
206232	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206233	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206234	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206235	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206236	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
206237	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
206238	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
206239	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
206240	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
206241	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
206242	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
206243	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
206244	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
206245	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
206246	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments	ok	
206247	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments	ok	
206248	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
206249	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
206250	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	0	
206251	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206252	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	179	
206253	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	179	
206254	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	0	
206255	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	0	
206256	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
206257	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
206258	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
206259	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
206260	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206261	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206262	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
206263	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
206264	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
206265	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	74672	
206266	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206267	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
206268	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
206269	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
206270	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206271	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206272	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206273	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206274	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
206275	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206276	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
206277	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
206278	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
206279	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206280	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206281	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
206282	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	1	
206283	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206284	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206285	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206286	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	24.0	
206287	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	24.0	
206288	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	26.0	
206289	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
206290	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206291	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206292	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206293	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments	ok	
206294	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
206295	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
206296	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
206297	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206298	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206299	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
206300	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
206301	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
206302	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
206303	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
206304	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
206305	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
206306	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
206307	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
206308	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
206309	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
206310	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
206311	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
206312	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
206313	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
206314	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
206315	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
206316	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206317	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206318	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206319	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206320	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
206321	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206322	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
206323	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
206324	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206325	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments	ok	
206326	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206327	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
206328	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
206329	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206330	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206331	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
206332	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
206333	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
206334	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30467	
206335	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206336	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
206337	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
206338	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
206339	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206340	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206341	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments	Base Voltage low	
206342	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206343	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206344	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206345	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206346	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206347	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206348	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
206349	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	5.0	
206350	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
206351	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
206352	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206353	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206354	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206355	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
206356	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
206357	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
206358	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
206359	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
206360	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
206361	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
206362	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
206363	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	811	
206364	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
206365	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
206366	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
206367	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
206368	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
206369	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
206370	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
206371	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
206372	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
206373	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
206374	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
206375	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
206376	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
206377	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
206378	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
206379	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
206380	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
206381	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
206382	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
206383	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1768	
206384	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
206385	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
206386	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
206387	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
206388	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	3	
206389	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
206390	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
206391	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
206392	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
206393	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
206394	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
206395	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
206396	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
206397	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206398	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	26905	
206399	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	
206400	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	volts
206401	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206402	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206403	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206404	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
206405	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
206406	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
206407	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
206408	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206409	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
206410	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
206411	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206412	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
206413	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
206414	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
206415	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
206416	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	...	
206417	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	2	
206418	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	576	
206419	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	576	
206420	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206421	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206422	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206423	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206424	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206425	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206426	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator chipped..	
206427	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206428	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206429	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
206430	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206431	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
206432	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
206433	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206434	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments	ok	
206435	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
206436	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
206437	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
206438	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206439	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206440	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
206441	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
206442	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
206443	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30081	
206444	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206445	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
206446	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
206447	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
206448	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206449	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206450	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206451	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206452	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
206453	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206454	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
206455	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
206456	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206457	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments	ok	
206458	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
206459	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
206460	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
206461	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206462	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206463	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
206464	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
206465	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
206466	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31842	
206467	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206468	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
206469	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
206470	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	139	
206471	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	1	
206472	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
206473	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
206474	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	1	
206475	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
206476	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206477	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
206478	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99991	
206479	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
206480	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
206481	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
206482	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206483	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206484	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206485	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206486	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206487	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206488	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206489	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
206490	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
206491	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
206492	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
206493	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
206494	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
206495	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
206496	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
206497	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
206498	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
206499	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
206500	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206501	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments	ok	
206502	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206503	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206504	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206505	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
206506	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	46.0	
206507	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
206508	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	39.0	
206509	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.000	millivolts
206510	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A5 Found Float Voltage	54.0	VDC
206511	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A5 Left Float Voltage	54.0	VDC
206512	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
206513	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206514	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206515	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206516	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206517	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	1.93	
206518	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	1.93	
206519	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	1.93	
206520	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
206521	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
206522	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206523	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206524	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206525	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206526	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
206527	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
206528	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
206529	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
206530	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206531	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
206532	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
206533	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments		
206534	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
206535	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
206536	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
206537	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
206538	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
206539	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
206540	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
206541	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
206542	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
206543	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
206544	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
206545	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
206546	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
206547	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
206548	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
206549	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments	ok	
206550	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments	ok	
206551	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206552	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
206553	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
206554	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
206555	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	139	
206556	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206557	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206558	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206559	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206560	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206561	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206562	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206563	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206564	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206565	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206566	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
206567	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
206568	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
206569	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
206570	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
206571	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
206572	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
206573	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
206574	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
206575	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
206576	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	28	
206577	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	32	
206578	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
206579	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
206580	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
206581	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
206582	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
206583	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments	ok	
206584	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
206585	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
206586	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
206587	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
206588	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
206589	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
206590	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
206591	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
206592	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
206593	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
206594	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
206595	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
206596	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
206597	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
206598	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
206599	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
206600	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
206601	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
206602	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
206603	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
206604	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
206605	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
206606	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
206607	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206608	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206609	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206610	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206611	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206612	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206613	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206614	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206615	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206616	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206617	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206618	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206619	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206620	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
206621	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
206622	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
206623	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206624	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206625	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206626	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206627	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
206628	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
206629	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
206630	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0142	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
206631	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
206632	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206633	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206634	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206635	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206636	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206637	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206638	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206639	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments	ok	
206640	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206641	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206642	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
206643	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
206644	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
206645	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
206646	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
206647	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
206648	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
206649	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
206650	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
206651	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
206652	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
206653	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
206654	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
206655	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
206656	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
206657	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
206658	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
206659	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
206660	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206661	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206662	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
206663	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
206664	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
206665	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
206666	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
206667	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
206668	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
206669	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206670	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206671	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206672	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206673	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206674	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
206675	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
206676	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
206677	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
206678	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
206679	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	3	
206680	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
206681	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
206682	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	6	
206683	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
206684	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
206685	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206686	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
206687	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
206688	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206689	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
206690	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206691	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206692	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206693	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206694	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
206695	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
206696	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
206697	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
206698	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
206699	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
206700	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
206701	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206702	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
206703	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
206704	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
206705	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
206706	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
206707	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
206708	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
206709	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	136	
206710	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	13L	
206711	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	7L	
206712	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	8L	
206713	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
206714	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	441	
206715	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	436	
206716	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments	ok	
206717	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
206718	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
206719	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
206720	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
206721	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments	ok	
206722	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
206723	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	General Comments		
206724	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206725	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206726	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206727	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206728	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	360.0	
206729	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	360.0	
206730	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	360.0	
206731	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
206732	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	60.0	
206733	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	0.0	
206734	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	0.0	
206735	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206736	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206737	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206738	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	7	
206739	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206740	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206741	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206742	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206743	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206744	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206745	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206746	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206747	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206748	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206749	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206750	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206751	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments	ok	
206752	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206753	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206754	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206755	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206756	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206757	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206758	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206759	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206760	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206761	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206762	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206763	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206764	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206765	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	216	
206766	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	216	
206767	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
206768	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	1	
206769	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
206770	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
206771	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206772	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206773	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206774	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206775	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206776	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
206777	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206778	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206779	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206780	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
206781	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206782	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206783	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206784	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206785	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206786	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206787	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206788	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206789	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206790	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
206791	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206792	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206793	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments	ok	
206794	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments	ok	
206795	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
206796	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
206797	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
206798	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	1	
206799	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
206800	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
206801	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	1	
206802	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	7.72	
206803	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	7.72	
206804	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	9.65	
206805	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206806	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206807	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
206808	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
206809	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
206810	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
206811	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
206812	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
206813	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
206814	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206815	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206816	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206817	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206818	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
206819	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206820	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
206821	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
206822	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206823	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
206824	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
206825	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
206826	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
206827	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
206828	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	60	°C
206829	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
206830	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
206831	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
206832	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
206833	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
206834	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
206835	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
206836	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments	ok	
206837	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
206838	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
206839	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
206840	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7R	
206841	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
206842	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206843	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
206844	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
206845	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
206846	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
206847	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
206848	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
206849	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
206850	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
206851	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206852	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
206853	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
206854	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
206855	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
206856	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
206857	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
206858	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
206859	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
206860	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
206861	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
206862	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
206863	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
206864	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
206865	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
206866	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
206867	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
206868	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
206869	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
206870	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
206871	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
206872	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
206873	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
206874	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
206875	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
206876	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
206877	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
206878	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
206879	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
206880	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1211	
206881	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1215	
206882	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
206883	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
206884	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
206885	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
206886	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0109	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
206887	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
206888	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
206889	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
206890	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
206891	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
206892	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
206893	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
206894	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
206895	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206896	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206897	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
206898	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
206899	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	93854	
206900	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
206901	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
206902	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
206903	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
206904	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206905	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
206906	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
206907	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
206908	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
206909	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
206910	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
206911	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
206912	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
206913	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
206914	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments	ok	
206915	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
206916	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	70	
206917	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	70	
206918	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
206919	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
206920	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
206921	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206922	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27946	
206923	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
206924	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
206925	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
206926	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
206927	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
206928	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
206929	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
206930	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
206931	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
206932	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
206933	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
206934	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
206935	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
206936	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
206937	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206938	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206939	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206940	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206941	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206942	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206943	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
206944	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206945	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206946	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
206947	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
206948	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
206949	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
206950	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	154733	
206951	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
206952	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
206953	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
206954	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
206955	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
206956	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
206957	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
206958	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
206959	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
206960	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
206961	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
206962	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
206963	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
206964	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
206965	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
206966	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
206967	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
206968	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
206969	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
206970	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
206971	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
206972	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
206973	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	1	
206974	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
206975	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	1	
206976	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
206977	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
206978	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
206979	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
206980	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
206981	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
206982	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
206983	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
206984	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
206985	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
206986	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
206987	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
206988	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
206989	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
206990	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
206991	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
206992	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
206993	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
206994	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
206995	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
206996	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
206997	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
206998	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
206999	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207000	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207001	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207002	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207003	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207004	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207005	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207006	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207007	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
207008	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments	ok	
207009	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207010	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
207011	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207012	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207013	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207014	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
207015	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207016	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207017	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
207018	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
207019	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
207020	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
207021	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
207022	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
207023	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
207024	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
207025	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207026	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207027	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207028	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207029	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207030	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207031	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207032	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207033	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
207034	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
207035	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
207036	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
207037	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207038	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207039	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207040	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207041	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207042	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207043	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
207044	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
207045	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
207046	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
207047	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
207048	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
207049	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
207050	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
207051	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
207052	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	145	
207053	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	146	
207054	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
207055	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207056	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207057	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	0	
207058	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
207059	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
207060	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments	ok	
207061	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
207062	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
207063	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
207064	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207065	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207066	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207067	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207068	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207069	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207070	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207071	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207072	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207073	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207074	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
207075	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207076	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207077	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207078	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207079	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207080	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207081	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207082	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
207083	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207084	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207085	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	2 large gaps under fence on side closest to the scrap yard ...top rail getting rusty ...1 bayonet is broken.	
207086	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207087	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207088	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207089	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207090	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments	ok	
207091	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207092	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	93	*F
207093	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207094	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207095	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arising Horns Good Condition?	y	
207096	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207097	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207098	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207099	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207100	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207101	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207102	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207103	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments	ok	
207104	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207105	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207106	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207107	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207108	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207109	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arising Horns Good Condition?	y	
207110	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207111	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207112	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
207113	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
207114	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
207115	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207116	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
207117	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
207118	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments	BERM NEEDS TO BE LOOKED AT.	
207119	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
207120	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207121	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207122	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207123	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207124	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207125	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207126	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207127	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
207128	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207129	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207130	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207131	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207132	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207133	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207134	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207135	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207136	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
207137	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207138	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207139	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	94	*F
207140	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207141	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207142	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207143	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments	ok	
207144	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207145	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207146	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207147	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207148	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207149	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207150	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207151	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207152	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207153	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
207154	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207155	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207156	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207157	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207158	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207159	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207160	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207161	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
207162	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207163	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
207164	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207165	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207166	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207167	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207168	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207169	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207170	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207171	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207172	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207173	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207174	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207175	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207176	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207177	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207178	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207179	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207180	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207181	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207182	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207183	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
207184	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207185	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207186	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207187	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207188	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207189	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207190	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207191	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207192	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207193	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207194	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207195	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207196	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207197	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207198	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207199	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207200	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments	ok	
207201	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207202	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207203	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207204	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
207205	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207206	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207207	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207208	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207209	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
207210	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207211	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207212	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207213	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
207214	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
207215	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207216	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207217	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207218	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207219	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207220	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
207221	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
207222	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	20037	
207223	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
207224	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
207225	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
207226	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207227	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
207228	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	0	
207229	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	174	
207230	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	174	
207231	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
207232	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
207233	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
207234	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207235	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207236	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207237	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
207238	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
207239	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207240	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207241	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207242	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207243	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207244	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	5	
207245	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207246	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207247	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207248	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	67.0	
207249	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	110.0	
207250	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	149.0	
207251	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207252	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207253	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207254	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207255	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
207256	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207257	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments	ok	
207258	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207259	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
207260	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207261	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments	ok	
207262	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207263	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207264	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207265	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207266	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207267	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207268	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207269	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207270	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207271	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207272	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments	ok	
207273	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207274	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207275	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207276	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207277	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207278	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207279	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207280	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207281	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207282	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207283	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207284	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207285	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207286	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
207287	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
207288	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
207289	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
207290	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
207291	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	2R	
207292	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
207293	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
207294	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
207295	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
207296	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments	ok	
207297	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
207298	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
207299	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
207300	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
207301	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207302	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
207303	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207304	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207305	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207306	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207307	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207308	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207309	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	1	
207310	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
207311	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
207312	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
207313	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207314	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments	ok	
207315	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207316	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
207317	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
207318	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
207319	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
207320	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	0	
207321	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
207322	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207323	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207324	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207325	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
207326	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207327	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207328	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207329	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207330	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207331	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207332	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207333	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207334	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207335	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207336	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207337	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207338	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207339	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207340	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207341	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
207342	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
207343	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
207344	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
207345	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
207346	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
207347	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
207348	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
207349	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
207350	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
207351	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
207352	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
207353	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
207354	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
207355	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
207356	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
207357	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
207358	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
207359	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
207360	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207361	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207362	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207363	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207364	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207365	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207366	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
207367	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
207368	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
207369	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
207370	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
207371	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
207372	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
207373	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments	ok	
207374	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments	ok	
207375	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
207376	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	1	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207377	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
207378	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	184	
207379	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	184	
207380	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207381	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207382	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207383	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207384	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207385	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207386	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
207387	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
207388	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
207389	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
207390	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1197	
207391	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
207392	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
207393	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
207394	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	14424	
207395	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	14424	
207396	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
207397	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
207398	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
207399	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207400	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
207401	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	100.0	
207402	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	100.0	
207403	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	100.0	
207404	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207405	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207406	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207407	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	2	
207408	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207409	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207410	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207411	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207412	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207413	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207414	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207415	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207416	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
207417	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	97	*F
207418	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
207419	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207420	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207421	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
207422	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207423	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
207424	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207425	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
207426	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207427	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207428	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207429	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
207430	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207431	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207432	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207433	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207434	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207435	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
207436	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
207437	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207438	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
207439	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
207440	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207441	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207442	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207443	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207444	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207445	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
207446	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207447	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
207448	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
207449	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
207450	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
207451	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207452	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
207453	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
207454	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207455	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207456	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207457	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207458	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207459	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207460	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
207461	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
207462	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
207463	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
207464	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
207465	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
207466	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
207467	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
207468	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
207469	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
207470	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
207471	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
207472	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
207473	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
207474	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
207475	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
207476	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
207477	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
207478	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
207479	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
207480	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
207481	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
207482	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
207483	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
207484	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
207485	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
207486	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
207487	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
207488	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
207489	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments	ok	
207490	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments	ok	
207491	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207492	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207493	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207494	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207495	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207496	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207497	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207498	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207499	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207500	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207501	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207502	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207503	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
207504	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207505	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
207506	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207507	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207508	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207509	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207510	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
207511	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207512	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207513	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207514	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207515	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207516	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207517	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207518	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207519	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207520	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207521	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207522	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207523	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207524	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207525	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207526	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207527	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207528	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207529	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207530	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207531	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207532	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
207533	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
207534	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207535	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207536	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207537	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207538	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207539	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
207540	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207541	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207542	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207543	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207544	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
207545	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	21.0	
207546	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	22.0	
207547	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	20.0	
207548	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207549	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207550	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207551	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	2	
207552	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
207553	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
207554	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
207555	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments	ok	
207556	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
207557	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
207558	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
207559	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
207560	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
207561	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
207562	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
207563	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
207564	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
207565	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
207566	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
207567	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments	ok	
207568	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments	ok	
207569	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
207570	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	1	
207571	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
207572	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	171	
207573	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	171	
207574	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	1	
207575	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
207576	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
207577	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
207578	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	2	
207579	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207580	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207581	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207582	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	82.0	
207583	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	96.0	
207584	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	74.0	
207585	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
207586	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207587	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207588	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207589	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
207590	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
207591	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
207592	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
207593	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1451	
207594	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
207595	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	2	
207596	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207597	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207598	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207599	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	100.0	
207600	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	88.0	
207601	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	87.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207602	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
207603	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207604	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207605	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207606	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
207607	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
207608	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	General Comments		
207609	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
207610	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
207611	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
207612	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
207613	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
207614	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	LTC0000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
207615	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
207616	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
207617	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
207618	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	96336	
207619	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
207620	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
207621	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207622	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207623	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207624	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207625	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207626	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207627	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
207628	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
207629	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
207630	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
207631	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
207632	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
207633	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
207634	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
207635	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
207636	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	145	
207637	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
207638	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
207639	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
207640	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
207641	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
207642	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
207643	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
207644	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
207645	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
207646	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
207647	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
207648	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
207649	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
207650	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	710.0	
207651	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	700.0	
207652	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207653	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207654	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207655	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207656	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207657	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
207658	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207659	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	2	
207660	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
207661	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
207662	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
207663	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	72.0	
207664	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	102.0	
207665	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	86.0	
207666	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
207667	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207668	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207669	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.8	VDC
207670	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
207671	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
207672	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
207673	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
207674	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207675	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
207676	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207677	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
207678	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments	ok	
207679	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207680	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
207681	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207682	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207683	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
207684	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207685	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207686	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207687	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207688	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207689	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207690	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207691	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
207692	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
207693	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207694	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207695	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
207696	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
207697	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
207698	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	145	
207699	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207700	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207701	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207702	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207703	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207704	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207705	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207706	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207707	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments	ok	
207708	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207709	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	95	*F
207710	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207711	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207712	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207713	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207714	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207715	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207716	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207717	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207718	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments	ok	
207719	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
207720	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
207721	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
207722	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
207723	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
207724	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207725	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
207726	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
207727	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	General Comments	ok	
207728	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
207729	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
207730	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
207731	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
207732	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	LTC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
207733	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
207734	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207735	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
207736	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207737	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207738	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
207739	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
207740	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207741	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207742	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
207743	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
207744	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
207745	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
207746	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207747	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
207748	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
207749	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207750	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207751	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207752	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
207753	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
207754	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207755	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
207756	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
207757	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207758	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
207759	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207760	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
207761	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207762	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207763	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
207764	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
207765	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
207766	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207767	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	680.0	
207768	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
207769	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
207770	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.6	VDC
207771	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
207772	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	15	
207773	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207774	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207775	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207776	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
207777	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
207778	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
207779	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
207780	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
207781	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
207782	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
207783	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
207784	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
207785	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
207786	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
207787	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
207788	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
207789	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
207790	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
207791	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
207792	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
207793	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
207794	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
207795	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments	ok	
207796	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments	ok	
207797	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
207798	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	1	
207799	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
207800	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	156	
207801	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	156	
207802	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	1	
207803	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
207804	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207805	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207806	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207807	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207808	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
207809	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
207810	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
207811	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
207812	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
207813	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
207814	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207815	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
207816	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
207817	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207818	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207819	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
207820	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
207821	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
207822	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
207823	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
207824	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
207825	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
207826	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207827	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
207828	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	95	*F
207829	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
207830	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
207831	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
207832	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
207833	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207834	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
207835	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
207836	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.6	VDC
207837	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
207838	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
207839	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
207840	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
207841	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
207842	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
207843	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
207844	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207845	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
207846	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
207847	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207848	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
207849	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
207850	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
207851	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
207852	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
207853	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
207854	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
207855	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207856	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207857	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207858	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207859	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments	New Fence Installed by others waiting for new grounding	
207860	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207861	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
207862	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207863	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207864	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
207865	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
207866	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207867	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
207868	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
207869	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207870	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207871	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207872	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207873	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
207874	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
207875	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
207876	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
207877	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
207878	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
207879	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BCH001118	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
207880	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.120	millivolts
207881	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
207882	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
207883	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
207884	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
207885	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	BCH001119	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
207886	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
207887	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
207888	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
207889	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
207890	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
207891	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
207892	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
207893	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
207894	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
207895	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
207896	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
207897	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	6547.20	kw
207898	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
207899	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
207900	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	60	*C
207901	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	50	*C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
207902	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
207903	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
207904	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
207905	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
207906	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
207907	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
207908	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
207909	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
207910	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.6820	
207911	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
207912	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
207913	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
207914	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
207915	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
207916	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207917	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207918	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207919	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207920	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
207921	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207922	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207923	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
207924	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
207925	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
207926	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
207927	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
207928	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
207929	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
207930	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
207931	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
207932	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
207933	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
207934	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
207935	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
207936	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
207937	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
207938	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
207939	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
207940	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	92	*F
207941	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
207942	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
207943	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
207944	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
207945	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
207946	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
207947	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
207948	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
207949	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	395	
207950	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	395	
207951	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
207952	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
207953	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
207954	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
207955	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
207956	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
207957	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
207958	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
207959	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
207960	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
207961	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
207962	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
207963	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
207964	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
207965	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
207966	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
207967	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
207968	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
207969	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
207970	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
207971	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
207972	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
207973	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
207974	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
207975	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
207976	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
207977	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
207978	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
207979	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
207980	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
207981	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
207982	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
207983	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
207984	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
207985	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
207986	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	1	
207987	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
207988	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	179	
207989	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	179	
207990	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
207991	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
207992	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
207993	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
207994	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
207995	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
207996	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
207997	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
207998	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
207999	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	2R	
208000	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
208001	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
208002	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
208003	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
208004	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
208005	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
208006	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
208007	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
208008	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
208009	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
208010	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
208011	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
208012	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
208013	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
208014	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
208015	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	All Connections OK?	y	
208016	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
208017	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
208018	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
208019	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
208020	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
208021	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
208022	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
208023	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
208024	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
208025	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
208026	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
208027	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
208028	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
208029	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	1	
208030	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
208031	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
208032	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
208033	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	1244	
208034	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
208035	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
208036	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	8R	
208037	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	2L	
208038	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
208039	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	6432	
208040	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	6423	
208041	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments	ok	
208042	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments	ok	
208043	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
208044	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
208045	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
208046	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
208047	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
208048	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	49	
208049	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
208050	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
208051	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208052	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
208053	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
208054	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
208055	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
208056	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
208057	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
208058	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
208059	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
208060	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
208061	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
208062	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
208063	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
208064	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
208065	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
208066	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
208067	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
208068	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
208069	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
208070	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
208071	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
208072	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
208073	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
208074	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
208075	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
208076	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
208077	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
208078	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
208079	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
208080	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
208081	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
208082	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
208083	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
208084	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
208085	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
208086	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
208087	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
208088	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
208089	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
208090	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
208091	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
208092	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
208093	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
208094	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
208095	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments	ok	
208096	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
208097	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
208098	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
208099	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
208100	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
208101	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
208102	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
208103	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
208104	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
208105	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
208106	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
208107	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
208108	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
208109	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
208110	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
208111	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
208112	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
208113	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
208114	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
208115	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
208116	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
208117	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
208118	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
208119	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
208120	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
208121	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
208122	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
208123	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
208124	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
208125	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
208126	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208127	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
208128	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
208129	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
208130	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
208131	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
208132	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
208133	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
208134	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
208135	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
208136	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
208137	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
208138	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
208139	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208140	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
208141	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
208142	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
208143	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
208144	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
208145	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208146	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208147	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208148	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208149	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208150	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208151	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208152	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208153	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
208154	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	80.0	
208155	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	120.0	
208156	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	80.0	
208157	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208158	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208159	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208160	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	16	
208161	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
208162	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
208163	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
208164	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
208165	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25599	
208166	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
208167	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
208168	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
208169	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
208170	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
208171	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
208172	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
208173	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
208174	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
208175	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
208176	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
208177	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
208178	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
208179	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
208180	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
208181	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
208182	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
208183	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
208184	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
208185	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
208186	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
208187	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
208188	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
208189	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
208190	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
208191	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
208192	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
208193	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
208194	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
208195	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
208196	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
208197	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
208198	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
208199	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	4	
208200	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
208201	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
208202	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	4	
208203	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	386	
208204	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	386	
208205	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
208206	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
208207	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
208208	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
208209	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
208210	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
208211	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208212	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
208213	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
208214	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
208215	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
208216	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
208217	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
208218	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
208219	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
208220	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
208221	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208222	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
208223	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208224	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	40	°C
208225	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	50	°C
208226	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
208227	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
208228	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	3230.40	kw
208229	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
208230	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
208231	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
208232	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208233	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
208234	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
208235	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208236	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
208237	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
208238	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208239	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
208240	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
208241	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
208242	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
208243	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
208244	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208245	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208246	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
208247	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
208248	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
208249	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
208250	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
208251	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
208252	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
208253	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
208254	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
208255	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
208256	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
208257	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	y	
208258	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
208259	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
208260	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
208261	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
208262	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
208263	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
208264	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
208265	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
208266	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
208267	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
208268	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
208269	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
208270	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
208271	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
208272	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
208273	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
208274	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
208275	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
208276	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208277	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
208278	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
208279	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
208280	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
208281	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
208282	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
208283	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
208284	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
208285	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	95	*F
208286	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
208287	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
208288	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
208289	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
208290	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
208291	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
208292	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
208293	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
208294	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
208295	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
208296	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
208297	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
208298	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
208299	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.5384	
208300	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
208301	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
208302	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
208303	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
208304	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	1	
208305	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208306	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
208307	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
208308	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
208309	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
208310	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
208311	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
208312	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
208313	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
208314	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208315	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208316	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	107.0	
208317	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	99.0	
208318	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	136.0	
208319	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
208320	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208321	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208322	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208323	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208324	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208325	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208326	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
208327	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
208328	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	1	
208329	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	178	
208330	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	178	
208331	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
208332	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	1	
208333	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208334	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
208335	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208336	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208337	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208338	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
208339	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	16.0	
208340	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	19.0	
208341	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	19.0	
208342	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208343	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208344	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
208345	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
208346	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
208347	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
208348	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
208349	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
208350	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
208351	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
208352	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
208353	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
208354	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
208355	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
208356	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
208357	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208358	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208359	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208360	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208361	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208362	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208363	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
208364	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
208365	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
208366	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
208367	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
208368	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
208369	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
208370	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
208371	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
208372	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
208373	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
208374	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
208375	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
208376	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
208377	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
208378	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
208379	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
208380	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
208381	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
208382	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	198	
208383	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	0	
208384	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
208385	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
208386	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208387	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
208388	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
208389	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
208390	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
208391	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
208392	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
208393	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
208394	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments	ok	
208395	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments	ok	
208396	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
208397	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208398	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
208399	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
208400	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	185	
208401	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	185	
208402	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	0	
208403	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
208404	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
208405	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
208406	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	1	
208407	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	170	
208408	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
208409	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	170	
208410	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
208411	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
208412	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
208413	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
208414	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
208415	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
208416	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
208417	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
208418	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	General Comments	ok	
208419	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
208420	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	LTC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
208421	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
208422	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
208423	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
208424	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
208425	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
208426	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208427	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
208428	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208429	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	2	
208430	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
208431	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
208432	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	1	
208433	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	1	
208434	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	181	
208435	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	181	
208436	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
208437	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
208438	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
208439	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
208440	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
208441	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
208442	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
208443	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
208444	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
208445	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
208446	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
208447	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
208448	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208449	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208450	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208451	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208452	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208453	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208454	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208455	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208456	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208457	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
208458	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	25.0	
208459	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	17.0	
208460	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	19.0	
208461	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208462	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208463	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208464	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	2	
208465	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
208466	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
208467	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	1	
208468	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208469	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208470	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208471	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208472	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208473	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208474	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
208475	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	211.0	
208476	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	260.0	
208477	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	250.0	
208478	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208479	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208480	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208481	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
208482	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
208483	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
208484	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
208485	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
208486	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
208487	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
208488	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
208489	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
208490	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
208491	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments	ok	
208492	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
208493	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
208494	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	11L	
208495	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
208496	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
208497	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
208498	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
208499	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
208500	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
208501	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208502	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
208503	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
208504	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
208505	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
208506	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
208507	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
208508	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
208509	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
208510	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
208511	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
208512	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
208513	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
208514	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
208515	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	28898	
208516	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
208517	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
208518	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
208519	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
208520	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	General Comments		
208521	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
208522	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
208523	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
208524	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
208525	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
208526	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
208527	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
208528	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
208529	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
208530	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
208531	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
208532	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	0	
208533	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	172	
208534	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	172	
208535	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
208536	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	0	
208537	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208538	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
208539	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments	ok	
208540	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments	ok	
208541	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
208542	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
208543	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
208544	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
208545	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
208546	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
208547	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
208548	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208549	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208550	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208551	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208552	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208553	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	2	
208554	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
208555	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
208556	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
208557	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
208558	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
208559	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
208560	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
208561	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
208562	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
208563	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
208564	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208565	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208566	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208567	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208568	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208569	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208570	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208571	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208572	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
208573	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
208574	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
208575	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
208576	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
208577	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
208578	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
208579	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments	ok	
208580	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments	ok	
208581	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
208582	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208583	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
208584	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
208585	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	198	
208586	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
208587	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
208588	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
208589	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top rail is getting rusty	
208590	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
208591	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
208592	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
208593	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
208594	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
208595	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
208596	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
208597	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
208598	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
208599	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
208600	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
208601	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
208602	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
208603	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
208604	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
208605	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
208606	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208607	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208608	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208609	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208610	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208611	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208612	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208613	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208614	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208615	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
208616	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
208617	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
208618	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
208619	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208620	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208621	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208622	9/9/2019 15:14	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	2	
208623	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
208624	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	24746	
208625	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
208626	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
208627	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
208628	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	1	
208629	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208630	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208631	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208632	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	86.0	
208633	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	81.0	
208634	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	86.0	
208635	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
208636	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208637	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
208638	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
208639	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208640	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
208641	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208642	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	40	*C
208643	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	48	*C
208644	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
208645	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
208646	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	4337.28	kw
208647	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
208648	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
208649	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
208650	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208651	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
208652	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
208653	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208654	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
208655	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
208656	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208657	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
208658	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
208659	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
208660	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
208661	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208662	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208663	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
208664	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
208665	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
208666	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
208667	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
208668	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
208669	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
208670	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
208671	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
208672	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
208673	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
208674	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
208675	9/9/2019 10:16	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
208676	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7112	
208677	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
208678	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
208679	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
208680	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
208681	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
208682	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208683	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
208684	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208685	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	55	*C
208686	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	85	*C
208687	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
208688	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
208689	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4106.88	kw
208690	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
208691	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
208692	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
208693	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments	ok	
208694	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
208695	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208696	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
208697	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
208698	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208699	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
208700	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
208701	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208702	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208703	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208704	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
208705	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
208706	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
208707	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
208708	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
208709	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
208710	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
208711	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
208712	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
208713	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
208714	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
208715	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
208716	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
208717	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
208718	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
208719	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
208720	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
208721	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
208722	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
208723	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
208724	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
208725	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
208726	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208727	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
208728	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
208729	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
208730	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
208731	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
208732	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
208733	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
208734	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	95746	
208735	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	95750	
208736	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
208737	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	2L	
208738	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
208739	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	8L	
208740	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	1078	
208741	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
208742	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
208743	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
208744	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7794	
208745	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
208746	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
208747	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
208748	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
208749	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
208750	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208751	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
208752	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208753	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
208754	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
208755	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
208756	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
208757	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	935.28	kw
208758	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
208759	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
208760	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
208761	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments	ok	
208762	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
208763	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208764	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
208765	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
208766	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208767	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
208768	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
208769	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208770	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208771	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208772	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
208773	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
208774	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
208775	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
208776	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	40	°C
208777	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	48	°C
208778	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.6024	
208779	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
208780	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
208781	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
208782	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
208783	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
208784	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
208785	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
208786	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
208787	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
208788	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
208789	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
208790	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
208791	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208792	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208793	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208794	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208795	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208796	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208797	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208798	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208799	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208800	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
208801	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	130.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208802	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
208803	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208804	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208805	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208806	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208807	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208808	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208809	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	25.98	
208810	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	25.98	
208811	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	139.0	
208812	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	130.0	
208813	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208814	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208815	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208816	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	0	
208817	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
208818	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
208819	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	0	
208820	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	0	
208821	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	157	
208822	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	157	
208823	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
208824	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	25.98	
208825	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
208826	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
208827	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
208828	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
208829	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
208830	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
208831	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
208832	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments	5 Unknown Ops 1 Trip Ck	
208833	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments	ok	
208834	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
208835	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
208836	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	1	
208837	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
208838	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	95	
208839	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	95	
208840	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	6	
208841	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
208842	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
208843	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
208844	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
208845	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	1	
208846	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	1	
208847	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	207	
208848	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	206	
208849	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
208850	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
208851	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
208852	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
208853	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
208854	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
208855	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
208856	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
208857	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
208858	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
208859	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
208860	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
208861	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
208862	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
208863	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
208864	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
208865	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
208866	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
208867	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
208868	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
208869	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	7	
208870	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208871	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208872	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208873	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	200.0	
208874	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	200.0	
208875	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	180.0	
208876	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208877	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
208878	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
208879	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
208880	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
208881	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
208882	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208883	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208884	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208885	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208886	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
208887	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
208888	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208889	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
208890	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
208891	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
208892	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
208893	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	21.60	kw
208894	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
208895	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
208896	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	37	°C
208897	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
208898	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208899	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
208900	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208901	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
208902	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
208903	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
208904	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	240	
208905	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0900	
208906	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
208907	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
208908	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
208909	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	55	°C
208910	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
208911	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
208912	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
208913	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
208914	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
208915	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
208916	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
208917	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
208918	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
208919	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
208920	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
208921	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
208922	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	209	
208923	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	209	
208924	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
208925	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
208926	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
208927	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
208928	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
208929	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	11.9	VDC
208930	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC0000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
208931	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC0000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
208932	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC0000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
208933	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
208934	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
208935	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
208936	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
208937	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	11.8	VDC
208938	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
208939	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
208940	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
208941	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
208942	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
208943	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
208944	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	36	°C
208945	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
208946	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
208947	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
208948	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
208949	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
208950	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
208951	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
208952	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
208953	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
208954	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
208955	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
208956	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
208957	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
208958	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
208959	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
208960	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
208961	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
208962	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
208963	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
208964	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
208965	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
208966	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
208967	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
208968	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
208969	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
208970	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
208971	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
208972	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	248	
208973	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	252	
208974	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
208975	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
208976	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
208977	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
208978	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
208979	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	5	
208980	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
208981	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	4	
208982	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
208983	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	1	
208984	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
208985	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
208986	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
208987	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
208988	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
208989	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
208990	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	190.0	
208991	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	240.0	
208992	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	120.0	
208993	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
208994	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
208995	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
208996	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC0000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
208997	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC0000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
208998	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC0000385	LTCControl	738-1	LTC Control Insp	General Comments		
208999	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209000	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
209001	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209002	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
209003	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
209004	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.300	millivolts
209005	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
209006	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
209007	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	4	
209008	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
209009	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	4	
209010	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	303	
209011	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	299	
209012	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
209013	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
209014	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
209015	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
209016	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
209017	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
209018	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
209019	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
209020	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
209021	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
209022	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
209023	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
209024	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
209025	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
209026	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209027	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
209028	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
209029	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
209030	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209031	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
209032	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209033	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209034	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209035	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209036	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209037	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209038	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209039	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
209040	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC000378	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
209041	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC000378	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
209042	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	9	
209043	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209044	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209045	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209046	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	60.0	
209047	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	100.0	
209048	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	60.0	
209049	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
209050	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209051	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
209052	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
209053	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
209054	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
209055	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
209056	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	5.20	
209057	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
209058	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	5.20	
209059	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
209060	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
209061	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
209062	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC000378	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
209063	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
209064	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	LTC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.7	VAC
209065	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
209066	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
209067	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209068	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
209069	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
209070	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209071	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BAT000312	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209072	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209073	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
209074	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
209075	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	190957	
209076	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	190970	
209077	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209078	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	4R	
209079	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	8R	
209080	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	9L	
209081	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1639	
209082	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209083	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209084	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209085	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
209086	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
209087	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209088	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
209089	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209090	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209091	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209092	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209093	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209094	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209095	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209096	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209097	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209098	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209099	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209100	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
209101	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	BATT NEEDS WATER ADDED	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209102	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
209103	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
209104	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
209105	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
209106	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
209107	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
209108	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
209109	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
209110	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
209111	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
209112	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
209113	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
209114	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
209115	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
209116	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
209117	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
209118	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
209119	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
209120	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
209121	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
209122	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
209123	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
209124	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
209125	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
209126	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
209127	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
209128	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	16	
209129	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209130	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209131	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209132	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1746	
209133	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
209134	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	13L	
209135	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	1R	
209136	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	7L	
209137	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209138	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	35944	
209139	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	35932	
209140	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
209141	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
209142	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
209143	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
209144	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
209145	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
209146	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
209147	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
209148	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
209149	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
209150	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209151	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
209152	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
209153	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
209154	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
209155	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
209156	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	LTC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
209157	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	14	
209158	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
209159	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
209160	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209161	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
209162	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
209163	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
209164	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
209165	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
209166	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
209167	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
209168	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
209169	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
209170	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
209171	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	General Comments		
209172	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
209173	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	LTC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
209174	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
209175	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209176	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209177	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
209178	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	57807	
209179	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	57816	
209180	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209181	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	3L	
209182	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	2R	
209183	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	9L	
209184	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	1030	
209185	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209186	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209187	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209188	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209189	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
209190	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	BAT000087	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209191	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
209192	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
209193	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
209194	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
209195	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
209196	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209197	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
209198	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209199	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
209200	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.2658	
209201	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
209202	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Present	46	°C
209203	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
209204	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209205	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
209206	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
209207	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209208	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209209	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209210	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209211	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
209212	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209213	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	2551.68	kw
209214	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209215	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
209216	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
209217	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209218	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
209219	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
209220	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
209221	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
209222	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
209223	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
209224	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	y	
209225	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
209226	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
209227	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
209228	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
209229	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
209230	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
209231	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
209232	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
209233	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
209234	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
209235	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
209236	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209237	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209238	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209239	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
209240	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
209241	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209242	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
209243	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
209244	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209245	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments	ok	
209246	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
209247	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
209248	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
209249	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
209250	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2306.88	kw
209251	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209252	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
209253	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
209254	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
209255	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209256	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
209257	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209258	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209259	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	4718	
209260	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
209261	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
209262	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209263	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
209264	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209265	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
209266	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9612	
209267	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209268	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
209269	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.6360	
209270	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
209271	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209272	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
209273	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209274	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
209275	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209276	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
209277	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209278	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209279	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209280	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
209281	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209282	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209283	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
209284	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209285	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	38	°C
209286	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
209287	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
209288	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
209289	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
209290	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
209291	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209292	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209293	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
209294	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments	There are some signs of an oil leak near transformer.	
209295	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209296	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	8801.28	kw
209297	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209298	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
209299	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	65	°C
209300	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	40	°C
209301	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209302	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209303	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209304	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
209305	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209306	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209307	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
209308	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.9168	
209309	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
209310	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209311	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
209312	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
209313	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	General Comments	ok	
209314	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
209315	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
209316	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
209317	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
209318	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
209319	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
209320	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209321	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209322	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209323	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209324	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209325	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209326	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
209327	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209328	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209329	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209330	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209331	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
209332	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209333	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209334	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments	ok	
209335	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments	ok	
209336	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209337	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	3553.92	kw
209338	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209339	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
209340	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	80	°C
209341	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	40	°C
209342	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209343	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209344	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209345	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209346	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
209347	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209348	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209349	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
209350	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.7404	
209351	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
209352	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209353	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209354	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209355	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209356	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	1127	
209357	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	7L	
209358	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	7R	
209359	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	1R	
209360	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209361	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	4727	
209362	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
209363	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209364	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209365	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209366	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
209367	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209368	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209369	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
209370	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
209371	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209372	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
209373	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
209374	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
209375	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209376	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209377	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3844.80	kw
209378	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209379	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
209380	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
209381	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209382	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209383	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
209384	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209385	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
209386	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
209387	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209388	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209389	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209390	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209391	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209392	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209393	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209394	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209395	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
209396	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
209397	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
209398	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
209399	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
209400	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	30	°C
209401	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	25	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209402	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209403	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
209404	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209405	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209406	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
209407	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
209408	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209409	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
209410	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209411	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
209412	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
209413	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
209414	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
209415	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
209416	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
209417	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
209418	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
209419	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
209420	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments	ok	
209421	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
209422	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
209423	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
209424	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
209425	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
209426	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
209427	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	LTC0000554	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
209428	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
209429	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
209430	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
209431	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
209432	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
209433	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
209434	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
209435	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
209436	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
209437	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
209438	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments	ok	
209439	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
209440	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209441	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
209442	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
209443	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209444	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
209445	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
209446	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209447	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209448	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209449	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
209450	9/9/2019 12:56	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
209451	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209452	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	50	*C
209453	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	70	*C
209454	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.5	psi
209455	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209456	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	11779.20	kw
209457	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209458	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
209459	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
209460	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209461	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209462	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
209463	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209464	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209465	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209466	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209467	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209468	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
209469	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
209470	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
209471	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
209472	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
209473	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
209474	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
209475	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
209476	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
209477	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
209478	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
209479	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
209480	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
209481	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments	FENCE NEEDS ROCK AROUND THE YARD(SOME PLACES HIGHER THEN OTHERS. TREE AT FRONT GATE NEEDS CUT BACK.	
209482	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
209483	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209484	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
209485	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8010	
209486	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
209487	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209488	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209489	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
209490	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209491	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209492	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209493	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209494	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209495	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209496	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	45	°C
209497	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
209498	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
209499	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209500	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209501	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209502	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209503	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
209504	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
209505	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
209506	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209507	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209508	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209509	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209510	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209511	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
209512	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
209513	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
209514	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
209515	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C Ø	0	
209516	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B Ø	0	
209517	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
209518	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
209519	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
209520	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
209521	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209522	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	8945.28	kw
209523	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209524	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
209525	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209526	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209527	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209528	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209529	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
209530	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209531	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209532	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
209533	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	10	
209534	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209535	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209536	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209537	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	59.0	
209538	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	51.0	
209539	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	40.0	
209540	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
209541	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209542	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Top Oil Temperature Present	45	°C
209543	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
209544	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
209545	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
209546	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
209547	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
209548	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
209549	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209550	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
209551	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	64.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209552	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.9318	
209553	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
209554	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209555	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
209556	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
209557	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
209558	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
209559	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	77.0	
209560	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	76.0	
209561	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209562	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209563	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209564	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	0	
209565	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
209566	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
209567	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
209568	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
209569	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
209570	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	
209571	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
209572	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
209573	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
209574	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
209575	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
209576	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
209577	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments	Counter is not working properly, done BFTC and counter did not change. Work order is made. AH	
209578	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
209579	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
209580	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
209581	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
209582	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
209583	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
209584	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
209585	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
209586	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
209587	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
209588	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
209589	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
209590	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
209591	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
209592	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
209593	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
209594	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
209595	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
209596	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
209597	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
209598	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
209599	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209600	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
209601	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	156.0	
209602	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	165.0	
209603	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	168.0	
209604	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209605	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209606	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
209607	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209608	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
209609	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
209610	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	277045	
209611	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	277049	
209612	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209613	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	10L	
209614	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	7L	
209615	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	13L	
209616	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	633	
209617	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209618	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	8	
209619	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
209620	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	5	
209621	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
209622	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
209623	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
209624	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209625	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209626	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209627	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
209628	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
209629	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
209630	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209631	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
209632	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209633	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
209634	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
209635	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
209636	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
209637	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
209638	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BAT000159	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
209639	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
209640	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209641	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209642	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209643	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209644	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209645	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209646	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	
209647	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
209648	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209649	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209650	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209651	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209652	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209653	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
209654	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
209655	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
209656	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
209657	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
209658	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
209659	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
209660	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 inches?	y	
209661	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
209662	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
209663	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
209664	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
209665	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
209666	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	5.0	
209667	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	5.0	
209668	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	5.0	
209669	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209670	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209671	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209672	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	9	
209673	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
209674	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209675	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209676	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209677	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209678	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209679	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209680	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209681	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209682	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209683	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209684	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209685	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
209686	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209687	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209688	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments	ok	
209689	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments	ok	
209690	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209691	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	2276.64	kw
209692	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209693	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
209694	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	55	°C
209695	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	45	°C
209696	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209697	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
209698	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209699	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209700	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209701	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209702	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209703	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209704	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
209705	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.9486	
209706	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
209707	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
209708	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
209709	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209710	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
209711	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
209712	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
209713	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
209714	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BCH000279	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
209715	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
209716	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209717	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209718	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209719	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209720	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209721	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209722	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209723	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209724	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209725	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209726	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209727	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	288	
209728	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	289	
209729	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	4	
209730	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	4	
209731	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
209732	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
209733	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
209734	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
209735	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
209736	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	1	
209737	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	0	
209738	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
209739	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209740	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
209741	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	190	
209742	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
209743	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	1	
209744	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
209745	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
209746	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
209747	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
209748	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
209749	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
209750	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
209751	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
209752	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
209753	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
209754	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
209755	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
209756	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
209757	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
209758	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	91	*F
209759	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
209760	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
209761	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
209762	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
209763	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
209764	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
209765	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
209766	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209767	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
209768	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209769	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
209770	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
209771	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
209772	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
209773	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
209774	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments	ok	
209775	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments	ok	
209776	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209777	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
209778	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
209779	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
209780	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
209781	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
209782	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
209783	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
209784	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
209785	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
209786	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
209787	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
209788	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
209789	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
209790	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
209791	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LTC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	OK	
209792	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LTC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
209793	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209794	9/9/2019 14:07	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
209795	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
209796	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
209797	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
209798	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
209799	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
209800	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
209801	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
209802	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
209803	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
209804	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
209805	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
209806	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	223227	
209807	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	223227	
209808	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209809	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1443	
209810	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
209811	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
209812	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
209813	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
209814	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
209815	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
209816	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1305	
209817	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209818	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209819	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209820	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
209821	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
209822	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
209823	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
209824	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
209825	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
209826	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
209827	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
209828	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209829	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209830	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
209831	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
209832	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
209833	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
209834	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
209835	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
209836	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
209837	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
209838	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
209839	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
209840	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
209841	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
209842	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
209843	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
209844	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
209845	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
209846	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments		
209847	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
209848	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
209849	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	y	
209850	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
209851	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
209852	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
209853	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
209854	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
209855	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
209856	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
209857	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
209858	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
209859	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
209860	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
209861	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209862	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209863	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209864	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
209865	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209866	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
209867	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
209868	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
209869	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
209870	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
209871	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209872	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
209873	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
209874	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	297569	
209875	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	297574	
209876	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209877	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	5L	
209878	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
209879	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	12L	
209880	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	1529	
209881	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209882	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209883	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
209884	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
209885	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
209886	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
209887	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
209888	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
209889	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209890	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
209891	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209892	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
209893	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
209894	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
209895	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
209896	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
209897	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
209898	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
209899	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
209900	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
209901	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
209902	9/9/2019 14:21	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
209903	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	55	*C
209904	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209905	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
209906	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209907	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209908	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
209909	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
209910	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209911	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
209912	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9702	
209913	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5620.32	kw
209914	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
209915	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
209916	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	58	*C
209917	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	42	*C
209918	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
209919	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
209920	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
209921	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
209922	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
209923	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
209924	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
209925	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
209926	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	A5 Found Float Voltage	53.5	VDC

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
209927	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
209928	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
209929	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209930	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	BCH000209	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
209931	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
209932	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
209933	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
209934	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	1091	
209935	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
209936	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
209937	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
209938	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	4L	
209939	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	9R	
209940	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	4R	
209941	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
209942	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	6364	
209943	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	6352	
209944	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments	ok	
209945	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments	ok	
209946	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
209947	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
209948	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	50.2	VDC
209949	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	50.2	VDC
209950	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
209951	9/9/2019 9:24	Distribution	Greenville West Quarterly Inspection	BCH000254	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
209952	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
209953	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
209954	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
209955	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
209956	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
209957	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
209958	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
209959	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
209960	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	y	
209961	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
209962	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
209963	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209964	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
209965	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
209966	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209967	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
209968	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
209969	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209970	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
209971	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
209972	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
209973	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
209974	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
209975	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
209976	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
209977	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
209978	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
209979	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
209980	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
209981	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
209982	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
209983	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
209984	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
209985	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
209986	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
209987	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
209988	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
209989	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
209990	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
209991	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
209992	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
209993	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
209994	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
209995	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
209996	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
209997	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
209998	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
209999	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments	ok	
210000	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
210001	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210002	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
210003	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9313.92	kw
210004	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
210005	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
210006	9/9/2019 10:23	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
210007	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
210008	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
210009	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210010	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
210011	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210012	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
210013	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210014	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
210015	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
210016	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
210017	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	130.0	
210018	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	100.0	
210019	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
210020	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210021	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210022	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
210023	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210024	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	42	°C
210025	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	60	°C
210026	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
210027	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210028	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	6249.60	kw
210029	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
210030	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments	ok	
210031	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments	ok	
210032	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210033	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
210034	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
210035	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210036	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
210037	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
210038	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
210039	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	General Comments	ok	
210040	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
210041	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	All Connections OK?	y	
210042	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
210043	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
210044	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
210045	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
210046	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
210047	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
210048	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
210049	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210050	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
210051	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
210052	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
210053	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
210054	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
210055	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
210056	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
210057	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
210058	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
210059	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	0	
210060	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
210061	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
210062	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
210063	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
210064	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
210065	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
210066	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
210067	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
210068	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
210069	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
210070	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
210071	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	
210072	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
210073	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
210074	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
210075	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
210076	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	256	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
210077	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	256	
210078	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
210079	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	0	
210080	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
210081	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
210082	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments	ok	
210083	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments	ok	
210084	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
210085	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
210086	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
210087	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
210088	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
210089	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.6510	
210090	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
210091	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210092	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
210093	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
210094	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
210095	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
210096	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
210097	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
210098	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
210099	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
210100	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
210101	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
210102	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
210103	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
210104	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	50.0	
210105	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	50.0	
210106	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	50.0	
210107	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
210108	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
210109	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
210110	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	11	
210111	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
210112	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
210113	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
210114	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
210115	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
210116	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210117	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
210118	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210119	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210120	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
210121	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
210122	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210123	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
210124	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5202	
210125	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	43	°C
210126	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
210127	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	10.0	
210128	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
210129	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
210130	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
210131	9/9/2019 9:01	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	3	
210132	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
210133	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
210134	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
210135	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
210136	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
210137	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
210138	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
210139	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
210140	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
210141	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
210142	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
210143	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
210144	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
210145	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
210146	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
210147	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
210148	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
210149	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
210150	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
210151	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAPO00036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
210152	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
210153	9/9/2019 13:45	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
210154	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
210155	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
210156	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
210157	9/9/2019 15:13	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
210158	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
210159	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210160	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
210161	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210162	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210163	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
210164	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
210165	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
210166	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
210167	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
210168	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
210169	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
210170	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
210171	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
210172	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
210173	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
210174	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
210175	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
210176	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
210177	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210178	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
210179	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
210180	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210181	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
210182	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
210183	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
210184	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
210185	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
210186	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
210187	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	324	
210188	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	320	
210189	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
210190	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
210191	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
210192	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
210193	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	32	°C
210194	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
210195	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
210196	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
210197	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
210198	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210199	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
210200	9/9/2019 11:30	Distribution	Denham Street Quarterly Inspection	MB0136	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
210201	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
210202	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
210203	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
210204	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
210205	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
210206	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
210207	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210208	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
210209	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210210	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210211	9/9/2019 15:12	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
210212	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
210213	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2496.96	kw
210214	9/9/2019 12:43	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
210215	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
210216	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
210217	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
210218	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
210219	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
210220	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
210221	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
210222	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	56691	
210223	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
210224	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
210225	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210226	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210227	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
210228	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
210229	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
210230	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
210231	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
210232	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210233	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
210234	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
210235	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
210236	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
210237	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
210238	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
210239	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
210240	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
210241	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	261	
210242	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	41	°C
210243	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
210244	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	41	°C
210245	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
210246	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	41	°C
210247	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
210248	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
210249	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
210250	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210251	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
210252	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
210253	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
210254	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
210255	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
210256	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
210257	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
210258	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210259	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
210260	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210261	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210262	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
210263	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
210264	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210265	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
210266	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
210267	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
210268	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
210269	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
210270	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
210271	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
210272	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
210273	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.6270	
210274	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
210275	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210276	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
210277	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
210278	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
210279	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
210280	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
210281	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
210282	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
210283	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
210284	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
210285	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
210286	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
210287	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
210288	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments	ok	
210289	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
210290	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
210291	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
210292	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
210293	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
210294	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
210295	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
210296	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
210297	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
210298	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
210299	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
210300	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210301	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210302	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments	ok	
210303	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
210304	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	6019.20	kw
210305	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210306	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
210307	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	55	°C
210308	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	45	°C
210309	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210310	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
210311	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210312	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210313	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
210314	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
210315	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210316	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
210317	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210318	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210319	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
210320	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
210321	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
210322	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
210323	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
210324	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
210325	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
210326	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
210327	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
210328	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
210329	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
210330	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
210331	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
210332	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
210333	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
210334	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
210335	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
210336	9/9/2019 13:20	Distribution	Leitchfield East Quarterly Inspection	LTC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
210337	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
210338	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
210339	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
210340	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
210341	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
210342	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
210343	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
210344	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
210345	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
210346	9/9/2019 12:34	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
210347	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
210348	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
210349	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	General Comments		
210350	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
210351	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
210352	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
210353	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	56695	
210354	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
210355	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	LTC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
210356	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
210357	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
210358	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210359	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
210360	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
210361	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
210362	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210363	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
210364	9/9/2019 12:22	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
210365	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
210366	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
210367	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	985	
210368	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
210369	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
210370	9/9/2019 13:29	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
210371	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
210372	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
210373	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
210374	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
210375	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
210376	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210377	9/9/2019 14:12	Distribution	Somerset 3 Quarterly Inspection	MB0123	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
210378	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
210379	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
210380	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
210381	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
210382	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
210383	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
210384	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.7806	
210385	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
210386	9/9/2019 13:58	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
210387	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
210388	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210389	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
210390	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
210391	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
210392	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
210393	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
210394	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	1219	
210395	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	6L	
210396	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	7R	
210397	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
210398	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
210399	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210400	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
210401	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
210402	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments	ok	
210403	9/9/2019 11:32	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
210404	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	689015	
210405	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	689008	
210406	9/9/2019 10:47	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments	ok	
210407	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
210408	9/9/2019 10:49	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
210409	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210410	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
210411	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
210412	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210413	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210414	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
210415	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210416	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
210417	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
210418	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
210419	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
210420	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
210421	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
210422	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
210423	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
210424	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
210425	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
210426	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210427	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
210428	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210429	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
210430	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210431	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
210432	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
210433	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210434	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.2	psi
210435	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
210436	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
210437	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
210438	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
210439	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
210440	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
210441	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	62	°C
210442	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	53	°C
210443	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
210444	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
210445	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	72	°C
210446	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	60	°C
210447	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	74	°C
210448	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	61	°C
210449	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	76	°C
210450	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	62	°C
210451	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210677	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
210678	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
210679	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
210680	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	148.0	
210681	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	123.0	
210682	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	128.0	
210683	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
210684	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
210685	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
210686	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
210687	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
210688	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
210689	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
210690	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
210691	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
210692	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
210693	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	30	
210694	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	30	
210695	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
210696	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
210697	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
210698	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
210699	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
210700	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0644	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
210701	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	58	
210702	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	58	
210703	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
210704	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
210705	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
210706	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
210707	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
210708	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
210709	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
210710	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
210711	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
210712	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
210713	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
210714	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
210715	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
210716	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
210717	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
210718	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	341.0	
210719	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	304.0	
210720	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	345.0	
210721	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
210722	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
210723	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
210724	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
210725	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LB0650	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
210726	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210727	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210728	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
210729	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
210730	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
210731	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
210732	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
210733	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
210734	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210735	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
210736	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
210737	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
210738	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
210739	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	17.0	
210740	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
210741	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
210742	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
210743	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
210744	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
210745	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
210746	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
210747	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	Light	
210748	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
210749	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
210750	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
210751	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitro bottle empty	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
210752	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
210753	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
210754	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
210755	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
210756	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210757	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
210758	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210759	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
210760	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210761	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
210762	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
210763	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210764	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
210765	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
210766	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
210767	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
210768	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
210769	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
210770	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
210771	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
210772	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
210773	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
210774	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
210775	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
210776	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
210777	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
210778	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
210779	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
210780	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
210781	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
210782	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
210783	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
210784	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
210785	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
210786	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
210787	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
210788	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
210789	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
210790	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
210791	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
210792	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
210793	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
210794	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
210795	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
210796	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
210797	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
210798	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LTC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
210799	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
210800	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
210801	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
210802	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
210803	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
210804	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
210805	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
210806	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
210807	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
210808	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
210809	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
210810	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
210811	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
210812	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
210813	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
210814	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
210815	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
210816	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Foundation Condition	Good	
210817	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
210818	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
210819	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Grounds in Place?	y	
210820	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
210821	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
210822	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	57	
210823	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
210824	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
210825	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	57	
210826	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
210827	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
210828	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
210829	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
210830	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
210831	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
210832	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
210833	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
210834	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
210835	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
210836	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
210837	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
210838	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
210839	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	360.0	
210840	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	400.0	
210841	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	360.0	
210842	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
210843	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
210844	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
210845	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
210846	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
210847	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
210848	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
210849	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
210850	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
210851	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
210852	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
210853	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
210854	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
210855	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
210856	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
210857	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
210858	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
210859	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
210860	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
210861	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
210862	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
210863	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
210864	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
210865	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
210866	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
210867	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.0	VDC
210868	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	47.0	VDC
210869	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
210870	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
210871	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
210872	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
210873	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
210874	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
210875	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
210876	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
210877	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
210878	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
210879	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
210880	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
210881	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
210882	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
210883	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
210884	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
210885	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
210886	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
210887	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
210888	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
210889	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
210890	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
210891	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
210892	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
210893	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BAT000562	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
210894	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
210895	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
210896	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
210897	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
210898	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
210899	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds In Place?	y	
210900	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
210901	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
210902	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
210903	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.7500	
210904	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1000	
210905	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
210906	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
210907	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
210908	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
210909	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
210910	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
210911	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
210912	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
210913	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
210914	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
210915	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
210916	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
210917	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2750.00	kw
210918	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
210919	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
210920	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
210921	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
210922	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
210923	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
210924	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
210925	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
210926	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
210927	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
210928	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
210929	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
210930	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
210931	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
210932	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
210933	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
210934	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >S' Clearance To Trees?	y	
210935	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
210936	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
210937	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
210938	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
210939	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
210940	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
210941	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
210942	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
210943	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
210944	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
210945	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
210946	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
210947	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
210948	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
210949	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
210950	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
210951	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
210952	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
210953	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	97	
210954	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	97	
210955	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
210956	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
210957	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
210958	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
210959	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
210960	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
210961	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
210962	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
210963	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
210964	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
210965	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
210966	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
210967	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
210968	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
210969	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
210970	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
210971	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
210972	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
210973	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
210974	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
210975	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
210976	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
210977	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
210978	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	28	
210979	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	28	
210980	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
210981	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
210982	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
210983	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
210984	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
210985	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
210986	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	390	
210987	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	390	
210988	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
210989	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
210990	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
210991	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
210992	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
210993	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
210994	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
210995	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
210996	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
210997	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
210998	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	%
210999	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	%
211000	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	%
211001	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211002	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	230.0	
211003	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	170.0	
211004	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	140.0	
211005	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211006	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211007	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211008	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	3	
211009	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
211010	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
211011	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
211012	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
211013	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
211014	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
211015	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
211016	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
211017	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
211018	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
211019	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Structure Patrol Inspection	Good	
211020	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
211021	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
211022	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
211023	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
211024	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
211025	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
211026	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	6	
211027	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211028	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211029	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211030	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
211031	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
211032	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
211033	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
211034	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
211035	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
211036	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
211037	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
211038	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
211039	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
211040	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
211041	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
211042	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
211043	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
211044	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
211045	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
211046	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
211047	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
211048	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
211049	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
211050	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
211051	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211052	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
211053	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
211054	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
211055	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
211056	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
211057	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
211058	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
211059	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
211060	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
211061	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
211062	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
211063	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
211064	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
211065	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
211066	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
211067	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	393	
211068	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	393	
211069	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
211070	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
211071	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
211072	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
211073	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
211074	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
211075	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
211076	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
211077	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
211078	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
211079	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211080	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211081	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211082	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211083	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	250.0	
211084	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	330.0	
211085	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	240.0	
211086	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211087	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211088	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211089	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	9	
211090	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
211091	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
211092	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
211093	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
211094	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
211095	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
211096	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
211097	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
211098	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
211099	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
211100	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
211101	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
211102	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
211103	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
211104	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
211105	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
211106	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
211107	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
211108	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
211109	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
211110	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
211111	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #-'s
211112	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
211113	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
211114	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
211115	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
211116	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
211117	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
211118	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
211119	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
211120	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
211121	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
211122	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15161	
211123	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
211124	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
211125	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
211126	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211127	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
211128	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
211129	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
211130	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
211131	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
211132	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
211133	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
211134	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
211135	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
211136	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
211137	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
211138	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
211139	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211140	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	226226	
211141	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	226226	
211142	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
211143	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
211144	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211145	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
211146	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
211147	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	99960	
211148	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	99960	
211149	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	0	
211150	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
211151	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Unknown Operations	0	
211152	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
211153	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
211154	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
211155	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
211156	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
211157	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
211158	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
211159	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
211160	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
211161	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
211162	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
211163	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
211164	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
211165	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
211166	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	2	
211167	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211168	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211169	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211170	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	140.0	
211171	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	100.0	
211172	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	100.0	
211173	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211174	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211175	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211176	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211177	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
211178	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
211179	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
211180	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
211181	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
211182	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
211183	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
211184	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
211185	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
211186	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
211187	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
211188	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
211189	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
211190	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
211191	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
211192	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
211193	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
211194	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
211195	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
211196	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
211197	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
211198	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
211199	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
211200	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
211201	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211202	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
211203	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
211204	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
211205	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
211206	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
211207	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
211208	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
211209	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
211210	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
211211	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
211212	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211213	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211214	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211215	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
211216	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
211217	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
211218	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
211219	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
211220	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
211221	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211222	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409389	
211223	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409389	
211224	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
211225	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
211226	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211227	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
211228	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
211229	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
211230	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
211231	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
211232	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
211233	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
211234	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
211235	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
211236	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
211237	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
211238	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
211239	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
211240	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
211241	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
211242	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
211243	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
211244	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
211245	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
211246	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
211247	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
211248	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
211249	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
211250	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	General Comments		
211251	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
211252	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
211253	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
211254	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
211255	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
211256	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	213	
211257	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	219	
211258	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	6	
211259	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
211260	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	6	
211261	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
211262	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
211263	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
211264	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0097	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
211265	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
211266	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
211267	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
211268	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
211269	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
211270	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
211271	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
211272	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
211273	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
211274	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
211275	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
211276	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
211277	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
211278	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
211279	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
211280	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
211281	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
211282	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
211283	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
211284	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
211285	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
211286	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
211287	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
211288	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
211289	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
211290	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
211291	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
211292	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18217	
211293	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
211294	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
211295	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
211296	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
211297	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
211298	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
211299	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
211300	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
211301	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
211302	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
211303	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
211304	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
211305	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
211306	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
211307	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
211308	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
211309	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
211310	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
211311	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
211312	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
211313	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
211314	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
211315	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
211316	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
211317	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
211318	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
211319	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
211320	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
211321	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
211322	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
211323	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
211324	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
211325	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
211326	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
211327	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
211328	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
211329	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
211330	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
211331	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
211332	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
211333	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
211334	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17072	
211335	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
211336	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
211337	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
211338	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
211339	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
211340	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
211341	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
211342	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
211343	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
211344	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
211345	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
211346	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
211347	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
211348	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
211349	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
211350	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
211351	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211352	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	BCH000404	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
211353	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
211354	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
211355	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
211356	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
211357	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
211358	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	150.0	
211359	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
211360	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
211361	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
211362	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
211363	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
211364	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
211365	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
211366	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
211367	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
211368	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
211369	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
211370	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
211371	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
211372	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
211373	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
211374	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
211375	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
211376	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
211377	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
211378	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
211379	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
211380	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
211381	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
211382	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
211383	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
211384	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
211385	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
211386	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
211387	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
211388	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
211389	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
211390	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	120.0	
211391	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	120.0	
211392	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	120.0	
211393	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
211394	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
211395	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
211396	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
211397	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
211398	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
211399	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
211400	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
211401	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
211402	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
211403	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
211404	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
211405	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
211406	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
211407	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
211408	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	337	
211409	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	341	
211410	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	4	
211411	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
211412	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
211413	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
211414	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	4	
211415	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
211416	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
211417	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
211418	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
211419	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
211420	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
211421	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
211422	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
211423	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
211424	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
211425	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
211426	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
211427	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
211428	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	11	
211429	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
211430	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
211431	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
211432	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
211433	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
211434	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
211435	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
211436	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
211437	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
211438	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
211439	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
211440	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
211441	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
211442	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
211443	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
211444	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
211445	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
211446	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
211447	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
211448	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
211449	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	General Comments		
211450	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
211451	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Unknown Operations	0	
211452	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
211453	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
211454	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	555	
211455	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	555	
211456	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
211457	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
211458	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
211459	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
211460	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
211461	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
211462	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
211463	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
211464	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
211465	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211466	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211467	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211468	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211469	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	20.0	
211470	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	30.0	
211471	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	20.0	
211472	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211473	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211474	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211475	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
211476	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
211477	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
211478	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
211479	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	174	
211480	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	178	
211481	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
211482	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
211483	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
211484	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
211485	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
211486	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
211487	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
211488	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
211489	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
211490	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
211491	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	0	
211492	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
211493	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
211494	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	4	
211495	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
211496	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	4	
211497	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	449	
211498	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	445	
211499	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	9	
211500	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
211501	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211502	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
211503	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	150.0	
211504	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	150.0	
211505	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
211506	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
211507	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
211508	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
211509	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
211510	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
211511	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
211512	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
211513	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
211514	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
211515	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
211516	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
211517	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1765.44	kw
211518	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
211519	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
211520	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	45	°C
211521	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
211522	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
211523	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
211524	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
211525	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
211526	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
211527	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
211528	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
211529	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
211530	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3678	
211531	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	45	°C
211532	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	35	°C
211533	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
211534	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
211535	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	5	
211536	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211537	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211538	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211539	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211540	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211541	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211542	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	913	
211543	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
211544	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
211545	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
211546	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
211547	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	179259	
211548	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	179259	
211549	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
211550	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
211551	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211552	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
211553	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	100.0	
211554	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	90.0	
211555	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	80.0	
211556	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211557	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211558	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211559	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211560	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
211561	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
211562	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
211563	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
211564	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
211565	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
211566	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211567	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211568	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211569	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
211570	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2371	
211571	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	51	°C
211572	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
211573	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments		
211574	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
211575	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
211576	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	4.2	psi

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
211577	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
211578	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
211579	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
211580	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
211581	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
211582	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
211583	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
211584	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
211585	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
211586	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
211587	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
211588	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
211589	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211590	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
211591	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
211592	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
211593	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
211594	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
211595	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
211596	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
211597	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
211598	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
211599	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
211600	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
211601	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
211602	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
211603	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
211604	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
211605	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
211606	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	418131	
211607	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	418131	
211608	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211609	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
211610	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
211611	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
211612	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
211613	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	191	
211614	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
211615	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211616	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211617	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211618	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
211619	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
211620	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
211621	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
211622	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
211623	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211624	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
211625	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
211626	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	15146	
211627	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	15146	
211628	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211629	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
211630	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	6R	
211631	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	8L	
211632	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
211633	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	1568	
211634	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211635	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211636	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211637	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
211638	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
211639	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
211640	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
211641	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
211642	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
211643	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
211644	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
211645	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
211646	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
211647	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
211648	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
211649	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
211650	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
211651	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211652	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
211653	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
211654	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
211655	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
211656	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
211657	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
211658	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
211659	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
211660	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
211661	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
211662	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
211663	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
211664	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
211665	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
211666	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
211667	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
211668	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
211669	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
211670	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
211671	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
211672	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
211673	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
211674	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1260.00	kw
211675	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
211676	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
211677	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
211678	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	38	°C
211679	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
211680	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
211681	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
211682	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
211683	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
211684	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
211685	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
211686	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
211687	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5250	
211688	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	50	°C
211689	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	38	°C
211690	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
211691	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
211692	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
211693	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
211694	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	65190	
211695	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
211696	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
211697	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
211698	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
211699	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
211700	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
211701	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
211702	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
211703	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
211704	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
211705	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
211706	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
211707	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
211708	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
211709	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
211710	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
211711	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
211712	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
211713	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
211714	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
211715	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
211716	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
211717	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
211718	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
211719	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
211720	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
211721	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
211722	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
211723	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
211724	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
211725	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
211726	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
211727	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
211728	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
211729	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
211730	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
211731	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
211732	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
211733	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
211734	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
211735	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
211736	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
211737	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
211738	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
211739	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
211740	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
211741	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
211742	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
211743	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
211744	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
211745	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
211746	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
211747	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
211748	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
211749	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
211750	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
211751	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
211752	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
211753	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
211754	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
211755	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
211756	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
211757	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
211758	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
211759	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
211760	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
211761	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
211762	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
211763	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
211764	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
211765	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
211766	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
211767	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
211768	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	250	
211769	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	254	
211770	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	4	
211771	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
211772	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	4	
211773	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
211774	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
211775	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
211776	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211777	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211778	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211779	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
211780	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
211781	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
211782	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211783	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211784	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211785	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211786	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
211787	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
211788	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
211789	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
211790	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
211791	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
211792	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
211793	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
211794	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
211795	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
211796	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
211797	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
211798	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
211799	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
211800	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
211801	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211802	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
211803	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
211804	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
211805	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
211806	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
211807	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
211808	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
211809	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
211810	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
211811	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
211812	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
211813	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
211814	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
211815	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	60456	
211816	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
211817	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
211818	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
211819	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
211820	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
211821	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
211822	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
211823	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
211824	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
211825	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
211826	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
211827	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
211828	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
211829	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
211830	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
211831	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
211832	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
211833	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
211834	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
211835	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	9	
211836	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
211837	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
211838	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
211839	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	25.0	
211840	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	25.0	
211841	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	25.0	
211842	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
211843	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
211844	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
211845	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
211846	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
211847	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
211848	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
211849	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
211850	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
211851	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
211852	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC0000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
211853	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211854	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211855	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
211856	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1115	
211857	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	54	°C
211858	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
211859	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
211860	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
211861	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
211862	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211863	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	9044	
211864	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	9044	
211865	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
211866	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
211867	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211868	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
211869	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
211870	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
211871	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
211872	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
211873	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
211874	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
211875	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	56	°C
211876	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211877	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
211878	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
211879	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
211880	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
211881	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
211882	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
211883	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
211884	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
211885	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	General Comments		
211886	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
211887	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
211888	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
211889	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
211890	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	LTC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
211891	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
211892	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
211893	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
211894	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
211895	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
211896	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
211897	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	200.0	
211898	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	275.0	
211899	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	290.0	
211900	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
211901	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
211902	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
211903	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
211904	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
211905	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
211906	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
211907	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
211908	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
211909	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
211910	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
211911	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
211912	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
211913	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
211914	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	566	
211915	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	566	
211916	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
211917	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
211918	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
211919	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
211920	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	885	°F
211921	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
211922	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
211923	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
211924	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
211925	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
211926	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
211927	9/6/2019 15:02	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
211928	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
211929	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
211930	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
211931	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
211932	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	67	
211933	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
211934	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
211935	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	65	
211936	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
211937	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
211938	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
211939	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments		
211940	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
211941	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
211942	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
211943	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
211944	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
211945	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
211946	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
211947	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
211948	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
211949	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
211950	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
211951	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
211952	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
211953	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
211954	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
211955	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
211956	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	791	
211957	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
211958	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
211959	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
211960	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
211961	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	561	
211962	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	565	
211963	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
211964	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
211965	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	10L	
211966	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
211967	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	5L	
211968	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
211969	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	6019	
211970	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	6019	
211971	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
211972	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
211973	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
211974	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
211975	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
211976	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
211977	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.0	
211978	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.0	
211979	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	249	
211980	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
211981	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
211982	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	286	
211983	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
211984	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
211985	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
211986	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
211987	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
211988	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
211989	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
211990	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
211991	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
211992	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
211993	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
211994	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
211995	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
211996	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
211997	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
211998	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
211999	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
212000	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
212001	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212002	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
212003	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212004	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
212005	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
212006	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212007	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
212008	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
212009	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
212010	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
212011	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
212012	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
212013	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212014	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212015	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
212016	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
212017	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
212018	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
212019	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
212020	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
212021	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
212022	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
212023	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Readings	General Comments		
212024	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	BB0105	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
212025	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
212026	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
212027	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
212028	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
212029	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
212030	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
212031	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
212032	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
212033	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
212034	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
212035	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
212036	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
212037	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
212038	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments	ok	
212039	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
212040	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
212041	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212042	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212043	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
212044	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
212045	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
212046	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
212047	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	*C
212048	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
212049	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
212050	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212051	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
212052	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
212053	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212054	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212055	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
212056	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212057	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
212058	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
212059	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212060	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212061	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212062	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212063	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212064	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
212065	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
212066	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
212067	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
212068	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
212069	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
212070	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
212071	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
212072	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
212073	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
212074	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
212075	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
212076	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
212077	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
212078	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
212079	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
212080	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
212081	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
212082	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
212083	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
212084	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
212085	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
212086	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
212087	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
212088	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
212089	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
212090	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
212091	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
212092	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
212093	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
212094	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
212095	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
212096	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
212097	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
212098	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
212099	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
212100	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
212101	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212102	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
212103	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
212104	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212105	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212106	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
212107	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
212108	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212109	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212110	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
212111	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
212112	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
212113	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
212114	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
212115	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
212116	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
212117	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212118	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
212119	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
212120	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212121	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212122	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
212123	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212124	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
212125	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
212126	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212127	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212128	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212129	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212130	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212131	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
212132	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
212133	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
212134	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212135	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212136	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
212137	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
212138	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
212139	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
212140	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
212141	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
212142	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
212143	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
212144	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
212145	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
212146	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
212147	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
212148	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
212149	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
212150	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
212151	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
212152	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
212153	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
212154	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
212155	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	114929	
212156	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
212157	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
212158	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
212159	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
212160	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
212161	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
212162	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
212163	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
212164	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
212165	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
212166	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
212167	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
212168	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
212169	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
212170	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
212171	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
212172	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
212173	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	9L	
212174	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
212175	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
212176	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212177	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
212178	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
212179	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	115878	
212180	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
212181	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
212182	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
212183	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
212184	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
212185	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
212186	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LTC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
212187	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
212188	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
212189	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
212190	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
212191	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
212192	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
212193	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
212194	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
212195	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
212196	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
212197	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
212198	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
212199	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
212200	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
212201	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
212202	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
212203	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
212204	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
212205	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
212206	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
212207	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
212208	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
212209	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
212210	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
212211	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	112628	
212212	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
212213	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
212214	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
212215	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
212216	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
212217	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
212218	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
212219	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
212220	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
212221	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
212222	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
212223	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
212224	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
212225	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
212226	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
212227	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
212228	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
212229	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
212230	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
212231	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
212232	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
212233	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
212234	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
212235	9/6/2019 11:52	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
212236	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
212237	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
212238	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
212239	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
212240	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
212241	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
212242	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
212243	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
212244	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
212245	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
212246	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
212247	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
212248	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
212249	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
212250	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
212251	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212252	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
212253	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
212254	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
212255	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	8	
212256	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
212257	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
212258	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
212259	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
212260	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
212261	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
212262	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
212263	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
212264	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
212265	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
212266	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
212267	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1600	
212268	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1600	
212269	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
212270	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
212271	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
212272	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
212273	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
212274	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
212275	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
212276	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
212277	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
212278	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
212279	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
212280	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1097	
212281	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
212282	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC000248	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
212283	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC000248	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
212284	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
212285	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
212286	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
212287	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
212288	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	1R	
212289	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
212290	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
212291	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
212292	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
212293	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
212294	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
212295	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
212296	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
212297	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
212298	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
212299	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
212300	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
212301	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
212302	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
212303	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
212304	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
212305	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
212306	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
212307	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	61674	
212308	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
212309	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
212310	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
212311	9/6/2019 8:04	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
212312	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Unknown Operations	0	
212313	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
212314	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	0	
212315	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	936	
212316	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	936	
212317	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
212318	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
212319	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
212320	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
212321	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
212322	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
212323	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
212324	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
212325	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
212326	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212327	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
212328	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
212329	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
212330	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	90.0	
212331	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	100.0	
212332	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	80.0	
212333	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
212334	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
212335	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
212336	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
212337	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	*F
212338	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
212339	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	9	
212340	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212341	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212342	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212343	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
212344	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
212345	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
212346	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
212347	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
212348	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212349	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212350	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212351	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212352	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212353	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212354	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212355	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212356	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
212357	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
212358	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
212359	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
212360	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
212361	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
212362	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
212363	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
212364	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
212365	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
212366	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
212367	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
212368	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
212369	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	459	
212370	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	463	
212371	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	4	
212372	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212373	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	4	
212374	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
212375	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
212376	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
212377	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
212378	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
212379	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
212380	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
212381	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
212382	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
212383	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
212384	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
212385	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
212386	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
212387	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	LTC0000248	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
212388	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
212389	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
212390	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
212391	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
212392	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	113890	
212393	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	113890	
212394	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
212395	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
212396	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
212397	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
212398	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Unknown Operations	0	
212399	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
212400	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	0	
212401	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	621	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212402	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	621	
212403	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
212404	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
212405	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
212406	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
212407	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
212408	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
212409	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
212410	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
212411	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
212412	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
212413	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
212414	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
212415	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
212416	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	30.0	
212417	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	20.0	
212418	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	20.0	
212419	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
212420	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
212421	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
212422	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	3	
212423	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
212424	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
212425	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
212426	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
212427	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
212428	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
212429	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
212430	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
212431	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
212432	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
212433	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212434	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212435	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
212436	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
212437	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
212438	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212439	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212440	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212441	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212442	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212443	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212444	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212445	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	40	°C
212446	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	65	°C
212447	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
212448	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
212449	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3775.68	kw
212450	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212451	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
212452	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
212453	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212454	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212455	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
212456	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212457	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212458	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212459	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212460	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212461	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
212462	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212463	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212464	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	1	
212465	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
212466	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
212467	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
212468	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
212469	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
212470	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212471	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212472	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
212473	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
212474	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
212475	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212476	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212477	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	68	
212478	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	68	
212479	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212480	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212481	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212482	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212483	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
212484	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
212485	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
212486	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
212487	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
212488	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
212489	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212490	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
212491	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212492	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	324	
212493	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	324	
212494	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	0	
212495	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
212496	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
212497	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
212498	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	0	
212499	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Unknown Operations	0	
212500	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	2	
212501	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212502	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
212503	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
212504	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
212505	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
212506	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
212507	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
212508	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
212509	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	20.0	
212510	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212511	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212512	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212513	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
212514	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
212515	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
212516	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
212517	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
212518	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
212519	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
212520	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
212521	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
212522	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
212523	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212524	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212525	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	36.0	
212526	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	10.0	
212527	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	21.0	
212528	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
212529	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
212530	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
212531	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
212532	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
212533	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	1	
212534	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
212535	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
212536	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
212537	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
212538	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212539	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212540	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212541	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212542	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212543	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
212544	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
212545	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.7866	
212546	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
212547	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212548	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212549	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
212550	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
212551	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212552	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
212553	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212554	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	73.0	
212555	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	60.0	
212556	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212557	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212558	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212559	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	6540.48	kw
212560	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
212561	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
212562	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	44	°C
212563	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	65	°C
212564	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212565	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212566	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
212567	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
212568	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
212569	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212570	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212571	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
212572	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212573	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212574	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212575	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212576	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212577	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212578	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
212579	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
212580	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
212581	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
212582	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
212583	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
212584	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	1.3626	
212585	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
212586	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
212587	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
212588	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
212589	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
212590	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
212591	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
212592	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
212593	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
212594	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
212595	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Foundation Condition	Good	
212596	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
212597	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
212598	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Grounds in Place?	y	
212599	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
212600	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
212601	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	74	
212602	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	74	
212603	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	0	
212604	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212605	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
212606	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
212607	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
212608	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	0	
212609	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212610	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
212611	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
212612	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
212613	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
212614	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212615	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
212616	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
212617	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
212618	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
212619	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
212620	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
212621	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
212622	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
212623	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
212624	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
212625	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212626	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212627	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
212628	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
212629	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
212630	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
212631	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
212632	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
212633	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
212634	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
212635	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212636	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212637	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212638	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212639	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments	A phase i.o.c	
212640	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212641	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
212642	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
212643	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
212644	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
212645	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
212646	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
212647	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
212648	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
212649	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	83	
212650	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	83	
212651	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	1	
212652	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212653	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
212654	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
212655	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
212656	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
212657	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212658	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
212659	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212660	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212661	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
212662	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
212663	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	
212664	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	0	
212665	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212666	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212667	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212668	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	65.0	
212669	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212670	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212671	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212672	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	145.0	
212673	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	155.0	
212674	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	160.0	
212675	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212676	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	290.0	
212677	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
212678	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
212679	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
212680	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
212681	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
212682	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
212683	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
212684	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
212685	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
212686	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
212687	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
212688	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
212689	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
212690	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
212691	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212692	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	1	
212693	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	80	
212694	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	80	
212695	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
212696	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
212697	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Grounds in Place?	y	
212698	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
212699	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
212700	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
212701	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212702	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
212703	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
212704	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
212705	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
212706	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
212707	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212708	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212709	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212710	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212711	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	84	
212712	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
212713	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212714	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
212715	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
212716	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212717	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212718	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212719	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212720	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	4.0	
212721	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
212722	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	1	
212723	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212724	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212725	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
212726	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
212727	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
212728	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212729	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212730	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
212731	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
212732	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
212733	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
212734	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
212735	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	1	
212736	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
212737	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
212738	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
212739	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
212740	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
212741	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
212742	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	300.0	
212743	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
212744	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
212745	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
212746	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
212747	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212748	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212749	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212750	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212751	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212752	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212753	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212754	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212755	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	257.0	
212756	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	297.0	
212757	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	319.0	
212758	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212759	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212760	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212761	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	0	
212762	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
212763	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
212764	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	1	
212765	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
212766	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
212767	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
212768	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
212769	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
212770	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
212771	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
212772	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
212773	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
212774	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
212775	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
212776	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212777	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
212778	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
212779	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
212780	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
212781	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
212782	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
212783	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
212784	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
212785	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
212786	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
212787	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
212788	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
212789	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
212790	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
212791	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
212792	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
212793	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
212794	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	84	
212795	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	300.0	
212796	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
212797	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
212798	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
212799	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
212800	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
212801	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
212802	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
212803	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
212804	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
212805	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
212806	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
212807	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
212808	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
212809	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
212810	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
212811	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
212812	9/6/2019 13:58	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
212813	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
212814	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
212815	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	*C
212816	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	*C
212817	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	*C
212818	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
212819	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
212820	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
212821	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-03-07 00:00:00.000000	
212822	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
212823	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	*C
212824	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212825	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212826	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
212827	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
212828	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
212829	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
212830	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	1	
212831	9/6/2019 9:41	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	4	
212832	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
212833	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
212834	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
212835	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	351	
212836	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
212837	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	47.0	
212838	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	36.0	
212839	9/6/2019 12:48	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212840	9/6/2019 14:31	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
212841	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
212842	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	351	
212843	9/6/2019 14:50	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
212844	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
212845	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
212846	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	477	
212847	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
212848	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
212849	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
212850	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
212851	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
212852	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
212853	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
212854	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	32.0	
212855	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.0	
212856	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	X0261	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	36.0	
212857	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
212858	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
212859	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
212860	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
212861	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
212862	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
212863	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
212864	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
212865	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
212866	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
212867	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
212868	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
212869	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212870	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
212871	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
212872	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
212873	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
212874	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	77	
212875	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
212876	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
212877	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
212878	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
212879	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
212880	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
212881	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
212882	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	369.0	
212883	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	419.0	
212884	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	409.0	
212885	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
212886	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
212887	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
212888	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
212889	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
212890	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
212891	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
212892	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
212893	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	1	
212894	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	199	
212895	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212896	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
212897	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	199	
212898	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
212899	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	0	
212900	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Heaters (All) Functioning?	y	
212901	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	
212902	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
212903	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
212904	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
212905	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
212906	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
212907	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
212908	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
212909	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
212910	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
212911	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
212912	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
212913	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
212914	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
212915	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
212916	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
212917	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
212918	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
212919	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
212920	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
212921	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
212922	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	177	
212923	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	177	
212924	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
212925	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
212926	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
212927	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
212928	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
212929	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
212930	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
212931	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
212932	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
212933	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
212934	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
212935	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212936	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
212937	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
212938	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
212939	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
212940	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
212941	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
212942	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
212943	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
212944	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
212945	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
212946	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
212947	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
212948	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49239	
212949	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
212950	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
212951	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
212952	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
212953	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
212954	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
212955	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
212956	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
212957	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
212958	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
212959	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
212960	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
212961	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
212962	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
212963	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
212964	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
212965	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
212966	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
212967	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
212968	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
212969	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
212970	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
212971	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
212972	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
212973	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
212974	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
212975	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	60	°C
212976	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	50	°C
212977	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212978	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
212979	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
212980	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
212981	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
212982	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
212983	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
212984	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
212985	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
212986	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
212987	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
212988	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
212989	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
212990	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
212991	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
212992	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
212993	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
212994	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
212995	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
212996	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
212997	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
212998	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
212999	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
213000	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
213001	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213002	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
213003	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	59	°C
213004	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	40	°C
213005	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
213006	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	65	°C
213007	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	65	°C
213008	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	70	°C
213009	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	40	°C
213010	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	70	°C
213011	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	55	°C
213012	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213013	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
213014	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213015	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213016	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	General Comments		
213017	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
213018	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
213019	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213020	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
213021	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.6372	
213022	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
213023	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
213024	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
213025	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
213026	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
213027	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
213028	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	748	
213029	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	15L	
213030	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	6L	
213031	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	10L	
213032	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
213033	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	15830	
213034	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	15821	
213035	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
213036	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
213037	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	45	°C
213038	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	40	°C
213039	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
213040	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
213041	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
213042	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
213043	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
213044	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
213045	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
213046	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
213047	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213048	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
213049	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213050	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
213051	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
213052	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213053	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213054	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213055	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213056	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
213057	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213058	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
213059	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
213060	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
213061	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213062	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213063	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
213064	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
213065	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Oil level shows level low.	
213066	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
213067	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
213068	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
213069	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
213070	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
213071	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
213072	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
213073	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213074	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
213075	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
213076	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
213077	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
213078	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
213079	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
213080	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
213081	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
213082	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
213083	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
213084	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	9175.68	kw
213085	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
213086	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213087	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
213088	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213089	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213090	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213091	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
213092	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
213093	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
213094	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
213095	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213096	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213097	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213098	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213099	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213100	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213101	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213102	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
213103	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
213104	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
213105	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
213106	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213107	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213108	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
213109	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
213110	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213111	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
213112	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
213113	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
213114	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
213115	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
213116	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
213117	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
213118	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
213119	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
213120	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213121	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
213122	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213123	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213124	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213125	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213126	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213127	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
213128	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
213129	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213130	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
213131	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
213132	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
213133	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
213134	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
213135	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
213136	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
213137	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
213138	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
213139	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
213140	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
213141	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	828	
213142	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
213143	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	10L	
213144	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	4L	
213145	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	7L	
213146	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
213147	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	71201	
213148	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	71201	
213149	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
213150	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
213151	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
213152	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
213153	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
213154	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
213155	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
213156	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
213157	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
213158	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
213159	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
213160	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	1	
213161	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	8	
213162	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213163	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213164	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213165	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	80.0	
213166	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	80.0	
213167	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	100.0	
213168	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
213169	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213170	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213171	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213172	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213173	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213174	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213175	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213176	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213177	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213178	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
213179	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
213180	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
213181	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
213182	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
213183	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
213184	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
213185	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
213186	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
213187	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
213188	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
213189	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
213190	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	233	
213191	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213192	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
213193	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
213194	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	237	
213195	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	4	
213196	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213197	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213198	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
213199	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213200	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
213201	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	4	
213202	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
213203	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
213204	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
213205	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
213206	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213207	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213208	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213209	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
213210	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213211	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
213212	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
213213	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
213214	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
213215	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213216	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	50	°C
213217	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
213218	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
213219	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
213220	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213221	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
213222	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Could not check fans, the switch was stuck in Auto, and the transformer needs Nitro. Transformer has a 6 pack	
213223	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
213224	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213225	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213226	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213227	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
213228	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
213229	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
213230	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213231	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213232	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213233	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213234	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213235	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213236	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213237	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
213238	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
213239	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213240	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
213241	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
213242	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213243	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
213244	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213245	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
213246	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213247	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
213248	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213249	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
213250	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213251	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
213252	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
213253	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
213254	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
213255	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
213256	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
213257	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
213258	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
213259	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	3	
213260	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
213261	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	3	
213262	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	224	
213263	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	221	
213264	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
213265	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
213266	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
213267	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
213268	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
213269	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
213270	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
213271	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
213272	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
213273	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
213274	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
213275	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	0	
213276	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
213277	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213278	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213279	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213280	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213281	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213282	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213283	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213284	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213285	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213286	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
213287	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	45.0	
213288	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	76.0	
213289	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	71.0	
213290	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
213291	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
213292	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
213293	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	5	
213294	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
213295	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		
213296	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
213297	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
213298	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213299	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
213300	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
213301	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
213302	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
213303	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220535	
213304	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220535	
213305	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments	..	
213306	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
213307	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
213308	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
213309	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
213310	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
213311	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
213312	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
213313	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
213314	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
213315	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
213316	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47752	
213317	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
213318	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
213319	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
213320	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
213321	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
213322	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
213323	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
213324	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
213325	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
213326	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
213327	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
213328	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
213329	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	182	
213330	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
213331	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
213332	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
213333	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
213334	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
213335	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
213336	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
213337	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
213338	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
213339	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
213340	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
213341	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	5	
213342	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
213343	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	5	
213344	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	220	
213345	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	215	
213346	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
213347	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
213348	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
213349	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
213350	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
213351	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
213352	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
213353	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
213354	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
213355	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
213356	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	
213357	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	1	
213358	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213359	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
213360	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
213361	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
213362	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
213363	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
213364	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
213365	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
213366	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
213367	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
213368	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
213369	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
213370	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
213371	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
213372	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
213373	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
213374	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213375	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	16.19	
213376	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213377	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
213378	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
213379	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
213380	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
213381	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
213382	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
213383	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
213384	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
213385	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
213386	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
213387	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
213388	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
213389	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
213390	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
213391	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
213392	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
213393	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
213394	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
213395	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
213396	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213397	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
213398	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213399	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213400	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
213401	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213402	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213403	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213404	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
213405	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213406	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	21	
213407	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213408	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
213409	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
213410	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
213411	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
213412	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213413	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	0.0	
213414	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	0.0	
213415	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213416	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213417	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213418	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	9	
213419	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	182	
213420	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213421	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
213422	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
213423	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
213424	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
213425	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
213426	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
213427	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
213428	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
213429	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
213430	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
213431	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
213432	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213433	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213434	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213435	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213436	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	326.0	
213437	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	328.0	
213438	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	324.0	
213439	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	3.39	%
213440	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	4.52	%
213441	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	4.52	%
213442	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
213443	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
213444	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
213445	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
213446	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
213447	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
213448	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
213449	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
213450	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
213451	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213452	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
213453	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213454	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213455	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213456	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213457	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213458	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213459	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213460	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213461	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213462	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213463	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213464	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213465	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213466	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
213467	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	140.0	
213468	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	120.0	
213469	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	140.0	
213470	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213471	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213472	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213473	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
213474	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	35.0	
213475	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213476	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
213477	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
213478	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213479	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213480	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
213481	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213482	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
213483	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213484	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
213485	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	..	
213486	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213487	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213488	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
213489	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
213490	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
213491	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213492	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
213493	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
213494	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
213495	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
213496	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	"F
213497	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
213498	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
213499	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
213500	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
213501	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
213502	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
213503	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
213504	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
213505	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
213506	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
213507	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
213508	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
213509	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BAT000421	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
213510	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
213511	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
213512	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
213513	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
213514	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
213515	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
213516	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
213517	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
213518	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213519	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	108.0	
213520	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	100.0	
213521	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	82.0	
213522	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
213523	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
213524	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
213525	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	1212	
213526	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213527	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	7L	
213528	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	1R	
213529	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	4L	
213530	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
213531	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	8792	
213532	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	8784	
213533	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
213534	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
213535	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
213536	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
213537	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
213538	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
213539	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45466	
213540	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
213541	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
213542	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
213543	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
213544	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
213545	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
213546	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
213547	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	1	
213548	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
213549	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
213550	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
213551	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	810.0	
213552	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	832.0	
213553	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	825.0	
213554	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213555	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213556	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213557	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213558	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
213559	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
213560	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
213561	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
213562	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
213563	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
213564	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
213565	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
213566	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments		
213567	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
213568	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
213569	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
213570	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
213571	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
213572	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
213573	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
213574	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
213575	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
213576	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	5	
213577	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213578	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213579	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213580	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	270.0	
213581	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	280.0	
213582	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	234.0	
213583	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
213584	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213585	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
213586	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LTC0000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	ok	
213587	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213588	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213589	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213590	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213591	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213592	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
213593	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
213594	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
213595	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LTC0000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
213596	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
213597	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
213598	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
213599	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
213600	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
213601	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213602	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
213603	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
213604	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
213605	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
213606	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
213607	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
213608	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
213609	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
213610	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
213611	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
213612	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
213613	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
213614	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
213615	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
213616	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
213617	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
213618	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
213619	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	208	
213620	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	211	
213621	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	3	
213622	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	2	
213623	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
213624	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	1	
213625	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
213626	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
213627	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
213628	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
213629	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
213630	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
213631	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
213632	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
213633	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
213634	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
213635	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
213636	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
213637	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
213638	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
213639	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
213640	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
213641	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
213642	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
213643	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	16	
213644	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
213645	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
213646	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	22	
213647	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
213648	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	235	
213649	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	261	
213650	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	26	
213651	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
213652	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	2	
213653	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
213654	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
213655	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
213656	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
213657	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
213658	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
213659	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
213660	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
213661	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
213662	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
213663	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
213664	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
213665	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
213666	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
213667	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
213668	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
213669	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
213670	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
213671	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
213672	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
213673	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
213674	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
213675	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments		
213676	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
213677	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213678	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
213679	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
213680	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
213681	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
213682	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
213683	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
213684	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
213685	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
213686	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
213687	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
213688	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
213689	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
213690	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
213691	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
213692	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
213693	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
213694	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
213695	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
213696	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
213697	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
213698	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
213699	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
213700	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
213701	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
213702	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
213703	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
213704	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
213705	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
213706	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
213707	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
213708	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
213709	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
213710	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
213711	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
213712	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
213713	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
213714	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
213715	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
213716	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
213717	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
213718	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
213719	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
213720	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
213721	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
213722	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
213723	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
213724	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213725	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
213726	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
213727	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213728	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	128	
213729	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	128	
213730	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
213731	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments		
213732	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
213733	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
213734	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
213735	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
213736	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
213737	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
213738	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
213739	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213740	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213741	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213742	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213743	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
213744	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
213745	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
213746	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213747	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213748	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	54	°C
213749	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	33	°C
213750	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	54	°C
213751	9/5/2019 13:06	Distribution	Jefferson town Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	32	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213752	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	54	°C
213753	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
213754	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213755	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
213756	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213757	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
213758	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
213759	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
213760	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
213761	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1850	psi
213762	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
213763	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213764	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
213765	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
213766	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
213767	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
213768	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
213769	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
213770	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
213771	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
213772	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
213773	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
213774	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BCH000483	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
213775	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
213776	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
213777	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
213778	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
213779	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	961	
213780	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	51	°C
213781	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	9	°C
213782	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
213783	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
213784	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
213785	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
213786	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
213787	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
213788	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	3191	
213789	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	3191	
213790	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	The LTC does not have a nitrogen gauge, needs to be removed from insp.	
213791	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
213792	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
213793	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
213794	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	32	°C
213795	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
213796	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	32	°C
213797	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
213798	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	33	°C
213799	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
213800	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
213801	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
213802	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
213803	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213804	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213805	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213806	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213807	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213808	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213809	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
213810	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213811	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
213812	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
213813	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
213814	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
213815	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213816	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213817	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
213818	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments	There is no cooling group position switch, needs to be removed from insp.	
213819	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
213820	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213821	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.9	psi
213822	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1025	psi
213823	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	53	°C
213824	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	34	°C
213825	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213826	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213827	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213828	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
213829	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
213830	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
213831	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
213832	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
213833	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
213834	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
213835	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	202	
213836	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
213837	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
213838	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
213839	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
213840	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	101910	
213841	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	101910	
213842	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
213843	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
213844	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
213845	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
213846	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	30	
213847	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213848	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213849	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213850	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	100.0	
213851	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	100.0	
213852	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	100.0	
213853	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
213854	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
213855	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
213856	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	890	
213857	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	890	
213858	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
213859	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments	Arc Sense, Actual counter	
213860	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
213861	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213862	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213863	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213864	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213865	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213866	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213867	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	8.87	
213868	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213869	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213870	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	2	
213871	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
213872	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
213873	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
213874	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
213875	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
213876	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
213877	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
213878	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
213879	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
213880	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
213881	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	62	°C
213882	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
213883	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	60	°C
213884	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
213885	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
213886	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
213887	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	60	°C
213888	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
213889	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
213890	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
213891	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
213892	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213893	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
213894	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
213895	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments	There is no cooling group position switch, needs to be removed from insp	
213896	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
213897	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213898	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
213899	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
213900	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
213901	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
213902	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
213903	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
213904	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
213905	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
213906	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	5	
213907	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	5	
213908	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	571	
213909	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
213910	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
213911	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
213912	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
213913	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
213914	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	571	
213915	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
213916	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
213917	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
213918	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
213919	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
213920	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
213921	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
213922	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
213923	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213924	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
213925	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
213926	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
213927	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
213928	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
213929	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
213930	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
213931	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
213932	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
213933	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
213934	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	12	
213935	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
213936	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
213937	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
213938	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
213939	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
213940	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
213941	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
213942	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213943	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
213944	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
213945	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
213946	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
213947	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
213948	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
213949	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
213950	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	7361.28	kw
213951	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
213952	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
213953	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	45	°C
213954	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	50	°C
213955	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
213956	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
213957	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
213958	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
213959	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	9.0	
213960	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	8.0	
213961	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
213962	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
213963	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
213964	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	8.0	
213965	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
213966	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
213967	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
213968	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
213969	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
213970	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
213971	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
213972	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
213973	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
213974	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
213975	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
213976	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
213977	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	10	
213978	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
213979	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
213980	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
213981	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	20.0	
213982	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	20.0	
213983	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	20.0	
213984	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
213985	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
213986	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
213987	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
213988	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
213989	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
213990	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
213991	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
213992	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
213993	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
213994	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
213995	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
213996	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
213997	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
213998	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
213999	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
214000	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
214001	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
214002	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
214003	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
214004	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	204589	
214005	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
214006	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	12L	
214007	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	3L	
214008	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	15L	
214009	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1461	
214010	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
214011	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
214012	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
214013	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	21	
214014	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
214015	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
214016	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
214017	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
214018	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
214019	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
214020	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
214021	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
214022	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	If no, which cells in comments
214023	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
214024	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
214025	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
214026	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	84	*F
214027	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
214028	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
214029	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
214030	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
214031	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
214032	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
214033	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
214034	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
214035	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
214036	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
214037	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
214038	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
214039	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
214040	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
214041	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
214042	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
214043	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
214044	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
214045	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
214046	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
214047	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
214048	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
214049	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
214050	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
214051	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214052	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
214053	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
214054	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
214055	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
214056	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
214057	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
214058	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
214059	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
214060	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
214061	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
214062	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
214063	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
214064	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	2.26	%
214065	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	1	
214066	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
214067	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
214068	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214069	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214070	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
214071	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
214072	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
214073	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
214074	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
214075	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
214076	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
214077	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
214078	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
214079	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
214080	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
214081	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
214082	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
214083	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	166	
214084	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	166	
214085	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
214086	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
214087	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
214088	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1479	
214089	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1479	
214090	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
214091	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
214092	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
214093	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
214094	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
214095	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
214096	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	°C
214097	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
214098	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
214099	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
214100	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	55	°C
214101	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
214102	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
214103	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
214104	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
214105	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
214106	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
214107	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
214108	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
214109	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
214110	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
214111	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
214112	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
214113	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
214114	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
214115	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
214116	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	55	°C
214117	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
214118	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
214119	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
214120	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
214121	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	360	
214122	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	364	
214123	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	4	
214124	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
214125	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	4	
214126	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
214127	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
214128	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
214129	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	0	
214130	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	2.26	%
214131	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	2.26	%
214132	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	2.26	%
214133	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	174.0	
214134	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	178.0	
214135	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	177.0	
214136	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214137	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214138	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
214139	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
214140	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
214141	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
214142	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214143	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214144	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
214145	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
214146	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.7668	
214147	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
214148	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
214149	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
214150	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
214151	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
214152	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	187	
214153	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	187	
214154	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
214155	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
214156	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
214157	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
214158	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
214159	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
214160	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
214161	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
214162	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
214163	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214164	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214165	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214166	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214167	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	187.0	
214168	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	189.0	
214169	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	184.0	
214170	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
214171	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
214172	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
214173	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
214174	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
214175	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
214176	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
214177	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
214178	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
214179	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
214180	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
214181	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
214182	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
214183	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
214184	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	618	
214185	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3R	
214186	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
214187	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
214188	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
214189	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	26621	
214190	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	26621	
214191	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
214192	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
214193	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
214194	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
214195	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
214196	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
214197	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
214198	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
214199	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1094	
214200	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
214201	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214202	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
214203	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
214204	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
214205	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
214206	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
214207	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	18874	
214208	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	18874	
214209	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
214210	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
214211	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
214212	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
214213	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
214214	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
214215	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
214216	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
214217	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
214218	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
214219	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
214220	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
214221	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
214222	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
214223	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
214224	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
214225	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
214226	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
214227	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
214228	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
214229	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
214230	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
214231	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
214232	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
214233	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
214234	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
214235	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
214236	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
214237	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
214238	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
214239	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
214240	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
214241	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
214242	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
214243	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
214244	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
214245	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
214246	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
214247	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
214248	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214249	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
214250	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Unknown Operations	0	
214251	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	1	
214252	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	1	
214253	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1270	
214254	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1270	
214255	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
214256	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
214257	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
214258	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
214259	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
214260	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	
214261	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
214262	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214263	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214264	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214265	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	100.0	
214266	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	130.0	
214267	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	120.0	
214268	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214269	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
214270	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214271	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments		
214272	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	22	
214273	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Unknown Operations	0	
214274	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	0	
214275	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	0	
214276	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214277	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
214278	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	General Comments		
214279	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
214280	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
214281	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
214282	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
214283	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1276	
214284	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1276	
214285	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
214286	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
214287	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
214288	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214289	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
214290	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
214291	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
214292	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
214293	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
214294	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
214295	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
214296	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
214297	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
214298	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
214299	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
214300	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	173	
214301	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	173	
214302	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	0	
214303	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
214304	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
214305	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
214306	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
214307	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214308	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
214309	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
214310	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
214311	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
214312	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
214313	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
214314	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
214315	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
214316	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
214317	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
214318	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
214319	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
214320	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
214321	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
214322	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments	needs Desiccant	
214323	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	204589	
214324	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
214325	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
214326	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
214327	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
214328	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
214329	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
214330	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
214331	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
214332	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
214333	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments	No spare fuses	
214334	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
214335	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
214336	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
214337	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
214338	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
214339	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
214340	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
214341	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
214342	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
214343	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
214344	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
214345	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
214346	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
214347	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
214348	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
214349	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
214350	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
214351	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214352	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
214353	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214354	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214355	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214356	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	140.0	
214357	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	160.0	
214358	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	160.0	
214359	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	26	
214360	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214361	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
214362	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214363	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
214364	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
214365	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
214366	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214367	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214368	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214369	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214370	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
214371	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	3.64	%
214372	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	7.28	%
214373	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
214374	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
214375	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
214376	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
214377	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
214378	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
214379	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
214380	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
214381	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
214382	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1619	
214383	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1619	
214384	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
214385	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
214386	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
214387	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
214388	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
214389	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
214390	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
214391	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	LTC0000853	LTCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds
214392	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	0	
214393	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
214394	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
214395	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
214396	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	127.0	
214397	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	129.0	
214398	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	126.0	
214399	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214400	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214401	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214402	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
214403	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
214404	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
214405	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
214406	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
214407	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
214408	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
214409	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
214410	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
214411	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
214412	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214413	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214414	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
214415	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
214416	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
214417	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
214418	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
214419	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
214420	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	10	
214421	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
214422	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
214423	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	0	
214424	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	44	
214425	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	44	
214426	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214427	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
214428	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
214429	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
214430	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
214431	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
214432	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
214433	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
214434	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
214435	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214436	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214437	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
214438	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
214439	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
214440	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	522	
214441	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	522	
214442	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
214443	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
214444	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
214445	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
214446	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214447	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214448	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214449	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214450	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
214451	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
214452	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
214453	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
214454	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214455	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
214456	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
214457	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
214458	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
214459	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
214460	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
214461	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	71.0	
214462	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	70.0	
214463	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	79.0	
214464	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
214465	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
214466	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
214467	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
214468	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
214469	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
214470	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
214471	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
214472	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
214473	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214474	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214475	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
214476	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
214477	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
214478	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	
214479	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
214480	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB00094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	4	
214481	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
214482	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
214483	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
214484	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
214485	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
214486	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
214487	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1141	
214488	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
214489	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
214490	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
214491	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
214492	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
214493	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
214494	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
214495	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
214496	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
214497	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
214498	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
214499	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
214500	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
214501	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214502	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
214503	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
214504	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
214505	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214506	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214507	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTC0000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
214508	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
214509	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	194077	
214510	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	194077	
214511	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
214512	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
214513	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
214514	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
214515	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
214516	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
214517	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
214518	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
214519	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
214520	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
214521	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
214522	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
214523	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
214524	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
214525	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
214526	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
214527	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
214528	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
214529	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
214530	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
214531	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	49	°C
214532	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
214533	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
214534	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
214535	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
214536	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
214537	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
214538	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
214539	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
214540	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
214541	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
214542	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
214543	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
214544	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
214545	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
214546	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214547	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
214548	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
214549	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
214550	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
214551	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214552	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
214553	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
214554	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	2	
214555	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	2	
214556	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	220	
214557	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	218	
214558	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
214559	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
214560	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
214561	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
214562	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
214563	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
214564	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
214565	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
214566	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
214567	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
214568	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
214569	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
214570	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
214571	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
214572	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
214573	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
214574	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
214575	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
214576	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214577	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
214578	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
214579	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
214580	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
214581	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
214582	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
214583	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
214584	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
214585	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
214586	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
214587	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
214588	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
214589	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
214590	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
214591	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
214592	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
214593	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	3617.28	kw
214594	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
214595	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
214596	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
214597	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
214598	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
214599	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
214600	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
214601	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
214602	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
214603	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	4	
214604	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
214605	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
214606	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
214607	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
214608	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
214609	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
214610	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
214611	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
214612	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214613	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	115.0	
214614	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	100.0	
214615	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	100.0	
214616	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
214617	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
214618	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
214619	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
214620	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
214621	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	90.0	
214622	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
214623	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
214624	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
214625	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
214626	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
214627	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
214628	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
214629	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
214630	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
214631	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
214632	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
214633	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
214634	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-26 00:00:00.000000	
214635	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
214636	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
214637	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
214638	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
214639	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
214640	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
214641	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
214642	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
214643	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
214644	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
214645	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
214646	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
214647	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
214648	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
214649	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
214650	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
214651	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214652	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
214653	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
214654	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
214655	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
214656	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
214657	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
214658	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
214659	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
214660	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
214661	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
214662	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
214663	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
214664	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
214665	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
214666	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
214667	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
214668	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
214669	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
214670	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
214671	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
214672	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
214673	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
214674	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214675	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214676	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	100.0	
214677	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	100.0	
214678	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
214679	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	100.0	
214680	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
214681	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
214682	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
214683	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
214684	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
214685	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
214686	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	1	
214687	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	172	
214688	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	172	
214689	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
214690	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	1	
214691	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Heaters (All) Functioning?	y	
214692	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
214693	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
214694	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
214695	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
214696	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments	1- unknown	
214697	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
214698	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	0	
214699	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
214700	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
214701	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
214702	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
214703	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
214704	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
214705	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
214706	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
214707	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214708	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
214709	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
214710	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
214711	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
214712	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
214713	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214714	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments		
214715	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
214716	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214717	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
214718	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	15R	
214719	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
214720	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
214721	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
214722	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
214723	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
214724	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
214725	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
214726	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
214727	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
214728	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
214729	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214730	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214731	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
214732	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
214733	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
214734	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
214735	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
214736	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
214737	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
214738	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
214739	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
214740	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
214741	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
214742	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
214743	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
214744	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
214745	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
214746	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	318	
214747	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
214748	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
214749	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
214750	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
214751	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
214752	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	318	
214753	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
214754	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
214755	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
214756	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
214757	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
214758	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
214759	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
214760	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
214761	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
214762	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
214763	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
214764	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
214765	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	80	*F
214766	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
214767	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
214768	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	90.0	
214769	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214770	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214771	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214772	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
214773	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
214774	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
214775	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
214776	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
214777	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
214778	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
214779	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
214780	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
214781	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
214782	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
214783	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
214784	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	195	
214785	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	195	
214786	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
214787	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil Level	Good	
214788	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
214789	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
214790	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
214791	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
214792	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
214793	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Unknown Operations	0	
214794	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
214795	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
214796	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
214797	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
214798	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
214799	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
214800	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214801	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	34	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214802	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214803	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	60.0	
214804	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	55.0	
214805	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
214806	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
214807	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	29	
214808	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	29	
214809	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
214810	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
214811	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
214812	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	55.0	
214813	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214814	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214815	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214816	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
214817	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
214818	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
214819	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
214820	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
214821	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
214822	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
214823	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	200	
214824	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	200	
214825	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
214826	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
214827	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Unknown Operations	0	
214828	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	47	
214829	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214830	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
214831	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214832	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	90.0	
214833	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	100.0	
214834	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
214835	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
214836	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
214837	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
214838	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
214839	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
214840	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
214841	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
214842	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
214843	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
214844	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
214845	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
214846	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
214847	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
214848	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	19	
214849	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214850	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
214851	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214852	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
214853	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
214854	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
214855	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
214856	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214857	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
214858	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
214859	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
214860	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
214861	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
214862	9/5/2019 13:06	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
214863	9/5/2019 13:06	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
214864	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
214865	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
214866	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
214867	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
214868	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
214869	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
214870	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
214871	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
214872	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
214873	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
214874	9/5/2019 13:06	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
214875	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214876	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
214877	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
214878	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
214879	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
214880	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
214881	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
214882	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
214883	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
214884	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
214885	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
214886	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
214887	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
214888	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
214889	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
214890	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
214891	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
214892	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
214893	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
214894	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
214895	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
214896	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
214897	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
214898	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	*C
214899	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
214900	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
214901	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
214902	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	49	
214903	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	0	*C
214904	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	0	*C
214905	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
214906	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
214907	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	68	*C
214908	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	*C
214909	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	0	*C
214910	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	0	*C
214911	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	*C
214912	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	46	*C
214913	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	49	
214914	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
214915	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
214916	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	*C
214917	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	30	
214918	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
214919	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
214920	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	12	
214921	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
214922	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
214923	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
214924	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	120.0	
214925	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	125.0	
214926	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	120.0	
214927	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
214928	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
214929	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
214930	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
214931	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
214932	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
214933	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
214934	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
214935	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments	High side inst Phase A	
214936	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
214937	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	809	
214938	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
214939	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
214940	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
214941	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	809	
214942	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
214943	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	
214944	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Unknown Operations	0	
214945	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
214946	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
214947	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
214948	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
214949	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
214950	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
214951	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
214952	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
214953	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
214954	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
214955	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
214956	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
214957	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
214958	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
214959	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
214960	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
214961	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
214962	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
214963	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
214964	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
214965	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
214966	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
214967	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
214968	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments		
214969	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
214970	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
214971	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
214972	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
214973	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
214974	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
214975	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
214976	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
214977	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
214978	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
214979	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
214980	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
214981	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
214982	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
214983	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
214984	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
214985	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
214986	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
214987	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
214988	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	300.0	
214989	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	300.0	
214990	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	300.0	
214991	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
214992	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
214993	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
214994	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	0	
214995	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Unit heaters are turned off at breaker	
214996	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
214997	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
214998	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
214999	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
215000	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
215001	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
215002	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
215003	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
215004	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215005	9/5/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
215006	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
215007	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
215008	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215009	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
215010	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
215011	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
215012	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
215013	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
215014	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
215015	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments	Could not read or reset X2, Oil Temp, or H2 max, button wont change screen. Screen needs to be replaced on a TRANSFORMER ADVA	
215016	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	45	*C
215017	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	45	*C
215018	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
215019	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
215020	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
215021	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	27478	
215022	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	27478	
215023	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
215024	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3R	
215025	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	13R	
215026	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	2L	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215027	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
215028	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
215029	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
215030	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
215031	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
215032	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
215033	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
215034	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
215035	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
215036	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
215037	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
215038	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
215039	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
215040	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
215041	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
215042	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
215043	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
215044	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
215045	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
215046	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
215047	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
215048	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
215049	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
215050	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
215051	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
215052	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
215053	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
215054	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7868.16	kw
215055	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
215056	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
215057	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
215058	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
215059	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
215060	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
215061	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	General Comments		
215062	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
215063	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
215064	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
215065	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
215066	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
215067	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
215068	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
215069	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
215070	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
215071	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	LTC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
215072	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
215073	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215074	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
215075	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	1	
215076	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
215077	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	164	
215078	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	164	
215079	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	3	
215080	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
215081	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
215082	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
215083	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
215084	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
215085	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	2	
215086	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	0	
215087	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215088	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215089	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
215090	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
215091	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
215092	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
215093	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215094	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments		
215095	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
215096	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
215097	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
215098	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
215099	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215100	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
215101	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215102	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215103	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
215104	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215105	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215106	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
215107	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
215108	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
215109	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
215110	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
215111	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
215112	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
215113	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1249	
215114	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1249	
215115	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
215116	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Arc Sense	
215117	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
215118	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
215119	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8196	
215120	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
215121	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
215122	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
215123	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
215124	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
215125	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
215126	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
215127	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
215128	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
215129	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
215130	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
215131	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
215132	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
215133	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
215134	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
215135	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
215136	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
215137	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
215138	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
215139	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
215140	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
215141	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
215142	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
215143	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
215144	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
215145	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
215146	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
215147	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
215148	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
215149	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
215150	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
215151	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
215152	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
215153	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	150.0	
215154	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
215155	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
215156	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
215157	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
215158	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
215159	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
215160	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
215161	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
215162	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
215163	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
215164	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
215165	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
215166	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
215167	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
215168	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
215169	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
215170	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
215171	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	0	
215172	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	149	
215173	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	149	
215174	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
215175	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
215176	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215177	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
215178	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
215179	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
215180	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
215181	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8965	
215182	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
215183	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
215184	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
215185	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
215186	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
215187	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
215188	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
215189	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
215190	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
215191	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
215192	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
215193	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
215194	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
215195	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
215196	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
215197	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
215198	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	87.0	
215199	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
215200	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
215201	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
215202	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	190	
215203	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	192	
215204	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	2	
215205	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	2	
215206	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
215207	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
215208	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
215209	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
215210	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
215211	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
215212	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
215213	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
215214	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
215215	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
215216	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
215217	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
215218	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
215219	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
215220	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
215221	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
215222	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
215223	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
215224	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
215225	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
215226	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
215227	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
215228	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
215229	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
215230	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
215231	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
215232	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
215233	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	52	°C
215234	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	66	°C
215235	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
215236	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
215237	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
215238	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
215239	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
215240	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
215241	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	52	°C
215242	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
215243	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	53	°C
215244	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	66	°C
215245	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
215246	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
215247	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
215248	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
215249	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
215250	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
215251	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215252	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
215253	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
215254	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
215255	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
215256	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8723	
215257	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
215258	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
215259	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
215260	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
215261	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
215262	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
215263	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
215264	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
215265	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215266	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
215267	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
215268	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215269	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
215270	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
215271	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
215272	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
215273	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
215274	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
215275	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
215276	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
215277	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
215278	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	26.0	
215279	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	35.0	
215280	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	28.0	
215281	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215282	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
215283	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	262	
215284	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	265	
215285	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	3	
215286	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
215287	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	2	
215288	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
215289	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
215290	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215291	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
215292	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
215293	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
215294	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
215295	9/5/2019 9:54	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
215296	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
215297	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215298	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215299	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	2	
215300	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
215301	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
215302	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
215303	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
215304	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
215305	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
215306	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	91.0	
215307	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	93.0	
215308	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
215309	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
215310	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	55	°C
215311	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
215312	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	45	°C
215313	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
215314	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
215315	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
215316	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
215317	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
215318	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
215319	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
215320	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
215321	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9500	
215322	9/5/2019 7:54	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.3768	
215323	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215324	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
215325	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
215326	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215327	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
215328	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
215329	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	89.0	
215330	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	111.0	
215331	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	65.0	
215332	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	100.0	
215333	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
215334	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
215335	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
215336	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215337	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
215338	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
215339	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
215340	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
215341	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
215342	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
215343	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
215344	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
215345	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
215346	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
215347	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
215348	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
215349	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
215350	9/5/2019 13:06	Distribution	Jeffersonstown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
215351	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	36	
215352	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
215353	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
215354	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
215355	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	663.0	
215356	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	654.0	
215357	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	642.0	
215358	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
215359	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
215360	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
215361	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
215362	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
215363	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
215364	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
215365	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
215366	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
215367	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
215368	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215369	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
215370	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
215371	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
215372	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
215373	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	72	
215374	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	69	
215375	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
215376	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
215377	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
215378	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215379	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
215380	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215381	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215382	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
215383	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215384	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
215385	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
215386	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
215387	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215388	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
215389	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215390	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
215391	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
215392	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
215393	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215394	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
215395	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
215396	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
215397	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
215398	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
215399	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
215400	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
215401	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215402	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10170	
215403	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
215404	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
215405	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
215406	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
215407	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
215408	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
215409	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
215410	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
215411	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
215412	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
215413	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
215414	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	60.0	
215415	9/5/2019 14:01	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
215416	3/14/2019 10:19	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	VCB Readings	9 Months Operations	26	
215417	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
215418	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
215419	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments		
215420	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	1	
215421	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	0	
215422	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
215423	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
215424	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
215425	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
215426	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
215427	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
215428	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
215429	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
215430	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
215431	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
215432	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
215433	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
215434	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
215435	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
215436	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
215437	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215438	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
215439	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
215440	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
215441	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
215442	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
215443	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
215444	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
215445	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
215446	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
215447	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	317	
215448	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	8.0	
215449	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
215450	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
215451	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
215452	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
215453	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
215454	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
215455	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	16.0	
215456	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	13.0	
215457	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
215458	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
215459	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
215460	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	317	
215461	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
215462	9/5/2019 13:06	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
215463	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
215464	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215465	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
215466	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	General Comments		
215467	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
215468	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215469	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	6	
215470	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215471	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
215472	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	0	
215473	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
215474	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
215475	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
215476	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215477	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
215478	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215479	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
215480	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
215481	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	1	
215482	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
215483	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
215484	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215485	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	7	
215486	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215487	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
215488	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
215489	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
215490	9/5/2019 13:06	Distribution	Jeffersonton Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
215491	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Low	
215492	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
215493	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
215494	9/5/2019 13:05	Distribution	Sharon Quarterly Inspection	BB0017	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	1	
215495	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
215496	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
215497	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	32.38	
215498	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	32.38	
215499	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	32.38	
215500	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215501	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
215502	9/5/2019 14:51	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
215503	9/5/2019 15:24	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215504	9/4/2019 12:09	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
215505	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215506	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
215507	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
215508	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
215509	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215510	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215511	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
215512	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
215513	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	85	°C
215514	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
215515	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
215516	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
215517	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
215518	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
215519	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
215520	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
215521	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
215522	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
215523	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
215524	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
215525	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments	26.9/24.9	
215526	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
215527	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	60	°C
215528	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
215529	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
215530	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
215531	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	General Comments		
215532	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
215533	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
215534	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
215535	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
215536	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	905	
215537	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
215538	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
215539	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
215540	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
215541	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	905	
215542	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
215543	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
215544	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
215545	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
215546	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
215547	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
215548	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
215549	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
215550	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
215551	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215552	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
215553	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
215554	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
215555	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215556	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
215557	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
215558	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	55	°C
215559	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
215560	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
215561	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
215562	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	60.0	
215563	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	60.0	
215564	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
215565	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
215566	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	8	
215567	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
215568	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
215569	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
215570	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	120.0	
215571	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
215572	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
215573	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
215574	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	9	
215575	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
215576	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
215577	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
215578	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
215579	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
215580	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
215581	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
215582	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
215583	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
215584	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
215585	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	General Comments		
215586	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
215587	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
215588	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
215589	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
215590	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
215591	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
215592	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
215593	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
215594	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
215595	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
215596	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
215597	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
215598	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
215599	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
215600	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
215601	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
215602	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
215603	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
215604	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
215605	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
215606	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
215607	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
215608	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
215609	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
215610	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
215611	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
215612	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	There is an old oil leak on the top of a few radiators. Oil is barely seeping.	
215613	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
215614	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215615	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	y	
215616	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
215617	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
215618	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
215619	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
215620	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
215621	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
215622	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
215623	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
215624	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
215625	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
215626	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215627	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
215628	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
215629	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
215630	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
215631	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
215632	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
215633	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
215634	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
215635	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
215636	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
215637	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
215638	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
215639	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
215640	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
215641	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
215642	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
215643	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
215644	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
215645	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
215646	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215647	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215648	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
215649	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
215650	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
215651	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
215652	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
215653	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
215654	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
215655	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
215656	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
215657	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
215658	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
215659	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
215660	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
215661	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
215662	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
215663	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	80	°C
215664	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
215665	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	85	°C
215666	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	700.0	
215667	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
215668	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
215669	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
215670	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
215671	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	700.0	
215672	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
215673	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
215674	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
215675	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
215676	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
215677	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
215678	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
215679	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
215680	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
215681	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
215682	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	700.0	
215683	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
215684	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
215685	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
215686	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
215687	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
215688	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
215689	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
215690	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
215691	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
215692	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
215693	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
215694	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
215695	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
215696	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1200	
215697	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
215698	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
215699	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	215	
215700	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
215701	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215702	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
215703	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
215704	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
215705	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
215706	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
215707	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
215708	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
215709	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
215710	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
215711	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
215712	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
215713	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
215714	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
215715	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215716	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215717	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
215718	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
215719	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	215	
215720	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	49	°C
215721	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	42	°C
215722	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
215723	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
215724	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
215725	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
215726	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
215727	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
215728	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
215729	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
215730	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
215731	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
215732	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
215733	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
215734	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
215735	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
215736	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
215737	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
215738	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
215739	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
215740	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
215741	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
215742	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
215743	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
215744	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
215745	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
215746	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
215747	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
215748	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	48.0	
215749	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
215750	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
215751	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments	Vent fan and the heater in the switchgear aren't working.	
215752	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
215753	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
215754	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
215755	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
215756	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
215757	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
215758	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
215759	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
215760	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
215761	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
215762	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
215763	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
215764	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
215765	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
215766	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.6	psi
215767	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
215768	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2688.00	kw
215769	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
215770	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
215771	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
215772	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	44	°C
215773	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
215774	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
215775	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
215776	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
215777	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
215778	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
215779	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
215780	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
215781	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
215782	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
215783	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
215784	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
215785	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
215786	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
215787	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
215788	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
215789	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
215790	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
215791	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
215792	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
215793	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
215794	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
215795	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
215796	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
215797	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
215798	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
215799	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
215800	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
215801	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
215802	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
215803	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
215804	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
215805	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
215806	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
215807	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
215808	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
215809	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
215810	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
215811	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
215812	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
215813	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
215814	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
215815	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
215816	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
215817	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
215818	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
215819	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
215820	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
215821	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
215822	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
215823	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
215824	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CAPO00103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
215825	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
215826	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
215827	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
215828	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
215829	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
215830	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
215831	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
215832	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
215833	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
215834	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
215835	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
215836	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
215837	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	.21	%
215838	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	2	
215839	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
215840	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
215841	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
215842	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
215843	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
215844	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
215845	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
215846	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
215847	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
215848	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
215849	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
215850	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
215851	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215852	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
215853	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
215854	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
215855	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
215856	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
215857	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
215858	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
215859	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
215860	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
215861	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
215862	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
215863	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
215864	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
215865	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
215866	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
215867	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
215868	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
215869	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
215870	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
215871	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
215872	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
215873	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
215874	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
215875	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
215876	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
215877	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
215878	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
215879	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
215880	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
215881	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
215882	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
215883	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
215884	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
215885	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
215886	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
215887	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
215888	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
215889	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
215890	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
215891	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
215892	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
215893	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
215894	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
215895	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
215896	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
215897	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
215898	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
215899	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
215900	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
215901	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
215902	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
215903	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
215904	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
215905	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
215906	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
215907	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
215908	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
215909	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
215910	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
215911	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
215912	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
215913	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
215914	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
215915	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
215916	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
215917	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
215918	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
215919	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
215920	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
215921	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
215922	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
215923	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
215924	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
215925	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
215926	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	A few limbs are starting to grow over the fence	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
215927	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
215928	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
215929	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
215930	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
215931	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
215932	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
215933	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
215934	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
215935	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
215936	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
215937	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
215938	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
215939	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
215940	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
215941	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
215942	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
215943	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
215944	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
215945	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
215946	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
215947	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
215948	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
215949	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
215950	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
215951	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
215952	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
215953	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
215954	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
215955	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
215956	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
215957	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
215958	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
215959	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215960	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215961	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
215962	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
215963	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
215964	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
215965	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
215966	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
215967	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
215968	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
215969	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
215970	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
215971	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
215972	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
215973	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
215974	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
215975	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
215976	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
215977	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
215978	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
215979	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
215980	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
215981	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
215982	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
215983	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
215984	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
215985	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
215986	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
215987	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
215988	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
215989	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
215990	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
215991	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
215992	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
215993	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
215994	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
215995	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
215996	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
215997	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	522	
215998	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
215999	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
216000	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
216001	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
216002	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
216003	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
216004	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
216005	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
216006	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
216007	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
216008	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
216009	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
216010	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
216011	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
216012	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	522	
216013	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
216014	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
216015	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
216016	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
216017	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
216018	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
216019	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
216020	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216021	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216022	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
216023	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
216024	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
216025	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216026	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
216027	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
216028	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
216029	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
216030	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
216031	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
216032	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
216033	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
216034	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
216035	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
216036	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
216037	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
216038	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
216039	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
216040	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
216041	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
216042	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
216043	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
216044	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
216045	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
216046	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
216047	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
216048	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
216049	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	740	
216050	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
216051	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
216052	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216053	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216054	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216055	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216056	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
216057	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
216058	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
216059	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
216060	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
216061	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
216062	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
216063	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
216064	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
216065	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	131	
216066	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	131	
216067	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
216068	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
216069	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
216070	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
216071	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
216072	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
216073	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216074	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216075	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
216076	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
216077	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216078	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
216079	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216080	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0031	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
216081	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
216082	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
216083	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
216084	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
216085	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
216086	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
216087	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
216088	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
216089	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
216090	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
216091	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
216092	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216093	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
216094	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
216095	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	164125	
216096	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216097	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
216098	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
216099	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
216100	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
216101	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
216102	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	164125	
216103	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
216104	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
216105	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
216106	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	1L	
216107	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
216108	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1919	
216109	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
216110	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216111	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216112	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216113	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
216114	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
216115	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
216116	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
216117	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
216118	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
216119	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	3	
216120	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
216121	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
216122	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
216123	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
216124	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
216125	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
216126	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
216127	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
216128	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
216129	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
216130	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
216131	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
216132	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216133	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
216134	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216135	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216136	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
216137	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216138	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
216139	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
216140	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
216141	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
216142	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
216143	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
216144	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
216145	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
216146	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
216147	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments	Breaker open	
216148	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
216149	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	142	
216150	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	142	
216151	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
216152	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
216153	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
216154	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
216155	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
216156	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
216157	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
216158	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
216159	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
216160	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
216161	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216162	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216163	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
216164	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
216165	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
216166	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
216167	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	198.0	
216168	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	189.0	
216169	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
216170	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
216171	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
216172	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
216173	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
216174	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
216175	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
216176	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
216177	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
216178	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
216179	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	200.0	
216180	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	.42	%
216181	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	.42	%
216182	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
216183	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
216184	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
216185	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
216186	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
216187	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
216188	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
216189	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
216190	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
216191	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
216192	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
216193	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
216194	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
216195	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
216196	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
216197	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
216198	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
216199	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
216200	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
216201	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
216202	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Unknown Operations	0	
216203	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
216204	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
216205	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
216206	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
216207	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	206	
216208	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	206	
216209	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
216210	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
216211	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
216212	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
216213	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
216214	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
216215	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
216216	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
216217	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
216218	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
216219	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
216220	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
216221	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
216222	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216223	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216224	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216225	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216226	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	60	*C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216227	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
216228	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
216229	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
216230	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	60	°C
216231	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
216232	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	740	
216233	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
216234	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
216235	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
216236	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
216237	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
216238	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
216239	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
216240	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
216241	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
216242	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
216243	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
216244	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
216245	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
216246	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
216247	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
216248	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
216249	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
216250	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
216251	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
216252	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
216253	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
216254	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
216255	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
216256	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
216257	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
216258	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
216259	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
216260	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
216261	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
216262	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
216263	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216264	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
216265	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
216266	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
216267	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
216268	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	876	
216269	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
216270	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
216271	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments	amp gauges are off by approx. 30-35 amps lower than the amp meter	
216272	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
216273	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
216274	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
216275	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
216276	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC0000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
216277	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
216278	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
216279	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
216280	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
216281	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
216282	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
216283	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
216284	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
216285	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
216286	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
216287	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	41.2	
216288	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	29.4	
216289	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	33.2	
216290	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
216291	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
216292	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
216293	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
216294	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
216295	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
216296	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
216297	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
216298	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	241	
216299	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	241	
216300	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
216301	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
216302	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Unknown Operations	0	
216303	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	1	
216304	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
216305	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
216306	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
216307	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
216308	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
216309	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
216310	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
216311	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
216312	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
216313	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
216314	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
216315	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
216316	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
216317	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
216318	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
216319	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
216320	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
216321	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
216322	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
216323	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41667	
216324	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
216325	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
216326	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
216327	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
216328	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
216329	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
216330	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216331	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
216332	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
216333	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	50	°C
216334	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	45	°C
216335	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
216336	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
216337	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
216338	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	67	°C
216339	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
216340	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
216341	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
216342	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
216343	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
216344	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
216345	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
216346	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Unknown Operations	0	
216347	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
216348	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	21	
216349	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	573	
216350	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	573	
216351	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
216352	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
216353	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
216354	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	22	
216355	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
216356	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments	A/B/C Phase IOC	
216357	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
216358	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
216359	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
216360	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	21	
216361	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
216362	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	380.0	
216363	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	360.0	
216364	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
216365	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216366	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
216367	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216368	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
216369	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
216370	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
216371	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
216372	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
216373	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
216374	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1401	
216375	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1401	
216376	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	61	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216377	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
216378	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	247	
216379	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
216380	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
216381	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Unknown Operations	0	
216382	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
216383	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
216384	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	General Comments		
216385	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
216386	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
216387	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
216388	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
216389	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
216390	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
216391	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
216392	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
216393	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216394	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216395	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
216396	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
216397	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
216398	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
216399	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
216400	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0033	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
216401	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0005	BreakersSF6	AK-1295	GCB Readings	Amps A Ø	340.0	
216402	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216403	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC0000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
216404	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC0000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
216405	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC0000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
216406	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
216407	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
216408	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
216409	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
216410	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
216411	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
216412	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
216413	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
216414	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
216415	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
216416	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
216417	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
216418	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
216419	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
216420	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
216421	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
216422	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	321	
216423	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	321	
216424	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
216425	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
216426	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
216427	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
216428	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
216429	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
216430	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
216431	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
216432	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
216433	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
216434	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216435	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
216436	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
216437	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
216438	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
216439	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
216440	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
216441	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Unknown Operations	0	
216442	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	213	
216443	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
216444	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
216445	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
216446	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
216447	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Unknown Operations	0	
216448	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216449	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216450	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216451	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	865	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216452	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	11L	
216453	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	1R	
216454	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	6L	
216455	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
216456	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71791	
216457	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71779	
216458	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
216459	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
216460	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216461	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
216462	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	50	°C
216463	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	80	°C
216464	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
216465	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	80	°C
216466	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	50	°C
216467	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
216468	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
216469	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
216470	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
216471	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
216472	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
216473	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
216474	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
216475	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
216476	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
216477	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
216478	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
216479	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
216480	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
216481	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
216482	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
216483	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
216484	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
216485	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
216486	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
216487	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
216488	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
216489	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216490	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216491	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
216492	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
216493	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
216494	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
216495	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
216496	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
216497	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
216498	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
216499	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
216500	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
216501	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
216502	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
216503	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
216504	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1860	
216505	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1860	
216506	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
216507	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
216508	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
216509	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
216510	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
216511	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
216512	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216513	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
216514	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216515	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
216516	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
216517	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
216518	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
216519	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	0.0	
216520	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	0.0	
216521	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	0.0	
216522	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
216523	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
216524	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
216525	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
216526	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
216527	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
216528	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
216529	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
216530	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216531	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216532	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
216533	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216534	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216535	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216536	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216537	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
216538	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
216539	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
216540	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
216541	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
216542	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
216543	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
216544	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
216545	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments	breaker open	
216546	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
216547	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
216548	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
216549	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
216550	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	213	
216551	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
216552	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
216553	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
216554	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216555	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216556	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
216557	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216558	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216559	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216560	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216561	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216562	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216563	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	854	
216564	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	8L	
216565	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	6R	
216566	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	3L	
216567	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	69053	
216568	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	69053	
216569	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
216570	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		
216571	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216572	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
216573	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216574	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216575	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
216576	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
216577	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
216578	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216579	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
216580	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216581	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
216582	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216583	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
216584	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
216585	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
216586	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
216587	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
216588	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
216589	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2375	
216590	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2375	
216591	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	26	
216592	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
216593	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
216594	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
216595	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216596	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216597	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216598	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
216599	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	882	
216600	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
216601	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216602	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
216603	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
216604	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
216605	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	45792	
216606	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
216607	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
216608	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
216609	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
216610	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	13L	
216611	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
216612	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
216613	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
216614	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	45761	
216615	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	45761	
216616	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
216617	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
216618	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216619	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
216620	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
216621	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
216622	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
216623	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
216624	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
216625	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
216626	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
216627	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
216628	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
216629	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
216630	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
216631	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
216632	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
216633	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
216634	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
216635	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
216636	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
216637	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	314	
216638	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	310	
216639	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
216640	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
216641	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
216642	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
216643	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
216644	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
216645	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
216646	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	General Comments		
216647	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
216648	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	4	
216649	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LTC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
216650	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LTC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
216651	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
216652	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	4	
216653	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
216654	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
216655	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
216656	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
216657	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
216658	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
216659	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
216660	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216661	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
216662	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
216663	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
216664	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
216665	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
216666	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1052	
216667	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1052	
216668	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
216669	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
216670	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
216671	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
216672	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
216673	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
216674	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
216675	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
216676	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216677	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216678	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
216679	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
216680	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
216681	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
216682	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
216683	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
216684	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216685	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
216686	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
216687	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
216688	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0024	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
216689	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
216690	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
216691	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
216692	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
216693	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
216694	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
216695	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216696	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216697	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216698	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216699	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
216700	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216701	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216702	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
216703	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
216704	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
216705	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	20.0	
216706	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	20.0	
216707	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	20.0	
216708	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
216709	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
216710	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
216711	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	10	
216712	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216713	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
216714	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
216715	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
216716	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
216717	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
216718	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
216719	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
216720	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
216721	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
216722	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
216723	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
216724	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	100.0	
216725	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	0	
216726	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
216727	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
216728	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
216729	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	1107.0	
216730	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	1093.0	
216731	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	1041.0	
216732	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
216733	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
216734	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
216735	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
216736	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
216737	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
216738	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	100.0	
216739	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	100.0	
216740	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
216741	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
216742	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
216743	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
216744	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
216745	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
216746	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
216747	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
216748	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
216749	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	1	
216750	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	247	
216751	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216752	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
216753	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
216754	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
216755	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
216756	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
216757	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
216758	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
216759	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216760	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
216761	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
216762	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
216763	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
216764	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
216765	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
216766	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
216767	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Needs Nitrogen refilled	
216768	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
216769	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
216770	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
216771	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
216772	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1487	
216773	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
216774	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
216775	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments	amp gauges are off approx 40-60 amps lower than amp meter	
216776	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
216777	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
216778	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
216779	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
216780	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
216781	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
216782	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
216783	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
216784	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
216785	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
216786	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	97.3	
216787	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	148.1	
216788	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	116.1	
216789	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
216790	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
216791	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
216792	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	General Comments		
216793	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
216794	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
216795	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
216796	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
216797	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
216798	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
216799	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
216800	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
216801	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216802	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
216803	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
216804	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
216805	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
216806	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
216807	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
216808	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
216809	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216810	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
216811	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
216812	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
216813	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0034	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
216814	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216815	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216816	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216817	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	360	
216818	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
216819	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
216820	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
216821	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
216822	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
216823	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	265181	
216824	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	265181	
216825	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
216826	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216827	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216828	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
216829	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
216830	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
216831	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
216832	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
216833	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
216834	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
216835	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
216836	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
216837	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
216838	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
216839	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
216840	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
216841	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
216842	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
216843	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
216844	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
216845	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
216846	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
216847	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
216848	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
216849	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
216850	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66119	
216851	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
216852	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
216853	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
216854	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
216855	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	1	
216856	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
216857	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
216858	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
216859	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
216860	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
216861	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
216862	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
216863	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
216864	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
216865	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
216866	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	1L	
216867	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	1R	
216868	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	10L	
216869	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	1387	
216870	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
216871	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
216872	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
216873	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	85	*F
216874	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
216875	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
216876	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
216877	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
216878	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
216879	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
216880	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
216881	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
216882	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
216883	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
216884	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
216885	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
216886	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
216887	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
216888	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
216889	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
216890	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
216891	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	42	
216892	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	42	
216893	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
216894	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
216895	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	65	psi
216896	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
216897	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
216898	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
216899	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	General Comments		
216900	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
216901	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216902	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
216903	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
216904	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
216905	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
216906	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	50	°C
216907	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
216908	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
216909	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
216910	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
216911	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
216912	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
216913	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
216914	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
216915	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
216916	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	45	°C
216917	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	55	°C
216918	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	45	°C
216919	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	55	°C
216920	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	45	°C
216921	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	55	°C
216922	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
216923	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
216924	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	50	°C
216925	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
216926	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
216927	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
216928	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216929	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
216930	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
216931	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
216932	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
216933	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
216934	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
216935	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
216936	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
216937	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	45	°C
216938	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
216939	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
216940	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
216941	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
216942	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
216943	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	270.0	
216944	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	280.0	
216945	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Unknown Operations	0	
216946	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	
216947	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
216948	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	809	
216949	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	809	
216950	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
216951	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
216952	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
216953	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
216954	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
216955	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
216956	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
216957	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
216958	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
216959	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
216960	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
216961	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
216962	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
216963	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
216964	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	10168	
216965	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	10168	
216966	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
216967	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
216968	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
216969	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	340.0	
216970	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
216971	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
216972	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
216973	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
216974	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	141.0	
216975	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	154.0	
216976	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	162.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
216977	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
216978	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
216979	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
216980	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	11	
216981	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
216982	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
216983	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
216984	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
216985	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
216986	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
216987	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
216988	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
216989	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
216990	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
216991	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
216992	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
216993	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
216994	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
216995	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
216996	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
216997	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
216998	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
216999	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217000	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217001	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
217002	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217003	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
217004	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
217005	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217006	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
217007	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
217008	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
217009	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
217010	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTC0000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
217011	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
217012	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217013	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217014	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
217015	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
217016	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217017	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
217018	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
217019	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
217020	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
217021	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
217022	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
217023	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
217024	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
217025	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
217026	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1578	
217027	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1578	
217028	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	61	
217029	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217030	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
217031	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217032	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	General Comments		
217033	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217034	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
217035	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217036	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
217037	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217038	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
217039	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
217040	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
217041	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
217042	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
217043	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59586	
217044	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59586	
217045	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
217046	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8R	
217047	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	69	
217048	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
217049	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
217050	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
217051	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217052	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
217053	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
217054	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	16342	
217055	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	16342	
217056	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
217057	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	1L	
217058	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8R	
217059	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	2R	
217060	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
217061	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	650	
217062	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
217063	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
217064	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
217065	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217066	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217067	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217068	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
217069	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
217070	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
217071	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
217072	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
217073	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
217074	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
217075	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
217076	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
217077	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
217078	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
217079	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
217080	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
217081	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
217082	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
217083	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
217084	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
217085	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
217086	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.1	volts
217087	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	69617	
217088	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
217089	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
217090	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
217091	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217092	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217093	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217094	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments	Liquid temp gauge max's will not reset	
217095	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments	Liquid Temperature gauge max will not reset	
217096	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
217097	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217098	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	y	
217099	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
217100	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
217101	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217102	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217103	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
217104	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
217105	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
217106	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	130.00	
217107	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTc Bushing Dynamic Health	0.00	
217108	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	50	°C
217109	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
217110	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
217111	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217112	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
217113	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
217114	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
217115	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47454	
217116	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
217117	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
217118	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
217119	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
217120	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
217121	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
217122	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
217123	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
217124	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
217125	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
217126	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217127	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
217128	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
217129	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	7R	
217130	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
217131	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
217132	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
217133	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
217134	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
217135	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
217136	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217137	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217138	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217139	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217140	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217141	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217142	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217143	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
217144	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217145	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217146	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217147	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217148	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217149	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217150	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217151	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217152	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217153	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0327	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217154	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
217155	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
217156	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
217157	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217158	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217159	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217160	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217161	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0340	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217162	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
217163	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217164	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217165	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217166	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217167	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217168	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0015	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
217169	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
217170	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217171	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217172	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217173	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217174	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217175	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217176	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217177	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
217178	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	6	
217179	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
217180	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
217181	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
217182	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217183	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217184	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217185	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217186	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217187	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
217188	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
217189	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
217190	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	209	
217191	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	209	
217192	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
217193	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
217194	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
217195	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
217196	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
217197	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
217198	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
217199	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations E Ø	0	
217200	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
217201	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217202	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217203	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217204	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217205	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	135.0	
217206	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	110.0	
217207	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	102.0	
217208	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217209	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217210	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217211	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	4	
217212	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC0000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
217213	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
217214	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
217215	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
217216	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC0000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
217217	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217218	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217219	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
217220	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217221	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
217222	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217223	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217224	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217225	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217226	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
217227	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
217228	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
217229	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
217230	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1672	
217231	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1672	
217232	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
217233	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217234	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
217235	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217236	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments		
217237	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217238	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
217239	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217240	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
217241	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217242	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
217243	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217244	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217245	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217246	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
217247	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
217248	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
217249	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
217250	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
217251	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
217252	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
217253	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
217254	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
217255	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
217256	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
217257	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	8	
217258	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	8	
217259	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
217260	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
217261	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217262	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
217263	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217264	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
217265	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
217266	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
217267	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
217268	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
217269	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
217270	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
217271	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217272	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	432.0	
217273	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	423.0	
217274	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	464.0	
217275	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
217276	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217277	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
217278	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	43	
217279	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
217280	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
217281	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
217282	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
217283	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
217284	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
217285	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
217286	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
217287	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
217288	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
217289	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
217290	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
217291	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
217292	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
217293	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
217294	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
217295	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
217296	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
217297	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217298	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
217299	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217300	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	55	°C
217301	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
217302	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
217303	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
217304	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
217305	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217306	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
217307	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
217308	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217309	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217310	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
217311	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
217312	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217313	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217314	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0330	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217315	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217316	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
217317	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
217318	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
217319	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LTC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
217320	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217321	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
217322	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217323	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
217324	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217325	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	5	
217326	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Unknown Operations	0	
217327	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
217328	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
217329	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	645	
217330	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	645	
217331	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
217332	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
217333	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments	Dont know what equipment this is	
217334	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
217335	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	y	
217336	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
217337	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
217338	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
217339	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
217340	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
217341	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
217342	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
217343	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
217344	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	845	
217345	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	845	
217346	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
217347	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
217348	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
217349	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
217350	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
217351	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217352	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	176	
217353	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	176	
217354	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
217355	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
217356	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
217357	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
217358	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Unknown Operations	0	
217359	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	31	
217360	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217361	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
217362	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217363	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
217364	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217365	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217366	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
217367	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217368	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
217369	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217370	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217371	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217372	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217373	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217374	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217375	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217376	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
217377	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
217378	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217379	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
217380	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
217381	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
217382	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
217383	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
217384	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
217385	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	8	
217386	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Unknown Operations	0	
217387	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
217388	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	9	
217389	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	879	
217390	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	879	
217391	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	24	
217392	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
217393	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
217394	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
217395	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
217396	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
217397	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	9	
217398	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217399	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217400	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217401	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217402	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217403	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
217404	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
217405	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217406	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
217407	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
217408	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217409	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
217410	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217411	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217412	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
217413	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
217414	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217415	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	7879.68	kw
217416	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
217417	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
217418	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	55	°C
217419	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	45	°C
217420	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217421	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
217422	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217423	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217424	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
217425	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
217426	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217427	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
217428	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.8208	
217429	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
217430	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
217431	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
217432	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	0.0	
217433	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	0.0	
217434	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
217435	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
217436	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
217437	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	571	
217438	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	571	
217439	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
217440	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
217441	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
217442	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
217443	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
217444	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
217445	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
217446	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
217447	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
217448	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
217449	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
217450	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
217451	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	0.0	
217452	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
217453	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
217454	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
217455	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217456	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217457	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
217458	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217459	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217460	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217461	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217462	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
217463	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
217464	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
217465	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
217466	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
217467	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
217468	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
217469	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
217470	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
217471	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
217472	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
217473	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
217474	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
217475	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217476	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217477	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
217478	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217479	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217480	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
217481	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
217482	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
217483	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217484	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
217485	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
217486	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
217487	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	46	°C
217488	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217489	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
217490	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
217491	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217492	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217493	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217494	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
217495	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
217496	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
217497	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
217498	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
217499	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	43	°C
217500	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
217501	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	47	°C

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
217502	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	46	°C
217503	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	48	°C
217504	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	48	°C
217505	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
217506	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	87.0	
217507	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	92.0	
217508	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	92.0	
217509	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217510	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217511	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217512	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	5	
217513	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
217514	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
217515	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
217516	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217517	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	1	
217518	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	1	
217519	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
217520	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
217521	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
217522	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
217523	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
217524	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
217525	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
217526	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
217527	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
217528	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217529	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217530	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217531	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217532	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	158	
217533	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	158	
217534	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
217535	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
217536	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
217537	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
217538	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
217539	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
217540	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
217541	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
217542	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
217543	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
217544	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	2) 8ft single pin bulbs	
217545	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
217546	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217547	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217548	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
217549	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
217550	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
217551	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	40.0	
217552	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	43.0	
217553	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	32.0	
217554	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217555	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217556	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217557	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	5	
217558	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
217559	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
217560	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	2	
217561	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	2	
217562	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	140	
217563	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217564	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217565	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	140	
217566	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
217567	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
217568	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
217569	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
217570	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
217571	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	156	
217572	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	156	
217573	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
217574	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
217575	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
217576	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
217577	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
217578	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
217579	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
217580	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
217581	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
217582	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
217583	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
217584	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
217585	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217586	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
217587	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
217588	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
217589	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217590	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
217591	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
217592	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217593	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217594	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217595	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
217596	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217597	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217598	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
217599	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
217600	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
217601	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217602	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217603	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217604	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217605	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217606	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217607	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217608	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217609	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
217610	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
217611	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217612	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
217613	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217614	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217615	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
217616	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Ltc relief device alarm is still isolated	
217617	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217618	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217619	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
217620	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
217621	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217622	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217623	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217624	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217625	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217626	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217627	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217628	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217629	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217630	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
217631	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
217632	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
217633	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
217634	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
217635	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217636	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
217637	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217638	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
217639	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
217640	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
217641	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
217642	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
217643	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
217644	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	4	
217645	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217646	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
217647	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
217648	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
217649	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
217650	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
217651	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217652	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
217653	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217654	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217655	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
217656	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217657	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
217658	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217659	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
217660	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
217661	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
217662	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
217663	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
217664	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
217665	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
217666	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
217667	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
217668	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
217669	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
217670	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
217671	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
217672	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
217673	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
217674	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1161	
217675	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
217676	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
217677	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
217678	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
217679	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
217680	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	84513	
217681	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	84513	
217682	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
217683	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
217684	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
217685	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
217686	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217687	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
217688	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
217689	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
217690	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
217691	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
217692	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
217693	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
217694	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
217695	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
217696	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
217697	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
217698	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
217699	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
217700	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
217701	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
217702	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
217703	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
217704	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
217705	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
217706	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
217707	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
217708	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
217709	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
217710	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
217711	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
217712	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
217713	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
217714	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
217715	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
217716	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
217717	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217718	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217719	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217720	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
217721	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
217722	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
217723	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
217724	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
217725	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
217726	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
217727	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217728	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
217729	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217730	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217731	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
217732	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
217733	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
217734	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	85.0	
217735	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
217736	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
217737	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
217738	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	90.0	
217739	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	80.0	
217740	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
217741	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217742	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	326.0	
217743	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	367.0	
217744	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	386.0	
217745	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217746	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217747	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217748	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
217749	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
217750	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
217751	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
217752	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217753	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217754	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	2	
217755	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
217756	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
217757	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
217758	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
217759	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217760	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
217761	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
217762	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217763	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217764	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
217765	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217766	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
217767	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217768	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217769	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments	One of the animal guard boots is about to fall off of the bushing. Its only held on by one wire tie.	
217770	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
217771	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217772	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
217773	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
217774	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217775	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217776	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217777	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
217778	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
217779	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	y	
217780	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217781	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217782	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217783	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217784	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217785	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217786	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217787	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217788	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
217789	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
217790	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
217791	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
217792	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
217793	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217794	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
217795	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
217796	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
217797	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
217798	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2500	psi
217799	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
217800	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
217801	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217802	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
217803	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
217804	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217805	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217806	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
217807	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217808	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
217809	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
217810	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217811	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
217812	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
217813	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
217814	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	1	
217815	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	1	
217816	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	160	
217817	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	160	
217818	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
217819	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
217820	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217821	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
217822	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
217823	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
217824	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
217825	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
217826	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
217827	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
217828	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
217829	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
217830	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217831	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217832	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217833	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217834	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217835	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217836	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
217837	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217838	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217839	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217840	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217841	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217842	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217843	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
217844	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217845	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217846	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
217847	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217848	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217849	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217850	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217851	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217852	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
217853	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217854	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217855	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217856	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
217857	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217858	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217859	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217860	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217861	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217862	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
217863	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
217864	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
217865	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
217866	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
217867	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		
217868	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
217869	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	184365	
217870	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	184365	
217871	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
217872	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7L	
217873	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	2R	
217874	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
217875	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217876	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
217877	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217878	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217879	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217880	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217881	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1593	
217882	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
217883	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
217884	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
217885	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
217886	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LTC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
217887	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217888	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
217889	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
217890	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217891	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217892	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	70	°C
217893	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	77	°C
217894	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217895	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217896	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0333	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217897	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217898	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	67	°C
217899	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
217900	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
217901	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	73	°C
217902	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
217903	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
217904	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
217905	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
217906	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Adequate	
217907	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
217908	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
217909	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
217910	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
217911	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
217912	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
217913	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
217914	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
217915	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
217916	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
217917	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
217918	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
217919	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
217920	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
217921	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
217922	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
217923	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
217924	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
217925	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
217926	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
217927	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
217928	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
217929	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
217930	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217931	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217932	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217933	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217934	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
217935	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217936	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217937	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
217938	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
217939	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
217940	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	69.0	
217941	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	67.0	
217942	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	83.0	
217943	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
217944	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
217945	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
217946	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	4	
217947	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
217948	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
217949	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	1	
217950	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	1	
217951	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	180	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
217952	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	180	
217953	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
217954	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
217955	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
217956	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
217957	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
217958	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
217959	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
217960	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
217961	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
217962	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
217963	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
217964	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
217965	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
217966	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
217967	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
217968	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217969	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
217970	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
217971	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
217972	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
217973	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
217974	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
217975	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
217976	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
217977	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
217978	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
217979	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
217980	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
217981	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
217982	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
217983	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
217984	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
217985	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
217986	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
217987	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
217988	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
217989	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
217990	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
217991	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
217992	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
217993	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
217994	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
217995	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
217996	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
217997	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
217998	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
217999	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
218000	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
218001	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
218002	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218003	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
218004	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
218005	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
218006	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
218007	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
218008	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218009	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218010	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218011	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218012	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218013	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218014	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
218015	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
218016	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
218017	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218018	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
218019	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
218020	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
218021	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
218022	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
218023	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218024	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
218025	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
218026	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218027	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
218028	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218029	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218030	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
218031	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
218032	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
218033	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
218034	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
218035	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
218036	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
218037	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
218038	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	General Comments		
218039	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
218040	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
218041	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
218042	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
218043	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	LTC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
218044	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
218045	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
218046	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
218047	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
218048	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
218049	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
218050	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
218051	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
218052	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
218053	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
218054	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1708	
218055	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1708	
218056	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
218057	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
218058	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
218059	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
218060	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
218061	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
218062	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
218063	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
218064	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218065	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218066	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	cubicle heater is bad	
218067	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
218068	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218069	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218070	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	cubicle heater bad.	
218071	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
218072	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
218073	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0342	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
218074	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
218075	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
218076	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
218077	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
218078	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
218079	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
218080	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218081	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218082	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	40	*C
218083	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	49	*C
218084	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1544	
218085	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
218086	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
218087	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
218088	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
218089	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
218090	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
218091	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
218092	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218093	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	41	*C
218094	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	50	*C
218095	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
218096	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
218097	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2770.56	kw
218098	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
218099	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
218100	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
218101	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
218102	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
218103	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
218104	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
218105	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
218106	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
218107	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
218108	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
218109	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
218110	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
218111	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218112	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	5	
218113	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	3.58	%
218114	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	3.58	%
218115	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	3.58	%
218116	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	246.0	
218117	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
218118	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
218119	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	General Comments		
218120	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
218121	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
218122	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
218123	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
218124	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	510	
218125	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	510	
218126	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
218127	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
218128	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
218129	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
218130	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
218131	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
218132	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
218133	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
218134	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
218135	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
218136	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
218137	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
218138	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
218139	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	477.0	
218140	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	477.0	
218141	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	469.0	
218142	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
218143	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
218144	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
218145	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0343	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
218146	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
218147	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218148	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218149	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
218150	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218151	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
218152	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218153	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
218154	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
218155	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
218156	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
218157	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
218158	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
218159	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
218160	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
218161	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
218162	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
218163	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
218164	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
218165	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
218166	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
218167	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
218168	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
218169	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
218170	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
218171	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
218172	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
218173	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
218174	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
218175	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
218176	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218177	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
218178	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		Structural steel is rusty and needs a fresh coat of paint. There is a work order in cascade for painting
218179	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
218180	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
218181	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
218182	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
218183	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
218184	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
218185	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
218186	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
218187	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
218188	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
218189	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
218190	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
218191	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	214	
218192	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	214	
218193	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	1	
218194	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
218195	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	1	
218196	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
218197	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Unknown Operations	0	
218198	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218199	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218200	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
218201	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
218202	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
218203	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
218204	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
218205	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
218206	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
218207	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
218208	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218209	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
218210	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
218211	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
218212	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
218213	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218214	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218215	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
218216	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
218217	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218218	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218219	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
218220	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218221	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218222	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218223	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218224	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
218225	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
218226	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
218227	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
218228	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
218229	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
218230	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
218231	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
218232	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
218233	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
218234	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
218235	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
218236	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
218237	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	198	
218238	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	198	
218239	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
218240	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
218241	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
218242	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
218243	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Unknown Operations	0	
218244	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218245	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218246	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218247	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218248	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218249	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218250	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
218251	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
218252	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218253	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218254	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218255	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218256	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
218257	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218258	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
218259	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218260	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	247.0	
218261	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	223.0	
218262	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
218263	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
218264	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
218265	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218266	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218267	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
218268	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218269	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218270	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218271	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218272	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
218273	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
218274	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
218275	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
218276	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
218277	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
218278	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
218279	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
218280	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
218281	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
218282	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
218283	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
218284	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
218285	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	514	
218286	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	514	
218287	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
218288	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
218289	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
218290	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
218291	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Unknown Operations	0	
218292	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	17	
218293	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
218294	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	5.37	%
218295	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	4.77	%
218296	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	200.0	
218297	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	202.0	
218298	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	205.0	
218299	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
218300	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
218301	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
218302	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
218303	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
218304	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	10	
218305	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	7.75	%
218306	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	8.94	%
218307	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	7.16	%
218308	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	83.0	
218309	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	89.0	
218310	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	89.0	
218311	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
218312	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
218313	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
218314	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218315	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218316	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
218317	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218318	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218319	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218320	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218321	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
218322	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
218323	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
218324	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
218325	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
218326	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218327	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
218328	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
218329	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
218330	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
218331	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
218332	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
218333	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
218334	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
218335	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
218336	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
218337	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
218338	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1542	
218339	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1542	
218340	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
218341	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
218342	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
218343	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
218344	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
218345	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
218346	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
218347	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
218348	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
218349	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
218350	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
218351	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
218352	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
218353	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218354	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218355	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
218356	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
218357	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
218358	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
218359	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
218360	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
218361	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
218362	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
218363	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
218364	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
218365	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
218366	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
218367	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
218368	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
218369	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
218370	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments	Operation counter is 174 not sure what has occurred here.	
218371	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
218372	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
218373	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
218374	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
218375	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
218376	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
218377	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
218378	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
218379	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
218380	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
218381	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
218382	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
218383	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
218384	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
218385	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
218386	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
218387	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil Level	Good	
218388	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
218389	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
218390	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
218391	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	y	
218392	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
218393	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218394	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218395	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
218396	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218397	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
218398	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218399	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
218400	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218401	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218402	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218403	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
218404	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
218405	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
218406	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
218407	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
218408	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
218409	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
218410	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
218411	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
218412	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
218413	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	Fabric and top rails rusty.	
218414	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
218415	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
218416	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
218417	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
218418	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
218419	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
218420	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
218421	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
218422	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
218423	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
218424	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
218425	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
218426	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
218427	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
218428	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
218429	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
218430	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
218431	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
218432	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
218433	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
218434	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
218435	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
218436	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218437	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
218438	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
218439	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
218440	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
218441	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
218442	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
218443	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
218444	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
218445	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
218446	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
218447	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
218448	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
218449	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
218450	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
218451	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
218452	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
218453	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
218454	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
218455	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
218456	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
218457	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
218458	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
218459	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218460	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218461	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
218462	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
218463	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
218464	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
218465	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
218466	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
218467	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
218468	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218469	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
218470	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
218471	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
218472	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
218473	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
218474	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
218475	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	450.0	
218476	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	470.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218477	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	450.0	
218478	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
218479	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
218480	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
218481	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
218482	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218483	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218484	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
218485	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
218486	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
218487	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
218488	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
218489	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
218490	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
218491	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
218492	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
218493	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218494	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
218495	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
218496	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	94	
218497	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
218498	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
218499	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
218500	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
218501	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
218502	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
218503	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
218504	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
218505	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
218506	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
218507	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
218508	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
218509	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
218510	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
218511	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
218512	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218513	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218514	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218515	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
218516	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
218517	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
218518	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Unknown Operations	0	
218519	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
218520	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
218521	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1317	
218522	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1317	
218523	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	3	
218524	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
218525	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments		
218526	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
218527	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
218528	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218529	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
218530	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218531	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
218532	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218533	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
218534	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
218535	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218536	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218537	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218538	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	20	
218539	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
218540	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
218541	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	60.0	
218542	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	90.0	
218543	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	80.0	
218544	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
218545	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
218546	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
218547	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
218548	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH01322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
218549	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
218550	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
218551	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
218552	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
218553	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
218554	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
218555	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
218556	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
218557	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218558	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	40	%
218559	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	40	%
218560	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
218561	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
218562	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
218563	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
218564	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
218565	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Work oder written in cascade to add oil to bushing	
218566	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments	A Phase Bushing is low on oil and a work order has been created	
218567	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
218568	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
218569	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
218570	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
218571	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
218572	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
218573	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218574	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
218575	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
218576	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
218577	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
218578	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
218579	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218580	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Low	
218581	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
218582	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
218583	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
218584	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	-3	amps
218585	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
218586	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
218587	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
218588	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
218589	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
218590	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	179	
218591	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	179	
218592	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
218593	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
218594	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
218595	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
218596	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
218597	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
218598	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
218599	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
218600	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
218601	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
218602	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218603	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218604	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218605	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218606	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
218607	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
218608	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
218609	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218610	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218611	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
218612	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
218613	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218614	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	6	
218615	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
218616	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
218617	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0020	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
218618	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
218619	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	309	
218620	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
218621	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
218622	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
218623	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
218624	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
218625	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
218626	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
218627	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6R	
218628	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	11R	
218629	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	9R	
218630	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
218631	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	79065	
218632	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	79065	
218633	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
218634	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
218635	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
218636	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
218637	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
218638	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
218639	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
218640	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
218641	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
218642	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
218643	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
218644	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
218645	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments	added 2 lbs nitrogem	
218646	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
218647	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	3870.00	kw
218648	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
218649	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
218650	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	55	°C
218651	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	47	°C
218652	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
218653	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
218654	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
218655	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
218656	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
218657	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
218658	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
218659	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
218660	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
218661	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
218662	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
218663	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
218664	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
218665	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
218666	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
218667	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
218668	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
218669	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
218670	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
218671	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
218672	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.6450	
218673	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
218674	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
218675	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
218676	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	4	
218677	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	717	
218678	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	713	
218679	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
218680	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
218681	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
218682	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
218683	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
218684	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
218685	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
218686	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
218687	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
218688	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
218689	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
218690	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
218691	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218692	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	4	
218693	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	4	
218694	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
218695	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
218696	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
218697	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
218698	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
218699	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
218700	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	146	
218701	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	146	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218702	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	12	
218703	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
218704	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Unknown Operations	0	
218705	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	0	
218706	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218707	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218708	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218709	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	810.0	
218710	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	730.0	
218711	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	720.0	
218712	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218713	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218714	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218715	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218716	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
218717	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
218718	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
218719	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
218720	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
218721	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
218722	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
218723	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
218724	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
218725	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	75	
218726	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	75	
218727	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
218728	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
218729	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Unknown Operations	0	
218730	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
218731	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
218732	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218733	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
218734	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
218735	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
218736	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218737	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
218738	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
218739	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
218740	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
218741	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
218742	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
218743	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
218744	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	4	
218745	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
218746	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	96	*F
218747	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
218748	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
218749	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
218750	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
218751	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
218752	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
218753	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
218754	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
218755	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
218756	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
218757	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
218758	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
218759	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
218760	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
218761	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
218762	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
218763	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
218764	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
218765	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
218766	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1475	
218767	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	General Comments		
218768	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
218769	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
218770	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
218771	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
218772	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	989	
218773	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	989	
218774	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
218775	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
218776	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218777	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
218778	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
218779	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
218780	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
218781	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
218782	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
218783	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
218784	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	*C
218785	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
218786	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
218787	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
218788	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
218789	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
218790	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
218791	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
218792	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
218793	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
218794	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
218795	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
218796	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
218797	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
218798	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	194	
218799	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	194	
218800	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
218801	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
218802	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
218803	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
218804	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	34872	
218805	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	34872	
218806	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
218807	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
218808	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
218809	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
218810	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
218811	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
218812	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
218813	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
218814	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
218815	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
218816	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
218817	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
218818	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
218819	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218820	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218821	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218822	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218823	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
218824	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
218825	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
218826	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LTC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
218827	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
218828	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
218829	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
218830	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	%
218831	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	21.0	
218832	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	18.0	
218833	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	74.0	
218834	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218835	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218836	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218837	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	2	%
218838	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
218839	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
218840	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218841	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218842	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218843	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
218844	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218845	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218846	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
218847	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
218848	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
218849	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	180.0	
218850	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	240.0	
218851	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	240.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218852	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218853	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218854	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218855	9/4/2019 11:52	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	12	
218856	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
218857	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
218858	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
218859	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
218860	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
218861	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
218862	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1422	
218863	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
218864	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
218865	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
218866	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
218867	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	700.0	
218868	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	750.0	
218869	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	700.0	
218870	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
218871	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
218872	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
218873	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
218874	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments	amp gauges dont match what amp meter says they are about 120 amps off	
218875	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
218876	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
218877	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
218878	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
218879	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
218880	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
218881	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
218882	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
218883	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
218884	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
218885	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	101.9	
218886	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	130.3	
218887	9/4/2019 13:54	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	124.7	
218888	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	18	
218889	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	18	
218890	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
218891	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
218892	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
218893	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218894	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218895	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
218896	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
218897	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
218898	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
218899	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
218900	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
218901	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
218902	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0032	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
218903	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
218904	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
218905	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
218906	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
218907	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
218908	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
218909	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
218910	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
218911	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
218912	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
218913	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
218914	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
218915	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
218916	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
218917	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
218918	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
218919	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
218920	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	55	°C
218921	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
218922	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
218923	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
218924	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	875	psi
218925	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
218926	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
218927	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
218928	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
218929	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
218930	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
218931	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
218932	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
218933	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
218934	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
218935	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
218936	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
218937	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
218938	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
218939	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
218940	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
218941	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
218942	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
218943	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
218944	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
218945	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
218946	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
218947	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
218948	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments	26.9/24.9	
218949	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
218950	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
218951	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	15	
218952	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
218953	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
218954	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
218955	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
218956	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
218957	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
218958	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
218959	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
218960	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
218961	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
218962	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
218963	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
218964	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
218965	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
218966	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
218967	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
218968	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
218969	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
218970	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
218971	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
218972	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
218973	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
218974	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
218975	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
218976	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
218977	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
218978	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
218979	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
218980	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	48.0	
218981	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
218982	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
218983	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
218984	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
218985	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
218986	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
218987	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
218988	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
218989	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	130.0	
218990	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	132.0	
218991	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	132.0	
218992	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
218993	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
218994	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
218995	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
218996	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
218997	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
218998	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
218999	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
219000	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
219001	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219002	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
219003	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
219004	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
219005	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
219006	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
219007	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
219008	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0037	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
219009	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
219010	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
219011	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	2	
219012	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	182	
219013	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	182	
219014	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
219015	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
219016	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
219017	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
219018	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
219019	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
219020	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
219021	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
219022	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219023	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
219024	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
219025	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
219026	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
219027	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
219028	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
219029	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
219030	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
219031	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
219032	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
219033	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	1	
219034	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	1	
219035	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219036	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
219037	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
219038	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219039	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	214.0	
219040	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	197.0	
219041	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	211.0	
219042	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219043	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219044	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219045	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
219046	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	25	
219047	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
219048	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	5	
219049	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
219050	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
219051	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
219052	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
219053	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
219054	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
219055	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
219056	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
219057	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
219058	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219059	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
219060	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
219061	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
219062	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219063	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219064	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219065	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	460.0	
219066	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	260.0	
219067	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	300.0	
219068	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219069	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
219070	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
219071	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219072	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
219073	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
219074	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
219075	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
219076	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219077	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
219078	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
219079	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments		
219080	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
219081	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	92	
219082	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	92	
219083	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	0	
219084	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
219085	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Unknown Operations	0	
219086	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	9	
219087	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219088	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219089	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219090	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	400.0	
219091	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	430.0	
219092	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	460.0	
219093	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219094	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
219095	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
219096	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219097	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
219098	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
219099	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
219100	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
219101	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
219102	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
219103	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
219104	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
219105	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
219106	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
219107	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments		
219108	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
219109	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
219110	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
219111	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
219112	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
219113	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	80	
219114	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
219115	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
219116	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	154	
219117	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	154	
219118	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	0	
219119	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
219120	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Unknown Operations	0	
219121	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
219122	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
219123	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219124	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	14	
219125	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219126	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219127	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219128	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	300.0	
219129	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	270.0	
219130	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	300.0	
219131	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219132	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
219133	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
219134	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	44.72	
219135	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	4	
219136	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
219137	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
219138	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
219139	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219140	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
219141	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
219142	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
219143	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
219144	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
219145	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
219146	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
219147	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
219148	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
219149	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	8150.40	kw
219150	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
219151	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219152	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
219153	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	40	°C
219154	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
219155	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
219156	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
219157	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
219158	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
219159	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
219160	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
219161	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
219162	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
219163	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
219164	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
219165	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
219166	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
219167	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
219168	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
219169	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
219170	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
219171	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
219172	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
219173	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
219174	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.8490	
219175	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
219176	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
219177	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
219178	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
219179	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
219180	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
219181	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
219182	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
219183	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
219184	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	126	
219185	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	126	
219186	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
219187	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
219188	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
219189	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
219190	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
219191	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
219192	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
219193	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	n	
219194	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
219195	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	n	
219196	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
219197	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
219198	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
219199	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
219200	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
219201	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
219202	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	y	
219203	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
219204	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
219205	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
219206	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
219207	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
219208	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
219209	9/4/2019 12:09	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
219210	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	9	
219211	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
219212	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
219213	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
219214	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
219215	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
219216	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	General Comments		
219217	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
219218	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
219219	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
219220	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
219221	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
219222	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
219223	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
219224	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
219225	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
219226	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219227	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
219228	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
219229	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
219230	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	General Comments		
219231	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
219232	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
219233	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	300.0	
219234	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	310.0	
219235	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
219236	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
219237	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
219238	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
219239	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	197945	
219240	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	197945	
219241	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
219242	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
219243	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
219244	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
219245	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	280.0	
219246	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
219247	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
219248	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
219249	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
219250	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
219251	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
219252	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
219253	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	3	
219254	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	696	
219255	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	696	
219256	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	1	
219257	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
219258	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Unknown Operations	1	
219259	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
219260	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
219261	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
219262	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
219263	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
219264	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
219265	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
219266	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
219267	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
219268	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
219269	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
219270	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
219271	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
219272	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
219273	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
219274	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1587	
219275	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1587	
219276	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
219277	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
219278	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
219279	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
219280	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
219281	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
219282	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
219283	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
219284	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
219285	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
219286	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
219287	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
219288	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
219289	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
219290	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
219291	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
219292	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
219293	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
219294	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
219295	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
219296	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
219297	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99996	
219298	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99996	
219299	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
219300	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
219301	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219302	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
219303	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
219304	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
219305	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
219306	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
219307	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
219308	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1557	
219309	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1557	
219310	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
219311	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
219312	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0329	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
219313	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
219314	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
219315	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
219316	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
219317	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
219318	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219319	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219320	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
219321	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
219322	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
219323	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219324	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
219325	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
219326	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
219327	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
219328	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
219329	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
219330	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
219331	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
219332	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
219333	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
219334	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
219335	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
219336	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
219337	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
219338	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
219339	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0326	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
219340	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	886	
219341	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	11L	
219342	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	2L	
219343	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	7L	
219344	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
219345	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
219346	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
219347	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
219348	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
219349	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
219350	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
219351	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
219352	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
219353	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
219354	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
219355	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
219356	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
219357	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
219358	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
219359	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
219360	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
219361	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
219362	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
219363	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
219364	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
219365	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
219366	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
219367	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
219368	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
219369	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
219370	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
219371	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
219372	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0345	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
219373	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219374	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219375	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
219376	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219377	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
219378	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
219379	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
219380	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
219381	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
219382	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
219383	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
219384	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
219385	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
219386	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
219387	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
219388	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
219389	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
219390	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
219391	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
219392	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
219393	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
219394	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
219395	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
219396	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
219397	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
219398	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
219399	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
219400	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
219401	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
219402	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
219403	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
219404	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0021	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
219405	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
219406	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
219407	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
219408	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
219409	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
219410	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
219411	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
219412	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
219413	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
219414	9/4/2019 11:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
219415	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
219416	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
219417	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
219418	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
219419	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
219420	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
219421	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1186	
219422	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
219423	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
219424	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1186	
219425	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
219426	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
219427	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
219428	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
219429	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
219430	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
219431	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
219432	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
219433	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
219434	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		Cubicle heaters in bus pot/ station service fuses are bad in both Sec 3 & 4. The wiring is bad. Pictures have been sent to Kevin S. and
219435	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
219436	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	y	
219437	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
219438	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
219439	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
219440	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
219441	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219442	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
219443	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
219444	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
219445	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
219446	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
219447	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
219448	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
219449	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
219450	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
219451	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219452	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
219453	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
219454	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
219455	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
219456	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
219457	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
219458	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
219459	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
219460	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
219461	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
219462	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
219463	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
219464	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
219465	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
219466	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
219467	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
219468	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
219469	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
219470	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
219471	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
219472	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
219473	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
219474	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
219475	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
219476	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
219477	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	122586	
219478	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	122586	
219479	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
219480	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
219481	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
219482	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	Neutral	
219483	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1766	
219484	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
219485	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
219486	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
219487	9/5/2019 10:51	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
219488	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
219489	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
219490	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
219491	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
219492	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
219493	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
219494	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
219495	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
219496	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
219497	9/4/2019 11:02	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62390	
219498	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
219499	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
219500	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
219501	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
219502	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	13	
219503	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	General Comments		
219504	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
219505	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
219506	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
219507	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
219508	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
219509	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
219510	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
219511	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
219512	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219513	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219514	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
219515	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
219516	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
219517	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
219518	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
219519	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
219520	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
219521	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
219522	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
219523	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
219524	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0014	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
219525	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
219526	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219527	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
219528	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
219529	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
219530	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
219531	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
219532	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
219533	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
219534	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
219535	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
219536	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
219537	9/4/2019 12:59	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
219538	9/4/2019 10:47	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
219539	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
219540	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
219541	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0013	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
219542	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
219543	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
219544	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
219545	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
219546	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
219547	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
219548	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
219549	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
219550	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
219551	9/10/2019 12:56	Distribution	Algonquin Quarterly Inspection	LB0017	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
219552	9/4/2019 13:13	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
219553	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A Ø	0	
219554	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
219555	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
219556	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
219557	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B Ø	0	
219558	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C Ø	0	
219559	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
219560	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
219561	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C Ø	430.0	
219562	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B Ø	429.0	
219563	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A Ø	434.0	
219564	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
219565	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
219566	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
219567	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
219568	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
219569	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
219570	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments		
219571	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	4	
219572	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	202	
219573	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	202	
219574	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
219575	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
219576	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
219577	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
219578	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
219579	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations This Read Vac	4	
219580	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
219581	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	0	
219582	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
219583	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
219584	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is old, looks rough ...couple of wash out spots on creek side of fence...corner fence post has been hit and bent in, making the to	
219585	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
219586	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	y	
219587	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
219588	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
219589	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
219590	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	5	
219591	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
219592	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
219593	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
219594	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
219595	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
219596	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
219597	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219598	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
219599	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
219600	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
219601	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219602	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
219603	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
219604	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments	Max hand not working on oil temp	
219605	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
219606	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
219607	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
219608	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
219609	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	oik	
219610	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.3	VDC
219611	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	7	
219612	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219613	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219614	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219615	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	240.0	
219616	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	240.0	
219617	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.4	VDC
219618	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
219619	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
219620	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
219621	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
219622	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219623	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
219624	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
219625	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
219626	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
219627	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
219628	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
219629	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2341.44	kw
219630	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
219631	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
219632	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
219633	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
219634	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
219635	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
219636	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
219637	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
219638	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
219639	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
219640	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
219641	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
219642	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
219643	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
219644	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
219645	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
219646	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
219647	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
219648	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
219649	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
219650	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
219651	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
219652	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
219653	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
219654	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9756	
219655	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
219656	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
219657	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	y	
219658	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
219659	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
219660	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
219661	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
219662	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
219663	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
219664	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
219665	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments	ok	
219666	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
219667	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC0000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
219668	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC0000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
219669	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC0000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
219670	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC0000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
219671	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC0000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
219672	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
219673	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
219674	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
219675	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
219676	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219677	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
219678	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
219679	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
219680	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
219681	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
219682	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	67.5	VDC
219683	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.6	VDC
219684	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
219685	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
219686	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
219687	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
219688	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
219689	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
219690	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
219691	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
219692	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
219693	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
219694	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
219695	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Broom on Site?	y	
219696	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
219697	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
219698	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
219699	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
219700	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
219701	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments	ok	
219702	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
219703	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	ok	
219704	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
219705	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
219706	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	3	
219707	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
219708	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
219709	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
219710	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	186	
219711	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	0	
219712	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	6	
219713	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	3	
219714	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
219715	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
219716	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
219717	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
219718	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
219719	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
219720	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
219721	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
219722	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
219723	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
219724	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
219725	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
219726	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
219727	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
219728	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
219729	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
219730	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
219731	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
219732	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
219733	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
219734	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
219735	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
219736	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments	Blown lightning arrester	
219737	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
219738	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
219739	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
219740	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
219741	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
219742	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.3	VDC
219743	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
219744	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
219745	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.3	VDC
219746	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
219747	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	314	
219748	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	314	
219749	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	0	
219750	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
219751	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219752	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
219753	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
219754	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
219755	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	240.0	
219756	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
219757	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
219758	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
219759	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219760	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219761	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
219762	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219763	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
219764	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
219765	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219766	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
219767	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
219768	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
219769	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
219770	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
219771	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
219772	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
219773	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
219774	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
219775	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
219776	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
219777	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
219778	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
219779	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
219780	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	119708	
219781	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
219782	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
219783	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
219784	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
219785	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
219786	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	18.81	
219787	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	4	
219788	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219789	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219790	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219791	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	18.81	
219792	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	18.81	
219793	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219794	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
219795	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219796	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219797	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
219798	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
219799	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
219800	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	120.0	
219801	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
219802	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	110.0	
219803	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	110.0	
219804	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219805	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219806	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219807	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	5	
219808	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	12.0	
219809	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	12.0	
219810	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	12.0	
219811	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
219812	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
219813	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
219814	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219815	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
219816	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
219817	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments	currently out of service	
219818	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments	ok	
219819	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	161	
219820	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	161	
219821	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
219822	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	Neutral	
219823	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	Neutral	
219824	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	Neutral	
219825	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	137	
219826	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
219827	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
219828	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
219829	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
219830	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
219831	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
219832	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
219833	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
219834	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
219835	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
219836	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
219837	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
219838	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
219839	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments	ok	
219840	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
219841	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
219842	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
219843	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
219844	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
219845	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
219846	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
219847	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
219848	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
219849	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	7R	
219850	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
219851	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
219852	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
219853	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
219854	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments	unable to reset	
219855	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
219856	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
219857	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
219858	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
219859	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
219860	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
219861	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
219862	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
219863	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	309333	
219864	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
219865	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
219866	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
219867	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
219868	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
219869	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
219870	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
219871	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
219872	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
219873	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LTC000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	116.9	VAC
219874	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LTC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
219875	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
219876	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
219877	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
219878	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
219879	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
219880	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
219881	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
219882	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
219883	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
219884	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LTC000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments	Let me know if I need to remove the Parellel Sw. Position above - Andy	
219885	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LTC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
219886	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
219887	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
219888	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
219889	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
219890	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
219891	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
219892	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
219893	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
219894	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
219895	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
219896	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
219897	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
219898	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
219899	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
219900	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	982	
219901	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	982	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219902	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
219903	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
219904	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
219905	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
219906	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
219907	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
219908	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
219909	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
219910	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
219911	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
219912	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
219913	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
219914	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
219915	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments	ok	
219916	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
219917	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
219918	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	1	
219919	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
219920	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	144	
219921	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	144	
219922	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	4	
219923	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
219924	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
219925	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
219926	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	3	
219927	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
219928	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
219929	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
219930	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
219931	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
219932	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	945	
219933	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
219934	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
219935	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	13L	
219936	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
219937	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	5L	
219938	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
219939	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	73696	
219940	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	73684	
219941	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
219942	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
219943	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
219944	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	DB0033	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
219945	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
219946	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
219947	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
219948	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
219949	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
219950	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
219951	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
219952	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
219953	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
219954	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
219955	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
219956	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
219957	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
219958	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
219959	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
219960	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
219961	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments	ok	
219962	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
219963	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
219964	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
219965	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
219966	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
219967	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
219968	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
219969	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
219970	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
219971	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
219972	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
219973	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
219974	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
219975	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
219976	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	CH000243	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
219977	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
219978	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
219979	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
219980	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
219981	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
219982	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
219983	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
219984	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	38	*C
219985	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	55	*C
219986	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
219987	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
219988	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
219989	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
219990	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
219991	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
219992	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
219993	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
219994	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
219995	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
219996	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
219997	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
219998	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
219999	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220000	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220001	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220002	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220003	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
220004	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
220005	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
220006	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
220007	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments	1 fan underhung in back radioator section not working	
220008	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
220009	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
220010	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
220011	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
220012	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
220013	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
220014	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
220015	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
220016	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
220017	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
220018	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
220019	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
220020	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
220021	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
220022	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
220023	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
220024	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
220025	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments	ok	
220026	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments	ok	
220027	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
220028	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
220029	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
220030	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
220031	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
220032	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence -5' Clearance To Trees?	y	
220033	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
220034	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
220035	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
220036	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
220037	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
220038	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
220039	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
220040	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
220041	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
220042	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
220043	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
220044	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments	ok	
220045	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
220046	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments	ok	
220047	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
220048	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
220049	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	55.6	VDC
220050	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
220051	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
220052	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
220053	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
220054	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
220055	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
220056	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
220057	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
220058	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
220059	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
220060	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments	ok	
220061	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
220062	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
220063	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
220064	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
220065	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
220066	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
220067	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
220068	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
220069	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	7R	
220070	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
220071	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
220072	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
220073	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments	ok	
220074	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
220075	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
220076	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
220077	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
220078	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
220079	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
220080	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
220081	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
220082	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
220083	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
220084	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
220085	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
220086	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
220087	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
220088	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
220089	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments	ok	
220090	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
220091	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	14R	
220092	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
220093	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
220094	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
220095	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
220096	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	
220097	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115103	volts
220098	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
220099	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
220100	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
220101	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
220102	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
220103	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
220104	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
220105	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
220106	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
220107	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
220108	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
220109	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
220110	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	2726.40	kw
220111	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
220112	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
220113	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments		
220114	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
220115	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
220116	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
220117	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
220118	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
220119	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
220120	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
220121	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
220122	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
220123	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
220124	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
220125	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
220126	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220127	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
220128	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
220129	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
220130	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	94	*F
220131	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
220132	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
220133	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
220134	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
220135	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
220136	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
220137	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
220138	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
220139	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
220140	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
220141	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
220142	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BAT000166	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
220143	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	7	
220144	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
220145	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
220146	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
220147	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	170.0	
220148	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	168.0	
220149	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	166.0	
220150	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
220151	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
220152	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
220153	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
220154	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
220155	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
220156	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
220157	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
220158	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
220159	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	7	
220160	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	186	
220161	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	186	
220162	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	7	
220163	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
220164	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0395	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
220165	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
220166	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
220167	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
220168	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
220169	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
220170	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
220171	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
220172	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	330	
220173	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	330	
220174	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
220175	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
220176	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
220177	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
220178	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
220179	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
220180	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
220181	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	1	
220182	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	1	
220183	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	182	
220184	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	182	
220185	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
220186	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	0	
220187	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220188	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
220189	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments	ok	
220190	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments		
220191	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
220192	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
220193	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
220194	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
220195	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
220196	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
220197	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
220198	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220199	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220200	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220201	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220202	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220203	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220204	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220205	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220206	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220207	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
220208	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
220209	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
220210	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
220211	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	3	
220212	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
220213	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
220214	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.8520	
220215	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
220216	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
220217	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
220218	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
220219	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
220220	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
220221	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
220222	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
220223	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	42	°C
220224	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	42	°C
220225	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
220226	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
220227	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	188	
220228	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	188	
220229	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	4	
220230	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments		
220231	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
220232	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
220233	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
220234	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
220235	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	
220236	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
220237	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
220238	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
220239	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
220240	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
220241	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
220242	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
220243	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
220244	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
220245	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	4	
220246	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	2	
220247	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
220248	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
220249	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
220250	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	150.0	
220251	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	140.0	
220252	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	150.0	
220253	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
220254	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220255	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220256	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220257	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220258	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220259	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220260	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220261	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220262	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220263	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
220264	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
220265	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
220266	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
220267	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
220268	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
220269	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
220270	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments	ok	
220271	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments	ok	
220272	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
220273	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220274	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	1	
220275	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
220276	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	137	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220277	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	137	
220278	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	1	
220279	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
220280	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
220281	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
220282	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
220283	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	0	
220284	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations This Read Vac	4	
220285	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	213	
220286	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
220287	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
220288	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
220289	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
220290	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
220291	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
220292	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
220293	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
220294	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
220295	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments	ok	
220296	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
220297	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
220298	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
220299	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
220300	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
220301	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
220302	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
220303	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
220304	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
220305	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
220306	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
220307	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
220308	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
220309	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
220310	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
220311	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
220312	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments	ok	
220313	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
220314	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
220315	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
220316	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
220317	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.8	VDC
220318	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
220319	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
220320	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	4	
220321	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
220322	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
220323	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
220324	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A Ø	0.0	
220325	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B Ø	0.0	
220326	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C Ø	0.0	
220327	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
220328	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
220329	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
220330	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
220331	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
220332	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
220333	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	
220334	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
220335	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments		
220336	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	4	
220337	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	185	
220338	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	185	
220339	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations This Read Vac	4	
220340	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	0	
220341	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
220342	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
220343	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	0	
220344	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations This Read Vac	4	
220345	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	General Comments		
220346	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Maintenance Operations	4	
220347	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	215	
220348	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	215	
220349	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations This Read Vac	4	
220350	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	0	
220351	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220352	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
220353	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
220354	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
220355	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
220356	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
220357	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
220358	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
220359	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
220360	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
220361	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	Blown lightning arrester 522	
220362	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
220363	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
220364	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
220365	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
220366	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
220367	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
220368	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
220369	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
220370	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
220371	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
220372	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
220373	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
220374	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	0	
220375	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
220376	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
220377	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
220378	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	0.0	
220379	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	0.0	
220380	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	0.0	
220381	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220382	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220383	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220384	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
220385	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
220386	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
220387	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
220388	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
220389	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments		
220390	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
220391	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	197	
220392	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	197	
220393	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations This Read Vac	0	
220394	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	0	
220395	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
220396	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
220397	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
220398	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
220399	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
220400	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	BCH000216	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
220401	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	4	
220402	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
220403	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	3	
220404	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
220405	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
220406	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
220407	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	264.0	
220408	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	254.0	
220409	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	252.0	
220410	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
220411	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
220412	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
220413	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
220414	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
220415	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
220416	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
220417	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
220418	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments		
220419	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	3	
220420	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	202	
220421	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	202	
220422	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations This Read Vac	3	
220423	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	0	
220424	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
220425	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
220426	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220427	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations This Read Vac	0	
220428	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	4	
220429	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	4	
220430	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
220431	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments		
220432	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
220433	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
220434	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
220435	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
220436	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
220437	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220438	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220439	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220440	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	0.0	
220441	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	0.0	
220442	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	0.0	
220443	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
220444	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
220445	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
220446	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	0	
220447	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	5	
220448	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
220449	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
220450	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
220451	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	379.0	
220452	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	374.0	
220453	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps C Ø	370.0	
220454	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
220455	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
220456	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
220457	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations A Ø	0	
220458	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations B Ø	0	
220459	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations C Ø	0	
220460	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations Ground	0	
220461	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Follow-up Action Required?	n	
220462	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
220463	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
220464	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
220465	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	2	
220466	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
220467	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
220468	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
220469	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	339	
220470	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
220471	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	4L	
220472	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	4R	
220473	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	1R	
220474	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
220475	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	786	
220476	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	786	
220477	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments	ok	
220478	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments	ok	
220479	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
220480	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
220481	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
220482	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments	ok	
220483	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
220484	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
220485	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
220486	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
220487	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
220488	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
220489	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
220490	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
220491	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
220492	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
220493	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
220494	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
220495	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
220496	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	4	
220497	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
220498	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
220499	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
220500	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	12.0	
220501	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	24.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220502	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	12.0	
220503	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
220504	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220505	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220506	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220507	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220508	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220509	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220510	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220511	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220512	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220513	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
220514	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
220515	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
220516	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
220517	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
220518	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
220519	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
220520	9/3/2019 11:55	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
220521	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
220522	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
220523	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	618.0	
220524	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	601.0	
220525	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	607.0	
220526	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0	
220527	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0	
220528	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0	
220529	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
220530	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
220531	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
220532	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
220533	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
220534	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments		
220535	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	4	
220536	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	199	
220537	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	199	
220538	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations This Read Vac	4	
220539	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	0	
220540	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
220541	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
220542	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
220543	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
220544	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
220545	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	2	
220546	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	111	
220547	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	111	
220548	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
220549	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
220550	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220551	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
220552	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments	Targets- A-51, N-51 reset	
220553	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments	ok	
220554	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
220555	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
220556	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
220557	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	1	
220558	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
220559	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
220560	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
220561	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	General Comments	ok	
220562	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
220563	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
220564	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
220565	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
220566	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
220567	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
220568	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
220569	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	1	
220570	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	1.15	
220571	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	1.15	
220572	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	2.31	
220573	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220574	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220575	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220576	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
220577	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220578	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220579	9/3/2019 11:03	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
220580	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
220581	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
220582	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
220583	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
220584	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
220585	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
220586	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
220587	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.5772	
220588	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
220589	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
220590	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
220591	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
220592	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
220593	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
220594	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
220595	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
220596	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
220597	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
220598	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	481.0	
220599	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	484.0	
220600	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	487.0	
220601	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
220602	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	5.15	%
220603	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
220604	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	5	
220605	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
220606	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
220607	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	General Comments	ok	
220608	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
220609	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
220610	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
220611	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
220612	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
220613	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	LTC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
220614	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	185	
220615	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	185	
220616	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
220617	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments		
220618	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
220619	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	
220620	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
220621	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
220622	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	4	
220623	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220624	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220625	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
220626	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
220627	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
220628	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
220629	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	6.01	%
220630	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
220631	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	6.01	%
220632	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	4	
220633	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
220634	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
220635	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
220636	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AF	213	
220637	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Maintenance Operations	4	
220638	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	General Comments		
220639	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Follow-up Action Required?	n	
220640	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
220641	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	0	
220642	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations This Read Vac	4	
220643	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
220644	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
220645	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
220646	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
220647	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
220648	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
220649	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
220650	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
220651	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220652	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
220653	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
220654	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments	ok	
220655	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments	ok	
220656	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
220657	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	5541.12	kw
220658	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
220659	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
220660	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	75	°C
220661	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	55	°C
220662	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
220663	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
220664	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
220665	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
220666	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	
220667	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
220668	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
220669	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
220670	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
220671	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
220672	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
220673	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
220674	9/3/2019 10:39	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
220675	9/3/2019 14:20	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
220676	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
220677	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
220678	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
220679	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
220680	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
220681	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
220682	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
220683	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	LTC0000818	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
220684	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	6	
220685	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
220686	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
220687	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
220688	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
220689	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220690	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
220691	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220692	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	10175	
220693	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
220694	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
220695	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
220696	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
220697	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
220698	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
220699	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
220700	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
220701	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
220702	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220703	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220704	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220705	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220706	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
220707	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
220708	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220709	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220710	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
220711	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
220712	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
220713	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
220714	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	244	
220715	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	248	
220716	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations This Read Vac	6	
220717	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
220718	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
220719	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
220720	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
220721	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
220722	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
220723	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
220724	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
220725	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
220726	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
220727	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
220728	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
220729	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
220730	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
220731	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
220732	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
220733	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
220734	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
220735	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
220736	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
220737	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
220738	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
220739	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
220740	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
220741	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
220742	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	19	
220743	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
220744	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
220745	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
220746	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220747	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
220748	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		
220749	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
220750	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
220751	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220752	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
220753	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
220754	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
220755	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
220756	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
220757	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
220758	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
220759	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
220760	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
220761	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
220762	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0575	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
220763	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
220764	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
220765	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
220766	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
220767	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
220768	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
220769	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
220770	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
220771	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
220772	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	97528	
220773	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
220774	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
220775	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220776	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220777	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220778	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220779	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220780	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
220781	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	140.0	
220782	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	140.0	
220783	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	140.0	
220784	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	2.49	%
220785	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	2.49	%
220786	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	2.99	%
220787	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	10	
220788	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
220789	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
220790	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
220791	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
220792	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220793	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220794	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220795	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220796	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220797	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
220798	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
220799	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
220800	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
220801	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.81	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220802	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.44	%
220803	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.81	%
220804	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0315	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
220805	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
220806	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
220807	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
220808	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
220809	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
220810	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
220811	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
220812	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
220813	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
220814	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
220815	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000393	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
220816	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	
220817	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
220818	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
220819	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
220820	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220821	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220822	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220823	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220824	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
220825	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220826	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
220827	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	1	
220828	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	0	
220829	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
220830	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
220831	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
220832	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
220833	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
220834	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
220835	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
220836	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
220837	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
220838	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
220839	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	325	
220840	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	325	
220841	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	1	
220842	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
220843	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	0	
220844	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
220845	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
220846	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
220847	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
220848	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
220849	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
220850	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0576	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
220851	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
220852	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
220853	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
220854	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
220855	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
220856	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
220857	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
220858	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
220859	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
220860	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
220861	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
220862	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
220863	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
220864	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
220865	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
220866	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
220867	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
220868	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?		
220869	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
220870	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3713.28	kw
220871	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
220872	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
220873	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
220874	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
220875	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
220876	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220877	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
220878	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
220879	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
220880	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
220881	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
220882	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
220883	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.1604	
220884	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
220885	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
220886	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
220887	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
220888	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	2934	
220889	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	2934	
220890	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
220891	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
220892	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
220893	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2L	
220894	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	243	
220895	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
220896	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
220897	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
220898	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
220899	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
220900	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
220901	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
220902	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	41416	
220903	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	41416	
220904	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
220905	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
220906	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
220907	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2L	
220908	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	371	
220909	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
220910	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
220911	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
220912	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
220913	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
220914	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	92.50	
220915	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6030	
220916	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
220917	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Top Oil Temperature Present	45	°C
220918	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Top Oil Temperature Max	60	°C
220919	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
220920	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
220921	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
220922	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
220923	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
220924	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
220925	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
220926	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
220927	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
220928	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
220929	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
220930	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
220931	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
220932	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
220933	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
220934	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
220935	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
220936	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
220937	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
220938	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
220939	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
220940	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	FE000338	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
220941	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
220942	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
220943	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
220944	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
220945	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
220946	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
220947	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
220948	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
220949	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
220950	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
220951	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
220952	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
220953	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
220954	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
220955	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	0	
220956	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	487	
220957	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	487	
220958	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
220959	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
220960	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
220961	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
220962	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
220963	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
220964	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
220965	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
220966	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
220967	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
220968	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	270.0	
220969	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	270.0	
220970	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	100.0	
220971	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
220972	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	9.61	%
220973	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
220974	6/26/2019 9:30	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	11	
220975	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
220976	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
220977	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
220978	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
220979	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
220980	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
220981	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
220982	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
220983	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
220984	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	
220985	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
220986	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
220987	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
220988	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
220989	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
220990	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
220991	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
220992	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
220993	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
220994	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
220995	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
220996	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
220997	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	
220998	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
220999	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
221000	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
221001	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
221002	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
221003	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221004	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
221005	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
221006	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	272	
221007	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	278	
221008	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations This Read Vac	6	
221009	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221010	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	6	
221011	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
221012	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
221013	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
221014	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
221015	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
221016	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
221017	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
221018	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
221019	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
221020	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
221021	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
221022	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
221023	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
221024	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
221025	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
221026	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221027	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
221028	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	R0574	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	1202	
221029	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	8	
221030	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221031	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221032	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221033	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	90.0	
221034	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	90.0	
221035	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	90.0	
221036	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
221037	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221038	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221039	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221040	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
221041	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
221042	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	5788.80	kw
221043	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
221044	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
221045	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
221046	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
221047	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
221048	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
221049	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
221050	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
221051	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
221052	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
221053	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
221054	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
221055	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
221056	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
221057	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
221058	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
221059	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
221060	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	B0401	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
221061	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
221062	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
221063	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
221064	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
221065	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
221066	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
221067	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
221068	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
221069	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
221070	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
221071	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
221072	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
221073	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
221074	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
221075	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
221076	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
221077	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
221078	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
221079	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	General Comments		
221080	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
221081	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
221082	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
221083	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
221084	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	LTC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
221085	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
221086	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
221087	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
221088	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
221089	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
221090	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
221091	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	10	
221092	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	1.99	%
221093	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	1.5	%
221094	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	1.5	%
221095	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	120.0	
221096	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	120.0	
221097	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	120.0	
221098	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
221099	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	173	
221100	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	178	
221101	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
221102	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221103	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
221104	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
221105	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	268	
221106	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	268	
221107	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	3	
221108	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221109	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	0	
221110	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
221111	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
221112	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
221113	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
221114	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
221115	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
221116	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
221117	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
221118	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
221119	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
221120	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Winding Temp Present	35	°C
221121	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Winding Temp Max	60	°C
221122	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Reading	1.1250	
221123	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
221124	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
221125	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
221126	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
221127	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
221128	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
221129	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
221130	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
221131	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
221132	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
221133	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
221134	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
221135	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	115	
221136	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	115	
221137	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
221138	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
221139	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
221140	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
221141	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
221142	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
221143	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	232145	
221144	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	232145	
221145	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
221146	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
221147	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
221148	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	62	
221149	6/26/2019 9:30	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
221150	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	17	
221151	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
221152	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
221153	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
221154	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
221155	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
221156	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221157	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
221158	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	5.69	%
221159	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	8.94	%
221160	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
221161	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
221162	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
221163	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
221164	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
221165	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
221166	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
221167	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
221168	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	1	
221169	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	1	
221170	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	1	
221171	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
221172	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
221173	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
221174	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221175	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221176	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221177	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221178	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221179	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221180	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
221181	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	200.0	
221182	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	200.0	
221183	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	200.0	
221184	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221185	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
221186	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221187	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221188	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221189	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221190	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221191	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221192	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221193	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221194	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221195	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
221196	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
221197	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
221198	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
221199	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
221200	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
221201	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
221202	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
221203	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
221204	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
221205	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221206	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221207	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221208	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	5	
221209	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0314	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
221210	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	if low,note cell #'s
221211	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
221212	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
221213	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
221214	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
221215	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
221216	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
221217	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
221218	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
221219	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
221220	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
221221	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
221222	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
221223	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
221224	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221225	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221226	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
221227	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
221228	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
221229	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
221230	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
221231	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
221232	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	General Comments		
221233	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
221234	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	LTC Totalizer Reading	10800.00	kw
221235	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
221236	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
221237	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	General Comments		
221238	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
221239	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
221240	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
221241	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
221242	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Max	60	*C
221243	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
221244	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
221245	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
221246	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	84	*F
221247	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
221248	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Present	35	*C
221249	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
221250	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
221251	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221252	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
221253	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	150.0	
221254	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
221255	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
221256	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
221257	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
221258	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	BB0193	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
221259	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
221260	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
221261	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
221262	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Follow-up Action Required?	n	
221263	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
221264	8/30/2019 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
221265	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
221266	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
221267	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
221268	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
221269	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
221270	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
221271	8/30/2019 8:05	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
221272	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
221273	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
221274	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
221275	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
221276	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
221277	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	259	
221278	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	4	
221279	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221280	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
221281	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
221282	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	4	
221283	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
221284	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
221285	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
221286	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
221287	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
221288	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
221289	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
221290	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
221291	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	n	
221292	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments	Spare Bkr.	
221293	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
221294	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
221295	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
221296	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.1212	
221297	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
221298	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
221299	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
221300	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
221301	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
221302	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
221303	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
221304	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
221305	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
221306	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
221307	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	6	
221308	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221309	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221310	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221311	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	170.0	
221312	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	170.0	
221313	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	180.0	
221314	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
221315	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221316	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221317	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221318	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221319	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221320	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations This Read Vac	2	
221321	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AL	183	
221322	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AF	183	
221323	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221324	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221325	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
221326	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221327	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1527	
221328	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Moisture and Leak Free?	y	
221329	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Maintenance Operations	0	
221330	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221331	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1527	
221332	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Grounds in Place?	y	
221333	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	General Comments		
221334	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
221335	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
221336	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221337	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221338	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221339	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
221340	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	General Comments		
221341	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Foundation Condition	Good	
221342	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Follow-up Action Required?	n	
221343	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
221344	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
221345	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
221346	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
221347	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
221348	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
221349	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
221350	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
221351	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
221352	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
221353	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
221354	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	General Comments	ok	
221355	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
221356	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
221357	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
221358	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
221359	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221360	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
221361	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
221362	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
221363	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
221364	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
221365	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
221366	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
221367	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
221368	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	15	
221369	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
221370	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	1L	
221371	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	2R	
221372	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
221373	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
221374	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	3913	
221375	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	3906	
221376	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
221377	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
221378	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
221379	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
221380	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	255	
221381	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
221382	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments	.	
221383	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
221384	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221385	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221386	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221387	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments	.	
221388	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
221389	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221390	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221391	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	13	
221392	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
221393	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
221394	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
221395	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
221396	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221397	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221398	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221399	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
221400	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
221401	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
221402	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
221403	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
221404	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
221405	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
221406	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221407	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
221408	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
221409	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
221410	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
221411	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
221412	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2556	
221413	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
221414	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
221415	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
221416	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
221417	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
221418	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
221419	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221420	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
221421	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
221422	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
221423	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
221424	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
221425	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
221426	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
221427	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221428	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221429	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
221430	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
221431	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
221432	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
221433	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
221434	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
221435	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
221436	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
221437	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
221438	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
221439	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments		
221440	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	5	
221441	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221442	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2556	
221443	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
221444	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
221445	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221446	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221447	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	75.0	
221448	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	60.0	
221449	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	45.0	
221450	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
221451	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
221452	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
221453	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
221454	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
221455	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
221456	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
221457	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
221458	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	106568	
221459	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
221460	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
221461	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
221462	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BA010	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
221463	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
221464	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
221465	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
221466	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
221467	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
221468	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
221469	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
221470	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
221471	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	General Comments		
221472	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
221473	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	LTC0000027	LTCControl	415-1	LTC Control Insp	All Connections OK?	y	
221474	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
221475	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
221476	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
221477	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
221478	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
221479	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
221480	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
221481	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
221482	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
221483	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
221484	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
221485	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
221486	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
221487	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
221488	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
221489	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
221490	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments		
221491	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
221492	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
221493	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
221494	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
221495	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
221496	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
221497	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
221498	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
221499	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
221500	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	351	
221501	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	351	
221502	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221503	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221504	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
221505	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
221506	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
221507	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
221508	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
221509	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
221510	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
221511	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	General Comments	OK	
221512	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221513	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221514	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221515	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
221516	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
221517	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221518	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221519	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	12.55	
221520	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	12.55	
221521	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221522	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	1	
221523	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	1	
221524	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
221525	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
221526	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
221527	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
221528	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221529	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221530	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221531	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments	.	
221532	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
221533	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
221534	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
221535	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
221536	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
221537	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
221538	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
221539	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
221540	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
221541	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
221542	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
221543	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221544	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	410.0	
221545	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	415.0	
221546	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
221547	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
221548	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	n	
221549	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
221550	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
221551	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221552	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
221553	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
221554	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
221555	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
221556	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	7674	
221557	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	7674	
221558	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
221559	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
221560	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
221561	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
221562	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1183	
221563	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
221564	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
221565	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
221566	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	410.0	
221567	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
221568	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221569	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221570	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221571	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221572	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221573	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221574	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221575	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221576	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221577	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
221578	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
221579	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
221580	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
221581	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
221582	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
221583	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
221584	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
221585	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
221586	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
221587	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
221588	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221589	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221590	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
221591	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
221592	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
221593	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
221594	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221595	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221596	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221597	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221598	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221599	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221600	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221601	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221602	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221603	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
221604	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	
221605	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
221606	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
221607	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
221608	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
221609	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
221610	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		
221611	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments	open	
221612	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
221613	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	0	
221614	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
221615	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	206	
221616	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	208	
221617	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations This Read Vac	2	
221618	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	2	
221619	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
221620	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
221621	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
221622	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
221623	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
221624	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
221625	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
221626	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
221627	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
221628	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
221629	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
221630	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
221631	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221632	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
221633	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221634	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
221635	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
221636	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
221637	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
221638	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
221639	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	General Comments		
221640	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
221641	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
221642	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
221643	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	193	
221644	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	very little load	
221645	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
221646	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
221647	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
221648	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
221649	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Fault Operations Ground	0	
221650	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
221651	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
221652	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
221653	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
221654	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
221655	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
221656	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
221657	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
221658	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
221659	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	*C
221660	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	*C
221661	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
221662	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
221663	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE00499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
221664	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
221665	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221666	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221667	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221668	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221669	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221670	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221671	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221672	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221673	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
221674	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
221675	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
221676	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
221677	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
221678	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221679	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
221680	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	134	
221681	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
221682	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
221683	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221684	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
221685	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
221686	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
221687	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
221688	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
221689	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
221690	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
221691	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
221692	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
221693	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BC000549	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
221694	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
221695	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments	no trash	
221696	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
221697	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
221698	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
221699	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
221700	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
221701	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	None	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221702	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
221703	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
221704	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
221705	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
221706	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
221707	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
221708	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
221709	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
221710	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
221711	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
221712	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
221713	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
221714	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BCH000549	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
221715	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
221716	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
221717	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
221718	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
221719	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
221720	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	132	
221721	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
221722	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
221723	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
221724	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Fault Operations	0	
221725	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
221726	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
221727	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
221728	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
221729	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
221730	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
221731	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
221732	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	
221733	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
221734	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	Need size info and qty
221735	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
221736	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
221737	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
221738	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
221739	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
221740	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments		
221741	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
221742	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
221743	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
221744	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
221745	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
221746	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
221747	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
221748	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
221749	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
221750	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
221751	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
221752	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
221753	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221754	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
221755	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
221756	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Ambient Temperature	75	°F
221757	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
221758	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
221759	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
221760	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
221761	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
221762	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
221763	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
221764	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
221765	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
221766	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
221767	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
221768	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
221769	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
221770	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221771	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
221772	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
221773	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221774	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
221775	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
221776	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221777	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
221778	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	200.0	
221779	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
221780	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	53	%
221781	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	50	°C
221782	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	50	°C
221783	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
221784	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
221785	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	1163.52	kw
221786	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
221787	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
221788	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
221789	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
221790	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
221791	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Tank Paint Condition	Good	
221792	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Switching Operations	0	
221793	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
221794	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 3	80	psi
221795	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 2	80	psi
221796	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 1	80	psi
221797	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
221798	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations This Read SF6	0	
221799	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AL	17	
221800	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AF	17	
221801	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	1	
221802	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
221803	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
221804	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Maintenance Operations	0	
221805	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Hydraulic Pump Start Counter	43	starts
221806	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Hydraulic Pump Start Cnt Delta	0	
221807	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Grounds in Place?	y	
221808	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
221809	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	General Comments		
221810	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
221811	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Foundation Condition	Good	
221812	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Follow-up Action Required?	n	
221813	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
221814	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
221815	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
221816	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
221817	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
221818	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
221819	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4495	
221820	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4495	
221821	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	0	
221822	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
221823	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
221824	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
221825	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
221826	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
221827	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	16.86	%
221828	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
221829	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
221830	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
221831	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
221832	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
221833	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
221834	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
221835	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
221836	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
221837	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
221838	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
221839	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
221840	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
221841	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
221842	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
221843	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
221844	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
221845	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
221846	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
221847	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
221848	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
221849	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
221850	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
221851	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
221852	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
221853	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
221854	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
221855	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
221856	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	213	
221857	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
221858	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
221859	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
221860	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	1257.60	kw
221861	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
221862	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
221863	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	60	°C
221864	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	45	°C
221865	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
221866	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
221867	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
221868	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
221869	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
221870	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
221871	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
221872	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
221873	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.2620	
221874	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
221875	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
221876	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
221877	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	y	
221878	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
221879	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
221880	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
221881	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
221882	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
221883	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
221884	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
221885	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
221886	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
221887	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
221888	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
221889	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
221890	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
221891	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
221892	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
221893	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
221894	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
221895	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
221896	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
221897	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
221898	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
221899	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
221900	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
221901	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
221902	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
221903	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
221904	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	916	
221905	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	916	
221906	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
221907	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221908	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
221909	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
221910	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
221911	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
221912	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
221913	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
221914	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
221915	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
221916	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
221917	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
221918	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
221919	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
221920	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
221921	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
221922	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
221923	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
221924	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
221925	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221926	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

	A	B	C	D	E	F	G	H	I	J
1	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
221927	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
221928	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
221929	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
221930	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
221931	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
221932	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
221933	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
221934	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
221935	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	3.02	%
221936	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
221937	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	794	
221938	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
221939	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
221940	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
221941	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
221942	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	3.02	%
221943	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
221944	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
221945	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
221946	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
221947	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
221948	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	30.0	
221949	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	70.0	
221950	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	40.0	
221951	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	50.0	
221952	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
221953	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
221954	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
221955	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
221956	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
221957	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	80.0	
221958	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	30.0	
221959	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
221960	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
221961	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
221962	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
221963	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
221964	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	
221965	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221966	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221967	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
221968	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments	.	
221969	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Heaters (All) Functioning?	y	
221970	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
221971	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
221972	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
221973	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
221974	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
221975	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
221976	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	265	
221977	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	265	
221978	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	3	
221979	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	3	
221980	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
221981	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
221982	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	12	
221983	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	3.02	%
221984	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	210.0	
221985	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	220.0	
221986	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
221987	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
221988	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
221989	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
221990	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
221991	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
221992	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
221993	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
221994	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
221995	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
221996	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
221997	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
221998	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
221999	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
222000	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222001	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
222002	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
222003	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
222004	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
222005	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
222006	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
222007	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
222008	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
222009	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		
222010	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
222011	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
222012	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222013	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
222014	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
222015	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	179	
222016	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	179	
222017	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations This Read Vac	0	
222018	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
222019	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222020	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	18	
222021	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222022	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
222023	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments	.	
222024	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
222025	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
222026	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
222027	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
222028	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
222029	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
222030	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	0	
222031	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222032	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222033	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
222034	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
222035	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
222036	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
222037	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
222038	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
222039	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222040	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222041	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222042	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	9	
222043	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
222044	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
222045	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
222046	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
222047	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
222048	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
222049	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
222050	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
222051	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
222052	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
222053	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
222054	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
222055	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
222056	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
222057	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
222058	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
222059	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
222060	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
222061	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
222062	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222063	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222064	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
222065	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
222066	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
222067	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
222068	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
222069	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	
222070	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42975	volts
222071	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
222072	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
222073	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
222074	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
222075	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
222076	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222077	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
222078	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
222079	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
222080	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
222081	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
222082	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
222083	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1306.08	kw
222084	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
222085	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
222086	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	61	*C
222087	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	46	*C
222088	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
222089	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
222090	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
222091	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
222092	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
222093	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
222094	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
222095	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
222096	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5442	
222097	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	150.0	
222098	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222099	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222100	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222101	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	13	
222102	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
222103	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
222104	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
222105	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
222106	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
222107	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
222108	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
222109	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
222110	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
222111	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
222112	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
222113	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222114	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222115	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222116	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	160.0	
222117	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
222118	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
222119	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
222120	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
222121	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
222122	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
222123	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
222124	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	110.0	
222125	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	250.0	
222126	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	119.0	
222127	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	270.0	
222128	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	100.0	
222129	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222130	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222131	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222132	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
222133	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
222134	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
222135	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
222136	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
222137	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
222138	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
222139	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
222140	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
222141	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
222142	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	22	
222143	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
222144	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
222145	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
222146	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222147	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222148	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
222149	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
222150	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
222151	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222152	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
222153	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
222154	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
222155	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
222156	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
222157	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments	major drainage issues in sub	
222158	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222159	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222160	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
222161	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments	.	
222162	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222163	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222164	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222165	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
222166	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments	.	
222167	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
222168	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
222169	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
222170	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
222171	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
222172	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
222173	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
222174	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
222175	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
222176	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
222177	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
222178	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
222179	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
222180	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222181	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
222182	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
222183	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
222184	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
222185	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
222186	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
222187	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
222188	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
222189	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
222190	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
222191	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
222192	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
222193	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
222194	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
222195	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
222196	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
222197	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
222198	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
222199	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
222200	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
222201	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
222202	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
222203	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
222204	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
222205	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
222206	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
222207	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
222208	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	250.0	
222209	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	150.0	
222210	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	250.0	
222211	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	150.0	
222212	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	250.0	
222213	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222214	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
222215	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
222216	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
222217	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
222218	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
222219	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
222220	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
222221	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
222222	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
222223	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
222224	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
222225	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
222226	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
222227	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222228	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
222229	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
222230	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
222231	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
222232	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
222233	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
222234	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
222235	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
222236	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
222237	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
222238	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
222239	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
222240	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
222241	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
222242	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
222243	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
222244	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
222245	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
222246	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
222247	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
222248	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
222249	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	108062	
222250	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
222251	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
222252	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
222253	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
222254	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
222255	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
222256	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
222257	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
222258	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
222259	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
222260	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations B Ø	0	
222261	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations C Ø	0	
222262	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations Ground	0	
222263	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Follow-up Action Required?	n	
222264	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Follow-up Action Required?	n	
222265	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Foundation Condition	Good	
222266	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	General Comments		
222267	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	General Comments		
222268	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
222269	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
222270	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
222271	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
222272	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
222273	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
222274	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222275	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
222276	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
222277	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments		
222278	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
222279	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
222280	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
222281	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
222282	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
222283	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
222284	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
222285	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
222286	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
222287	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
222288	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
222289	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
222290	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	89.0	
222291	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	112.0	
222292	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	81.0	
222293	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
222294	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
222295	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
222296	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	7	
222297	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
222298	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	2	
222299	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
222300	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	0	
222301	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222302	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations This Read Vac	0	
222303	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	178	
222304	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	178	
222305	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Moisture and Leak Free?	y	
222306	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Maintenance Operations	0	
222307	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222308	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Grounds in Place?	y	
222309	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Switching Operations	0	
222310	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Tank Paint Condition	Good	
222311	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Unknown Operations	0	
222312	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations	4	
222313	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
222314	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
222315	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
222316	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps A Ø	190.0	
222317	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
222318	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
222319	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
222320	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
222321	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps B Ø	145.0	
222322	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps C Ø	168.0	
222323	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushing Condition	Good	
222324	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
222325	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
222326	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
222327	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
222328	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
222329	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
222330	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
222331	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
222332	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
222333	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
222334	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
222335	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
222336	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
222337	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
222338	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
222339	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
222340	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
222341	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
222342	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222343	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
222344	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222345	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222346	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222347	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222348	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations A Ø	0	
222349	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
222350	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
222351	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	159	
222352	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
222353	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
222354	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222355	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
222356	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
222357	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
222358	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
222359	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
222360	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
222361	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
222362	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
222363	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
222364	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
222365	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
222366	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	8.38	
222367	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	8.38	
222368	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222369	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
222370	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
222371	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
222372	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
222373	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	If no, which cells in comments VDC
222374	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
222375	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
222376	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTC0000820	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222377	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
222378	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
222379	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
222380	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
222381	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	LTCC000820	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
222382	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
222383	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
222384	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
222385	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BAT000523	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
222386	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
222387	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
222388	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
222389	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
222390	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
222391	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	214	
222392	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	206	
222393	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations This Read Vac	2	
222394	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	2	
222395	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
222396	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
222397	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
222398	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
222399	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
222400	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
222401	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
222402	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
222403	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
222404	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
222405	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
222406	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
222407	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	0	
222408	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	256	
222409	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	256	
222410	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
222411	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
222412	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
222413	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
222414	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
222415	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
222416	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
222417	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
222418	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
222419	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
222420	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments	no ltc nitrogen	
222421	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	477937	
222422	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	477944	
222423	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
222424	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	5L	
222425	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
222426	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	5L	
222427	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
222428	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
222429	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	
222430	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	260.0	
222431	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
222432	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
222433	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
222434	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
222435	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	General Comments	OK	
222436	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
222437	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	General Comments	OK	
222438	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
222439	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
222440	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
222441	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
222442	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
222443	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
222444	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
222445	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
222446	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	317	
222447	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
222448	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
222449	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
222450	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
222451	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222452	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
222453	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
222454	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
222455	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
222456	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
222457	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	6	
222458	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222459	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222460	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222461	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	0.0	
222462	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	0.0	
222463	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	0.0	
222464	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	0.0	
222465	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	0.0	
222466	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	0.0	
222467	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222468	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222469	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222470	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222471	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	50.0	
222472	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
222473	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53195	
222474	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
222475	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
222476	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
222477	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	190.0	
222478	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
222479	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	50.0	
222480	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	150.0	
222481	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	60.0	
222482	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222483	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222484	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222485	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	11	
222486	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
222487	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222488	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
222489	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
222490	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
222491	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
222492	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
222493	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
222494	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
222495	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
222496	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
222497	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
222498	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
222499	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
222500	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
222501	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
222502	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
222503	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
222504	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
222505	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222506	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
222507	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
222508	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
222509	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
222510	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
222511	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	y	
222512	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
222513	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
222514	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	1	
222515	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
222516	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
222517	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
222518	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
222519	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
222520	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	
222521	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
222522	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
222523	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
222524	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
222525	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
222526	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222527	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222528	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222529	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222530	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222531	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11582	
222532	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11582	
222533	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
222534	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
222535	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
222536	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
222537	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
222538	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC
222539	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
222540	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	LTC0000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
222541	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
222542	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
222543	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
222544	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
222545	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
222546	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
222547	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
222548	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222549	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222550	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222551	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222552	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	160.0	
222553	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
222554	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
222555	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
222556	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
222557	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
222558	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
222559	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
222560	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
222561	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
222562	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	0	
222563	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	0	
222564	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222565	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222566	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222567	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	390.0	
222568	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	380.0	
222569	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	420.0	
222570	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
222571	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	20.73	%
222572	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
222573	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	16	
222574	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	0	
222575	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	0	
222576	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	0	
222577	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	194	
222578	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	194	
222579	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
222580	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments		
222581	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
222582	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
222583	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
222584	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
222585	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
222586	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222587	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222588	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222589	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	360.0	
222590	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	400.0	
222591	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	480.0	
222592	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	15.15	%
222593	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	19.93	%
222594	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
222595	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	8	
222596	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Leaks	None	
222597	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
222598	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4430	
222599	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
222600	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
222601	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222602	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
222603	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
222604	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
222605	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
222606	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
222607	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
222608	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
222609	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
222610	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
222611	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
222612	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
222613	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
222614	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
222615	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	20.48	%
222616	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	30.11	%
222617	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	24.09	%
222618	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	370.0	
222619	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	400.0	
222620	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	420.0	
222621	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222622	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222623	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
222624	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
222625	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
222626	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	1	
222627	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
222628	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
222629	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	C phase IOC	
222630	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
222631	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	495	
222632	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	495	
222633	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
222634	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
222635	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
222636	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222637	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222638	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
222639	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
222640	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
222641	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
222642	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
222643	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	0	
222644	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
222645	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
222646	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
222647	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
222648	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
222649	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
222650	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
222651	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
222652	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
222653	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	952.0	
222654	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	932.0	
222655	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
222656	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	2.01	%
222657	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
222658	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
222659	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
222660	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	51	
222661	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	51	
222662	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
222663	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
222664	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
222665	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
222666	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
222667	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
222668	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
222669	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222670	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222671	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222672	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	280.0	
222673	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	260.0	
222674	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	340.0	
222675	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
222676	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222677	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
222678	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	0	
222679	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
222680	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
222681	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
222682	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
222683	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
222684	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
222685	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
222686	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
222687	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
222688	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
222689	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
222690	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222691	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222692	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222693	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
222694	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
222695	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
222696	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
222697	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
222698	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
222699	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222700	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222701	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222702	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222703	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
222704	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
222705	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
222706	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
222707	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments		
222708	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
222709	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
222710	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
222711	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
222712	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
222713	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
222714	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
222715	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
222716	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
222717	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
222718	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
222719	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	842	
222720	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	*C
222721	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
222722	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
222723	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
222724	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	4R	
222725	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	1R	
222726	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
222727	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	29561	
222728	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	29561	
222729	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
222730	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
222731	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
222732	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
222733	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
222734	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
222735	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
222736	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	19.93	%
222737	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	36	
222738	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
222739	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
222740	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
222741	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	103	
222742	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	103	
222743	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
222744	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
222745	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
222746	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
222747	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
222748	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
222749	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
222750	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222751	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222752	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222753	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	964.0	
222754	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
222755	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
222756	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
222757	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	271	
222758	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
222759	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
222760	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
222761	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
222762	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
222763	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
222764	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	BreakerSF6	y	
222765	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
222766	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
222767	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
222768	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
222769	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
222770	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
222771	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
222772	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
222773	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
222774	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
222775	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
222776	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
222777	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
222778	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	9R	
222779	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	4R	
222780	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
222781	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	9448	
222782	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	9440	
222783	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
222784	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
222785	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
222786	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
222787	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
222788	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4984	
222789	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4984	
222790	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
222791	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
222792	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
222793	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
222794	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
222795	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
222796	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
222797	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
222798	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
222799	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222800	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222801	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222802	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222803	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	350.0	
222804	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
222805	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
222806	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
222807	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
222808	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
222809	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
222810	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
222811	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
222812	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
222813	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
222814	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
222815	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
222816	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
222817	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	If no, which cells in comments
222818	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
222819	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
222820	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
222821	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
222822	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
222823	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
222824	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
222825	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
222826	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222827	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
222828	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
222829	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
222830	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
222831	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
222832	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
222833	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
222834	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
222835	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
222836	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
222837	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	84	*F
222838	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
222839	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
222840	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222841	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
222842	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
222843	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
222844	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
222845	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
222846	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
222847	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
222848	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
222849	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
222850	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
222851	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
222852	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
222853	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
222854	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
222855	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	350.0	
222856	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps Ø	370.0	
222857	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	240.0	
222858	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
222859	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
222860	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
222861	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	3	
222862	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
222863	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
222864	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	0	
222865	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	173	
222866	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	173	
222867	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
222868	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
222869	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
222870	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	20	
222871	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	3.33	%
222872	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	3.33	%
222873	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	3.33	%
222874	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
222875	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
222876	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
222877	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
222878	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
222879	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
222880	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
222881	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
222882	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
222883	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
222884	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
222885	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
222886	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
222887	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
222888	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
222889	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
222890	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
222891	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
222892	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
222893	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	397	
222894	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	397	
222895	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	0	
222896	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
222897	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
222898	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
222899	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
222900	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
222901	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222902	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
222903	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
222904	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
222905	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	100.0	
222906	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	290.0	
222907	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	80.0	
222908	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
222909	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
222910	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	120.0	
222911	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	80.0	
222912	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
222913	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
222914	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
222915	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	21	
222916	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	0	
222917	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	152	
222918	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	152	
222919	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
222920	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments		
222921	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
222922	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
222923	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
222924	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
222925	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
222926	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222927	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222928	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222929	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	250.0	
222930	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	280.0	
222931	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	280.0	
222932	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
222933	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
222934	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
222935	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	2	
222936	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
222937	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
222938	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	0	
222939	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	198	
222940	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	198	
222941	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
222942	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
222943	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
222944	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
222945	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
222946	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
222947	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
222948	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
222949	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
222950	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222951	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
222952	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
222953	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
222954	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
222955	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
222956	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
222957	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
222958	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
222959	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
222960	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	60	°C
222961	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
222962	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	60	°C
222963	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
222964	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
222965	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
222966	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
222967	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
222968	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
222969	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	General Comments		
222970	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
222971	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
222972	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	79	°F
222973	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	133.7	VDC
222974	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
222975	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
222976	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
222977	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
222978	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
222979	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
222980	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
222981	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
222982	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
222983	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
222984	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
222985	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
222986	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
222987	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
222988	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
222989	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
222990	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
222991	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
222992	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
222993	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
222994	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
222995	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
222996	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
222997	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
222998	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
222999	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
223000	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
223001	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
223002	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
223003	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
223004	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	General Comments		
223005	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.0	VDC
223006	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223007	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
223008	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
223009	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
223010	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
223011	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223012	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
223013	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	2	
223014	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	2	
223015	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1121	
223016	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	300.0	
223017	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	80.0	
223018	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1121	
223019	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
223020	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
223021	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
223022	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
223023	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
223024	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
223025	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
223026	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
223027	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
223028	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223029	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223030	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223031	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223032	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223033	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223034	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	5	
223035	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
223036	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
223037	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223038	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223039	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223040	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
223041	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223042	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BAT000513	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
223043	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	90.0	
223044	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	90.0	
223045	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	80.0	
223046	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	80.0	
223047	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	90.0	
223048	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	90.0	
223049	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223050	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223051	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223052	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	10	
223053	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223054	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
223055	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
223056	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223057	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
223058	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
223059	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
223060	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
223061	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	94168	
223062	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	94168	
223063	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
223064	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
223065	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
223066	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
223067	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
223068	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
223069	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
223070	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
223071	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
223072	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
223073	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
223074	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
223075	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
223076	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
223077	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
223078	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
223079	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
223080	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
223081	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
223082	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
223083	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
223084	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
223085	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
223086	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
223087	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
223088	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
223089	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
223090	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
223091	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
223092	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
223093	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
223094	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
223095	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
223096	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
223097	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
223098	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
223099	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
223100	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
223101	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
223102	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
223103	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
223104	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
223105	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
223106	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
223107	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	60	*C
223108	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	*C
223109	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	W/LTC Bushing Dynamic Health	0.00	
223110	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.0	VDC
223111	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
223112	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
223113	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	216	
223114	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
223115	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	*C
223116	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	*C
223117	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	65	*C
223118	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	85	*C
223119	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
223120	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
223121	8/14/2019 15:07	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223122	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
223123	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
223124	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223125	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223126	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223127	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
223128	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223129	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223130	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223131	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
223132	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	220	
223133	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	4	
223134	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
223135	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	4	
223136	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
223137	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
223138	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223139	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
223140	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
223141	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
223142	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
223143	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
223144	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
223145	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
223146	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
223147	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
223148	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
223149	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
223150	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
223151	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
223152	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
223153	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
223154	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
223155	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
223156	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2850	
223157	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
223158	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	29	
223159	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	834	
223160	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
223161	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
223162	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
223163	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
223164	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
223165	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
223166	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
223167	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
223168	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
223169	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
223170	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
223171	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
223172	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223173	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223174	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223175	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223176	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
223177	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
223178	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
223179	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
223180	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Follow-up Action Required?	n	
223181	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
223182	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
223183	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
223184	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
223185	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	788	
223186	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	788	
223187	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations This Read AM	2	
223188	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	2	
223189	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
223190	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
223191	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223192	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223193	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223194	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223195	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	50.0	
223196	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
223197	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
223198	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
223199	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
223200	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
223201	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	4L	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223202	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
223203	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
223204	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
223205	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
223206	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	50.0	
223207	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	50.0	
223208	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
223209	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
223210	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
223211	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
223212	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
223213	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
223214	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
223215	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
223216	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
223217	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	738	
223218	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	738	
223219	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations This Read AM	2	
223220	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	2	
223221	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
223222	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	10	
223223	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223224	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223225	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223226	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
223227	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
223228	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
223229	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	
223230	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	911	
223231	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	911	
223232	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
223233	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
223234	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
223235	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
223236	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
223237	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
223238	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
223239	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
223240	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
223241	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223242	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223243	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223244	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223245	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	150.0	
223246	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
223247	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
223248	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
223249	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	0	
223250	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	834	
223251	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	150.0	
223252	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	150.0	
223253	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	150.0	
223254	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	150.0	
223255	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	150.0	
223256	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.01	%
223257	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	1.01	%
223258	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	1.01	%
223259	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
223260	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
223261	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
223262	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
223263	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	
223264	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223265	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223266	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223267	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223268	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
223269	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
223270	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
223271	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
223272	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
223273	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
223274	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
223275	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
223276	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
223277	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1041	
223278	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1041	
223279	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	0	
223280	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
223281	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
223282	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
223283	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
223284	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	0	
223285	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	387	
223286	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	387	
223287	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
223288	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
223289	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
223290	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
223291	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
223292	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
223293	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
223294	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
223295	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
223296	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223297	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223298	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223299	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223300	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	270.0	
223301	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	50.0	
223302	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	260.0	
223303	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	30.0	
223304	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223305	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
223306	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
223307	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223308	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
223309	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	50.0	
223310	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	50.0	
223311	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	50.0	
223312	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223313	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223314	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223315	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	11	
223316	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
223317	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
223318	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
223319	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
223320	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
223321	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
223322	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
223323	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
223324	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
223325	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15230	
223326	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
223327	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Leaks	None	
223328	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
223329	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
223330	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223331	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223332	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223333	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
223334	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
223335	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223336	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
223337	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
223338	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223339	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		
223340	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
223341	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
223342	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
223343	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	151.20	kw
223344	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
223345	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
223346	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223347	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
223348	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223349	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223350	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
223351	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223352	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223353	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
223354	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.1890	
223355	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	194	
223356	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223357	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223358	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223359	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
223360	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations B Ø	0	
223361	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations C Ø	0	
223362	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations Ground	0	
223363	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
223364	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
223365	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
223366	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	411	
223367	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	411	
223368	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
223369	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
223370	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
223371	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
223372	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
223373	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
223374	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
223375	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
223376	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
223377	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
223378	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
223379	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
223380	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
223381	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
223382	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223383	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223384	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223385	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223386	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	290.0	
223387	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	115.0	
223388	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	140.0	
223389	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	68.0	
223390	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	240.0	
223391	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	100.0	
223392	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223393	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223394	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223395	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	11	
223396	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
223397	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
223398	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	50	°C
223399	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	60	°C
223400	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	1.0090	
223401	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
223402	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223403	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
223404	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
223405	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223406	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
223407	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
223408	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
223409	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
223410	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
223411	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
223412	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
223413	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
223414	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
223415	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223416	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223417	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223418	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223419	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	180.0	
223420	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	70.0	
223421	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	240.0	
223422	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	50.0	
223423	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	270.0	
223424	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	90.0	
223425	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223426	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223427	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223428	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	7	
223429	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
223430	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
223431	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
223432	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	51	°C
223433	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	35	°C
223434	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
223435	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Months Operations	11	
223436	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223437	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223438	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223439	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø	0.0	
223440	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø Max	0.0	
223441	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø	0.0	
223442	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø Max	0.0	
223443	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø	0.0	
223444	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø Max	0.0	
223445	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223446	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223447	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223448	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
223449	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223450	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223451	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations A Ø	0	
223452	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223453	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
223454	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
223455	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223456	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
223457	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223458	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223459	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
223460	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
223461	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223462	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3847.68	kw
223463	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
223464	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
223465	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	45	°C
223466	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	45	°C
223467	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223468	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
223469	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223470	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223471	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
223472	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
223473	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223474	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
223475	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.4008	
223476	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
223477	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
223478	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
223479	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
223480	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
223481	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
223482	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
223483	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223484	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223485	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223486	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
223487	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	270.0	
223488	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
223489	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	21.68	%
223490	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	56.61	%
223491	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	44.57	%
223492	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
223493	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223494	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223495	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
223496	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments	.	
223497	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223498	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223499	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
223500	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223501	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	45	°C

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223502	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	55	°C
223503	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
223504	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
223505	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
223506	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	10251.44	kw
223507	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223508	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
223509	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
223510	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
223511	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
223512	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	318	
223513	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	318	
223514	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
223515	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	307	
223516	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	307	
223517	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations This Read AM	0	
223518	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
223519	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
223520	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
223521	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223522	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223523	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
223524	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
223525	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223526	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
223527	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	.4370	
223528	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	52	°C
223529	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	36	°C
223530	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
223531	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
223532	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTC000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
223533	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTC000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
223534	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTC000797	LTCControl	461-1	LTC Control Insp	General Comments		
223535	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
223536	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223537	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
223538	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223539	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223540	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
223541	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
223542	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
223543	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
223544	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
223545	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
223546	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
223547	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
223548	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
223549	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
223550	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
223551	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
223552	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223553	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
223554	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
223555	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BCH000941	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
223556	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
223557	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223558	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223559	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
223560	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223561	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
223562	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
223563	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223564	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
223565	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
223566	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
223567	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
223568	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
223569	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
223570	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
223571	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
223572	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
223573	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
223574	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
223575	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
223576	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223577	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
223578	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
223579	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
223580	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
223581	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
223582	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
223583	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
223584	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
223585	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
223586	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
223587	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	11	
223588	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
223589	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
223590	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
223591	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
223592	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	4	
223593	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
223594	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	4	
223595	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1578	
223596	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1574	
223597	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
223598	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
223599	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223600	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
223601	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
223602	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
223603	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
223604	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
223605	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
223606	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
223607	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
223608	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
223609	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
223610	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
223611	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
223612	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
223613	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
223614	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
223615	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
223616	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
223617	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
223618	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
223619	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
223620	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
223621	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
223622	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
223623	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
223624	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
223625	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
223626	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
223627	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
223628	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
223629	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
223630	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
223631	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
223632	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
223633	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
223634	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
223635	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223636	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
223637	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
223638	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
223639	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
223640	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223641	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223642	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223643	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	260.0	
223644	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	260.0	
223645	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	260.0	
223646	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
223647	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	10.84	%
223648	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.84	%
223649	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
223650	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
223651	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
223652	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
223653	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223654	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
223655	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
223656	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
223657	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		
223658	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
223659	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
223660	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
223661	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
223662	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
223663	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
223664	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
223665	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
223666	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
223667	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
223668	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
223669	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
223670	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	0	
223671	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	0	
223672	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223673	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	
223674	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223675	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223676	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
223677	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
223678	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223679	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	10488.00	kw
223680	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	522	
223681	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	522	
223682	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
223683	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
223684	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
223685	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
223686	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
223687	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
223688	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
223689	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223690	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
223691	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223692	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223693	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
223694	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
223695	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
223696	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
223697	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
223698	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
223699	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	7	
223700	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
223701	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
223702	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
223703	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
223704	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
223705	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
223706	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
223707	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
223708	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
223709	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
223710	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
223711	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
223712	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
223713	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
223714	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
223715	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
223716	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
223717	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
223718	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
223719	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
223720	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
223721	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
223722	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
223723	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	71	
223724	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	71	
223725	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
223726	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223727	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
223728	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
223729	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	181	
223730	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
223731	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
223732	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
223733	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments		
223734	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
223735	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
223736	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
223737	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
223738	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
223739	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223740	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
223741	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
223742	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
223743	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
223744	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
223745	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
223746	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
223747	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
223748	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
223749	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
223750	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
223751	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
223752	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	4	
223753	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	334	
223754	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	334	
223755	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	0	
223756	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2019-02-14 00:00:00.000000	
223757	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
223758	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
223759	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
223760	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
223761	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
223762	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223763	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223764	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223765	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
223766	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
223767	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223768	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
223769	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223770	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
223771	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
223772	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
223773	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
223774	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
223775	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
223776	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
223777	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
223778	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
223779	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
223780	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
223781	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
223782	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
223783	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	0	
223784	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
223785	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
223786	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
223787	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
223788	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223789	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
223790	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
223791	8/29/2019 11:11	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	2.0	
223792	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223793	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
223794	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
223795	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
223796	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
223797	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
223798	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	905	
223799	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
223800	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
223801	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
	EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
223802	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
223803	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	11L	
223804	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	2L	
223805	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	5L	
223806	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
223807	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
223808	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
223809	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
223810	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
223811	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments		
223812	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
223813	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
223814	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
223815	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
223816	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	3384	
223817	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Found Counter	3384	
223818	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
223819	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
223820	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
223821	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
223822	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
223823	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
223824	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
223825	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
223826	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
223827	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
223828	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
223829	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
223830	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
223831	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
223832	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments		
223833	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
223834	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
223835	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
223836	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
223837	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
223838	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
223839	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
223840	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
223841	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		
223842	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
223843	8/29/2019 11:54	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Control Insp	LTC Operation Checked?	y	
223844	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
223845	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
223846	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
223847	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
223848	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
223849	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
223850	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
223851	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
223852	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
223853	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
223854	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	155	
223855	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
223856	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
223857	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.0	
223858	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	165	
223859	8/29/2019 8:55	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
223860	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.25	%
223861	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
223862	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
223863	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
223864	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
223865	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223866	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223867	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223868	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
223869	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
223870	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
223871	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
223872	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
223873	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
223874	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
223875	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	30	
223876	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223877	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
223878	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
223879	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
223880	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	30	
223881	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
223882	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
223883	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
223884	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
223885	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223886	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments	.	
223887	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
223888	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments	.	
223889	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223890	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223891	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223892	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
223893	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
223894	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223895	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223896	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223897	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments	.	
223898	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
223899	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
223900	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223901	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223902	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
223903	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments	.	
223904	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
223905	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
223906	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
223907	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
223908	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments	.	
223909	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
223910	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
223911	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
223912	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
223913	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
223914	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
223915	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
223916	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
223917	7/10/2019 14:42	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
223918	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments	.	
223919	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
223920	8/29/2019 14:19	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	6	
223921	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
223922	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
223923	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
223924	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
223925	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223926	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
223927	8/29/2019 13:19	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
223928	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223929	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
223930	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
223931	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223932	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223933	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
223934	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
223935	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223936	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
223937	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
223938	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
223939	8/29/2019 10:50	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
223940	8/29/2019 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
223941	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
223942	8/29/2019 12:13	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
223943	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
223944	7/2/2019 14:52	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	12.05	%
223945	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
223946	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
223947	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	269813	
223948	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
223949	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
223950	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
223951	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
223952	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	269813	
223953	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
223954	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
223955	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
223956	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
223957	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
223958	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
223959	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
223960	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
223961	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
223962	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223963	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
223964	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223965	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
223966	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
223967	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
223968	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
223969	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
223970	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223971	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223972	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
223973	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
223974	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
223975	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
223976	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
223977	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
223978	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	100.0	
223979	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	100.0	
223980	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
223981	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
223982	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
223983	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
223984	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
223985	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
223986	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223987	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223988	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223989	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
223990	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
223991	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
223992	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	3	
223993	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
223994	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
223995	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
223996	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
223997	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
223998	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
223999	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
224000	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
224001	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
224002	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
224003	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
224004	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
224005	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1538	
224006	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	10L	
224007	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	5R	
224008	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	4L	
224009	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
224010	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	73803	
224011	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	73803	
224012	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
224013	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
224014	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
224015	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
224016	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	100.0	
224017	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224018	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224019	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
224020	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
224021	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	902	
224022	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	902	
224023	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
224024	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
224025	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
224026	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224027	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
224028	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
224029	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
224030	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224031	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	4	
224032	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	0	
224033	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
224034	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations This Read AM	0	
224035	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	541	
224036	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	541	
224037	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	
224038	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments		
224039	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
224040	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
224041	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
224042	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
224043	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
224044	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
224045	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
224046	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
224047	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
224048	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		
224049	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments	DESICCANT IS BAD AND 0 NITRO IN BOTTLE	
224050	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	100.0	
224051	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
224052	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
224053	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
224054	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
224055	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
224056	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
224057	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
224058	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
224059	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
224060	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
224061	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	75	°C
224062	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	45	°C
224063	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
224064	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
224065	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
224066	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
224067	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
224068	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
224069	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
224070	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
224071	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
224072	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
224073	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
224074	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
224075	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1574	
224076	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
224077	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
224078	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4R	
224079	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	3L	
224080	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224081	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224082	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224083	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
224084	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
224085	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	430.0	
224086	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224087	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224088	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224089	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
224090	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	440.0	
224091	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	450.0	
224092	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224093	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224094	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
224095	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
224096	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
224097	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
224098	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LTCC000342	BreakerAirMagnetic	WT-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
224099	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
224100	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
224101	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	1	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224177	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	50	°C
224178	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	85	°C
224179	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	75	°C
224180	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	80	°C
224181	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
224182	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	35	
224183	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224184	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224185	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224186	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
224187	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
224188	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
224189	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	62	
224190	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	62	
224191	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
224192	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
224193	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	200.0	
224194	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	150.0	
224195	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	180.0	
224196	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224197	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224198	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224199	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
224200	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	0	
224201	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	0	
224202	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
224203	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
224204	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
224205	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
224206	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
224207	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
224208	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
224209	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
224210	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
224211	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
224212	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	45	°C
224213	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	75	°C
224214	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	1	
224215	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
224216	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
224217	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
224218	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224219	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	353	
224220	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
224221	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224222	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224223	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	50	°C
224224	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	75	°C
224225	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
224226	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	85	°C
224227	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	50	°C
224228	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	75	°C
224229	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
224230	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
224231	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
224232	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224233	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224234	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	200.0	
224235	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	220.0	
224236	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	150.0	
224237	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224238	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224239	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224240	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	8	
224241	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224242	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
224243	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
224244	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
224245	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
224246	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
224247	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
224248	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
224249	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
224250	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
224251	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	100.0	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224252	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	100.0	
224253	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	0	
224254	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	0	
224255	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	3	
224256	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	747	
224257	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	727	
224258	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
224259	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
224260	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
224261	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
224262	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
224263	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
224264	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
224265	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
224266	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
224267	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224268	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224269	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
224270	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
224271	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224272	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224273	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
224274	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
224275	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
224276	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
224277	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
224278	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
224279	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224280	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
224281	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224282	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
224283	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224284	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224285	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
224286	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224287	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
224288	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	150.0	
224289	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	150.0	
224290	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	150.0	
224291	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224292	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
224293	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
224294	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
224295	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	362	
224296	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	362	
224297	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
224298	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
224299	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
224300	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
224301	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
224302	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
224303	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
224304	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
224305	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
224306	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
224307	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
224308	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
224309	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
224310	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
224311	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
224312	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
224313	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
224314	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
224315	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
224316	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
224317	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
224318	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
224319	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
224320	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
224321	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224322	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	98	
224323	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
224324	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
224325	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
224326	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224327	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224328	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224329	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224330	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
224331	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
224332	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	150.0	
224333	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224334	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
224335	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99	
224336	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99	
224337	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
224338	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
224339	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
224340	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
224341	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
224342	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
224343	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
224344	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
224345	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
224346	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
224347	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
224348	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
224349	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
224350	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
224351	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
224352	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
224353	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
224354	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
224355	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
224356	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
224357	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
224358	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
224359	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
224360	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
224361	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
224362	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
224363	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
224364	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
224365	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
224366	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
224367	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
224368	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224369	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224370	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
224371	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224372	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	210.0	
224373	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	210.0	
224374	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	210.0	
224375	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
224376	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
224377	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	334	
224378	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	334	
224379	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
224380	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
224381	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
224382	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224383	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224384	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224385	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
224386	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
224387	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
224388	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
224389	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
224390	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
224391	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224392	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	861	
224393	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
224394	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
224395	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
224396	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
224397	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
224398	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	400.0	
224399	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	400.0	
224400	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	400.0	
224401	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224402	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
224403	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
224404	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	14	
224405	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	0	
224406	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	0	
224407	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	0	
224408	8/28/2019 13:11	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	861	
224409	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
224410	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
224411	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
224412	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
224413	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224414	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
224415	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
224416	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
224417	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
224418	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	37221	
224419	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
224420	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
224421	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
224422	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
224423	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
224424	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
224425	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
224426	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
224427	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	849	
224428	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	844	
224429	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224430	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	5	
224431	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224432	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224433	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
224434	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
224435	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224436	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224437	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
224438	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
224439	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
224440	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
224441	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	37724	
224442	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
224443	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224444	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224445	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224446	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
224447	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224448	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
224449	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
224450	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
224451	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
224452	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
224453	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
224454	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
224455	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
224456	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
224457	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
224458	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
224459	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
224460	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
224461	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
224462	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
224463	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
224464	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
224465	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
224466	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
224467	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
224468	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
224469	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
224470	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
224471	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
224472	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
224473	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
224474	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
224475	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
224476	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224477	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
224478	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
224479	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224480	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224481	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224482	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224483	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
224484	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
224485	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224486	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224487	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
224488	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
224489	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224490	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
224491	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
224492	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
224493	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224494	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224495	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224496	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224497	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224498	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224499	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224500	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224501	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224502	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224503	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224504	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
224505	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
224506	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	251	
224507	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	246	
224508	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224509	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	5	
224510	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224511	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224512	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224513	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
224514	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224515	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224516	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
224517	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
224518	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224519	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224520	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
224521	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
224522	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224523	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
224524	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
224525	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	1476	
224526	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
224527	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	9L	
224528	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
224529	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
224530	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224531	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224532	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
224533	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
224534	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
224535	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224536	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224537	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224538	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	44	
224539	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
224540	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
224541	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
224542	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
224543	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
224544	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
224545	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
224546	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
224547	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
224548	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	165	
224549	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224550	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	6	
224551	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224552	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224553	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224554	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
224555	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
224556	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
224557	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
224558	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224559	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224560	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224561	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224562	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224563	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224564	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224565	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224566	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224567	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224568	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224569	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224570	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224571	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224572	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224573	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224574	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224575	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224576	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224577	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224578	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224579	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224580	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224581	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0133	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
224582	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
224583	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
224584	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
224585	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
224586	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
224587	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
224588	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
224589	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
224590	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
224591	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
224592	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
224593	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
224594	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
224595	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
224596	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
224597	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
224598	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
224599	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
224600	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
224601	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
224602	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
224603	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
224604	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
224605	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
224606	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
224607	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
224608	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
224609	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
224610	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
224611	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
224612	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
224613	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
224614	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
224615	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	19	
224616	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	19	
224617	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224618	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
224619	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224620	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224621	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224622	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
224623	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224624	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	CB0132	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224625	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
224626	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224627	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
224628	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
224629	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
224630	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	BCH000329	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
224631	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224632	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224633	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224634	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224635	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224636	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
224637	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224638	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
224639	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
224640	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	150.0	
224641	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
224642	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
224643	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
224644	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	1R	
224645	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	3L	
224646	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
224647	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	269810	
224648	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	269805	
224649	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
224650	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
224651	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
224652	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
224653	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Bushing Condition	Good	
224654	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
224655	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
224656	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
224657	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
224658	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panels Dusted?	y	
224659	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
224660	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
224661	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	General Comments		
224662	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
224663	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
224664	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Swept?	y	
224665	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
224666	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224667	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224668	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224669	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
224670	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
224671	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Evidence of Insects	None	
224672	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
224673	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
224674	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
224675	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224676	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224677	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
224678	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
224679	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Broom on Site?	y	
224680	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
224681	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224682	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224683	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224684	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224685	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224686	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	158	
224687	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	158	
224688	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
224689	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
224690	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224691	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
224692	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
224693	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
224694	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
224695	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
224696	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
224697	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
224698	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
224699	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
224700	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
224701	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	134	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224702	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	134	
224703	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224704	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
224705	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224706	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
224707	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
224708	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
224709	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
224710	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
224711	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
224712	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
224713	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
224714	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
224715	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
224716	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
224717	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
224718	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
224719	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224720	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224721	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224722	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224723	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224724	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224725	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224726	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224727	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224728	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
224729	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
224730	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
224731	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	LTC0000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
224732	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Left Counter	219085	
224733	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
224734	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Current Tap Position	4L	
224735	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Max Tap Position	3R	
224736	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Min Tap Position	8L	
224737	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
224738	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
224739	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
224740	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Operations Since Last Insp	1695	
224741	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
224742	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
224743	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
224744	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
224745	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
224746	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
224747	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
224748	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	60	°C
224749	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	72	°C
224750	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
224751	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
224752	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	8505.60	kw
224753	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
224754	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
224755	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
224756	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
224757	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
224758	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
224759	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
224760	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
224761	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	38519	
224762	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
224763	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
224764	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
224765	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
224766	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
224767	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
224768	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None	
224769	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
224770	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224771	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224772	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
224773	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224774	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224775	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224776	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224777	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
224778	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
224779	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
224780	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
224781	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224782	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
224783	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224784	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224785	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224786	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
224787	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224788	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224789	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
224790	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224791	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
224792	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	120.0	
224793	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	180.0	
224794	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	120.0	
224795	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
224796	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	14	
224797	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224798	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
224799	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
224800	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
224801	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
224802	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
224803	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224804	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224805	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
224806	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
224807	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
224808	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
224809	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
224810	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
224811	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
224812	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
224813	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
224814	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
224815	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
224816	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
224817	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
224818	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
224819	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
224820	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
224821	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
224822	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224823	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224824	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224825	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
224826	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
224827	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
224828	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
224829	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
224830	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
224831	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
224832	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
224833	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
224834	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
224835	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
224836	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
224837	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
224838	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
224839	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
224840	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224841	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224842	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224843	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224844	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224845	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224846	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224847	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224848	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224849	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224850	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224851	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224852	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224853	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
224854	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224855	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	76	
224856	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
224857	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
224858	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
224859	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
224860	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
224861	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
224862	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
224863	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
224864	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
224865	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
224866	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
224867	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
224868	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
224869	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
224870	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
224871	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
224872	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
224873	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
224874	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
224875	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
224876	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
224877	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
224878	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
224879	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
224880	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
224881	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
224882	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
224883	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
224884	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	15	
224885	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
224886	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
224887	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
224888	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	120.0	
224889	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	107.0	
224890	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	120.0	
224891	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
224892	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224893	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224894	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
224895	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
224896	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99950	
224897	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224898	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224899	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
224900	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	
224901	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	
224902	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	
224903	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
224904	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
224905	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
224906	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224907	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224908	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224909	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224910	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224911	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224912	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0174	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224913	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224914	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224915	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224916	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
224917	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
224918	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
224919	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
224920	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
224921	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
224922	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
224923	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
224924	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	
224925	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
224926	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	BCH000387	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

1	A	B	C	D	E	F	G	H	I	J
EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
224927	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
224928	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
224929	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
224930	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
224931	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
224932	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
224933	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
224934	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
224935	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
224936	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
224937	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
224938	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
224939	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
224940	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
224941	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224942	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224943	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224944	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224945	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224946	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224947	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
224948	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
224949	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
224950	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
224951	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
224952	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
224953	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	28	
224954	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
224955	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
224956	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
224957	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
224958	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
224959	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
224960	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
224961	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
224962	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
224963	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	2	
224964	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
224965	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	330.0	
224966	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	330.0	
224967	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
224968	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
224969	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
224970	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
224971	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
224972	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0176	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
224973	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99950	
224974	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
224975	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
224976	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
224977	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
224978	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
224979	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
224980	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	CB0175	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
224981	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
224982	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
224983	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
224984	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
224985	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
224986	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
224987	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
224988	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
224989	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
224990	8/27/2019 11:26	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
224991	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
224992	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Follow-up Action Required?	n	
224993	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
224994	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	General Comments		
224995	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	General Comments		
224996	8/27/2019 14:45	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Found Counter	219080	
224997	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
224998	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.8860	
224999	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
225000	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
225001	8/27/2019 13:48	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	